

Mr. Tracy Purcell  
ANR Pipeline Company  
27725 Stansbury Boulevard  
Farmington Hills, MI 48334

Re: 145-15112-00011  
Review Request  
**T 145-6240-00011**

Dear Mr. Purcell:

ANR Pipeline Company was issued a Part 70 Operating permit on October 8, 1998, for a stationary pipeline compressor station. A letter requesting the addition of an emergency generator to provide back-up electrical power to the facility was received on November 30, 2001.

Pursuant to the provisions of 326 IAC 2-7-1 (xxii)(BB)(cc), the unit is considered an insignificant activity. The engine is rated at 814 horsepower and does not exceed the 16,000 horsepower rating for emergency generators. There is no specifically applicable requirement, therefore, it is not necessary to amend the Title V permit.

If you have any questions on this matter, please contact Janet Mobley, at (800) 451-6027, press 0 and ask for Janet Mobley or extension 2-8369, or dial (317) 232-8369.

Sincerely,

Paul Dubenetzky, Chief  
Permits Branch  
Office of Air Quality

PD/jm

cc: File - Shelby County  
Shelby County Health Department  
Air Compliance Section Inspector - D. J. Knotts  
Permit Review II - Janet Mobley

