



December 2, 2004

Ms. Karen Mehta
MCI
2400 North Glenville Drive
Richardson, Texas 75082

Certified Mail: 7000 0600 0023 5187 5309

Re: Response to Review Request No. 097-19699-00322 Permit status evaluation

Dear Ms. Mehta

MCI, located at 720 West Henry Street and 730 West Henry Street, Indianapolis, Indiana 46225, submitted a review request on September 21, 2004 to the Indianapolis Office of Environmental Services (OES), and Indiana Department of Environmental Management, Office of Air Quality (IDEM, OAQ). The request was submitted to determine if MCI requires an air pollution permit for two (2) emergency generators.

Emergency generators, fired by fuel oil #2, may comply with 326 IAC 2-9-13(b)(2)(A) by using less than 1,408.0 kgal of fuel oil #2 per year. Pursuant to 326 IAC 2-9-13(c), source specific operating agreements (SSOAs) are not required for emergency generators as long as the source elects to comply with 326 IAC 2-9-13(b)(2)(A). If a source elects to comply with 326 IAC 2-9-13(b)(2)(A), the source must be able to demonstrate compliance no later than thirty (30) days after receipt of a written request by OES, Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ), or Environmental Protection Agency (EPA).

Emergency generators, fired by fuel oil #2, may comply with 326 IAC 2-9-13(b)(2)(B) by using less than 2,253.0 kgal of fuel oil #2 per year. Pursuant to 326 IAC 2-9-13(d), source specific operating agreements (SSOAs) are required for emergency generators as long as the source elects to comply with 326 IAC 2-9-13(b)(2)(B). If a source elects to meet the limits established in 326 IAC 2-9-13(b)(2)(B), the source must comply with the requirements of 326 IAC 2-9-1.

If the source requires a definite decision to be made by the IDEM, OAQ and OES and an approval be issued, filing fees and any other permit fees shall be applicable according to the level of permit required. Questions should be directed to Angelique Oligier, OES, 2700 South Belmont Avenue, Indianapolis, Indiana 46221, or call (317) 327-2846.

Sincerely,

John B. Chavez
Administrator

aco

cc: OES Files - 2 copies
Compliance - Matt Mosier
USEPA - R5
Marion County Health Dept.
IDEM, Mindy Hahn

Department of Public Works
Office of Environmental Services
2700 South Belmont Avenue (317) 327-2234
Indianapolis, Indiana 46221 (fax) 327-2274
(TDD) 325-5186
www.indygov.org