



Mitchell E. Daniels, Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
(800) 451-6027
www.IN.gov/idem

TO: Interested Parties / Applicant
DATE: November 14, 2005
RE: Dragon/ESP Ltd. / 049-21673-00008
FROM: Paul Dubenetzky
Chief, Permits Branch
Office of Air Quality

Notice of Decision: Approval - Effective Immediately

Please be advised that on behalf of the Commissioner of the Department of Environmental Management, I have issued a decision regarding the enclosed matter. Pursuant to IC 13-15-5-3, this permit is effective immediately, unless a petition for stay of effectiveness is filed and granted according to IC 13-15-6-3, and may be revoked or modified in accordance with the provisions of IC 13-15-7-1.

If you wish to challenge this decision, IC 4-21.5-3 and IC 13-15-6-1 require that you file a petition for administrative review. This petition may include a request for stay of effectiveness and must be submitted to the Office of Environmental Adjudication, 100 North Senate Avenue, Government Center North, Room 1049, Indianapolis, IN 46204, **within eighteen (18) calendar days of the mailing of this notice**. The filing of a petition for administrative review is complete on the earliest of the following dates that apply to the filing:

- (1) the date the document is delivered to the Office of Environmental Adjudication (OEA);
- (2) the date of the postmark on the envelope containing the document, if the document is mailed to OEA by U.S. mail; or
- (3) The date on which the document is deposited with a private carrier, as shown by receipt issued by the carrier, if the document is sent to the OEA by private carrier.

The petition must include facts demonstrating that you are either the applicant, a person aggrieved or adversely affected by the decision or otherwise entitled to review by law. Please identify the permit, decision, or other order for which you seek review by permit number, name of the applicant, location, date of this notice and all of the following:

- (1) the name and address of the person making the request;
- (2) the interest of the person making the request;
- (3) identification of any persons represented by the person making the request;
- (4) the reasons, with particularity, for the request;
- (5) the issues, with particularity, proposed for considerations at any hearing; and
- (6) identification of the terms and conditions which, in the judgment of the person making the request, would be appropriate in the case in question to satisfy the requirements of the law governing documents of the type issued by the Commissioner.

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178. Callers from within Indiana may call toll-free at 1-800-451-6027, ext. 3-0178.

Enclosures
FNPER.dot 1/10/05



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We make Indiana a cleaner, healthier place to live.

Mitchell E. Daniels, Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
(800) 451-6027
www.in.gov/idem

Mr. Rob Girton
Dragon/Midwest – ESP Midwest, Ltd.
8857 E SR 14
Akron, IN 46910

November 14, 2005

Re: **049-21673-00008**
First Significant Revision to
FESOP 049-19280-00008

Dear Mr. Girton:

Dragon/Midwest – ESP Midwest, Ltd. was issued a Federally Enforceable State Operating Permit (FESOP) F 049-19280-00008 on September 1, 2004 for a metal fabricating source. A letter requesting changes to this permit was received on August 23, 2005. Pursuant to the provisions of 326 IAC 2-8-11.1 a Significant Permit Revision to this permit is hereby approved as described in the attached Technical Support Document.

The revision consists of the addition of insignificant welding and flame cutting stations. As a result of these additions, changes in the PM₁₀ and HAP limits are required to ensure that the source remains below Part 70 thresholds.

The following construction conditions are applicable to the proposed project:

1. General Construction Conditions
The data and information supplied with the application shall be considered part of this source modification approval. Prior to any proposed change in construction which may affect the potential to emit (PTE) of the proposed project, the change must be approved by the Office of Air Quality (OAQ).
2. This approval to construct does not relieve the permittee of the responsibility to comply with the provisions of the Indiana Environmental Management Law (IC 13-11 through 13-20; 13-22 through 13-25; and 13-30), the Air Pollution Control Law (IC 13-17) and the rules promulgated thereunder, as well as other applicable local, state, and federal requirements.
3. Effective Date of the Permit
Pursuant to IC 13-15-5-3, this approval becomes effective upon its issuance.
4. Pursuant to 326 IAC 2-1.1-9 (Revocation), the Commissioner may revoke this approval if construction is not commenced within eighteen (18) months after receipt of this approval or if construction is suspended for a continuous period of one (1) year or more.
5. All requirements and conditions of this construction approval shall remain in effect unless modified in a manner consistent with procedures established pursuant to 326 IAC 2.

Pursuant to 326 IAC 2-8-11.1, this permit shall be revised by incorporating the significant permit revision into the permit. All other conditions of the permit shall remain unchanged and in effect. For your convenience, the entire revised FESOP, with all revisions and amendments made to it, is being provided.

This decision is subject to the Indiana Administrative Orders and Procedures Act - IC 4-21.5-3-5. If you have any questions on this matter, please contact Craig J. Friederich, c/o OAQ, 100 North Senate Avenue, Indianapolis, Indiana, 46204, at 631-691-3395 or in Indiana at 1-800-451-6027 (ext 631-691-3395).

Sincerely,

Original signed by
Paul Dubenetzky, Chief
Permits Branch
Office of Air Quality

Attachments
CJF/MES

cc: File - Fulton County
U.S. EPA, Region V
FultonCounty Health Department
Northern Regional Office
Air Compliance Section Inspector – David North
Compliance Branch
Administrative and Development Section
Technical Support and Modeling - Michele Boner
John Kilmer – BCA Consultants, Inc.



Mitchell E. Daniels, Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204-2251-
2251
(317) 232-8603
(800) 451-6027
www.in.gov/idem

FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP) OFFICE OF AIR QUALITY

**Dragon/ESP-Midwest, Ltd.
8857 East State Road 14
Akron, Indiana 46910**

(herein known as the Permittee) is hereby authorized to operate subject to the conditions contained herein, the source described in Section A (Source Summary) of this permit.

The Permittee must comply with all conditions of this permit. Noncompliance with any provision of this permit is grounds for enforcement action; permit termination, revocation and reissuance, or modification; and denial of a permit renewal application. It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. An emergency does constitute an affirmative defense in an enforcement action provided the Permittee complies with the applicable requirements set forth in Section B, Emergency Provisions.

This permit is issued in accordance with 326 IAC 2 and 40 CFR Part 70 Appendix A and contains the conditions and provisions specified in 326 IAC 2-8 as required by 42 U.S.C. 7401, et. seq. (Clean Air Act as amended by the 1990 Clean Air Act Amendments), 40 CFR Part 70.6, IC 13-15 and IC 13-17.

Operation Permit No.: F 049-19280-00008	
Issued by: Paul Dubenetzky, Branch Chief Office of Air Quality	Issuance Date: September 1, 2004 Expiration Date: September 1, 2009

First Administrative Amendment AAF 049-20277-00008, issued February 22, 2005

First Significant Permit Revision: 049-21673-00008	Conditions Affected: A.3, B.23, D.1.6, Facility Description Box in D.2, and all Quarterly Report Forms
Issued by: Original signed by Paul Dubenetzky, Branch Chief Office of Air Quality	Issuance Date: November 14, 2005

TABLE OF CONTENTS

SECTION A	SOURCE SUMMARY	4
A.1	General Information [326 IAC 2-8-3(b)]	
A.2	Emission Units and Pollution Control Equipment Summary [326 IAC 2-8-3(c)(3)]	
A.3	Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-8-3(c)(3)(l)]	
A.4	FESOP Applicability [326 IAC 2-8-2]	
A.5	Prior Permits Superseded [326 IAC 2-1.1-9.5]	
SECTION B	GENERAL CONDITIONS	6
B.1	Permit No Defense [IC 13]	
B.2	Definitions [326 IAC 2-8-1]	
B.3	Permit Term [326 IAC 2-8-4(2)] [326 IAC 2-1.1-9.5]	
B.4	Enforceability [326 IAC 2-8-6]	
B.5	Termination of Right to Operate [326 IAC 2-8-9] [326 IAC 2-8-3(h)]	
B.6	Severability [326 IAC 2-8-4(4)]	
B.7	Property Rights or Exclusive Privilege [326 IAC 2-8-4(5)(D)]	
B.8	Duty to Provide Information [326 IAC 2-8-4(5)(E)]	
B.9	Compliance Order Issuance [326 IAC 2-8-5(b)]	
B.10	Certification [326 IAC 2-8-3(d)] [326 IAC 2-8-4(3)(C)(i)] [326 IAC 2-8-5(1)]	
B.11	Annual Compliance Certification [326 IAC 2-8-5(a)(1)]	
B.12	Preventive Maintenance Plan [326 IAC 1-6-3] [326 IAC 2-8-4(9)] [326 IAC 2-8-5(a)(1)]	
B.13	Emergency Provisions [326 IAC 2-8-12]	
B.14	Deviations from Permit Requirements and Conditions [326 IAC 2-8-4(3)(C)(ii)]	
B.15	Permit Modification, Reopening, Revocation and Reissuance, or Termination [326 IAC 2-8-4(5)(C)] [326 IAC 2-8-7(a)] [326 IAC 2-8-8]	
B.16	Permit Renewal [326 IAC 2-8-3(h)]	
B.17	Permit Amendment or Revision [326 IAC 2-8-10] [326 IAC 2-8-11.1]	
B.18	Operational Flexibility [326 IAC 2-8-15][326 IAC 2-8-11.1]	
B.19	Permit Revision Requirement [326 IAC 2-8-11.1]	
B.20	Inspection and Entry [326 IAC 2-8-5(a)(2)] [IC13-14-2-2] [IC 13-17-3-2] [IC13-30-3-1]	
B.21	Transfer of Ownership or Operational Control [326 IAC 2-8-10] [IC 13-17-3-2]	
B.22	Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-8-4(6)] [326 IAC 2-8-16] [326 IAC 2-1.1-7]	
B.23	Credible Evidence [326 IAC 2-8-4(3)][326 IAC 2-8-5][62 FR 8314] [326 IAC 1-1-6]	
SECTION C	SOURCE OPERATION CONDITIONS	15
	Emission Limitations and Standards [326 IAC 2-8-4(1)]	
C.1	Particulate Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) pounds per hour [40 CFR 52 Subpart P] [326 IAC 6-3-2]	
C.2	Overall Source Limit [326 IAC 2-8]	
C.3	Opacity [326 IAC 5-1]	
C.4	Open Burning [326 IAC 4-1] [IC 13-17-9]	
C.5	Incineration [326 IAC 4-2] [326 IAC 9-1-2(3)]	
C.6	Fugitive Dust Emissions [326 IAC 6-4]	
C.7	Operation of Equipment [326 IAC 2-8-5(a)(4)]	
C.8	Stack Height [326 IAC 1-7]	
C.9	Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61 Subpart M]	
	Testing Requirements [326 IAC 2-8-4(3)]	
C.10	Performance Testing [326 IAC 3-6]	
	Compliance Requirements [326 IAC 2-1.1-11]	
C.11	Compliance Requirements [326 IAC 2-1.1-11]	

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

- C.12 Compliance Monitoring [326 IAC 2-8-4(3)] [326 IAC 2-8-5(a)(1)]
- C.13 Monitoring Methods [326 IAC 3] [40 CFR 60] [40 CFR 63]
- C.14 Pressure Gauge and Other Instrument Specifications [326 IAC 2-1.1-11]
[326 IAC 2-8-4(3)] [326 IAC 2-8-5(1)]

Corrective Actions and Response Steps [326 IAC 2-8-4] [326 IAC 2-8-5]

- C.15 Risk Management Plan [326 IAC 2-8-4] [40 CFR 68]
- C.16 Compliance Response Plan -Preparation, Implementation, Records, and Reports
[326 IAC 2-8-4] [326 IAC 2-8-5]
- C.17 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-8-4]
[326 IAC 2-8-5]

Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]

- C.18 General Record Keeping Requirements [326 IAC 2-8-4(3)] [326 IAC 2-8-5]
- C.19 General Reporting Requirements [326 IAC 2-8-4(3)(C)] [326 IAC 2-1.1-11]

Stratospheric Ozone Protection

- C.20 Compliance with 40 CFR 82 and 326 IAC 22-1

SECTION D.1 FACILITY OPERATION CONDITIONS: One (1) paint room and one (1) grit blast booth..... 22

Emission Limitations and Standards [326 IAC 2-8-4(1)]

- D.1.1 Volatile Organic Compounds (VOC) [326 IAC 8-2-12]
- D.1.2 Volatile Organic Compound (VOC) Limitations, Clean-up Requirements [326 IAC 8-2-9]
- D.1.3 Particulate Matter (PM) [40 CFR 52 Subpart P]
- D.1.4 Particulate [326 IAC 6-3-2]
- D.1.5 Particulate [326 IAC 6-3-2(d)]
- D.1.6 FESOP Limits [326 IAC 2-8-4]
- D.1.7 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

Compliance Determination Requirements

- D.1.8 Volatile Organic Compounds (VOC) [326 IAC 8-1-2] [326 IAC 8-1-4]
- D.1.9 Particulate Control

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

- D.1.10 Monitoring
- D.1.11 Visible Emissions Notations
- D.1.12 Parametric Monitoring
- D.1.13 Dust Collector Inspections
- D.1.14 Broken or Failed Cartridge Detection

Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

- D.1.15 Record Keeping Requirements
- D.1.16 Reporting Requirements

Certification Form	27
Emergency Occurrence Form	28
Quarterly Report Forms	30
Quarterly Deviation and Compliance Monitoring Report Form	32

SECTION A

SOURCE SUMMARY

This permit is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ). The information describing the source contained in Conditions A.1 through A.3 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this permit pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

A.1 General Information [326 IAC 2-8-3(b)]

The Permittee owns and operates a stationary metal fabricating source.

Authorized individual:	Chief Operating Officer
Source Address:	8857 East State Road 14, Akron, Indiana 46910
Mailing Address:	8857 East State Road 14, Akron, Indiana 46910
General Source Phone:	574 - 893 - 1569
SIC Code:	3444
Source Location Status:	Fulton
Source Status:	Attainment for all criteria pollutants Federally Enforceable State Operating Permit (FESOP) Minor Source, under PSD Rules; Minor Source, Section 112 of the Clean Air Act

A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-8-3(c)(3)]

This stationary source consists of the following emission units and pollution control devices:

- (a) One (1) paint room, identified as EU-01, equipped with airless spray applicators, using dry filters for particulate control, exhausting to Stack S-1, capacity: 0.125 fractionation tanks and 0.125 containers per hour.
- (b) One (1) grit blast booth, identified as EU-02, equipped with a cartridge dust collector for particulate control, exhausting to Stack S-2, capacity: 3,320 pounds of steel per hour.

A.3 Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-8-3(c)(3)(I)]

This stationary source also includes the following insignificant activities, as defined in 326 IAC 2-7-1(21):

- (a) Propane for liquefied petroleum gas, or butane-fired combustion sources with heat input equal to or less than six million (6,000,000) British thermal units per hour, consisting of:
 - (1) Two (2) space heaters, identified as H-1 and H-2, firing propane gas, capacity: 0.1 million British thermal units per hour, each.
 - (2) One (1) space heater, identified as H-3, firing propane gas, capacity: 0.3 million British thermal units per hour.
- (b) A gasoline fuel transfer and dispensing operation handling less than or equal to 1,300 gallons per day, such as filling of tanks, locomotives, automobiles, having a storage capacity less than or equal to 10,500 gallons.
- (c) A petroleum fuel, other than gasoline, dispensing facility, having a storage capacity of less than or equal to 10,500 gallons, and dispensing less than or equal to 230,000 gallons per month.

- (d) Machining where an aqueous cutting coolant continuously floods the machining interface.
- (e) The following equipment related to manufacturing activities not resulting in the emission of HAPs: brazing equipment, cutting torches, soldering equipment, welding equipment.

One (1) welding, cutting and assembly process, capacity: 9,960 pounds of steel per hour, consisting of the following equipment:
 - (1) Fifty-five (55) welding stations, using Metal Inert Gas, capacity: 3.0 pounds of wire per station per hour.
 - (2) Ten (10) oxyacetylene flame-cutting stations, capacity: 20.0 inches of 0.25 inch thick metal per minute, each.
 - (3) One (1) plasma flame-cutting station, capacity: 20.0 inches of 1.00 inch thick metal per minute.
- (f) Replacement or repair of electrostatic precipitators, bags in baghouses and filters in other air filtration equipment.
- (g) Paved and unpaved roads and parking lots with public access.
- (h) Blowdown for any of the following: sight glass; boiler; compressors; pumps; and cooling tower.

A.4 FESOP Applicability [326 IAC 2-8-2]

This stationary source, otherwise required to have a Part 70 Permit as described in 326 IAC 2-7-2(a), has applied to the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ) for a Federally Enforceable State Operating Permit (FESOP).

A.5 Prior Permits Superseded [326 IAC 2-1.1-9.5]

- (a) All terms and conditions of previous permits issued pursuant to permitting programs approved into the state implementation plan have been either
 - (1) incorporated as originally stated,
 - (2) revised, or
 - (3) deletedby this permit.
- (b) All previous registrations and permits are superseded by this permit.

SECTION B

GENERAL CONDITIONS

B.1 Permit No Defense [IC 13]

Indiana statutes from IC 13 and rules from 326 IAC, quoted in conditions in this permit, are those applicable at the time the permit was issued. The issuance or possession of this permit shall not alone constitute a defense against an alleged violation of any law, regulation or standard, except for the requirement to obtain a FESOP under 326 IAC 2-8.

B.2 Definitions [326 IAC 2-8-1]

Terms in this permit shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, the applicable definitions found in the statutes or regulations (IC 13-11, 326 IAC 1-2, and 326 IAC 2-7) shall prevail.

B.3 Permit Term [326 IAC 2-8-4(2)] [326 IAC 2-1.1-9.5]

This permit is issued for a fixed term of five (5) years from the issuance date of this permit, as determined in accordance with IC 4-21.5-3-5(f) and IC 13-15-5-3. Subsequent revisions, modifications, or amendments of this permit do not affect the expiration date.

B.4 Enforceability [326 IAC 2-8-6]

Unless otherwise stated, all terms and conditions in this permit, including any provisions designed to limit the source's potential to emit, are enforceable by IDEM, the United States Environmental Protection Agency (U.S. EPA) and by citizens in accordance with the Clean Air Act.

B.5 Termination of Right to Operate [326 IAC 2-8-9] [326 IAC 2-8-3(h)]

The Permittee's right to operate this source terminates with the expiration of this permit unless a timely and complete renewal application is submitted at least nine (9) months prior to the date of expiration of the source's existing permit, consistent with 326 IAC 2-8-3(h) and 326 IAC 2-8-9.

B.6 Severability [326 IAC 2-8-4(4)]

The provisions of this permit are severable; a determination that any portion of this permit is invalid shall not affect the validity of the remainder of the permit.

B.7 Property Rights or Exclusive Privilege [326 IAC 2-8-4(5)(D)]

This permit does not convey any property rights of any sort, or any exclusive privilege.

B.8 Duty to Provide Information [326 IAC 2-8-4(5)(E)]

(a) The Permittee shall furnish to IDEM, OAQ, within a reasonable time, any information that IDEM, OAQ, may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The submittal by the Permittee does require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1). Upon request, the Permittee shall also furnish to IDEM, OAQ, copies of records required to be kept by this permit.

(b) For information furnished by the Permittee to IDEM, OAQ, the Permittee may include a claim of confidentiality in accordance with 326 IAC 17.1 when furnishing copies of requested records directly to U.S. EPA, the Permittee may assert a claim of confidentiality in accordance with 40 CFR 2, Subpart B.

B.9 Compliance Order Issuance [326 IAC 2-8-5(b)]

IDEM, OAQ may issue a compliance order to this Permittee upon discovery that this permit is in nonconformance with an applicable requirement. The order may require immediate compliance or contain a schedule for expeditious compliance with the applicable requirement.

B.10 Certification [326 IAC 2-8-3(d)] [326 IAC 2-8-4(3)(C)(i)] [326 IAC 2-8-5(1)]

- (a) Where specifically designated by this permit or required by an applicable requirement, any application form, report, or compliance certification submitted shall contain certification by an authorized individual of truth, accuracy, and completeness. This certification, shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
- (b) One (1) certification shall be included, using the attached Certification Form, with each submittal requiring certification.
- (c) An authorized individual is defined at 326 IAC 2-1.1-1(1).

B.11 Annual Compliance Certification [326 IAC 2-8-5(a)(1)]

- (a) The Permittee shall annually submit a compliance certification report which addresses the status of the source's compliance with the terms and conditions contained in this permit, including emission limitations, standards, or work practices. The initial certification shall cover the time period from the date of final permit issuance through December 31 of the same year. All subsequent certifications shall cover the time period from January 1 to December 31 of the previous year, and shall be submitted in letter form no later than July 1 of each year to:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

- (b) The annual compliance certification report required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.
- (c) The annual compliance certification report shall include the following:
 - (1) The appropriate identification of each term or condition of this permit that is the basis of the certification;
 - (2) The compliance status;
 - (3) Whether compliance was continuous or intermittent;
 - (4) The methods used for determining the compliance status of the source, currently and over the reporting period consistent with 326 IAC 2-8-4(3); and
 - (5) Such other facts as specified in Sections D of this permit, IDEM, OAQ, may require to determine the compliance status of the source.

The notification which shall be submitted by the Permittee does require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).

B.12 Preventive Maintenance Plan [326 IAC 1-6-3] [326 IAC 2-8-4(9)] [326 IAC 2-8-5(a)(1)]

- (a) If required by specific condition(s) in Section D of this permit, the Permittee shall prepare and maintain Preventive Maintenance Plans (PMPs) within ninety (90) days after issuance of this permit, including the following information on each facility:

- (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;
- (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
- (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

If due to circumstances beyond the Permittee's control, the PMPs cannot be prepared and maintained within the above time frame, the Permittee may extend the date an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

The PMP extension notification does not require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (b) The Permittee shall implement the PMPs, including any required record keeping, as necessary to ensure that failure to implement a PMP does not cause or contribute to an exceedance of any limitation on emissions or potential to emit.
- (c) A copy of the PMPs shall be submitted to IDEM, OAQ, upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. IDEM, OAQ, may require the Permittee to revise its PMPs whenever lack of proper maintenance causes or is the primary contributor to an exceedance of any limitation on emissions or potential to emit. The PMP does not require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (d) To the extent the Permittee is required by 40 CFR Part 60/63 to have an Operation, Maintenance, and Monitoring (OMM) Plan for a unit, such Plan is deemed to satisfy the PMP requirements of 326 IAC 1-6-3 for that unit.

B.13 Emergency Provisions [326 IAC 2-8-12]

- (a) An emergency, as defined in 326 IAC 2-7-1(12), is not an affirmative defense for an action brought for noncompliance with a federal or state health-based emission limitation, except as provided in 326 IAC 2-8-12.
- (b) An emergency, as defined in 326 IAC 2-7-1(12), constitutes an affirmative defense to an action brought for noncompliance with a health-based or technology-based emission limitation if the affirmative defense of an emergency is demonstrated through properly signed, contemporaneous operating logs or other relevant evidence that describes the following:
 - (1) An emergency occurred and the Permittee can, to the extent possible, identify the causes of the emergency;
 - (2) The permitted facility was at the time being properly operated;
 - (3) During the period of an emergency, the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards or other requirements in this permit;

- (4) For each emergency lasting one (1) hour or more, the Permittee notified IDEM, OAQ and the Northern Regional Office, within four (4) daytime business hours after the beginning of the emergency, or after the emergency was discovered or reasonably should have been discovered;

Telephone No.: 1-800-451-6027 (ask for Office of Air Quality, Compliance Section) or,
Telephone No.: 317-233-5674 (ask for Compliance Section)
Facsimile No.: 317-233-5967
Northern Regional Office: 574-245-4870, Facsimile Number: 574-245-4877

- (5) For each emergency lasting one (1) hour or more, the Permittee submitted the attached Emergency Occurrence Report Form or its equivalent, either by mail or facsimile to:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

within two (2) working days of the time when emission limitations were exceeded due to the emergency.

The notice fulfills the requirement of 326 IAC 2-8-4(3)(C)(ii) and must contain the following:

- (A) A description of the emergency;
(B) Any steps taken to mitigate the emissions; and
(C) Corrective actions taken.

The notification which shall be submitted by the Permittee does not require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (6) The Permittee immediately took all reasonable steps to correct the emergency.
- (c) In any enforcement proceeding, the Permittee seeking to establish the occurrence of an emergency has the burden of proof.
- (d) This emergency provision supersedes 326 IAC 1-6 (Malfunctions). This permit condition is in addition to any emergency or upset provision contained in any applicable requirement.
- (e) IDEM, OAQ may require that the Preventive Maintenance Plans required under 326 IAC 2-8-3(c)(6) be revised in response to an emergency.
- (f) Failure to notify IDEM, OAQ by telephone or facsimile of an emergency lasting more than one (1) hour in accordance with (b)(4) and (5) of this condition shall constitute a violation of 326 IAC 2-8 and any other applicable rules.
- (g) Operations may continue during an emergency only if the following conditions are met:
- (1) If the emergency situation causes a deviation from a technology-based limit, the Permittee may continue to operate the affected emitting facilities during the emergency

provided the Permittee immediately takes all reasonable steps to correct the emergency and minimize emissions.

- (2) If an emergency situation causes a deviation from a health-based limit, the Permittee may not continue to operate the affected emissions facilities unless:
- (A) The Permittee immediately takes all reasonable steps to correct the emergency situation and to minimize emissions; and
 - (B) Continued operation of the facilities is necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw material of substantial economic value.

Any operations shall continue no longer than the minimum time required to prevent the situations identified in (g)(2)(B) of this condition.

- (h) The Permittee shall include all emergencies in the Quarterly Deviation and Compliance Monitoring Report.

B.14 Deviations from Permit Requirements and Conditions [326 IAC 2-8-4(3)(C)(ii)]

- (a) Deviations from any permit requirements (for emergencies see Section B - Emergency Provision), the probable cause of such deviations, and any response steps or preventive measures taken shall be reported to:

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

using the attached Quarterly Deviation and Compliance Monitoring Report, or its equivalent. A deviation required to be reported pursuant to an applicable requirement that exists independent of this permit, shall be reported according to the schedule stated in the applicable requirement and does need to be included in this report.

The Quarterly Deviation and Compliance Monitoring Report does require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (b) A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit.

B.15 Permit Modification, Reopening, Revocation and Reissuance, or Termination [326 IAC 2-8-4(5)(C)]
[326 IAC 2-8-7(a)] [326 IAC 2-8-8]

- (a) This permit may be modified, reopened, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a FESOP modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any condition of this permit. [326 IAC 2-8-4(5)(C)] The notification by the Permittee does require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (b) This permit shall be reopened and revised under any of the circumstances listed in IC 13-15-7-2 or if IDEM, OAQ determines any of the following:

- (1) That this permit contains a material mistake.

- (2) That inaccurate statements were made in establishing the emissions standards or other terms or conditions.
- (3) That this permit must be revised or revoked to assure compliance with an applicable requirement. [326 IAC 2-8-8(a)]
- (c) Proceedings by IDEM, OAQ to reopen and revise this permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of this permit for which cause to reopen exists. Such reopening and revision shall be made as expeditiously as practicable. [326 IAC 2-8-8(b)]
- (d) The reopening and revision of this permit, under 326 IAC 2-8-8(a), shall not be initiated before notice of such intent is provided to the Permittee by IDEM, OAQ at least thirty (30) days in advance of the date this permit is to be reopened, except that IDEM, OAQ may provide a shorter time period in the case of an emergency. [326 IAC 2-8-8(c)]

B.16 Permit Renewal [326 IAC 2-8-3(h)]

- (a) The application for renewal shall be submitted using the application form or forms prescribed by IDEM, OAQ and shall include the information specified in 326 IAC 2-8-3. Such information shall be included in the application for each emission unit at this source, except those emission units included on the trivial or insignificant activities list contained in 326 IAC 2-7-1(21) and 326 IAC 2-7-1(40). The renewal application does require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).

Request for renewal shall be submitted to:

Indiana Department of Environmental Management
Permits Branch, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

- (b) Timely Submittal of Permit Renewal [326 IAC 2-8-3]
 - (1) A timely renewal application is one that is:
 - (A) Submitted at least nine (9) months prior to the date of the expiration of this permit; and
 - (B) If the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
 - (2) If IDEM, OAQ, upon receiving a timely and complete permit application, fails to issue or deny the permit renewal prior to the expiration date of this permit, this existing permit shall not expire and all terms and conditions shall continue in effect until the renewal permit has been issued or denied.
- (c) Right to Operate After Application for Renewal [326 IAC 2-8-9]

If the Permittee submits a timely and complete application for renewal of this permit, the source's failure to have a permit is not a violation of 326 IAC 2-8 until IDEM, OAQ takes final action on the renewal application, except that this protection shall cease to apply if, subsequent to the completeness determination, the Permittee fails to submit by the dead-

line specified in writing by IDEM, OAQ any additional information identified as needed to process the application.

B.17 Permit Amendment or Revision [326 IAC 2-8-10] [326 IAC 2-8-11.1]

- (a) Permit amendments and revisions are governed by the requirements of 326 IAC 2-8-10 or 326 IAC 2-8-11.1 whenever the Permittee seeks to amend or modify this permit.
- (b) Any application requesting an amendment or modification of this permit shall be submitted to:
- Indiana Department of Environmental Management
Permits Branch, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251
- Any such application shall be certified by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (c) The Permittee may implement the administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-8-10(b)(3)]
- (d) No permit amendment or modification is required for the addition, operation or removal of a nonroad engine, as defined in 40 CFR 89.2.

B.18 Operational Flexibility [326 IAC 2-8-15] [326 IAC 2-8-11.1]

- (a) The Permittee may make any change or changes at this source that are described in 326 IAC 2-8-15(b) through (d), without prior permit revision, if each of the following conditions is met:
- (1) The changes are not modifications under any provision of Title I of the Clean Air Act;
 - (2) Any approval required by 326 IAC 2-8-11.1 has been obtained;
 - (3) The changes do not result in emissions which exceed the emissions allowable under this permit (whether expressed herein as a rate of emissions or in terms of total emissions);
 - (4) The Permittee notifies the:

Indiana Department of Environmental Management
Permits Branch, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V
Air and Radiation Division, Regulation Development Branch - Indiana (AR-18J)
77 West Jackson Boulevard
Chicago, Illinois 60604-3590

in advance of the change by written notification at least ten (10) days in advance of the proposed change. The Permittee shall attach every such notice to the Permittee's copy of this permit; and

- (5) The Permittee maintains records on-site which document, on a rolling five (5) year basis, all such changes and emissions trading that are subject to 326 IAC 2-8-15(b) through (d) and makes such records available, upon reasonable request, to public review.

Such records shall consist of all information required to be submitted to IDEM, OAQ in the notices specified in 326 IAC 2-8-15(b)(2), (c)(1), and (d).

- (b) Emission Trades [326 IAC 2-8-15(c)]
The Permittee may trade increases and decreases in emissions in the source, where the applicable SIP provides for such emission trades without requiring a permit revision, subject to the constraints of Section (a) of this condition and those in 326 IAC 2-8-15(c).
- (c) Alternative Operating Scenarios [326 IAC 2-8-15(d)]
The Permittee may make changes at the source within the range of alternative operating scenarios that are described in the terms and conditions of this permit in accordance with 326 IAC 2-8-4(7). No prior notification of IDEM, OAQ or U.S. EPA is required.

B.19 Permit Revision Requirement [326 IAC 2-8-11.1]

A modification, construction, or reconstruction is governed by the requirements of 326 IAC 2 and 326 IAC 2-8-11.1.

B.20 Inspection and Entry [326 IAC 2-8-5(a)(2)] [IC 13-14-2-2] [IC 13-17-3-2] [IC 13-17-3-2] [IC13-30-3-1]

Upon presentation of proper identification cards, credentials, and other documents as may be required by law, and subject to the Permittee's right under all applicable laws and regulations to assert that the information collected by the agency is confidential and entitled to be treated as such, the Permittee shall allow IDEM, OAQ, U.S. EPA, or an authorized representative to perform the following:

- (a) Enter upon the Permittee's premises where a FESOP source is located, or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
- (b) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- (c) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, inspect at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit;
- (d) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with this permit or applicable requirements; and
- (e) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, utilize any photographic, recording, testing, monitoring, or other equipment for the purpose of assuring compliance with this permit or applicable requirements.

B.21 Transfer of Ownership or Operational Control [326 IAC 2-8-10] [IC 13-17-3-2]

- (a) The Permittee must comply with the requirements of 326 IAC 2-8-10 whenever the Permittee seeks to change the ownership or operational control of the source and no other change in the permit is necessary.
- (b) Any application requesting a change in the ownership or operational control of the source shall contain a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new Permittee. The application shall be submitted to:

Indiana Department of Environmental Management
Permits Branch, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

The application which shall be submitted by the Permittee does require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-8-10(b)(3)]

B.22 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-8-4(6)] [326 IAC 2-8-16] [326 IAC 2-1.1-7]

- (a) The Permittee shall pay annual fees to IDEM, OAQ, within thirty (30) calendar days of receipt of a billing. Pursuant to 326 IAC 2-7-19(b), if the Permittee does not receive a bill from IDEM, OAQ the applicable fee is due April 1 of each year.
- (b) Failure to pay may result in administrative enforcement action, or revocation of this permit.
- (c) The Permittee may call the following telephone numbers: 1-800-451-6027 or 317-233-4320 (ask for OAQ, Billing, Licensing, and Training Section), to determine the appropriate permit fee.

B.23 Credible Evidence [326 IAC 2-8-4(3)][326 IAC 2-8-5][62 FR 8314] [326 IAC 1-1-6]

For the purpose of submitting compliance certifications or establishing whether or not the Permittee has violated or is in violation of any condition of this permit, nothing in this permit shall preclude the use, including the exclusive use, of any credible evidence or information relevant to whether the Permittee would have been in compliance with the condition of this permit if the appropriate performance or compliance test or procedure had been performed.

SECTION C

SOURCE OPERATION CONDITIONS

Entire Source

Emissions Limitations and Standards [326 IAC 2-8-4(1)]

C.1 Particulate Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) pounds per hour [40 CFR 52 Subpart P] [326 IAC 6-3-2]

- (a) Pursuant to 40 CFR 52 Subpart P, particulate matter emissions from any process not already regulated by 326 IAC 6-1 or any New Source Performance Standard, and which has a maximum process weight rate less than 100 pounds per hour shall not exceed 0.551 pounds per hour.
- (b) Pursuant to 326 IAC 6-3-2(e)(2), particulate emissions from any process not exempt under 326 IAC 6-3-1(b) or (c) which has a maximum process weight rate less than 100 pounds per hour and the methods in 326 IAC 6-3-2(b) through (d) do not apply shall not exceed 0.551 pounds per hour.

C.2 Overall Source Limit [326 IAC 2-8]

The purpose of this permit is to limit this source's potential to emit to less than major source levels for the purpose of Section 502(a) of the Clean Air Act.

- (a) Pursuant to 326 IAC 2-8:
 - (1) The potential to emit any regulated pollutant, except particulate matter (PM), from the entire source shall be limited to less than one-hundred (100) tons per twelve (12) consecutive month period. This limitation shall also make the requirements of 326 IAC 2-2 (Prevention of Significant Deterioration (PSD)) not applicable;
 - (2) The potential to emit any individual hazardous air pollutant (HAP) from the entire source shall be limited to less than ten (10) tons per twelve (12) consecutive month period; and
 - (3) The potential to emit any combination of HAPs from the entire source shall be limited to less than twenty-five (25) tons per twelve (12) consecutive month period.
- (b) This condition shall include all emission points at this source including those that are insignificant as defined in 326 IAC 2-7-1(21). The source shall be allowed to add insignificant activities not already listed in this permit, provided that the source's potential to emit does not exceed the above specified limits.
- (c) Section D of this permit contains independently enforceable provisions to satisfy this requirement.

C.3 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

- (a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.

- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

C.4 Open Burning [326 IAC 4-1] [IC 13-17-9]

The Permittee shall not open burn any material except as provided in 326 IAC 4-1-3, 326 IAC 4-1-4 or 326 IAC 4-1-6. The previous sentence notwithstanding, the Permittee may open burn in accordance with an open burning approval issued by the Commissioner under 326 IAC 4-1-4.1.

C.5 Incineration [326 IAC 4-2] [326 IAC 9-1-2(3)]

The Permittee shall not operate an incinerator or incinerate any waste or refuse except as provided in 326 IAC 4-2 and in 326 IAC 9-1-2.

C.6 Fugitive Dust Emissions [326 IAC 6-4]

The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions).

C.7 Operation of Equipment [326 IAC 2-8-5(a)(4)]

Except as otherwise provided by statute, rule or in this permit, all air pollution control equipment listed in this permit and used to comply with an applicable requirement shall be operated at all times that the emission units vented to the control equipment are in operation.

C.8 Stack Height [326 IAC 1-7]

The Permittee shall comply with the applicable provisions of 326 IAC 1-7 (Stack Height Provisions), for all exhaust stacks through which a potential (before controls) of twenty-five (25) tons per year or more of particulate matter or sulfur dioxide is emitted.

C.9 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

- (a) Notification requirements apply to each owner or operator. If the combined amount of regulated asbestos containing material (RACM) to be stripped, removed or disturbed is at least 260 linear feet on pipes or 160 square feet on other facility components, or at least thirty-five (35) cubic feet on all facility components, then the notification requirements of 326 IAC 14-10-3 are mandatory. All demolition projects require notification whether or not asbestos is present.
- (b) The Permittee shall ensure that a written notification is sent on a form provided by the Commissioner at least ten (10) working days before asbestos stripping or removal work or before demolition begins, per 326 IAC 14-10-3, and shall update such notice as necessary, including, but not limited to the following:
 - (1) When the amount of affected asbestos containing material increases or decreases by at least twenty percent (20%); or
 - (2) If there is a change in the following:
 - (A) Asbestos removal or demolition start date;
 - (B) Removal or demolition contractor; or
 - (C) Waste disposal site.

- (c) The Permittee shall ensure that the notice is postmarked or delivered according to the guidelines set forth in 326 IAC 14-10-3(2).
- (d) The notice to be submitted shall include the information enumerated in 326 IAC 14-10-3(3).

All required notifications shall be submitted to:

Indiana Department of Environmental Management
Asbestos Section, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

The notice shall include a signed certification from the owner or operator that the information provided in this notification is correct and that only Indiana licensed workers and project supervisors will be used to implement the asbestos removal project. The notifications do not require a certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (e) **Procedures for Asbestos Emission Control**
The Permittee shall comply with the applicable emission control procedures in 326 IAC 14-10-4 and 40 CFR 61.145(c). Per 326 IAC 14-10-1 emission control requirements are applicable for any removal or disturbance of RACM greater than three (3) linear feet on pipes or three (3) square feet on any other facility components or a total of at least 0.75 cubic feet on all facility components.
- (f) **Demolition and renovation**
The Permittee shall thoroughly inspect the affected facility or part of the facility where the demolition or renovation will occur for the presence of asbestos pursuant to 40 CFR 61.145(a).
- (g) **Indiana Accredited Asbestos Inspector**
The Permittee shall comply with 326 IAC 14-10-1(a) that requires the owner or operator, prior to a renovation/demolition, to use an Indiana Accredited Asbestos Inspector to thoroughly inspect the affected portion of the facility for the presence of asbestos. The requirement to use an Indiana Accredited Asbestos inspector is not federally enforceable.

Testing Requirements [326 IAC 2-8-4(3)]

C.10 Performance Testing [326 IAC 3-6]

- (a) All testing shall be performed according to the provisions of 326 IAC 3-6 (Source Sampling Procedures), except as provided elsewhere in this permit, utilizing any applicable procedures and analysis methods specified in 40 CFR 51, 40 CFR 60, 40 CFR 61, 40 CFR 63, 40 CFR 75, or other procedures approved by IDEM, OAQ.

A test protocol, except as provided elsewhere in this permit, shall be submitted to:

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

no later than thirty-five (35) days prior to the intended test date. The protocol submitted by the Permittee does not require certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (b) The Permittee shall notify IDEM, OAQ of the actual test date at least fourteen (14) days prior to the actual test date. The notification submitted by the Permittee does not require certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (c) Pursuant to 326 IAC 3-6-4(b), all test reports must be received by IDEM, OAQ not later than forty-five (45) days after the completion of the testing. An extension may be granted by IDEM, OAQ if the Permittee submits to IDEM, OAQ a reasonable written explanation not later than five (5) days prior to the end of the initial forty-five (45) day period.

Compliance Requirements [326 IAC 2-1.1-11]

C.11 Compliance Requirements [326 IAC 2-1.1-11]

The commissioner may require stack testing, monitoring, or reporting at any time to assure compliance with all applicable requirements by issuing an order under 326 IAC 2-1.1-11. Any monitoring or testing shall be performed in accordance with 326 IAC 3 or other methods approved by the commissioner or the U.S. EPA.

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

C.12 Compliance Monitoring [326 IAC 2-8-4(3)] [326 IAC 2-8-5(a)(1)]

Unless otherwise specified in this permit, all monitoring and record keeping requirements not already legally required shall be implemented within ninety (90) days of permit issuance. If required by Section D, the Permittee shall be responsible for installing any necessary equipment and initiating any required monitoring related to that equipment. If due to circumstances beyond its control, that equipment cannot be installed and operated within *ninety (90) days*, the Permittee may extend the compliance schedule related to the equipment for an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

in writing, prior to the end of the initial ninety (90) day compliance schedule with full justification of the reasons for inability to meet this date.

The notification, which shall be submitted by the Permittee, does require the certification by the "authorized individual", as defined by 326 IAC 2-1.1-1(1).

Unless otherwise specified in the approval for the new emissions unit, compliance monitoring for new emission units or emission units added through a permit revision shall be implemented when operation begins.

C.13 Monitoring Methods [326 IAC 3] [40 CFR 60] [40 CFR 63]

Any monitoring or testing required by Section D of this permit shall be performed according to the provisions of 326 IAC 3, 40 CFR 60, Appendix A, 40 CFR 60 Appendix B, 40 CFR 63 or other approved methods as specified in this permit.

C.14 Pressure Gauge and Other Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-8-4(3)] [326 IAC 2-8-5(1)]

- (a) Whenever a condition in this permit requires the measurement of pressure drop across any part of the unit or its control device, the gauge employed shall have a scale such that the expected normal reading shall be no less than twenty percent (20%) of full scale and be accurate within plus or minus two percent (" 2%) of full scale reading.

- (b) The Permittee may request the IDEM, OAQ approve the use of a pressure gauge or other instrument that does not meet the above specifications provided the Permittee can demonstrate an alternative pressure gauge or other instrument specification will adequately ensure compliance with permit conditions requiring the measurement of pressure drop or other parameters.

Corrective Actions and Response Steps [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

C.15 Risk Management Plan [326 IAC 2-8-4] [40 CFR 68]

If a regulated substance as defined in 40 CFR 68 is present at a source in more than a threshold quantity, the Permittee must comply with the applicable requirements of 40 CFR 68.

C.16 Compliance Response Plan - Preparation, Implementation, Records, and Reports [326 IAC 2-8-4] [326 IAC 2-8-5]

- (a) The Permittee is required to prepare a Compliance Response Plan (CRP) for each compliance monitoring condition of this permit. A CRP shall be submitted to IDEM, OAQ upon request. The CRP shall be prepared within ninety (90) days after issuance of this permit by the Permittee, supplemented from time to time by the Permittee, maintained on site, and is comprised of:
- (1) Reasonable response steps that may be implemented in the event that a response step is needed pursuant to the requirements of Section D of this permit; and an expected time frame for taking reasonable response steps.
 - (2) If, at any time, the Permittee takes reasonable response steps that are not set forth in the Permittee's current Compliance Response Plan and the Permittee documents such response in accordance with subsection (e) below, the Permittee shall amend its Compliance Response Plan to include such response steps taken.
- (b) For each compliance monitoring condition of this permit, reasonable response steps shall be taken when indicated by the provisions of that compliance monitoring condition as follows:
- (1) Reasonable response steps shall be taken as set forth in the Permittee's current Compliance Response Plan; or
 - (2) If none of the reasonable response steps listed in the Compliance Response Plan is applicable or responsive to the excursion, the Permittee shall devise and implement additional response steps as expeditiously as practical. Taking such additional response steps shall not be considered a deviation from this permit so long as the Permittee documents such response steps in accordance with this condition.
 - (3) If the Permittee determines that additional response steps would necessitate that the emissions unit or control device be shut down, and it will be ten (10) days or more until the unit or device will be shut down, then the Permittee shall promptly notify the IDEM, OAQ of the expected date of the shut down. The notification shall also include the status of the applicable compliance monitoring parameter with respect to normal, and the results of the response actions taken up to the time of notification.
 - (4) Failure to take reasonable response steps shall be considered a deviation from the permit.

- (c) The Permittee is not required to take any further response steps for any of the following reasons:
 - (1) A false reading occurs due to the malfunction of the monitoring equipment and prompt action was taken to correct the monitoring equipment.
 - (2) The Permittee has determined that the compliance monitoring parameters established in the permit conditions are technically inappropriate, has previously submitted a request for an administrative amendment to the permit, and such request has not been denied.
 - (3) An automatic measurement was taken when the process was not operating.
 - (4) The process has already returned or is returning to operating within "normal" parameters and no response steps are required.
- (d) When implementing reasonable steps in response to a compliance monitoring condition, if the Permittee determines that an exceedance of an emission limitation has occurred, the Permittee shall report such deviations pursuant to Section B-Deviations from Permit Requirements and Conditions.
- (e) The Permittee shall record all instances when response steps are taken. In the event of an emergency, the provisions of 326 IAC 2-8-12 (Emergency Provisions) requiring prompt corrective action to mitigate emissions shall prevail.
- (f) Except as otherwise provided by a rule or provided specifically in Section D, all monitoring as required in Section D shall be performed when the emission unit is operating, except for time necessary to perform quality assurance and maintenance activities.

C.17 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-8-4] [326 IAC 2-8-5]

- (a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this permit exceed the level specified in any condition of this permit, the Permittee shall take appropriate response actions. The Permittee shall submit a description of these response actions to IDEM, OAQ, within thirty (30) days of receipt of the test results. The Permittee shall take appropriate action to minimize excess emissions from the affected facility while the response actions are being implemented.
- (b) A retest to demonstrate compliance shall be performed within one hundred twenty (120) days of receipt of the original test results. Should the Permittee demonstrate to IDEM, OAQ that retesting in one-hundred and twenty (120) days is not practicable, IDEM, OAQ may extend the retesting deadline.
- (c) IDEM, OAQ reserves the authority to take any actions allowed under law in response to noncompliant stack tests.

The response action documents submitted pursuant to this condition do require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).

Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]

C.18 General Record Keeping Requirements [326 IAC 2-8-4(3)] [326 IAC 2-8-5]

- (a) Records of all required monitoring data, reports and support information required by this permit shall be retained for a period of at least five (5) years from the date of monitoring sample, measurement, report, or application. These records shall be physically present or electronically accessible at the source location for a minimum of three (3) years. The

records may be stored elsewhere for the remaining two (2) years as long as they are available upon request. If the Commissioner makes a request for records to the Permittee, the Permittee shall furnish the records to the Commissioner within a reasonable time.

- (b) Unless otherwise specified in this permit, all record keeping requirements not already legally required shall be implemented within ninety (90) days of permit issuance.

C.19 General Reporting Requirements [326 IAC 2-8-4(3)(C)] [326 IAC 2-1.1-11]

- (a) The source shall submit the attached Quarterly Deviation and Compliance Monitoring Report or its equivalent. Any deviation from permit requirements, the date(s) of each deviation, the cause of the deviation, and the response steps taken must be reported. This report shall be submitted within thirty (30) days of the end of the reporting period. The Quarterly Deviation and Compliance Monitoring Report shall include the certification by the "authorized individual" as defined by 326 IAC2-1.1-1(1).
- (b) The report required in (a) of this condition and reports required by conditions in Section D of this permit shall be submitted to:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251
- (c) Unless otherwise specified in this permit, any notice, report, or other submission required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
- (d) Unless otherwise specified in this permit, all reports required in Section D of this permit shall be submitted within thirty (30) days of the end of the reporting period. All reports do require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (e) The first report covered the period commencing on the date of issuance of the original FESOP and ended on the last day of the reporting period. All subsequent reporting periods shall be based on calendar years.

Stratospheric Ozone Protection

C.20 Compliance with 40 CFR 82 and 326 IAC 22-1

Pursuant to 40 CFR 82 (Protection of Stratospheric Ozone), Subpart F, except as provided for motor vehicle air conditioners in Subpart B, the Permittee shall comply with the standards for recycling and emissions reduction:

- (a) Persons opening appliances for maintenance, service, repair or disposal must comply with the required practices pursuant to 40 CFR 82.156
- (b) Equipment used during the maintenance, service, repair or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to 40 CFR 82.158.
- (c) Persons performing maintenance, service, repair or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161.

SECTION D.1

FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-8-4(10)]: One (1) paint room and one (1) grit blast booth

- (a) One (1) paint room, identified as EU-01, equipped with airless spray applicators, using dry filters for particulate control, exhausting to Stack S-1, capacity: 0.125 fractionation tanks and 0.125 containers per hour.
- (b) One (1) grit blast booth, identified as EU-02, equipped with a cartridge dust collector for particulate control, exhausting to Stack S-2, capacity: 3,320 pounds of steel per hour.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-8-4(1)]

D.1.1 Volatile Organic Compound (VOC) [326 IAC 8-2-9]

Pursuant to 326 IAC 8-2-9, the owner or operator shall not allow the discharge into the atmosphere VOC in excess of three and five-tenths (3.5) pounds of VOC per gallon of coating, excluding water, as delivered to the applicators at the one (1) paint room (EU-01).

D.1.2 Volatile Organic Compound (VOC) Limitations, Clean-up Requirements [326 IAC 8-2-9]

Pursuant to 326 IAC 8-2-9(f), all solvents sprayed from the application equipment of the one (1) paint room (EU-01) during cleanup or color changes shall be directed into containers. Said containers shall be closed as soon as the solvent spraying is complete. In addition, all waste solvent shall be disposed of in such a manner that minimizes evaporation.

D.1.3 Particulate Matter (PM) [40 CFR 52 Subpart P]

Pursuant to MSOP 049-12681-00008 issued on January 8, 2001, and 40 CFR 52, Subpart P the particulate matter (PM) from the one (1) paint room, identified as EU-01, shall be limited by the following:

Interpolation of the data for the process weight rate up to sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 4.10 P^{0.67} \quad \text{where } E = \text{rate of emission in pounds per hour; and} \\ P = \text{process weight rate in tons per hour}$$

D.1.4 Particulate [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), the allowable particulate emission rate from the grit blast booth (EU-02) shall not exceed 5.76 pounds per hour when operating at a process weight rate of 3,320 pounds per hour (1.66 tons per hour).

The pounds per hour limitation was calculated with the following equation:

Interpolation of the data for the process weight rate up to 60,000 pounds per hour shall be accomplished by use of the equation:

$$E = 4.10 P^{0.67} \quad \text{where } E = \text{rate of emission in pounds per hour; and} \\ P = \text{process weight rate in tons per hour}$$

D.1.5 Particulate [326 IAC 6-3-2(d)]

Pursuant to MSOP 049-12681-00008 issued on January 8, 2001 and 326 IAC 6-3-2(d), particulate from the one (1) paint room, identified as EU-01, shall be controlled by a dry particulate filter, and the Permittee shall operate the control device in accordance with manufacturer's specifications.

D.1.6 FESOP Limits [326 IAC 2-8-4]

- (a) The PM₁₀ emissions from the one (1) paint room (EU-01) shall be limited to less than 12.5 pounds per hour, which is equivalent to 55.0 tons per twelve (12) consecutive month period, with compliance determined at the end of each month.
- (b) The total amount of any single HAP delivered to the applicators at the one (1) paint room (EU-01), including coatings, adhesives, dilution solvents and clean-up solvents, shall be limited to less than ten (10) tons per twelve (12) consecutive month period, with compliance determined at the end of each month.
- (c) The total amount of all HAPs delivered to the applicators at the one (1) paint room (EU-01), including coatings, adhesives, dilution solvents and clean-up solvents, shall be limited to less than 24.0 tons per twelve (12) consecutive month period, with compliance determined at the end of each month.

These limitations render the requirements of 326 IAC 2-7 (Part 70 Operating Permits) and 326 IAC 2-4.1 (Major Sources of HAPs) not applicable.

D.1.7 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

A Preventive Maintenance Plan, in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for the one (1) paint room (EU-01), the grit blast booth (EU-02), and each associated control device.

Compliance Determination Requirements

D.1.8 Volatile Organic Compounds (VOC) [326 IAC 8-1-2] [326 IAC 8-1-4]

Compliance with the VOC content and usage limitations contained in Condition D.1.1 shall be determined pursuant to 326 IAC 8-1-4(a)(3) and 326 IAC 8-1-2(a) by preparing or obtaining from the manufacturer the copies of the "as supplied" and "as applied" VOC data sheets. IDEM, OAQ reserves the authority to determine compliance using Method 24 in conjunction with the analytical procedures specified in 326 IAC 8-1-4.

D.1.9 Particulate Control

In order to comply with Condition D.1.4, the cartridge dust collector for particulate control shall be in operation and control emissions from the grit blast booth (EU-02) at all times that the grit blast booth (EU-02) is in operation.

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

D.1.10 Monitoring

- (a) Daily inspections shall be performed to verify the placement, integrity and particle loading of the filters. To monitor the performance of the dry filters, weekly observations shall be made of the overspray from the surface coating booth (Stack S-1) while one or more of the booths are in operation. The Compliance Response Plan shall be followed whenever a condition exists which should result in a response step. Failure to take response steps in accordance with Section C - Compliance Response Plan - Preparation, Implementation, Records, and Reports, shall be considered a deviation from this permit.

- (b) Monthly inspections shall be performed of the coating emissions from the stack and the presence of overspray on the rooftops and the nearby ground. The Compliance Response Plan for this unit shall contain troubleshooting contingency and response steps for when a noticeable change in overspray emission, or evidence of overspray emission is observed. The Compliance Response Plan shall be followed whenever a condition exists which should result in a response step. Failure to take response steps in accordance with Section C - Compliance Response Plan -Preparation, Implementation, Records, and Reports, shall be considered a deviation from this permit.
- (c) Additional inspections and preventive measures shall be performed as prescribed in the Preventive Maintenance Plan.

D.1.11 Visible Emissions Notations

- (a) Visible emission notations of the grit blast booth (EU-02) stack exhaust shall be performed once per shift during normal daylight operations when exhausting to the atmosphere. A trained employee shall record whether emissions are normal or abnormal.
- (b) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.
- (c) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- (d) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.
- (e) The Compliance Response Plan for this unit shall contain troubleshooting contingency and response steps for when an abnormal emission is observed. Failure to take response steps in accordance with Section C - Compliance Response Plan - Preparation, Implementation, Records, and Reports, shall be considered a deviation from this permit.

D.1.12 Parametric Monitoring

The Permittee shall record the total static pressure drop across the cartridge dust collector used in conjunction with the grit blast booth (EU-02), at least once per shift when the process is in operation. When for any one reading, the pressure drop across the cartridge dust collector is outside the normal range of 5.0 to 8.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps in accordance with Section C- Compliance Response Plan - Preparation, Implementation, Records, and Reports. A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps in accordance with Section C - Compliance Response Plan - Preparation, Implementation, Records, and Reports, shall be considered a deviation from this permit.

The instrument used for determining the pressure shall comply with Section C - Pressure Gauge and Other Instrument Specifications, of this permit, shall be subject to approval by IDEM, OAQ and shall be calibrated at least once every six (6) months.

D.1.13 Dust Collector Inspections

An inspection shall be performed each calendar quarter of all cartridges controlling the grit blast booth (EU-02). Inspections required by this condition shall not be performed in consecutive months. All defective cartridges shall be replaced.

D.1.14 Broken or Failed Cartridge Detection

In the event that cartridge failure has been observed:

- (a) For multi-compartment units, the affected compartments will be shut down immediately until the failed units have been repaired or replaced. Within eight (8) business hours of the determination of failure, response steps according to the timetable described in the Compliance Response Plan shall be initiated. For any failure with corresponding response steps and timetable not described in the Compliance Response Plan, response steps shall be devised within eight (8) business hours of discovery of the failure and shall include a timetable for completion. Failure to take response steps in accordance with Section C - Compliance Response Plan - Preparation, Implementation, Records, and Reports, shall be considered a deviation from this permit. If operations continue after cartridge failure is observed and it will be 10 days or more after the failure is observed before the failed units will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed units will be repaired or replaced. The notification shall also include the status of the applicable compliance monitoring parameters with respect to normal, and the results of any response actions taken up to the time of notification.
- (b) For single compartment dust collectors, if failure is indicated by a significant drop in the pressure readings with abnormal visible emissions or the failure is indicated by an opacity violation, or if cartridge failure is determined by other means, such as gas temperatures, flow rates, air infiltration, leaks, dust traces or triboflows, then failed units and the associated process will be shut down immediately until the failed units have been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).

Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

D.1.15 Record Keeping Requirements

- (a) To document compliance with Condition D.1.1, the Permittee shall maintain records in accordance with (1) and (2) below. Records maintained for (1) and (2) shall be taken monthly and shall be complete and sufficient to establish compliance with the VOC content limit established in Condition D.1.1.
 - (1) The VOC content of each coating material and solvent used.
 - (2) The amount of coating material and solvent used less water on daily basis.
 - (A) Records shall include purchase orders, invoices, and material safety data sheets (MSDS) necessary to verify the type and amount used.
 - (B) Solvent usage records shall differentiate between those added to coatings and those used as cleanup solvents.
- (b) To document compliance with Condition D.1.6(b), the Permittee shall maintain records in accordance with (1) through (5) below. Records maintained for (1) through (5) shall be taken monthly and shall be complete and sufficient to establish compliance with the HAP usage limits established in Condition D.1.6(b). Records necessary to demonstrate compliance shall be available within 30 days of the end of each compliance period.
 - (1) The HAP content of each coating material and solvent used.
 - (2) The amount of coating material and solvent less water used on a monthly basis.

- (A) Records shall include purchase orders, invoices, and material safety data sheets (MSDS) necessary to verify the type and amount used.
- (B) Solvent usage records shall differentiate between those added to coatings and those used as cleanup solvents;
 - (3) The cleanup solvent usage for each month;
 - (4) The total HAP usage for each month; and
 - (5) The weight of HAPs emitted for each compliance period.
- (c) To document compliance with Condition D.1.10, the Permittee shall maintain a log of weekly overspray observations, daily and monthly inspections, and those additional inspections prescribed by the Preventive Maintenance Plan.
- (d) To document compliance with Condition D.1.11, the Permittee shall maintain records of visible emission notations of the grit blast booth (EU-02) stack exhaust once per shift.
- (e) To document compliance with Condition D.1.12, the Permittee shall maintain records once per shift of the total static pressure drop during normal operation.
- (f) To document compliance with Condition D.1.13, the Permittee shall maintain records of the results of the inspections required under Condition D.1.13.
- (g) To document compliance with Condition D.1.7, the Permittee shall maintain of records of any additional inspections prescribed by the Preventive Maintenance Plan.
- (h) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

D.1.16 Reporting Requirements

A quarterly summary of the information to document compliance with Condition 1.6(b) shall be submitted to the address listed in Section C - General Reporting Requirements, of this permit, using the reporting forms located at the end of this permit, or their equivalent, within thirty (30) days after the end of the quarter being reported. The report submitted by the Permittee does require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1). with Section C- Performance Testing.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY**

**FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP)
CERTIFICATION**

Source Name: Dragon/ESP-Midwest, Ltd.
Source Address: 8857 East State Road 14, Akron, Indiana 46910
Mailing Address: 8857 East State Road 14, Akron, Indiana 46910
FESOP No.: F 049-19280-00008

This certification shall be included when submitting monitoring, testing reports/results or other documents as required by this permit.

Please check what document is being certified:

- Annual Compliance Certification Letter
- Test Result (specify) _____
- Report (specify) _____
- Notification (specify) _____
- Affidavit (specify) _____
- Other (specify) _____

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Signature:

Printed Name:

Title/Position:

Date:

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE BRANCH
100 North Senate Avenue
Indianapolis, Indiana 46204-2251
Phone: 317-233-5674
Fax: 317-233-5967**

**FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP)
EMERGENCY OCCURRENCE REPORT**

Source Name: Dragon/ESP-Midwest, Ltd.
Source Address: 8857 East State Road 14, Akron, Indiana 46910
Mailing Address: 8857 East State Road 14, Akron, Indiana 46910
FESOP No.: F 049-19280-00008

This form consists of 2 pages

Page 1 of 2

- | |
|---|
| <input type="checkbox"/> This is an emergency as defined in 326 IAC 2-7-1(12) <ul style="list-style-type: none">• The Permittee must notify the Office of Air Quality (OAQ), within four (4) business hours (1-800-451-6027 or 317-233-5674, ask for Compliance Section); and• The Permittee must submit notice in writing or by facsimile within two (2) working days (Facsimile Number: 317-233-5967), and follow the other requirements of 326 IAC 2-7-16 |
|---|

If any of the following are not applicable, mark N/A

Facility/Equipment/Operation:
Control Equipment:
Permit Condition or Operation Limitation in Permit:
Description of the Emergency:
Describe the cause of the Emergency:

If any of the following are not applicable, mark N/A

Page 2 of 2

Date/Time Emergency started:
Date/Time Emergency was corrected:
Was the facility being properly operated at the time of the emergency? Y N Describe:
Type of Pollutants Emitted: TSP, PM-10, SO ₂ , VOC, NO _x , CO, Pb, other:
Estimated amount of pollutant(s) emitted during emergency:
Describe the steps taken to mitigate the problem:
Describe the corrective actions/response steps taken:
Describe the measures taken to minimize emissions:
If applicable, describe the reasons why continued operation of the facilities are necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw materials of substantial economic value:

Form Completed by: _____

Title / Position: _____

Date: _____

Phone: _____

A certification is not required for this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE DATA SECTION**

FESOP Quarterly Report

Source Name: Dragon/ESP-Midwest, Ltd.
Source Address: 8857 East State Road 14, Akron, Indiana 46910
Mailing Address: 8857 East State Road 14, Akron, Indiana 46910
FESOP No.: F 049-19280-00008
Facility: One (1) paint room (EU-01)
Parameter: Worst Case single HAP usage
Limit: Less than ten (10) tons per twelve (12) consecutive month period, with compliance determined at the end of each month

YEAR: _____

Month	Single HAP Usage (tons)	Single HAP Usage (tons)	Single HAP Usage (tons)
	This Month	Previous 11 Months	12 Month Total

- No deviation occurred in this month.
- Deviation/s occurred in this month.
Deviation has been reported on _____

Submitted by: _____

Title/Position: _____

Signature: _____

Date: _____

Phone: _____

Attach a signed certification to complete this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE DATA SECTION**

FESOP Quarterly Report

Source Name: Dragon/ESP-Midwest, Ltd.
Source Address: 8857 East State Road 14, Akron, Indiana 46910
Mailing Address: 8857 East State Road 14, Akron, Indiana 46910
FESOP No.: F 049-19280-00008
Facility: One (1) paint room (EU-01)
Parameter: Total HAPs usage
Limit: Less than 24.0 tons per twelve (12) consecutive month period, with compliance determined at the end of each month

YEAR: _____

Month	Total HAPs Usage (tons)	Total HAPs Usage (tons)	Total HAPs Usage (tons)
	This Month	Previous 11 Months	12 Month Total

- No deviation occurred in this month.
- Deviation/s occurred in this month.
Deviation has been reported on _____

Submitted by: _____

Title/Position: _____

Signature: _____

Date: _____

Phone: _____

Attach a signed certification to complete this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE DATA SECTION**

**FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP)
QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT**

Source Name: Dragon/ESP-Midwest, Ltd.
Source Address: 8857 East State Road 14, Akron, Indiana 46910
Mailing Address: 8857 East State Road 14, Akron, Indiana 46910
FESOP No.: F 049-19280-00008

Months: _____ to _____ Year: _____

<p>This report shall be submitted quarterly based on a calendar year. Any deviation from the requirements, the date(s) of each deviation, the probable cause of the deviation, and the response steps taken must be reported. A deviation required to be reported pursuant to an applicable requirement that exists independent of the permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. Additional pages may be attached if necessary. If no deviations occurred, please specify in the box marked "No deviations occurred this reporting period".</p>	
<input type="checkbox"/> NO DEVIATIONS OCCURRED THIS REPORTING PERIOD.	
<input type="checkbox"/> THE FOLLOWING DEVIATIONS OCCURRED THIS REPORTING PERIOD	
Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	

Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	

Form Completed by: _____

Title / Position: _____

Date: _____

Phone: _____

A certification is not required for this report.

Indiana Department of Environmental Management Office of Air Quality

Technical Support Document (TSD) for a Significant Permit Revision to a Federally Enforceable State Operating Permit

Source Background and Description

Source Name:	Dragon/ESP-Midwest, Ltd.
Source Location:	8857 East State Road 14, Akron, Indiana 46910
County:	Fulton
SIC Code:	3444
Operation Permit No.:	F 049-19280-00008
Operation Permit Issuance Date:	September 1, 2004
Significant Permit Revision No.:	SPR 049-21673-00008
Permit Reviewer:	Craig J. Friederich

The Office of Air Quality (OAQ) has reviewed a significant permit revision application from Dragon/ESP-Midwest, Ltd. relating to the construction and operation of the following emission units and pollution control devices:

- (a) Forty Eight (48) welding stations, using Metal Inert Gas, capacity: 3.0 pounds of wire per station per hour.
- (b) Ten (10) oxyacetylene flame-cutting stations, capacity: 20.0 inches of 0.25 inch thick metal per minute, each.
- (c) One (1) plasma flame-cutting station, capacity: 20.0 inches of 1.00 inch thick metal per minute.

History

On August 23, 2005, Dragon/ESP-Midwest, Ltd. submitted an application to the OAQ requesting to add additional welding, oxyacetylene, and plasma flame-cutting stations. Dragon/ESP-Midwest, Ltd. was issued a Federally Enforceable State Operating Permit (FESOP) on September 1, 2004.

Enforcement Issue

There are no enforcement actions pending.

Stack Summary

There are no stacks associated with this revision.

Recommendation

The staff recommends to the Commissioner that the FESOP Significant Permit Revision be approved. This recommendation is based on the following facts and conditions:

Unless otherwise stated, information used in this review was derived from the application and additional information submitted by the applicant.

An application for the purposes of this review was received on August 23, 2005. Additional information was received on September 1, 2005.

Emission Calculations

See page 1 of 1 of Appendix A of this document for detailed emissions calculations.

Potential To Emit of Revision

Pursuant to 326 IAC 2-1.1-1(16), Potential to Emit is defined as “the maximum capacity of a stationary source to emit any air pollutant under its physical and operational design. Any physical or operational limitation on the capacity of a source to emit an air pollutant, including air pollution control equipment and restrictions on hours of operation or type or amount of material combusted, stored, or processed shall be treated as part of its design if the limitation is enforceable by the U.S. EPA.

This table reflects the PTE before controls for this revision. Control equipment is not considered federally enforceable until it has been required in a federally enforceable permit.

Pollutant	Potential To Emit (tons/year)
PM	5.62
PM ₁₀	5.62
SO ₂	--
VOC	--
CO	--
NO _x	--

HAPs	Potential To Emit (tons/year)
Manganese	0.315

Justification for Revision

The FESOP is being revised through a FESOP Significant Permit Revision. This revision is being performed pursuant to 326 IAC 2-8-11.1(g)(2), because this revision requires an adjustment to the FESOP emissions cap limitations.

County Attainment Status

The source is located in Fulton County.

Pollutant	Status
PM _{2.5}	attainment
PM ₁₀	attainment
SO ₂	attainment
NO ₂	attainment
1-Hour Ozone	attainment
8-Hour Ozone	attainment
CO	attainment
Lead	attainment

- (a) Volatile organic compounds (VOC) and nitrogen oxides (NO_x) are regulated under the Clean Air Act (CAA) for the purposes of attaining and maintaining the National Ambient Air Quality Standards (NAAQS) for ozone. Therefore, VOC and NO_x emissions are considered when evaluating the rule applicability relating to ozone. Fulton County has been designated as attainment or unclassifiable for ozone. Therefore, VOC and NO_x emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2. See the State Rule Applicability - Entire Source section of this document.
- (b) Fulton County has been classified as unclassifiable or attainment for PM_{2.5}. U.S. EPA has not yet established the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2 for PM_{2.5} emissions. Therefore, until the U.S.EPA adopts specific provisions for PSD review for PM_{2.5} emissions, it has directed states to regulate PM₁₀ emissions as surrogate for PM_{2.5} emissions. See the State Rule Applicability for the source section.
- (c) Fulton County has been classified as attainment or unclassifiable in Indiana for all criteria pollutants. Therefore, these emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2. See the State Rule Applicability - Entire Source section of this document.
- (d) Fugitive Emissions
 Since this type of operation is not one of the twenty-eight (28) listed source categories under 326 IAC 2-2 or 2-3 and since there are no applicable New Source Performance Standards that were in effect on August 7, 1980, the fugitive particulate matter (PM) and volatile organic compound (VOC) emissions are not counted toward determination of PSD and Emission Offset applicability.

Source Status

Existing Source PSD or Emission Offset Definition (emissions after controls, based upon 8,760 hours of operation per year at rated capacity and/or as otherwise limited):

Pollutant	Emissions (tons/year)
PM	112
PM ₁₀	Less than 100

Pollutant	Emissions (tons/year)
SO ₂	--
VOC	54.2
CO	0.045
NO _x	0.335

- (a) This existing source is not a major stationary source because no attainment regulated pollutant is emitted at a rate of two-hundred fifty (250) tons per year or more, and it is not one of the twenty-eight (28) listed source categories.
- (b) These emissions are based upon the TSD for FESOP 049-19280, issued September 1, 2004.

Potential to Emit of Revision After Issuance

The table below summarizes the potential to emit, reflecting all limits, of the significant emission units after controls. The control equipment is considered federally enforceable only after issuance of this FESOP revision.

Process/facility	Potential to Emit (tons/year)						
	PM	PM ₁₀	SO ₂	VOC	CO	NO _x	HAPs
Proposed Revision	5.62	5.62	--	--	--	--	0.315
PSD or Offset Threshold Level	250	250	250	250	250	250	-

This revision to an existing minor stationary source is not major because the emission increase is less than the PSD threshold levels. Therefore, pursuant to 326 IAC 2-2, the PSD requirements do not apply.

Revised Limited Potential to Emit

The following table was abstracted from the Technical Support Document for the Federally Enforceable State Operating Permit, 049-19280-00008, issued on September 1, 2004, and shows the revisions in the limited potential to emit of the existing emission units, using bold for additions and strikeouts for deletions.

Emission Unit	Limited Potential to Emit (tons/year)						
	PM	PM ₁₀	SO ₂	VOC	CO	NO _x	HAPs
Paint Room EU-01	77.8	69.9 55.0	0.00	54.2	0.00	0.00	single < 10 total < 25 24.0
Grit Blast Booth EU-02	32.4	27.8	0.00	0.00	0.00	0.00	0.00
Insignificant Activities	2.24 7.86	2.24 7.86	0.00	0.012	0.045	0.335	Negligible 0.315
Total Emissions	112 118	99.9 90.7	0.058	54.2	0.045	0.335	single < 10 total < 25 24.0

This revision to the existing FESOP will not change the status of the stationary source because the emissions from the entire source will still be limited to less than the Part 70 major source thresholds.

Federal Rule Applicability

- (a) There are no New Source Performance Standards (NSPS) (326 IAC 12 and 40 CFR Part 60) included in the permit for this proposed revision.
- (b) There are no National Emission Standards for Hazardous Air Pollutants (NESHAP)(326 IAC 14, 20 and 40 CFR Part 61, 63) included in the permit for this proposed revision.

State Rule Applicability - Individual Facilities

326 IAC 2-8-4 (FESOP)

Pursuant to this rule, the amount of PM₁₀ shall be limited to less than one hundred (100) tons per year. In addition, the amount of a single HAP shall be limited to less than ten (10) tons per year and the combination of all HAPs shall be limited to less than twenty-five (25) tons per year. Therefore, the requirements of 326 IAC 2-7 (Part 70 Operating Permits), do not apply. The addition of the insignificant welding, oxyacetylene, and plasma flame-cutting stations, with a potential to emit PM₁₀ of 5.62 tons per year, and the potential to emit Manganese of 0.315 tons per year, will require the existing limits to be adjusted for the source to retain their FESOP status.

- (a) The PM₁₀ emissions from the one (1) paint room (EU-01) shall be limited to less than 12.5 pounds per hour, which is equivalent to 55.0 tons per twelve (12) consecutive month period, with compliance determined at the end of each month. This limitation, combined with the unlimited potential emissions from the remaining equipment of 35.7 tons of PM₁₀ per year, will ensure that the PM₁₀ emissions from this source are less than one hundred (100) tons per year.
- (b) The total amount of any single HAP delivered to the applicators at the one (1) paint room (EU-01), including coatings, adhesives, dilution solvents and clean-up solvents, shall be limited to less than ten (10) tons per twelve (12) consecutive month period, with compliance determined at the end of each month. Also, the total amount of all HAPs delivered to the

applicators at the one (1) paint room (EU-01), including coatings, adhesives, dilution solvents and clean-up solvents, shall be limited to less than 24.0 tons per twelve (12) consecutive month period, with compliance determined at the end of each month.

326 IAC 6-3 (Particulate Emission Limitations for Manufacturing Processes)

- (a) The welding operations are exempt from the requirements of 326 IAC 6-3 because they consume less than 625 pounds of wire per day.
- (b) The oxyacetylene and plasma cutting operations are exempt from the requirements of 326 IAC 6-3 because less than 3,400 inches per hour of stock one (1) inch thickness or less is cut.

Compliance Requirements

Permits issued under 326 IAC 2-8 are required to ensure that sources can demonstrate compliance with applicable state and federal rules on a more or less continuous basis. All state and federal rules contain compliance provisions, however, these provisions do not always fulfill the requirement for a more or less continuous demonstration. When this occurs IDEM, OAQ, in conjunction with the source, must develop specific conditions to satisfy 326 IAC 2-8-4. As a result, compliance requirements are divided into two sections: Compliance Determination Requirements and Compliance Monitoring Requirements.

Compliance Determination Requirements in Section D of the permit are those conditions that are found more or less directly within state and federal rules and the violation of which serves as grounds for enforcement action. If these conditions are not sufficient to demonstrate continuous compliance, they will be supplemented with Compliance Monitoring Requirements, also in Section D of the permit.

Unlike Compliance Determination Requirements, failure to meet Compliance Monitoring conditions would serve as a trigger for corrective actions and not grounds for enforcement action. However, a violation in relation to a compliance monitoring condition will arise through a source's failure to take the appropriate corrective actions within a specific time period.

Proposed Changes

The permit language is changed to read as follows (deleted language appears as ~~strikeouts~~, new language appears in bold):

Change 1:

The addition of the welding and torch cutting is added as follows:

A.3 Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-8-3(c)(3)(I)]

This stationary source also includes the following insignificant activities, as defined in 326 IAC 2-7-1(21):

- (e) The following equipment related to manufacturing activities not resulting in the emission of HAPs: brazing equipment, cutting torches, soldering equipment, welding equipment.

One (1) welding, cutting and assembly process, capacity: ~~3,320~~ **9,960** pounds of steel per hour, consisting of the following equipment:

- (1) ~~Seven (7)~~ **Fifty-five (55)** welding stations, using Metal Inert Gas, capacity: 3.0 pounds of wire per station per hour.

- (2) ~~One (1) oxyacetylene flame-cutting station, capacity: 1.0 inch of 0.25 inch thick metal per minute.~~
- (2) **Ten (10) oxyacetylene flame-cutting stations, capacity: 20.0 inches of 0.25 inch thick metal per minute, each.**
- (3) **One (1) plasma flame-cutting station, capacity: 20.0 inches of 1.00 inch thick metal per minute.**

Change 2:

Since there are no specific emission limitations or standards which are applicable to the insignificant activities in Section D.2, that section has been removed as follows:

SECTION D.2 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-8-4(10)] Insignificant Activities

- ~~(a) Propane for liquefied petroleum gas, or butane fired combustion sources with heat input equal to or less than six million (6,000,000) British thermal units per hour, consisting of:
 - ~~(1) Two (2) space heaters, identified as H-1 and H-2, firing propane gas, capacity: 0.1 million British thermal units per hour, each.~~
 - ~~(2) One (1) space heater, identified as H-3, firing propane gas, capacity: 0.3 million British thermal units per hour.~~~~
- ~~(b) A gasoline fuel transfer and dispensing operation handling less than or equal to 1,300 gallons per day, such as filling of tanks, locomotives, automobiles, having a storage capacity less than or equal to 10,500 gallons.~~
- ~~(c) A petroleum fuel, other than gasoline, dispensing facility, having a storage capacity of less than or equal to 10,500 gallons, and dispensing less than or equal to 230,000 gallons per month.~~
- ~~(d) Machining where an aqueous cutting coolant continuously floods the machining interface.~~
- ~~(e) The following equipment related to manufacturing activities not resulting in the emission of HAPs: brazing equipment, cutting torches, soldering equipment, welding equipment.
 - ~~One (1) welding, cutting and assembly process, capacity: 3,320 pounds of steel per hour, consisting of the following equipment:
 - ~~(1) Seven (7) welding stations, using Metal Inert Gas, capacity: 3.0 pounds of wire per station per hour.~~
 - ~~(2) One (1) oxyacetylene flame-cutting station, capacity: 1.0 inch of 0.25 inch thick metal per minute.~~~~~~
- ~~(f) Replacement or repair of electrostatic precipitators, bags in baghouses and filters in other air filtration equipment.~~
- ~~(g) Paved and unpaved roads and parking lots with public access.~~

(h) ~~Blowdown for any of the following: sight glass; boiler; compressors; pumps; and cooling tower.~~

~~There are no specific emission limitations or standards applicable to these facilities.~~

Change 3:

The addition of the insignificant activities will require the existing FESOP limits on the paint room be revised, to ensure that the limited potential to emit of all criteria pollutants is less than the FESOP thresholds. The changes are as follows, with the changes to the Quarterly Report Forms shown at the end of this document:

D.1.6 FESOP Limits [326 IAC 2-8-4]

- (a) The PM₁₀ emissions from the one (1) paint room (EU-01) shall be limited to less than ~~45.9~~ **12.5** pounds per hour, which is equivalent to ~~69.9~~ **55.0** tons per twelve (12) consecutive month period, with compliance determined at the end of each month.
- (b) The total amount of any single HAP delivered to the applicators at the one (1) paint room (EU-01), including coatings, adhesives, dilution solvents and clean-up solvents, shall be limited to less than ten (10) tons per twelve (12) consecutive month period, with compliance determined at the end of each month.
- (c) The total amount of all HAPs delivered to the applicators at the one (1) paint room (EU-01), including coatings, adhesives, dilution solvents and clean-up solvents, shall be limited to less than ~~twenty-five (25)~~ **24.0** tons per twelve (12) consecutive month period, with compliance determined at the end of each month.

Change 4:

Indiana was required to incorporate credible evidence provisions into state rules consistent with the SIP call published by U.S. EPA in 1997 (62 FR 8314). Indiana has incorporated the credible evidence provision in 326 IAC 1-1-6. This rule is effective March 16, 2005; therefore, the condition reflecting this rule will be incorporated into the permit as follows:

B.23 Credible Evidence [326 IAC 2-8-4(3)][326 IAC 2-8-5][62 FR 8314] [326 IAC 1-1-6]

For the purpose of submitting compliance certifications or establishing whether or not the Permittee has violated or is in violation of any condition of this permit, nothing in this permit shall preclude the use, including the exclusive use, of any credible evidence or information relevant to whether the Permittee would have been in compliance with the condition of this permit if the appropriate performance or compliance test or procedure had been performed.

Conclusion

The construction and operation of this proposed revision shall be subject to the conditions of the attached proposed FESOP Significant Permit Revision No. 049-21673-00008.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
 OFFICE OF AIR QUALITY
 COMPLIANCE DATA SECTION**

FESOP Quarterly Report

Source Name: Dragon/ESP-Midwest, Ltd.
 Source Address: 8857 East State Road 14, Akron, Indiana 46910
 Mailing Address: 8857 East State Road 14, Akron, Indiana 46910
 FESOP No.: F 049-19280-00008
 Facility: One (1) paint room (EU-01)
 Parameter: Total HAPs usage
 Limit: Less than ~~twenty-five (25)~~ **24.0** tons per twelve (12) consecutive month period, with compliance determined at the end of each month

YEAR: _____

Month	Total HAPs Usage (tons)	Total HAPs Usage (tons)	Total HAPs Usage (tons)
	This Month	Previous 11 Months	12 Month Total

- No deviation occurred in this month.
- Deviation/s occurred in this month.
 Deviation has been reported on _____

Submitted by: _____
 Title/Position: _____
 Signature: _____
 Date: _____
 Phone: _____

Attach a signed certification to complete this report.

**Appendix A: Emissions Calculations
Welding and Thermal Cutting**

Company Name: Dragon/ESP - Midwest, Ltd.
Address City IN Zip: 8857 East State Road 14, Akron, Indiana 46910
Permit Number: 049-21673
Plt ID: 049-00008
Reviewer: Craig J. Friederich
Application Date: August 23, 2005

PROCESS	Number of Stations	Max. electrode consumption per station (lbs/hr)	EMISSION FACTORS* (lb pollutant/lb electrode)				EMISSIONS (lbs/hr)				HAPS (lbs/hr)	
			PM = PM10	Mn	Ni	Cr	PM = PM10	Mn	Ni	Cr		
WELDING												
Submerged Arc	0	0	0.036	0.011			0.000	0.000	0.000	0	0.000	
Metal Inert Gas (MIG)(carbon steel)	48	3	0.0055	0.0005			0.792	0.072	0.000	0	0.072	
Stick (E7018 electrode)	0	0	0.0211	0.0009			0.000	0.000	0.000	0	0.000	
Tungsten Inert Gas (TIG)(carbon steel)	0	0	0.0055	0.0005			0.000	0.000	0.000	0	0.000	
Oxyacetylene(carbon steel)	0	0	0.0055	0.0005			0.000	0.000	0.000	0	0.000	
FLAME CUTTING	Number of Stations	Max. Metal Thickness Cut (in.)	Max. Metal Cutting Rate (in./minute)	EMISSION FACTORS (lb pollutant/1,000 inches cut, 1" thick)**				EMISSIONS (lbs/hr)				HAPS (lbs/hr)
				PM = PM10	Mn	Ni	Cr	PM = PM10	Mn	Ni	Cr	
Oxyacetylene	10	0.25	20	0.1622	0.0005	0.0001	0.0003	0.487	0.000	0.000	0.000	0.000
Oxymethane	0	0	0	0.0815	0.0002		0.0002	0.000	0.000	0.000	0.000	0.000
Plasma**	1	1	20	0.0039				0.005	0.000	0.000	0.000	0.000
EMISSION TOTALS												
Potential Emissions lbs/hr								1.28	0.07	0.00	0.00	0.07
Potential Emissions lbs/day								30.80	1.73	0.00	0.00	1.73
Potential Emissions tons/year								5.62	0.32	0.00	0.00	0.315

METHODOLOGY

*Emission Factors are default values for carbon steel unless a specific electrode type is noted in the Process column.

**Emission Factor for plasma cutting from American Welding Society (AWS). Trials reported for wet cutting of 8 mm thick mild steel with 3.5 m/min cutting speed (at 0.2 g/min emitted). Therefore, the emission factor for plasma cutting is for 8 mm thick rather than 1 inch, and the maximum metal thickness is not used in calculating the emissions.

Using AWS average values: (0.25 g/min)/(3.6 m/min) x (0.0022 lb/g)/(39.37 in./m) x (1,000 in.) = 0.0039 lb/1,000 in. cut, 8 mm thick

Plasma cutting emissions, lb/hr: (# of stations)(max. cutting rate, in./min.)(60 min./hr.)(emission factor, lb. pollutant/1,000 in. cut, 8 mm thick)

Cutting emissions, lb/hr: (# of stations)(max. metal thickness, in.)(max. cutting rate, in./min.)(60 min./hr.)(emission factor, lb. pollutant/1,000 in. cut, 1" thick)

Welding emissions, lb/hr: (# of stations)(max. lbs of electrode used/hr/station)(emission factor, lb. pollutant/lb. of electrode used)

Emissions, lbs/day = emissions, lbs/hr x 24 hrs/day

Emissions, tons/yr = emissions, lb/hr x 8,760 hrs/year x 1 ton/2,000 lbs.

Welding and other flame cutting emission factors are from an internal training session document, "Welding and Flame Cutting". See Rebecca Mason if you need a copy.

Refer to AP-42, Chapter 12.19 for additional emission factors for welding.