

October 27, 2005



Daniel M. Wooley
John M. Wooley Lumber Company, Inc.
1789 S. Old State Road 67
Martinsville, IN 46151

VIA CERTIFIED MAIL: 7000 0600 0023 5187 3121

Re: Registered Construction and Operation Status,
097-21805-00568

Dear Mr. Wooley:

The application from John M. Wooley Lumber Company Inc., received on September 19, 2005, has been reviewed. Based on the data submitted and the provisions 326 IAC 2-5.5, it has been determined that the following 9.6 MMBtu/hr Hurst boiler, to be located at 1118 East 30th Street, Indianapolis, Indiana, is classified as registered:

- (a) One (1) 9.6 MMBtu/hr Hurst Boiler, identified as HYB 1345-150-1, fired with natural gas or wood, using no control, and exhausting to one (1) stack.

The following conditions shall be applicable:

1. Pursuant to 326 IAC 5-1-2 (Opacity Limitations) except as provided in 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following:
 - (a) Opacity shall not exceed an average of thirty percent (30%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
 - (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of 15 minutes (60 readings) in a 6-hour period as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor in a six (6) hour period.
2. Pursuant to 326 IAC 6-2-4 (Particulate Emission Limitations for Sources of Indirect Heating) Particulate emissions from the 9.6 MMBtu/hr boiler shall be limited by the following equation:

$$Pt = \frac{1.09}{Q^{0.26}}$$

Where: Pt = Pounds of particulate matter emitted per million Btu (lbs/MMBtu) heat input.
Q = Total source maximum operating capacity rating in million Btu (lbs/MMBtu) Heat input.

Q for this boiler and the source is 9.6 MMBtu/hr. For Q less than 10 MMBtu/hr, Pt shall not exceed 0.6.

**Department of Public Works
Office of Environmental Services**
2700 South Belmont Avenue (317) 327-2234
Indianapolis, Indiana 46221 (fax) 327-2274
(TDD) 325-5186
www.indygov.org

The source may operate according to 326 IAC 2-5.5. An authorized individual shall provide an annual notice to the Indiana Department of Environmental Management (IDEM) Office of Air Quality (OAQ) and the City of Indianapolis Office of Environmental Services (OES) that the source is in operation and in compliance with this registration pursuant to 326 IAC 2-5.5-4(a)(3). The annual notice shall be submitted to:

Compliance Data Section
Office of Air Quality
100 North Senate Avenue
Indianapolis, IN 46204-2251

and

Office of Environmental Service, Compliance Data Group
City of Indianapolis
2700 S. Belmont Avenue
Indianapolis, IN 46221

no later than March 1 of each year, with the annual notice being submitted in the format attached.

An application or notification shall be submitted in accordance with 326 IAC 2 to the Office of Air Quality (OAQ) and OES if the source proposes to construct new emission units, modify existing emission units, or otherwise modify the source.

Sincerely,

ORIGINAL SIGNED BY:

Felicia A. Robinson
Manager of Environmental Planning

FAR/an

cc: File
Air Compliance – Matt Mosier
Enforcement
IDEM, OAQ – Mindy Hahn
Marion County Health Department
US EPA Region V

Registration Annual Notification

This form should be used to comply with the notification requirements under **326 IAC 2-5.1-2(f)(3) or 326 IAC 2-5.5-4(a)(3)**

Company Name:	John M. Wooley Lumber Company, Inc.
Address:	1118 East 30th Street
City:	Indianapolis
Authorized individual:	Daniel Wooley
Phone #:	(765) 349-3299
Registration #:	097-21805-00568

I hereby certify that John M. Wooley Lumber Company is still in operation and is in compliance with the requirements of Registration 097-21805-00568.

Name (typed):
Title:
Signature:
Date: