



*Mitchell E. Daniels, Jr.*  
Governor

*Thomas W. Easterly*  
Commissioner

100 North Senate Avenue  
Indianapolis, Indiana 46204  
(317) 232-8603  
(800) 451-6027  
www.IN.gov/idem

TO: Interested Parties / Applicant  
DATE: March 23, 2006  
RE: Eli Lilly & Company / 063-22798-00053  
FROM: Nisha Sizemore  
Chief, Permits Branch  
Office of Air Quality

### Notice of Decision – Approval

Please be advised that on behalf of the Commissioner of the Department of Environmental Management, I have issued a decision regarding the enclosed matter. Pursuant to 326 IAC 2, this approval was effective immediately upon submittal of the application.

If you wish to challenge this decision, IC 4-21.5-3-7 requires that you file a petition for administrative review. This petition may include a request for stay of effectiveness and must be submitted to the Office of Environmental Adjudication, 100 North Senate Avenue, Government Center North, Room 1049, Indianapolis, IN 46204, **within eighteen (18) calendar days from the mailing of this notice**. The filing of a petition for administrative review is complete on the earliest of the following dates that apply to the filing:

- (1) the date the document is delivered to the Office of Environmental Adjudication (OEA);
- (2) the date of the postmark on the envelope containing the document, if the document is mailed to OEA by U.S. mail; or
- (3) The date on which the document is deposited with a private carrier, as shown by receipt issued by the carrier, if the document is sent to the OEA by private carrier.

The petition must include facts demonstrating that you are either the applicant, a person aggrieved or adversely affected by the decision or otherwise entitled to review by law. Please identify the permit, decision, or other order for which you seek review by permit number, name of the applicant, location, date of this notice and all of the following:

- (1) the name and address of the person making the request;
- (2) the interest of the person making the request;
- (3) identification of any persons represented by the person making the request;
- (4) the reasons, with particularity, for the request;
- (5) the issues, with particularity, proposed for considerations at any hearing; and
- (6) identification of the terms and conditions which, in the judgment of the person making the request, would be appropriate in the case in question to satisfy the requirements of the law governing documents of the type issued by the Commissioner.

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178. Callers from within Indiana may call toll-free at 1-800-451-6027, ext. 3-0178.

Enclosures  
FNPER-AM.dot 1/10/05



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We make Indiana a cleaner, healthier place to live.

Mitchell E. Daniels, Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
(800) 451-6027
www.IN.gov/idem

Mr. Brian Brown
Eli Lilly and Company
Lilly Corporate Center
Indianapolis, Indiana 46285

March 23, 2006

Re: 063-22798-00053
Notice Only Change to
063-19057-00053

Dear Mr. Brown:

Eli Lilly and Company was issued a Minor Source Operating Permit (MSOP) on October 18, 2004. Eli Lilly and Company submitted a request for an address change, a change in the phone number, a change in the Standard Industrial Classification code (SIC), and clarification of the back-up fuels used. The location address changed from Airwest Business Park, Stanley Road, Plainfield, Indiana, to 2222 Stanley Road, Airwest Business Park, due to re-addressing the buildings in the business park. The telephone number has been changed to the Plainfield site Manager's number from the Lilly Corporate Center Authorized Individual's number. The SIC code has been corrected from 2834 to 4225. 2834 is for pharmaceutical manufacturing. The Plainfield Distribution Center is not engaged in manufacturing; it is a warehouse only. The back-up fuel used with two (2) natural gas fired boilers has changed from No. 2 fuel oil to No. 1 and/or No. 2 back-up fuels. The source uses both No. 1 and No. 2 fuel oil and the emission factors are the same for both. These distillate oils will have no impact upon potential emissions or applicable requirements. The MSOP has been revised as follows (new language shown in bold and deleted language shown in strikeout.)

- 1. The address change affects the cover page, condition A.1, and the annual notification report. The SIC code is changed in condition A.1.

A.1 General Information [326 IAC 2-5.1-3(c)] [326 IAC 2-6.1-4(a)]

The Permittee owns and operates a stationary pharmaceutical distribution facility.

Authorized Individual: Manager, Distribution
Source Address: 2222 Stanley Road, Airwest Business Park, Stanley Road, Plainfield, Indiana, 46168
Mailing Address: Lilly Corporate Center, Indianapolis, Indiana, 46285
General Source Phone: (317) 276-3339 6211
SIC Code: 2834 4225
County Location: Hendricks
Source Location Status: Nonattainment for ozone under the 8-hour standard
Attainment for all other criteria pollutants
Source Status: Minor Source Operating Permit
Minor Source, under PSD and Nonattainment NSR;
Minor Source, Section 112 of the Clean Air Act
Not 1 of 28 Source Categories



**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE BRANCH**

**MINOR SOURCE OPERATING PERMIT  
ANNUAL NOTIFICATION**

This form should be used to comply with the notification requirements under 326 IAC 2-6.1-5(a)(5).

<b>Company Name:</b>	<b>Eli Lilly and Company Distribution Facility</b>
<b>Address:</b>	<b>2222 Stanley Road, Airwest Business Park, Stanley Road</b>
<b>City:</b>	<b>Plainfield, Indiana 46168</b>
<b>Phone #:</b>	<b>(317) 276-6211</b>
<b>MSOP #:</b>	<b>063-19057-00053</b>

I hereby certify that Eli Lilly and Company Distribution Facility is  still in operation.

no longer in operation.

I hereby certify that Eli Lilly and Company Distribution Facility is  in compliance with the requirements of MSOP 063-19057-00053

not in compliance with the requirements of MSOP 063-19057-00053

<b>Authorized Individual (typed):</b>
<b>Title:</b>
<b>Signature:</b>
<b>Date:</b>

If there are any conditions or requirements for which the source is not in compliance, provide a narrative description of how the source did or will achieve compliance and the date compliance was, or will be achieved.

<b>Noncompliance:</b>

2. The facility uses both No. 1 and No. 2 fuel oil, rather than just No. 2 fuel oil as currently stated in the permit. The emission factors for No. 1 and No. 2 fuel oils are the same and adding No. 1 will have no impact upon potential emissions or applicable requirements.

**A.2 Emission Units and Pollution Control Equipment Summary**

This stationary source is approved to construct and operate the following emission units and pollution control devices:

- (a) Two (2) natural gas fired boilers, identified as #1 and #2, using **No. 1 and/or** No. 2 fuel oils as **back-up fuels**, each with a maximum heat input capacity of 8.5 MMBtu/hr, and exhausting through one (1) common stack.
- (b) One (1) diesel fired emergency generator, identified as #EG-1, with a maximum power output of 2,922 horsepower and a maximum operating hours of 500 hrs/yr, and exhausting through stack EG-1.
- (c) One (1) diesel fired fire pump, identified as #DFP-1, with a maximum power output of 240 horsepower and a maximum operating hours of 500 hrs/yr, and exhausting through stack DFP-1.
- (d) One (1) fuel oil storage tank, identified as TK-1, with a maximum capacity of 10,000 gallons.
- (e) One (1) diesel storage tank, identified as TK-EGS-1, with a maximum capacity of 3,000 gallons.
- (f) One (1) diesel storage tank, identified as TK-DFP-1, with a maximum capacity of 350 gallons.

**SECTION D.1 FACILITY OPERATION CONDITIONS**

**Facility Description [326 IAC 2-6.1]:**

- (a) Two (2) natural gas fired boilers, identified as #1 and #2, using **No. 1 and/or** No. 2 fuel oil as **back-up fuels**, each with a maximum heat input capacity of 8.5 MMBtu/hr, and exhausting through one (1) common stack.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

This decision is subject to the Indiana Administrative Orders and Procedures Act IC 4-21.5-3.5

Sincerely,

Original signed by  
Nysa L. James, Section Chief  
Permits Branch  
Office of Air Quality

NLJ/clb

cc: File - Hendricks County  
Hendricks County Health Department  
Air Compliance Section Inspector: Vaughn Ison  
Permit Review Section 1- Cynthia Bymaster  
Billing, Licensing and Training Section - Chet Bohannon



Mitchell E. Daniels, Jr.  
Governor

Thomas W. Easterly  
Commissioner

100 North Senate Avenue  
Indianapolis, Indiana 46204  
(317) 232-8603  
(800) 451-6027  
www.IN.gov/idem

## NEW SOURCE CONSTRUCTION PERMIT AND MINOR SOURCE OPERATING PERMIT OFFICE OF AIR QUALITY

**Eli Lilly and Company Distribution Facility  
2222 Stanley Road, Airwest Business Park  
Plainfield, Indiana 46168**

(herein known as the Permittee) is hereby authorized to construct and operate subject to the conditions contained herein, the emission units described in Section A (Source Summary) of this permit.

This permit is issued to the above mentioned company under the provisions of 326 IAC 2-1.1, (326 IAC 2-5.1 if new source), 326 IAC 2-6.1 and 40 CFR 52.780, with conditions listed on the attached pages.

Operation Permit No.: MSOP 063-19057-00053	
Issued by: Original signed by Paul Dubenetzky, Branch Chief Office of Air Quality	Issuance Date: October 18, 2004 Expiration Date: October 18, 2009
Notice Only Change: 063-22798-00053	Pages Affected: 3, 12, and 14
Issued by: Original signed by Nysa L. James, Section Chief Office of Air Quality	Issuance Date: March 23, 2006 Expiration Date: October 18, 2009

## SECTION A SOURCE SUMMARY

This permit is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ). The information describing the source contained in conditions A.1 and A.2 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this permit pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

### A.1 General Information [326 IAC 2-5.1-3(c)] [326 IAC 2-6.1-4(a)]

---

The Permittee owns and operates a stationary pharmaceutical distribution facility.

Authorized Individual:	Manager, Distribution
Source Address:	2222 Stanley Road, Airwest Business Park, Plainfield, Indiana, 46168
Mailing Address:	Lilly Corporate Center, Indianapolis, Indiana, 46285
General Source Phone:	(317) 276-6211
SIC Code:	4225
County Location:	Hendricks
Source Location Status:	Nonattainment for ozone under the 8-hour standard Attainment for all other criteria pollutants
Source Status:	Minor Source Operating Permit Minor Source, under PSD and Nonattainment NSR; Minor Source, Section 112 of the Clean Air Act Not 1 of 28 Source Categories

### A.2 Emission Units and Pollution Control Equipment Summary

---

This stationary source is approved to construct and operate the following emission units and pollution control devices:

- (a) Two (2) natural gas fired boilers, identified as #1 and #2, using No. 1 and/or No. 2 fuel oil as back-up fuels, each with a maximum heat input capacity of 8.5 MMBtu/hr, and exhausting through one (1) common stack.
- (b) One (1) diesel fired emergency generator, identified as #EG-1, with a maximum power output of 2,922 horsepower and a maximum operating hours of 500 hrs/yr, and exhausting through stack EG-1.
- (c) One (1) diesel fired fire pump, identified as #DFP-1, with a maximum power output of 240 horsepower and a maximum operating hours of 500 hrs/yr, and exhausting through stack DFP-1.
- (d) One (1) fuel oil storage tank, identified as TK-1, with a maximum capacity of 10,000 gallons.
- (e) One (1) diesel storage tank, identified as TK-EGS-1, with a maximum capacity of 3,000 gallons.
- (f) One (1) diesel storage tank, identified as TK-DFP-1, with a maximum capacity of 350 gallons.

**SECTION D.1**

**FACILITY OPERATION CONDITIONS**

**Facility Description [326 IAC 2-6.1]:**

- (a) Two (2) natural gas fired boilers, identified as #1 and #2, using No. 1 and/or No. 2 as back-up fuels, each with a maximum heat input capacity of 8.5 MMBtu/hr, and exhausting through one (1) common stack.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

**Emission Limitations and Standards [326 IAC 2-6.1]**

**D.1.1 PM Emissions [326 IAC 6-2-4]**

---

Pursuant to 326 IAC 6-2-4(a) (PM Emissions for Sources of Indirect Heating), PM emissions from each of the boilers #1 and #2 shall not exceed 0.52 lbs/MMBtu.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE BRANCH**

**MINOR SOURCE OPERATING PERMIT  
ANNUAL NOTIFICATION**

This form should be used to comply with the notification requirements under 326 IAC 2-6.1-5(a)(5).

<b>Company Name:</b>	<b>Eli Lilly and Company Distribution Facility</b>
<b>Address:</b>	<b>2222 Stanley Road, Airwest Business Park</b>
<b>City:</b>	<b>Plainfield, Indiana 46168</b>
<b>Phone #:</b>	<b>(317) 276-6211</b>
<b>MSOP #:</b>	<b>063-19057-00053</b>

- I hereby certify that Eli Lilly and Company Distribution Facility is  still in operation.  
 no longer in operation.
- I hereby certify that Eli Lilly and Company Distribution Facility is  in compliance with the requirements of MSOP 063-19057-00053  
 not in compliance with the requirements of MSOP 063-19057-00053

<b>Authorized Individual (typed):</b>
<b>Title:</b>
<b>Signature:</b>
<b>Date:</b>

If there are any conditions or requirements for which the source is not in compliance, provide a narrative description of how the source did or will achieve compliance and the date compliance was, or will be achieved.

<b>Noncompliance:</b>