



Mitchell E. Daniels, Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
(800) 451-6027
www.IN.gov/idem

TO: Interested Parties / Applicant

DATE: December 28, 2005

RE: Hoosier Energy REC, Inc. / 125-23308-00001

FROM: Paul Dubenetzky
Chief, Permits Branch
Office of Air Quality

Notice of Decision – Approval

Please be advised that on behalf of the Commissioner of the Department of Environmental Management, I have issued a decision regarding the enclosed matter. Pursuant to 326 IAC 2, this approval was effective immediately upon submittal of the application.

If you wish to challenge this decision, IC 4-21.5-3-7 requires that you file a petition for administrative review. This petition may include a request for stay of effectiveness and must be submitted to the Office of Environmental Adjudication, 100 North Senate Avenue, Government Center North, Room 1049, Indianapolis, IN 46204, **within eighteen (18) calendar days from the mailing of this notice**. The filing of a petition for administrative review is complete on the earliest of the following dates that apply to the filing:

- (1) the date the document is delivered to the Office of Environmental Adjudication (OEA);
- (2) the date of the postmark on the envelope containing the document, if the document is mailed to OEA by U.S. mail; or
- (3) The date on which the document is deposited with a private carrier, as shown by receipt issued by the carrier, if the document is sent to the OEA by private carrier.

The petition must include facts demonstrating that you are either the applicant, a person aggrieved or adversely affected by the decision or otherwise entitled to review by law. Please identify the permit, decision, or other order for which you seek review by permit number, name of the applicant, location, date of this notice and all of the following:

- (1) the name and address of the person making the request;
- (2) the interest of the person making the request;
- (3) identification of any persons represented by the person making the request;
- (4) the reasons, with particularity, for the request;
- (5) the issues, with particularity, proposed for considerations at any hearing; and
- (6) identification of the terms and conditions which, in the judgment of the person making the request, would be appropriate in the case in question to satisfy the requirements of the law governing documents of the type issued by the Commissioner.

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178. Callers from within Indiana may call toll-free at 1-800-451-6027, ext. 3-0178.

Enclosures
FNPER-AM.dot 1/10/05



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We make Indiana a cleaner, healthier place to live.

Mitchell E. Daniels, Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
(800) 451-6027
www.IN.gov/idem

December 28, 2005

Mr. Karl Back, Ratts Station Manager
Hoosier Energy REC, Inc.- Ratts Generating Station
P.O. Box 908
Bloomington, IN 47402-0908

Re: **125-23308-00001**
First Administrative Amendment
Part 70 125-6932-00001

Dear Mr. Back:

Hoosier Energy REC, Inc. – Ratts Generating Station located at 6825 North Blackburn Road, Petersburg, Indiana was issued a Part 70 permit on June 29, 2004, for an electric generating station operation. A letter requesting a change in the Responsible Official was received on November 22, 2005. Pursuant to the provisions of 326 IAC 2-7-11, the permit is hereby administratively amended as follows (deletions are marked with a ~~strikeout~~ and the new information is in **bold**):

- 1. The responsible official has been changed in Section A.1 General Information. Because of potential future changes in personnel, and to avoid excessive administrative permit amendments, only job titles are being listed.

A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)]

The Permittee owns and operates a stationary electric generating station (**Ratts Generating Station**).

Responsible Official: ~~Manager, Power Production~~ **Ratts Station Manager**
Source Address: State Highway 57, Petersburg, Indiana 47567
Mailing Address: P.O. Box 908, Bloomington, IN 47402
General Source Phone Number: (812)876-2021
SIC Code: 4911
County Location: Pike
County Status: Attainment for all criteria pollutants
Source Status: Part 70 Source
PSD Major Source
Major Source, Section 112 of the Clean Air Act
1 of 28 Listed Source Categories



Affected Source under Title IV

The Ratts Station Manager position has been designated the Responsible Official replacing Manager, Power Production position. This position meets the requirements under 326 IAC 2-7-1(34)(A)(v) as a Responsible Official.

2. The mailing address of IDEM, Office of Air Quality (OAQ) has changed. All references in the permit to “Post Office Box 6015, Indianapolis, Indiana 46206-6015” have been changed to “**100 North Senate, Indianapolis, Indiana 46204-2251**”.

All other conditions of the permit shall remain unchanged and in effect. Please find enclosed a copy of the revised Part 70 permit.

This decision is subject to the Indiana Administrative Orders and Procedures Act - IC 4-21.5-3-5. If you have any questions on this matter, please contact Janet Mobley, of my staff, at 317-232-8369 or 1-800-451-6027 extension 2-8369.

Sincerely,
Original signed by

Paul Dubenetzky
Assistant Commissioner
Office of Air Quality

PD/jm

Enclosure: Revised Permit

cc: File - Pike County

Pike County Health Department
Air Compliance Section – Dan Hancock
IDEM Southwest Regional Office
Permit Review Section II – Janet Mobley



Mitchell E. Daniels, Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204-2251
(317) 232-8603
(800) 451-6027
www.IN.gov/idem

PART 70 OPERATING PERMIT OFFICE OF AIR QUALITY

Hoosier Energy Rural Electric Cooperative (REC), Inc. Ratts Generating Station State Highway 57 Petersburg, Indiana 47567

(herein known as the Permittee) is hereby authorized to operate subject to the conditions contained herein, the source described in Section A (Source Summary) of this permit. The Permittee must comply with all conditions of this permit. Noncompliance with any provisions of this permit is grounds for enforcement action; permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. Noncompliance with any provision of this permit, except any provision specifically designated as not federally enforceable, constitutes a violation of the Clean Air Act. It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. An emergency does constitute an affirmative defense in an enforcement action provided the Permittee complies with the applicable requirements set forth in Section B, Emergency Provisions.

This permit is issued in accordance with 326 IAC 2 and 40 CFR Part 70 Appendix A and contains the conditions and provisions specified in 326 IAC 2-7 as required by 42 U.S.C. 7401, et. seq. (Clean Air Act as amended by the 1990 Clean Air Act Amendments), 40 CFR Part 70.6, IC 13-15 and IC 13-17.

Operation Permit No.: T125-6932-00001	
Issued by: Janet G. McCabe, Assistant Commissioner Office of Air Quality	Issuance Date: June 29, 2004 Expiration Date: June 29, 2009

First Administrative Amendment No.: 125-23308-00001	Page Affected: 5
Issued by: Origin signed by Paul Dubenetzky, Assistant Commissioner Office of Air Quality	Issuance Date: December 28, 2005 Expiration Date: June 29, 2009



TABLE OF CONTENTS

A SOURCE SUMMARY

- A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)]
- A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)]
- A.3 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-7-4(c)]
[326 IAC 2-7-5(15)]
- A.4 Part 70 Permit Applicability [326 IAC 2-7-2]

B GENERAL CONDITIONS

- B.1 Definitions [326 IAC 2-7-1]
- B.2 Permit Term [326 IAC 2-7-5(2)] [326 IAC 2-1.1-9.5]
- B.3 Enforceability [326 IAC 2-7-7]
- B.4 Termination of Right to Operate [326 IAC 2-7-10] [326 IAC 2-7-4(a)]
- B.5 Severability [326 IAC 2-7-5(5)]
- B.6 Property Rights or Exclusive Privilege [326 IAC 2-7-5(6)(D)]
- B.7 Duty to Provide Information [326 IAC 2-7-5(6)(E)]
- B.8 Certification [326 IAC 2-7-4(f)] [326 IAC 2-7-6(1)] [326 IAC 2-7-5(3)(C)]
- B.9 Annual Compliance Certification [326 IAC 2-7-6(5)]
- B.10 Preventive Maintenance Plan (PMP) [326 IAC 2-7-5(1),(3)and (13)]
[326 IAC 2-7-6(1)and(6)]
- B.11 Emergency Provisions [326 IAC 2-7-16]
- B.12 Permit Shield [326 IAC 2-7-15] [326 IAC 2-7-20] [326 IAC 2-7-12]
- B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5]
- B.14 Deviations from Permit Requirements and Conditions [326 IAC 2-7-5(3)(C)(ii)]
- B.15 Permit Modification, Reopening, Revocation and Reissuance, or Termination
[326 IAC 2-7-5(6)(C)] [326 IAC 2-7-8(a)] [326 IAC 2-7-9]
- B.16 Permit Renewal [326 IAC 2-7-4]
- B.17 Source Modification [326 IAC 2-7-10.5]
- B.18 Permit Amendment or Modification [326 IAC 2-7-11] [326 IAC 2-7-12] [40 CFR 72]
- B.19 Permit Revision under Economic Incentives and Other Programs [326 IAC 2-7-5(8)]
[326 IAC 2-7-12(b)(2)]
- B.20 Operational Flexibility [326 IAC 2-7-20] [326 IAC 2-7-10.5]
- B.21 Inspection and Entry [326 IAC 2-7-6] [IC 13-30-3-1](#) [[IC 13-17-3-2](#)]
- B.22 Transfer of Ownership or Operational Control [326 IAC 2-7-11]
- B.23 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-7-5(7)] [326 IAC 2-1.1-7]
- B.24 [Credible Evidence](#) [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [62 FR 8314]

C SOURCE OPERATION CONDITIONS

- Emission Limitations and Standards [326 IAC 2-7-5(1)]**
- C.1 Particulate Matter Emission Limitations for Processes with Process Weight Rates Less
Than One Hundred (100) pounds per hour [[40 CFR 52 Subpart P](#)] [326 IAC 6-3-2]
- C.2 Opacity [326 IAC 5-1]
- C.3 Open Burning [326 IAC 4-1] [[IC 13-17-9](#)]
- C.4 Incineration [326 IAC 4-2] [326 IAC 9-1-2]
- C.5 Fugitive Dust Emissions [326 IAC 6-4]
- C.6 Stack Height [326 IAC 1-7]
- C.7 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61.140, Subpart M]
- Testing Requirements [326 IAC 2-7-6(1)]**
- C.8 Performance Testing [326 IAC 3-6]
- Compliance Requirements [326 IAC 2-1.1-11]**
- C.9 Compliance Requirements [326 IAC 2-1.1-11]

- Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]**
- C.10 Compliance Monitoring [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]
- C.11 Maintenance of Opacity Monitoring Equipment [326 IAC 2-7-5(3)(A)(iii)]
- C.12 Maintenance of Continuous Emission Monitoring Equipment [326 IAC 2-7-5(3)(A)(iii)]
- C.13 Monitoring Methods [326 IAC 3] [40 CFR 60] [40 CFR 63]
- C.14 Pressure Gauge and Other Instrument Specifications [326 IAC 2-1.1-11]
[326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]
- Corrective Actions and Response Steps [326 IAC 2-7-5] [326 IAC 2-7-6]**
- C.15 Emergency Reduction Plan (ERP) [326 IAC 1-5-2] [326 IAC 1-5-3]
- C.16 Risk Management Plan (RMP) [326 IAC 2-7-5(12)] [40 CFR 68.215]
- C.17 Compliance Response Plan (CRP) - Preparation, Implementation, Records, and Reports
[326 IAC 2-7-5] [326 IAC 2-7-6]
- C.18 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5]
[326 IAC 2-7-6]
- Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**
- C.19 Emission Statement [326 IAC 2-7-5(3)(C)(iii)] [326 IAC 2-7-5(7)] [326 IAC 2-7-19(c)]
[326 IAC 2-6]
- C.20 General Record Keeping Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-6]
- C.21 General Reporting Requirements [326 IAC 2-7-5(3)(C)] [326 IAC 2-1.1-11]
- Stratospheric Ozone Protection**
- C.22 Compliance with 40 CFR 82 and 326 IAC 22-1
- Ambient Monitoring Requirements [326 IAC 7-3]**
- C.23 Ambient Monitoring [326 IAC 7-3]
- Part 2 MACT Application Submittal Requirement**
- C.24 Application Requirements for Section 112(j) of the Clean Air Act [40 CFR 63.52(e)]
[326 IAC 2-7-12]

D.1 FACILITY OPERATION CONDITIONS

- Emission Limitations and Standards [326 IAC 2-7-5(1)]**
- D.1.1 Particulate Emission Limitations [326 IAC 6-2-3]
- D.1.2 Opacity Exemption [326 IAC 5-1-3]
- D.1.3 Sulfur Dioxide (SO₂) [326 IAC 7-1.1] [326 IAC 7-1.1-2(a)(1)]
- D.1.4 Operation Standards [326 IAC 2-1.1-5(a)(4)] [40 CFR 261] [329 IAC 13]
- D.1.5 Preventive Maintenance Plan (PMP) [326 IAC 2-7-5(13)]
- Compliance Determination Requirements**
- D.1.6 Testing Requirements [326 IAC 2-7-6(1),(6)] [326 IAC 2-1.1-11]
- D.1.7 Operation of Electrostatic Precipitator (ESP) [326 IAC 2-7-6(6)]
- D.1.8 Continuous Emissions Monitoring [326 IAC 3-5]
- D.1.9 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 2-7-5(A)] [326 IAC 2-7-6]
[326 IAC 3] [326 IAC 7]
- D.1.10 Cleaning Waste Analysis [326 IAC 2-1.1-5(a)(4)] [40 CFR 261]
- Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]**
- D.1.11 Opacity Readings [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]
- D.1.12 Transformer-Rectifier (T-R) Sets [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
- Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**
- D.1.13 Record Keeping Requirements
- D.1.14 Reporting Requirements
- Nitrogen Oxides Monitoring Requirement [326 IAC 10-4-4]**
- D.1.15 Nitrogen Oxides Monitoring Requirement [326 IAC 10-4-4(b)(1)]
[326 IAC 10-4-12(b) and (c)] [40 CFR 75] [326 IAC 10-4-4(a)(1)] [326 IAC 10-4-7]

D.2 FACILITY OPERATION CONDITIONS

Emission Limitations and Standards [326 IAC 2-7-5(1)]

- D.2.1 Particulate Matter (PM) [326 IAC 6-2-3]
- D.2.2 Opacity Exemption [326 IAC 5-1-3]
- D.2.3 Preventive Maintenance Plan (PMP) [326 IAC 2-7-5(13)]

Compliance Determination Requirements

None

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- D.2.4 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

- D.2.5 Record Keeping Requirements
- D.2.6 National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers and Process Heaters [326 IAC 20-1][40 CFR Part 63, Subpart A] [40 CFR Part 63, Subpart DDDDD]
- D.2.7 Requirement to Submit a Significant Permit Modification Application [326 IAC 2-7-12] [326 IAC 2-7-5]

D.3 FACILITY OPERATION CONDITIONS

Emission Limitations and Standards [326 IAC 2-7-5(1)]

- D.3.1 Particulate Emissions Limitations (PM) [326 IAC 6-3-2]
- D.3.2 Fugitive Dust Emissions [326 IAC 6-4]
- D.3.3 Preventive Maintenance Plan (PMP) [326 IAC 2-7-5(13)]

Compliance Determination Requirements

None

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

None

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

None

D.4 FACILITY OPERATION CONDITIONS

Emission Limitations and Standards [326 IAC 2-7-5(1)]

- D.4.1 Particulate Emission Limitations [326 IAC 6-3-2]
- D.4.2 Volatile Organic Compounds (VOC) [326 IAC 8-3-2] [326 IAC 8-3-5(a)(b)]

Compliance Determination Requirements

None

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

None

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

None

E ACID RAIN PROGRAM CONDITIONS

- E.1 Acid Rain Permit [326 IAC 2-7-5(1)(C)] [326 IAC 21] [49 CFR 78]
- E.2 Title IV Emissions Allowances [326 IAC 2-7-5(4)]

Appendix A: Phase II Acid Rain Permit AR125-5060-00005

Part 70 Operating Permit Certification

Part 70 Operating Permit Emergency Occurrence Report

Part 70 Operating Permit Quarterly Deviation and Compliance Monitoring Report

Part 70 Operating Permit Quarterly SO₂ Emission Rate Report

SECTION A SOURCE SUMMARY

This permit is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ). The information describing the source contained in conditions A.1 through A.3 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this permit pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)]

The Permittee owns and operates a stationary electric generating station ([Ratts Generating Station](#)).

Responsible Official:	Ratts Station Manager
Source Address:	State Highway 57, Petersburg, Indiana 47567
Mailing Address:	P.O. Box 908, Bloomington, IN 47402
General Source Phone Number:	(812)876-2021
SIC Code:	4911
County Location:	Pike
County Status:	Attainment for all criteria pollutants
Source Status:	Part 70 Source PSD Major Source Major Source, Section 112 of the Clean Air Act 1 of 28 Listed Source Categories Affected Source under Title IV

A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)] [326 IAC 2-7-5(15)]

This stationary source consists of the following emission units and pollution control devices:

- (a) One (1) pulverized coal-fired dry bottom boiler, identified as Boiler #1, constructed in 1970, rated at 1160 million Btu per hour energy input, used to generate up to 132 megawatts (gross) of electricity at the above location.

Particulate matter emissions are controlled by an electrostatic precipitator, emissions are measured with a continuous opacity monitor.

NOx emissions are inhibited by a Low NOx Burner.

Controlled boiler emissions are exhausted to the atmosphere through a 300 foot tall chimney with an 11 foot exit diameter.

- (b) One (1) pulverized coal-fired dry bottom boiler, identified as Boiler #2, constructed in 1970, rated at 1160 million Btu per hour energy input, used to generate up to 132 megawatts (gross) of electricity at the above location.

Particulate matter emissions are controlled by an electrostatic precipitator, emissions are measured with a continuous opacity monitor.

NOx emissions are inhibited by a Low NOx Burner.

Controlled boiler emissions are exhausted to the atmosphere through a 300 foot tall chimney with an 11 foot exit diameter.

- (c) One (1) distillate oil #2-fired auxiliary boiler, constructed in 1970, with a heat input rate of 20.0 mmBtu/hr and with no control equipment and exhausting to stack SV3.
- (d) One (1) coal storage and handling system, with a maximum throughput of 890,000 tons of coal per year consisting of the following systems:
 - (1) One (1) 2.23 acre outdoor coal storage pile with a storage capacity of 40,000 tons.
 - (2) One (1) enclosed conveyor system, with enclosures for dust control. This system has a maximum throughput of 890,000 tons/year.
 - (3) Four (4) receiving systems, where shipments of coal are discharged into one (1) of the following systems:
 - (A) Off site supplied Coal Conveyor Delivery
 - (B) Train Delivery to Hoppers
 - (C) Truck Delivery to Hoppers
 - (D) Truck Deliver to Dead Storage Piles
- (e) Fugitive emissions from vehicle traffic. A combination of roads include paved asphalt or paved concrete and unpaved stone or unpaved gravel.

A.3 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-7-4(c)]
[326 IAC 2-7-5(15)]

This stationary source also includes the following insignificant activities which are specifically regulated, as defined in 326 IAC 2-7-1(21):

- (a) Degreasing operations that do not exceed 145 gallons per 12 months.
[326 IAC 8-3-2] [326 IAC 8-3-5]
- (b) Equipment related to manufacturing activities not resulting in the emission of HAPs: brazing equipment, cutting torches, soldering equipment, welding equipment.
[326 IAC 6-3-2]
- (c) Grinding and machining operations controlled with fabric filters, scrubbers, mist collectors, wet collectors and electrostatic precipitators with a design grain loading of less than or equal to 0.03 grains per actual cubic foot and a gas flow rate less than or equal to 4,000 actual cubic feet per minute, including the following: deburring, buffing, polishing, abrasive blasting, pneumatic conveying, and woodworking operations.
[326 IAC 6-3-2]

A.4 Part 70 Permit Applicability [326 IAC 2-7-2]

This stationary source is required to have a Part 70 permit by 326 IAC 2-7-2 (Applicability) because:

- (a) It is a major source, as defined in 326 IAC 2-7-1(22).
- (b) It is an affected source under Title IV (Acid Deposition Control) of the Clean Air Act, as

defined in 326 IAC 2-7-1(3).

- (c) It is a source in a source category designated by the United States Environmental Protection Agency (U.S. EPA) under 40 CFR 70.3 (Part 70 - Applicability).

SECTION B

GENERAL CONDITIONS

B.1 Definitions [326 IAC 2-7-1]

Terms in this permit shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, the applicable definitions found in the statutes or regulations (IC 13-11, 326 IAC 1-2 and 326 IAC 2-7) shall prevail.

B.2 Permit Term [326 IAC 2-7-5(2)] [326 IAC 2-1.1-9.5]

This permit is issued for a fixed term of five (5) years from the [issuance date of this permit](#), as determined in accordance with IC 4-21.5-3-5(f) and IC 13-15-5-3. Subsequent revisions, modifications, or amendments of this permit do not affect the expiration date of this permit or of permits issued pursuant to Title IV of the Clean Air Act and 326 IAC 21 (Acid Deposition Control).

B.3 Enforceability [326 IAC 2-7-7]

Unless otherwise stated, all terms and conditions in this permit, including any provisions designed to limit the source's potential to emit, are enforceable by IDEM, the United States Environmental Protection Agency (U.S. EPA) and by citizens in accordance with the Clean Air Act.

B.4 Termination of Right to Operate [326 IAC 2-7-10] [326 IAC 2-7-4(a)]

The Permittee's right to operate this source terminates with the expiration of this permit unless a timely and complete renewal application is submitted at least nine (9) months prior to the date of expiration of the source's existing permit, consistent with 326 IAC 2-7-3 and 326 IAC 2-7-4(a).

B.5 Severability [326 IAC 2-7-5(5)]

The provisions of this permit are severable; a determination that any portion of this permit is invalid shall not affect the validity of the remainder of the permit.

B.6 Property Rights or Exclusive Privilege [326 IAC 2-7-5(6)(D)]

This permit does not convey any property rights of any sort, or any exclusive privilege.

B.7 Duty to Provide Information [326 IAC 2-7-5(6)(E)]

- (a) [The Permittee shall furnish to IDEM, OAQ, within a reasonable time, any information that IDEM, OAQ, may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The submittal by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1\(34\). Upon request, the Permittee shall also furnish to IDEM, OAQ, copies of records required to be kept by this permit.](#)
- (b) [For information furnished by the Permittee to IDEM, OAQ, the Permittee may include a claim of confidentiality in accordance with 326 IAC 17.1. When furnishing copies of requested records directly to U. S. EPA, the Permittee may assert a claim of confidentiality in accordance with 40 CFR 2, Subpart B.](#)

B.8 Certification [326 IAC 2-7-4(f)] [326 IAC 2-7-6(1)] [326 IAC 2-7-5(3)(C)]

- (a) [Where specifically designated by this permit or required by an applicable requirement, any application form, report, or compliance certification submitted shall contain certification by a responsible official of truth, accuracy, and completeness. This certification shall state](#)

that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

- (b) One (1) certification shall be included, using the attached Certification Form, with each submittal requiring certification. One (1) certification can cover multiple forms in one (1) submittal.
- (c) A responsible official is defined at 326 IAC 2-7-1(34).

B.9 Annual Compliance Certification [326 IAC 2-7-6(5)]

- (a) The Permittee shall annually submit a compliance certification report which addresses the status of the source's compliance with the terms and conditions contained in this permit, including emission limitations, standards, or work practices. The initial certification shall cover the time period from the date of final permit issuance through December 31 of the same year. All subsequent certifications shall cover the time period from January 1 to December 31 of the previous year, and shall be submitted in letter form no later than July 1 of each year to:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V
Air and Radiation Division, Air Enforcement Branch - Indiana (AE-17J)
77 West Jackson Boulevard
Chicago, Illinois 60604-3590

- (b) The annual compliance certification report required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.
- (c) The annual compliance certification report shall include the following:
 - (1) The appropriate identification of each term or condition of this permit that is the basis of the certification;
 - (2) The compliance status;
 - (3) Whether compliance was continuous or intermittent; and
 - (4) The methods used for determining the compliance status of the source, currently and over the reporting period consistent with 326 IAC 2-7-5(3); and

The submittal by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

B.10 Preventive Maintenance Plan (PMP) [326 IAC 2-7-5(1),(3) and (13)] [326 IAC 2-7-6(1) and (6)]
[326 IAC 1-6-3]

- (a) If required by specific condition(s) in Section D of this permit, the Permittee shall prepare and maintain Preventive Maintenance Plans (PMPs) within ninety (90) days after issuance of this permit, including the following information on each facility:
- (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;
 - (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
 - (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

If, due to circumstances beyond the Permittee's control, the PMPs cannot be prepared and maintained within the above time frame, the Permittee may extend the date an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

The PMP extension notification does not require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

- (b) The Permittee shall implement the PMPs, [including any required record keeping](#), as necessary to ensure that failure to implement a PMP does not cause or contribute to an [exceedance](#) of any limitation on emissions or potential to emit.
- (c) A copy of the PMPs shall be submitted to IDEM, OAQ, upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. IDEM, OAQ, may require the Permittee to revise its PMPs whenever lack of proper maintenance causes or [is the primary contributor to an exceedance of any limitation on emissions or potential to emit](#). The PMP does not require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).
- (d) [To the extent the Permittee is required by 40 CFR Part 60 or 40 CFR Part 63 to have an Operation, Maintenance, and Monitoring \(OMM\) Plan for a unit, such Plan is deemed to satisfy the PMP requirements of 326 IAC 1-6-3 for that unit.](#)

The [PMP extension](#) notification [does](#) not require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

B.11 Emergency Provisions [326 IAC 2-7-16]

- (a) An emergency, as defined in 326 IAC 2-7-1(12), is not an affirmative defense for an action brought for noncompliance with a federal or state health-based emission limitation.
- (b) An emergency, as defined in 326 IAC 2-7-1(12), constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limitation if the

affirmative defense of an emergency is demonstrated through properly signed, contemporaneous operating logs or other relevant evidence that describe the following:

- (1) An emergency occurred and the Permittee can, to the extent possible, identify the causes of the emergency;
- (2) The permitted facility was at the time being properly operated;
- (3) During the period of an emergency, the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards or other requirements in this permit;
- (4) For each emergency lasting one (1) hour or more, the Permittee notified IDEM, OAQ within four (4) daytime business hours after the beginning of the emergency, or after the emergency was discovered or reasonably should have been discovered;

Telephone Number: 1-800-451-6027 (ask for Office of Air Quality, Compliance Section), or
Telephone Number: 317-233-5674 (ask for Compliance Section)
Facsimile Number: 317-233-5967.

- (5) For each emergency lasting one (1) hour or more, the Permittee submitted the attached Emergency Occurrence Report Form or its equivalent, either by mail or facsimile to:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

within two (2) working days of the time when emission limitations were exceeded due to the emergency.

The notice fulfills the requirement of 326 IAC 2-7-5(3)(C)(ii) and must contain the following:

- (A) A description of the emergency;
- (B) Any steps taken to mitigate the emissions; and
- (C) Corrective actions taken.

The notification which shall be submitted by the Permittee does not require the certification by the “responsible official” as defined by 326 IAC 2-7-1(34).

- (6) The Permittee immediately took all reasonable steps to correct the emergency.
- (c) In any enforcement proceeding, the Permittee seeking to establish the occurrence of an emergency has the burden of proof.
 - (d) This emergency provision supersedes 326 IAC 1-6 (Malfunctions). This permit condition is in addition to any emergency or upset provision contained in any applicable

requirement.

- (e) IDEM, OAQ, may require that the Preventive Maintenance Plans (PMPs) required under 326 IAC 2-7-4-(c)(9) be revised in response to an emergency.
- (f) Failure to notify IDEM, OAQ, by telephone or facsimile of an emergency lasting more than one (1) hour in accordance with (b)(4) and (5) of this condition shall constitute a violation of 326 IAC 2-7 and any other applicable rules.
- (g) If the emergency situation causes a deviation from a technology-based limit, the Permittee may continue to operate the affected emitting facilities during the emergency provided the Permittee immediately takes all reasonable steps to correct the emergency and minimize emissions.
- (h) [The Permittee shall include all emergencies in the Quarterly Deviation and Compliance Monitoring Report.](#)

B.12 Permit Shield [326 IAC 2-7-15] [326 IAC 2-7-20] [326 IAC 2-7-12]

- (a) Pursuant to 326 IAC 2-7-15, the Permittee has been granted a permit shield. The permit shield provides that compliance with the conditions of this permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that either the applicable requirements are included and specifically identified in this permit or the permit contains an explicit determination or concise summary of a determination that other specifically identified requirements are not applicable. The Indiana statutes from IC 13 and rules from 326 IAC, referenced in conditions in this permit, are those applicable at the time the permit was issued. The issuance or possession of this permit shall not alone constitute a defense against an alleged violation of any law, regulation or standard, except for the requirement to obtain a Part 70 permit under 326 IAC 2-7 or for applicable requirements for which a permit shield has been granted.

This permit shield does not extend to applicable requirements which are promulgated after the date of issuance of this permit unless this permit has been modified to reflect such new requirements.

- (b) If, after issuance of this permit, it is determined that the permit is in nonconformance with an applicable requirement that applied to the source on the date of permit issuance, IDEM, OAQ, shall immediately take steps to reopen and revise this permit and issue a compliance order to the Permittee to ensure expeditious compliance with the applicable requirement until the permit is reissued. The permit shield shall continue in effect so long as the Permittee is in compliance with the compliance order.
- (c) No permit shield shall apply to any permit term or condition that is determined after issuance of this permit to have been based on erroneous information supplied in the permit application. Erroneous information means information that the Permittee knew to be false, or in the exercise of reasonable care should have been known to be false, at the time the information was submitted.
- (d) Nothing in 326 IAC 2-7-15 or in this permit shall alter or affect the following:
 - (1) The provisions of Section 303 of the Clean Air Act (emergency orders), including the authority of the U.S. EPA under Section 303 of the Clean Air Act;

- (2) The liability of the Permittee for any violation of applicable requirements prior to or at the time of this permit's issuance;
 - (3) The applicable requirements of the acid rain program, consistent with Section 408(a) of the Clean Air Act; and
 - (4) The ability of U.S. EPA to obtain information from the Permittee under Section 114 of the Clean Air Act.
- (e) This permit shield is not applicable to any change made under 326 IAC 2-7-20(b)(2) (Sections 502(b)(10) of the Clean Air Act changes) and 326 IAC 2-7-20(c)(2) (trading based on State Implementation Plan (SIP) provisions).
- (f) This permit shield is not applicable to modifications eligible for group processing until after IDEM, OAQ, has issued the modifications. [326 IAC 2-7-12(c)(7)]
- (g) This permit shield is not applicable to minor Part 70 permit modifications until after IDEM, OAQ, has issued the modification. [326 IAC 2-7-12(b)(8)]

B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5]

- (a) All terms and conditions of previous permits issued pursuant to permitting programs approved into the state implementation plan have been either
- (1) incorporated as originally stated,
 - (2) revised, or
 - (3) deleted
- by this permit.
- (b) All previous registrations and permits are superseded by this permit, except for permits issued pursuant to Title IV of the Clean Air Act or 326 IAC 21 (Acid Deposition Control).

B.14 Deviations from Permit Requirements and Conditions [326 IAC 2-7-5(3)(C)(ii)]

- (a) Deviations from any permit requirements (for emergencies see Section B - Emergency Provisions), the probable cause of such deviations, and any response steps or preventive measures taken shall be reported to:

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

using the attached Quarterly Deviation and Compliance Monitoring Report, or its equivalent. A deviation required to be reported pursuant to an applicable requirement that exists independent of this permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report.

- The Quarterly Deviation and Compliance Monitoring Report does require the certification by the “responsible official” as defined by 326 IAC 2-7-1(34).
- (b) A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit.

B.15 Permit Modification, Reopening, Revocation and Reissuance, or Termination
[326 IAC 2-7-5(6)(C)] [326 IAC 2-7-8(a)] [326 IAC 2-7-9]

- (a) This permit may be modified, reopened, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a Part 70 permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any condition of this permit. [326 IAC 2-7-5(6)(C)] The notification by the Permittee does require the certification by the “responsible official” as defined by 326 IAC 2-7-1(34).
- (b) This permit shall be reopened and revised under any of the circumstances listed in IC 13-15-7-2 or if IDEM, OAQ, determines any of the following:
- (1) That this permit contains a material mistake.
 - (2) That inaccurate statements were made in establishing the emissions standards or other terms or conditions.
 - (3) That this permit must be revised or revoked to assure compliance with an applicable requirement. [326 IAC 2-7-9(a)(3)]
- (c) Proceedings by IDEM, OAQ, to reopen and revise this permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of this permit for which cause to reopen exists. Such reopening and revision shall be made as expeditiously as practicable. [326 IAC 2-7-9(b)]
- (d) The reopening and revision of this permit, under 326 IAC 2-7-9(a), shall not be initiated before notice of such intent is provided to the Permittee by IDEM, OAQ at least thirty (30) days in advance of the date this permit is to be reopened, except that IDEM, OAQ, may provide a shorter time period in the case of an emergency. [326 IAC 2-7-9(c)]

B.16 Permit Renewal [326 IAC 2-7-3] [326 IAC 2-7-4]

- (a) The application for renewal shall be submitted using the application form or forms prescribed by IDEM, OAQ, and shall include the information specified in 326 IAC 2-7-4. Such information shall be included in the application for each emission unit at this source, except those emission units included on the trivial or insignificant activities list contained in 326 IAC 2-7-1(21) and 326 IAC 2-7-1(40). The renewal application does require the certification by the “responsible official” as defined by 326 IAC 2-7-1(34).

Request for renewal shall be submitted to:

Indiana Department of Environmental Management
Permits Branch, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

- (b) Timely Submittal of Permit Renewal [326 IAC 2-7-4(a)(1)(D)]
- (1) A timely renewal application is one that is:

- (A) Submitted at least nine (9) months prior to the date of the expiration of this permit; and
 - (B) If the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.
- (2) If IDEM, OAQ, upon receiving a timely and complete permit application, fails to issue or deny the permit renewal prior to the expiration date of this permit, this existing permit shall not expire and all terms and conditions shall continue in effect, including any permit shield provided in 326 IAC 2-7-15, until the renewal permit has been issued or denied.
- (c) Right to Operate After Application for Renewal [326 IAC 2-7-3] [326 IAC 2-7-4]
If the Permittee submits a timely and complete application for renewal of this permit, the source's failure to have a permit is not a violation of 326 IAC 2-7 until IDEM, OAQ, takes final action on the renewal application, except that this protection shall cease to apply if, subsequent to the completeness determination, the Permittee fails to submit by a reasonable deadline specified in writing by IDEM, OAQ, any additional information identified as being needed to process the application. [326 IAC 2-7-4(a)(2)(D) and (E)]
- (d) United States Environmental Protection Agency Authority [326 IAC 2-7-8(e)]
If IDEM, OAQ, fails to act in a timely way on a Part 70 permit renewal, the U.S. EPA may invoke its authority under Section 505(e) of the Clean Air Act to terminate or revoke and reissue a Part 70 permit.

B.17 Source Modification [326 IAC 1-2-42] [326 IAC 2-7-10.5]

- (a) The Permittee shall obtain approval as required by 326 IAC 2-7-10.5 from the OAQ prior to making any modification to the source. Pursuant to 326 IAC 1-2-42, "Modification" means one (1) or more of the following activities at an existing source:
- (1) A physical change or change in the method of operation of any existing emissions unit that increases the potential to emit any regulated pollutant that could be emitted from the emissions unit, or that results in emissions of any regulated pollutant not previously emitted.
 - (2) Construction of one (1) or more new emissions units that have the potential to emit regulated air pollutants.
 - (3) Reconstruction of one (1) or more existing emission units that increases the potential to emit of any regulated air pollutant.
- (b) Any application requesting a source modification shall be submitted to:

Indiana Department of Environmental Management
Permits Branch, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

Any such application shall be certified by the “responsible official” as defined by 326 IAC 2-7-1(34).

- (c) The Permittee shall also comply with the applicable provisions of 326 IAC 2-7-11 (Administrative Permit Amendments) or 326 IAC 2-7-12 (Permit Modification) prior to operating the approved modification.

B.18 Permit Amendment or Modification [326 IAC 2-7-11] [326 IAC 2-7-12] [40 CFR 72]

- (a) Permit amendments and modifications are governed by the requirements of 326 IAC 2-7-11 or 326 IAC 2-7-12 whenever the Permittee seeks to amend or modify this permit.
- (b) Pursuant to 326 IAC 2-7-11(b) and 326 IAC 2-7-12(a), administrative Part 70 permit amendments and permit modifications for purposes of the acid rain portion of a Part 70 permit shall be governed by regulations promulgated under Title IV of the Clean Air Act. [40 CFR 72]
- (c) Any application requesting an amendment or modification of this permit shall be submitted to:

Indiana Department of Environmental Management
Permits Branch, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

Any such application shall be certified by the “responsible official” as defined by 326 IAC 2-7-1(34).

- (d) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-7-11(c)(3)]
- (e) No permit amendment or modification is required for the addition, operation or removal of a nonroad engine, as defined in 40 CFR 89.2.

B.19 Permit Revision Under Economic Incentives and Other Programs [326 IAC 2-7-5(8)] [326 IAC 2-7-12 (b)(2)]

- (a) No Part 70 permit revision shall be required under any approved economic incentives, marketable Part 70 permits, emissions trading, and other similar programs or processes for changes that are provided for in a Part 70 permit.
- (b) Notwithstanding 326 IAC 2-7-12(b) and 326 IAC 2-7-12(c)(1), minor Part 70 permit modification procedures may be used for Part 70 modifications involving the use of economic incentives, marketable Part 70 permits, emissions trading, and other similar approaches to the extent that such minor Part 70 permit modification procedures are explicitly provided for in the applicable State Implementation Plan (SIP) or in applicable requirements promulgated or approved by the U.S. EPA.

B.20 Operational Flexibility [326 IAC 2-7-20] [326 IAC 2-7-10.5]

- (a) The Permittee may make any change or changes at the source that are described in 326 IAC 2-7-20(b), (c), or (e), without a prior permit revision, if each of the following conditions is met:

- (1) The changes are not modifications under any provision of Title I of the Clean Air

Act;

- (2) Any preconstruction approval required by 326 IAC 2-7-10.5 has been obtained;
- (3) The changes do not result in emissions which exceed the emissions allowable under this permit (whether expressed herein as a rate of emissions or in terms of total emissions);
- (4) The Permittee notifies the:

Indiana Department of Environmental Management
Permits Branch, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V
Air and Radiation Division, Regulation Development Branch - Indiana (AR-18J)
77 West Jackson Boulevard
Chicago, Illinois 60604-3590

in advance of the change by written notification at least ten (10) days in advance of the proposed change. The Permittee shall attach every such notice to the Permittee's copy of this permit; and

- (5) The Permittee maintains records on-site which document, on a rolling five (5) year basis, all such changes and emissions trading that are subject to 326 IAC 2-7-20(b), (c), or (e) and makes such records available, upon reasonable request, for public review.

Such records shall consist of all information required to be submitted to IDEM, OAQ, in the notices specified in 326 IAC 2-7-20(b)(1), (c)(1), and (e)(2).

- (b) The Permittee may make Section 502(b)(10) of the Clean Air Act changes (this term is defined at 326 IAC 2-7-1(36)) without a permit revision, subject to the constraint of 326 IAC 2-7-20(a). For each such Section 502(b)(10) of the Clean Air Act change, the required written notification shall include the following:
 - (1) A brief description of the change within the source;
 - (2) The date on which the change will occur;
 - (3) Any change in emissions; and
 - (4) Any permit term or condition that is no longer applicable as a result of the change.

The notification which shall be submitted is not considered an application form, report or compliance certification. Therefore, the notification by the Permittee does not require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

- (c) Emission Trades [326 IAC 2-7-20(c)]

The Permittee may trade increases and decreases in emissions in the source, where the applicable SIP provides for such emission trades without requiring a permit revision, subject to the constraints of Section (a) of this condition and those in 326 IAC 2-7-20(c).

- (d) Alternative Operating Scenarios [326 IAC 2-7-20(d)]
The Permittee may make changes at the source within the range of alternative operating scenarios that are described in the terms and conditions of this permit in accordance with 326 IAC 2-7-5(9). No prior notification of IDEM, OAQ, or U.S. EPA is required.
- (e) Backup fuel switches specifically addressed in, and limited under, Section D of this permit shall not be considered alternative operating scenarios. Therefore, the notification requirements of part (a) of this condition do not apply.

B.21 Inspection and Entry [326 IAC 2-7-6] [IC 13-14-2-2] [IC 13-30-3-1] [IC 13-17-3-2]

Upon presentation of proper identification cards, credentials, and other documents as may be required by law, and subject to the Permittee's right under all applicable laws and regulations to assert that the information collected by the agency is confidential and entitled to be treated as such, the Permittee shall allow IDEM, OAQ, U.S. EPA, or an authorized representative to perform the following:

- (a) Enter upon the Permittee's premises where a Part 70 source is located, or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
- (b) [As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1](#), have access to and copy any records that must be kept under the conditions of this permit;
- (c) [As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1](#), inspect any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit;
- (d) [As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1](#), sample or monitor substances or parameters for the purpose of assuring compliance with this permit or applicable requirements; and
- (e) [As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1](#), utilize any photographic, recording, testing, monitoring, or other equipment for the purpose of assuring compliance with this permit or applicable requirements.

B.22 Transfer of Ownership or Operational Control [326 IAC 2-7-11]

- (a) The Permittee must comply with the requirements of 326 IAC 2-7-11 whenever the Permittee seeks to change the ownership or operational control of the source and no other change in the permit is necessary.
- (b) Any application requesting a change in the ownership or operational control of the source shall contain a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new Permittee. The application shall be submitted to:

Indiana Department of Environmental Management
Permits Branch, Office of Air Quality
100 North Senate Avenue

Indianapolis, Indiana 46204-2251

The application which shall be submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-7-11(c)(3)]

B.23 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-7-5(7)] [326 IAC 2-1.1-7]

- (a) The Permittee shall pay annual fees to IDEM, OAQ, within thirty (30) calendar days of receipt of a billing. Pursuant to 326 IAC 2-7-19(b), if the Permittee does not receive a bill from IDEM, OAQ, the applicable fee is due April 1 of each year.
- (b) Except as provided in 326 IAC 2-7-19(e), failure to pay may result in administrative enforcement action or revocation of this permit.
- (c) The Permittee may call the following telephone numbers: 1-800-451-6027 or 317-233-4230 (ask for OAQ, **Billing, Licensing, and Training Section**), to determine the appropriate permit fee.

B.24 Credible Evidence [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [62 FR 8314]

Notwithstanding the conditions of this permit that state specific methods that may be used to demonstrate compliance with, or a violation of, applicable requirements, any person (including the Permittee) may also use other credible evidence to demonstrate compliance with, or a violation of, any term or condition of this permit.

SECTION C

SOURCE OPERATION CONDITIONS

Entire Source

Emission Limitations and Standards [326 IAC 2-7-5(1)]

C.1 Particulate Matter Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) pounds per hour [326 IAC 6-3-2] [40 CFR 52 Subpart P]

- (a) Pursuant to 40 CFR 52 Subpart P, the allowable particulate matter emissions rate from any process not already regulated by 326 IAC 6-1 or any New Source Performance Standard, and which has a maximum process weight rate less than 100 pounds per hour shall not exceed 0.551 pounds per hour.
- (b) Pursuant to 326 IAC 6-3-2(e)(2), the allowable particulate emissions rate from any process not exempt under 326 IAC 6-3-1(b) or (c) which has a maximum process weight rate less than 100 pounds per hour and the methods in 326 IAC 6-3-2(b) through (d) do not apply shall not exceed 0.551 pounds per hour.

This condition is not federally enforceable.

C.2 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

- (a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

C.3 Open Burning [326 IAC 4-1] [IC 13-17-9]

The Permittee shall not open burn any material except as provided in 326 IAC 4-1-3, 326 IAC 4-1-4 or 326 IAC 4-1-6. The previous sentence notwithstanding, the Permittee may open burn in accordance with an open burning approval issued by the Commissioner under 326 IAC 4-1-4.1. 326 IAC 4-1-3 (a)(2)(A) and (B) are not federally enforceable.

C.4 Incineration [326 IAC 4-2][326 IAC 9-1-2]

The Permittee shall not operate an incinerator or incinerate any waste or refuse except as provided in 326 IAC 4-2 and 326 IAC 9-1-2. 326 IAC 9-1-2 is not federally enforceable.

C.5 Fugitive Dust Emissions [326 IAC 6-4]

The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions). 326 IAC 6-4-2(4) is not federally enforceable.

C.6 Stack Height [326 IAC 1-7]

The Permittee shall comply with the applicable provisions of 326 IAC 1-7 (Stack Height Provisions), for all exhaust stacks through which a potential (before controls) of twenty-five (25)

tons per year or more of particulate matter or sulfur dioxide is emitted.

The provisions of [326 IAC 1-7-1\(3\)](#), [326 IAC 1-7-2](#), [326 IAC 1-7-3\(c\)](#) and (d), [326 IAC 1-7-4](#), and [326 IAC 1-7-5\(a\)](#), (b), and (d) are not federally enforceable.

C.7 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

The Permittee shall comply with the applicable requirements of [326 IAC 14-10](#), [326 IAC 18](#), and [40 CFR 61.140](#).

Testing Requirements [326 IAC 2-7-6(1)]

C.8 Performance Testing [326 IAC 3-6]

(a) All testing shall be performed according to the provisions of [326 IAC 3-6](#) (Source Sampling Procedures), except as provided elsewhere in this permit, utilizing any applicable procedures and analysis methods specified in [40 CFR 51](#), [40 CFR 60](#), [40 CFR 61](#), [40 CFR 63](#), [40 CFR 75](#), or other procedures approved by IDEM, OAQ.

A test protocol, except as provided elsewhere in this permit, shall be submitted to:

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

no later than thirty-five (35) days prior to the intended test date. The protocol submitted by the Permittee does not require certification by the "responsible official" as defined by [326 IAC 2-7-1\(34\)](#).

(b) The Permittee shall notify IDEM, OAQ of the actual test date at least fourteen (14) days prior to the actual test date. The notification submitted by the Permittee does not require certification by the "responsible official" as defined by [326 IAC 2-7-1\(34\)](#).

(c) Pursuant to [326 IAC 3-6-4\(b\)](#), all test reports must be received by IDEM, OAQ not later than forty-five (45) days after the completion of the testing. An extension may be granted by IDEM, OAQ, if the Permittee submits to IDEM, OAQ, a reasonable written explanation not later than five (5) days prior to the end of the initial forty-five (45) day period.

Compliance Requirements [326 IAC 2-1.1-11]

C.9 Compliance Requirements [326 IAC 2-1.1-11]

The commissioner may require stack testing, monitoring, or reporting at any time to assure compliance with all applicable requirements by [issuing an order under 326 IAC 2-1.1-11](#). Any monitoring or testing shall be performed in accordance with [326 IAC 3](#) or other methods approved by the commissioner or the U. S. EPA.

Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]

C.10 Compliance Monitoring [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

Unless otherwise specified in this permit, all monitoring and record keeping requirements not already legally required shall be implemented within ninety (90) days of permit issuance. If required by Section D, the Permittee shall be responsible for installing any necessary equipment and initiating any required monitoring related to that equipment. If due to circumstances beyond

its control, that equipment cannot be installed and operated within ninety (90) days, the Permittee may extend the compliance schedule related to the equipment for an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

in writing, prior to the end of the initial ninety (90) day compliance schedule, with full justification of the reasons for the inability to meet this date.

The notification which shall be submitted by the Permittee does require the certification by the “responsible official” as defined by 326 IAC 2-7-1(34).

Unless otherwise specified in the approval for the new emission unit(s), compliance monitoring for new emission units or emission units added through a source modification shall be implemented when operation begins.

C.11 Maintenance of Continuous Opacity Monitoring Equipment [326 IAC 2-7-5(3)(A)(iii)]

- (a) The Permittee shall install, calibrate, maintain, and operate all necessary continuous opacity monitoring systems (COMS) and related equipment. For a boiler, the COM shall be in operation at all times that the induced draft fan is in operation.
- (b) All continuous opacity monitoring systems shall meet the performance specifications of 40 CFR 60, Appendix B, Performance Specification No. 1, and are subject to monitor system certification requirements pursuant to 326 IAC 3-5.
- (c) In the event that a breakdown of a continuous opacity monitoring system occurs, a record shall be made of the times and reasons of the breakdown and efforts made to correct the problem.
- (d) Whenever a continuous opacity monitor (COM) is malfunctioning or will be down for calibration, maintenance, or repairs for a period of one (1) hour or more, compliance with the applicable opacity limits shall be demonstrated by the following:
 - (1) Visible emission (VE) notations shall be performed once per hour during daylight operations following the shutdown or malfunction of the primary COM. A trained employee shall record whether emissions are normal or abnormal for the state of operation of the emission unit at the time of the reading.
 - (A) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.
 - (B) If abnormal emissions are noted during two consecutive emission notations, the Permittee shall begin Method 9 opacity observations with four (4) hours of the second abnormal notation.
 - (C) VE notations may be discontinued once a COM is online or formal Method 9 readings have been implemented.

- (2) If a COM is not online within twenty-four (24) hours of shutdown or malfunction of the primary COM, the Permittee shall provide certified opacity reader(s), who may be employees of the Permittee or independent contractors, to self-monitor the emissions from the boiler stack.
 - (A) Visible emission readings shall be performed in accordance with 40 CFR 60, Appendix A, Method 9, for a minimum of five (5) consecutive six (6) minute averaging periods) beginning not more than twenty-four (24) hours after the start of the malfunction or down time.
 - (B) Method 9 opacity readings shall be repeated for a minimum five (5) consecutive six (6) minute averaging periods) at least once every four (4) hours during daylight operations, until such time that a COM is in operation.
 - (C) Method 9 readings may be discontinued once a COM is online.
 - (D) Any opacity exceedances determined by Method 9 readings shall be reported with the Quarterly Opacity Exceedances Reports.
- (3) If abnormal emissions are observed at any boiler exhaust, the Permittee shall take reasonable response steps in accordance with Section C - Compliance Response Plan - Preparation, Implementation, Records, and Reports. Observation of abnormal emissions that do not violate an applicable opacity limit is not a deviation from this permit. Failure to take response steps in accordance with Section C - Compliance Response Plan - Preparation, Implementation, Records, and Reports, shall be considered a deviation from this permit.
- (e) Nothing in this condition, or in Section D of this permit, shall excuse the Permittee from complying with the requirements to operate a continuous opacity monitoring system pursuant to 326 IAC 3-5.

C.12 Maintenance of Continuous Emission Monitoring Equipment [326 IAC 2-7-5(3)(A)(iii)]

- (a) The Permittee shall install, calibrate, maintain, and operate all necessary continuous emission monitoring systems (CEMS) and related equipment.
- (b) In the event that a breakdown of a continuous emission monitoring system occurs, a record shall be made of the times and reasons of the breakdown and efforts made to correct the problem.
- (c) Whenever a continuous emission monitor other than an opacity monitor is malfunctioning or is down for maintenance or repairs, the following shall be used as an alternative to continuous data collection:
 - (1) When the CEM is required for monitoring NO_x or SO₂ emissions pursuant to 40 CFR 75 (Title IV Acid Rain program) or 326 IAC 10-4 (NO_x Budget Trading Program), the Permittee shall comply with the relevant requirements of 40 CFR 75 Subpart D - Missing Data Substitution Procedures.
 - (2) When the CEM is not used to monitor NO_x or SO₂ emissions for applicable requirements other than 40 CFR 75 or 326 IAC 10-4, then supplemental or intermittent monitoring of the parameter shall be implemented as specified in

Section D of this permit until such time as the emission monitor system is back in operation.

- (d) Nothing in this condition, or in Section D of this permit, shall excuse the Permittee from complying with the requirements to operate a continuous emission monitoring system pursuant to 326 IAC 3-5, 40 CFR Part 75 and 326 IAC 10-4.

C.13 Monitoring Methods [326 IAC 3] [40 CFR 60] [40 CFR 63]

Any monitoring or testing required by Section D of this permit shall be performed according to the provisions of 326 IAC 3, 40 CFR 60 Appendix A, 40 CFR 60 Appendix B, 40 CFR 63, or other approved methods as specified in this permit.

C.14 Pressure Gauge and Other Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

- (a) Whenever a condition in this permit requires the measurement of pressure drop across any part of the unit or its control device, the gauge employed shall have a scale such that the expected normal reading shall be no less than twenty percent (20%) of full scale and be accurate within plus or minus two percent (2%) of full scale reading.
- (b) Whenever a condition in this permit requires the measurement of a temperature, flow rate, or pH level, the instrument employed shall have a scale such that the expected normal reading shall be no less than twenty percent (20%) of full scale and be accurate within plus or minus two percent (2%) of full scale reading.
- (c) The Permittee may request the IDEM, OAQ approve the use of a pressure gauge or other instrument that does not meet the above specifications provided the Permittee can demonstrate an alternative pressure gauge or other instrument specification will adequately ensure compliance with permit conditions requiring the measurement of pressure drop or other parameters.

Corrective Actions and Response Steps [326 IAC 2-7-5] [326 IAC 2-7-6]

C.15 Emergency Reduction Plans (ERP) [326 IAC 1-5-2] [326 IAC 1-5-3]

Pursuant to 326 IAC 1-5-2 (Emergency Reduction Plans; Submission):

- (a) The Permittee shall prepare written emergency reduction plans (ERPs) consistent with safe operating procedures.
- (b) These ERPs shall be submitted for approval to:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

within ninety (90) days after the date of issuance of this permit.

The ERP does require the certification by the “responsible official” as defined by 326 IAC 2-7-1(34).

- (c) If the ERP is disapproved by IDEM, OAQ, the Permittee shall have an additional thirty

(30) days to resolve the differences and submit an approvable ERP.

- (d) These ERPs shall state those actions that will be taken, when each episode level is declared, to reduce or eliminate emissions of the appropriate air pollutants.
- (e) Said ERPs shall also identify the sources of air pollutants, the approximate amount of reduction of the pollutants, and a brief description of the manner in which the reduction will be achieved.
- (f) Upon direct notification by IDEM, OAQ, that a specific air pollution episode level is in effect, the Permittee shall immediately put into effect the actions stipulated in the approved ERP for the appropriate episode level. [326 IAC 1-5-3]

C.16 Risk Management Plan (RMP) [326 IAC 2-7-5(12)] [40 CFR 68.215]

If a regulated substance, as defined in 40 CFR 68, is present at a source in more than a threshold quantity, the Permittee must comply with the applicable requirements of 40 CFR 68.

C.17 Compliance Response Plan (CRP) - Preparation, Implementation, Records, and Reports
[326 IAC 2-7-5] [326 IAC 2-7-6]

- (a) The Permittee is required to prepare a Compliance Response Plan (CRP) for each compliance monitoring condition of this permit. If a Permittee is required to have an Operation, Maintenance and Monitoring (OMM) Plan or Parametric Monitoring Plan and Start-up, Shutdown, and Malfunction (SSM) Plan under 40 CFR 60 or 40 CFR 63, such plans shall be deemed to satisfy the requirements for a CRP for those compliance monitoring conditions.

A CRP shall be submitted to IDEM, upon request. The CRP shall be prepared within ninety (90) days after issuance of this permit by the Permittee, supplemented from time to time by the Permittee, maintained on site, and comprised of:

- (1) Reasonable response steps that may be implemented in the event that a response step is needed pursuant to the requirements of Section D of this permit; and an expected timeframe for taking reasonable response steps.
- (2) If, at any time, the Permittee takes reasonable response steps that are not set forth in the Permittee's current Compliance Response Plan or Operation, Maintenance and Monitoring (OMM) Plan or Parametric Monitoring Plan and Start-up, Shutdown, and Malfunction (SSM) Plan and the Permittee documents such response in accordance with subsection (e) below, the Permittee shall amend its Compliance Response Plan or Operation, Maintenance and Monitoring (OMM) Plan or Parametric Monitoring Plan and Start-up, Shutdown, and Malfunction (SSM) Plan to include such response steps taken.

The OMM Plan or Parametric Monitoring Plan and SMM Plan shall be submitted within the time frames specified by the applicable 40 CFR60 or 40 CFR Part 63 requirement.

- (b) For each compliance monitoring condition of this permit, reasonable response steps shall be taken when indicated by the provisions of that compliance monitoring condition as follows:
 - (1) Reasonable response steps shall be taken as set forth in the Permittee's

- current Compliance Response Plan or Operation, Maintenance and Monitoring (OMM) Plan or Parametric Monitoring Plan and Start-up, Shutdown, and Malfunction (SSM) Plan; or
- (2) If none of the reasonable response steps listed in the Compliance Response Plan or Operation, Maintenance and Monitoring (OMM) Plan or Parametric Monitoring Plan and Start-up, Shutdown, and Malfunction (SSM) Plan is applicable or responsive to the excursion, the Permittee shall devise and implement additional response steps as expeditiously as practical. Taking such additional response steps shall not be considered a deviation from this permit so long as the Permittee documents such response steps in accordance with this condition.
 - (3) If the Permittee determines that additional response steps would necessitate that the emissions unit or control device be shut down, and it will be ten (10) days or more until the unit or device will be shut down, then the Permittee shall promptly notify the IDEM, OAQ of the expected date of the shut down. The notification shall also include the status of the applicable compliance monitoring parameter with respect to normal, and the results of the response actions taken up to the time of notification.
 - (4) Failure to take reasonable response steps shall be considered a deviation from the permit.
- (c) The Permittee is not required to take any further response steps for any of the following reasons:
- (1) A false reading occurs due to the malfunction of the monitoring equipment and prompt action was taken to correct the monitoring equipment.
 - (2) The Permittee has determined that the compliance monitoring parameters established in the permit conditions are technically inappropriate, has previously submitted a request for a minor permit modification to the permit, and such request has not been denied.
 - (3) An automatic measurement was taken when the process was not operating.
 - (4) The process has already returned or is returning to operating within “normal” parameters and no response steps are required.
- (d) When implementing reasonable steps in response to a compliance monitoring condition, if the Permittee determines that an exceedance of an emission limitation has occurred, the Permittee shall report such deviations pursuant to Section B-Deviations from Permit Requirements and Conditions.
- (e) The Permittee shall record all instances when, in accordance with Section D, response steps are taken. In the event of an emergency, the provisions of 326 IAC 2-7-16 (Emergency Provisions) requiring prompt corrective action to mitigate emissions shall prevail.
- (f) Except as otherwise provided by a rule or provided specifically in Section D, all monitoring as required in Section D shall be performed when the emission unit is operating, except for time necessary to perform quality assurance and maintenance activities.

C.18 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5] [326 IAC 2-7-6]

- (a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this permit exceed the level specified in any condition of this permit, the Permittee shall take appropriate response actions. The Permittee shall submit a description of these response actions to IDEM, OAQ, within thirty (30) days of receipt of the test results. The Permittee shall take appropriate action to minimize excess emissions from the affected facility while the response actions are being implemented.
- (b) A retest to demonstrate compliance shall be performed within one hundred twenty (120) days of receipt of the original test results. Should the Permittee demonstrate to IDEM, OAQ that retesting in one-hundred and twenty (120) days is not practicable, IDEM, OAQ may extend the retesting deadline.
- (c) IDEM, OAQ reserves the authority to take any actions allowed under law in response to noncompliant stack tests.

The [response action](#) documents submitted pursuant to this condition do require the certification by the “responsible official” as defined by 326 IAC 2-7-1(34).

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

C.19 Emission Statement [326 IAC 2-7-5(3)(C)(iii)][326 IAC 2-7-5(7)][326 IAC 2-7-19(c)][326 IAC 2-6]

- (a) The Permittee shall submit an emission statement certified pursuant to the requirements of 326 IAC 2-6. This statement must be received in accordance with the compliance schedule specified in 326 IAC 2-6-3, and must comply with the minimum requirements specified in 326 IAC 2-6-4.

The [submittal](#) should cover the period identified in 326 IAC 2-6. The [emission statement](#) shall meet the following requirements:

- (1) Indicate estimated actual emissions of criteria pollutants from the source, in compliance with 326 IAC 2-6 (Emission Reporting).
- (2) Indicate estimated actual emissions of regulated pollutants as defined by 326 IAC 2-7-1(32) (“Regulated pollutant which is used only for purposes of Section 19 of this rule”) from the source, for purposes of Part 70 fee assessment.

The [emission statement](#) must be submitted to:

Indiana Department of Environmental Management
Technical Support and Modeling Section, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

The [emission statement](#) does require the certification by the “responsible official” as defined by 326 IAC 2-7-1(34).

- (b) The [emission statement](#) required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by

any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.

C.20 General Record Keeping Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-6]

- (a) Records of all required **monitoring** data, reports and support information **required by this permit** shall be retained for a period of at least five (5) years from the date of monitoring sample, measurement, report, or application. These records shall **be physically present or electronically accessible** at the source location for a minimum of three (3) years. The records may be stored elsewhere for the remaining two (2) years as long as they are available upon request. If the Commissioner makes a request for records to the Permittee, the Permittee shall furnish the records to the Commissioner within a reasonable time.
- (b) Unless otherwise specified in this permit, all record keeping requirements not already legally required shall be implemented within ninety (90) days of permit issuance.

C.21 General Reporting Requirements [326 IAC 2-7-5(3)(C)] [326 IAC 2-1.1-11]

- (a) The **Permittee** shall submit the attached Quarterly Deviation and Compliance Monitoring Report or its equivalent. Any deviation from permit requirements, the date(s) of each deviation, the cause of the deviation, and the response steps taken must be reported. This report shall be submitted within thirty (30) days of the end of the reporting period. The Quarterly Deviation and Compliance Monitoring Report shall include the certification by the “responsible official” as defined by 326 IAC 2-7-1(34).
- (b) The report required in (a) of this condition and reports required by conditions in Section D of this permit shall be submitted to:

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251
- (c) Unless otherwise specified in this permit, any notice, report, or other submission required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.
- (d) Unless otherwise specified in this permit, all reports required in Section D of this permit shall be submitted within thirty (30) days of the end of the reporting period. All reports do require the certification by the “responsible official” as defined by 326 IAC 2-7-1(34).
- (e) The first report shall cover the period commencing on the date of issuance of this permit and ending on the last day of the reporting period. Reporting periods are based on calendar years.

Stratospheric Ozone Protection

C.22 Compliance with 40 CFR 82 and 326 IAC 22-1

Pursuant to 40 CFR 82 (Protection of Stratospheric Ozone), Subpart F, except as provided for motor vehicle air conditioners in Subpart B, the Permittee shall comply with the standards for

recycling and emissions reduction:

- (a) Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to 40 CFR 82.156.
- (b) Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to 40 CFR 82.158.
- (c) Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161.
- (d) Pursuant to 40 CFR 82, Subpart E (The Labeling of Products Using Ozone-Depleting Substances), all containers in which a Class I or Class II substance is stored or transported and all products containing a Class I substance shall be labeled as required under 40 CFR Part 82.

Ambient Monitoring Requirements [326 IAC 7-3]

C.23 Ambient Monitoring [326 IAC 7-3]

- (a) The Permittee shall operate continuous ambient sulfur dioxide air quality monitors and a meteorological data acquisition according to a monitoring plan submitted to the commissioner for approval. The monitoring plan shall include requirements listed in 326 IAC 7-3-2(a)(1), 326 IAC 7-3-2(a)(2) and 326 IAC 7-3-2(a)(3).
- (b) The Permittee and other operators subject to the requirements of this rule, located in the same county, may submit a joint monitoring plan to satisfy the requirements of this rule. [326 IAC 7-3-2(c)]
- (c) The Permittee may petition the commissioner for an administrative waiver of all or some of the requirements of 326 IAC 7-3 if such owner or operator can demonstrate that ambient monitoring is unnecessary to determine continued maintenance of the sulfur dioxide ambient air quality standards in the vicinity of the source. [326 IAC 7-3-2(d)]

Part 2 MACT Application Submittal Requirement

C.24 Application Requirements for Section 112(j) of the Clean Air Act [40 CFR 63.52(e)] [326 IAC 2-7-12]

- (a) The Permittee shall submit a Part 2 Maximum Achievable Control Technology (MACT) Application in accordance with 40 CFR 63.52(e)(1). The Part 2 MACT Application shall meet the requirements of 40 CFR 63.53(b).
- (b) Notwithstanding paragraph (a), the Permittee is not required to submit a Part 2 MACT Application if the Permittee no longer meets the applicability criteria of 40 CFR 63.50 by the application deadline in 40 CFR 63.52(e)(1). For example, the Permittee would not have to submit a Part 2 MACT Application if, by the application deadline:
 - (1) The source is no longer a major source of hazardous air pollutants, as defined in 40 CFR 63.2;
 - (2) The source no longer includes one or more units in an affected source category for which the U.S. EPA failed to promulgate an emission standard by May 15, 2002; or

- (3) The MACT standard or standards for the affected source categories included at the source are promulgated.
- (c) Notwithstanding paragraph (a), the Permittee shall comply with an applicable promulgated **Maximum Achievable Control technology** (MACT) standard, including the initial notification requirements of the MACT standard, in accordance with the schedule provided in the MACT standard, if the MACT standard is promulgated prior to the Part 2 MACT Application deadline. If a MACT has been promulgated and the source is subject to the MACT, the Permittee shall submit an application for a significant permit modification under 326 IAC 2-7-12 no later than nine (9) months prior to the compliance date for the MACT.

The application should include information regarding which portions of the MACT are applicable to the emission units at the source and which compliance options will be followed.

If a permit renewal application is due before the date that a significant permit modification application would be due, the Permittee shall include the required information in the renewal application in lieu of submitting an application for a significant permit modification.

SECTION D.1

FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]

- (a) One (1) pulverized coal-fired dry bottom boiler, identified as Boiler #1, constructed in 1970, rated at 1160 million Btu per hour energy input, used to generate up to 132 megawatts (gross) of electricity at the above location.

Particulate matter emissions are controlled by an electrostatic precipitator, emissions are measured with a continuous opacity monitor.

NOx emissions are inhibited by a Low NOx Burner.

Controlled boiler emissions are exhausted to the atmosphere through a 300 foot tall chimney with an 11 foot exit diameter.

- (b) One (1) pulverized coal-fired dry bottom boiler, identified as Boiler #2, constructed in 1970, rated at 1160 million Btu per hour energy input, used to generate up to 132 megawatts (gross) of electricity at the above location.

Particulate matter emissions are controlled by an electrostatic precipitator, emissions are measured with a continuous opacity monitor.

NOx emissions are inhibited by a Low NOx Burner.

Controlled boiler emissions are exhausted to the atmosphere through a 300 foot tall chimney with an 11 foot exit diameter.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.1.1 Particulate Emissions Limitations [326 IAC 6-2-3]

Pursuant to 326 IAC 6-2-3 (Particulate Emission Limitations for Sources of Indirect Heating), particulate emissions from Boiler #1 or Boiler #2 shall not exceed 0.35 lb/mmBtu. This limitation was calculated using the following equation:

$$Pt = \frac{(C)(a)(h)}{76.5 (Q^{0.75})(N^{0.25})}$$

Where : C = 50 m/m³

Q = total source capacity (mmBtu/hr)
2340 mmBtu/hr

N = number of stacks (3)

a = 0.8

h = average stack height (feet) (300)

Pt = pounds of particulate matter emitted per million Btu heat input (lb/mmBtu)

D.1.2 Opacity Exemption [326 IAC 5-1-3]

- (a) Pursuant to 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), the following applies:

- (1) When building a new fire in a boiler, opacity may exceed the 40% opacity limitation for a period not to exceed 2 hours (20 six minute-average periods) or until the electrostatic precipitator (ESP) reaches 250 degrees F, whichever occurs first.
 - (2) When shutting down a boiler, opacity may exceed the 40% opacity limitation for a period not to exceed one (1) hour (10 six minute average periods).
 - (3) Operation of the electrostatic precipitators are not required during these times unless necessary to comply with these limits.
- (b) When removing ashes from the fuel bed or furnace in a boiler or blowing tubes, opacity may exceed the applicable limit established in 326 IAC 5-1-2 and stated in Section C - Opacity. However, opacity levels shall not exceed sixty percent (60%) for any six (6)-minute averaging period and opacity in excess of the applicable limit shall not continue for more than one (1) six (6)-minute averaging periods in any sixty (60) minute period. The averaging periods shall not be permitted for more than three (3) six (6)-minute averaging periods in a twelve (12) hour period.

D.1.3 Sulfur Dioxide (SO₂) [326 IAC 7-1.1-2(a)(1)]

Pursuant to 326 IAC 7-1.1 (Sulfur Dioxide Emission Limitations), the SO₂ emissions from either Boiler #1 or Boiler #2 shall not exceed 6.0 pounds per million Btu (lbs/mmBtu) based on a thirty (30) day rolling average.

D.1.4 Operation Standards [326 IAC 2-1.1-5(a)(4)] [40 CFR 261] [329 IAC 13]

- (a) All coal burned, including coal treated with any additive, shall meet the ASTM definition of coal.
- (b) The burning of hazardous waste, as defined by 40 CFR 261, is prohibited in these facilities. Any boiler tube chemical cleaning waste liquids, binding agent, or used oil combusted shall meet the toxicity characteristic requirements for non-hazardous waste.
- (c) Any boiler tube chemical cleaning waste liquids fired in the boilers shall only contain the cleaning solution and two full volume boiler rinses.

D.1.5 Preventive Maintenance Plan (PMP) [326 IAC 2-7-5(13)]

- (a) A Preventive Maintenance Plan (PMP), in accordance with Section B - Preventive Maintenance Plan (PMP), of this permit, is required for these facilities and their control devices.
- (b) The PMP for an electrostatic precipitator shall include the following inspections, performed according to the indicated schedules:
 - (1) Plate and electrode alignment, every major maintenance outage, but no less than every 2 years;
 - (2) ESP TR set components, performed whenever there is an outage of any nature lasting more than three days, unless such inspections have been performed within the last six months. At a minimum, unless the ESP is not so equipped, the following inspections shall be performed:

- (A) Internal inspection of shell corrosion (i.e., doors, hatches, insulator housings, roof area).
 - (B) Effectiveness of rapping (i.e., buildup of dust on discharge electrodes and plates).
 - (C) Gas distribution (i.e., buildup of dust on distribution plates and turning vanes).
 - (D) Dust accumulation (i.e., buildup of dust on shell and support members that could result in grounds or promote advanced corrosion).
 - (E) Major misalignment of plates (i.e., visual check of plate alignment).
 - (F) Rapper, vibrator and TR set control cabinets (motors, lubrication, etc.).
 - (G) Rapper assembly (i.e., loose bolts, ground wires, water in air lines, solenoids, etc.).
 - (H) Vibrator and rapper seals (i.e., air in-leakage, wear, deterioration).
 - (I) TR set controllers (i.e., low voltage trip point, over current trip point, spark rate, etc.).
 - (J) Vibrator air pressure settings.
- (3) Air and water infiltration, once per month. The recommended method for this inspection is for audible checks around ash hoppers/hatches, duct expansion joints, and areas of corrosion.
- (c) Reasonable response steps shall be taken in accordance with Section C - Compliance Response Plan -Preparation, Implementation, Records and Reports for any improper or abnormal conditions found during an inspection. Discovery of an abnormal or improper condition is not a deviation from this permit. Failure to take response steps in accordance with Section C - Compliance Response Plan -Preparation, Implementation, Records and Reports, shall be considered a deviation from this permit.

Compliance Determination Requirements

D.1.6 Testing Requirements [326 IAC 2-7-6(1),(6)] [326 IAC 2-1.1-11]

Within the two (2) calendar years following the most recent stack test, compliance with the PM limitation in Condition D.1.1 shall be determined by a performance stack test conducted utilizing methods as approved by the Commissioner.

This test shall be repeated at least once every two (2) calendar years following the most recent valid compliance demonstration.

Testing shall be conducted in accordance with Section C – Performance Testing.

D.1.7 Operation of Electrostatic Precipitator [326 IAC 2-7-6(6)]

Except as otherwise provided by statute or rule or in this permit, the electrostatic precipitators

shall be operated at all times that the boilers vented to the ESPs are in operation.

D.1.8 Continuous Emissions Monitoring [326 IAC 3-5]

Pursuant to 326 IAC 3-5 (Continuous Monitoring of Emissions), a continuous monitoring system shall be calibrated, maintained, and operated for measuring Opacity which meets the performance specifications of 326 IAC 3-5-2.

D.1.9 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 2-7-5(A)] [326 IAC 2-7-6] [326 IAC 3] [326 IAC 7]

(a) Pursuant to 326 IAC 7-2-1, the Permittee shall demonstrate that the sulfur dioxide emissions do not exceed the equivalent of six (6.0) pounds per MMBtu demonstrated using a thirty (30) day rolling weighted average. Pursuant to 326 IAC 7-2-1(e) and 326 IAC 3-7, coal sampling and analysis data shall be collected as follows:

- (1) Coal sampling shall be performed using the methods specified in 326 IAC 3-7-2(a), the coal samples shall be prepared as specified in 326 IAC 3-7-2(c), the heat content of the coal samples shall be determined as specified in 326 IAC 3-7-2(d), and the sulfur content of the coal samples shall be determined pursuant to 326 IAC 3-7-2(e); or
- (2) Pursuant to 326 IAC 3-7-3, manual or other non-ASTM automatic sampling and analysis procedures may be used upon a demonstration, submitted to the department for approval, that such procedures provide sulfur dioxide emission estimates representative either of estimates based on coal sampling and analysis procedures specified in 326 IAC 3-7-2 or of continuous emissions monitoring.

The fuel sampling and analysis data may be used to determine compliance or noncompliance with the emission limitations contained in 326 IAC 7. Computation of calculated sulfur dioxide emission rates from fuel sampling and analysis data shall be based on the emission factors contained in U.S. EPA publication AP-42, "Compilation of Air Pollutant Emission Factors" (September 1988), unless other emission factors based on site-specific sulfur dioxide measurements are approved by the commissioner and the U.S. EPA.

(b) Compliance with the emission limitations contained in 326 IAC 7 may be determined by conducting a stack test for sulfur dioxide emissions from the boiler in accordance with 326 IAC 3-6, utilizing the procedures in 40 CFR 60, Appendix A, Method 6, 6A, 6C, or 8. [326 IAC 7-2-1(d)]

A determination of noncompliance pursuant to either of the methods specified in (a) or (b) above shall not be refuted by evidence of compliance pursuant to the other method. [326 IAC 7-2-1(f)]

(c) Upon written notification to IDEM by a facility owner or operator, continuous emission monitoring data collected and reported pursuant to 326 IAC 3-5 may be used as the means for determining compliance with the emission limitations in 326 IAC 7. Upon such notification, the other requirements of 326 IAC 7-2 shall not apply. [326 IAC 7-2-1(g)]

D.1.10 Cleaning Waste Analysis [326 IAC 2-1.1-5(a)(4)] [40 CFR 261]

The Permittee shall use appropriate test methods as listed in 40 CFR Part 261 to analyze all boiler chemical cleaning wastes that will be burned, to determine the concentration of the compounds listed in the Operation Standards in this D Section.

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.1.11 Opacity Readings [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- (a) In the event of opacity exceeding twenty-five percent (25%) average opacity for three (3) consecutive six (6) minute averaging periods, appropriate response steps shall be taken in accordance with Section C - Compliance Response Plan - Preparation, Implementation, Records and Reports such that the cause(s) of the excursion are identified and corrected and opacity levels are brought back below twenty-five percent (25%). Examples of response steps include, but are not limited to, boiler loads being reduced and ESP T-R sets being returned to service.
- (b) Opacity readings in excess of twenty-five percent (25%) percent but not exceeding the opacity limit for the unit are not a deviation from this permit. Failure to take response steps in accordance with Section C - Compliance Response Plan - Preparation, Implementation, Records and Reports, shall be considered a deviation from this permit.

D.1.12 Transformer-Rectifier (T-R) Sets [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- (a) The ability of the ESP to control particulate emissions shall be monitored once per shift, when the unit is in operation, by measuring and recording the number of T-R sets in service and the primary and secondary voltages and the currents of the transformer-rectifier (T-R) sets.
- (b) Reasonable response steps shall be taken in accordance with Section C - Compliance Response Plan - Preparation, Implementation, Records and Reports whenever the percentage of T-R sets in service falls below 75 percent (75%). T-R set failure resulting in less than 75 percent (75%) availability, is not a deviation from this permit. Failure to take response steps in accordance with Section C - Compliance Response Plan -Preparation, Implementation, Records, and Reports, shall be considered a deviation from this permit.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.1.13 Record Keeping Requirements

- (a) To document compliance with Conditions D.1.3 and D.1.9, the Permittee shall maintain records in accordance with (1) through (4) below. Records maintained for (1) through (4) shall be sufficient to demonstrate compliance using a thirty (30) day rolling weighted average and shall be complete and sufficient to establish compliance with the SO₂ limit established in Condition D.1.3.
 - (1) Calendar dates covered in the compliance demonstration period;
 - (2) Actual coal usage since last compliance determination period;
 - (3) Sulfur content and heat content, and
 - (4) Sulfur dioxide emission rates.
- (b) Pursuant to 326 IAC 3-7-5(a), the Permittee shall develop a standard operating procedure (SOP) to be followed for sampling, handling, analysis, quality control, quality assurance, and data reporting of the information collected pursuant to 326 IAC 3-7-2 through 326 IAC 3-7-4. In addition, any revision to the SOP shall be submitted to IDEM , OAQ.

- (c) To document compliance with Section C - Opacity and Conditions D.1.1, D.1.2, D.1.3, D.1.4, D.1.5, D.1.6, D.1.7, D.1.8, D.1.10, D.1.11, and D.1.12, the Permittee shall maintain records in accordance with (1) through (5) below. Records shall be complete and sufficient to establish compliance with the limits established in Section C - Opacity and in Conditions D.1.1, D.1.2 and D.1.3.
 - (1) Data and results from the most recent stack test;
 - (2) All continuous emissions monitoring data, pursuant to 326 IAC 3-5 and 326 IAC 7-2-1(g) and/or 40 CFR 60;
 - (3) All parametric monitoring readings;
 - (4) Records of the results of the ESP inspections, and
 - (5) All preventive maintenance measures taken.
- (d) The Permittee shall maintain records of any additional inspections prescribed by the Preventive Maintenance Plan (PMP).
- (e) Records necessary to demonstrate compliance shall be available within 30 days of the end of each compliance period.
- (f) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

D.1.14 Reporting Requirements

A quarterly summary of the information to document compliance with condition D.1.3 shall be submitted to the address listed in Section C - General Reporting Requirements, of this permit, using the reporting form located at the end of this permit, or its equivalent, within thirty (30) days after the end of the quarter being reported.

The report submitted by the Permittee does require the certification by the “responsible official” as defined by 326 IAC 2-7-1(34).

Nitrogen Oxides Monitoring Requirement [326 IAC 10-4-4]

D.1.15 Nitrogen Oxides Monitoring Requirement [326 IAC 10-4-4(b)(1)] [326 IAC 10-4-12(b) and (c)] [40 CFR 75] [326 IAC 10-4-4(a)(1)] [326 IAC 10-4-7]

- (a) The Permittee shall meet the monitoring requirements of 326 IAC 10-4-12(b)(1) through (b)(3) that are applicable to their monitoring system for the NO_x budget unit on or before May 1, 2003.
- (b) The Permittee shall record, report, and quality assure the data from the monitoring systems on and after May 1, 2003 in accordance with 326 IAC 10-4-12 and 40 CFR 75.
- (c) The NO_x authorized account representative of the NO_x budget units submitted a NO_x budget permit application to IDEM, OAQ pursuant to 326 IAC 10-4-7(b)(1)(A).

SECTION D.2 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]

One (1) distillate oil #2-fired auxiliary boiler, constructed in 1970, with a heat input rate of 20.0 mmBtu/hr and with no control equipment and exhausting to stack SV3.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.2.1 Particulate Matter Limitation (PM) [326 IAC 6-2-3]

Pursuant to 326 IAC 6-2-3 (Particulate Matter Emission Limitations for Sources of Indirect Heating), particulate matter emissions from the Auxiliary Boiler shall not exceed 0.35 lbs/mmBtu.

This limitation was calculated using the following equation:

$$Pt = \frac{(C)(a)(h)}{76.5 (Q^{0.75}) (N^{0.25})}$$

Where C = 50 m/m³

Q = total source capacity mmBtu/hr
(2340 mmBtu/hr)

N = number of stacks

a = 0.8

h = average stack height (feet)

Pt = pounds of particulate matter

D.2.2 Opacity Exemption [326 IAC 5-1-3]

Pursuant to 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), the following applies:

- (a) When building a new fire in a boiler, or shutting down a boiler, opacity may exceed the applicable limit established in 326 IAC 5-1-2 and stated in Section C - Opacity. However, opacity levels shall not exceed sixty percent (60%) for any six (6)-minute averaging period. Opacity in excess of the applicable limit established in 326 IAC 5-1-2 shall not continue for more than two (2) six (6)-minute averaging periods in any twenty-four (24) hour period.
- (b) When removing ashes from the fuel bed or furnace in a boiler or blowing tubes, opacity may exceed the applicable limit established in 326 IAC 5-1-2 and stated in Section C - Opacity. However, opacity levels shall not exceed sixty percent (60%) for any six (6)-minute averaging period and opacity in excess of the applicable limit shall not continue for more than one (1) six (6)-minute averaging periods in any sixty (60) minute period. The averaging periods shall not be permitted for more than three (3) six (6)-minute averaging periods in a twelve (12) hour period.
- (c) If this facility cannot meet the opacity limitations in (a) and (b) of this condition, the Permittee may submit a written request to IDEM, OAQ, for a temporary alternative opacity limitation in accordance with 326 IAC 5-1-3(d). The Permittee must demonstrate that the alternative limit is needed and justifiable.

D.2.3 Preventive Maintenance Plan (PMP) [326 IAC 2-7-5(13)]

A Preventive Maintenance Plan (PMP), in accordance with Section B - Preventive Maintenance

Plan (PMP), of this permit, is required for this facility and any control devices.

Compliance Determination Requirements

None

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.2.4 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- (a) Visible emission notations of the boiler stack exhaust shall be performed once per shift during normal daylight operations when exhausting to the atmosphere. A trained employee shall record whether emissions are normal or abnormal.
- (b) Visible emission notations of the fuel oil fired boiler exhausts shall be performed during each daylight startup. This will suffice for the VE observation for that shift. A trained employee shall record whether emissions are normal or abnormal.
- (c) "Normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.
- (d) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.
- (e) If abnormal emissions are observed at any boiler exhaust, the Permittee shall take reasonable response steps in accordance with Section C - Compliance Response Plan - Preparation, Implementation, Records, and Reports. Observation of abnormal emissions that do not violate an applicable opacity limit is not a deviation from this permit. Failure to take response steps in accordance with Section C - Compliance Response Plan - Preparation, Implementation, Records, and Reports, shall be considered a [deviation from](#) this permit.

Record Keeping and Reporting Requirement [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.2.5 Record Keeping Requirements

- (a) To document compliance with Condition D.2.4, the Permittee shall maintain records of visible emission notations of the stack exhaust once per shift.
- (b) [The Permittee shall maintain records of any additional inspections prescribed by the Preventive Maintenance Plan \(PMP\).](#)
- (c) [Records necessary to demonstrate compliance shall be available within 30 days of the end of each compliance period.](#)
- (d) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

D.2.6 [National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers and Process Heaters \[326 IAC 20-1\] \[40 CFR Part 63, Subpart A\] \[40 CFR Part 63, Subpart DDDDD\]](#)

- (a) [General Provision](#)

The provisions of 40 CFR 63 Subpart A - General Provisions, which are incorporated as 326 IAC 20-1-1, apply to the auxiliary boiler, except when otherwise specified in 40 CFR 63 Subpart DDDDD.

(b) Effective Date

The auxiliary boiler is subject to the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Industrial, Commercial, and Institutional Boilers and Process Heaters, (40 CFR 63, Subpart DDDDD), as of the effective date of 40 CFR 63, Subpart DDDDD. Pursuant to this rule, the Permittee must comply with 40 CFR 63, Subpart DDDDD on and after three (3) years after the date of publication of the final rule for 40 CFR 63, Subpart DDDDD in the Federal Register.

(c) Permit Shield

Since the applicable requirements associated with the compliance options for this auxiliary boiler are not included and specifically identified in this permit, the permit shield authorized by Section B - Permit Shield of this permit, and set out in 326 IAC 2-7-15 does not apply to paragraph (a) of this condition.

(d) Initial Notification

Pursuant to 40 CFR 63.7545(a) and 40 CFR 63.7506(b), the Permittee shall submit an Initial Notification for the auxiliary boiler containing the information specified in 40 CFR 63.9(b)(2) not later than 120 days after the date of publication of the final rule for 40 CFR 63, Subpart DDDDD in the Federal Register, as required by 40 CFR 63.7545(b).

The initial notification shall be submitted to:
Indiana Department of Environmental Management
Compliance Data Section, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251
and
United States Environmental Protection Agency, Region V
Director, Air and Radiation Division
77 West Jackson Boulevard
Chicago, Illinois 60604-3590

The initial notification requires the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

D.2.7 Requirement to Submit a Significant Permit Modification Application [326 IAC 2-7-12]
[326 IAC 2-7-5]

The Permittee shall submit an application for a significant permit modification to IDEM, OAQ to include information regarding which compliance option or options will be chosen in the Part 70 permit for this affected source.

- (a) The significant permit modification application shall be consistent with 326 IAC 2-7-12, including information sufficient for IDEM, OAQ to incorporate into the Part 70 permit the applicable requirements of 40 CFR 63, Subpart DDDDD, a description of the affected source and activities subject to the standard, and a description of how the Permittee will meet the applicable requirements of the standard.

- (b) The significant permit modification application shall be submitted no later than nine (9) months prior to the compliance date as specified in 40 CFR 63.7495(b).

- (c) The significant permit modification application shall be submitted to:
Indiana Department of Environmental Management
Permits Branch, Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46204-2251

SECTION D.3

FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]

One (1) coal storage and handling system, with a maximum throughput of 890,000 tons of coal per year consisting of the following:

- (1) One (1) 2.23 acre outdoor coal storage pile with a storage capacity of 40,000 tons.
- (2) One (1) enclosed conveyor system, with enclosures for dust control. This system has a maximum throughput of 890,000 tons/year.
- (3) Four (4) receiving systems, where shipments of coal are discharged into one (1) of the following systems:
 - (A) Off site supplied Coal Conveyor Delivery
 - (B) Train Delivery to Hoppers
 - (C) Truck Delivery to Hoppers
 - (D) Truck Delivery to Dead Storage Piles

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.3.1 Particulate Emissions Limitations [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2, the allowable **particulate** emission rate from the coal conveying and unloading processes shall not exceed 51.41 pounds per hour when operating at a process weight rate of 101.5 tons per hour.

The pounds per hour limitation was calculated using the following equation:

Interpolation and extrapolation of the data for the process weight rate in excess of to sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 55.0 P^{0.11} - 40 \quad \text{where } E = \text{rate of emission in pounds per hour and} \\ P = \text{process weight rate in tons per hour}$$

D.3.2 Fugitive Dust Emissions [326 IAC 6-4]

The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions).

326 IAC 6-4-2(4) is not federally enforceable.

D.3.3 Preventive Maintenance Plan (PMP) [326 IAC 2-7-5(13)]

A preventive Maintenance Plan (PMP), in accordance with Section B - Preventive Maintenance Plan (PMP), of this permit, is required for this facility and its control device.

Compliance Determination Requirements

None

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

None

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

None

SECTION D.4

FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]	Insignificant Activities:
(a) Degreasing operations that do not exceed 145 gallons per 12 months.	
(b) Equipment related to manufacturing activities not resulting in the emission of HAPs: brazing equipment, cutting torches, soldering equipment, welding equipment.	
(c) Grinding and machining operations controlled with fabric filters, scrubbers, mist collectors, wet collectors and electrostatic precipitators with a design grain loading of less than or equal to 0.03 grains per actual cubic foot and gas flow rate less than or equal to 4,000 actual cubic feet per minute, including the following: deburring, buffing, polishing, abrasive blasting, pneumatic conveying, and woodworking operations.	
(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)	

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.4.1 Particulate Emission Limitations [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2 (Process Operations), the allowable **particulate** emission rate from the brazing equipment, cutting torches, soldering equipment, welding equipment and structural steel and bridge fabrication or the grinding and machining operations activities shall not exceed the allowable PM emission rate based on the following equation:

Interpolation of the data for the process weight rate up to 60,000 pounds per hour shall be accomplished by use of the equation:

$$E = 4.10P^{0.67}$$

where: E = rate of emission in pounds per hour;
P = process weight rate in tons per hour

D.4.2 Volatile Organic Compounds (VOC) [326 IAC 8-3-2] [326 IAC 8-3-5(a)(b)]

(a) Pursuant to 326 IAC 8-3-2 and 8-3-5(a) (Cold Cleaner Operations) the Permittee of a cold cleaner degreaser without remote solvent reservoirs constructed after July 1, 1990, shall ensure that the following requirements are met:

(1) Equip the degreaser with a cover. The cover must be designed so that it can be easily operated with one (1) hand if:

(A) The solvent volatility is greater than two (2) kiloPascals (fifteen (15) millimeters of mercury or three-tenths (0.3) pounds per square inch) measured at thirty-eight degrees Celsius (38⁰C) (one hundred degrees Fahrenheit (100^oF));

(B) The solvent is agitated; or

(C) The solvent is heater.

- (2) Equip the degreaser with a facility for draining cleaned articles. If the solvent volatility is greater than four and three-tenths (4.3) kiloPascals (thirty-two (32) millimeters of mercury or six-tenths (0.6) pounds per square inch) measured at thirty-eight degrees Celsius (38[°]C) (one hundred degrees Fahrenheit (100[°]F)), then the drainage facility must be internal such that articles are enclosed under the cover while draining. The drainage facility may be external for applications where an internal type cannot fit into the cleaning system.
 - (3) Provide a permanent, conspicuous label which lists the operating requirements outlined in subsection (b).
 - (4) The solvent spray, if used, must be a solid, fluid stream and shall be applied at a pressure which does not cause excessive splashing.
 - (5) Equip the degreaser with a facility for draining cleaned articles. If the solvent volatility is greater than four and three-tenths (4.3) kiloPascals (thirty-two (32) millimeters of mercury or six-tenths (0.6) pounds per square inch) measured at thirty-eight degrees Celsius (38[°]C) (one hundred degrees Fahrenheit (100[°]F)), or if the solvent is heated to a temperature greater than forty-eight and nine-tenths degrees Celsius (48.9[°]C) (one hundred twenty degrees Fahrenheit (120[°]F));
 - (A) A freeboard that attains a freeboard ratio of seventy-five hundredths (0.75) or greater.
 - (B) A water cover when solvent is used is insoluble in, and heavier than, water.
 - (C) Other systems of demonstrated equivalent control such as a refrigerated chiller or carbon adsorption. Such systems shall be submitted to U.S. EPA as a SIP revision.
- (b) Pursuant to 326 IAC 8-3-2 and 326 IAC 8-3-5(b) (Cold Cleaner Degreaser Operation and Control), the Permittee of a cold cleaning facility construction of which commenced after July 1, 1990, shall ensure that the following operating requirements are met:
- (1) Close the cover whenever articles are not being handled in the degreaser.
 - (2) Drain cleaned articles for at least fifteen (15) seconds or until dripping ceases.
 - (3) Store waste solvent only in covered containers and prohibit the disposal or transfer of waste solvent in any manner in which greater than twenty percent (20%) of the waste solvent by weight could evaporate.

Compliance Determination Requirements

None

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

None

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

None

Hoosier Energy REC, Inc.
56
– Ratts Generating Station
00001
Petersburg, Indiana
Permit Writer: Iryn Calilung

First Administrative Amendment No.: 125-23308

Amendment by: Janet Mobley

Page 44 of
Part 70 Permit No. 125-6932-

SECTION E

ACID RAIN PROGRAM CONDITIONS

Facility Description [326 IAC 2-7-5(15)]

- (a) One (1) pulverized coal-fired dry bottom boiler, identified as Boiler #1, constructed in 1970, rated at 1160 million Btu per hour energy input, used to generate up to 132 megawatts (gross) of electricity at the above location.

Particulate matter emissions are controlled by an electrostatic precipitator, emissions are measured with a continuous opacity monitor. NOx emissions are inhibited by a Low NOx Burner.

Controlled boiler emissions are exhausted to the atmosphere through a 300 foot tall chimney with an 11 foot exit diameter.

- (b) One (1) pulverized coal-fired dry bottom boiler, identified as Boiler #2, constructed in 1970, rated at 1160 million Btu per hour energy input, used to generate up to 132 megawatts (gross) of electricity at the above location.

Particulate matter emissions are controlled by an electrostatic precipitator, emissions are measured with a continuous opacity monitor. NOx emissions are inhibited by a Low NOx Burner.

Controlled boiler emissions are exhausted to the atmosphere through a 300 foot tall chimney with an 11 foot exit diameter.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

E.1 Acid Rain Permit [326 IAC 2-7-5(1)(C)] [326 IAC 21] [40 CFR 78]

- (a) The Acid Rain Permit for this source including any revisions is incorporated by reference into this Part 70 Permit. Pursuant to 326 IAC 21 (Acid Deposition Control), the Permittee shall comply with all provisions of the Acid Rain Permit and Amendments issued for this source, and any other applicable requirements contained in 40 CFR 72 through 40 CFR 78.
- (b) Where an applicable requirement of the Clean Air Act is more stringent than an applicable requirement of regulations promulgated under Title IV of the Act, both provisions shall apply.

E.2 Title IV Emissions Allowances [326 IAC 2-7-5(4)]

Emissions exceeding any allowances that the Permittee lawfully holds under the Title IV Acid Rain Program of the Clean Air Act are prohibited, subject to the following limitations:

- (a) No revision of this permit shall be required for increases in emissions that are authorized by allowances acquired under Title IV Acid Rain Program, provided that such increases do not require a permit revision under any other applicable requirement.
- (b) No limit shall be placed on the number of allowances held by the Permittee. The Permittee may not use allowances as a defense to noncompliance with any other applicable requirement.

- (c) Any such allowance shall be accounted for according to the procedures established in regulations promulgated under Title IV of the Clean Air Act.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY**

**PART 70 OPERATING PERMIT
CERTIFICATION**

Source Name: Hoosier Energy Rural Electric Cooperative (REC), Inc. - Ratts Generating Station
Source Address: State Highway 57, Petersburg, Indiana 47567
Mailing Address: P.O. Box 908, Bloomington, IN 47402
Part 70 Permit No.: T125-6932-00001

This certification shall be included when submitting monitoring, testing reports/results or other documents as required by this permit.

Please check what document is being certified:

- Annual Compliance Certification Letter (specify the year) _____
- Test Result (specify)
- Report (specify)
- Notification (specify)
- Affidavit (specify)
- Other (specify)

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Signature:

Printed Name:

Title/Position:

Telephone:

Date:

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE BRANCH
100 North Senate Avenue
Indianapolis, Indiana 46204-2251
Phone: 317-233-5674. Fax: 317-233-5967**

**PART 70 OPERATING PERMIT
EMERGENCY OCCURRENCE REPORT**

Source Name: Hoosier Energy Rural Electric Cooperative (REC), Inc. - Ratts Generating Station
Source Address: State Highway 57, Petersburg, Indiana 47567
Mailing Address: P.O. Box 908, Bloomington, IN 47402
Part 70 Permit No.: T125-6932-00001

This form consists of 2 pages

Page 1 of 2

This is an emergency as defined in 326 IAC 2-7-1(12)

The Permittee must notify the Office of Air Quality (OAQ), within four (4) business hours.
(1-800-451-6027 or 317-233-5674, ask for Compliance Section); and

The Permittee must submit notice in writing or by facsimile within two (2) days.
(Facsimile Number: 317-233-5967), and follow the other requirements of 326 IAC 2-7-16

If any of the following are not applicable, mark N/A

Facility/Equipment/Operation:

Control Equipment:

Permit Condition or Operation Limitation in Permit:

Description of the Emergency:

Describe the cause of the Emergency:

Hoosier Energy REC, Inc.
56
– Ratts Generating Station
00001
Petersburg, Indiana
Permit Writer: Iryn Calilung

First Administrative Amendment No.: 125-23308

Amendment by: Janet Mobley

Page 49 of
Part 70 Permit No. 125-6932-



Page 2 of 2 of the Emergency Occurrence Report

If any of the following are not applicable, mark N/A

Date/Time Emergency started:
Date/Time Emergency was corrected:
Was the facility being properly operated at the time of the emergency/deviation? Y N Describe:
Type of Pollutants Emitted: TSP, PM-10, SO ₂ , VOC, NO _x , CO, Pb, other:
Estimated amount of pollutant(s) emitted during emergency:
Describe the steps taken to mitigate the problem:
Describe the corrective actions/response steps taken:
Describe the measures taken to minimize emissions:
If applicable, describe the reasons why continued operation of the facilities are necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw materials of substantial economic value:
Form Completed by:
Title/Position:
Date:
Telephone:

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE DATA SECTION**

**PART 70 OPERATING PERMIT
QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT**

Source Name: Hoosier Energy Rural Electric Cooperative (REC), Inc. - Ratts generating Station
Source Address: State Highway 57, Petersburg, Indiana 47567
Mailing Address: P.O. Box 908, Bloomington, IN 47402
Part 70 Permit No.: T125-6932-00001

Months: _____ to _____ Year: _____

Page 1 of 2

This report shall be submitted quarterly based on a calendar year. Any deviation from the requirements, the date(s) of each deviation, the probable cause of the deviation, and the response steps taken must be reported. Deviations that are required to be reported by an applicable requirement shall be reported according to the schedule stated in the applicable requirement and do not need to be included in this report. Additional pages may be attached if necessary. If no deviations occurred, please specify in the box marked "No" deviations occurred this reporting period.

NO DEVIATIONS OCCURRED THIS REPORTING PERIOD.

THE FOLLOWING DEVIATIONS OCCURRED THIS REPORTING PERIOD

Permit Requirement (specify permit condition #)

Date of Deviation:

Duration of Deviation:

Number of Deviations:

Probable Cause of Deviation:

Response Steps Taken:

Permit Requirement (specify permit condition #)

Date of Deviation:

Duration of Deviation:

Number of Deviations:

Probable Cause of Deviation:

Response Steps Taken:

Hoosier Energy REC, Inc.
56
– Ratts Generating Station
00001
Petersburg, Indiana
Permit Writer: Iryn Calilung

First Administrative Amendment No.: 125-23308

Amendment by: Janet Mobley

Page 52 of
Part 70 Permit No. 125-6932-



Page 2 of 2 of the Quarterly Deviation And Compliance Monitoring Report

Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	

Form Completed by:
Title/Position:
Date:
Telephone:

Hoosier Energy REC, Inc.
56
– Ratts Generating Station
00001
Petersburg, Indiana
Permit Writer: Iryn Calilung

First Administrative Amendment No.: 125-23308

Amendment by: Janet Mobley

Page 54 of
Part 70 Permit No. 125-6932-

Attach a signed certification to complete this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE DATA SECTION**

**PART 70 OPERATING PERMIT
QUARTERLY SO₂ EMISSION RATE REPORT**

Source Name: Hoosier Energy Rural Electric Cooperative (REC), Inc. - Ratts Generating Station
Source Address: State Highway 57, Petersburg, Indiana 47567
Mailing Address: P.O. Box 908, Bloomington, Indiana 47402
Facility: Boiler #1 and Boiler #2
Part 70 Permit No.: T125-6932-00001
Parameter: SO₂ Emission Rate
Limit: SO₂ emission rate from either Boiler #1 and Boiler #2 shall not exceed 6.0 lbs/mmBtu based on a 30 day rolling average.

YEAR:

Month	Coal Consumption	Sulfur Content	Coal Heat Content	Ash Content	SO ₂ Emission Rate

- No deviation occurred in this quarter.
- Deviation/s occurred in this quarter.
Deviation has been reported on:

Submitted by:

Form Completed by:
Title/Position:
Date:
Telephone:

Hoosier Energy REC, Inc.
56
– Ratts Generating Station
00001
Petersburg, Indiana
Permit Writer: Iryn Calilung

First Administrative Amendment No.: 125-23308

Amendment by: Janet Mobley

Page 56 of
Part 70 Permit No. 125-6932-

Attach a signed certification to complete this report.