



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

TO: Interested Parties / Applicant

DATE: May 7, 2008

RE: Northern Indiana Public Service Company (NIPSCO) / 073-23745-00008

FROM: Matthew Stuckey, Branch Chief
Permits Branch
Office of Air Quality

Notice of Decision: Approval – Effective Immediately

Please be advised that on behalf of the Commissioner of the Department of Environmental Management, I have issued a decision regarding the enclosed matter. Pursuant to IC 13-15-5-3, this permit is effective immediately, unless a petition for stay of effectiveness is filed and granted, and may be revoked or modified in accordance with the provisions of IC 13-15-7-1.

If you wish to challenge this decision, IC 4-21.5-3-7 and IC 13-15-6-1(b) or IC 13-15-6-1(a) require that you file a petition for administrative review. This petition may include a request for stay of effectiveness and must be submitted to the Office of Environmental Adjudication, 100 North Senate Avenue, Government Center North, Suite N 501E, Indianapolis, IN 46204.

For an **initial Title V Operating Permit**, a petition for administrative review must be submitted to the Office of Environmental Adjudication within **thirty (30)** days from the receipt of this notice provided under IC 13-15-5-3, pursuant to IC 13-15-6-1(b).

For a **Title V Operating Permit renewal**, a petition for administrative review must be submitted to the Office of Environmental Adjudication within **fifteen (15)** days from the receipt of this notice provided under IC 13-15-5-3, pursuant to IC 13-15-6-1(a).

The filing of a petition for administrative review is complete on the earliest of the following dates that apply to the filing:

- (1) the date the document is delivered to the Office of Environmental Adjudication (OEA);
- (2) the date of the postmark on the envelope containing the document, if the document is mailed to OEA by U.S. mail; or
- (3) The date on which the document is deposited with a private carrier, as shown by receipt issued by the carrier, if the document is sent to the OEA by private carrier.

The petition must include facts demonstrating that you are either the applicant, a person aggrieved or adversely affected by the decision or otherwise entitled to review by law. Please identify the permit, decision, or other order for which you seek review by permit number, name of the applicant, location, date of this notice and all of the following:

- (1) the name and address of the person making the request;

- (2) the interest of the person making the request;
- (3) identification of any persons represented by the person making the request;
- (4) the reasons, with particularity, for the request;
- (5) the issues, with particularity, proposed for considerations at any hearing; and
- (6) identification of the terms and conditions which, in the judgment of the person making the request, would be appropriate in the case in question to satisfy the requirements of the law governing documents of the type issued by the Commissioner.

Pursuant to 326 IAC 2-7-18(d), any person may petition the U.S. EPA to object to the issuance of an initial Title V operating permit, permit renewal, or modification within sixty (60) days of the end of the forty-five (45) day EPA review period. Such an objection must be based only on issues that were raised with reasonable specificity during the public comment period, unless the petitioner demonstrates that it was impracticable to raise such issues, or if the grounds for such objection arose after the comment period.

To petition the U.S. EPA to object to the issuance of a Title V operating permit, contact:

U.S. Environmental Protection Agency
401 M Street
Washington, D.C. 20406

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178. Callers from within Indiana may call toll-free at 1-800-451-6027, ext. 3-0178.



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels, Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

PART 70 OPERATING PERMIT
OFFICE OF AIR QUALITY

Northern Indiana Public Service Company (NIPSCO)
R. M. Schahfer Generating Station
2723 East, 1500 North
Wheatfield, Indiana 46392

(herein known as the Permittee) is hereby authorized to operate subject to the conditions contained herein, the source described in Section A (Source Summary) of this permit.

The Permittee must comply with all conditions of this permit. Noncompliance with any provisions of this permit is grounds for enforcement action; permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. Noncompliance with any provision of this permit, except any provision specifically designated as not federally enforceable, constitutes a violation of the Clean Air Act. It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. An emergency does constitute an affirmative defense in an enforcement action provided the Permittee complies with the applicable requirements set forth in Section B, Emergency Provisions.

This permit is issued in accordance with 326 IAC 2 and 40 CFR Part 70 Appendix A and contains the conditions and provisions specified in 326 IAC 2-7 as required by 42 U.S.C. 7401, et. seq. (Clean Air Act as amended by the 1990 Clean Air Act Amendments), 40 CFR Part 70.6, IC 13-15 and IC 13-17. This permit also addresses certain new source review requirements for existing equipment and is intended to fulfill the new source review procedures pursuant to 326 IAC 2-2 and 326 IAC 2-7-10.5, applicable to those conditions.

Operation Permit No.: T073-6792-00008	
Original signed by Nisha Sizemore, Chief Permits Branch Office of Air Quality	Issuance Date: September 7, 2006 Expiration Date: September 7, 2011

First Significant Permit Modification No.: T073-23745-00008	
Issued by/ Original signed by: Matthew Stuckey, Deputy Branch Chief Permits Branch Office of Air Quality	Issuance Date: May 7, 2008 Expiration Date: September 7, 2011

TABLE OF CONTENTS

A	SOURCE SUMMARY	7
A.1	General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)] [326 IAC 2-7-1(22)]	
A.2	Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)] [326 IAC 2-7-5(15)]	
A.3	Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)]	
A.4	Part 70 Permit Applicability [326 IAC 2-7-2]	
B	GENERAL CONDITIONS	12
B.1	Definitions [326 IAC 2-7-1]	
B.2	Permit Term [326 IAC 2-7-5(2)][326 IAC 2-1.1-9.5][326 IAC 2-7-4(a)(1)(D)][IC 15-13-6(a)]	
B.3	Enforceability [326 IAC 2-7-7]	
B.4	Termination of Right to Operate [326 IAC 2-7-10] [326 IAC 2-7-4(a)]	
B.5	Severability [326 IAC 2-7-5(5)]	
B.6	Property Rights or Exclusive Privilege [326 IAC 2-7-5(6)(D)]	
B.7	Duty to Provide Information [326 IAC 2-7-5(6)(E)]	
B.8	Certification [326 IAC 2-7-4(f)] [326 IAC 2-7-6(1)] [326 IAC 2-7-5(3)(C)]	
B.9	Annual Compliance Certification [326 IAC 2-7-6(5)]	
B.10	Preventive Maintenance Plan [326 IAC 2-7-5(1),(3)and (13)] [326 IAC 2-7-6(1) and (6)] [326 IAC 1-6-3]	
B.11	Emergency Provisions [326 IAC 2-7-16]	
B.12	Permit Shield [326 IAC 2-7-15] [326 IAC 2-7-20] [326 IAC 2-7-12]	
B.13	Prior Permits Superseded [326 IAC 2-1.1-9.5][326 IAC 2-7-10.5]	
B.14	Deviations from Permit Requirements and Conditions [326 IAC 2-7-5(3)(C)(ii)]	
B.15	Permit Modification, Reopening, Revocation and Reissuance, or Termination [326 IAC 2-7-5(6)(C)] [326 IAC 2-7-8(a)] [326 IAC 2-7-9]	
B.16	Permit Renewal [326 IAC 2-7-3] [326 IAC 2-7-4][326 IAC 2-7-8(e)]	
B.17	Source Modification Requirements [326 IAC 1-2-42] [326 IAC 2-7-10.5][326 IAC 2-2-2]	
B.18	Permit Amendment or Modification [326 IAC 2-7-11] [326 IAC 2-7-12] [40 CFR 72]	
B.19	Permit Revision Under Economic Incentives and Other Programs [326 IAC 2-7-5(8)] [326 IAC 2-7-12 (b)(2)]	
B.20	Operational Flexibility [326 IAC 2-7-20] [326 IAC 2-7-10.5]	
B.21	Inspection and Entry [326 IAC 2-7-6] [IC 13-14-2-2] [IC 13-17-3-2] [IC 13-30-3-1]	
B.22	Transfer of Ownership or Operational Control [326 IAC 2-7-11]	
B.23	Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-7-5(7)] [326 IAC 2-1.1-7]	
B.24	Credible Evidence [326 IAC 2-7-5(3)][326 IAC 2-7-6][62 FR 8314][326 IAC 1-1-6]	
B.25	Term of Conditions [326 IAC 2-1.1-9.5]	
C	SOURCE OPERATION CONDITIONS	23
	Emission Limitations and Standards [326 IAC 2-7-5(1)]	
C.1	Particulate Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]	
C.2	Opacity [326 IAC 5-1]	
C.3	Open Burning [326 IAC 4-1] [IC 13-17-9]	
C.4	Incineration [326 IAC 4-2] [326 IAC 9-1-2]	
C.5	Fugitive Dust Emissions [326 IAC 6-4]	
C.6	Motor Vehicle Fugitive Dust Sources [326 IAC 6-4-4]	
C.7	Stack Height [326 IAC 1-7]	
C.8	Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]	
	Testing Requirements [326 IAC 2-7-6(1)]	
C.9	Performance Testing [326 IAC 3-6]	
	Compliance Requirements [326 IAC 2-1.1-11]	
C.10	Compliance Requirements [326 IAC 2-1.1-11]	

TABLE OF CONTENTS (Continued)

	Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]	
	C.11 Compliance Monitoring [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]	
	C.12 Maintenance of Continuous Opacity Monitoring Equipment [326 IAC 2-7-5(3)(A)(iii)]	
	C.13 Monitoring Methods [326 IAC 3] [40 CFR 60] [40 CFR 63]	
	C.14 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]	
	Corrective Actions and Response Steps [326 IAC 2-7-5] [326 IAC 2-7-6]	
	C.15 Emergency Reduction Plans [326 IAC 1-5-2] [326 IAC 1-5-3]	
	C.16 Risk Management Plan [326 IAC 2-7-5(12)] [40 CFR 68]	
	C.17 Response to Excursions or Exceedances [326 IAC 2-7-5] [326 IAC 2-7-6]	
	C.18 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5] [326 IAC 2-7-6]	
	Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]	
	C.19 Emission Statement [326 IAC 2-7-5(3)(C)(iii)] [326 IAC 2-7-5(7)] [326 IAC 2-7-19(c)] [326 IAC 2-6]	
	C.20 General Record Keeping Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-6][326 IAC 2-2] [326 IAC 2-3]	
	C.21 General Reporting Requirements [326 IAC 2-7-5(3)(C)] [326 IAC 2-1.1-11][326 IAC 2-2] [326 IAC 2-3]	
	Stratospheric Ozone Protection	
	C.22 Compliance with 40 CFR 82 and 326 IAC 22-1	
	Ambient Monitoring Requirements [326 IAC 7-3]	
	C.23 Ambient Monitoring [326 IAC 7-3]	
D.1	FACILITY OPERATION CONDITIONS - Coal-Fired Boiler, Unit 14.....	32
	D.1.0 NOV Provisions	
	Emission Limitations and Standards [326 IAC 2-7-5(1)]	
	D.1.1 Particulate Emission Requirements [326 IAC 6-2.1(g)]	
	D.1.2 Startup, Shutdown, and Other Opacity Limits [326 IAC 5-1-3]	
	D.1.3 Sulfur Dioxide (SO ₂) [326 IAC 7-1.1-2]	
	D.1.4 Capacity Limitation [326 IAC 6-2-1(g)] [326 IAC 2-7-5]	
	Compliance Determination Requirements	
	D.1.5 Testing Requirements [326 IAC 2-7-6(1),(6)] [326 IAC 2-1.1-11]	
	D.1.6 Operation of Electrostatic Precipitator [326 IAC 2-7-6(6)]	
	D.1.7 Continuous Emissions Monitoring [326 IAC 3-5]	
	D.1.8 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3] [326 IAC 7-2] [326 IAC 7-1.1-2]	
	Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]	
	D.1.9 Transformer-Rectifier (T-R) Sets [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]	
	D.1.10 Opacity Readings [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]	
	D.1.11 SO ₂ Monitoring System Downtime [326 IAC 2-7-6] [326 IAC 2-7-5(3)]	
	Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]	
	D.1.12 Record Keeping Requirements	
	D.1.13 Reporting Requirements	
D.2	FACILITY OPERATION CONDITIONS - Coal-Fired Boiler, Unit 15.....	37
	D.2.0 NOV Provisions	

TABLE OF CONTENTS (Continued)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

- D.2.1 New Source Performance Standard (NSPS) [326 IAC 12] [40 CFR 60, Subpart D] [326 IAC 6-2-1(f)]
- D.2.2 Startup, Shutdown, and Other Opacity Limits [326 IAC 5-1-3]
- D.2.3 Sulfur Dioxide (SO₂) [326 IAC 7-1.1-2]
- D.2.4 General Provisions Relating to NSPS [326 IAC 12-1] [40 CFR 60, Subpart A]

Compliance Determination Requirements

- D.2.5 Testing Requirements [326 IAC 2-7-6(1),(6)] [326 IAC 2-1.1-11]
- D.2.6 Operation of Electrostatic Precipitator [326 IAC 2-7-6(6)]
- D.2.7 Continuous Emissions Monitoring [326 IAC 3-5] [326 IAC 12] [40 CFR 60, Subpart D] [326 IAC 2-2]
- D.2.8 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3] [326 IAC 7-2] [326 IAC 7-1.1]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- D.2.9 Transformer-Rectifier (T-R) Sets [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
- D.2.10 SO₂ Monitoring System Downtime [326 IAC 2-7-6] [326 IAC 2-7-5(3)]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

- D.2.11 Record Keeping Requirements
- D.2.12 Reporting Requirements

D.3 FACILITY OPERATION CONDITIONS - Coal-Fired Boilers, Units 17 and 18 44

Emission Limitations and Standards [326 IAC 2-7-5(1)]

- D.3.1 Prevention of Significant Deterioration (PSD) and Construction Permit Limitations [40 CFR 52.21] [326 IAC 2-2] [326 IAC 6-2-1(g)] [326 IAC 7-1.1-2]
- D.3.2 New Source Performance Standard (NSPS) [326 IAC 12] [40 CFR 60, Subpart Da]
- D.3.3 Alternative Fuel Blends [326 IAC 2-2]
- D.3.4 General Provisions Relating to NSPS [326 IAC 12-1] [40 CFR 60, Subpart A]

Compliance Determination Requirements

- D.3.5 Testing Requirements [326 IAC 2-7-6(1),(6)] [326 IAC 2-1.1-11]
- D.3.6 Operation of Electrostatic Precipitator [326 IAC 2-7-6(6)]
- D.3.7 Scrubber Operation [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
- D.3.8 NSPS Compliance Provisions [326 IAC 12] [40 CFR 60, Subpart Da]
- D.3.9 Continuous Emissions Monitoring [326 IAC 3-5] [326 IAC 12] [40 CFR 60, Subpart Da] [326 IAC 2-2]
- D.3.10 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3] [326 IAC 7-2] [326 IAC 7-1.1-2]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- D.3.11 Transformer-Rectifier (T-R) Sets [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
- D.3.12 SO₂ Monitoring System Downtime [326 IAC 2-7-6] [326 IAC 2-7-5(3)]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

- D.3.13 Record Keeping Requirements
- D.3.14 Reporting Requirements

D.4 FACILITY OPERATION CONDITIONS - Turbines 16A and 16B 51

Emission Limitations and Standards [326 IAC 2-7-5(1)]

- D.4.1 Prevention of Significant Deterioration (PSD) and Construction Permit Limitations [40 CFR 52.21] [326 IAC 2-2] [326 IAC 6-2-1(g)] [326 IAC 7-1.1-2]
- D.4.2 New Source Performance Standard (NSPS) [326 IAC 12] [40 CFR 60, Subpart GG]

TABLE OF CONTENTS (Continued)

D.4.3	Opacity [326 IAC 5-1]	
D.4.4	General Provisions Relating to NSPS [326 IAC 12-1] [40 CFR 60, Subpart A]	
Compliance Determination Requirements		
D.4.5	NO _x Control	
D.4.6	Continuous Monitoring System [326 IAC 12][40 CFR 60, Subpart GG]	
D.4.7	Natural Gas Definition [326 IAC 12] [40 CFR 60, Subpart GG]	
Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]		
D.4.8	Record Keeping Requirements	
D.4.9	Reporting Requirements	
D.5	FACILITY OPERATION CONDITIONS - Units 14 & 15 Fuel Handling	55
Emission Limitations and Standards [326 IAC 2-7-5(1)]		
D.5.1	Particulate [326 IAC 6-3-2]	
D.6	FACILITY OPERATION CONDITIONS - Units 17 & 18 Fuel Handling	57
Emission Limitations and Standards [326 IAC 2-7-5(1)]		
D.6.1	Prevention of Significant Deterioration (PSD) and Construction Permit Limitations [40 CFR 52.21] [326 IAC 2-2]	
D.6.2	New Source Performance Standards (NSPS) [326 IAC 12] [40 CFR 60, Subpart Y]	
D.6.3	Particulate [326 IAC 6-3-2]	
D.6.4	General Provisions Relating to NSPS [36 IAC 12-1] [40 CFR 60, Subpart A]	
Compliance Determination Requirements		
D.6.5	Particulate Control [326 IAC 2-7-6(6)]	
Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]		
D.6.5	Baghouse Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]	
D.6.6	NSPS Compliance Provisions [326 IAC 12] [40 CFR 60, Subpart Y]	
D.6.7	Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]	
D.6.8	Baghouse Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]	
Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]		
D.6.9	Record Keeping Requirements	
D.7	FACILITY OPERATION CONDITIONS - FGD System Material Handling	61
Emission Limitations and Standards [326 IAC 2-7-5(1)]		
D.7.1	Particulate [326 IAC 6-3-2]	
D.8	FACILITY OPERATION CONDITIONS - Fly Ash Handling	62
Emission Limitations and Standards [326 IAC 2-7-5(1)]		
D.8.1	Prevention of Significant Deterioration (PSD) and Construction Permit Limitations [40 CFR 52.21] [326 IAC 2-2]	
D.8.2	Particulate [326 IAC 6-3-2]	
Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]		
D.8.3	Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]	
D.8.4	Baghouse Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]	
D.8.5	Broken or Failed Bag Detection [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]	

TABLE OF CONTENTS (Continued)

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
D.8.6 Record Keeping Requirements

D.9 FACILITY OPERATION CONDITIONS - Bottom Ash and FGD Waste Material Handling 65

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.9.1 Prevention of Significant Deterioration (PSD) and Construction Permit Limitations [40 CFR 52.21] [326 IAC 2-2]
D.9.2 Fugitive Dust Emission Limitations [326 IAC 6-4-2]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.9.3 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
D.9.4 Record Keeping Requirements

D.10 FACILITY OPERATION CONDITIONS - Emergency Generator 68

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.10.1 Sulfur Dioxide (SO₂) [326 IAC 7-1.1-2]

Compliance Determination Requirements
D.10.2 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3] [326 IAC 7-2] [326 IAC 7-1.1-2]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
D.10.3 Record Keeping Requirements

D.11 FACILITY OPERATION CONDITIONS - Additional Insignificant Activities 69
TABLE OF CONTENTS (Continued)

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.11.1 Particulate [326 IAC 6-3-2]

E ACID RAIN PROGRAM CONDITIONS 70

E.1 Acid Rain Permit [326 IAC 2-7-5(1)(C)] [326 IAC 21] [40 CFR 72 through 40 CFR 78]
E.2 Title IV Emissions Allowances [326 IAC 2-7-5(4)] [326 IAC 21]

F NITROGEN OXIDES BUDGET TRADING PROGRAM - NO_x Budget Permit 72

F.1 Automatic Incorporation of Definitions [326 IAC 10-4-7(e)]
F.2 Standard Permit Requirements [326 IAC 10-4-4(a)]
F.3 Monitoring Requirements [326 IAC 10-4-4(b)]
F.4 Nitrogen Oxides Requirements [326 IAC 10-4-4(c)]
F.5 Excess Emissions Requirements [326 IAC 10-4-4(d)]
F.6 Record Keeping Requirements [326 IAC 10-4-4(e)] [326 IAC 2-7-5(3)]
F.7 Reporting Requirements [326 IAC 10-4-4(e)]
F.8 Liability [326 IAC 10-4-4(f)]
F.9 Effect on Other Authorities [326 IAC 10-4-4(g)]

Certification 77
Emergency Occurrence Report..... 78
Quarterly Report..... 80-81
Quarterly Deviation and Compliance Monitoring Report 82
Appendix A: Acid Rain Permit attachment

SECTION A

SOURCE SUMMARY

This permit is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ). The information describing the source contained in conditions A.1 through A.3 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this permit pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)] [326 IAC 2-7-1(22)]

The Permittee owns and operates a stationary electric utility generating station.

Source Address: 2723 East, 1500 North, Wheatfield, Indiana, 46392
Mailing Address: Arthur E. Smith, 801 E. 86th Avenue, Merrillville, Indiana, 46410
Telephone Number: 219-647-5252
SIC Code: 4911
County Location: Jasper
County Status: Attainment for all criteria pollutants
Source Status: Part 70 Permit Program
Major Source, under PSD Rules;
Major Source, Section 112 of the Clean Air Act
1 of 28 Source Categories

A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)] [326 IAC 2-7-5(15)]

This stationary source consists of the following emission units and pollution control devices:

- (a) One (1) cyclone coal-fired boiler identified as Unit 14, with construction commenced in 1970 and commercial operation begun in 1976, with a design heat input capacity of 4650 million Btu per hour (MMBtu/hr), combusting No. 2 fuel oil and/or natural gas for ignition and as supplemental fuels, using an electrostatic precipitator (ESP) for control of particulate matter and exhausting to stack 14. Unit 14 has a selective catalytic reduction (SCR) system, and has continuous emissions monitoring systems (CEMS) for monitoring nitrogen oxides (NO_x) and sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system.
- (b) One (1) dry bottom pulverized coal-fired boiler identified as Unit 15, with construction commenced in 1974 and commercial operation begun in 1979, with a design heat input capacity of 5100 million Btu per hour (MMBtu/hr), with low NO_x burners, combusting No. 2 fuel oil and/or natural gas for ignition and as supplemental fuels, using an electrostatic precipitator (ESP) with a flue gas conditioning (FGC) system for control of particulate matter, and exhausting to stack 15. Unit 15 has continuous emissions monitoring systems (CEMS) for monitoring nitrogen oxides (NO_x) and sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system.
- (c) One (1) dry bottom pulverized coal-fired boiler identified as Unit 17, with construction started in 1980 and commercial operation begun in 1983, with a design heat input capacity of 3967 million Btu per hour (MMBtu/hr) based on 30-day averages from coal sampling, with low NO_x burners, combusting No. 2 fuel oil and/or natural gas for ignition and as supplemental fuels, using an electrostatic precipitator (ESP) for control of particulate matter, and exhausting through a limestone-based flue gas desulfurization system to stack 17. Unit 17 is equipped with continuous emissions monitoring systems (CEMS) for monitoring nitrogen oxides (NO_x) and sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Unit 17 has been approved to fire blends of coal and petroleum coke.

- (d) One (1) dry bottom pulverized coal-fired boiler identified as Unit 18, with construction started in 1980 and commercial operation begun in 1986, with a design heat input capacity of 3,967 million Btu per hour (MMBtu/hr) with low NO_x burners, combusting No. 2 fuel oil and/or natural gas for ignition and as supplemental fuels, using an electrostatic precipitator (ESP) for control of particulate matter, and exhausting through a limestone-based flue gas desulfurization system to stack 18. Unit 18 has continuous emissions monitoring systems (CEMS) for monitoring nitrogen oxides (NO_x) and sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Unit 18 has been approved to fire blends of coal and petroleum coke.
- (e) Two (2) natural gas-fired combustion turbines, identified as 16A and 16B, constructed in 1979, each with a design heat input capacity of 1,450 million Btu per hour (MMBtu/hr), each using water injection as needed for NO_x control, exhausting to stacks 16A and 16B, respectively. Units 16A and 16B have continuous emissions monitoring systems (CEMS) for monitoring nitrogen oxides (NO_x) for use during the ozone control period, and continuous monitoring systems to measure the water to fuel ratio.
- (f) Coal storage and handling systems for Unit 14 and 15 boilers, constructed in 1972.
 - (1) Rail car unloading with wet suppression for PM control during unloading and enclosure for ancillary dust control.
 - (2) Coal pile unloading, coal storage pile(s), material handling equipment, and coal conveyors.
 - (3) Transfer House, with carryover wet suppression and enclosed transfer points within an enclosure for ancillary dust control, with an estimated throughput of 3,000 tons per hour.
 - (4) Crusher House, with carryover wet suppression for PM control and enclosed transfer points within an enclosure for ancillary dust control.
 - (5) Tripper House to tripper bays, with enclosed transfer points within an enclosure for dust control.
 - (6) Two (2) tripper bays with an estimated combined capacity of 3,000 tons per hour, with carryover wet suppression for PM control, each using an enclosure for ancillary dust control.
- (g) Fuel storage and handling systems for Unit 17 and 18 boilers.
 - (1) Rail car unloading of coal, with a multi-compartment baghouse for PM control and enclosure for ancillary dust control.
 - (2) Truck unloading of petroleum coke (petcoke).
 - (3) Coal pile unloading, coal storage pile(s), petcoke pile unloading, petcoke storage pile(s), material handling equipment, and conveyors.
 - (4) Transfer House with an estimated throughput of 4,000 tons per hour, with enclosed transfer points within an enclosure for ancillary dust control, with a multi-compartment baghouse for PM control. To produce petcoke blends, coal and petcoke are combined in rotary plow during transfer to conveyor.
 - (5) Crusher House with a designated capacity of 3,000 tons per hour, with enclosed transfer points within an enclosure for dust control, with a multi-compartment baghouse for PM control.

- (6) Transfer House to tripper with an estimated throughput of 3,000 tons per hour, with enclosed transfer points within an enclosure for ancillary dust control.
 - (7) Two (2) tripper conveyors with an estimated combined throughput of 3,000 tons per hour with enclosure for ancillary dust control, with a multi-compartment baghouse for PM control.
 - (8) Twelve (12) Fuel Silos (bunkers) with enclosure for dust control, with two (2) multi-compartment vent filters for PM control.
- (h) Material handling for the flue gas desulfurization systems for Unit 17 and 18 boilers, including the following:
- (1) One (1) limestone slurry preparation system with a maximum hourly throughput rate of 38,941 pounds of limestone per hour.
 - (2) Two (2) ground limestone pneumatic truck unloading systems connected to Unit 17 limestone silos, with baghouses for PM control.
 - (3) Two (2) ground limestone pneumatic truck unloading systems connected to Unit 18 limestone silos, with baghouses for PM control.
 - (4) One (1) gypsum conveying system, with a maximum design throughput of 150 tons per hour. All gypsum is handled wet.
- (i) Dry fly ash handling and disposal.
- (1) Pneumatic conveyance to storage silos, with a design capacity of 70 tons per hour of fly ash from Units 14 and 15 combined, and a design capacity of 63 tons per hour of fly ash from each of Units 17 and 18.
 - (2) Fly ash storage silos for Units 14, 15, 17, and 18, with cyclone separators, silo collector bag filters, and silo bin vent bag filters. Each silo has wet and dry unloaders, each with a design unloading capacity of 300+ tons per hour, with particulate emissions controlled by the use of a telescoping chute with a vacuum system and a bin vent filter when the ash is being loaded dry, and controlled by the use of water spray mixed with the ash when the ash is being loaded wet.
 - (3) Two (2) storage silos originally used for dual-alkali FGD system, currently used for storage of fly ash from Unit 15; with cyclone separators, silo collector bag filters, and bin vent bag filters; with telescoping chute unloaders with vacuum line to the silo for dry ash unloading to enclosed trucks.
 - (4) Transportation by truck via in-plant haul roads; and onsite disposal area.
- (j) Wet process bottom ash handling, with sluicing lines conveying ash to storage ponds in the Waste Disposal Area.
- (k) Ponded bottom ash handling/removal operations.

A.3 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-7-4(c)]
[326 IAC 2-7-5(15)]

This stationary source also includes the following insignificant activities which are specifically regulated, as defined in 326 IAC 2-7-1(21):

- (a) Conveyors as follows: [326 IAC 6-3]

- (1) Covered conveyor for coal or coke conveying of less than or equal to 360 tons per day;
 - (2) Covered conveyors for limestone conveying of less than or equal to 7,200 tons per day for sources other than mineral processing plants constructed after August 31, 1983;
 - (3) Uncovered coal conveying of less than or equal to 120 tons per day; and
 - (4) Underground conveyors.
- (b) Coal bunker and coal scale exhausts and associated dust collector vents. [326 IAC 6-3]
- (c) The following equipment related to manufacturing activities not resulting in the emission of HAPs: brazing equipment, cutting torches, soldering equipment, welding equipment. [326 IAC 6-3]
- (d) Any of the following structural steel and bridge fabrication activities: [326 IAC 6-3]
- (1) Cutting 200,000 linear feet or less of one inch (10) plate or equivalent.
 - (2) Using 80 tons or less of welding consumables.
- (e) Emergency generators as follows: Diesel generators not exceeding 1600 horsepower. [326 IAC 7]
- (f) Grinding and machining operations controlled with fabric filters, scrubbers, mist collectors, wet collectors and electrostatic precipitators with a design grain loading of less than or equal to 0.03 grains per actual cubic foot and a gas flow rate less than or equal to 4000 actual cubic feet per minute, including the following: deburring; buffing; polishing; abrasive blasting; pneumatic conveying; and woodworking operations. [326 IAC 6-3]
- (g) Other activities or categories not previously identified with potential, uncontrolled emissions equal to or less than thresholds require listing only: Pb 0.6 ton per year or 3.29 pounds per day, SO₂ 5 pounds per hour or 25 pounds per day, NO_x 5 pounds per hour or 25 pounds per day, CO 25 pounds per day, PM 5 pounds per hour or 25 pounds per day, VOC 3 pounds per hour or 15 pounds per day:
- (1) Evaporation of Boiler Chemical Cleaning wastes.
 - (2) Coal pile wind erosion. [326 IAC 6-4]
 - (3) Wet handling of FGD sludge material collected from the FGD building sumps, sluiced to the Material Storage Runoff Pond. FGD material dredged from pond inlet area is dewatered on the pond bank with trucks conveying dewatered material to onsite landfill. [326 IAC 6-4]
 - (4) Shot blasters. [326 IAC 6-3]
 - (5) Gypsum stockpile. [326 IAC 6-3]

A.4 Part 70 Permit Applicability [326 IAC 2-7-2]

This stationary source is required to have a Part 70 permit by 326 IAC 2-7-2 (Applicability) because:

- (a) It is a major source, as defined in 326 IAC 2-7-1(22);
- (b) It is a source in a source category designated by the United States Environmental Protection Agency (U.S. EPA) under 40 CFR 70.3 (Part 70 - Applicability); and
- (c) It is an affected source under Title IV (Acid Deposition Control) of the Clean Air Act, as defined in 326 IAC 2-7-1(3).

SECTION B

GENERAL CONDITIONS

B.1 Definitions [326 IAC 2-7-1]

Terms in this permit shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, the applicable definitions found in the statutes or regulations (IC 13-11, 326 IAC 1-2 and 326 IAC 2-7) shall prevail.

B.2 Permit Term [326 IAC 2-7-5(2)] [326 IAC 2-1.1-9.5] [326 IAC 2-7-4(a)(1)(D)][IC 15-13-6(a)]

(a) This permit, T073-6792-00008, is issued for a fixed term of five (5) years from the issuance date of this permit, as determined in accordance with IC 4-21.5-3-5(f) and IC 13-15-5-3. Subsequent revisions, modifications, or amendments of this permit do not affect the expiration date of this permit or of permits issued pursuant to Title IV of the Clean Air Act and 326 IAC 21 (Acid Deposition Control).

(b) If IDEM, OAQ, upon receiving a timely and complete renewal permit application, fails to issue or deny the permit renewal prior to the expiration date of this permit, this existing permit shall not expire and all terms and conditions shall continue in effect, including any permit shield provided in 326 IAC 2-7-15, until the renewal permit has been issued or denied.

B.3 Enforceability [326 IAC 2-7-7]

Unless otherwise stated, all terms and conditions in this permit, including any provisions designed to limit the source's potential to emit, are enforceable by IDEM, the United States Environmental Protection Agency (U.S. EPA) and by citizens in accordance with the Clean Air Act.

B.4 Termination of Right to Operate [326 IAC 2-7-10] [326 IAC 2-7-4(a)]

The Permittee's right to operate this source terminates with the expiration of this permit unless a timely and complete renewal application is submitted at least nine (9) months prior to the date of expiration of the source's existing permit, consistent with 326 IAC 2-7-3 and 326 IAC 2-7-4(a).

B.5 Severability [326 IAC 2-7-5(5)]

The provisions of this permit are severable; a determination that any portion of this permit is invalid shall not affect the validity of the remainder of the permit.

B.6 Property Rights or Exclusive Privilege [326 IAC 2-7-5(6)(D)]

This permit does not convey any property rights of any sort, or any exclusive privilege.

B.7 Duty to Provide Information [326 IAC 2-7-5(6)(E)]

(a) The Permittee shall furnish to IDEM, OAQ, within a reasonable time, any information that IDEM, OAQ, may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The submittal by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34). Upon request, the Permittee shall also furnish to IDEM, OAQ, copies of records required to be kept by this permit.

(b) For information furnished by the Permittee to IDEM, OAQ, the Permittee may include a claim of confidentiality in accordance with 326 IAC 17.1. When furnishing copies of requested records directly to U. S. EPA, the Permittee may assert a claim of confidentiality in accordance with 40 CFR 2, Subpart B.

B.8 Certification [326 IAC 2-7-4(f)] [326 IAC 2-7-6(1)] [326 IAC 2-7-5(3)(C)]

(a) Where specifically designated by this permit or required by an applicable requirement, any application form, report, or compliance certification submitted shall contain certification by a responsible official of truth, accuracy, and completeness. This certification shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

- (b) One (1) certification shall be included, using the attached Certification Form, with each submittal requiring certification. One (1) certification may cover multiple forms in one (1) submittal.
- (c) A responsible official is defined at 326 IAC 2-7-1(34).

B.9 Annual Compliance Certification [326 IAC 2-7-6(5)]

- (a) The Permittee shall annually submit a compliance certification report which addresses the status of the source's compliance with the terms and conditions contained in this permit, including emission limitations, standards, or work practices. The initial certification shall cover the time period from the date of final permit issuance through December 31 of the same year. All subsequent certifications shall cover the time period from January 1 to December 31 of the previous year, and shall be submitted in letter form no later than July 1 of each year to:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V
Air and Radiation Division, Air Enforcement Branch - Indiana (AE-17J)
77 West Jackson Boulevard
Chicago, Illinois 60604-3590

- (b) The annual compliance certification report required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.
- (c) The annual compliance certification report shall include the following:
 - (1) The appropriate identification of each term or condition of this permit that is the basis of the certification;
 - (2) The compliance status;
 - (3) Whether compliance was continuous or intermittent; and
 - (4) The methods used for determining the compliance status of the source, currently and over the reporting period consistent with 326 IAC 2-7-5(3).

The submittal by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

B.10 Preventive Maintenance Plan [326 IAC 2-7-5(1),(3) and (13)] [326 IAC 2-7-6(1) and (6)] [326 IAC 1-6-3]

- (a) The Permittee shall prepare and maintain Preventive Maintenance Plans (PMPs) within ninety (90) days after issuance of this permit for the source as described in 326 IAC 1-6-3. At a minimum, the PMPs shall include:

- (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;
- (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
- (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

If, due to circumstances beyond the Permittee's control, the PMPs cannot be prepared and maintained within the above time frame, the Permittee may extend the date an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

The PMP extension notification does not require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

- (b) A copy of the PMPs shall be submitted to IDEM, OAQ, upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. IDEM, OAQ, may require the Permittee to revise its PMPs whenever lack of proper maintenance causes or is the primary contributor to an exceedance of any limitation on emissions or potential to emit. The PMPs do not require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).
- (c) To the extent the Permittee is required by 40 CFR Part 63 to have an Operation, Maintenance, and Monitoring (OMM) Plan for a unit, such Plan is deemed to satisfy the PMP requirements of 326 IAC 1-6-3 for that unit.

B.11 Emergency Provisions [326 IAC 2-7-16]

- (a) An emergency, as defined in 326 IAC 2-7-1(12), is not an affirmative defense for an action brought for noncompliance with a federal or state health-based emission limitation.
- (b) An emergency, as defined in 326 IAC 2-7-1(12), constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limitation if the affirmative defense of an emergency is demonstrated through properly signed, contemporaneous operating logs or other relevant evidence that describe the following:
 - (1) An emergency occurred and the Permittee can, to the extent possible, identify the causes of the emergency;
 - (2) The permitted facility was at the time being properly operated;
 - (3) During the period of an emergency, the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards or other requirements in this permit;
 - (4) For each emergency lasting one (1) hour or more, the Permittee notified IDEM, OAQ, within four (4) daytime business hours after the beginning of the emergency, or after the emergency was discovered or reasonably should have been discovered;

Telephone Number: 1-800-451-6027 (ask for Office of Air Quality, Compliance Section), or
Telephone Number: 317-233-0178 (ask for Compliance Section)
Facsimile Number: 317-233-6885.

- (5) For each emergency lasting one (1) hour or more, the Permittee submitted the attached Emergency Occurrence Report Form or its equivalent, either by mail or facsimile to:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

within two (2) working days of the time when emission limitations were exceeded due to the emergency.

The notice fulfills the requirement of 326 IAC 2-7-5(3)(C)(ii) and must contain the following:

- (A) A description of the emergency;
- (B) Any steps taken to mitigate the emissions; and
- (C) Corrective actions taken.

The notification which shall be submitted by the Permittee does not require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

- (6) The Permittee immediately took all reasonable steps to correct the emergency.
- (c) In any enforcement proceeding, the Permittee seeking to establish the occurrence of an emergency has the burden of proof.
 - (d) This emergency provision supersedes 326 IAC 1-6 (Malfunctions). This permit condition is in addition to any emergency or upset provision contained in any applicable requirement.
 - (e) The Permittee seeking to establish the occurrence of an emergency shall make records available upon request to ensure that failure to implement a PMP did not cause or contribute to an exceedance of any limitations on emissions. However, IDEM, OAQ, may require that the Preventive Maintenance Plans required under 326 IAC 2-7-4-(c)(9) be revised in response to an emergency.
 - (f) Failure to notify IDEM, OAQ, by telephone or facsimile of an emergency lasting more than one (1) hour in accordance with (b)(4) and (5) of this condition shall constitute a violation of 326 IAC 2-7 and any other applicable rules.
 - (g) If the emergency situation causes a deviation from a technology-based limit, the Permittee may continue to operate the affected emitting facilities during the emergency provided the Permittee immediately takes all reasonable steps to correct the emergency and minimize emissions.
 - (h) The Permittee shall include all emergencies in the Quarterly Deviation and Compliance Monitoring Report.

B.12 Permit Shield [326 IAC 2-7-15] [326 IAC 2-7-20] [326 IAC 2-7-12]

- (a) Pursuant to 326 IAC 2-7-15, the Permittee has been granted a permit shield. The permit shield provides that compliance with the conditions of this permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that either the applicable requirements are included and specifically identified in this permit or the permit contains an explicit determination or concise summary of a determination that other specifically identified requirements are not applicable. The Indiana statutes from IC 13 and rules from 326 IAC, referenced in conditions in this permit, are those applicable at the time the permit was issued. The issuance or possession of this permit shall not alone constitute a defense against an alleged violation of any law, regulation or standard, except for the requirement to obtain a Part 70 permit under 326 IAC 2-7 or for applicable requirements for which a permit shield has been granted.

This permit shield does not extend to applicable requirements which are promulgated after the date of issuance of this permit unless this permit has been modified to reflect such new requirements.

- (b) If, after issuance of this permit, it is determined that the permit is in nonconformance with an applicable requirement that applied to the source on the date of permit issuance, IDEM, OAQ, shall immediately take steps to reopen and revise this permit and issue a compliance order to the Permittee to ensure expeditious compliance with the applicable requirement until the permit is reissued. The permit shield shall continue in effect so long as the Permittee is in compliance with the compliance order.
- (c) No permit shield shall apply to any permit term or condition that is determined after issuance of this permit to have been based on erroneous information supplied in the permit application. Erroneous information means information that the Permittee knew to be false, or in the exercise of reasonable care should have been known to be false, at the time the information was submitted.
- (d) Nothing in 326 IAC 2-7-15 or in this permit shall alter or affect the following:
- (1) The provisions of Section 303 of the Clean Air Act (emergency orders), including the authority of the U.S. EPA under Section 303 of the Clean Air Act;
 - (2) The liability of the Permittee for any violation of applicable requirements prior to or at the time of this permit's issuance;
 - (3) The applicable requirements of the acid rain program, consistent with Section 408(a) of the Clean Air Act; and
 - (4) The ability of U.S. EPA to obtain information from the Permittee under Section 114 of the Clean Air Act.
- (e) This permit shield is not applicable to any change made under 326 IAC 2-7-20(b)(2) (Sections 502(b)(10) of the Clean Air Act changes) and 326 IAC 2-7-20(c)(2) (trading based on State Implementation Plan (SIP) provisions).
- (f) This permit shield is not applicable to modifications eligible for group processing until after IDEM, OAQ, has issued the modifications. [326 IAC 2-7-12(c)(7)]
- (g) This permit shield is not applicable to minor Part 70 permit modifications until after IDEM, OAQ, has issued the modification. [326 IAC 2-7-12(b)(8)]

B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5][326 IAC 2-7-10.5]

- (a) All terms and conditions of permits established prior to T073-6792-00008 and issued pursuant to permitting programs approved into the state implementation plan have been either
- (1) incorporated as originally stated,
 - (2) revised under 326 IAC 2-7-10.5, or
 - (3) deleted under 326 IAC 2-7-10.5.
- (b) All previous registrations and permits are superseded by this part 70 operating permit, except for permits issued pursuant to Title IV of the Clean Air Act and 326 IAC 21 (Acid Deposition Control).

B.14 Deviations from Permit Requirements and Conditions [326 IAC 2-7-5(3)(C)(ii)]

- (a) Deviations from any permit requirements (for emergencies see Section B - Emergency Provisions), the probable cause of such deviations, and any response steps or preventive measures taken shall be reported to:

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

using the attached Quarterly Deviation and Compliance Monitoring Report, or its equivalent. A deviation required to be reported pursuant to an applicable requirement that exists independent of this permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report.

The Quarterly Deviation and Compliance Monitoring Report does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

- (b) A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit.

B.15 Permit Modification, Reopening, Revocation and Reissuance, or Termination
[326 IAC 2-7-5(6)(C)] [326 IAC 2-7-8(a)] [326 IAC 2-7-9]

- (a) This permit may be modified, reopened, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a Part 70 permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any condition of this permit. [326 IAC 2-7-5(6)(C)] The notification by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).
- (b) This permit shall be reopened and revised under any of the circumstances listed in IC 13-15-7-2 or if IDEM, OAQ, determines any of the following:
- (1) That this permit contains a material mistake.
 - (2) That inaccurate statements were made in establishing the emissions standards or other terms or conditions.
 - (3) That this permit must be revised or revoked to assure compliance with an applicable requirement. [326 IAC 2-7-9(a)(3)]

- (c) Proceedings by IDEM, OAQ, to reopen and revise this permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of this permit for which cause to reopen exists. Such reopening and revision shall be made as expeditiously as practicable. [326 IAC 2-7-9(b)]
- (d) The reopening and revision of this permit, under 326 IAC 2-7-9(a), shall not be initiated before notice of such intent is provided to the Permittee by IDEM, OAQ at least thirty (30) days in advance of the date this permit is to be reopened, except that IDEM, OAQ, may provide a shorter time period in the case of an emergency. [326 IAC 2-7-9(c)]

B.16 Permit Renewal [326 IAC 2-7-3] [326 IAC 2-7-4] [326 IAC 2-7-8(e)]

- (a) The application for renewal shall be submitted using the application form or forms prescribed by IDEM, OAQ, and shall include the information specified in 326 IAC 2-7-4. Such information shall be included in the application for each emission unit at this source, except those emission units included on the trivial or insignificant activities list contained in 326 IAC 2-7-1(21) and 326 IAC 2-7-1(40). The renewal application does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

Request for renewal shall be submitted to:

Indiana Department of Environmental Management
Permits Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

- (b) A timely renewal application is one that is:
 - (1) Submitted at least nine (9) months prior to the date of the expiration of this permit; and
 - (2) If the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.
- (c) If the Permittee submits a timely and complete application for renewal of this permit, the source's failure to have a permit is not a violation of 326 IAC 2-7 until IDEM, OAQ, takes final action on the renewal application, except that this protection shall cease to apply if, subsequent to the completeness determination, the Permittee fails to submit by a reasonable deadline specified in writing by IDEM, OAQ, any additional information identified as being needed to process the application. [326 IAC 2-7-4(a)(2)(D) and (E)]

B.17 Source Modification Requirements [326 IAC 1-2-42][326 IAC 2-7-10.5] [326 IAC 2-2-2] [326 IAC 2-3-2]

- (a) The Permittee shall obtain approval as required by 326 IAC 2-7-10.5 from the IDEM, OAQ prior to making any modification to the source.

- (b) Any application requesting a source modification shall be submitted to:

Indiana Department of Environmental Management
Permits Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN
Indianapolis, Indiana 46204-2251

Any such application shall be certified by the “responsible official” as defined by 326 IAC 2-7-1(34).

- (c) The Permittee shall also comply with the applicable provisions of 326 IAC 2-7-11 (Administrative Permit Amendments) or 326 IAC 2-7-12 (Permit Modification) prior to operating the approved modification.
- (d) Any modification at an existing major source is governed by the requirements of 326 IAC 2-2-2.

B.18 Permit Amendment or Modification [326 IAC 2-7-11] [326 IAC 2-7-12] [40 CFR 72]

- (a) Permit amendments and modifications are governed by the requirements of 326 IAC 2-7-11 or 326 IAC 2-7-12 whenever the Permittee seeks to amend or modify this permit.
- (b) Pursuant to 326 IAC 2-7-11(b) and 326 IAC 2-7-12(a), administrative Part 70 permit amendments and permit modifications for purposes of the acid rain portion of a Part 70 permit shall be governed by regulations promulgated under Title IV of the Clean Air Act. [40 CFR 72]
- (c) Any application requesting an amendment or modification of this permit shall be submitted to:

Indiana Department of Environmental Management
Permits Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

Any such application shall be certified by the “responsible official” as defined by 326 IAC 2-7-1(34).

- (d) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-7-11(c)(3)]

B.19 Permit Revision Under Economic Incentives and Other Programs [326 IAC 2-7-5(8)] [326 IAC 2-7-12 (b)(2)]

- (a) No Part 70 permit revision shall be required under any approved economic incentives, marketable Part 70 permits, emissions trading, and other similar programs or processes for changes that are provided for in a Part 70 permit.
- (b) Notwithstanding 326 IAC 2-7-12(b)(1) and 326 IAC 2-7-12(c)(1), minor Part 70 permit modification procedures may be used for Part 70 modifications involving the use of economic incentives, marketable Part 70 permits, emissions trading, and other similar approaches to the extent that such minor Part 70 permit modification procedures are explicitly provided for in the applicable State Implementation Plan (SIP) or in applicable requirements promulgated or approved by the U.S. EPA..

B.20 Operational Flexibility [326 IAC 2-7-20] [326 IAC 2-7-10.5]

- (a) The Permittee may make any change or changes at the source that are described in 326 IAC 2-7-20(b), (c), or (e), without a prior permit revision, if each of the following conditions is met:
 - (1) The changes are not modifications under any provision of Title I of the Clean Air Act;

- (2) Any preconstruction approval required by 326 IAC 2-7-10.5 has been obtained;
- (3) The changes do not result in emissions which exceed the limitations provided in this permit (whether expressed herein as a rate of emissions or in terms of total emissions);
- (4) The Permittee notifies the:

Indiana Department of Environmental Management
Permits Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V
Air and Radiation Division, Regulation Development Branch - Indiana (AR-18J)
77 West Jackson Boulevard
Chicago, Illinois 60604-3590

in advance of the change by written notification at least ten (10) days in advance of the proposed change. The Permittee shall attach every such notice to the Permittee's copy of this permit; and

- (5) The Permittee maintains records on-site, on a rolling five (5) year basis, which document all such changes and emission trades that are subject to 326 IAC 2-7-20(b), (c), or (e). The Permittee shall make such records available, upon reasonable request, for public review.

Such records shall consist of all information required to be submitted to IDEM, OAQ, in the notices specified in 326 IAC 2-7-20(b)(1), (c)(1), and (e)(2).

- (b) The Permittee may make Section 502(b)(10) of the Clean Air Act changes (this term is defined at 326 IAC 2-7-1(36)) without a permit revision, subject to the constraint of 326 IAC 2-7-20(a). For each such Section 502(b)(10) of the Clean Air Act change, the required written notification shall include the following:

- (1) A brief description of the change within the source;
- (2) The date on which the change will occur;
- (3) Any change in emissions; and
- (4) Any permit term or condition that is no longer applicable as a result of the change.

The notification which shall be submitted is not considered an application form, report or compliance certification. Therefore, the notification by the Permittee does not require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

- (c) Emission Trades [326 IAC 2-7-20(c)]
The Permittee may trade emissions increases and decreases at the source, where the applicable SIP provides for such emission trades without requiring a permit revision, subject to the constraints of Section (a) of this condition and those in 326 IAC 2-7-20(c).

- (d) Alternative Operating Scenarios [326 IAC 2-7-20(d)]
The Permittee may make changes at the source within the range of alternative operating scenarios that are described in the terms and conditions of this permit in accordance with 326 IAC 2-7-5(9). No prior notification of IDEM, OAQ, or U.S. EPA is required.
 - (e) Backup fuel switches specifically addressed in, and limited under, Section D of this permit shall not be considered alternative operating scenarios. Therefore, the notification requirements of part (a) of this condition do not apply.
-
- (f) This condition does not apply to emission trades of SO₂ or NO_x under 326 IAC 21 or 326 IAC 10-4.

B.21 Inspection and Entry [326 IAC 2-7-6] [IC 13-14-2-2] [IC 13-17-3-2] [IC 13-30-3-1]

Upon presentation of proper identification cards, credentials, and other documents as may be required by law, and subject to the Permittee's right under all applicable laws and regulations to assert that the information collected by the agency is confidential and entitled to be treated as such, the Permittee shall allow IDEM, OAQ, U.S. EPA, or an authorized representative to perform the following:

- (a) Enter upon the Permittee's premises where a Part 70 source is located, or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
- (b) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, have access to and copy any records that must be kept under the conditions of this permit;
- (c) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, inspect any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit;
- (d) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, sample or monitor substances or parameters for the purpose of assuring compliance with this permit or applicable requirements; and
- (e) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, utilize any photographic, recording, testing, monitoring, or other equipment for the purpose of assuring compliance with this permit or applicable requirements.

B.22 Transfer of Ownership or Operational Control [326 IAC 2-7-11]

- (a) The Permittee must comply with the requirements of 326 IAC 2-7-11 whenever the Permittee seeks to change the ownership or operational control of the source and no other change in the permit is necessary.
- (b) Any application requesting a change in the ownership or operational control of the source shall contain a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new Permittee. The application shall be submitted to:

Indiana Department of Environmental Management
Permits Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

The application which shall be submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-7-11(c)(3)]

B.23 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-7-5(7)] [326 IAC 2-1.1-7]

- (a) The Permittee shall pay annual fees to IDEM, OAQ, within thirty (30) calendar days of receipt of a billing. Pursuant to 326 IAC 2-7-19(b), if the Permittee does not receive a bill from IDEM, OAQ the applicable fee is due April 1 of each year.
- (b) Except as provided in 326 IAC 2-7-19(e), failure to pay may result in administrative enforcement action or revocation of this permit.
- (c) The Permittee may call the following telephone numbers: 1-800-451-6027 or 317-233-4230 (ask for Billing, Licensing, and Training Section), to determine the appropriate permit fee.

B.24 Credible Evidence [326 IAC 2-7-5(3)][326 IAC 2-7-6][62 FR 8314][326 IAC 1-1-6]

For the purpose of submitting compliance certifications or establishing whether or not the Permittee has violated or is in violation of any condition of this permit, nothing in this permit shall preclude the use, including the exclusive use, of any credible evidence or information relevant to whether the Permittee would have been in compliance with the condition of this permit if the appropriate performance or compliance test or procedure had been performed.

B.25 Term of Conditions [326 IAC 2-1.1-9.5]

Notwithstanding the permit term of a permit to construct, a permit to operate, or a permit modification, any condition established in a permit issued pursuant to a permitting program approved in the state implementation plan shall remain in effect until:

- (a) The condition is modified in a subsequent permit action pursuant to Title I of the Clean Air Act; or
- (b) The emission unit to which the condition pertains permanently ceases operation.

SECTION C

SOURCE OPERATION CONDITIONS

Entire Source

Emission Limitations and Standards [326 IAC 2-7-5(1)]

- C.1 Particulate Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]
-
- Pursuant to 326 IAC 6-3-2(e)(2), particulate emissions from any process not exempt under 326 IAC 6-3-1(b) or (c) which has a maximum process weight rate less than 100 pounds per hour and the methods in 326 IAC 6-3-2(b) through (d) do not apply shall not exceed 0.551 pounds per hour.
- C.2 Opacity [326 IAC 5-1]
-
- Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations) and except for Units 17 and 18 and Units 17 and 18 coal processing and conveying equipment, opacity shall meet the following, unless otherwise stated in this permit:
- (a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
 - (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.
- C.3 Open Burning [326 IAC 4-1] [IC 13-17-9]
-
- The Permittee shall not open burn any material except as provided in 326 IAC 4-1-3, 326 IAC 4-1-4 or 326 IAC 4-1-6. The previous sentence notwithstanding, the Permittee may open burn in accordance with an open burning approval issued by the Commissioner under 326 IAC 4-1-4.1. 326 IAC 4-1-3 (a)(2)(A) and (B) are not federally enforceable.
- C.4 Incineration [326 IAC 4-2] [326 IAC 9-1-2]
-
- The Permittee shall not operate an incinerator or incinerate any waste or refuse except as provided in 326 IAC 4-2 and 326 IAC 9-1-2.
- C.5 Fugitive Dust Emissions [326 IAC 6-4]
-
- The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions). 326 IAC 6-4-2(4) is not federally enforceable.
- C.6 Motor Vehicle Fugitive Dust Sources [326 IAC 6-4-4]
-
- Pursuant to 326 IAC 6-4-4, no vehicle, shall be driven or moved on any public street, road, alley, highway, or other thoroughfare, unless such vehicle is so constructed as to prevent its contents from dripping, sifting, leaking, or otherwise escaping therefrom so as to create conditions which result in fugitive dust. This section applies only to the cargo any vehicle may be conveying and mud tracked by the vehicle.
- C.7 Stack Height [326 IAC 1-7]
-
- The Permittee shall comply with the applicable provisions of 326 IAC 1-7 (Stack Height Provisions), for all exhaust stacks through which a potential (before controls) of twenty-five (25) tons per year or more of particulate matter or sulfur dioxide is emitted. The provisions of 326 IAC 1-7-1(3), 326 IAC 1-7-2, 326 IAC 1-7-3(c) and (d), 326 IAC 1-7-4, and 326 IAC 1-7-5(a), (b), and (d) are not federally enforceable.

C.8 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

The Permittee shall comply with the applicable requirements of 326 IAC 14-10, 326 IAC 18, and 40 CFR 61.140.

Testing Requirements [326 IAC 2-7-6(1)]

C.9 Performance Testing [326 IAC 3-6]

- (a) All required testing shall be performed according to the provisions of 326 IAC 3-6 (Source Sampling Procedures), except as provided elsewhere in this permit, utilizing any applicable procedures and analysis methods specified in 40 CFR 51, 40 CFR 60, 40 CFR 61, 40 CFR 63, 40 CFR 75, or other procedures approved by IDEM, OAQ.

A test protocol, except as provided elsewhere in this permit, shall be submitted to:

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

no later than thirty-five (35) days prior to the intended test date. The protocol submitted by the Permittee does not require certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

- (b) The Permittee shall notify IDEM, OAQ of the actual test date at least fourteen (14) days prior to the actual test date. The notification submitted by the Permittee does not require certification by the "responsible official" as defined by 326 IAC 2-7-1(34).
- (c) Pursuant to 326 IAC 3-6-4(b), all test reports must be received by IDEM, OAQ not later than forty-five (45) days after the completion of the testing. An extension may be granted by IDEM, OAQ, if the Permittee submits to IDEM, OAQ, a reasonable written explanation not later than five (5) days prior to the end of the initial forty-five (45) day period.

Compliance Requirements [326 IAC 2-1.1-11]

C.10 Compliance Requirements [326 IAC 2-1.1-11]

The commissioner may require stack testing, monitoring, or reporting at any time to assure compliance with all applicable requirements by issuing an order under 326 IAC 2-1.1-11. Any monitoring or testing shall be performed in accordance with 326 IAC 3 or other methods approved by the commissioner or the U. S. EPA.

Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]

C.11 Compliance Monitoring [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

Unless otherwise specified in this permit, all monitoring and record keeping requirements not already legally required shall be implemented within ninety (90) days of permit issuance. If required by Section D, the Permittee shall be responsible for installing any necessary equipment and initiating any required monitoring related to that equipment. If due to circumstances beyond its control, that equipment cannot be installed and operated within ninety (90) days, the Permittee may extend the compliance schedule related to the equipment for an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

in writing, prior to the end of the initial ninety (90) day compliance schedule, with full justification of the reasons for the inability to meet this date.

The notification which shall be submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

Unless otherwise specified in the approval for the new emission unit(s), compliance monitoring for new emission units or emission units added through a source modification shall be implemented when operation begins.

C.12 Maintenance of Continuous Opacity Monitoring Equipment [326 IAC 2-7-5(3)(A)(iii)]

- (a) The Permittee shall calibrate, maintain, and operate all necessary continuous opacity monitoring systems (COMS) and related equipment. For a boiler, the COMS shall be in operation at all times that the induced draft fan is in operation.
- (b) All COMS shall meet the performance specifications of 40 CFR 60, Appendix B, Performance Specification No. 1, and are subject to monitor system certification requirements pursuant to 326 IAC 3-5.
- (c) In the event that a breakdown of a COMS occurs, a record shall be made of the time and reason of the breakdown and efforts made to correct the problem.
- (d) Whenever a COMS is malfunctioning or is down for maintenance or repairs for a period of twenty-four (24) hours or more and a backup COMS is not online within twenty-four (24) hours of shutdown or malfunction of the primary COMS, the Permittee shall provide a certified opacity reader, who may be an employee of the Permittee or an independent contractor, to self-monitor the emissions from the emission unit stack when plume conditions allow.
 - (1) When plume conditions allow, visible emission readings shall be performed in accordance with 40 CFR 60, Appendix A, Method 9, for a minimum of five (5) consecutive six (6) minute averaging periods beginning not more than twenty-four (24) hours after the start of the malfunction or down time.
 - (2) When plume conditions allow method 9 opacity readings shall be repeated for a minimum of five (5) consecutive six (6) minute averaging periods at least twice per day during daylight operations with at least four (4) hours between each set of readings, until such time that a COMS is online.
 - (3) Method 9 readings may be discontinued once a COMS is online.
 - (4) Any opacity exceedances determined by Method 9 readings shall be reported with the Quarterly Opacity Exceedances Reports.
 - (5) When plume conditions do not allow Method 9 visible emission readings, Permittee shall keep a record of the period during which such readings could not be taken and the reason why such readings could not be taken.
- (e) Nothing in this permit shall excuse the Permittee from complying with the requirements to operate a continuous opacity monitoring system pursuant to 326 IAC 3-5 and 40 CFR 60.

C.13 Monitoring Methods [326 IAC 3] [40 CFR 60] [40 CFR 63]

Any monitoring or testing required by Section D of this permit shall be performed according to the provisions of 326 IAC 3, 40 CFR 60 Appendix A, 40 CFR 60 Appendix B, 40 CFR 63, or other approved methods as specified in this permit.

C.14 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-7-5(3)][326 IAC 2-7-6(1)]

- (a) When required by any condition of this permit, an analog instrument used to measure a parameter related to the operation of an air pollution control device shall have a scale such that the expected maximum reading for the normal range shall be no less than twenty percent (20%) of full scale.
- (b) The Permittee may request that the IDEM, OAQ approve the use of an instrument that does not meet the above specifications provided the Permittee can demonstrate that an alternative instrument specification will adequately ensure compliance with permit conditions requiring the measurement of the parameters.

Corrective Actions and Response Steps [326 IAC 2-7-5] [326 IAC 2-7-6]

C.15 Emergency Reduction Plans [326 IAC 1-5-2] [326 IAC 1-5-3]

Pursuant to 326 IAC 1-5-2 (Emergency Reduction Plans; Submission):

- (a) The Permittee prepared and submitted written emergency reduction plans (ERPs) consistent with safe operating procedures on December 28, 1979.
- (b) Upon direct notification by IDEM, OAQ, that a specific air pollution episode level is in effect, the Permittee shall immediately put into effect the actions stipulated in the approved ERP for the appropriate episode level. [326 IAC 1-5-3]

C.16 Risk Management Plan [326 IAC 2-7-5(12)] [40 CFR 68]

If a regulated substance as defined in 40 CFR 68, is present at a source in more than a threshold quantity, the Permittee must comply with the applicable requirements at 40 CFR 68.

C.17 Response to Excursions or Exceedances [326 IAC 2-7-5] [326 IAC 2-7-6]

- (a) Upon detecting an excursion or exceedance, the Permittee shall restore operation of the emissions unit(s) (including any control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing emissions.
- (b) The response shall include minimizing the period of any startup, shutdown or malfunction and taking any necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of an excursion or exceedance (other than those caused by excused startup or shutdown conditions). Corrective actions may include, but are not limited to, the following:
 - (1) initial inspection and evaluation;
 - (2) recording that operations returned to normal without operator action (such as through response by a computerized distribution control system); or
 - (3) any necessary follow-up actions to return operation to within the indicator range, designated condition, or below the applicable emission limitation or standard, as applicable.
- (c) A determination of whether the Permittee has used acceptable procedures in response to an excursion or exceedance will be based on information available, which may include, but is not limited to, the following:
 - (1) monitoring results;
 - (2) review of operation and maintenance procedures and records; and
 - (3) inspection of the control device, associated capture system, and the process.

- (d) Failure to take reasonable response steps shall be considered a deviation from the permit.
- (e) The Permittee shall maintain the following records:
 - (1) monitoring data;
 - (2) monitor performance data, if applicable; and
 - (3) corrective actions taken.

C.18 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5][326 IAC 2-7-6]

- (a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this permit exceed the level specified in any condition of this permit, the Permittee shall take appropriate response actions. The Permittee shall submit a description of these response actions to IDEM, OAQ, within thirty (30) days of receipt of the test results. The Permittee shall take appropriate action to minimize excess emissions from the affected facility, for the pollutant for which the test was performed, while the response actions are being implemented.
- (b) A retest to demonstrate compliance shall be performed within one hundred twenty (120) days of receipt of the original test results. Should the Permittee demonstrate to IDEM, OAQ that retesting in one hundred twenty (120) days is not practicable, IDEM, OAQ may extend the retesting deadline.
- (c) IDEM, OAQ reserves the authority to take any actions allowed under law in response to noncompliant stack tests.

The response action documents submitted pursuant to this condition do require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

C.19 Emission Statement [326 IAC 2-7-5(3)(C)(iii)][326 IAC 2-7-5(7)][326 IAC 2-7-19(c)][326 IAC 2-6]

- (a) Pursuant to 326 IAC 2-6-3(a)(1), the Permittee shall submit by July 1 of each year an emission statement covering the previous calendar year. The emission statement shall contain, at a minimum, the information specified in 326 IAC 2-6-4(c) and shall meet the following requirements:
 - (1) Indicate estimated actual emissions of all pollutants listed in 326 IAC 2-6-4(a);
 - (2) Indicate estimated actual emissions of regulated pollutants as defined by 326 IAC 2-7-1(32) ("Regulated pollutant which is used only for purposes of Section 19 of this rule") from the source, for purposes of fee assessment.

The statement must be submitted to:

Indiana Department of Environmental Management
Technical Support and Modeling Section, Office of Air Quality
100 North Senate Avenue
MC 61-50 IGCN 1003
Indianapolis, Indiana 46204-2251

The emission statement does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

- (b) The emission statement required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.

C.20 General Record Keeping Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [326 IAC 2-2]
[326 IAC 2-3]

- (a) Records of all required monitoring data, reports and support information required by this permit shall be retained for a period of at least five (5) years from the date of monitoring sample, measurement, report, or application. These records shall be physically present or electronically accessible at the source location for a minimum of three (3) years. The records may be stored elsewhere for the remaining two (2) years as long as they are available upon request. If the Commissioner makes a request for records to the Permittee, the Permittee shall furnish the records to the Commissioner within a reasonable time.
- (b) Unless otherwise specified in this permit, all record keeping requirements not already legally required shall be implemented within ninety (90) days of permit issuance.
- (c) If there is a reasonable possibility that a "project" (as defined in 326 IAC 2-2-1 (qq) and/or 326 IAC 2-3-1 (ll)) at an existing emissions unit, other than projects at a Clean Unit (or at a source with Plant-wide Applicability Limitation (PAL)), which is not part of a "major modification" (as defined in 326 IAC 2-2-1 (ee) and/or 326 IAC 2-3-1 (z)) may result in significant emissions increase and the Permittee elects to utilize the "projected actual emissions" (as defined in 326 IAC 2-2-1 (rr) and/or 326 IAC 2-3-1 (mm)), the Permittee shall comply with following:
 - (1) Before beginning actual construction of the "project" (as defined in 326 IAC 2-2-1 (qq) and/or 326 IAC 2-3-1 (ll)) at an existing emissions unit, document and maintain the following records:
 - (A) A description of the project.
 - (B) Identification of any emissions unit whose emissions of a regulated new source review pollutant could be affected by the project.
 - (C) A description of the applicability test used to determine that the project is not a major modification for any regulated NSR pollutant, including:
 - (i) Baseline actual emissions;
 - (ii) Projected actual emissions;
 - (iii) Amount of emissions excluded under section 326 IAC 2-2-1(rr)(2)(A)(iii) and/or 326 IAC 2-3-1(mm)(2)(A)(iii); and
 - (iv) An explanation for why the amount was excluded, and any netting calculations, if applicable.
 - (2) Monitor the emissions of any regulated NSR pollutant that could increase as a result of the project and that is emitted by any existing emissions unit identified in (1)(B) above; and

- (3) Calculate and maintain a record of the annual emissions, in tons per year on a calendar year basis, for a period of five (5) years following resumption of regular operations after the change, or for a period of ten (10) years following resumption of regular operations after the change if the project increases the design capacity of or the potential to emit that regulated NSR pollutant at the emissions unit.

C.21 General Reporting Requirements [326 IAC 2-7-5(3)(C)] [326 IAC 2-1.1-11] [326 IAC 2-2]
[326 IAC 2-3]

- (a) The Permittee shall submit the attached Quarterly Deviation and Compliance Monitoring Report or its equivalent. Any deviation from permit requirements, the date(s) of each deviation, the cause of the deviation, and the response steps taken must be reported. This report shall be submitted within thirty (30) days of the end of the reporting period. The Quarterly Deviation and Compliance Monitoring Report shall include the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).
- (b) The report required in (a) of this condition and reports required by conditions in Section D of this permit shall be submitted to:

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251
- (c) Unless otherwise specified in this permit, any notice, report, or other submission required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.
- (d) Unless otherwise specified in this permit, all reports required in Section D of this permit shall be submitted within thirty (30) days of the end of the reporting period. All reports do require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).
- (e) The first report shall cover the period commencing on the date of issuance of this permit and ending on the last day of the reporting period. Reporting periods are based on calendar years, unless otherwise specified in this permit. For the purpose of this permit, "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.
- (f) If the Permittee is required to comply with the recordkeeping provisions of (c) in Section C- General Record Keeping Requirements for any "project" (as defined in 326 IAC 2-2-1 (qq) and/or 326 IAC 2-3-1 (ll)) at an existing Electric Utility Steam Generating Unit, then for that project the Permittee shall:
 - (1) Submit to IDEM, OAQ a copy of the information required by (c)(1) in Section C- General Record Keeping Requirements
 - (2) Submit a report to IDEM, OAQ within sixty (60) days after the end of each year during which records are generated in accordance with (c)(2) and (3) in Section C- General Record Keeping Requirements. The report shall contain all information and data describing the annual emissions for the emissions units during the calendar year that preceded the submission of report.

Reports required in this part shall be submitted to:

Indiana Department of Environmental Management
Air Compliance Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

- (g) If the Permittee is required to comply with the recordkeeping provisions of (c) in Section C - General Record Keeping Requirements for any "project" (as defined in 326 IAC 2-2-1 (qq) and/or 326 IAC 2-3-1 (ll)) at an existing emissions unit other than Electric Utility Steam Generating Unit, and the project meets the following criteria, then the Permittee shall submit a report to IDEM, OAQ:
- (1) The annual emissions, in tons per year, from the project identified in (c)(1) in Section C- General Record Keeping Requirements exceed the baseline actual emissions, as documented and maintained under Section C- General Record Keeping Requirements (c)(1)(C)(i), by a significant amount, as defined in 326 IAC 2-2-1 (xx) and/or 326 IAC 2-3-1 (qq), for that regulated NSR pollutant, and
 - (2) The emissions differ from the preconstruction projection as documented and maintained under Section C- General Record Keeping Requirements (c)(1)(C)(ii).
- (h) The report for project at an existing emissions unit other than Electric Utility Steam Generating Unit shall be submitted within sixty (60) days after the end of the year and contain the following:
- (1) The name, address, and telephone number of the major stationary source.
 - (2) The annual emissions calculated in accordance with (c)(2) and (3) in Section C- General Record Keeping Requirements.
 - (3) The emissions calculated under the actual-to-projected actual test stated in 326 IAC 2-2-2(d)(3) and/or 326 IAC 2-3-2(c)(3).
 - (4) Any other information that the Permittee deems fit to include in this report,

Reports required in this part shall be submitted to:

Indiana Department of Environmental Management
Air Compliance Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

- (i) The Permittee shall make the information required to be documented and maintained in accordance with (c) in Section C- General Record Keeping Requirements available for review upon a request for inspection by IDEM, OAQ. The general public may request this information from the IDEM, OAQ under 326 IAC 17.1.

Stratospheric Ozone Protection

C.22 Compliance with 40 CFR 82 and 326 IAC 22-1

Pursuant to 40 CFR 82 (Protection of Stratospheric Ozone), Subpart F, except as provided for motor vehicle air conditioners in Subpart B, the Permittee shall comply with the standards for recycling and emissions reduction:

- (a) Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to 40 CFR 82.156.
- (b) Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to 40 CFR 82.158.
- (c) Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161.
- (d) Pursuant to 40 CFR 82, Subpart E (The Labeling of Products Using Ozone-Depleting Substances), all containers in which a Class I or Class II substance is stored or transported and all products containing a Class I substance shall be labeled as required under 40 CFR Part 82.

Ambient Monitoring Requirements [326 IAC 7-3]

C.23 Ambient Monitoring [326 IAC 7-3]

- (a) The Permittee shall operate continuous ambient sulfur dioxide air quality monitors and a meteorological data acquisition system according to a monitoring plan submitted to the commissioner for approval. The monitoring plan shall include requirements listed in 326 IAC 7-3-2(a)(1), 326 IAC 7-3-2(a)(2) and 326 IAC 7-3-2(a)(3).
- (b) The Permittee and other operators subject to the requirements of this rule, located in the same county, may submit a joint monitoring plan to satisfy the requirements of this rule. [326 IAC 7-3-2(c)]
- (c) The Permittee may petition the commissioner for an administrative waiver of all or some of the requirements of 326 IAC 7-3 if such owner or operator can demonstrate that ambient monitoring is unnecessary to determine continued maintenance of the sulfur dioxide ambient air quality standards in the vicinity of the source. [326 IAC 7-3-2(d)]

SECTION D.1

FACILITY OPERATION CONDITIONS - Coal-Fired Boiler, Unit 14

Facility Description [326 IAC 2-7-5(15)]

- (a) One (1) cyclone coal-fired boiler identified as Unit 14, with construction commenced in 1970 and commercial operation begun in 1976, with a design heat input capacity of 4650 million Btu per hour (MMBtu/hr), combusting No. 2 fuel oil and/or natural gas for ignition and as supplemental fuels, using an electrostatic precipitator (ESP) for control of particulate matter and exhausting to stack 14. Unit 14 has a selective catalytic reduction (SCR) system, and has continuous emissions monitoring systems (CEMS) for monitoring nitrogen oxides (NO_x) and sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system.

Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)]:

- (g) Other activities or categories not previously identified with potential, uncontrolled emissions equal to or less than thresholds require listing only: Pb 0.6 ton per year or 3.29 pounds per day, SO₂ 5 pounds per hour or 25 pounds per day, NO_x 5 pounds per hour or 25 pounds per day, CO 25 pounds per day, PM 5 pounds per hour or 25 pounds per day, VOC 3 pounds per hour or 15 pounds per day:
- (1) Evaporation of Boiler Chemical Cleaning wastes.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

D.1.0 NOV Provisions

U.S. EPA has issued a Notice of Violation to this Permittee for allegedly failing to obtain, and comply with, New Source Review ("NSR"), Prevention of Significant Deterioration, and/or NSR for minor source Permits authorizing construction of physical modifications to units and operation of the modified units, as required by provisions set out in the Clean Air Act and 326 IAC 2. Therefore, the permit shield in Section B - Permit Shield does not shield the Permittee from possible enforcement actions initiated by U.S. EPA, IDEM or citizens involving boiler Unit 14. Compliance with the terms of this permit does not serve as proof of compliance for boiler Unit 14 or the matters addressed in the NOV. Following resolution of this action, IDEM will reopen this permit, if necessary, to incorporate a compliance schedule or any new applicable requirements. The standard language of Section B - Permit Shield does not shield any activity on which the permit is silent.

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.1.1 Particulate Emission Requirements [326 IAC 6-2-1(g)]

Pursuant to 326 IAC 6-2-1(g) and Operation Permit 37-05-91-0102, issued on September 14, 1988, the particulate matter (PM) emissions to the atmosphere from the boiler identified as Unit 14 shall not exceed 0.1 pound per million Btu (lb/MMBtu) of energy input. The Permittee may request a permit revision to change the Unit 14 particulate limit to that required pursuant to 326 IAC 6-2-3, in accordance with 326 IAC 2-7-12, if accompanied by a demonstration that the National Ambient Air Quality Standards (NAAQS) are protected.

D.1.2 Startup, Shutdown, and Other Opacity Limits [326 IAC 5-1-3]

- (a) Pursuant to 326 IAC 5-1-3(e) (Temporary Alternative Opacity Limitations), the following applies:

- (1) When building a new fire in a boiler, opacity may exceed the applicable limitation established in 326 IAC 5-1-2 for a period not to exceed a cumulative total of one (1) hour (ten (10) six (6)-minute averaging periods) during the startup period, or until the flue gas temperature reaches two hundred fifty (250) degrees Fahrenheit at the inlet of the electrostatic precipitator, whichever occurs first, provided, however, that once every three years opacity may exceed the applicable limitation established in 326 IAC 5-1-2 for a period not to exceed a cumulative total of three (3) hours (thirty (30) six (6) minute averaging periods) during the startup period.
 - (2) When shutting down a boiler, opacity may exceed the applicable limitation established in 326 IAC 5-1-2 for a period not to exceed a total of one (1) hour (ten (10) six (6)-minute averaging periods) during the shutdown period.
 - (3) Operation of the electrostatic precipitator is not required during these times.
- (b) When removing ashes from the fuel bed or furnace in a boiler or blowing tubes, opacity may exceed the applicable limit established in 326 IAC 5-1-2. However, opacity shall not exceed sixty percent (60%) for any six (6)-minute averaging period and opacity in excess of the applicable limit shall not continue for more than one (1) six (6)-minute averaging period in any sixty (60) minute period. The averaging periods in excess of forty percent (40%) shall not be permitted for more than three (3) six (6)-minute averaging periods in a twelve (12) hour period. [326 IAC 5-1-3(b)]
 - (c) If a facility cannot meet the opacity limitations of 326 IAC 5-1-3(b), the Permittee may submit a written request to IDEM, OAQ, for a temporary alternative opacity limitation in accordance with 326 IAC 5-1-3(d). The Permittee must demonstrate that the alternative limit is needed and justifiable.

D.1.3 Sulfur Dioxide (SO₂) [326 IAC 7-1.1-2]

- (a) Pursuant to 326 IAC 7.1.1-2(a)(3), sulfur dioxide emissions from Unit 14 shall not exceed 0.5 pounds per million Btu's (lb/MMBtu) when combusting only distillate oil or only distillate oil and natural gas.
- (b) Pursuant to 326 IAC 7-1.1-2(a)(1), sulfur dioxide emissions from Unit 14 shall not exceed six and zero-tenths (6.0) pounds per million Btu for coal combustion.
- (c) Pursuant to 326 IAC 7-1.1-2(b), sulfur dioxide emissions from Unit 14 shall not exceed six and zero-tenths (6.0) pounds per million Btu when combusting coal and oil simultaneously.

D.1.4 Capacity Limitation [326 IAC 6-2-1(g)] [326 IAC 2-7-5]

Pursuant to 326 IAC 6-2-1(g) and Operation Permit 37-05-91-0102, issued on September 14, 1988, unit No. 14 shall not exceed a maximum hourly average of 468 megawatts gross until such time as stack testing indicates compliance with the PM and opacity limitations in Condition D.1.1 and Section C - Opacity at a higher level. The Permittee may request a temporary exemption in accordance with 326 IAC 2-1.1-3(g)(3) for stack testing at a higher capacity.

Compliance Determination Requirements

D.1.5 Testing Requirements [326 IAC 2-7-6(1),(6)] [326 IAC 2-1.1-11]

By December 31 of the second calendar year following the most recent stack test, or within 180 days after issuance of this permit, whichever is later, compliance with the PM limitation in Condition D.1.1 shall be determined by a performance stack test conducted using Method 5 or other methods as approved by the Commissioner. This testing shall be repeated by December 31 of every second calendar year following this valid compliance demonstration. Testing shall be conducted in accordance with Section C - Performance Testing.

For the purpose of this permit, "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.

D.1.6 Operation of Electrostatic Precipitator [326 IAC 2-7-6(6)]

Except as otherwise provided by statute or rule or in this permit, the electrostatic precipitator (ESP) for Unit 14 shall be operated at all times that coal is being combusted in Unit 14.

D.1.7 Continuous Emissions Monitoring [326 IAC 3-5]

- (a) Pursuant to 326 IAC 3-5 (Continuous Monitoring of Emissions), continuous emission monitoring systems for Unit 14 shall be calibrated, maintained, and operated for measuring SO₂, and either CO₂ or O₂, which meet the performance specifications of 326 IAC 3-5-2.
- (b) All continuous emission monitoring systems are subject to monitor system certification requirements pursuant to 326 IAC 3-5-3.
- (c) Pursuant to 326 IAC 3-5-4(a), if revisions are made to the continuous monitoring standard operating procedures (SOP), the Permittee shall submit updates to the department biennially.
- (d) Nothing in this permit shall excuse the Permittee from complying with the requirements to operate a continuous emission monitoring system pursuant to 326 IAC 3-5, 326 IAC 10-4, 40 CFR 60, or 40 CFR 75.

D.1.8 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3] [326 IAC 7-2] [326 IAC 7-1.1-2]

- (a) Pursuant to 326 IAC 7-2-1(c), the Permittee shall demonstrate that the sulfur dioxide emissions do not exceed the SO₂ emission limits in Condition D.1.3 using a thirty (30) day rolling weighted average.
- (b) Continuous emission monitoring data collected and reported pursuant to 326 IAC 3-5 may be used as the means for determining compliance with the emission limitations in 326 IAC 7 and other requirements of 326 IAC 7-2 shall not apply. [326 IAC 7-2-1(g)]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.1.9 Transformer-Rectifier (T-R) Sets [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- (a) The ability of the ESP to control particulate emissions shall be monitored once per day, when the unit is in operation, by measuring and recording the number of T-R sets in service and the primary and secondary voltages and the currents of the T-R sets.
- (b) Reasonable response steps shall be taken in accordance with Section C - Response to Excursions and Exceedances whenever the percentage of T-R sets in service falls below ninety percent (90%). T-R set failure resulting in less than ninety percent (90%) availability is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions and Exceedances shall be considered a deviation from this permit.

D.1.10 Opacity Readings [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- (a) In the event of emissions exceeding thirty percent (30%) average opacity for three (3) consecutive six (6) minute averaging periods, appropriate response steps shall be taken in accordance with Section C - Response to Excursions and Exceedances such that the cause(s) of the excursion are identified and corrected and opacity levels are brought back below thirty percent (30%). Examples of expected response steps include, but are not limited to, boiler loads being reduced and ESP T-R sets being returned to service.

- (b) Opacity readings in excess of thirty percent (30%) but not exceeding the opacity limit for the unit are not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions and Exceedances shall be considered a deviation from this permit.
- (c) The Permittee may request that the IDEM, OAQ approve a different opacity trigger level than the one specified in (a) and (b) of this condition, provided the Permittee can demonstrate, through stack testing or other appropriate means, that a different opacity trigger level is appropriate for monitoring compliance with the applicable particulate matter mass emission limits.

D.1.11 SO₂ Monitoring System Downtime [326 IAC 2-7-6] [326 IAC 2-7-5(3)]

- (a) Whenever both the primary and back-up SO₂ continuous emission monitoring systems (CEMS) are malfunctioning or down for repairs or adjustments, the following shall be used to provide information related to SO₂ emissions:
 - (1) If the CEMS is down for less than twenty-four (24) hours, the Permittee shall substitute an average of the quality-assured data from the hour immediately before and the hour immediately after the missing data period for each hour of missing data.
 - (2) If the CEMS is down for twenty-four (24) hours or more:
 - (A) Either fuel sampling and fuel preparation and analysis shall be conducted in accordance with 326 IAC 3-7-2(b) and (c), 326 IAC 3-7-2 (d) and 326 IAC 3-7-2(e) or, alternatively, a portable analyzer, properly calibrated according to the manufacturer specifications (such as manufacturer operating or maintenance manuals), shall be used to monitor SO₂ emissions. To the extent the Permittee elects to conduct fuel sampling: the Permittee shall collect the coal sample as bunkered; coal shall be sampled at least three (3) times per day and at least one (1) time per eight (8) hour period unless no coal is bunkered during the preceding eight (8) hour period; and minimum sample size shall be five hundred (500) grams.

or

 - (B) Pursuant to 326 IAC 3-7-3, other manual and other non-ASTM automatic sampling and analysis procedures may be used upon a demonstration, submitted to the department for approval, that such procedures provide sulfur dioxide emission estimates representative either of estimates based on coal sampling and analysis procedures specified in 326 IAC 3-7-2 or of continuous emissions monitoring.
- (b) To the extent the Permittee elects to conduct fuel sampling to comply with Condition D.1.11(a), pursuant to 326 IAC 3-7-5(a), the Permittee shall develop a standard operating procedure (SOP) to be followed for sampling, handling, analysis, quality control, quality assurance, and data reporting of any information collected pursuant to 326 IAC 3-7-2 through 326 IAC 3-7-4 under this Condition D.1.11. In addition, any revision to the SOP shall be submitted to IDEM, OAQ.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.1.12 Record Keeping Requirements

- (a) To document compliance with Section C - Maintenance of Continuous Opacity Monitoring Equipment, and the particulate matter and opacity requirements in Conditions D.1.1, D.1.2, D.1.5, D.1.9, and D.1.10, the Permittee shall maintain records in accordance with

(1) through (4) below. Records shall be complete and sufficient to establish compliance with the limits in Conditions D.1.1, and D.1.2.

- (1) Data and results from the most recent stack test.
 - (2) All continuous opacity monitoring data, pursuant to 326 IAC 3-5-6.
 - (3) The results of all Method 9 visible emission readings taken during any periods of COMS downtime.
 - (4) All ESP parametric monitoring readings pursuant to D.1.9.
- (b) To document compliance with SO₂ Conditions D.1.3, D.1.8, and D.1.11, the Permittee shall maintain the records identified in (1) through (3) below. Records shall be complete and sufficient to establish compliance with the SO₂ limits as required in Conditions D.1.3 and D.1.8. The Permittee shall maintain records in accordance with (2) and (3) below during SO₂ CEM system downtime.
- (1) All SO₂ continuous emissions monitoring data, pursuant to 326 IAC 3-5-6 and 326 IAC 7-2-1(g).
 - (2) Any fuel sampling and analysis data collected for or portable analyzer data for SO₂ CEM downtime, in accordance with Condition D.1.11.
 - (3) Actual fuel usage during each SO₂ CEM downtime to the extent such data is required by Condition D.1.11 to be obtained.
- (c) To document compliance with Condition D.1.4, the Permittee shall maintain records of the Unit 14 gross output, in gross MW per hour.
- (d) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

D.1.13 Reporting Requirements

- (a) A quarterly report of opacity exceedances and a quarterly summary of the information to document compliance with Conditions D.1.1, D.1.3, D.1.4, and D.1.7 shall be submitted to the address listed in Section C - General Reporting Requirements, of this permit, within thirty (30) days after the end of the quarter being reported. The report submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).
- (b) Pursuant to 326 IAC 3-5-7(5), reporting of continuous monitoring system instrument downtime, except for zero (0) and span checks, which shall be reported separately, shall include the following:
 - (1) Date of downtime.
 - (2) Time of commencement.
 - (3) Duration of each downtime.
 - (4) Reasons for each downtime.
 - (5) Nature of system repairs and adjustments.

The report submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

SECTION D.2 FACILITY OPERATION CONDITIONS - Coal Fired Boiler, Unit 15

Facility Description [326 IAC 2-7-5(15)]

- (b) One (1) dry bottom pulverized coal-fired boiler identified as Unit 15, with construction commenced in 1974 and commercial operation begun in 1979, with a design heat input capacity of 5100 million Btu per hour (MMBtu/hr), with low NO_x burners, combusting No. 2 fuel oil and/or natural gas for ignition and as supplemental fuels, using an electrostatic precipitator (ESP) with a flue gas conditioning (FGC) system for control of particulate matter, and exhausting to stack 15. Unit 15 has continuous emissions monitoring systems (CEMS) for monitoring nitrogen oxides (NO_x) and sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system.

Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)]:

- (g) Other activities or categories not previously identified with potential, uncontrolled emissions equal to or less than thresholds require listing only: Pb 0.6 ton per year or 3.29 pounds per day, SO₂ 5 pounds per hour or 25 pounds per day, NO_x 5 pounds per hour or 25 pounds per day, CO 25 pounds per day, PM 5 pounds per hour or 25 pounds per day, VOC 3 pounds per hour or 15 pounds per day:

- (1) Evaporation of Boiler Chemical Cleaning wastes.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

D.2.0 NOV Provisions

U.S. EPA has issued a Notice of Violation to this Permittee for allegedly failing to obtain, and comply with, New Source Review ("NSR"), Prevention of Significant Deterioration, and/or NSR for minor source Permits authorizing construction of physical modifications to units and operation of the modified units, as required by provisions set out in the Clean Air Act and 326 IAC 2. Therefore, the permit shield in Section B - Permit Shield does not shield the Permittee from possible enforcement actions initiated by U.S. EPA, IDEM or citizens involving boiler Unit 15. Compliance with the terms of this permit does not serve as proof of compliance for boiler Unit 15 or the matters addressed in the NOV. Following resolution of this action, IDEM will reopen this permit, if necessary, to incorporate a compliance schedule or any new applicable requirements. The standard language of Section B - Permit Shield does not shield any activity on which the permit is silent.

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.2.1 New Source Performance Standard (NSPS) [326 IAC 12] [40 CFR 60, Subpart D] [326 IAC 6-2-1(f)]

Pursuant to 326 IAC 12 and 40 CFR 60, Subpart D (Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction is Commenced After August 17, 1971), emissions from Unit 15 shall not exceed the following:

- (a) For particulate matter:
- (1) 0.10 pound PM per million Btu (lb/MMBtu) heat input derived from fossil fuel. [40 CFR 60.42(a)(1)] [326 IAC 6-2-1(f)]
 - (2) Twenty percent (20%) opacity except for one six-minute period per hour of not more than twenty-seven percent (27%) opacity, except during periods of startup, shutdown, or malfunction. [40 CFR 60.11(c), 40 CFR 60.42(a)(2), and 40 CFR 60.45(g)(1)]

- (b) For sulfur dioxide:
- (1) 0.80 pound SO₂ per million Btu (lb/MMBtu) heat input derived from liquid fossil fuel. [40 CFR 60.43(a)(1)]
 - (2) 1.2 pound SO₂ per million Btu (lb/MMBtu) heat input derived from solid fossil fuel. [40 CFR 60.43(a)(2)]
 - (3) When combusting different fossil fuels simultaneously, the applicable SO₂ limit shall be determined using the formula in 40 CFR 60.43(b).
 - (4) Compliance shall be based on the total heat input from all fossil fuels burned, including gaseous fuels. [40 CFR 60.43(c)]
- (c) For nitrogen oxides:
- (1) 0.20 pound NO_x per million Btu (lb/MMBtu) heat input derived from gaseous fossil fuel. [40 CFR 60.44(a)(1)]
 - (2) 0.30 pound NO_x per million Btu (lb/MMBtu) heat input derived from liquid fossil fuel. [40 CFR 60.44(a)(2)]
 - (3) 0.70 pound NO_x per million Btu (lb/MMBtu) heat input derived from solid fossil fuel (except lignite or a solid fossil fuel containing twenty-five percent (25%), by weight, or more of coal refuse). [40 CFR 60.44(a)(3)]
 - (4) When combusting different fossil fuels simultaneously, the applicable NO_x limit shall be determined using the formula in 40 CFR 60.44(b).

D.2.2 Startup, Shutdown, and Other Opacity Limits [326 IAC 5-1-3]

Pursuant to 326 IAC 5-1-3(e) (Temporary Alternative Opacity Limitations), the following applies:

- (a) When building a new fire in a boiler, opacity may exceed the applicable limitation established in 326 IAC 5-1-2 for a period not to exceed a total of two (2) hours (twenty (20) six (6)-minute averaging periods) during the startup period, or until the flue gas temperature reaches two hundred fifty (250) degrees Fahrenheit at the inlet of the electrostatic precipitation, whichever occurs first.
- (b) When shutting down a boiler, opacity may exceed the applicable limitation established in 326 IAC 5-1-2 for a period not to exceed a total of two (2) hours (twenty (20) six (6)-minute averaging periods) during the shutdown period.
- (c) Operation of the electrostatic precipitator is not required during these times.

D.2.3 Sulfur Dioxide (SO₂) [326 IAC 7-1.1-2]

- (a) Pursuant to 326 IAC 7.1.1-2(a)(3), sulfur dioxide emissions from Unit 15 shall not exceed five-tenths (0.5) pound per million Btu's (lb/MMBtu) when combusting only distillate oil or only distillate oil and natural gas.
- (b) Pursuant to 326 IAC 7-1.1-2(a)(1), sulfur dioxide emissions from Unit 15 shall not exceed six and zero-tenths (6.0) pounds per million Btu for coal combustion.
- (c) Pursuant to 326 IAC 7-1.1-2(b), sulfur dioxide emissions from Unit 15 shall not exceed six and zero-tenths (6.0) pounds per million Btu when combusting coal and oil simultaneously.

D.2.4 General Provisions Relating to NSPS [326 IAC 12-1] [40 CFR 60, Subpart A]

The provisions of 40 CFR Part 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the facility described in this section except when otherwise specified in 40 CFR Part 60, Subpart D.

Compliance Determination Requirements

D.2.5 Testing Requirements [326 IAC 2-7-6(1),(6)] [326 IAC 2-1.1-11]

By December 31 of the second calendar year following the most recent stack test, or within 180 days after issuance of this permit, whichever is later, compliance with the PM limitation in Condition D.2.1 shall be determined by a performance stack test conducted using Method 5 or other methods as approved by the Commissioner. This testing shall be repeated by December 31 of every second calendar year following this valid compliance demonstration. Testing shall be conducted in accordance with Section C- Performance Testing.

For the purpose of this permit, "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.

D.2.6 Operation of Electrostatic Precipitator [326 IAC 2-7-6(6)]

Except as otherwise provided by statute or rule or in this permit, the electrostatic precipitator (ESP) shall be operated at all times that the boiler vented to the ESP is in operation.

D.2.7 Continuous Emissions Monitoring [326 IAC 3-5] [326 IAC 12] [40 CFR 60, Subpart D] [326 IAC 2-2]

- (a) Pursuant to 326 IAC 3-5 (Continuous Monitoring of Emissions) and 40 CFR 60.45, continuous emission monitoring systems for Unit 15 shall be calibrated, maintained, and operated for measuring SO₂, NO_x and either O₂ or CO₂, which meet the performance specifications of 326 IAC 3-5-2 and 40 CFR 60.45.
- (b) All continuous emission monitoring systems are subject to monitor system certification requirements pursuant to 326 IAC 3-5-3.
- (c) Pursuant to 40 CFR 60.11(c), the opacity standard in Condition D.2.1(a) and 40 CFR 60.42(a)(2) shall apply at all times except during periods of startup, shutdown, or malfunction. At all times, including periods of startup, shutdown, and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions [40 CFR 60.11(d)].
- (d) Pursuant to 40 CFR 60.13(e), except for system breakdowns, repairs, calibration checks, and zero and span adjustments required under paragraph (d) of 40 CFR 60.13, all continuous monitoring systems shall be in continuous operation and shall meet minimum frequency of operation requirements as follows:
 - (1) All continuous monitoring systems referenced by paragraph (c) of this section for measuring opacity of emissions shall complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period.
 - (2) All continuous monitoring systems referenced by paragraph (c) of this section for measuring emissions, except opacity, shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.

- (e) Excess SO₂ emissions for affected facilities are defined as any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) of sulfur dioxide as measured by a continuous monitoring system exceed the applicable standard under 40 CFR 60.43. [40 CFR 60.45(g)(2)(i)]
- (f) Excess NO_x emissions for affected facilities using a continuous monitoring system for measuring nitrogen oxides are defined as any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) exceed the applicable standards under 40 CFR 60.44. [40 CFR 60.45(g)(3)]
- (g) Pursuant to 326 IAC 3-5-4(a), if revisions are made to the continuous monitoring standard operating procedures (SOP), the Permittee shall submit updates to the department biennially.
- (h) Nothing in this permit shall excuse the Permittee from complying with the requirements to operate a continuous emission monitoring system pursuant to 326 IAC 3-5, 326 IAC 10-4, 40 CFR 60, or 40 CFR 75.

D.2.8 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3] [326 IAC 7-2] [326 IAC 7-1.1-2]

- (a) Pursuant to 326 IAC 7-2-1(a) and (c), the Permittee shall demonstrate that the sulfur dioxide emissions do not exceed the equivalent of five-tenths (0.5) pound per MMBtu when combusting distillate oil or distillate oil and natural gas using a thirty (30) day rolling weighted average.
- (b) Continuous emission monitoring data collected and reported pursuant to 326 IAC 3-5 may be used as the means for determining compliance with the emission limitations in 326 IAC 7 and the other requirements of 326 IAC 7-2 shall not apply. [326 IAC 7-2-1(g)]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.2.9 Transformer-Rectifier (T-R) Sets [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- (a) The ability of the ESP to control particulate emissions shall be monitored once per day, when the unit is in operation, by measuring and recording the number of T-R sets in service and the primary and secondary voltages and the currents of the T-R sets.
- (b) Reasonable response steps shall be taken in accordance with Section C - Response to Excursions and Exceedances whenever a total of more than four (4) T-R sets are not in service. T-R set failure resulting in a response step obligation under the preceding sentence is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions and Exceedances shall be considered a deviation from this permit.

D.2.10 SO₂ Monitoring System Downtime [326 IAC 2-7-6] [326 IAC 2-7-5(3)]

Whenever both the primary and back-up SO₂ continuous emission monitoring systems (CEMS) are malfunctioning or down for repairs or adjustments, the following shall be used to provide information related to SO₂ emissions:

- (a) If the CEMS is down for less than twenty-four (24) hours, the Permittee shall substitute an average of the quality-assured data from the hour immediately before and the hour immediately after the missing data period for each hour of missing data.
- (b) If the CEMS is down for twenty-four (24) hours or more:

- (1) Either fuel sampling and fuel preparation and analysis shall be conducted in accordance with 326 IAC 3-7-2(b) and (c), 326 IAC 3-7-2(d) and 326 IAC 3-7-2(e) or, alternatively, a portable analyzer, properly calibrated according to manufacturer specifications (such as manufacturer operating or maintenance manuals), shall be used to monitor SO₂ emissions. To the extent the Permittee elects to conduct fuel sampling: the Permittee shall collect the coal sample as bunkered; coal shall be sampled at least three (3) times per day and at least one (1) time per eight (8) hour period unless no coal is bunkered during the preceding eight (8) hour period; and minimum sample size shall be five hundred (500) grams

or

- (2) Pursuant to 326 IAC 3-7-3, other manual and other non-ASTM automatic sampling and analysis procedures may be used upon a demonstration, submitted to the department for approval, that such procedures provide sulfur dioxide emission estimates representative either of estimates based on coal sampling and analysis procedures specified in 326 IAC 3-7-2 or of continuous emissions monitoring.
- (c) To the extent the Permittee elects to conduct fuel sampling to comply with Condition D.2.10(a), pursuant to 326 IAC 3-7-5(a), the Permittee shall develop a standard operating procedure (SOP) to be followed for sampling, handling, analysis, quality control, quality assurance, and data reporting of any information collected pursuant to 326 IAC 3-7-2 through 326 IAC 3-7-4 under this Condition D.2.10. In addition, any revision to the SOP shall be submitted to IDEM, OAQ.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.2.11 Record Keeping Requirements

-
- (a) To document compliance with Section C - Maintenance of Continuous Opacity Monitoring Equipment, and the particulate matter and opacity requirements in Conditions D.2.1, D.2.2, D.2.6, D.2.7, and D.2.9, the Permittee shall maintain records in accordance with (1) through (4) below. Records shall be complete and sufficient to establish compliance with the limits in Conditions D.2.1 and D.2.2.
 - (1) Data and results from the most recent stack test.
 - (2) All continuous opacity monitoring data, pursuant to 326 IAC 3-5-6 and 40 CFR 60.42(a)(2).
 - (3) The results of all Method 9 visible emission readings taken during any periods of COMS downtime.
 - (4) All ESP parametric monitoring readings pursuant to condition D.2.9.
 - (b) To document compliance with the SO₂ requirements in Conditions D.2.1, D.2.3, D.2.7, D.2.8, and D.2.10, the Permittee shall maintain the records identified in (1) through (3) below. Records shall be complete and sufficient to establish compliance with the applicable SO₂ limit(s) as required in Conditions D.2.1, D.2.3, D.2.7, and D.2.8. The Permittee shall maintain records in accordance with (2) and (3) below during SO₂ CEM system downtime.
 - (1) All SO₂ continuous emissions monitoring data, pursuant to 326 IAC 3-5-6, 326 IAC 7-2-1(g), and 40 CFR 60.45.

- (2) Any fuel sampling and analysis data collected for or portable analyzer data for SO₂ CEM downtime, in accordance with Condition D.2.10.
- (3) Actual fuel usage during each SO₂ CEM downtime to the extent such data is required by Condition D.2.10 to be obtained.
- (c) To document compliance with the NO_x requirements in Conditions D.2.1 and D.2.7, the Permittee shall maintain records of all NO_x and CO₂ or O₂ continuous emissions monitoring data, pursuant to 326 IAC 3-5-6 and 40 CFR 60.45. Records shall be complete and sufficient to establish compliance with the NO_x limit as required in Condition D.2.1 and D.2.7.
- (d) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

D.2.12 Reporting Requirements

- (a) A quarterly report of opacity exceedances and a quarterly summary of the information to document compliance with Conditions D.2.1, D.2.2, D.2.3, D.2.7, and D.2.8 shall be submitted to the address listed in Section C - General Reporting Requirements, of this permit, within thirty (30) days after the end of the quarter being reported. The report submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).
- (b) Pursuant to 40 CFR 60.45(g), excess emissions and monitoring system performance (MSP) reports shall be submitted to the administrator semi-annually for each six month period in the calendar year. All semiannual reports shall be postmarked by the 30th day following the end of each six-month period. Each excess emission and MSP report shall include the information required in 40 CFR 60.7(c). These reports shall be submitted to:

U.S. Environmental Protection Agency
Director, Air and Radiation Division
77 West Jackson Boulevard
Chicago, IL 60604-3590

and

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

The report submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

- (c) Pursuant to 326 IAC 3-5-7(5), reporting of continuous monitoring system instrument downtime, except for zero (0) and span checks, which shall be reported separately, shall include the following:
 - (1) Date of downtime.
 - (2) Time of commencement.
 - (3) Duration of each downtime.
 - (4) Reasons for each downtime.

(5) Nature of system repairs and adjustments.

The report submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

SECTION D.3 FACILITY OPERATION CONDITIONS - Coal-Fired Boilers, Units 17 and 18

Facility Description [326 IAC 2-7-5(15)]

- (c) One (1) dry bottom pulverized coal-fired boiler identified as Unit 17, with construction started in 1980 and commercial operation begun in 1983, with a design heat input capacity of 3967 million Btu per hour (MMBtu/hr), with low NO_x burners, combusting No. 2 fuel oil and/or natural gas for ignition and as supplemental fuels, using an electrostatic precipitator (ESP) for control of particulate matter, and exhausting through a limestone-based flue gas desulfurization system to stack 17. Unit 17 is equipped with continuous emissions monitoring systems (CEMS) for monitoring nitrogen oxides (NO_x) and sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Unit 17 has been approved to fire blends of coal and petroleum coke.
- (d) One (1) dry bottom pulverized coal-fired boiler identified as Unit 18, with construction started in 1980 and commercial operation begun in 1986, with a design heat input capacity of 3,967 million Btu per hour (MMBtu/hr), with low NO_x burners, combusting No. 2 fuel oil and/or natural gas for ignition and as supplemental fuels, using an electrostatic precipitator (ESP) for control of particulate matter, and exhausting through a limestone-based flue gas desulfurization system to stack 18. Unit 18 has continuous emissions monitoring systems (CEMS) for monitoring nitrogen oxides (NO_x) and sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Unit 18 has been approved to fire blends of coal and petroleum coke.

Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)]:

- (g) Other activities or categories not previously identified with potential, uncontrolled emissions equal to or less than thresholds require listing only: Pb 0.6 ton per year or 3.29 pounds per day, SO₂ 5 pounds per hour or 25 pounds per day, NO_x 5 pounds per hour or 25 pounds per day, CO 25 pounds per day, PM 5 pounds per hour or 25 pounds per day, VOC 3 pounds per hour or 15 pounds per day:
- (1) Evaporation of Boiler Chemical Cleaning wastes.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.3.1 Prevention of Significant Deterioration (PSD) and Construction Permit Limitations [40 CFR 52.21] [326 IAC 2-2][326 IAC 6-2-1(g)][326 IAC 7-1.1-2]

Pursuant to Prevention of Significant Deterioration Approval to Construct EPA-5-A-80-18, issued on April 3, 1980, and the preconstruction approval from the Indiana Air Pollution Control Board, Construction Permit PC (37) 1460, issued April 14, 1980:

- (a) Each boiler unit (Units 17 and 18) shall not be operated in excess of 3,967 MMBtu per hour heat input. (in EPA-5-A-80-18 only)
- (b) Stack gas particulate emissions shall be controlled to 0.03 pound or less of total suspended particulates per million BTU (lb/MMBtu) of heat input to comply with the NSPS.

This requirement will be met by using electrostatic precipitators (ECP) which will provide a 99.8 percent guaranteed control efficiency. (in PC (37) 1460 only)

- (c) The opacity of the exhaust gases shall not exceed twenty percent (20%) based on a six-minute average except for one six-minute period per hour of opacity not exceeding twenty-seven percent (27%). (EPA 5-A-80-18 only)
- (d) Stack gas sulfur dioxide emissions from each unit shall not exceed 0.62 pound per million BTU (lb/MMBTU) of heat input. A 90 percent reduction in potential SO₂ emissions is required, as determined on a continuous basis by using continuous monitors to obtain a 30-day rolling average.
- (e) Nitrogen oxide emissions from each boiler shall not exceed 0.6 pound per million BTU (lb/MMBTU) of heat input.
- (f) The Permittee shall continue to operate the existing meteorological and air quality sampling network for SO₂. [326 IAC 2-2-4(c)(5) and (6)] (in PC (37) 1460 only)

D.3.2 New Source Performance Standard (NSPS) [326 IAC 12] [40 CFR 60, Subpart Da]

Pursuant to 326 IAC 12 and 40 CFR 60, Subpart Da (Standards of Performance for Electric Utility Steam Generating Units for Which Construction is Commenced After September 18, 1978), emissions from Units 17 and 18 shall not exceed the following:

- (a) for particulate matter:
 - (1) 0.03 pound PM per million Btu (lb/MMBtu) heat input when combusting solid, liquid, or gaseous fuel. [40 CFR 60.42a(a)(1)]
 - (2) Ninety-nine percent (99%) reduction in PM emissions when combusting solid fuel. [40 CFR 60.42a(a)(2)]
 - (3) Seventy percent (70%) reduction in PM emissions when combusting liquid fuel. [40 CFR 60.42a(a)(3)]
 - (4) 20 percent (%) opacity (six (6)-minute average), except for one six (6)-minute period per hour of not more than 27 percent (%) opacity. [40 CFR 60.42a(b)]
- (b) For sulfur dioxide:
 - (1) While combusting solid fuel or solid-derived fuel:
 - (A) 1.20 pound SO₂ per million Btu (lb/MMBtu) heat input and 10 percent (%) of the potential combustion concentration (90 percent (%) reduction), or
 - (B) 30 percent (%) of the potential combustion concentration (70 percent (%) reduction), when emissions are less than 0.60 pound SO₂ per million Btu (lb/MMBtu) heat input. [40 CFR 60.43a(a)(1) and (2)].
 - (2) While combusting liquid or gaseous fuels:
 - (A) 0.80 pound SO₂ per million Btu (lb/MMBtu) heat input and 10 percent (%) of the potential combustion concentration (90 percent (%) reduction), or
 - (B) One hundred percent (100%) of the potential combustion concentration (zero (0%) reduction) when emissions are less than 0.20 pound SO₂ per million Btu (0.20 lb/MMBtu) heat input. [40 CFR 60.43a(b)(1) and (2)]
 - (3) When different fuels are combusted simultaneously, the applicable standard is determined using the formula in 40 CFR 60.43a(h).

(c) For nitrogen oxides:

- (1) 0.20 pound NO_x per million Btu (lb/MMBtu) heat input and 25 percent (%) reduction while combusting gaseous fuels. [40 CFR 60.44a(a)(1) and (2)]
- (2) 0.30 pound NO_x per million Btu (lb/MMBtu) heat input and thirty percent (30%) reduction while combusting liquid fuels. [40 CFR 60.44a(a)(1) and (2)]
- (3) 0.50 pound NO_x per million Btu (lb/MMBtu) heat input and 65 percent (%) reduction while combusting subbituminous coal. [40 CFR 60.44a(a)(1) and (2)]
- (4) 0.60 pound NO_x per million Btu (lb/MMBtu) heat input and 65 percent (%) reduction while combusting bituminous coal. [40 CFR 60.44a(a)(1) and (2)]
- (5) 0.60 pound NO_x per million Btu (lb/MMBtu) heat input and 65 percent (%) reduction while combusting all other solid fuels. [40 CFR 60.44a(a)(1) and (2)]
- (6) When combusting two or more fuels simultaneously, the applicable standard is determined by proration using the formula in 40 CFR 60.44a(c).

D.3.3 Alternative Fuel Blends [326 IAC 2-2]

- (a) Pursuant to a letter from IDEM, OAQ, to NIPSCO dated June 13, 1996, based on the results of emissions testing performed in 1995 and subsequent ambient air modeling studies, petroleum coke may be combusted in Units 17 and 18 at a blend rate of no more than 30 percent (30%) petroleum coke (by weight). The conditions of the Units 17 and 18 federal PSD construction permit are not affected by this ruling, and all requirements contained therein still apply.
- (b) The flue gas desulfurization (FGD) system shall be in operation at all times when pet coke is being fired. Should an emergency condition occur which causes a malfunction of the FGD system, the Permittee shall cease bunkering pet coke until the FGD system is fully operational.

D.3.4 General Provisions Relating to NSPS [326 IAC 12-1] [40 CFR Part 60, Subpart A]

The provisions of 40 CFR Part 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the facilities described in this section except when otherwise specified in 40 CFR Part 60, Subpart Da.

Compliance Determination Requirements

D.3.5 Testing Requirements [326 IAC 2-7-6(1),(6)] [326 IAC 2-1.1-11]

By December 31 of the second calendar year following the most recent stack test, or within 180 days after issuance of this permit, whichever is later, compliance with the PM limitation in Condition D.3.1 shall be determined by a performance stack test conducted using Method 5B or 17, or other methods as approved by the Commissioner. This testing shall be repeated by December 31 of every second calendar year following this valid compliance demonstration. Testing shall be conducted in accordance with Section C- Performance Testing.

For the purpose of this permit, "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.

D.3.6 Operation of Electrostatic Precipitator [326 IAC 2-7-6(6)]

Except as otherwise provided by statute or rule or in this permit, the electrostatic precipitator (ESP) shall be operated at all times that the corresponding boiler is in operation.

D.3.7 Scrubber Operation [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

Except as otherwise provided by statute or rule or in this permit, the flue gas desulfurization (FGD) system shall be operated as needed to maintain compliance with all applicable SO₂ emission limits.

D.3.8 NSPS Compliance Provisions [326 IAC 12] [40 CFR 60, Subpart Da]

- (a) Compliance with the pound per million Btu (lb/MMBtu) PM emission limitation in Condition D.3.2 constitutes compliance with the percent reduction requirements for PM in Condition D.3.2. [40 CFR 60.46a(a)]
- (b) Compliance with the pound per million Btu (lb/MMBtu) NO_x emission limitations in Condition D.3.2 constitutes compliance with the percent reduction requirements for NO_x in Condition D.3.2. [40 CFR 60.46a(b)]
- (c) The PM and opacity emission limitations in Condition D.3.2(a) and the NO_x emission limitations in Condition D.3.2(c) apply at all times except during periods of startup, shutdown, or malfunction. [40 CFR 60.46a(c)]
- (d) The SO₂ emission limitations in Condition D.3.2 apply at all times except during periods of startup, shutdown, or when emergency conditions exist and the procedures under 40 CFR 40.46a(d) are implemented. [40 CFR 60.46a(c)]
- (e) Pursuant to 40 CFR 60.46a(d), during emergency conditions in the principal company, an affected facility with a malfunctioning flue gas desulfurization (FGD) system may be operated if sulfur dioxide emissions are minimized by:
 - (1) Operating all operable FGD system modules, and bringing back into operation any malfunctioned module as soon as repairs are completed,
 - (2) Bypassing flue gases around only those FGD system modules that have been taken out of operation because they were incapable of any sulfur dioxide emission reduction or which would have suffered significant physical damage if they had remained in operation, and
 - (3) Designing, constructing, and operating a spare FGD system module. The Administrator may at his discretion require the owner or operator within 60 days of notification to demonstrate spare module capability.
- (f) Compliance with the SO₂ emission limitations and SO₂ percent reduction requirements under 40 CFR 60.43a and the NO_x emission limitations under 40 CFR 60.44a (shown in Condition D.3.2) shall be based on the average emission rate for 30 successive boiler operating days. A separate performance test is completed at the end of each boiler operating day after the initial performance test, and a new 30 day average emission rate for both SO₂ and NO_x and a new percent reduction for sulfur dioxide are calculated to show compliance. [40 CFR 60.46a(e)]
- (g) Compliance is determined by calculating the arithmetic average of all hourly emission rates for SO₂ and NO_x for the 30 successive boiler operating days, except for data obtained during startup, shutdown, or malfunction for NO_x, and data obtained during startup, shutdown, or emergency conditions for SO₂. Compliance with the percentage reduction requirements for SO₂ is determined based on the average inlet and average outlet SO₂ emission rates for the 30 successive boiler operating days. [40 CFR 60.46a(g)]
- (h) If an owner or operator has not obtained the minimum quantity of emission data as required under 40 CFR 60.47a, compliance of the affect facility with the emission requirements under 40 CFR 60.43a and 40 CFR 60.44a for the day on which the 30-day period ends may be determined by the Administrator by following the applicable procedures in section 7 of Method 19. [40 CFR 60.46a(h)]

D.3.9 Continuous Emissions Monitoring [326 IAC 3-5] [326 IAC 12] [40 CFR 60, Subpart Da]
[326 IAC 2-2] [326 IAC 7-2-1(g)]

- (a) Pursuant to 326 IAC 3-5 (Continuous Monitoring of Emissions), 40 CFR 60 Subpart Da, Indiana Air Pollution Control Board Construction Permit PC (37) 1460, issued April 14, 1980, and 326 IAC 2-2, continuous emission monitoring systems for Units 17 and 18 shall be calibrated, maintained, and operated for measuring opacity, SO₂, NO_x, and either CO₂ or O₂, which meet all applicable performance specifications of 326 IAC 3-5-2 and 40 CFR 60.49a.
- (b) All continuous emission monitoring systems are subject to monitor system certification requirements pursuant to 326 IAC 3-5-3.
- (c) If the owner or operator has installed a nitrogen oxides (NO_x) emission rate continuous monitoring system (CEMS) to meet the requirements of 40 CFR 75 and is continuing to meet the ongoing requirements of 40 CFR 75, that CEMS may be used to meet the requirements of 40 CFR 60.49a, except that the owner or operator shall also meet the requirements of 40 CFR 60.51a. Data reported to meet the requirements of 40 CFR 60.51a shall not include data substituted using the missing data procedures in subpart D of 40 CFR 75, nor shall the data have been bias adjusted according to the procedures of 40 CFR 75. [40 CFR 60.49a(c)(2)]
- (d) The continuous monitoring systems under 40 CFR 60.49a(b), (c), and (d) (SO₂, NO_x, and O₂ or CO₂) are operated and data recorded during all periods of operation of the affected facility including periods of startup, shutdown, malfunction or emergency conditions, except for continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments. [40 CFR 60.49a(e)]
- (e) The owner or operator shall obtain emission data for at least 18 hours in at least 22 out of 30 successive boiler operating days. If this minimum data requirement cannot be met with a continuous monitoring system, the owner or operator shall supplement emission data with other monitoring systems approved by the Administrator or the reference methods and procedures as described in 40 CFR 60.49a(h). [40 CFR 60.49a(f)]
- (f) Pursuant to 326 IAC 3-5-4(a), if revisions are made to the continuous monitoring standard operating procedures (SOP), the Permittee shall submit updates to the department biennially.
- (g) Nothing in this permit shall excuse the Permittee from complying with the requirements to operate a continuous emission monitoring system pursuant to 326 IAC 3-5, 326 IAC 10-4, 40 CFR 60, or 40 CFR 75.

D.3.10 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3]

The Permittee shall demonstrate that the sulfur dioxide emissions do not exceed the limits in Condition D.3.1(d), as established in PSD Approval to Construct EPA-5-A-80-18, issued on April 3, 1980, and Construction Permit PC (37) 1460, issued April 14, 1980, using a thirty (30) day rolling arithmetic average in the same manner as is required under D.3.8(g).

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.3.11 Transformer-Rectifier (T-R) Sets [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- (a) The ability of the ESP to control particulate emissions shall be monitored once per day, when the unit is in operation, by measuring and recording the number of T-R sets in service and the primary and secondary voltages and the currents of the T-R sets.

- (b) Reasonable response steps shall be taken in accordance with Section C - Response to Excursions and Exceedances whenever a total of more than three (3) T-R sets at Unit 17 or a total of more than two (2) T-R sets at Unit 18 are not in service. T-R set failure resulting in a response step obligation under the preceding sentence is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions and Exceedances shall be considered a deviation from this permit.

D.3.12 SO₂ Monitoring System Downtime [326 IAC 2-2] [326 IAC 2-7-6] [326 IAC 2-7-5(3)]

Whenever both the primary and back-up SO₂ continuous emission monitoring systems (CEMS) are malfunctioning or down for repairs or adjustments for a period of twenty-four (24) hours or more, the Permittee shall monitor and record boiler load, recirculation pH, slurry valve position, and absorber level to demonstrate that the operation of the scrubber continues in a manner typical for the boiler load and sulfur content of the coal fired. Scrubber parametric monitoring readings shall be recorded at least twice per day until the primary CEMS or a backup CEMS is brought online.

Record Keeping and Reporting Requirement [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.3.13 Record Keeping Requirements

- (a) To document compliance with Section C - Maintenance of Continuous Opacity Monitoring Equipment, and the particulate matter and opacity requirements in Conditions D.3.1, D.3.2, D.3.8, D.3.9, and D.3.11 the Permittee shall maintain records in accordance with (1) through (4) below. Records shall be complete and sufficient to establish compliance with the limits in Conditions D.3.1 and D.3.2.
- (1) Data and results from the most recent stack test.
 - (2) All continuous opacity monitoring data, pursuant to 326 IAC 3-5-6 and 40 CFR 60.47a.
 - (3) The results of all Method 9 visible emission readings taken during any periods of COMS downtime.
 - (4) All ESP parametric monitoring readings pursuant to condition D.3.11.
- (b) To document compliance with SO₂ Conditions D.3.1(d), D.3.2(b), D.3.8, D.3.9, D.3.10, and D.3.12, the Permittee shall maintain records in accordance with (1) and (2) below. Records shall be complete and sufficient to establish compliance with the SO₂ limit(s) as required in Conditions D.3.1(d), D.3.2(b), D.3.8, D.3.9, D.3.10, and D.3.12. The Permittee shall maintain records in accordance with (2) below during SO₂ CEM system downtime.
- (1) All SO₂ continuous emissions monitoring data, pursuant to 326 IAC 3-5-6, 326 IAC 7-2-1(g) and/or 40 CFR 60.47a.
 - (2) All scrubber parametric monitoring readings taken during any periods of CEM downtime, in accordance with Condition D.3.12.
- (c) To document compliance with NO_x Conditions D.3.1(e), D.3.2(c), D.3.8 and D.3.9, the Permittee shall maintain records of all NO_x and CO₂ or O₂ continuous emissions monitoring data, pursuant to 326 IAC 3-5-6, 326 IAC 2-2 and 40 CFR 60.47a. Records shall be complete and sufficient to establish compliance with the NO_x limits as required in Conditions D.3.1(e), D.3.2(c), D.3.8, and D.3.9.
- (d) To document compliance with the ambient monitoring requirements of Condition D.3.1(f), the Permittee shall maintain records of the meteorological and SO₂ readings.

- (e) To document compliance with Condition D.3.3, the Permittee shall maintain records of the amount of petroleum coke combusted and the pet coke/coal blend rate for each boiler. Records shall be complete and sufficient to establish compliance with the fuel limit of Condition D.3.3 using a thirty (30) day rolling weighted average.
- (f) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

D.3.14 Reporting Requirements

- (a) A quarterly report of opacity exceedances and a quarterly summary of the information to document compliance with Conditions D.3.1 and D.3.3 shall be submitted to the address listed in Section C - General Reporting Requirements, of this permit, within thirty (30) days after the end of the quarter being reported. The report submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).
- (b) The Permittee shall report the air quality and meteorological data required by Condition D.3.1(f) in a format specified by the commissioner within ninety (90) days after the end of each calendar quarter.
- (c) To document compliance with Condition D.3.2 and pursuant to 40 CFR 60.49a(i), the reports required under 40 CFR 60a and 40 CFR 60 Subpart A shall be submitted to the administrator semi-annually for each six month period in the calendar year. All semiannual reports shall be postmarked by the 30th day following the end of each six-month period. These reports shall be submitted to:

U.S. Environmental Protection Agency
Director, Air and Radiation Division
77 West Jackson Boulevard
Chicago, IL 60604-3590

and

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

The report submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

- (d) Pursuant to 326 IAC 3-5-7(5), reporting of continuous monitoring system instrument downtime, except for zero (0) and span checks, which shall be reported separately, shall include the following:
 - (1) Date of downtime.
 - (2) Time of commencement.
 - (3) Duration of each downtime.
 - (4) Reasons for each downtime.
 - (5) Nature of system repairs and adjustments.

The report submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

SECTION D.4 FACILITY OPERATION CONDITIONS - Turbines 16A and 16B

Facility Description [326 IAC 2-7-5(15)]

- (e) Two (2) natural gas-fired combustion turbines, identified as 16A and 16B, constructed in 1979, each with a design heat input capacity of 1,450 million Btu per hour (MMBtu/hr), each using water injection as needed for NO_x control, exhausting to stacks 16A and 16B, respectively. Units 16A and 16B have continuous emissions monitoring systems (CEMS) for monitoring nitrogen oxides (NO_x) for use during the ozone control period, and continuous monitoring systems to measure the water to fuel ratio.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.4.1 Prevention of Significant Deterioration (PSD) and Construction Permit Limitations [40 CFR 52.21] [326 IAC 2-2]

Pursuant to Prevention of Significant Deterioration Approval to Construct EPA-5-79-A-25, issued on August 16, 1979, and the preconstruction approval from the Indiana Air Pollution Control Board, Construction Permit PC (37) 1380, issued May 9, 1979:

- (a) Nitrogen oxide (NO_x) emissions from each turbine shall not exceed 93 ppm at 15% oxygen on a dry basis.
- (b) Each turbine unit shall not operate in excess of 2,000 hours per twelve (12) consecutive month period with compliance determined at the end of each month.

D.4.2 New Source Performance Standard (NSPS) [326 IAC 12] [40 CFR 60, Subpart GG]

Pursuant to 326 IAC 12 and 40 CFR 60, Subpart GG (Stationary Gas Turbines), emissions from the combustion turbine shall be limited as follows:

- (a) Nitrogen oxides (NO_x) emissions, as required by 40 CFR 60.332, shall not exceed:

$$STD = 0.0075 \frac{(14.4)}{Y} + F$$

where STD = allowable NO_x emissions (percent by volume at 15 percent oxygen on a dry basis).

Y = manufacturer's rated heat rate at manufacturer's rated load (kilojoules per watt hour) or, actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt hour.

F = NO_x emission allowance for fuel-bound nitrogen as defined in paragraph (a)(3) of 40 CFR 60.332.

- (b) Sulfur dioxide (SO₂) emissions, as required by 40 CFR 60.333, shall not exceed 0.015 percent by volume at fifteen percent (15%) oxygen on a dry basis, or the Permittee shall only use fuel with a sulfur content less than or equal to 0.8 percent by weight.

D.4.3 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

- (a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

D.4.4 General Provisions Relating to NSPS [326 IAC 12-1] [40 CFR 60, Subpart A]

The provisions of 40 CFR Part 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the facilities described in this section except when otherwise specified in 40 CFR Part 60, Subpart GG.

Compliance Determination Requirements

D.4.5 NO_x Control

To the extent necessary to comply with Condition D.4.1, the water injection systems which are used to control the NO_x emissions from turbines 16A and 16B shall be in operation and control emissions from turbines 16A and 16B.

D.4.6 Continuous Monitoring System [326 IAC 12] [40 CFR 60, Subpart GG]

- (a) Pursuant to 40 CFR 60, Subpart GG (Stationary Gas Turbines), a continuous monitoring system for the measurement of fuel consumption and the ratio of water to fuel being fired in the turbine, shall be installed, calibrated, operated, and maintained. This system shall be accurate to within 5.0 percent and shall be approved by the Administrator.
[40 CFR 60.334]
- (b) Pursuant to 40 CFR 60.334(b), the Permittee may, as an alternative to operating the continuous monitoring system for the fuel consumption and the ratio of water or steam to fuel being fired, install, certify, maintain, operate, and quality-assure a continuous emission monitoring system (CEMS) consisting of NO_x and O₂ monitors. The CEMS shall be installed, certified, maintained and operated as specified in 40 CFR 60.334(b)(1) through (3).
- (c) Nothing in this permit shall excuse the Permittee from complying with the requirements to operate a continuous emission monitoring system pursuant to 326 IAC 10-4 or 40 CFR 75.

D.4.7 Natural Gas Definition [326 IAC 12] [40 CFR 60, Subpart GG]

Pursuant to 40 CFR 60.334(h)(3), the Permittee may elect not to monitor the total sulfur content of the gaseous fuel combusted in the turbine, if the gaseous fuel is demonstrated to meet the definition of natural gas in 40 CFR 60.331(u), regardless of whether an existing custom schedule approved by the administrator for subpart GG requires such monitoring. The Permittee shall use one of the following sources of information to make the required demonstration:

- (a) The gas quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less; or
- (b) Representative fuel sampling data which show that the sulfur content of the gaseous fuel does not exceed 20 grains/100 scf. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of appendix D to part 75 of this chapter is required.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.4.8 Record Keeping Requirements

- (a) To document compliance with Conditions D.4.1(a), D.4.2, D.4.6, and D.4.7, the Permittee shall maintain records in accordance with (1) through (3) below. Records shall be complete and sufficient to establish compliance with the nitrogen oxides (NO_x) and sulfur dioxide (SO₂) limits established in Conditions D.4.1(a) and D.4.2.
- (1) Data and results from the most recent stack test.
- (2) To document compliance with Condition D.4.6, the Permittee shall maintain records of:
- (i) All continuous monitoring system data of fuel consumption and the ratio of water to fuel being fired; or
- (i) All continuous emission monitoring system (CEMS) data of NO_x and O₂ whenever Permittee elects to use CEMS to monitor NO_x and O₂.
- (3) Documents to support that the fuel used in turbines 16A and 16B meets the natural gas definition in 40 CFR 60.331(u).
- (b) To document compliance with Condition D.4.1(b), the Permittee shall maintain records of the date and times for all periods of turbine operation.
- (c) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

D.4.9 Reporting Requirements

- (a) To document compliance with Condition D.4.1(a), the Permittee shall submit a quarterly summary of :
- (1) The ratio of water to fuel if using the continuous monitoring method outlined in Condition D.4.6(a); or
- (2) The NO_x emissions if using the continuous emissions monitoring method outlined in Condition D.4.6(b).
- The report submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).
- (b) To document compliance with Condition D.4.1(b), the Permittee shall submit a quarterly summary of the hours of operation for each combustion turbine. These reports shall be submitted to the address listed in Section C - General Reporting Requirements, of this approval. The report submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).
- (c) The Permittee shall submit the following information pursuant to 40 CFR 60.334 and 40 CFR 60.7:
- (1) To document compliance with Conditions D.4.2, D.4.6, and D.4.7, pursuant to 40 CFR 60.334(j)(1)(iii), excess emissions and monitoring system performance (MSP) reports shall be submitted to the administrator semi-annually for each six month period in the calendar year. All semiannual reports shall be postmarked by the 30th day following the end of each six-month period. For the purpose of reports required under 40 CFR 60.7(c), periods of excess emissions that shall be reported are defined as follows:

- (A) An hour of excess emissions shall be any unit operating hour in which the 4-hour rolling average NOx concentration exceeds the applicable emission limit in 40 CFR 60.332(a)(1) or (2). For the purposes of this subpart, a "4-hour rolling average NOx concentration" is the arithmetic average of the average NOx concentration measured by the CEMS for a given hour (corrected to 15 percent O₂ and, if required under 40 CFR 60.335(b)(1), to ISO standard conditions) and the three unit operating hour average NOx concentrations immediately preceding that unit operating hour.
 - (B) A period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour, for either NOx concentration or diluent (or both).
 - (C) Each report shall include the ambient conditions (temperature, pressure, and humidity) at the time of the excess emission period and (if the Permittee has claimed an emission allowance for fuel bound nitrogen) the nitrogen content of the fuel during the period of excess emissions. The Permittee is not required to report ambient conditions if they opt to use the worst case ISO correction factor as specified in 40 CFR 60.334(b)(3)(ii), or if are not using the ISO correction equation under the provisions of 40 CFR 60.335(b)(1).
- (2) For ice fog, pursuant to 40 CFR 60.334(c)(3), each period during which an exemption is provided in 40 CFR 60.332(f) is in effect shall be reported in writing to the Administrator quarterly.

These reports shall be submitted to:

U.S. Environmental Protection Agency
Director, Air and Radiation Division
77 West Jackson Boulevard
Chicago, IL 60604-3590

and

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

The report submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

SECTION D.5 FACILITY OPERATION CONDITIONS - Units 14 and 15 Fuel Handling

Facility Description [326 IAC 2-7-5(15)]

- (f) Coal storage and handling systems for Unit 14 and 15 boilers constructed in 1972.
 - (1) Rail car unloading with wet suppression for PM control during unloading and enclosure for ancillary dust control.
 - (2) Coal pile unloading, coal storage pile(s), material handling equipment, and coal conveyors.
 - (3) Transfer House, with carryover wet suppression and enclosed transfer points within an enclosure for ancillary dust control, with an estimated throughput of 3,000 tons per hour.
 - (4) Crusher House, with carryover wet suppression for PM control and enclosed transfer points within an enclosure for ancillary dust control.
 - (5) Tripper House to tripper bays, with enclosed transfer points within an enclosure for dust control.
 - (6) Two (2) tripper bays with an estimated combined capacity of 3,000 tons per hour, with carryover wet suppression for PM control, each using an enclosure for ancillary dust control.

Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)]:

- (a) Conveyors as follows [326 IAC 6-3]:
 - (1) Covered conveyor for coal or coke conveying of less than or equal to 360 tons per day;
 - (3) Uncovered coal conveying of less than or equal to 120 tons per day.
 - (4) Underground conveyors.
- (b) Coal bunker and coal scale exhausts and associated dust collector vents. [326 IAC 6-3]

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.5.1 Particulate [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), allowable particulate emissions for the coal handling operations shall be calculated as follows:

- (a) Particulate shall not be emitted in excess of the amount shown in the table in 326 IAC 6-3-2(e). The allowable rate of emission shall be based on the process weight rate for the process.
- (b) Interpolation of the data in the table in 326 IAC 6-3-2(e) for process weight rates up to sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 4.10 P^{0.67} \quad \text{where } E = \text{rate of emission in pounds per hour and} \\ P = \text{process weight rate in tons per hour.}$$

- (c) Interpolation and extrapolation of the data in the table in 326 IAC 6-3-2(e) for process weight rates in excess of sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 55.0 P^{0.11} - 40$$

where E = rate of emission in pounds per hour; and
P = process weight rate in tons per hour.

- (d) When the process weight rate exceeds two hundred (200) tons per hour, the allowable emission may exceed that shown in the table in 326 IAC 6-3-2(e), provided the concentration of particulate in the discharge gases to the atmosphere is less than one-tenth (0.10) pound per one thousand (1,000) pounds of gases.

7

SECTION D.6 FACILITY OPERATION CONDITIONS - Units 17 and 18 Fuel Handling

Facility Description [326 IAC 2-7-5(15)]

- (g) Fuel storage and handling systems for Unit 17 and 18 boilers.
- (1) Rail car unloading of coal, with a multi-compartment baghouse for PM control and enclosure for ancillary dust control.
 - (2) Truck unloading of petroleum coke (petcoke).
 - (3) Coal pile unloading, coal storage pile(s), petcoke pile unloading, petcoke storage pile(s), material handling equipment, and conveyors.
 - (4) Transfer House with an estimated throughput of 4,000 tons per hour, with enclosed transfer points within an enclosure for ancillary dust control, with a multi-compartment baghouse for PM control. To produce petcoke blends, coal and petcoke are combined in rotary plow during transfer to conveyor.
 - (5) Crusher House with a designated capacity of 3,000 tons per hour, with enclosed transfer points within an enclosure for dust control, with a multi-compartment baghouse for PM control.
 - (6) Transfer House to tripper with an estimated throughput of 3,000 tons per hour, with enclosed transfer points within an enclosure for ancillary dust control.
 - (7) Two (2) tripper conveyors with an estimated combined throughput of 3,000 tons per hour with enclosure for ancillary dust control, with a multi-compartment baghouse for PM control.
 - (8) Twelve (12) Fuel Silos (bunkers) with enclosure for dust control, with two (2) multi-compartment vent filters for PM control.

Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)]:

- (a) Conveyors as follows [326 IAC 6-3]:
- (1) Covered conveyor for coal or coke conveying of less than or equal to 360 tons per day;
 - (3) Uncovered coal conveying of less than or equal to 120 tons per day; and
 - (4) Underground conveyors.
- (b) Coal bunker and coal scale exhausts and associated dust collector vents. [326 IAC 6-3]

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.6.1 Prevention of Significant Deterioration (PSD) [40 CFR 52.21] [326 IAC 2-2]

Pursuant to Approval to Construct EPA-5-A-80-18, issued on April 3, 1980:

- (a) Particulate emissions from coal unloading shall not exceed ten percent (10%) opacity for the duration of the unloading operation.

- (b) All coal conveyors shall be completely enclosed.
- (c) All transfer points shall be completely enclosed except those at the storage pile.
- (d) Particulate emissions from the crusher house, conveyor room and reclaim tunnels shall be controlled to 99 percent.
- (e) Fugitive emissions from the coal piles shall be minimized by compaction and other appropriate measures (surfactant spray etc.).

D.6.2 New Source Performance Standard (NSPS) [326 IAC 12] [40 CFR 60, Subpart Y]

- (a) Pursuant to 326 IAC 12 and 40 CFR 60.252, the emissions from the fuel storage and handling systems for Units 17 and 18, beginning after the fuel storage piles, shall not exhibit opacity greater than or equal to twenty percent (20%).
- (b) For the purposes of 40 CFR 60, Subpart Y, petroleum coke is classified as coal. [40 CFR 60.251(c)]

D.6.3 Particulate [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), for the fuel storage and handling systems for Units 17 and 18 other than the coal storage piles, allowable particulate emissions for the coal handling operations shall be calculated as follows:

- (a) Particulate shall not be emitted in excess of the amount shown in the table in 326 IAC 6-3-2(e). The allowable rate of emission shall be based on the process weight rate for the process.
- (b) Interpolation of the data in the table in 326 IAC 6-3-2(e) for process weight rates up to sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 4.10 P^{0.67} \quad \text{where } E = \text{rate of emission in pounds per hour and} \\ P = \text{process weight rate in tons per hour.}$$

- (c) Interpolation and extrapolation of the data in the table in 326 IAC 6-3-2(e) for process weight rates in excess of sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 55.0 P^{0.11} - 40 \quad \text{where } E = \text{rate of emission in pounds per hour; and} \\ P = \text{process weight rate in tons per hour.}$$

- (d) When the process weight rate exceeds two hundred (200) tons per hour, the allowable emission may exceed that shown in the table in 326 IAC 6-3-2(e), provided the concentration of particulate in the discharge gases to the atmosphere is less than one-tenth (0.10) pound per one thousand (1,000) pounds of gases.

D.6.4 General Provisions Relating to NSPS [326 IAC 12-1] [40 CFR 60, Subpart A]

The provisions of 40 CFR Part 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the fuel storage and handling systems for Units 17 and 18, beginning after the fuel storage piles, except when otherwise specified in 40 CFR Part 60, Subpart Y.

Compliance Determination Requirements

D.6.5 Particulate Control [326 IAC 2-7-6(6)]

In the event that bag failure is observed in a multi-compartment baghouse, if operations will continue for ten (10) days or more after the failure is observed before the failed bag will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed bag will be repaired or replaced. The notification shall also include the results of any response actions taken up to the time of notification.

D.6.6 NSPS Compliance Provisions [326 IAC 12] [40 CFR 60, Subpart Y]

Method 9 and the procedures in 40 CFR 60.11 shall be used to determine opacity.
[40 CFR 60.254(b)(2)]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.6.7 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- (a) Visible emission notations of the rail car unloading station openings shall be performed once per day during normal daylight operations when unloading coal. A trained employee shall record whether emissions are normal or abnormal.
- (b) Visible emission notations of the fuel transfer exhaust points shall be performed once per week during normal daylight operations when transferring fuel. A trained employee shall record whether emissions are normal or abnormal.
- (c) Visible emission notations of the coal crusher exhaust shall be performed once per week during normal daylight operations when the crusher is in operation. A trained employee shall record whether emissions are normal or abnormal.
- (d) If abnormal emissions of dust are observed from the rail car unloading station openings, the fuel transfer exhaust points, or the coal crusher exhaust, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions and Exceedances. Observation of abnormal visible emissions that do not violate 326 IAC 6-4 (Fugitive Dust Emissions) or an applicable opacity limit is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions and Exceedances, shall be considered a deviation from this permit.
- (e) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation.
- (f) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- (g) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.

D.6.8 Baghouse Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- (a) The Permittee shall record the pressure drop across the baghouse used in conjunction with the coal crusher at least once per week when the coal crusher is in operation. When for any one reading, the pressure drop across the baghouse is outside the normal range of 2.0 and 8.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions and Exceedances. A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions and Exceedances, shall be considered a deviation from this permit.

- (b) The Permittee shall record the pressure drop across each of the baghouses used in conjunction with the fuel transfer points at least once per week when fuel is being transferred. When for any one reading, the pressure drop across the baghouse is outside the normal range of 2.0 and 8.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions and Exceedances. A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions and Exceedances, shall be considered a deviation from this permit.
- (c) Each instrument used for determining the pressure shall comply with Section C - Instrument Specifications, and shall be calibrated in accordance with the manufacturer's specifications. The specifications shall be available on site with the Preventive Maintenance Plan.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.6.9 Record Keeping Requirements

- (a) To document compliance with Condition D.6.7, the Permittee shall maintain records of the visible emission notations of the coal unloading station openings, coal transfer exhaust points, and crusher baghouse exhaust.
- (b) To document compliance with Condition D.6.8, the Permittee shall maintain records of the pressure drop across each baghouse.
- (c) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

SECTION D.7 FACILITY OPERATION CONDITIONS - FGD System Material Handling

Facility Description [326 IAC 2-7-5(15)]

- (h) Material handling for the flue gas desulfurization systems for Units 17 and 18, including the following:
- (1) One (1) limestone slurry preparation system with a maximum hourly throughput rate of 38,941 pounds of limestone per hour.
 - (2) Two (2) ground limestone pneumatic truck unloading systems connected to Unit 17 limestone silos, with baghouses for PM control.
 - (3) Two (2) ground limestone pneumatic truck unloading systems connected to Unit 18 limestone silos, with baghouses for PM control.
 - (4) One (1) gypsum conveying system, with a maximum design throughput of 150 tons per hour. All gypsum is handled wet.

Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)]:

- (a) Conveyors as follows [326 IAC 6-3]:
- (2) Covered conveyors for limestone conveying of less than or equal to 7,200 tons per day for sources other than mineral processing plants constructed after August 31, 1983;
 - (4) Underground conveyors.
- (g) Other activities or categories not previously identified with potential, uncontrolled emissions equal to or less than thresholds require listing only: Pb 0.6 ton per year or 3.29 pounds per day, SO₂ 5 pounds per hour or 25 pounds per day, NO_x 5 pounds per hour or 25 pounds per day, CO 25 pounds per day, PM 5 pounds per hour or 25 pounds per day, VOC 3 pounds per hour or 15 pounds per day:
- (5) Gypsum stockpile [326 IAC 6-3].

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.7.1 Particulate [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), the particulate emission rate from the limestone handling system shall not exceed 30 pounds per hour when operating at a process weight rate of 38,941 pounds per hour. This pounds per hour limitation was calculated using the following equation:

Interpolation of the data for the process weight rate up to sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 4.10 P^{0.67}$$

where E = rate of emission in pounds per hour and
P = process weight rate in tons per hour.

SECTION D.8 FACILITY OPERATION CONDITIONS - Fly Ash Handling

Facility Description [326 IAC 2-7-5(15)]

- (i) Dry fly ash handling and disposal.
 - (1) Pneumatic conveyance to storage silos, with a design capacity of 70 tons per hour of fly ash from Units 14 and 15 combined, and a design capacity of 63 tons per hour of fly ash from each of Units 17 and 18.
 - (2) Fly ash storage silos for Units 14, 15, 17, and 18, with cyclone separators, silo collector bag filters, and silo bin vent bag filters. Each silo has wet and dry unloaders, each with a design unloading capacity of 300+ tons per hour, with particulate emissions controlled by the use of a telescoping chute with a vacuum system and a bin vent filter when the ash is being loaded dry, and controlled by the use of water spray mixed with the ash when the ash is being loaded wet.
 - (3) Two (2) storage silos originally used for dual-alkali FGD system, currently used for storage of fly ash from Unit 15; with cyclone separators, silo collector bag filters, and bin vent bag filters; with telescoping chute unloaders with vacuum line to the silo for dry ash unloading to enclosed trucks.
 - (4) Transportation by truck via in-plant haul roads; and onsite disposal area.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.8.1 Prevention of Significant Deterioration (PSD) [40 CFR 52.21] [326 IAC 2-2]

For the fly ash from Units 17 and 18, pursuant to Approval to Construct EPA-5-A-80-18, issued on April 3, 1980:

Fly ash handling, storage and transport shall be controlled by wetting and/or by installation of baghouses. Trucks utilized for dry or unconditioned ash disposal shall be covered. (in EPA-5-A-80-18 only)

D.8.2 Particulate [326 IAC 6-3-2]

- (a) Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), the particulate emission rate from the fly ash conveyance from Units 14 and 15 shall not exceed 47.8 pounds per hour when operating at a process weight rate of 70 tons per hour of ash, and the particulate emission rate from the fly ash conveyance from each of Units 17 and 18 shall not exceed 46.8 pounds per hour when operating at a process weight rate of 63 tons per hour of fly ash from each of Units 17 and 18. These pounds per hour limitations were calculated using the following equation:

Interpolation and extrapolation of the data for the process weight rate in excess of 60,000 pounds per hour shall be accomplished by use of the equation:

$$E = 55.0 P^{0.11} - 40 \quad \text{where } E = \text{rate of emission in pounds per hour; and} \\ P = \text{process weight rate in tons per hour}$$

- (b) Pursuant to 326 IAC 6-3-2(e)(3) (Particulate Emission Limitations for Manufacturing Processes), for dry fly ash silo unloading at a throughput rate greater than 200 tons per hour, the concentration of particulate in the discharge gases to the atmosphere shall be less than 0.10 pounds per one thousand (1,000) pounds of gases.

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.8.3 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- (a) Visible emission notations of the ash silo unloading station openings shall be performed at least once per day during normal daylight operations when ash is being unloaded. A trained employee shall record whether emissions are normal or abnormal.
- (b) Visible emission notations of the fly ash conveyance and silo bag filter and bin vent filter exhausts shall be performed at least once per day during normal daylight operations when transferring ash to the corresponding silo. A trained employee shall record whether emissions are normal or abnormal.
- (c) Visible emission notations of the nozzle of each telescoping chute shall be performed at least once per day during normal daylight operations when unloading ash through the chute. A trained employee shall record whether emissions are normal or abnormal.
- (d) If abnormal visible emissions of ash are observed from the ash silo unloading station openings, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions and Exceedances. Observation of abnormal visible emissions that do not violate 326 IAC 6-4 (Fugitive Dust Emissions) or an applicable opacity limit is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions and Exceedances, shall be considered a deviation from this permit.
- (e) If abnormal emissions are observed at any bag filter exhaust, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions and Exceedances. Observation of abnormal emissions that do not violate 326 IAC 6-4 (Fugitive Dust Emissions) or an applicable opacity limit is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions and Exceedances, shall be considered a deviation from this permit.
- (f) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.
- (g) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- (h) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.

D.8.4 Baghouse Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- (a) The Permittee shall record the pressure drop across the bag filters used in conjunction with the ash handling at least once per day when the ash handling is in operation. When for any one reading, the pressure drop across the baghouse is outside the normal range of 3.0 and 6.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions and Exceedances. A pressure drop reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions and Exceedances, shall be considered a deviation from this permit.
- (b) The instrument used for determining the pressure shall comply with Section C - Instrument Specifications, and shall be calibrated in accordance with the manufacturer's specifications. The specifications shall be available on site with the Preventive Maintenance Plan.

D.8.5 Broken or Failed Bag Detection [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

In the event that bag failure has been observed:

For bin vent filters, if failure is indicated by an opacity violation, or if filter failure is determined by other means, such as gas temperatures, flow rates, air infiltration, leaks, dust traces or triboflows, then failed unit and the associated process will be shut down immediately until the failed unit has been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**D.8.6 Record Keeping Requirements**

- (a) To document compliance with Condition D.8.3, the Permittee shall maintain records of the visible emission notations of the Unit 17 and 18 ash silo unloading station openings, and the Unit 17 and 18 baghouse stack exhaust.
- (b) To document compliance with Condition D.8.4, the Permittee shall maintain records of the pressure drop across each bag filter.
- (c) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

SECTION D.9 FACILITY OPERATION CONDITIONS - Bottom Ash and FGD Waste

Facility Description [326 IAC 2-7-5(15)]

- (j) Wet process bottom ash handling, with sluicing lines conveying ash to storage ponds in the Waste Disposal Area.
- (k) Poned bottom ash handling/removal operations.

Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)]:

- (g) Other activities or categories not previously identified with potential, uncontrolled emissions equal to or less than thresholds require listing only: Pb 0.6 ton per year or 3.29 pounds per day, SO₂ 5 pounds per hour or 25 pounds per day, NO_x 5 pounds per hour or 25 pounds per day, CO 25 pounds per day, PM 5 pounds per hour or 25 pounds per day, VOC 3 pounds per hour or 15 pounds per day:
 - (3) Wet handling of FGD sludge material collected from the FGD building sumps, sluiced to the Material Storage Runoff Pond. FGD material dredged from pond inlet area is dewatered on the pond bank with trucks conveying dewatered material to onsite landfill. [326 IAC 6-4]

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.9.1 Prevention of Significant Deterioration (PSD) and Construction Permit Limitations [40 CFR 52.21] [326 IAC 2-2]

Pursuant to Approval to Construct EPA-5-A-80-18, issued on April 3, 1980, and Indiana Air Pollution Control Board Construction Permit PC (37) 1460, issued April 14, 1980, with respect to Units 17 and 18:

- (a) The bottom ash shall be sluiced to waste disposal ponds. (in PC (37) 1460 only)
- (b) Bottom ash handling, storage and transport shall be controlled by wetting and/or by installation of baghouses. (in EPA-5-A-80-18 only)

D.9.2 Fugitive Dust Emission Limitations [326 IAC 6-4-2]

Pursuant to 326 IAC 6-4-2:

- (a) Any ash storage pond area or onsite landfill generating fugitive dust shall be in violation of this rule (326 IAC 6-4) if any of the following criteria are violated:
 - (1) A source or combination of sources which cause to exist fugitive dust concentrations greater than sixty-seven percent (67%) in excess of ambient upwind concentrations as determined by the following formula:

$$P = \frac{100(R - U)}{U}$$

Where

P = Percentage increase

R = Number of particles of fugitive dust measured at downward receptor site

U = Number of particles of fugitive dust measured at upwind or background site

- (2) The fugitive dust is comprised of fifty percent (50%) or more respirable dust, then the percent increase of dust concentration in subdivision (1) of this section shall be modified as follows:

$$P_R = (1.5 N) P$$

Where

N = Fraction of fugitive dust that is respirable dust;

P_R = allowable percentage increase in dust concentration above background;
and

P = no value greater than sixty-seven percent (67%).

- (3) The ground level ambient air concentrations exceed fifty (50) micrograms per cubic meter above background concentrations for a sixty (60) minute period.
- (4) If fugitive dust is visible crossing the boundary or property line of a source. This subdivision may be refuted by factual data expressed in subdivisions (1), (2) or (3) of this section. 326 IAC 6-4-2(4) is not federally enforceable.
- (b) Pursuant to 326 IAC 6-4-6(6) (Exceptions), fugitive dust from a source caused by adverse meteorological conditions will be considered an exception to this rule (326 IAC 6-4) and therefore not in violation.

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.9.3 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- (a) Visible emission notations of any active onsite landfill area(s) shall be performed at least once per day during normal daylight operations. Any storage pond in the Waste Disposal Area or the Material Storage Runoff Pond area that contains either bottom ash and/or FGD sludge shall be observed once per week to determine if sufficient water is present in the pond to cover or saturate bottom ash and/or sludge deposited in the pond. During any period when there is not sufficient water in the pond to cover or saturate bottom ash and/or sludge present in the pond, visible emission notations of such storage pond area(s) shall be performed at least once per day during normal daylight operations. When daily visible emission notations are made, a trained employee shall record whether emissions are normal or abnormal.
- (b) If visible emissions are observed crossing the property line or boundaries of the property, right-of-way, or easement on which the source is located, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions and Exceedances. Failure to take response steps in accordance with Section C - Response to Excursions and Exceedances, shall be considered a deviation from this permit.
- (c) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation.
- (d) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- (e) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.9.4 Record Keeping Requirements

- (a) To document compliance with Condition D.9.3, the Permittee shall maintain records of visible observations, and any resulting visible emission notations of the Waste Disposal Area and the Material Storage Runoff Pond area, and records of visible emission notations relating to any active onsite landfill area(s).
- (b) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

SECTION D.10 FACILITY OPERATION CONDITIONS - Emergency Generator

Facility Description [326 IAC 2-7-5(15)]

Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)]:

- (e) Emergency generators as follows: Diesel generators not exceeding 1600 horsepower. [326 IAC 7]

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.10.1 Sulfur Dioxide (SO₂) [326 IAC 7-1.1-2]

Pursuant to 326 IAC 7-1.1-2 (Sulfur Dioxide Emission Limitations), the SO₂ emissions from the diesel-fired emergency generator(s) shall not exceed 0.5 pounds per million Btu (lbs/MMBtu).

Compliance Determination Requirements

D.10.2 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3] [326 IAC 7-2] [326 IAC 7-1.1-2]

Compliance with Condition D.10.1 shall be determined utilizing one of the following options:

- (a) Pursuant to 326 IAC 7-2-1(c), the Permittee shall demonstrate that the sulfur dioxide emissions from the emergency generator(s) do not exceed the equivalent of five-tenths (0.5) pound per million Btu heat input.
- (b) Pursuant to 326 IAC 7-2-1(e) and 326 IAC 3-7-4, fuel sampling and analysis data shall be collected as follows:
- (1) The Permittee may rely upon vendor analysis of fuel delivered, if accompanied by a vendor certification [326 IAC 3-7-4(b)]; or,
 - (2) The Permittee shall perform sampling and analysis of fuel oil samples in accordance with 326 IAC 3-7-4(a).
 - (A) Oil samples shall be collected from the tanker truck load prior to transferring fuel to the storage tank; or
 - (B) Oil samples shall be collected from the storage tank immediately after each addition of fuel to the tank.

Record Keeping and Reporting Requirement [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.10.3 Record Keeping Requirements

- (a) To document compliance with the requirements in Conditions D.10.1 and D.10.2, the Permittee shall maintain records of all fuel sampling and analysis data, pursuant to 326 IAC 7-2. Records shall be complete and sufficient to establish compliance with the SO₂ limit in Condition D.10.1.
- (b) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

SECTION D.11 FACILITY OPERATION CONDITIONS - Additional Insignificant Activities

Facility Description [326 IAC 2-7-5(15)]

Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)]:

- (c) The following equipment related to manufacturing activities not resulting in the emission of HAPs: brazing equipment, cutting torches, soldering equipment, welding equipment. [326 IAC 6-3]
- (d) Any of the following structural steel and bridge fabrication activities: [326 IAC 6-3]
 - (1) Cutting 200,000 linear feet or less of one inch (10) plate or equivalent.
 - (2) Using 80 tons or less of welding consumables.
- (f) Grinding and machining operations controlled with fabric filters, scrubbers, mist collectors, wet collectors and electrostatic precipitators with a design grain loading of less than or equal to 0.03 grains per actual cubic foot and a gas flow rate less than or equal to 4000 actual cubic feet per minute, including the following: deburring; buffing; polishing; abrasive blasting; pneumatic conveying; and woodworking operations. [326 IAC 6-3]
- (g) Other activities or categories not previously identified with potential, uncontrolled emissions equal to or less than thresholds require listing only: Pb 0.6 ton per year or 3.29 pounds per day, SO₂ 5 pounds per hour or 25 pounds per day, NO_x 5 pounds per hour or 25 pounds per day, CO 25 pounds per day, PM 5 pounds per hour or 25 pounds per day, VOC 3 pounds per hour or 15 pounds per day: [326 IAC 6-3]
 - (4) Shot blasters. [326 IAC 6-3]

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.11.1 Particulate [326 IAC 6-3-2]

- (a) Pursuant to 326 IAC 6-3-2(e)(2), particulate emissions from any process not exempt under 326 IAC 6-3-1(b) or (c) which has a maximum process weight rate less than 100 pounds per hour and the methods in 326 IAC 6-3-2(b) through (d) do not apply shall not exceed 0.551 pounds per hour.
- (b) Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), particulate emission rate from the brazing, cutting, soldering, welding, grinding, and machining operations shall not exceed an amount determined by the following, for a process weight rate equal to or greater than 100 pounds per hour:

Interpolation of the data for the process weight rate up to sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 4.10 P^{0.67} \quad \text{where } E = \text{rate of emission in pounds per hour and} \\ P = \text{process weight rate in tons per hour.}$$

SECTION E

TITLE IV CONDITIONS

Facility Description [326 IAC 2-7-5(15)]

- (a) One (1) cyclone coal-fired boiler identified as Unit 14, with construction commenced in 1970 and commercial operation begun in 1976, with a design heat input capacity of 4650 million Btu per hour (MMBTU/hr), combusting No. 2 fuel oil and/or natural gas for ignition and as supplemental fuels, using an electrostatic precipitator (ESP) for control of particulate matter and exhausting to stack 14. Unit 14 has a selective catalytic reduction (SCR) system, and has continuous emissions monitoring systems (CEMS) for monitoring nitrogen oxides (NO_x) and sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system.
- (b) One (1) dry bottom pulverized coal-fired boiler identified as Unit 15, with construction commenced in 1974 and commercial operation begun in 1979, with a design heat input capacity of 5100 million Btu per hour (MMBTU/hr), with low NO_x burners, combusting No. 2 fuel oil and/or natural gas for ignition and as supplemental fuels, using an electrostatic precipitator (ESP) with a flue gas conditioning (FGC) system for control of particulate matter, and exhausting to stack 15. Unit 15 has continuous emissions monitoring systems (CEMS) for monitoring nitrogen oxides (NO_x) and sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system.
- (c) One (1) dry bottom pulverized coal-fired boiler identified as Unit 17, with construction started in 1980 and commercial operation begun in 1983, with a design heat input capacity of 3967 million Btu per hour (MMBTU/hr), with low NO_x burners, combusting No. 2 fuel oil and/or natural gas for ignition and as supplemental fuels, using an electrostatic precipitator (ESP) for control of particulate matter, and exhausting through a limestone-based flue gas desulfurization system to stack 17. Unit 17 is equipped with continuous emissions monitoring systems (CEMS) for monitoring nitrogen oxides (NO_x) and sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Unit 17 has been approved to fire blends of coal and petroleum coke.
- (d) One (1) dry bottom pulverized coal-fired boiler identified as Unit 18, with construction started in 1980 and commercial operation begun in 1986, with a design heat input capacity of 3967 million Btu per hour (MMBTU/hr), with low NO_x burners, combusting No. 2 fuel oil and/or natural gas for ignition and as supplemental fuels, using an electrostatic precipitator (ESP) for control of particulate matter, and exhausting through a limestone-based flue gas desulfurization system to stack 18. Unit 18 has continuous emissions monitoring systems (CEMS) for monitoring nitrogen oxides (NO_x) and sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Unit 18 has been approved to fire blends of coal and petroleum coke.
- (e) Two (2) natural gas-fired combustion turbines, identified as 16A and 16B, constructed in 1979, each with a design heat input capacity of 998 million Btu per hour (MMBTU/hr), each using water injection as needed for NO_x control, exhausting to stacks 16A and 16B, respectively. Units 16A and 16B have continuous emissions monitoring systems (CEMS) for monitoring nitrogen oxides (NO_x) for use during the ozone control period, and continuous monitoring systems to measure the water to fuel ratio.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Acid Rain Program

E.1 Acid Rain Permit [326 IAC 2-7-5(1)(C)] [326 IAC 21] [40 CFR 72 through 40 CFR 78]

Pursuant to 326 IAC 21 (Acid Deposition Control), the Permittee shall comply with all provisions of the Acid Rain permit issued for this source, and any other applicable requirements contained in 40 CFR 72 through 40 CFR 78. The Acid Rain permit for this source is attached to this permit as Appendix A, and is incorporated by reference.

E.2 Title IV Emissions Allowances [326 IAC 2-7-5(4)] [326 IAC 21]

Emissions exceeding any allowances that the Permittee lawfully holds under the Title IV Acid Rain Program of the Clean Air Act are prohibited, subject to the following limitations:

- (a) No revision of this permit shall be required for increases in emissions that are authorized by allowances acquired under the Title IV Acid Rain Program, provided that such increases do not require a permit revision under any other applicable requirement.
- (b) No limit shall be placed on the number of allowances held by the Permittee. The Permittee may not use allowances as a defense to noncompliance with any other applicable requirement.
- (c) Any such allowance shall be accounted for according to the procedures established in regulations promulgated under Title IV of the Clean Air Act.

SECTION F Nitrogen Oxides Budget Trading Program - NO_x Budget Permit for NO_x Budget Units Under 326 IAC 10-4-1(a)

ORIS Code: 6085

NO_x Budget Source [326 IAC 2-7-5(15)]

- (a) One (1) cyclone coal-fired boiler identified as Unit 14, with construction commenced in 1970 and commercial operation begun in 1976, with a design heat input capacity of 4650 million Btu per hour (MMBTU/hr), combusting No. 2 fuel oil and/or natural gas for ignition and as supplemental fuels, using an electrostatic precipitator (ESP) for control of particulate matter and exhausting to stack 14. Unit 14 has a selective catalytic reduction (SCR) system, and has continuous emissions monitoring systems (CEMS) for monitoring nitrogen oxides (NO_x) and sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system.
- (b) One (1) dry bottom pulverized coal-fired boiler identified as Unit 15, with construction commenced in 1974 and commercial operation begun in 1979, with a design heat input capacity of 5100 million Btu per hour (MMBTU/hr), with low NO_x burners, combusting No. 2 fuel oil and/or natural gas for ignition and as supplemental fuels, using an electrostatic precipitator (ESP) with a flue gas conditioning (FGC) system for control of particulate matter, and exhausting to stack 15. Unit 15 has continuous emissions monitoring systems (CEMS) for monitoring nitrogen oxides (NO_x) and sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system.
- (c) One (1) dry bottom pulverized coal-fired boiler identified as Unit 17, with construction started in 1980 and commercial operation begun in 1983, with a design heat input capacity of 3967 million Btu per hour (MMBTU/hr), with low NO_x burners, combusting No. 2 fuel oil and/or natural gas for ignition and as supplemental fuels, using an electrostatic precipitator (ESP) for control of particulate matter, and exhausting through a limestone-based flue gas desulfurization system to stack 17. Unit 17 is equipped with continuous emissions monitoring systems (CEMS) for monitoring nitrogen oxides (NO_x) and sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Unit 17 has been approved to fire blends of coal and petroleum coke.
- (d) One (1) dry bottom pulverized coal-fired boiler identified as Unit 18, with construction started in 1980 and commercial operation begun in 1986, with a design heat input capacity of 3967 million Btu per hour (MMBTU/hr), with low NO_x burners, combusting No. 2 fuel oil and/or natural gas for ignition and as supplemental fuels, using an electrostatic precipitator (ESP) for control of particulate matter, and exhausting through a limestone-based flue gas desulfurization system to stack 18. Unit 18 has continuous emissions monitoring systems (CEMS) for monitoring nitrogen oxides (NO_x) and sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Unit 18 has been approved to fire blends of coal and petroleum coke.
- (e) Two (2) natural gas-fired combustion turbines, identified as 16A and 16B, constructed in 1979, each with a design heat input capacity of 998 million Btu per hour (MMBTU/hr), each using water injection as needed for NO_x control, exhausting to stacks 16A and 16B, respectively. Units 16A and 16B have continuous emissions monitoring systems (CEMS) for monitoring nitrogen oxides (NO_x) for use during the ozone control period, and continuous monitoring systems to measure the water to fuel ratio.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

F.1 Automatic Incorporation of Definitions [326 IAC 10-4-7(e)]

This NO_x budget permit is deemed to incorporate automatically the definitions of terms under 326 IAC 10-4-2.

F.2 Standard Permit Requirements [326 IAC 10-4-4(a)]

- (a) The owners and operators of the NO_x budget source and each NO_x budget unit shall operate each unit in compliance with this NO_x budget permit.
- (b) The NO_x budget units subject to this NO_x budget permit are Unit 14, Unit 15, Unit 17, Unit 18, Unit 16A, and Unit 16B.

F.3 Monitoring Requirements [326 IAC 10-4-4(b)]

- (a) The owners and operators and, to the extent applicable, the NO_x authorized account representative of the NO_x budget source and each NO_x budget unit at the source shall comply with the monitoring requirements of 40 CFR 75 and 326 IAC 10-4-12.
- (b) The emissions measurements recorded and reported in accordance with 40 CFR 75 and 326 IAC 10-4-12 shall be used to determine compliance by each unit with the NO_x budget emissions limitation under 326 IAC 10-4-4(c) and Condition F.4, Nitrogen Oxides Requirements.

F.4 Nitrogen Oxides Requirements [326 IAC 10-4-4(c)]

- (a) The owners and operators of the NO_x budget source and each NO_x budget unit at the source shall hold NO_x allowances available for compliance deductions under 326 IAC 10-4-10(j), as of the NO_x allowance transfer deadline, in each unit's compliance account and the source's overdraft account in an amount:
 - (1) Not less than the total NO_x emissions for the ozone control period from the unit, as determined in accordance with 40 CFR 75 and 326 IAC 10-4-12;
 - (2) To account for excess emissions for a prior ozone control period under 326 IAC 10-4-10(k)(5); or
 - (3) To account for withdrawal from the NO_x budget trading program, or a change in regulatory status of a NO_x budget opt-in unit.
- (b) Each ton of NO_x emitted in excess of the NO_x budget emissions limitation shall constitute a separate violation of the Clean Air Act (CAA) and 326 IAC 10-4.
- (c) Each NO_x budget unit shall be subject to the requirements under (a) above and 326 IAC 10-4-4(c)(1) starting on May 31, 2004.
- (d) NO_x allowances shall be held in, deducted from, or transferred among NO_x allowance tracking system accounts in accordance with 326 IAC 10-4-9 through 11, 326 IAC 10-4-13, and 326 IAC 10-4-14.
- (e) A NO_x allowance shall not be deducted, in order to comply with the requirements under (a) above and 326 IAC 10-4-4(c)(1), for an ozone control period in a year prior to the year for which the NO_x allowance was allocated.
- (f) A NO_x allowance allocated under the NO_x budget trading program is a limited authorization to emit one (1) ton of NO_x in accordance with the NO_x budget trading program. No provision of the NO_x budget trading program, the NO_x budget permit application, the NO_x budget permit, or an exemption under 326 IAC 10-4-3 and no provision of law shall be construed to limit the authority of the U.S. EPA or IDEM, OAQ to terminate or limit the authorization.
- (g) A NO_x allowance allocated under the NO_x budget trading program does not constitute a property right.

- (h) Upon recordation by the U.S. EPA under 326 IAC 10-4-10, 326 IAC 10-4-11, or 326 IAC 10-4-13, every allocation, transfer, or deduction of a NO_x allowance to or from each NO_x budget unit's compliance account or the overdraft account of the source where the unit is located is deemed to amend automatically, and become a part of, this NO_x budget permit of the NO_x budget unit by operation of law without any further review.

F.5 Excess Emissions Requirements [326 IAC 10-4-4(d)]

The owners and operators of each NO_x budget unit that has excess emissions in any ozone control period shall do the following:

- (a) Surrender the NO_x allowances required for deduction under 326 IAC 10-4-10(k)(5).
- (b) Pay any fine, penalty, or assessment or comply with any other remedy imposed under 326 IAC 10-4-10(k)(7).

F.6 Record Keeping Requirements [326 IAC 10-4-4(e)] [326 IAC 2-7-5(3)]

Unless otherwise provided, the owners and operators of the NO_x budget source and each NO_x budget unit at the source shall keep, either on site at the source or at a central location within Indiana for those owners or operators with unattended sources, each of the following documents for a period of five (5) years:

- (a) The account certificate of representation for the NO_x authorized account representative for the source and each NO_x budget unit at the source and all documents that demonstrate the truth of the statements in the account certificate of representation, in accordance with 326 IAC 10-4-6(h). The certificate and documents shall be retained either on site at the source or at a central location within Indiana for those owners or operators with unattended sources beyond the five (5) year period until the documents are superseded because of the submission of a new account certificate of representation changing the NO_x authorized account representative.
- (b) All emissions monitoring information, in accordance with 40 CFR 75 and 326 IAC 10-4-12, provided that to the extent that 40 CFR 75 and 326 IAC 10-4-12 provide for a three (3) year period for record keeping, the three (3) year period shall apply.
- (c) Copies of all reports, compliance certifications, and other submissions and all records made or required under the NO_x budget trading program.
- (d) Copies of all documents used to complete a NO_x budget permit application and any other submission under the NO_x budget trading program or to demonstrate compliance with the requirements of the NO_x budget trading program.

This period may be extended for cause, at any time prior to the end of five (5) years, in writing by IDEM, OAQ or the U.S. EPA. Records retained at a central location within Indiana shall be available immediately at the location and submitted to IDEM, OAQ or U.S. EPA within three (3) business days following receipt of a written request. Nothing in 326 IAC 10-4-4(e) shall alter the record retention requirements for a source under 40 CFR 75. Unless otherwise provided, all records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

F.7 Reporting Requirements [326 IAC 10-4-4(e)]

- (a) The NO_x authorized account representative of the NO_x budget source and each NO_x budget unit at the source shall submit the reports and compliance certifications required under the NO_x budget trading program, including those under 326 IAC 10-4-8, 326 IAC 10-4-12, or 326 IAC 10-4-13.

(b) Pursuant to 326 IAC 10-4-4(e) and 326 IAC 10-4-6(e)(1), each submission shall include the following certification statement by the NO_x authorized account representative: "I am authorized to make this submission on behalf of the owners and operators of the NO_x budget sources or NO_x budget units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."

(c) Where 326 IAC 10-4 requires a submission to IDEM, OAQ, the NO_x authorized account representative shall submit required information to:

Indiana Department of Environmental Management
Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

(d) Where 326 IAC 10-4 requires a submission to U.S. EPA, the NO_x authorized account representative shall submit required information to:

U.S. Environmental Protection Agency
Clean Air Markets Division
1200 Pennsylvania Avenue, NW
Mail Code 6204N
Washington, DC 20460

F.8 Liability [326 IAC 10-4-4(f)]

The owners and operators of each NO_x budget source shall be liable as follows:

- (a) Any person who knowingly violates any requirement or prohibition of the NO_x budget trading program, a NO_x budget permit, or an exemption under 326 IAC 10-4-3 shall be subject to enforcement pursuant to applicable state or federal law.
- (b) Any person who knowingly makes a false material statement in any record, submission, or report under the NO_x budget trading program shall be subject to criminal enforcement pursuant to the applicable state or federal law.
- (c) No permit revision shall excuse any violation of the requirements of the NO_x budget trading program that occurs prior to the date that the revision takes effect.
- (d) Each NO_x budget source and each NO_x budget unit shall meet the requirements of the NO_x budget trading program.
- (e) Any provision of the NO_x budget trading program that applies to a NO_x budget source, including a provision applicable to the NO_x authorized account representative of a NO_x budget source, shall also apply to the owners and operators of the source and of the NO_x budget units at the source.
- (f) Any provision of the NO_x budget trading program that applies to a NO_x budget unit, including a provision applicable to the NO_x authorized account representative of a NO_x budget unit, shall also apply to the owners and operators of the unit. Except with regard

to the requirements applicable to units with a common stack under 40 CFR 75 and 326 IAC 10-4-12, the owners and operators and the NO_x authorized account representative of one (1) NO_x budget unit shall not be liable for any violation by any other NO_x budget unit of which they are not owners or operators or the NO_x authorized account representative and that is located at a source of which they are not owners or operators or the NO_x authorized account representative.

F.9 Effect on Other Authorities [326 IAC 10-4-4(g)]

No provision of the NO_x budget trading program, a NO_x budget permit application, a NO_x budget permit, or an exemption under 326 IAC 10-4-3 shall be construed as exempting or excluding the owners and operators and, to the extent applicable, the NO_x authorized account representative of a NO_x budget source or NO_x budget unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the CAA.

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT OFFICE OF AIR QUALITY

PART 70 OPERATING PERMIT CERTIFICATION

Source Name: NIPSCO R. M. Schahfer Generating Station
Source Address: 2723 East, 1500 North, Wheatfield, Indiana, 46392
Mailing Address: Arthur E. Smith, 801 E. 86th Avenue, Merrillville, Indiana, 46410
Part 70 Permit No.: T073-6792-00008

This certification shall be included when submitting monitoring, testing reports/results or other documents as required by this permit.

Please check what document is being certified:

- Annual Compliance Certification Letter
- Test Result (specify)
- Report (specify)
- Notification (specify)
- Affidavit (specify)
- Other (specify)

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Signature:

Printed Name:

Title/Position:

Telephone:

Date:

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE BRANCH
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251
Phone: 317-233-0178
Fax: 317-233-6865**

**PART 70 OPERATING PERMIT
EMERGENCY OCCURRENCE REPORT**

Source Name: NIPSCO R. M. Schahfer Generating Station
Source Address: 2723 East, 1500 North, Wheatfield, Indiana, 46392
Mailing Address: Arthur E. Smith, 801 E. 86th Avenue, Merrillville, Indiana, 46410
Part 70 Permit No.: T073-6792-00008

This form consists of 2 pages

Page 1 of 2

This is an emergency as defined in 326 IAC 2-7-1(12)

- C The Permittee must notify the Office of Air Quality (OAQ), within four (4) business hours (1-800-451-6027 or 317-233-0178, ask for Compliance Section); and
- C The Permittee must submit notice in writing or by facsimile within two (2) working days (Facsimile Number: 317-233-6865), and follow the other requirements of 326 IAC 2-7-16.

If any of the following are not applicable, mark N/A

Facility/Equipment/Operation:
Control Equipment:
Permit Condition or Operation Limitation in Permit:
Description of the Emergency:
Describe the cause of the Emergency:

If any of the following are not applicable, mark N/A

Page 2 of 2

Date/Time Emergency started:
Date/Time Emergency was corrected:
Was the facility being properly operated at the time of the emergency? Y N Describe:
Type of Pollutants Emitted: TSP, PM-10, SO ₂ , VOC, NO _x , CO, Pb, other:
Estimated amount of pollutant(s) emitted during emergency:
Describe the steps taken to mitigate the problem:
Describe the corrective actions/response steps taken:
Describe the measures taken to minimize emissions:
If applicable, describe the reasons why continued operation of the facilities are necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw materials of substantial economic value:

Form Completed by:

Title / Position:

Date:

Telephone:

A certification is not required for this report.

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT OFFICE OF AIR QUALITY Compliance Data Section

Part 70 Quarterly Report

Source Name: NIPSCO R. M. Schahfer Generating Station
Source Address: 2723 East, 1500 North, Wheatfield, Indiana, 46392
Mailing Address: Arthur E. Smith, 801 E. 86th Avenue, Merrillville, Indiana, 46410
Part 70 Permit No.: T073-6792-00008
Facility: Turbine 16A
Parameter: Operating Hours
Limit: Less than 2,000 hours per twelve (12) consecutive month period with compliance determined at the end of each month

YEAR:

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

- No deviation occurred in this quarter.
- Deviation/s occurred in this quarter.
Deviation has been reported on:

Submitted by:
Title / Position:
Signature:
Date:
Phone:

Attach a signed certification to complete this report.

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT OFFICE OF AIR QUALITY Compliance Data Section

Part 70 Quarterly Report

Source Name: NIPSCO R. M. Schahfer Generating Station
Source Address: 2723 East, 1500 North, Wheatfield, Indiana, 46392
Mailing Address: Arthur E. Smith, 801 E. 86th Avenue, Merrillville, Indiana, 46410
Part 70 Permit No.: T073-6792-00008
Facility: Turbine 16B
Parameter: Operating Hours
Limit: Less than 2,000 hours per twelve (12) consecutive month period with compliance determined at the end of each month

YEAR:

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

- No deviation occurred in this quarter.
- Deviation/s occurred in this quarter.
Deviation has been reported on:

Submitted by:
Title / Position:
Signature:
Date:
Phone:

Attach a signed certification to complete this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE DATA SECTION**

**PART 70 OPERATING PERMIT
QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT**

Source Name: NIPSCO R. M. Schahfer Generating Station
Source Address: 2723 East, 1500 North, Wheatfield, Indiana, 46392
Mailing Address: Arthur E. Smith, 801 E. 86th Avenue, Merrillville, Indiana, 46410
Part 70 Permit No.: T073-6792-00008

Months: _____ to _____ Year: _____

This report shall be submitted quarterly based on a calendar year. For the purpose of this permit, "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive. Any deviation from the requirements, the date(s) of each deviation, the probable cause of the deviation, and the response steps taken must be reported. A deviation required to be reported pursuant to an applicable requirement that exists independent of the permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. Additional pages may be attached if necessary. If no deviations occurred, please specify in the box marked "No deviations occurred this reporting period".

NO DEVIATIONS OCCURRED THIS REPORTING PERIOD.

THE FOLLOWING DEVIATIONS OCCURRED THIS REPORTING PERIOD

Permit Requirement (specify permit condition #)

Date of Deviation:

Duration of Deviation:

Number of Deviations:

Probable Cause of Deviation:

Response Steps Taken:

Permit Requirement (specify permit condition #)

Date of Deviation:

Duration of Deviation:

Number of Deviations:

Probable Cause of Deviation:

Response Steps Taken:

Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	

Form Completed By:

Title/Position:

Date:

Telephone:

Attach a signed certification to complete this report.

**Indiana Department of Environmental Management
Office of Air Quality**

Technical Support Document (TSD) for a Part 70 Significant
Permit Modification.

Source Description and Location

Source Name:	Northern Indiana Public Service Company (NIPSCO) – R. M. Schahfer Generating Station
Source Location:	2723 East, 1500 North, Wheatfield, Indiana 46392
County:	Jasper
SIC Code:	4911
Operation Permit No.:	T073-6792-00008
Operation Permit Issuance Date:	September 7, 2006
Significant Permit Modification No.:	073-23745-00008
Permit Reviewer:	Gary Freeman

Source Definition

This source consists of an electric utility generating station.

Existing Approvals

The source was issued Part 70 Operating Permit No. T073-6792-00008 on September 7, 2006.

Description of Proposed Modification

This modification consists of modifying the existing Part 70 Operating Permit Conditions to reflect the resolution of the petition that was signed by Northern Indiana Public Service Company (NIPSCO) – R. M. Schahfer Generating Station on January 4, 2008 for an administrative review (Cause 06-A-J-3798) of their Title V Operating Permit No. T073-6792-00008.

Proposed Changes

The changes listed below have been made to Part 70 Operating Permit No. T073-6792-00008 that reflect the resolution for the Cause 06-A-J-3798. Deleted language appears as ~~strikethroughs~~ and new language appears in **bold**:

Change 1. The Table of Contents was updated to reflect the changes in certain Sections as follows:

D.3	FACILITY OPERATION CONDITIONS - Coal-Fired Boilers, Units 17 and 18	45
	D.3.0 NOV Provisions	
D.5	FACILITY OPERATION CONDITIONS - Units 14 & 15 Fuel Handling	57
	Emission Limitations and Standards [326 IAC 2-7-5(1)]	
	D.5.1 Particulate [326 IAC 6-3-2]	
	Compliance Determination Requirements	
	D.5.2 Particulate Control [326 IAC 2-7-6(6)]	
	Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]	

~~D.5.3 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]~~

~~**Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**~~

~~D.5.4 Record Keeping Requirements~~

~~D.6.9 Broken or Failed Bag Detection [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]~~

~~**Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**~~

~~D.6.10 D.6.9 Record Keeping Requirements~~

~~**Compliance Determination Requirements**~~

~~D.7.2 Particulate Control [326 IAC 2-7-6(6)]~~

~~**Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]**~~

~~D.7.3 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]~~

~~D.7.4 Baghouse Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]~~

~~D.7.5 Broken or Failed Bag Detection [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]~~

~~**Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**~~

~~D.7.6 Record Keeping Requirements~~

~~**Compliance Determination Requirements**~~

~~D.8.3 Particulate Control~~

~~**Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]**~~

~~D.8.4 D.8.3 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]~~

~~D.8.5 D.8.4 Baghouse Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]~~

~~D.8.6 D.8.5 Broken or Failed Bag Detection [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]~~

~~**Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**~~

~~D.8.7 D.8.6 Record Keeping Requirements~~

~~**Compliance Determination Requirement**~~

~~D.11.2 Particulate Control [326 IAC 2-7-6(6)]~~

Change 2 Condition B.17 has been updated to reflect changes to the Source Modification Requirements. Condition B.17 was changed as follows:

B.17 Source Modification Requirements [326 IAC 1-2-42][326 IAC 2-7-10.5] [326 IAC 2-2-2] [326 IAC 2-3-2]

(a) The Permittee shall obtain approval as required by 326 IAC 2-7-10.5 from the IDEM, OAQ prior to making any modification to the source. Pursuant to 326 IAC 1-2-42, "Modification" means one (1) or more of the following activities at an existing source:

(1) A physical change or change in the method of operation of any existing emissions unit that increases the potential to emit any regulated pollutant that could be emitted from the emissions unit, or that results in emissions of any regulated pollutant not previously emitted.

~~(2) Construction of one (1) or more new emissions units that have the potential to emit regulated air pollutants.~~

~~(3) Reconstruction of one (1) or more existing emission units that increases the potential to emit of any regulated air pollutant.~~

(b) Any application requesting a source modification shall be submitted to:

Indiana Department of Environmental Management
Permits Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN
Indianapolis, Indiana 46204-2251

Change 3. Condition C.2, Opacity, was changed to update the requirements concerning opacity as follows:

C.2 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations) **and except for Units 17 and 18 and Units 17 and 18 coal processing and conveying equipment**, opacity shall meet the following, unless otherwise stated in this permit:

Change 4. Condition C.12, Maintenance of Continuous Opacity Monitoring Equipment was modified to include plume conditions as indicated:

C.12 Maintenance of Continuous Opacity Monitoring Equipment [326 IAC 2-7-5(3)(A)(iii)]

(d) Whenever a COMS is malfunctioning or is down for maintenance or repairs for a period of twenty-four (24) hours or more and a backup COMS is not online within twenty-four (24) hours of shutdown or malfunction of the primary COMS, the Permittee shall provide a certified opacity reader, who may be an employee of the Permittee or an independent contractor, to self-monitor the emissions from the emission unit stack **when plume conditions allow**.

(1) **When plume conditions allow**, ~~✓~~ visible emission readings shall be performed in accordance with 40 CFR 60, Appendix A, Method 9, for a minimum of five (5) consecutive six (6) minute averaging periods beginning not more than twenty-four (24) hours after the start of the malfunction or down time.

(2) **When plume conditions allow** ~~M~~ method 9 opacity readings shall be repeated for a minimum of five (5) consecutive six (6) minute averaging periods at least twice per day during daylight operations with at least four (4) hours between each set of readings, until such time that a COMS is online.

(3) Method 9 readings may be discontinued once a COMS is online.

(4) Any opacity exceedances determined by Method 9 readings shall be reported with the Quarterly Opacity Exceedances Reports.

- (5) **When plume conditions do not allow Method 9 visible emission readings, Permittee shall keep a record of the period during which such readings could not be taken and the reason why such readings could not be taken.**

Change 5. Condition D.1.2, Startup, Shutdown, and Other Opacity Limits was modified as follows:

D.1.2 Startup, Shutdown, and Other Opacity Limits [326 IAC 5-1-3]

- (a) Pursuant to 326 IAC 5-1-3(e) (Temporary Alternative Opacity Limitations), the following applies:
- (1) When building a new fire in a boiler, opacity may exceed the applicable limitation established in 326 IAC 5-1-2 for a period not to exceed a cumulative total of one (1) hour (ten (10) six (6)-minute averaging periods) during the startup period, or until the flue gas temperature reaches two hundred fifty (250) degrees Fahrenheit at the inlet of the electrostatic precipitator, whichever occurs first, **provided, however, that once every three years opacity may exceed the applicable limitation established in 326 IAC 5-1-2 for a period not to exceed a cumulative total of three (3) hours (thirty (30) six (6) minute averaging periods) during the startup period.**

Change 6. Condition D.1.4, Capacity Limitation was replaced with a substitute Condition D.1.4 as listed below:

D.1.4 Capacity Limitation [326 IAC 6-2-1(g)] [326 IAC 2-7-5]

Pursuant to 326 IAC 6-2-1(g) and Operation Permit 37-05-91-0102, issued on September 14, 1988, unit No. 14 shall not exceed a maximum hourly average of ~~434 megawatts net~~ (468 megawatts gross) until such time as stack testing indicates compliance with the PM and opacity limitations in Condition D.1.1 and Section C - Opacity at a higher level. The Permittee may request a temporary exemption in accordance with 326 IAC 2-1.1-3(g)(3) for stack testing at a higher capacity.

Change 7. Condition D.1.7, Continuous Emissions Monitoring, has been changed as indicated:

D.1.7 Continuous Emissions Monitoring [326 IAC 3-5]

- (a) Pursuant to 326 IAC 3-5 (Continuous Monitoring of Emissions), continuous emission monitoring systems for Unit 14 shall be calibrated, maintained, and operated for measuring ~~opacity~~, SO₂, and either CO₂ or O₂, which meet the performance specifications of 326 IAC 3-5-2.

Change 8. Condition D.1.11, SO₂ Monitoring System Downtime, was modified with a substitute Condition D.1.11 as follows:

D.1.11 SO₂ Monitoring System Downtime [326 IAC 2-7-6] [326 IAC 2-7-5(3)]

- (2) If the CEMS is down for twenty-four (24) hours or more, ~~coal sampling and analysis data shall be collected in accordance with one of the following:~~

(A) **Either fuel sampling and fuel preparation and analysis shall be conducted in accordance with Pursuant to 326 IAC 3-7-2(b) and (c), 326 IAC 3-7-2 (d) and 326 IAC 3-7-2(e) or, alternatively, a portable analyzer, properly calibrated according to the manufacturer specifications (such as manufacturer operating or maintenance manuals), shall be used to monitor SO₂ emissions. To the extent the Permittee elects to conduct fuel sampling:** the Permittee shall collect the coal sample as bunkered; ~~€~~ coal shall be sampled at least three (3) times per day and at least one (1) time per eight (8) hour period unless no coal is bunkered during the preceding eight (8) hour period; ~~and~~ **the minimum sample size shall be five hundred (500) grams. Coal samples shall be prepared and analyzed as specified in 326 IAC 3-7-2(c), 326 IAC 3-7-2(d), and 326 IAC 3-7-2(e).**

or

(B) Pursuant to 326 IAC 3-7-3, **other manual and ~~or~~ other non-ASTM automatic sampling and analysis procedures** may be used upon a demonstration, submitted to the department for approval, that such procedures provide sulfur dioxide emission estimates representative either of estimates based on coal sampling and analysis procedures specified in 326 IAC 3-7-2 or of continuous emissions monitoring.

(b) **To the extent the Permittee elects to conduct fuel sampling to comply with Condition D.1.11(a), Pursuant to 326 IAC 3-7-5(a), the Permittee shall develop a standard operating procedure (SOP) to be followed for sampling, handling, analysis, quality control, quality assurance, and data reporting of any the information collected pursuant to 326 IAC 3-7-2 through 326 IAC 3-7-4 under this Condition D.1.11.** In addition, any revision to the SOP shall be submitted to IDEM, OAQ.

Change 9. Condition D.1.12, Record Keeping Requirements, was changed as follows:

D.1.12 Record Keeping Requirements

(4) All ESP parametric monitoring readings **pursuant to D.1.9.**

(b) To document compliance with SO₂ Conditions D.1.3, D.1.8, and D.1.11, the Permittee shall maintain **the records identified in accordance with** (1) through (3) below. Records shall be complete and sufficient to establish compliance with the SO₂ limits as required in Conditions D.1.3 and D.1.8. The Permittee shall maintain records in accordance with (2) and (3) below during SO₂ CEM system downtime.

(1) All SO₂ continuous emissions monitoring data, pursuant to 326 IAC 3-5-6 and 326 IAC 7-2-1(g).

(2) **Any ~~All~~ fuel sampling and analysis data collected for or portable analyzer data for SO₂ CEM downtime, in accordance with Condition D.1.11.**

(3) Actual fuel usage during each SO₂ CEM downtime **to the extent such data is required by Condition D.1.11 to be obtained.**

(c) To document compliance with Condition D.1.4, the Permittee shall maintain records of the Unit 14 **gross** output, in **gross** MW per hour.

Change 10. Condition D.2.2, Startup, Shutdown, and Other Opacity Limits, was changed by adding a substitute Condition D.2.2 as indicated below:

D.2.2 Startup, Shutdown, and Other **Opacity Limits [326 IAC 5-1-3]**

Pursuant to 326 IAC 5-1-3(e) (Temporary Alternative Opacity Limitations), the following applies:

- (a) When building a new fire in a boiler, opacity may exceed the applicable limitation established in 326 IAC 5-1-2 for a period not to exceed a total of ~~one (1)~~ **two (2)** hours (~~ten (10)~~ **twenty (20)** six (6)- minute averaging periods) during the startup period, or until the flue gas temperature reaches two hundred fifty (250) degrees Fahrenheit at the inlet of the electrostatic precipitation, whichever occurs first.
- (b) When shutting down a boiler, opacity may exceed the applicable limitation established in 326 IAC 5-1-2 for a period not to exceed a total of ~~one (1)~~ **two (2)** hours (~~ten (10)~~ **twenty (20)** six (6)-minute averaging periods) during the shutdown period.
- (c) Operation of the electrostatic precipitator is not required during these times.

Change 11. Condition D.2.7, Continuous Emissions Monitoring was changed as follows.

D.2.7 Continuous Emissions Monitoring [326 IAC 3-5] [326 IAC 12] [40 CFR 60, Subpart D] [326 IAC 2-2]

- (a) Pursuant to 326 IAC 3-5 (Continuous Monitoring of Emissions) and 40 CFR 60.45, continuous emission monitoring systems for Unit 15 shall be calibrated, maintained, and operated for measuring ~~opacity~~, SO₂, NO_x and either O₂ or CO₂, which meet the performance specifications of 326 IAC 3-5-2 and 40 CFR 60.45.

Change 12. Condition D.2.9, Transformer – Rectifier (T-R) Sets, was modified as indicated below:

D.2.9 Transformer-Rectifier (T-R) Sets [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- (a) The ability of the ESP to control particulate emissions shall be monitored once per day, when the unit is in operation, by measuring and recording the number of T-R sets in service and the primary and secondary voltages and the currents of the T-R sets.
- (b) Reasonable response steps shall be taken in accordance with Section C - Response to Excursions and Exceedances whenever **a total of more than four (4)** ~~the percentage of~~ T-R sets **are not** in service ~~falls below ninety percent (90%)~~. T-R set failure resulting in **a response step obligation under the preceding sentence** ~~less than ninety percent (90%) availability~~ is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions and Exceedances shall be considered a deviation from this permit.

Change 13. Condition D.2.10, SO₂ Monitoring System Downtime, was changed as follows:

D.2.10 SO₂ Monitoring System Downtime [326 IAC 2-7-6] [326 IAC 2-7-5(3)]

- (b) If the CEMS is down for twenty-four (24) hours or more, ~~coal sampling and analysis data shall be collected in accordance with one of the following:~~

- (1) **Either fuel sampling and fuel preparation and analysis shall be conducted in accordance with Pursuant to 326 IAC 3-7-2(b) and (c), 326 IAC 3-7-2(d) and 326 IAC 3-7-2(e) or, alternatively, a portable analyzer, properly calibrated according to manufacturer specifications (such as manufacturer operating or maintenance manuals), shall be used to monitor SO₂ emissions the Permittee shall collect the coal sample as bunkered. To the extent the Permittee elects to conduct fuel sampling: the Permittee shall collect the coal sample as bunkered; C coal shall be sampled at least three (3) times per day and at least one (1) time per eight (8) hour period unless no coal is bunkered during the preceding eight (8) hour period; and —M minimum sample size shall be five hundred (500) grams.—Coal samples shall be prepared and analyzed as specified in 326 IAC 3-7-2(c), 326 IAC 3-7-2(d), and 326 IAC 3-7-2(e).**

or

- (2) Pursuant to 326 IAC 3-7-3, **other manual and or other non-ASTM automatic** sampling and analysis procedures may be used upon a demonstration, submitted to the department for approval, that such procedures provide sulfur dioxide emission estimates representative either of estimates based on coal sampling and analysis procedures specified in 326 IAC 3-7-2 or of continuous emissions monitoring.
- (c) **To the extent the Permittee elects to conduct fuel sampling to comply with Condition D.2.10(a), P** pursuant to 326 IAC 3-7-5(a), the Permittee shall develop a standard operating procedure (SOP) to be followed for sampling, handling, analysis, quality control, quality assurance, and data reporting of **any** the information collected pursuant to 326 IAC 3-7-2 through 326 IAC 3-7-4 **under this Condition D.2.10**. In addition, any revision to the SOP shall be submitted to IDEM, OAQ.

Change 14. Condition D.2.11, Record Keeping Requirements, was modified as follows:

D.2.11 Record Keeping Requirements

- (a) To document compliance with Section C - Maintenance of Continuous Opacity Monitoring Equipment, and the particulate matter and opacity requirements in Conditions D.2.1, D.2.2, D.2.6, D.2.7, **and** D.2.9, the Permittee shall maintain records in accordance with (1) through (4) below. Records shall be complete and sufficient to establish compliance with the limits in Conditions D.2.1 and D.2.2.

- (4) All ESP parametric monitoring readings **pursuant to condition D.2.9**.
- (b) To document compliance with the SO₂ requirements in Conditions D.2.1, D.2.3, D.2.7, D.2.8, and D.2.10, the Permittee shall maintain **the records identified in accordance with** (1) through (3) below. Records shall be complete and sufficient to establish compliance with the applicable SO₂ limit(s) as required in Conditions D.2.1, D.2.3, D.2.7, and D.2.8. The Permittee shall maintain records in accordance with (2) and (3) below during SO₂ CEM system downtime.
- (1) All SO₂ continuous emissions monitoring data, pursuant to 326 IAC 3-5-6, 326 IAC 7-2-1(g), and 40 CFR 60.45.
- (2) **Any All-fuel sampling and analysis data collected for or portable analyzer data for SO₂ CEM downtime, in accordance with Condition D.2.10.**

- (3) Actual fuel usage during each SO₂ CEM downtime **to the extent such data is required by Condition D.2.10 to be obtained.**

Change 15. Condition D.3.0 NOV Provisions was deleted from the permit per the Stay Agreement. The subsequent conditions were not renumbered since numbering normally would start with a D.3.1.

~~D.3.0 NOV Provisions~~

~~U.S. EPA has issued a Notice of Violation to this Permittee for allegedly failing to obtain, and comply with, New Source Review ("NSR"), Prevention of Significant Deterioration, and/or NSR for minor source Permits authorizing construction of physical modifications to units and operation of the modified units, as required by provisions set out in the Clean Air Act and 326 IAC 2. Therefore, the permit shield in Section B – Permit Shield does not shield the Permittee from possible enforcement actions initiated by U.S. EPA, IDEM or citizens involving boilers Unit 17 and Unit 18. Compliance with the terms of this permit does not serve as proof of compliance for boilers Unit 17 and Unit 18 or the matters addressed in the NOV. Following resolution of this action, IDEM will reopen this permit, if necessary, to incorporate a compliance schedule or any new applicable requirements. The standard language of Section B – Permit Shield does not shield any activity on which the permit is silent.~~

Change 16 Condition D.3.1, Prevention of Significant Deterioration (PSD) and Construction Limitations, was changed with a substitute Condition D.3.1 as follows:

D.3.1 Prevention of Significant Deterioration (PSD) and Construction Permit Limitations
[40 CFR 52.21] [326 IAC 2-2][326 IAC 6-2-1(g)][326 IAC 7-1.1-2]

- (c) The opacity of the exhaust gases shall not exceed twenty percent (20%) based on a six-minute average except for one six-minute period per hour of opacity not exceeding twenty-seven percent (27%). **(EPA 5-A-80-18 only)**

Change 17. Condition D.3.9, Continuous Emissions Monitoring, was modified as indicated:

D.3.9 Continuous Emissions Monitoring [326 IAC 3-5] [326 IAC 12] [40 CFR 60, Subpart Da]
[326 IAC 2-2] [326 IAC 7-2-1(g)]

-
- (a) Pursuant to 326 IAC 3-5 (Continuous Monitoring of Emissions), 40 CFR 60 Subpart Da, Indiana Air Pollution Control Board Construction Permit PC (37) 1460, issued April 14, 1980, and 326 IAC 2-2, continuous emission monitoring systems for Units 17 and 18 shall be calibrated, maintained, and operated for measuring opacity, SO₂, NO_x, and either CO₂ or O₂, which meet all applicable performance specifications of 326 IAC 3-5-2 and 40 CFR ~~60.47a~~ **60.49a**.
- (b) All continuous emission monitoring systems are subject to monitor system certification requirements pursuant to 326 IAC 3-5-3.
- (c) If the owner or operator has installed a nitrogen oxides (NO_x) emission rate continuous monitoring system (CEMS) to meet the requirements of 40 CFR 75 and is continuing to meet the ongoing requirements of 40 CFR 75, that CEMS may be used to meet the requirements of 40 CFR ~~60.47a~~ **60.49a**, except that the owner or operator shall also meet the requirements of 40 CFR ~~60.49a~~ 60.51a. Data reported to meet the requirements of 40 CFR ~~60.49a~~ 60.51a shall not include data substituted using the missing data procedures in subpart D of 40 CFR 75, nor shall the data have been bias adjusted according to the procedures of 40 CFR 75. [40 CFR ~~60.47a~~ **60.49a(c)(2)**]

- (d) The continuous monitoring systems under 40 CFR ~~60.47a~~ **60.49a**(b), (c), and (d) (SO₂, NO_x, and O₂ or CO₂) are operated and data recorded during all periods of operation of the affected facility including periods of startup, shutdown, malfunction or emergency conditions, except for continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments. [40 CFR ~~60.47a~~ **60.49a**(e)]
- (e) The owner or operator shall obtain emission data for at least 18 hours in at least 22 out of 30 successive boiler operating days. If this minimum data requirement cannot be met with a continuous monitoring system, the owner or operator shall supplement emission data with other monitoring systems approved by the Administrator or the reference methods and procedures as described in 40 CFR ~~60.47~~ **60.49a**(h). [40 CFR ~~60.47~~ **60.49a**(f)]

Change 18. Condition D.3.10, Sulfur Dioxide Emissions and Sulfur Content, was changed as follows:

D.3.10 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3] ~~[326 IAC 7-2]~~ ~~[326 IAC 7-1.1-2]~~

~~Pursuant to 326 IAC 7-2-1(a) and (c), †~~ The Permittee shall demonstrate that the sulfur dioxide emissions do not exceed the limits in Condition D.3.1(d), as established in PSD Approval to Construct EPA-5-A-80-18, issued on April 3, 1980, and Construction Permit PC (37) 1460, issued April 14, 1980, using a thirty (30) day rolling ~~weighted arithmetic average~~ **as is required under D.3.8(g).**

Change 19. Condition D.3.11, Transformer – Rectifier (T-R) Sets, was modified as listed below:

D.3.11 Transformer-Rectifier (T-R) Sets [326 IAC 2-7-6(1)] ~~[326 IAC 2-7-5(1)]~~

- (b) Reasonable response steps shall be taken in accordance with Section C - Response to Excursions and Exceedances whenever **a total of more than three (3) T-R sets at Unit 17 or a total of more than two (2)** ~~the percentage of T-R sets at Unit 18 are not in service falls below ninety percent (90%).~~ T-R set failure resulting in **a response step obligation under the preceding sentence** ~~less than ninety percent (90%) availability~~ is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions and Exceedances shall be considered a deviation from this permit.

Change 20. Condition D.3.13, Record Keeping Requirements, was changed as follows:

D.3.13 Record Keeping Requirements

- (4) All ESP parametric monitoring readings **pursuant to condition D.3.11.**
- (b) To document compliance with SO₂ Conditions D.3.1(d), D.3.2(b), D.3.8, D.3.9, D.3.10, and D.3.12, the Permittee shall maintain records in accordance with (1) ~~and through (3)~~ **(2)** below. Records shall be complete and sufficient to establish compliance with the SO₂ limit(s) as required in Conditions D.3.1(d), D.3.2(b), D.3.8, D.3.9, D.3.10, and D.3.12. The Permittee shall maintain records in accordance with (2) ~~and (3)~~ below during SO₂ CEM system downtime.

~~(3) Actual fuel usage during each SO₂ CEM downtime.~~

Change 21. Condition D.4.2, New Source Performance Standard (NSPS) was changed with a substitute Condition D.4.2 as follows.

D.4.2 New Source Performance Standard (NSPS) [326 IAC 12] [40 CFR 60, Subpart GG]

F = NO_x emission allowance for fuel-bound nitrogen as defined in paragraph (a)(3) of 40 CFR 60.332.

~~Water injection shall be used to control NO_x emissions to the level required by equation stated above.~~

Change 22. Condition D.4.5, NO_x Control, was changed as follows:

D.4.5 NO_x Control

~~In order to comply with Conditions D.4.1 and D.4.2, the water injection systems which are used to control the NO_x emissions from turbines 16A and 16B shall be in operation and control emissions from turbines 16A and 16B at all times that these units are in operation.~~

Change 23. Condition D.4.8, Record Keeping Requirements, was changed as indicated below:

D.4.8 Record Keeping Requirements

- (i) All continuous monitoring system data of fuel consumption and the ratio of water to fuel being fired; or
- (i) All continuous emission monitoring system (CEMS) data of NO_x and O₂ **whenever Permittee elects to use CEMS to monitor NO_x and O₂.**

Change 24. Condition D.5.1, Particulate, was changed with a substitute Conditions D.5.1 as follows:

D.5.1 Particulate [326 IAC 6-3-2]

~~Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), for the Unit 14 and 15 coal storage and handling systems other than the coal storage piles, at a throughput rate greater than 200 tons per hour the concentration of particulate in the discharge gases to the atmosphere shall be less than 0.10 pounds per one thousand (1,000) pounds of gases allowable particulate emissions for the coal handling operations shall be calculated as follows:~~

- (a) **Particulate shall not be emitted in excess of the amount shown in the table in 326 IAC 6-3-2(e). The allowable rate of emission shall be based on the process weight rate for the process.**
- (b) **Interpolation of the data in the table in 326 IAC 6-3-2(e) for process weight rates up to sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:**

**$E = 4.10 P^{0.67}$ where E = rate of emission in pounds per hour and
P = process weight rate in tons per hour.**

- (c) **Interpolation and extrapolation of the data in the table in 326 IAC 6-3-2(e) for process weight rates in excess of sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:**

$$E = 55.0 P^{0.11} - 40 \quad \text{where } E = \text{rate of emission in pounds per hour; and} \\ P = \text{process weight rate in tons per hour.}$$

- (d) **When the process weight rate exceeds two hundred (200) tons per hour, the allowable emission may exceed that shown in the table in 326 IAC 6-3-2(e), provided the concentration of particulate in the discharge gases to the atmosphere is less than one-tenth (0.10) pound per one thousand (1,000) pounds of gases.**

Change 25. Conditions D.5.2 through D.5.4 were deleted from the permit as per the Stay Agreement:

Compliance Determination Requirements

~~D.5.2 Particulate Control [326 IAC 2-7-6(6)]~~

~~Except as otherwise provided by statute or rule or in this permit, in order to comply with Condition D.5.1, the dust collectors and the wet suppression systems shall be in operation and control emissions at all times the associated processes are in operation.~~

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

~~D.5.3 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]~~

- ~~(a) Visible emission notations of the rail car unloading station openings shall be performed once per day during normal daylight operations when unloading coal. A trained employee shall record whether emissions are normal or abnormal.~~
- ~~(b) Visible emission notations of the coal transfer exhaust points shall be performed once per day during normal daylight operations when transferring coal. A trained employee shall record whether emissions are normal or abnormal.~~
- ~~(c) Visible emission notations of the coal crusher exhaust shall be performed once per day during normal daylight operations when the crusher is in operation. A trained employee shall record whether emissions are normal or abnormal.~~
- ~~(d) If abnormal emissions of dust are observed from the coal unloading station openings, the Permittee shall take reasonable response steps in accordance with Section C – Response to Excursions and Exceedances. Observation of abnormal visible emissions that do not violate 326 IAC 6-4 (Fugitive Dust Emissions) or an applicable opacity limit is not a deviation from this permit. Failure to take response steps in accordance with Section C – Response to Excursions and Exceedances, shall be considered a deviation from this permit.~~
- ~~(e) If abnormal emissions are observed at a transfer point exhaust or crusher exhaust, the Permittee shall take reasonable response steps in accordance with Section C – Response to Excursions and Exceedances. Observation of abnormal emissions that do not violate 326 IAC 6-4 (Fugitive Dust Emissions) or an applicable opacity limit is not a deviation from this permit. Failure to take response steps in accordance with Section C – Response to Excursions and Exceedances, shall be considered a deviation from this permit.~~
- ~~(f) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation.~~
- ~~(g) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.~~

- ~~(h) — A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.~~

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.5.4 Record Keeping Requirements

- ~~(a) — To document compliance with Condition D.5.3, the Permittee shall maintain records of the visible emission notations of the coal unloading station openings, the coal transfer exhaust points, and the coal crusher exhaust.~~
- ~~(b) — All records shall be maintained in accordance with Section C – General Record Keeping Requirements, of this permit.~~

Change 26. Condition D.6.1, Prevention of Significant Deterioration (PSD) has been change with the following substitute Condition D.6.1:

D.6.1 Prevention of Significant Deterioration (PSD) and Construction Permit Limitations [40 CFR 52.21] [326 IAC 2-2]

~~Pursuant to Approval to Construct EPA-5-A-80-18, issued on April 3, 1980, and Indiana Air Pollution Control Board Construction Permit PC (37) 1460, issued April 14, 1980:~~

~~***~~

- ~~(d) — Emissions from all conveyor systems shall be controlled by bag type dust collectors at applicable transfer houses. (in PC (37) 1460 only)~~
- ~~(e)(d) Particulate emissions from the crusher house, conveyor room and reclaim tunnels shall be controlled to 99 percent. (in EPA 5-A-80-18 only)~~
- ~~(f) — The coal piles shall be sprayed with a surfactant on a regular basis as needed to minimize fugitive dust. Dust control by any other method must be approved by IDEM, OAQ. (in PC (37) 1460 only)~~
- ~~(g)(e) Fugitive emissions from the coal piles shall be minimized by compaction and other appropriate measures (surfactant spray etc.). (in EPA 5-A-80-18 only)~~

Change 27. Condition D.6.3, Particulate has been changed as indicated below:

D.6.3 Particulate [326 IAC 6-3-2]

~~Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), for the fuel storage and handling systems for Units 17 and 18 other than the coal storage piles, at a throughput rate greater than 200 tons per hour, the concentration of particulate in the discharge gases to the atmosphere shall be less than 0.10 pounds per one thousand (1,000) pounds of gases allowable particulate emissions for the coal handling operations shall be calculated as follows:.~~

- (a) Particulate shall not be emitted in excess of the amount shown in the table in 326 IAC 6-3-2(e). The allowable rate of emission shall be based on the process weight rate for the process.**
- (b) Interpolation of the data in the table in 326 IAC 6-3-2(e) for process weight rates up to sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:**

$$E = 4.10 P^{0.67} \quad \text{where } E = \text{rate of emission in pounds per hour and} \\ P = \text{process weight rate in tons per hour.}$$

- (c) **Interpolation and extrapolation of the data in the table in 326 IAC 6-3-2(e) for process weight rates in excess of sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:**

$$E = 55.0 P^{0.11} - 40 \quad \text{where } E = \text{rate of emission in pounds per hour; and} \\ P = \text{process weight rate in tons per hour.}$$

- (d) **When the process weight rate exceeds two hundred (200) tons per hour, the allowable emission may exceed that shown in the table in 326 IAC 6-3-2(e), provided the concentration of particulate in the discharge gases to the atmosphere is less than one-tenth (0.10) pound per one thousand (1,000) pounds of gases.**

Change 28. Condition D.6.5, Particulate Control, has been changed as follows:

D.6.5 Particulate Control [326 IAC 2-7-6(6)]

- (a) ~~Except as otherwise provided by statute or rule or in this permit, in order to comply with Conditions D.6.1 and D.6.3, the baghouses, vent filters, and dust collectors for particulate control shall be in operation and control emissions at all times the associated crusher or conveyor is in operation.~~
- (b) In the event that bag failure is observed in a multi-compartment baghouse, if operations will continue for ten (10) days or more after the failure is observed before the failed **bag units** will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed **bag units** will be repaired or replaced. The notification shall also include ~~the status of the applicable compliance monitoring parameters with respect to normal,~~ and the results of any response actions taken up to the time of notification.

Change 29. Condition D.6.9 was deleted from the permit as per the Stay Agreement and the subsequent Condition was renumbered:

~~D.6.9 Broken or Failed Bag Detection [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]~~

- (a) ~~For a single compartment baghouse controlling emissions from a process operated continuously, a failed unit and the associated process shall be shut down immediately until the failed unit has been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B – Emergency Provisions).~~
- (b) ~~For a single compartment baghouse controlling emissions from a batch process, the feed to the process shall be shut down immediately until the failed unit has been repaired or replaced. The emissions unit shall be shut down no later than the completion of the processing of the material in the emission units. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B – Emergency Provisions).~~

~~Bag failure can be indicated by a significant drop in the baghouse's pressure reading with abnormal visible emissions, by an opacity violation, or by other means such as gas temperature, flow rate, air infiltration, leaks, dust traces or tribeflows.~~

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

~~D.6.10~~ D.6.9 Record Keeping Requirements

Change 30. Conditions D.7.2 through D.7.6 were deleted from the permit per the Stay Agreement:

Compliance Determination Requirements

~~D.7.2 Particulate Control [326 IAC 2-7-6(6)]~~

- ~~(a) Except as otherwise provided by statute or rule or in this permit, the baghouses for PM control shall be in operation and control emissions at all times the associated limestone transfer points are in operation.~~
- ~~(b) In the event that bag failure is observed in a multi-compartment baghouse, if operations will continue for ten (10) days or more after the failure is observed before the failed units will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed units will be repaired or replaced. The notification shall also include the status of the applicable compliance monitoring parameters with respect to normal, and the results of any response actions taken up to the time of notification.~~

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

~~D.7.3 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]~~

- ~~(a) Visible emission notations of the limestone unloading station exhausts shall be performed at least once per week during normal daylight operations when limestone is being unloaded. A trained employee shall record whether emissions are normal or abnormal.~~
- ~~(b) If abnormal emissions are observed at any baghouse exhaust, the Permittee shall take reasonable response steps in accordance with Section C – Response to Excursions and Exceedances. Observation of abnormal visible emissions that do not violate 326 IAC 6-4 (Fugitive Dust Emissions) or an applicable opacity limit is not a deviation from this permit. Failure to take response steps in accordance with Section C – Response to Excursions and Exceedances, shall be considered a deviation from this permit.~~
- ~~(c) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut-down time.~~
- ~~(d) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.~~
- ~~(e) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.~~

~~D.7.4 Baghouse Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]~~

- ~~(a) The Permittee shall record the pressure drop across each baghouse used in conjunction with the limestone handling at least once per week when corresponding unloading station is in operation. When for any one reading, the pressure drop across the baghouse is outside the normal range of 2.0 and 8.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps in accordance with Section C – Response to Excursions and Exceedances. A pressure drop reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps in accordance with Section C – Response to Excursions and Exceedances, shall be considered a deviation from this permit.~~
- ~~(b) The instrument used for determining the pressure shall comply with Section C – Instrument Specifications, and shall be calibrated in accordance with the manufacturer's specifications. The specifications shall be available on site with the Preventive Maintenance Plan.~~

~~D.7.5 Broken or Failed Bag Detection [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]~~

- ~~(a) For a single compartment baghouse controlling emissions from a process operated continuously a failed unit and the associated process shall be shut down immediately until the failed unit has been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B – Emergency Provisions).~~
- ~~(b) For a single compartment baghouse controlling emissions from a batch process, the feed to the process shall be shut down immediately until the failed unit has been repaired or replaced. The emissions unit shall be shut down no later than the completion of the processing of the material in the emission units. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B – Emergency Provisions).~~

~~Bag failure can be indicated by a significant drop in the baghouse's pressure reading with abnormal visible emissions, by an opacity violation, or by other means such as gas temperature, flow rate, air infiltration, leaks, dust traces or triboflows.~~

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

~~D.7.6 Record Keeping Requirements~~

- ~~(a) To document compliance with Condition D.7.3, the Permittee shall maintain records of the visible emission notations of the limestone unloading station exhausts.~~
- ~~(b) To document compliance with Condition D.7.4, the Permittee shall maintain records of the pressure drop across each baghouse.~~
- ~~(c) All records shall be maintained in accordance with Section C – General Record Keeping Requirements, of this permit.~~

Change 31. Condition D.8.1, Prevention of Significant Deterioration (PSD) has been modified as follows:

~~D.8.1 Prevention of Significant Deterioration (PSD) and Construction Permit Limitations
[40 CFR 52.21] [326 IAC 2-2]~~

~~For the fly ash from Units 17 and 18, pursuant to Approval to Construct EPA-5-A-80-18, issued on April 3, 1980, and Indiana Air Pollution Control Board Construction Permit PC (37) 1460, issued April 14, 1980:~~

- ~~(a) The dry fly ash from the ESP's shall be pneumatically conveyed to fly ash storage silos equipped with bag-type dust collectors.~~
- ~~(b) Fly ash handling, storage and transport shall be controlled by wetting and/or by installation of baghouses. Trucks utilized for dry or unconditioned ash disposal shall be covered. (in EPA-5-A-80-18 only)~~
- ~~(c) The Permittee shall minimize cargo material being tracked onto public roads by haul trucks, as follows:~~
- ~~(1) The Permittee shall inspect all outgoing trucks hauling ash to ensure proper tarping or closure and to ensure that excess ash material observed on top of the tarp or on top of the truck is removed before the trucks exit the facility.~~
- ~~(2) The Permittee shall operate a wheel wash facility to clean all outgoing haul trucks, weather conditions permitting.~~

~~(3) The Permittee shall clean the roadway near the western gate when the pavement surface is covered with excessive visible dust, weather conditions permitting.~~

Change 32. Condition D.8.3 was deleted from the permit and subsequent Conditions were renumbered as follows:

Compliance Determination Requirements

~~D.8.3 Particulate Control [326 IAC 2-7-6(6)]~~

- ~~(a) Except as otherwise provided by statute or rule or in this permit, the cyclone separators, silo collector bag filters, and silo bin vent filters shall be in operation and control emissions at all times that fly ash is being transferred to the associated storage silo; and the telescoping chute unloaders with a vacuum line, or the water spray, shall be in operation and control emissions at all times that the associated truck loading system is in operation.~~
- ~~(b) Pursuant to EPA-5-A-80-18, issued on April 3, 1980, fly ash handling, storage and transport shall be controlled by wetting and or by installation of dust collectors.~~

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

~~D.8.4 D.8.3 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]~~

~~D.8.5 D.8.4 Baghouse Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]~~

~~D.8.6 D.8.5 Broken or Failed Bag Detection [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]~~

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

~~D.8.7 D.8.6 Record Keeping Requirements~~

Change 33. Condition D.8.4, Visible Emissions Notations, has been changed as indicated below:

~~D.8.4 D.8.3 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]~~

- (c) Visible emission notations of the nozzle of each telescoping chute shall be performed at least once per day during normal daylight operations when unloading ash through the chute. A trained employee shall record whether emissions are normal or abnormal.
- ~~(d) Visible emission notations of the onsite roadway used by the ash haul trucks shall be performed at least once per day during normal daylight operations when in use by a haul truck. A trained employee shall record whether emissions are normal or abnormal.~~
- ~~(e) If visible emissions are observed crossing the property line or boundaries of the property, right-of-way, or easement on which the source is located, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions and Exceedances.~~
- ~~(f)(d)~~ If abnormal visible emissions of ash are observed from the ash silo unloading station openings, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions and Exceedances. Observation of abnormal visible emissions that do not violate 326 IAC 6-4 (Fugitive Dust Emissions) or an applicable

opacity limit is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions and Exceedances, shall be considered a deviation from this permit.

- ~~(g)~~(e) If abnormal emissions are observed at any bag filter exhaust, ~~or from the onsite roadways used by the ash haul trucks,~~ the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions and Exceedances. Observation of abnormal emissions that do not violate 326 IAC 6-4 (Fugitive Dust Emissions) or an applicable opacity limit is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions and Exceedances, shall be considered a deviation from this permit.
- ~~(h)~~(f) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.
- ~~(i)~~(g) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- ~~(j)~~(h) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.

Change 34. Condition ~~D.8.7~~ D.8.6, Record Keeping Requirements, was changed as follows:

~~D.8.7~~ D.8.6 Record Keeping Requirements

- ~~(a)~~ To document compliance with Condition ~~D.8.1(c)(1),~~ the Permittee shall maintain records of all inspections of outgoing ash haul trucks.
- ~~(b)~~(a) To document compliance with Condition ~~D.8.4~~ D.8.3, the Permittee shall maintain records of the visible emission notations of the **Unit 17 and 18** ash silo unloading station openings, and the **Unit 17 and 18** baghouse stack exhaust.
- ~~(c)~~(b) To document compliance with Condition ~~D.8.5~~ D.8.4, the Permittee shall maintain records of the pressure drop across each bag filter.
- ~~(d)~~(c) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

Change 35. Condition D.9.1, Prevention of Significant Deterioration (PSD) and Construction Permit Limitations has been changed with a substitute Conditions D.9.1:

D.9.1 Prevention of Significant Deterioration (PSD) and Construction Permit Limitations
[40 CFR 52.21] [326 IAC 2-2]

Pursuant to Approval to Construct EPA-5-A-80-18, issued on April 3, 1980, and Indiana Air Pollution Control Board Construction Permit PC (37) 1460, issued April 14, 1980, **with respect to Units 17 and 18:**

- (a) The bottom ash shall be sluiced to waste disposal ponds. (in PC (37) 1460 only)
- (b) Bottom ash handling, storage and transport shall be controlled by wetting and/or by installation of baghouses. ~~Trucks utilized for ash disposal shall be covered.~~
(in EPA-5-A-80-18 only)

Change 36. Condition D.9.3, Visible Emission Notations has been modified as indicated below:

D.9.3 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- (a) Visible emission notations of the ~~Waste Disposal Area, the Material Storage Runoff Pond area,~~ and any active onsite landfill area(s) shall be performed at least once per day during normal daylight operations. **Any storage pond in the Waste Disposal Area or the Material Storage Runoff Pond area that contains either bottom ash and/or FGD sludge shall be observed once per week to determine if sufficient water is present in the pond to cover or saturate bottom ash and/or sludge deposited in the pond. During any period when there is not sufficient water in the pond to cover or saturate bottom ash and/or sludge present in the pond, visible emission notations of such storage pond area(s) shall be performed at least once per day during normal daylight operations. When daily visible emission notations are made, a A trained employee shall record whether emissions are normal or abnormal.**

Change 37. Condition D.9.4, Record Keeping Requirements, has been changed as follows:

D.9.4 Record Keeping Requirements

- (a) To document compliance with Condition D.9.3, the Permittee shall maintain records of **visible observations, and any resulting** visible emission notations of the Waste Disposal Area, **and** the Material Storage Runoff Pond area, and **records of visible emission notations relating to** any active onsite landfill area(s).
- (b) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

Change 38. Condition D.11.2 was deleted from the permit as per the Stay Agreement:

~~**Compliance Determination Requirement**~~

~~D.11.2 Particulate Control [326 IAC 2-7-6(6)]~~

~~Except as otherwise provided by statute or rule or in this permit, the particulate control shall be in operation and control emissions from the grinding and machining operations and the shot blasters at all times that the associated process is in operation.~~

Other Changes

Upon further review IDEM, OAQ has made the following changes to the Title V permit. (deleted language appears as ~~strikeout~~ and the new language **bolded**):

Change 1. Since the issue of the Part 70 Operating Permit 073-6792-00008, Condition A.1 was updated to reflect the new procedure IDEM implemented and will no longer list the name or title of the Responsible Official (R.O.) in the permit document. Condition A.1 was changed as follows:

A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)] [326 IAC 2-7-1(22)]

The Permittee owns and operates a stationary electric utility generating station.

~~Responsible Official: Vice President, Electric Generation~~
Source Address: 2723 East, 1500 North, Wheatfield, Indiana, 46392
Mailing Address: Arthur E. Smith, 801 E. 86th Avenue, Merrillville, Indiana, 46410
Telephone Number: 219-647-5252

SIC Code: 4911
County Location: Jasper
County Status: Attainment for all criteria pollutants
Source Status: Part 70 Permit Program
Major Source, under PSD Rules;
Major Source, Section 112 of the Clean Air Act
1 of 28 Source Categories

Change 2. All occurrences of IDEM mailing address have been revised to include a mail code (MC) as follows:

Compliance Branch:	MC 61-53 IGCN 1003
Permits Branch:	MC 61-53 IGCN 1003
Technical Support and Modeling	MC 61-50-IGCN 1003

Conclusion and Recommendation

The source shall be subject to the conditions of the attached proposed Part 70 Significant Permit Modification No. 073-23745-00008. The staff recommends to the Commissioner that this Part 70 Significant Permit Modification be approved.