



Mitchell E. Daniels, Jr.  
Governor

Thomas W. Easterly  
Commissioner

100 North Senate Avenue  
Indianapolis, Indiana 46204  
(317) 232-8603  
(800) 451-6027  
www.IN.gov/idem

TO: Interested Parties / Applicant  
DATE: July 27, 2007  
RE: Central Indiana Ethanol, LLC / 053-21057-00062  
FROM: Nisha Sizemore  
Chief, Permits Branch  
Office of Air Quality

### Notice of Decision: Approval - Effective Immediately

Please be advised that on behalf of the Commissioner of the Department of Environmental Management, I have issued a decision regarding the enclosed matter. Pursuant to IC 13-15-5-3, this permit is effective immediately, unless a petition for stay of effectiveness is filed and granted according to IC 13-15-6-3, and may be revoked or modified in accordance with the provisions of IC 13-15-7-1.

If you wish to challenge this decision, IC 4-21.5-3 and IC 13-15-6-1 require that you file a petition for administrative review. This petition may include a request for stay of effectiveness and must be submitted to the Office of Environmental Adjudication, 100 North Senate Avenue, Government Center North, Room 1049, Indianapolis, IN 46204, **within eighteen (18) calendar days of the mailing of this notice**. The filing of a petition for administrative review is complete on the earliest of the following dates that apply to the filing:

- (1) the date the document is delivered to the Office of Environmental Adjudication (OEA);
- (2) the date of the postmark on the envelope containing the document, if the document is mailed to OEA by U.S. mail; or
- (3) The date on which the document is deposited with a private carrier, as shown by receipt issued by the carrier, if the document is sent to the OEA by private carrier.

The petition must include facts demonstrating that you are either the applicant, a person aggrieved or adversely affected by the decision or otherwise entitled to review by law. Please identify the permit, decision, or other order for which you seek review by permit number, name of the applicant, location, date of this notice and all of the following:

- (1) the name and address of the person making the request;
- (2) the interest of the person making the request;
- (3) identification of any persons represented by the person making the request;
- (4) the reasons, with particularity, for the request;
- (5) the issues, with particularity, proposed for considerations at any hearing; and
- (6) identification of the terms and conditions which, in the judgment of the person making the request, would be appropriate in the case in question to satisfy the requirements of the law governing documents of the type issued by the Commissioner.

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178. Callers from within Indiana may call toll-free at 1-800-451-6027, ext. 3-0178.

Enclosures  
FNPER.dot 03/23/06



Mitchell E. Daniels, Jr.  
*Governor*

Thomas W. Easterly  
*Commissioner*

100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251  
(317) 232-8603  
(800) 451-6027  
[www.IN.gov/idem](http://www.IN.gov/idem)

July 27, 2007

Mr. Mitch Miller  
Central Indiana Ethanol, LLC  
2955 West Delphi Pike  
Marion, Indiana 46952

Re: 053-24415-00062  
Second Significant Revision to  
FESOP No. 053-21057-00062

Dear Mr. Miller:

Central Indiana Ethanol, LLC, was issued a Federally Enforceable State Operating Permit (FESOP) on August 4, 2005, for the construction and operation of an ethanol production plant. A letter requesting changes to this permit was received on March 8, 2007. Pursuant to the provisions of 326 IAC 2-8-11(f), a significant permit revision to this permit is hereby approved as described in the attached Technical Support Document.

This source has not completed the construction of this new plant and has requested to modify the plant design permitted in FESOP No. 053-21057-00062, issued on August 4, 2005. However, this revision will not increase the ethanol production rate at this plant. The revision consists of adding several insignificant activities: decreasing the permitted capacity of the Corn Bins #1 and #2 (EU004 and EU005); increasing the permitted denatured ethanol loadout rate from 63,000 kgal per year to 64,900 kgal per year; allow for the ability to make blended ethanol up to 30% gasoline; adding a denaturant limit of 4,900 kgal per year; and adding a denatured ethanol non-dedicated railcar loadout rate limit of 2,500 kgal per year. The revision also includes revising the truck traffic road emissions to account for an increased silt load factor in the winter months, and providing emissions estimates for insignificant combustion activities.

The following conditions are applicable to the proposed project:

1. General Construction Conditions  
The data and information supplied with the application shall be considered part of this source modification approval. Prior to any proposed change in construction which may affect the potential to emit (PTE) of the proposed project, the change must be approved by the Office of Air Quality (OAQ).
2. This approval to construct does not relieve the Permittee of the responsibility to comply with the provisions of the Indiana Environmental Management Law (IC 13-11 through 13-20; 13-22 through 13-25; and 13-30), the Air Pollution Control Law (IC 13-17) and the rules promulgated thereunder, as well as other applicable local, state, and federal requirements.
3. Effective Date of the Permit  
Pursuant to IC 13-15-5-3, this approval becomes effective upon its issuance.
4. Pursuant to 326 IAC 2-1.1-9 (Revocation), the Commissioner may revoke this approval if construction is not commenced within eighteen (18) months after receipt of this approval or if construction is suspended for a continuous period of one (1) year or more.
5. All requirements and conditions of this approval shall remain in effect unless modified in a manner consistent with procedures established pursuant to 326 IAC 2.

Pursuant to 326 IAC 2-8-11.1, this permit shall be revised by incorporating the significant permit revision into the permit. All other conditions of the permit shall remain unchanged and in effect. Attached is a copy of the revised permit.

Pursuant to Contract No. A305-5-65, IDEM, OAQ has assigned the processing of this application to Eastern Research Group, Inc., (ERG). Therefore, questions should be directed to Jason Renzaglia, ERG, 1600 Perimeter Park Drive, Morrisville, North Carolina 27560, or call (919) 468-7893 to speak directly to Mr. Renzaglia. Questions may also be directed to Duane Van Laningham at IDEM, OAQ, 100 North Senate Avenue, MC 61-53 IGCN 1003, Indianapolis, Indiana, 46204-2251, or call (800) 451-6027 and ask for Duane Van Laningham or extension 3-6878, or dial (317) 233-6878.

Sincerely,

*Original document signed by*

Nisha Sizemore, Chief  
Permits Branch  
Office of Air Quality

#### Attachments

ERG/JR

cc: File – Grant County  
Grant County Health Department  
Air Compliance Section Inspector – Marc Goldman  
Compliance Data Section  
Administrative and Development  
Technical Support and Modeling - Michele Boner  
Billing, Licensing, and Training Section - Dan Stamatkin



Mitchell E. Daniels, Jr.  
Governor

Thomas W. Easterly  
Commissioner

100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251  
(317) 232-8603  
(800) 451-6027  
www.IN.gov/idem

## FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP) OFFICE OF AIR QUALITY

**Central Indiana Ethanol, LLC  
2955 W. Delphi Pike  
Marion, Indiana 46952**

(herein known as the Permittee) is hereby authorized to operate subject to the conditions contained herein, the source described in Section A (Source Summary) of this permit.

**The Permittee must comply with all conditions of this permit. Noncompliance with any provision of this permit is grounds for enforcement action; permit termination, revocation and reissuance, or modification; and denial of a permit renewal application. It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. An emergency does constitute an affirmative defense in an enforcement action provided the Permittee complies with the applicable requirements set forth in Section B, Emergency Provisions.**

This permit is issued in accordance with 326 IAC 2 and 40 CFR Part 70 Appendix A and contains the conditions and provisions specified in 326 IAC 2-8 as required by 42 U.S.C. 7401, et. seq. (Clean Air Act as amended by the 1990 Clean Air Act Amendments), 40 CFR Part 70.6, IC 13-15 and IC 13-17. This permit also addresses new source review requirements and is intended to fulfill the new source review procedures and permit revision requirements pursuant to 326 IAC 2-8-11.1, applicable to those conditions.

Indiana statutes from IC 13 and rules from 326 IAC, quoted in conditions in this permit, are those applicable at the time the permit was issued. The issuance or possession of this permit shall not alone constitute a defense against an alleged violation of any law, regulation or standard, except for the requirement to obtain a FESOP under 326 IAC 2-8.

Operation Permit No.: F053-21057-00062	
Issued by: Paul Dubenetzky, Branch Chief Office of Air Quality	Issuance Date: August 4, 2005 Expiration Date: August 4, 2010

First Significant Permit Revision No.: 053-22564-00062, issued July 20, 2006

Second Significant Permit Revision No.: 053-24415-00062	Pages Affected: Entire permit
Issued by: <i>Original document signed by</i> Nisha Sizemore, Chief Permits Branch Office of Air Quality	Issuance Date: July 27, 2007 Expiration Date: August 4, 2010

## TABLE OF CONTENTS

<b>SECTION A</b>	<b>SOURCE SUMMARY</b> .....	8
A.1	General Information [326 IAC 2-8-3(b)]	
A.2	Emission Units and Pollution Control Equipment Summary [326 IAC 2-8-3(c)(3)]	
A.3	Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-8-3(c)(3)(I)]	
A.4	FESOP Applicability [326 IAC 2-8-2]	
<b>SECTION B</b>	<b>GENERAL CONDITIONS</b> .....	12
B.1	Definitions [326 IAC 2-8-1]	
B.2	Permit Term [326 IAC 2-8-4(2)][326 IAC 2-1.1-9.5]	
B.3	Terms of Conditions [326 IAC 2-1.1-9.5]	
B.4	Enforceability [326 IAC 2-8-6]	
B.5	Severability [326 IAC 2-8-4(4)]	
B.6	Property Rights or Exclusive Privilege [326 IAC 2-8-4(5)(D)]	
B.7	Duty to Provide Information[326 IAC 2-8-4(5)(E)]	
B.8	Compliance Order Issuance [326 IAC 2-8-5(b)]	
B.8	Certification [326 IAC 2-8-3(d)] [326 IAC 2-8-4(3)(C)(i)] [326 IAC 2-8-5(1)]	
B.10	Annual Compliance Certification [326 IAC 2-8-5(a)(1)]	
B.11	Preventive Maintenance Plan [326 IAC 1-6-3][326 IAC 2-8-4(9)][326 IAC 2-8-5(a)(1)]	
B.12	Emergency Provisions [326 IAC 2-8-12]	
B.13	Prior Permits Superseded [326 IAC 2-1.1-9.5]	
B.14	Termination of Right to Operate [326 IAC 2-8-9][326 IAC 2-8-3(h)]	
B.15	Deviations from Permit Requirements and Conditions [326 IAC 2-8-4(3)(C)(ii)]	
B.16	Permit Modification, Reopening, Revocation and Reissuance, or Termination [326 IAC 2-8-4(5)(C)][326 IAC 2-8-7(a)][326 IAC 2-8-8]	
B.17	Permit Renewal [326 IAC 2-8-3(h)]	
B.18	Permit Amendment or Revision [326 IAC 2-8-10][326 IAC 2-8-11.1]	
B.19	Operational Flexibility [326 IAC 2-8-15][326 IAC 2-8-11.1]	
B.20	Source Modification Requirement [326 IAC 2-8-11.1]	
B.21	Inspection and Entry [326 IAC 2-8-5(a)(2)][IC 13-14-2-2][IC 13-17-3-2][IC 13-30-3-1]	
B.22	Transfer of Ownership or Operational Control [326 IAC 2-8-10]	
B.23	Annual Fee Payment [326 IAC 2-7-19][326 IAC 2-8-4(6)] [326 IAC 2-8-16] [326 IAC 2-1.1-7]	
B.24	Advanced Source Modification Approval [326 IAC 2-8-4(11)] [326 IAC 2-1.1-9]	
B.25	Credible Evidence [326 IAC 2-8-4(3)][326 IAC 2-8-5][62 FR 8314][326 IAC 1-1-6]	
<b>SECTION C</b>	<b>SOURCE OPERATION CONDITIONS</b> .....	21
	<b>Emission Limitations and Standards [326 IAC 2-8-4(1)]</b>	
C.1	Particulate Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) pounds per hour [326 IAC 6-3-2]	
C.2	Overall Source Limit [326 IAC 2-8] [326 IAC 2-2]	
C.3	Opacity [326 IAC 5-1]	
C.4	Open Burning [326 IAC 4-1][IC 13-17-9]	
C.5	Incineration [326 IAC 4-2] [326 IAC 9-1-2(3)]	
C.6	Fugitive Dust Emissions [326 IAC 6-4]	
C.7	Stack Height [326 IAC 1-7]	
C.8	Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61 Subpart M]	
	<b>Testing Requirements [326 IAC 2-8-4(3)]</b>	
C.9	Performance Testing [326 IAC 3-6]	
	<b>Compliance Requirements [326 IAC 2-1.1-11]</b>	
C.10	Compliance Requirements [326 IAC 2-1.1-11]	

**TABLE OF CONTENTS (Continued)**

**Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]**

- C.11 Compliance Monitoring [326 IAC 2-8-4(3)] [326 IAC 2-8-5(a)(1)]
- C.12 Monitoring Methods [326 IAC 3][40 CFR 60][40 CFR 63]
- C.13 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-8-4(3)] [326 IAC 2-8-5(1)]

**Corrective Actions and Response Steps [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]**

- C.14 Risk Management Plan [326 IAC 2-8-4] [40 CFR 68]
- C.15 Response to Excursions or Exceedances [326 IAC 2-8-4][326 IAC 2-8-5]
- C.16 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-8-4] [326 IAC 2-8-5]

**Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]**

- C.17 General Record Keeping Requirements [326 IAC 2-8-4(3)][326 IAC 2-8-5]
- C.18 General Reporting Requirements [326 IAC 2-8-4(3)(C)] [326 IAC 2-1.1-11]

**Stratospheric Ozone Protection**

- C.19 Compliance with 40 CFR 82 and 326 IAC 22-1

**SECTION D.1 FACILITY OPERATION CONDITIONS – Grain Receiving and Handling Processes ..... 28**

***Construction Conditions***

**General Construction Conditions**

- D.1.1 Permit No Defense
- D.1.2 Federally Enforceable State Operating Permit [326 IAC 2-8]

**Effective Date of the Permit**

- D.1.3 Effective Date of the Permit [IC 13-15-5-3]
- D.1.4 Modification to Construction Conditions [326 IAC 2]

***Operation Conditions***

**Emission Limitations and Standards [326 IAC 2-8-4(1)]**

- D.1.5 PM and PM10 Emissions [326 IAC 2-2] [326 IAC 2-8-4]
- D.1.6 Particulate Emission Limitations [326 IAC 6-3-2]
- D.1.7 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

**Compliance Determination Requirements**

- D.1.8 Particulate Control
- D.1.9 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11]

**Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]**

- D.1.10 Visible Emissions Notations
- D.1.11 Parametric Monitoring
- D.1.12 Broken or Failed Bag Detection

**Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]**

- D.1.13 Record Keeping Requirements

**TABLE OF CONTENTS (Continued)**

**SECTION D.2 FACILITY OPERATION CONDITIONS – Fermentation Process ..... 33**

***Construction Conditions***

**General Construction Conditions**

- D.2.1 Permit No Defense
- D.2.2 Federally Enforceable State Operating Permit [326 IAC 2-8]

**Effective Date of the Permit**

- D.2.3 Effective Date of the Permit [IC 13-15-5-3]
- D.2.4 Modification to Construction Conditions [326 IAC 2]

***Operation Conditions***

**Emission Limitations and Standards [326 IAC 2-8-4(1)]**

- D.2.5 VOC and HAP Emissions [326 IAC 2-2] [326 IAC 2-8-4] [326 IAC 2-4.1]
- D.2.6 VOC Emissions [326 IAC 8-5-6]
- D.2.7 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]
- D.2.8 Equipment Leaks of VOC [326 IAC 12][40 CFR 60, Subpart VV]
- D.2.9 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

**Compliance Determination Requirements**

- D.2.10 VOC and HAP Control
- D.2.11 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11] [326 IAC 8-5-6]

**Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]**

- D.2.12 Parametric Monitoring [326 IAC 8-5-6]
- D.2.13 Scrubber Detection

**Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]**

- D.2.14 Record Keeping Requirements [326 IAC 8-5-6]

**SECTION D.3 FACILITY OPERATION CONDITIONS – TO/HRSG System and DDGS Drying Process ..... 36**

***Construction Conditions***

**General Construction Conditions**

- D.3.1 Permit No Defense
- D.3.2 Federally Enforceable State Operating Permit [326 IAC 2-8]

**Effective Date of the Permit**

- D.3.3 Effective Date of the Permit [IC 13-15-5-3]
- D.3.4 Modification to Construction Conditions [326 IAC 2]

***Operation Conditions***

**Emission Limitations and Standards [326 IAC 2-8-4(1)]**

- D.3.5 FESOP Limits [326 IAC 2-2] [326 IAC 2-8-4] [326 IAC 2-4.1]
- D.3.6 VOC Emissions [326 IAC 8-5-6]
- D.3.7 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]
- D.3.8 NOx Emissions [326 IAC 12-1][40 CFR 60, Subpart Db]
- D.3.9 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]
- D.3.10 Equipment Leaks of VOC [326 IAC 12][40 CFR 60, Subpart VV]

## TABLE OF CONTENTS (Continued)

- D.3.11 Particulate Emissions [326 IAC 6-2-4]
- D.3.12 Particulate Emission Limitations [326 IAC 6-3-2]
- D.3.13 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

### **Compliance Determination Requirements**

- D.3.14 PM and PM10 Control
- D.3.15 VOC and HAP Control
- D.3.16 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11] [326 IAC 2-2] [40 CFR 60, Subpart Db] [326 IAC 8-5-6]

### **Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]**

- D.3.17 Continuous Emissions Monitoring [326 IAC 3-5] [326 IAC 12] [40 CFR 60, Subpart Db]
- D.3.18 Visible Emissions Notations
- D.3.19 Thermal Oxidizer Temperature [326 IAC 8-5-6]
- D.3.20 Parametric Monitoring [326 IAC 8-5-6]

### **Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]**

- D.3.21 Record Keeping Requirements [326 IAC 8-5-6]
- D.3.22 Recordkeeping Requirements [40 CFR 60, Subpart Db] [326 IAC 12]
- D.3.23 Reporting Requirements [40 CFR 60, Subpart Db] [326 IAC 12]

## **SECTION D.4 FACILITY OPERATION CONDITIONS – DDGS Cooler ..... 43**

### ***Construction Conditions***

#### **General Construction Conditions**

- D.4.1 Permit No Defense
- D.4.2 Federally Enforceable State Operating Permit [326 IAC 2-8]

#### **Effective Date of the Permit**

- D.4.3 Effective Date of the Permit [IC 13-15-5-3]
- D.4.4 Modification to Construction Conditions [326 IAC 2]

### ***Operation Conditions***

#### **Emission Limitations and Standards [326 IAC 2-8-4(1)]**

- D.4.5 PM and PM10 Emissions [326 IAC 2-2] [326 IAC 2-8-4]
- D.4.6 Particulate Emission Limitations [326 IAC 6-3-2]
- D.4.7 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

#### **Compliance Determination Requirements**

- D.4.8 Particulate Control
- D.4.9 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11]

#### **Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]**

- D.4.10 Visible Emissions Notations
- D.4.11 Parametric Monitoring
- D.4.12 Broken or Failed Bag Detection

#### **Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]**

- D.4.13 Record Keeping Requirements
- D.4.14 Reporting Requirements

**TABLE OF CONTENTS (Continued)**

**SECTION D.5 FACILITY OPERATION CONDITIONS – Ethanol Loading Racks ..... 47**

***Construction Conditions***

**General Construction Conditions**

- D.5.1 Permit No Defense
- D.5.2 Federally Enforceable State Operating Permit [326 IAC 2-8]

**Effective Date of the Permit**

- D.5.3 Effective Date of the Permit [IC 13-15-5-3]
- D.5.4 Modification to Construction Conditions [326 IAC 2]

***Operation Conditions***

**Emission Limitations and Standards [326 IAC 2-8-4(1)]**

- D.5.5 FESOP Limits [326 IAC 2-2] [326 IAC 2-8-4] [326 IAC 2-4.1]
- D.5.6 VOC Emissions [326 IAC 8-5-6]
- D.5.7 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]
- D.5.8 Equipment Leaks of VOC [326 IAC 12][40 CFR 60, Subpart VV]
- D.5.9 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

**Compliance Determination Requirements**

- D.5.10 VOC and HAP Control
- D.5.11 Testing Requirements [326 IAC 2-8-5(a)(1), (4)][326 IAC 2-1.1-11][326 IAC 2-2] [326 IAC 8-5-6]

**Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]**

- D.5.12 Flare Pilot Flame [326 IAC 8-5-6]

**Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]**

- D.5.13 Record Keeping Requirements [326 IAC 8-5-6]
- D.5.14 Reporting Requirements

**SECTION D.6 FACILITY OPERATION CONDITIONS – Fire Pump and Biomethanator..... 50**

**Emission Limitations and Standards [326 IAC 2-8-4(1)]**

- D.6.1 FESOP Limits [326 IAC 2-2] [326 IAC 2-8-4] [326 IAC 2-4.1]

**Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]**

- D.6.2 Record Keeping Requirements
- D.6.3 Reporting Requirements

**SECTION D.7 FACILITY OPERATION CONDITIONS – Storage Tanks ..... 51**

**Emission Limitations and Standards [326 IAC 2-8-4(1)]**

- D.7.1 Volatile Organic Compounds (VOC) [326 IAC 8-9]
- D.7.2 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]
- D.7.3 Storage Tanks [326 IAC 12][40 CFR 60, Subpart Kb]
- D.7.4 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

**Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]**

- D.7.5 Testing and Procedures [40 CFR 60, Subpart Kb] [326 IAC 12]

**Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]**

- D.7.6 Record Keeping Requirements

**TABLE OF CONTENTS (Continued)**

**SECTION E.1 40 CFR 60, Subpart VV - Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry ..... 55**

**Emission Limitations and Standards [326 IAC 2-8-4(1)]**

- E.1.1 Standards: Pumps in Light Liquid Service [326 IAC 12][40 CFR 60, Subpart VV]
- E.1.2 Standards: Pressure Relief Devices in Gas/Vapor Service [326 IAC 12][40 CFR 60, Subpart VV]
- E.1.3 Standards: Sampling Connection Systems [326 IAC 12][40 CFR 60, Subpart VV]
- E.1.4 Standards: Open-Ended Valves or Lines [326 IAC 12][40 CFR 60, Subpart VV]
- E.1.5 Standards: Valves in Gas/Vapor Service and in Light Liquid Service [326 IAC 12][40 CFR 60, Subpart VV]
- E.1.6 Standards: Pumps and Valves in Heavy Liquid Service, Pressure Relief Devices in Light Liquid or Heavy Liquid Service, and Connectors [326 IAC 12][40 CFR 60, Subpart VV]
- E.1.7 Standards: Closed Vent Systems and Control Devices [326 IAC 12][40 CFR 60, Subpart VV]
- E.1.8 Standards: Delay of Repair [326 IAC 12][40 CFR 60, Subpart VV]

**Compliance Determination Requirements**

- E.1.9 Test Methods and Procedures [326 IAC 12][40 CFR 60, Subpart VV]

**Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]**

- E.1.10 Recordkeeping Requirements [326 IAC 12][40 CFR 60, Subpart VV]
- E.1.11 Reporting Requirements [326 IAC 12][40 CFR 60, Subpart VV]

Certification Form ..... 68  
Emergency Occurrence Form ..... 69  
Quarterly Report Form ..... 71-75  
Quarterly Deviation and Compliance Monitoring Report Form ..... 76

## SECTION A SOURCE SUMMARY

This permit is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ). The information describing the source contained in conditions A.1 through A.3 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this permit pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

### A.1 General Information [326 IAC 2-8-3(b)]

---

The Permittee owns and operates a stationary ethanol production plant.

Source Address:	2955 W. Delphi Pike, Marion, Indiana 46952
Mailing Address:	2955 W. Delphi Pike, Marion, Indiana 46952
General Source Phone:	(765) 384-4001
SIC Code:	2869
County Location:	Grant County
Source Location Status:	Attainment for all other criteria pollutants
Source Status:	Federally Enforceable State Operating Permit (FESOP) Minor Source, under PSD Rules Minor Source, Section 112 of the Clean Air Act Not 1 of 28 Source Categories

### A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-8-3(c)(3)]

---

This stationary source consists of the following stationary emission units and pollution control devices:

- (a) Three (3) corn dump pits, identified as EU001, constructed in 2006, each with a maximum throughput rate of 420 tons of corn per hour, controlled by baghouse CE001, and exhausting through stack EP001. This consists of two (2) truck dump pits and one (1) railcar dump pit.
- (b) One (1) grain handling operation, constructed in 2006, controlled by baghouse CE001, exhausting through stack EP001, and consisting of the following:
  - (1) One (1) corn conveyor, identified as EU002, with a maximum throughput rate of 420 tons per hour.
  - (2) One (1) corn elevator, identified as EU003, with a maximum throughput rate of 420 tons per hour.
  - (3) Two (2) corn storage bins, identified as EU004 and EU005, each with a maximum capacity of 200,000 bushels and maximum throughput rate of 420 tons per hour.
  - (4) One (1) scalper, identified as EU006, with a maximum throughput rate of 140 tons per hour.
  - (5) One (1) surge bin, identified as EU007, with a maximum throughput rate of 140 tons per hour.
  - (6) Two (2) corn storage bins, identified as EU064 and EU065, each with a maximum capacity of 425,000 bushels and maximum throughput rate of 420 tons per hour.
- (c) Two (2) hammermills, identified as EU010 and EU011, constructed in 2006, each with a maximum throughput rate of 140 tons of corn per hour, controlled by baghouse CE003, and exhausting through stack EP003.

- (d) One (1) fermentation process, constructed in 2006, with a maximum throughput rate of 7,060 gallons of ethanol per hour, controlled by CO<sub>2</sub> scrubber CE005, exhausting through stack EP005, and consisting of the following:
  - (1) Five (5) fermenters, identified as EU016, EU017, EU018, EU019, and EU057.
  - (2) One (1) beer well, identified as EU020.
- (e) One (1) thermal oxidizer with heat recovery steam generator (TO/HRSG) system, identified as CE007, constructed in 2006, with a maximum heat input capacity of 135 MMBtu/hr, using natural gas and process waste gases from the DDGS dryers as fuels, with emissions exhausted through stack EP007.
- (f) One (1) distillation process, constructed in 2006, with a maximum throughput rate of 6,850 gallons of ethanol per hour, controlled by TO/HRSG system CE007, exhausting through stack EP007, and consisting of the following:
  - (1) Two (2) slurry mixers, identified as EU049 and EU058.
  - (2) One (1) slurry tank, identified as EU050.
  - (3) Three (3) liquefaction tanks, identified as EU014, EU051, and EU059, each with a maximum capacity of 7,000 gallons per hour.
  - (4) One (1) cook tube, identified as EU052.
  - (5) One (1) flash tank, identified as EU053.
  - (6) One (1) yeast tank, identified as EU015.
  - (7) One (1) 190 proof condenser, identified as EU054.
  - (8) One (1) 200 proof condenser, identified as EU055.
  - (9) One (1) beer stripper, identified as EU021.
  - (10) One (1) side stripper, identified as EU022.
  - (11) One (1) rectifier, identified as EU023.
  - (12) Molecular sieve units, identified as EU024.
  - (13) Eight (8) evaporators, identified as EU025.
  - (14) Four (4) centrifuges, identified as EU026 through EU029.
- (g) Two (2) natural gas fired DDGS dryers, identified as EU035 and EU056, constructed in 2006, each with a maximum heat input rate of 45 MMBtu/hr and a maximum throughput rate of 34 tons of DDGS per hour, controlled by multiclone CE006, with emissions venting to TO/HRSG system CE007, and exhausting to stack EP007.
- (h) One (1) DDGS cooler, identified as EU036, constructed in 2006, with a maximum throughput rate of 34 tons/hr of DDGS, controlled by baghouse CE014, and exhausting to stack EP014.
- (i) One (1) DDGS loadout operation, constructed in 2006 with a maximum throughput rate of 101 tons per hour, controlled by baghouse CE008, exhausting to stack EP008, and consisting of the following:

- (1) One (1) DDGS dump pit, identified as EU040.
- (2) One (1) DDGS elevator, identified as EU041.
- (3) One (1) DDGS conveyor, identified as EU042.
- (4) One (1) DDGS load spout, identified as EU043.
- (j) One (1) ethanol loading rack for trucks, identified as EU045A, constructed in 2006, with a maximum throughput rate of 48,000 gallons per hour. The truck loading process is controlled by the enclosed flare CE009, which is fueled by natural gas and has a maximum heat input capacity of 10.0 MMBtu/hr, and exhausts through stack EP009.
- (k) One (1) ethanol loading rack for railcars, identified as EU045B, constructed in 2006, with a maximum throughput rate of 60,000 gallons per hour. Railcars are dedicated to carrying denatured ethanol.

A.3 Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-8-3(c)(3)(I)]

This stationary source also includes the following insignificant activities, as defined in 326 IAC 2-7-1(21):

- (a) Solvent recycling systems with batch capacity less than or equal to 100 gallons.
- (b) Forced and induced draft cooling tower system not regulated under a NESHAP.
- (c) Replacement or repair of electrostatic precipitators, bags in baghouses and filters in other air filtration equipment.
- (d) Heat exchanger cleaning and repair.
- (e) Process vessel degassing and cleaning to prepare for internal repairs.
- (f) Paved roads and parking lots with public access. [326 IAC 6-4]
- (g) Blowdown for any of the following: sight glass; boiler; compressors; pumps; and cooling tower.
- (h) Stationary fire pumps, including one (1) diesel fire pump, identified as EU034, constructed in 2006, with a maximum power output rate of 300 horsepower, and exhausting to stack EP006. [326 IAC 2-8-4]
- (i) Farm operations.
- (j) Other emission units, not regulated by a NESHAP, with PM<sub>10</sub>, NO<sub>x</sub>, and SO<sub>2</sub> emissions less than five (5) pounds per hour or twenty-five (25) pounds per day, CO emissions less than twenty-five (25) pounds per day, VOC emissions less than three (3) pounds per hour or fifteen (15) pounds per day, lead emissions less than six-tenths (0.6) tons per year or three and twenty-nine hundredths (3.29) pounds per day, and emitting greater than one (1) pound per day but less than five (5) pounds per day or one (1) ton per year of a single HAP, or emitting greater than one (1) pound per day but less than twelve and five tenths (12.5) pounds per day or two and five tenths (2.5) ton per year of any combination of HAPs:
  - (1) One (1) 190 proof tank, identified as T001, constructed in 2006, with a maximum capacity of 100,000 gallons. [40 CFR 60, Subpart Kb]
  - (2) One (1) 200 proof tank, identified as T002, constructed in 2006, with a maximum capacity of 100,000 gallons. [40 CFR 60, Subpart Kb]

- (3) One (1) denaturant tank, identified as T003, constructed in 2006, with a maximum capacity of 100,000 gallons. [40 CFR 60, Subpart Kb] [326 IAC 8-4-3]
- (4) Two (2) denatured ethanol tanks, identified as T004 and T005, constructed in 2006, each with a maximum capacity of 750,000 gallons. [40 CFR 60, Subpart Kb]
- (5) One (1) fuel additive tank, identified as T006, constructed in 2006, with a maximum storage capacity less than 2,300 gallons.
- (6) One (1) diesel storage tank, identified as T007, constructed in 2006, with a maximum storage capacity less than 1,000 gallons.
- (7) One (1) biomethanator, identified as EU048, constructed in 2006, controlled by 6.0 MMBtu/hr biomethanator flare CE013, and exhausting to stack EP013. [326 IAC 2-8-4]
- (8) One (1) corn oil separation unit, identified as EU061.
- (9) Two (2) corn oil storage tanks, identified as EU062 and EU063, each with a maximum capacity of 35,000 gallons.

A.4 FESOP Applicability [326 IAC 2-8-2]

This stationary source, otherwise required to have a Part 70 permit as described in 326 IAC 2-7-2(a), has applied to the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ) for a Federally Enforceable State Operating Permit (FESOP).

## **SECTION B GENERAL CONDITIONS**

### **B.1 Definitions [326 IAC 2-8-1]**

---

Terms in this permit shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, the applicable definitions found in the statutes or regulations (IC 13-11, 326 IAC 1-2, and 326 IAC 2-7) shall prevail.

### **B.2 Permit Term [326 IAC 2-8-4(2)] [326 IAC 2-1.1-9.5]**

---

- (a) This permit F053-24415-00062 is issued for a fixed term of five (5) years from the issuance date of this permit, as determined in accordance with IC 4-21.5-3-5(f) and IC 13-15-5-3. Subsequent revisions, modifications, or amendments of this permit do not affect the expiration date of this permit.
- (b) If IDEM, OAQ, upon receiving a timely and complete renewal permit application, fails to issue or deny the permit renewal prior to the expiration date of this permit, this existing permit shall not expire and all terms and conditions shall continue in effect, until the renewal permit has been issued or denied.

### **B.3 Term of Conditions [326 IAC 2-1.1-9.5]**

---

Notwithstanding the permit term of a permit to construct, a permit to operate, or a permit modification, any condition established in a permit issued pursuant to a permitting program approved in the state implementation plan shall remain in effect until:

- (a) the condition is modified in a subsequent permit action pursuant to Title I of the Clean Air Act; or
- (b) the emission unit to which the condition pertains permanently ceases operation.

### **B.4 Enforceability [326 IAC 2-8-6]**

---

Unless otherwise stated, all terms and conditions in this permit, including any provisions designed to limit the source's potential to emit, are enforceable by IDEM, the United States Environmental Protection Agency (U.S. EPA) and by citizens in accordance with the Clean Air Act.

### **B.5 Severability [326 IAC 2-8-4(4)]**

---

The provisions of this permit are severable; a determination that any portion of this permit is invalid shall not affect the validity of the remainder of the permit.

### **B.6 Property Rights or Exclusive Privilege [326 IAC 2-8-4(5)(D)]**

---

This permit does not convey any property rights of any sort, or any exclusive privilege.

### **B.7 Duty to Provide Information [326 IAC 2-8-4(5)(E)]**

---

- (a) The Permittee shall furnish to IDEM, OAQ, within a reasonable time, any information that IDEM, OAQ, may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The submittal by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1). Upon request, the Permittee shall also furnish to IDEM, OAQ, copies of records required to be kept by this permit.
- (b) For information furnished by the Permittee to IDEM, OAQ, the Permittee may include a claim of confidentiality in accordance with 326 IAC 17.1. When furnishing copies of requested records directly to U.S. EPA, the Permittee may assert a claim of confidentiality in accordance with 40 CFR 2, Subpart B.

### **B.8 Compliance Order Issuance [326 IAC 2-8-5(b)]**

---

IDEM, OAQ may issue a compliance order to this Permittee upon discovery that this permit is in nonconformance with an applicable requirement. The order may require immediate compliance or contain a schedule for expeditious compliance with the applicable requirement.

B.9 Certification [326 IAC 2-8-3(d)] [326 IAC 2-8-4(3)(C)(i)] [326 IAC 2-8-5(1)]

- (a) Where specifically designated by this permit or required by an applicable requirement, any application form, report, or compliance certification submitted shall contain certification by an authorized individual of truth, accuracy, and completeness. This certification, shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
- (b) One (1) certification shall be included, using the attached Certification Form, with each submittal requiring certification. One (1) certification may cover multiple forms in one (1) submittal.
- (c) An authorized individual is defined at 326 IAC 2-1.1-1(1).

B.10 Annual Compliance Certification [326 IAC 2-8-5(a)(1)]

- (a) The Permittee shall annually submit a compliance certification report which addresses the status of the source's compliance with the terms and conditions contained in this permit, including emission limitations, standards, or work practices. The initial certification shall cover the time period from the date of final permit issuance through December 31 of the same year. All subsequent certifications shall cover the time period from January 1 to December 31 of the previous year, and shall be submitted in letter form no later than July 1 of each year to:

Indiana Department of Environmental Management  
Compliance Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

- (b) The annual compliance certification report required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.
- (c) The annual compliance certification report shall include the following:
  - (1) The appropriate identification of each term or condition of this permit that is the basis of the certification;
  - (2) The compliance status;
  - (3) Whether compliance was continuous or intermittent;
  - (4) The methods used for determining the compliance status of the source, currently and over the reporting period consistent with 326 IAC 2-8-4(3); and
  - (5) Such other facts as specified in Sections D of this permit, IDEM, OAQ, may require to determine the compliance status of the source.

The submittal by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

B.11 Preventive Maintenance Plan [326 IAC 1-6-3] [326 IAC 2-8-4(9)] [326 IAC 2-8-5(a)(1)]

- (a) If required by specific condition(s) in Section D of this permit, the Permittee shall prepare and maintain Preventive Maintenance Plans (PMPs) within ninety (90) days after issuance of this permit, including the following information on each facility:
  - (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;

- (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
- (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

If due to circumstances beyond the Permittee's control, the PMPs cannot be prepared and maintained within the above time frame, the Permittee may extend the date an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management  
Compliance Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

The PMP extension notification does not require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (b) A copy of the PMPs shall be submitted to IDEM, OAQ, upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. IDEM, OAQ, may require the Permittee to revise its PMPs whenever lack of proper maintenance causes or is the primary contributor to an exceedance of any limitation on emissions or potential to emit. The PMPs do not require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (c) To the extent the Permittee is required by 40 CFR Part 60/63 to have an Operation, Maintenance, and Monitoring (OMM) Plan for a unit, such Plan is deemed to satisfy the PMP requirements of 326 IAC 1-6-3 for that unit.

#### B.12 Emergency Provisions [326 IAC 2-8-12]

---

- (a) An emergency, as defined in 326 IAC 2-7-1(12), is not an affirmative defense for an action brought for noncompliance with a federal or state health-based emission limitation, except as provided in 326 IAC 2-8-12.
- (b) An emergency, as defined in 326 IAC 2-7-1(12), constitutes an affirmative defense to an action brought for noncompliance with a health-based or technology-based emission limitation if the affirmative defense of an emergency is demonstrated through properly signed, contemporaneous operating logs or other relevant evidence that describe the following:
  - (1) An emergency occurred and the Permittee can, to the extent possible, identify the causes of the emergency;
  - (2) The permitted facility was at the time being properly operated;
  - (3) During the period of an emergency, the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards or other requirements in this permit;
  - (4) For each emergency lasting one (1) hour or more, the Permittee notified IDEM, OAQ Indianapolis Offices, within four (4) daytime business hours after the beginning of the emergency, or after the emergency was discovered or reasonably should have been discovered;

Telephone Number: 1-800-451-6027 (ask for Office of Air Quality, Compliance Section) or,  
Telephone Number: 317-233-5674 (ask for Compliance Section)

Facsimile Number: 317-233-5967  
Indianapolis Offices: 317-232-8603

- (5) For each emergency lasting one (1) hour or more, the Permittee submitted the attached Emergency Occurrence Report Form or its equivalent, either by mail or facsimile to:

Indiana Department of Environmental Management  
Compliance Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

within two (2) working days of the time when emission limitations were exceeded due to the emergency.

The notice fulfills the requirement of 326 IAC 2-8-4(3)(C)(ii) and must contain the following:

- (A) A description of the emergency;
- (B) Any steps taken to mitigate the emissions; and
- (C) Corrective actions taken.

The notification which shall be submitted by the Permittee does not require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (6) The Permittee immediately took all reasonable steps to correct the emergency.
- (c) In any enforcement proceeding, the Permittee seeking to establish the occurrence of an emergency has the burden of proof.
- (d) This emergency provision supersedes 326 IAC 1-6 (Malfunctions). This permit condition is in addition to any emergency or upset provision contained in any applicable requirement.
- (e) The Permittee seeking to establish the occurrence of an emergency shall make records available upon request to ensure that failure to implement a PMP did not cause or contribute to an exceedance of any limitations on emissions. However, IDEM, OAQ may require that the Preventive Maintenance Plans required under 326 IAC 2-8-3(c)(6) be revised in response to an emergency.
- (f) Failure to notify IDEM, OAQ by telephone or facsimile of an emergency lasting more than one (1) hour in accordance with (b)(4) and (5) of this condition shall constitute a violation of 326 IAC 2-8 and any other applicable rules.
- (g) Operations may continue during an emergency only if the following conditions are met:
- (1) If the emergency situation causes a deviation from a technology-based limit, the Permittee may continue to operate the affected emitting facilities during the emergency provided the Permittee immediately takes all reasonable steps to correct the emergency and minimize emissions.
  - (2) If an emergency situation causes a deviation from a health-based limit, the Permittee may not continue to operate the affected emissions facilities unless:
    - (A) The Permittee immediately takes all reasonable steps to correct the emergency situation and to minimize emissions; and

- (B) Continued operation of the facilities is necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw material of substantial economic value.

Any operations shall continue no longer than the minimum time required to prevent the situations identified in (g)(2)(B) of this condition.

- (h) The Permittee shall include all emergencies in the Quarterly Deviation and Compliance Monitoring Report.

**B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5]**

---

- (a) All terms and conditions of permits established prior to 181-24072-00046 and issued pursuant to permitting programs approved into the state implementation plan have been either:

- (1) incorporated as originally stated,
- (2) revised, or
- (3) deleted.

- (b) All previous registrations and permits are superseded by this permit.

**B.14 Termination of Right to Operate [326 IAC 2-8-9][326 IAC 2-8-3(h)]**

---

The Permittee's right to operate this source terminates with the expiration of this permit unless a timely and complete renewal application is submitted at least nine (9) months prior to the date of expiration of the source's existing permit, consistent with 326 IAC 2-8-3(h) and 326 IAC 2-8-9.

**B.15 Deviations from Permit Requirements and Conditions [326 IAC 2-8-4(3)(C)(ii)]**

---

- (a) Deviations from any permit requirements (for emergencies see Section B - Emergency Provision), the probable cause of such deviations, and any response steps or preventive measures taken shall be reported to:

Indiana Department of Environmental Management  
Compliance Data Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

using the attached Quarterly Deviation and Compliance Monitoring Report, or its equivalent. A deviation required to be reported pursuant to an applicable requirement that exists independent of this permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report.

The Quarterly Deviation and Compliance Monitoring Report does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (b) A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit.

**B.16 Permit Modification, Reopening, Revocation and Reissuance, or Termination [326 IAC 2-8-4(5)(C)] [326 IAC 2-8-7(a)] [326 IAC 2-8-8]**

---

- (a) This permit may be modified, reopened, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a Federally Enforceable State Operating Permit (FESOP) modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any condition of this permit. [326 IAC 2-8-4(5)(C)] The notification by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (b) This permit shall be reopened and revised under any of the circumstances listed in IC 13-15-7-2 or if IDEM, OAQ determines any of the following:
  - (1) That this permit contains a material mistake.
  - (2) That inaccurate statements were made in establishing the emissions standards or other terms or conditions.
  - (3) That this permit must be revised or revoked to assure compliance with an applicable requirement. [326 IAC 2-8-8(a)]
- (c) Proceedings by IDEM, OAQ to reopen and revise this permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of this permit for which cause to reopen exists. Such reopening and revision shall be made as expeditiously as practicable. [326 IAC 2-8-8(b)]
- (d) The reopening and revision of this permit, under 326 IAC 2-8-8(a), shall not be initiated before notice of such intent is provided to the Permittee by IDEM, OAQ at least thirty (30) days in advance of the date this permit is to be reopened, except that IDEM, OAQ may provide a shorter time period in the case of an emergency. [326 IAC 2-8-8(c)]

B.17 Permit Renewal [326 IAC 2-8-3(h)]

- (a) The application for renewal shall be submitted using the application form or forms prescribed by IDEM, OAQ and shall include the information specified in 326 IAC 2-8-3. Such information shall be included in the application for each emission unit at this source, except those emission units included on the trivial or insignificant activities list contained in 326 IAC 2-7-1(21) and 326 IAC 2-7-1(40). The renewal application does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

Request for renewal shall be submitted to:

Indiana Department of Environmental Management  
Permits Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

- (b) A timely renewal application is one that is:
  - (1) Submitted at least nine (9) months prior to the date of the expiration of this permit; and
  - (2) If the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
- (c) If the Permittee submits a timely and complete application for renewal of this permit, the source's failure to have a permit is not a violation of 326 IAC 2-8 until IDEM, OAQ takes final action on the renewal application, except that this protection shall cease to apply if, subsequent to the completeness determination, the Permittee fails to submit by the deadline specified in writing by IDEM, OAQ any additional information identified as being needed to process the application.

B.18 Permit Amendment or Revision [326 IAC 2-8-10] [326 IAC 2-8-11.1]

- (a) Permit amendments and revisions are governed by the requirements of 326 IAC 2-8-10 or 326 IAC 2-8-11.1 whenever the Permittee seeks to amend or modify this permit.

- (b) Any application requesting an amendment or modification of this permit shall be submitted to:

Indiana Department of Environmental Management  
Permits Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

Any such application shall be certified by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-8-10(b)(3)]
- (d) No permit amendment or modification is required for the addition, operation or removal of a nonroad engine, as defined in 40 CFR 89.2.

B.19 Operational Flexibility [326 IAC 2-8-15] [326 IAC 2-8-11.1]

- (a) The Permittee may make any change or changes at the source that are described in 326 IAC 2-8-15(b) through (d) without a prior permit revision, if each of the following conditions is met:

- (1) The changes are not modifications under any provision of Title I of the Clean Air Act;
- (2) Any approval required by 326 IAC 2-8-11.1 has been obtained;
- (3) The changes do not result in emissions which exceed the limitations provided in this permit (whether expressed herein as a rate of emissions or in terms of total emissions);
- (4) The Permittee notifies the:

Indiana Department of Environmental Management  
Permits Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V  
Air and Radiation Division, Regulation Development Branch - Indiana (AR-18J)  
77 West Jackson Boulevard  
Chicago, Illinois 60604-3590

in advance of the change by written notification at least ten (10) days in advance of the proposed change. The Permittee shall attach every such notice to the Permittee's copy of this permit; and

- (5) The Permittee maintains records on-site, on a rolling five (5) year basis, which document, all such changes and emission trades that are subject to 326 IAC 2-8-15(b) through (d). The Permittee shall make such records available, upon reasonable request, for public review.

Such records shall consist of all information required to be submitted to IDEM, OAQ in the notices specified in 326 IAC 2-8-15(b)(2), (c)(1), and (d).

- (b) Emission Trades [326 IAC 2-8-15(c)]  
The Permittee may trade emissions increases and decreases at the source, where the applicable SIP provides for such emission trades without requiring a permit revision, subject to the constraints of Section (a) of this condition and those in 326 IAC 2-8-15(c).
- (c) Alternative Operating Scenarios [326 IAC 2-8-15(d)]  
The Permittee may make changes at the source within the range of alternative operating scenarios that are described in the terms and conditions of this permit in accordance with 326 IAC 2-8-4(7). No prior notification of IDEM, OAQ or U.S. EPA is required.
- (d) Backup fuel switches specifically addressed in, and limited under, Section D of this permit shall not be considered alternative operating scenarios. Therefore, the notification requirements of part (a) of this condition do not apply.

**B.20 Source Modification Requirement [326 IAC 2-8-11.1]**

---

A modification, construction, or reconstruction is governed by the requirements of 326 IAC 2 and 326 IAC 2-8-11.1.

**B.21 Inspection and Entry [326 IAC 2-8-5(a)(2)] [IC 13-14-2-2] [IC 13-17-3-2] [IC 13-30-3-1]**

---

Upon presentation of proper identification cards, credentials, and other documents as may be required by law, and subject to the Permittee's right under all applicable laws and regulations to assert that the information collected by the agency is confidential and entitled to be treated as such, the Permittee shall allow IDEM, OAQ, U.S. EPA, or an authorized representative to perform the following:

- (a) Enter upon the Permittee's premises where a FESOP source is located, or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
- (b) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- (c) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, inspect, at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit;
- (d) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with this permit or applicable requirements; and
- (e) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, utilize any photographic, recording, testing, monitoring, or other equipment for the purpose of assuring compliance with this permit or applicable requirements.

**B.22 Transfer of Ownership or Operational Control [326 IAC 2-8-10]**

---

- (a) The Permittee must comply with the requirements of 326 IAC 2-8-10 whenever the Permittee seeks to change the ownership or operational control of the source and no other change in the permit is necessary.
- (b) Any application requesting a change in the ownership or operational control of the source shall contain a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new Permittee. The application shall be submitted to:

Indiana Department of Environmental Management  
Permits Branch, Office of Air Quality

100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

The application which shall be submitted by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-8-10(b)(3)]

B.23 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-8-4(6)] [326 IAC 2-8-16] [326 IAC 2-1.1-7]

- (a) The Permittee shall pay annual fees to IDEM, OAQ, within thirty (30) calendar days of receipt of a billing. Pursuant to 326 IAC 2-7-19(b), if the Permittee does not receive a bill from IDEM, OAQ the applicable fee is due April 1 of each year.
- (b) Failure to pay may result in administrative enforcement action, or revocation of this permit.
- (c) The Permittee may call the following telephone numbers: 1-800-451-6027 or 317-233-4230 (ask for OAQ, Billing, Licensing, and Training Section), to determine the appropriate permit fee.

B.24 Advanced Source Modification Approval [326 IAC 2-8-4(11)] [326 IAC 2-1.1-9]

- (a) The requirements to obtain a permit revision under 326 IAC 2-8-11.1 are satisfied by this permit for the proposed emission units, control equipment or insignificant activities in Sections A.2 and A.3.
- (b) Pursuant to 326 IAC 2-1.1-9 any permit authorizing construction may be revoked if construction of the emission unit has not commenced within eighteen (18) months from the date of issuance of the permit, or if during the construction work is suspended for a continuous period of one (1) year or more.

B.25 Credible Evidence [326 IAC 2-8-4(3)] [326 IAC 2-8-5] [62 FR 8314] [326 IAC 1-1-6]

For the purpose of submitting compliance certifications or establishing whether or not the Permittee has violated or is in violation of any condition of this permit, nothing in this permit shall preclude the use, including the exclusive use, of any credible evidence or information relevant to whether the Permittee would have been in compliance with the condition of this permit if the appropriate performance or compliance test or procedure had been performed.

## SECTION C SOURCE OPERATION CONDITIONS

Entire Source

### Emissions Limitations and Standards [326 IAC 2-8-4(1)]

#### C.1 Particulate Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2(e)(2), particulate emissions from any process not exempt under 326 IAC 6-3-1(b) or (c), and which has a maximum process weight rate less than 100 pounds per hour and the methods in 326 IAC 6-3-2(b) through (d) do not apply shall not exceed 0.551 pounds per hour.

#### C.2 Overall Source Limit [326 IAC 2-8] [326 IAC 2-2]

The purpose of this permit is to limit this source's potential to emit to less than major source levels for the purpose of Section 502(a) of the Clean Air Act.

(a) Pursuant to 326 IAC 2-8:

- (1) The potential to emit any regulated pollutant, except particulate matter (PM), from the entire source shall be limited to less than one-hundred (100) tons per twelve (12) consecutive month period. This limitation shall also make the requirements of 326 IAC 2-2 (Prevention of Significant Deterioration (PSD)) not applicable;
- (2) The potential to emit any individual hazardous air pollutant (HAP) from the entire source shall be limited to less than ten (10) tons per twelve (12) consecutive month period; and
- (3) The potential to emit any combination of HAPs from the entire source shall be limited to less than twenty-five (25) tons per twelve (12) consecutive month period.

(b) The potential to emit particulate matter (PM) from the entire source shall be limited to less than two hundred fifty (250) tons per twelve (12) consecutive month period. This limitation shall also make the requirements of 326 IAC 2-2 (Prevention of Significant Deterioration (PSD)) not applicable.

(c) This condition shall include all emission points at this source including those that are insignificant as defined in 326 IAC 2-7-1(21). The source shall be allowed to add insignificant activities not already listed in this permit, provided the source's potential to emit does not exceed the above specified limits.

(d) Section D of this permit contains independently enforceable provisions to satisfy this requirement.

#### C.3 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

- (a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A,

Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

**C.4 Open Burning [326 IAC 4-1] [IC 13-17-9]**

---

The Permittee shall not open burn any material except as provided in 326 IAC 4-1-3, 326 IAC 4-1-4 or 326 IAC 4-1-6. The previous sentence notwithstanding, the Permittee may open burn in accordance with an open burning approval issued by the Commissioner under 326 IAC 4-1-4.1.

**C.5 Incineration [326 IAC 4-2] [326 IAC 9-1-2(3)]**

---

The Permittee shall not operate an incinerator or incinerate any waste or refuse except as provided in 326 IAC 4-2 and 326 IAC 9-1-2.

**C.6 Fugitive Dust Emissions [326 IAC 6-4]**

---

The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions).

**C.7 Stack Height [326 IAC 1-7]**

---

The Permittee shall comply with the applicable provisions of 326 IAC 1-7 (Stack Height Provisions), for all exhaust stacks through which a potential (before controls) of twenty-five (25) tons per year or more of particulate matter or sulfur dioxide is emitted.

**C.8 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]**

---

- (a) Notification requirements apply to each owner or operator. If the combined amount of regulated asbestos containing material (RACM) to be stripped, removed or disturbed is at least 260 linear feet on pipes or 160 square feet on other facility components, or at least thirty-five (35) cubic feet on all facility components, then the notification requirements of 326 IAC 14-10-3 are mandatory. All demolition projects require notification whether or not asbestos is present.
- (b) The Permittee shall ensure that a written notification is sent on a form provided by the Commissioner at least ten (10) working days before asbestos stripping or removal work or before demolition begins, per 326 IAC 14-10-3, and shall update such notice as necessary, including, but not limited to the following:
  - (1) When the amount of affected asbestos containing material increases or decreases by at least twenty percent (20%); or
  - (2) If there is a change in the following:
    - (A) Asbestos removal or demolition start date;
    - (B) Removal or demolition contractor; or
    - (C) Waste disposal site.
- (c) The Permittee shall ensure that the notice is postmarked or delivered according to the guidelines set forth in 326 IAC 14-10-3(2).
- (d) The notice to be submitted shall include the information enumerated in 326 IAC 14-10-3(3).

All required notifications shall be submitted to:

Indiana Department of Environmental Management  
Asbestos Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-52 IGCN 1003  
Indianapolis, Indiana 46204-2251

The notice shall include a signed certification from the owner or operator that the information provided in this notification is correct and that only Indiana licensed workers and project supervisors will be used to implement the asbestos removal project. The notifications do not require a certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (e) **Procedures for Asbestos Emission Control**  
The Permittee shall comply with the applicable emission control procedures in 326 IAC 14-10-4 and 40 CFR 61.145(c). Per 326 IAC 14-10-1, emission control requirements are applicable for any removal or disturbance of RACM greater than three (3) linear feet on pipes or three (3) square feet on any other facility components or a total of at least 0.75 cubic feet on all facility components.
- (f) **Demolition and renovation**  
The Permittee shall thoroughly inspect the affected facility or part of the facility where the demolition or renovation will occur for the presence of asbestos pursuant to 40 CFR 61.145(a).
- (g) **Indiana Accredited Asbestos Inspector**  
The Permittee shall comply with 326 IAC 14-10-1(a) that requires the owner or operator, prior to a renovation/demolition, to use an Indiana Accredited Asbestos Inspector to thoroughly inspect the affected portion of the facility for the presence of asbestos.

### **Testing Requirements [326 IAC 2-8-4(3)]**

#### **C.9 Performance Testing [326 IAC 3-6]**

---

- (a) All testing shall be performed according to the provisions of 326 IAC 3-6 (Source Sampling Procedures), except as provided elsewhere in this permit, utilizing any applicable procedures and analysis methods specified in 40 CFR 51, 40 CFR 60, 40 CFR 61, 40 CFR 63, 40 CFR 75, or other procedures approved by IDEM, OAQ.

A test protocol, except as provided elsewhere in this permit, shall be submitted to:

Indiana Department of Environmental Management  
Compliance Data Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

no later than thirty-five (35) days prior to the intended test date. The protocol submitted by the Permittee does not require certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (b) The Permittee shall notify IDEM, OAQ of the actual test date at least fourteen (14) days prior to the actual test date. The notification submitted by the Permittee does not require certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (c) Pursuant to 326 IAC 3-6-4(b), all test reports must be received by IDEM, OAQ not later than forty-five (45) days after the completion of the testing. An extension may be granted by IDEM, OAQ, if the Permittee submits to IDEM, OAQ, a reasonable written explanation not later than five (5) days prior to the end of the initial forty-five (45) day period.

### **Compliance Requirements [326 IAC 2-1.1-11]**

#### **C.10 Compliance Requirements [326 IAC 2-1.1-11]**

---

The commissioner may require stack testing, monitoring, or reporting at any time to assure compliance with all applicable requirements by issuing an order under 326 IAC 2-1.1-11. Any

monitoring or testing shall be performed in accordance with 326 IAC 3 or other methods approved by the commissioner or the U. S. EPA.

### **Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]**

#### **C.11 Compliance Monitoring [326 IAC 2-8-4(3)] [326 IAC 2-8-5(a)(1)]**

---

Unless otherwise specified in this permit, all monitoring and record keeping requirements not already legally required shall be implemented within ninety (90) days of permit issuance. If required by Section D, the Permittee shall be responsible for installing any necessary equipment and initiating any required monitoring related to that equipment. If due to circumstances beyond its control, that equipment cannot be installed and operated within ninety (90) days, the Permittee may extend the compliance schedule related to the equipment for an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management  
Compliance Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

in writing, prior to the end of the initial ninety (90) day compliance schedule with full justification of the reasons for inability to meet this date.

The notification which shall be submitted by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

Unless otherwise specified in the approval for the new emissions unit, compliance monitoring for new emission units or emission units added through a permit revision shall be implemented when operation begins.

#### **C.12 Monitoring Methods [326 IAC 3] [40 CFR 60] [40 CFR 63]**

---

Any monitoring or testing required by Section D of this permit shall be performed according to the provisions of 326 IAC 3, 40 CFR 60, Appendix A, 40 CFR 60, Appendix B, 40 CFR 63, or other approved methods as specified in this permit.

#### **C.13 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-8-4(3)] [326 IAC 2-8-5(1)]**

---

- (a) When required by any condition of this permit, an analog instrument used to measure a parameter related to the operation of an air pollution control device shall have a scale such that the expected maximum reading shall be no less than twenty percent (20%) of full scale.
- (b) The Permittee may request that the IDEM, OAQ approve the use of an instrument that does not meet the above specifications provided the Permittee can demonstrate that an alternative instrument specification will adequately ensure compliance with permit conditions requiring the measurement of the parameters.

### **Corrective Actions and Response Steps [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]**

#### **C.14 Risk Management Plan [326 IAC 2-8-4] [40 CFR 68]**

---

If a regulated substance, as defined in 40 CFR 68, is present at a source in more than a threshold quantity, the Permittee must comply with the applicable requirements of 40 CFR 68.

#### **C.15 Response to Excursions or Exceedances [326 IAC 2-8-4] [326 IAC 2-8-5]**

---

- (a) Upon detecting an excursion or exceedance, the Permittee shall restore operation of the emissions unit (including any control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing emissions.

- (b) The response shall include minimizing the period of any startup, shutdown or malfunction and taking any necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of an excursion or exceedance (other than those caused by excused startup or shutdown conditions). Corrective actions may include, but are not limited to, the following:
  - (1) initial inspection and evaluation;
  - (2) recording that operations returned to normal without operator action (such as through response by a computerized distribution control system); or
  - (3) any necessary follow-up actions to return operation to within the indicator range, designated condition, or below the applicable emission limitation or standard, as applicable.
- (c) A determination of whether the Permittee has used acceptable procedures in response to an excursion or exceedance will be based on information available, which may include, but is not limited to, the following:
  - (1) monitoring results;
  - (2) review of operation and maintenance procedures and records;
  - (3) inspection of the control device, associated capture system, and the process.
- (d) Failure to take reasonable response steps shall be considered a deviation from the permit.
- (e) The Permittee shall maintain the following records:
  - (1) monitoring data; and
  - (2) monitor performance data, if applicable.
  - (3) corrective actions taken.

C.16 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-8-4][326 IAC 2-8-5]

- (a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this permit exceed the level specified in any condition of this permit, the Permittee shall take appropriate response actions. The Permittee shall submit a description of these response actions to IDEM, OAQ, within thirty (30) days of receipt of the test results. The Permittee shall take appropriate action to minimize excess emissions from the affected facility while the response actions are being implemented.
- (b) A retest to demonstrate compliance shall be performed within one hundred twenty (120) days of receipt of the original test results. Should the Permittee demonstrate to IDEM, OAQ that retesting in one-hundred and twenty (120) days is not practicable, IDEM, OAQ may extend the retesting deadline.
- (c) IDEM, OAQ reserves the authority to take any actions allowed under law in response to noncompliant stack tests.

The response action documents submitted pursuant to this condition do require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

## **Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]**

### **C.17 General Record Keeping Requirements [326 IAC 2-8-4(3)] [326 IAC 2-8-5]**

---

- (a) Records of all required monitoring data, reports and support information required by this permit shall be retained for a period of at least five (5) years from the date of monitoring sample, measurement, report, or application. These records shall be physically present or electronically accessible at the source location for a minimum of three (3) years. The records may be stored elsewhere for the remaining two (2) years as long as they are available upon request. If the Commissioner makes a request for records to the Permittee, the Permittee shall furnish the records to the Commissioner within a reasonable time.
- (b) Unless otherwise specified in this permit, all record keeping requirements not already legally required shall be implemented within ninety (90) days of permit issuance.

### **C.18 General Reporting Requirements [326 IAC 2-8-4(3)(C)] [326 IAC 2-1.1-11]**

---

- (a) The source shall submit the attached Quarterly Deviation and Compliance Monitoring Report or its equivalent. Any deviation from permit requirements, the date(s) of each deviation, the cause of the deviation, and the response steps taken must be reported. This report shall be submitted within thirty (30) days of the end of the reporting period. The Quarterly Deviation and Compliance Monitoring Report shall include the certification by an "authorized individual" as defined by 326 IAC2-1.1-1(1).
- (b) The report required in (a) of this condition and reports required by conditions in Section D of this permit shall be submitted to:  
  
Indiana Department of Environmental Management  
Compliance Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251
- (c) Unless otherwise specified in this permit, any notice, report, or other submission required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.
- (d) Unless otherwise specified in this permit, all reports required in Section D of this permit shall be submitted within thirty (30) days of the end of the reporting period. All reports do require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (e) The first report covered the period commencing on the date of issuance of the original FESOP and ended on the last day of the reporting period. All subsequent reporting periods shall be based on calendar years, unless otherwise specified in this permit. For the purpose of this permit "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.

## **Stratospheric Ozone Protection**

### **C.19 Compliance with 40 CFR 82 and 326 IAC 22-1**

---

Pursuant to 40 CFR 82 (Protection of Stratospheric Ozone), Subpart F, except as provided for motor vehicle air conditioners in Subpart B, the Permittee shall comply with the standards for recycling and emissions reduction:

- (a) Persons opening appliances for maintenance, service, repair or disposal must comply with the required practices pursuant to 40 CFR 82.156

- (b) Equipment used during the maintenance, service, repair or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to 40 CFR 82.158.
- (c) Persons performing maintenance, service, repair or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161.

## SECTION D.1 FACILITY OPERATION CONDITIONS – Grain Receiving and Handling Processes

### Facility Description [326 IAC 2-8-4(10)] – Grain Receiving and Handling Processes:

- (a) Three (3) corn dump pits, identified as EU001, constructed in 2006, each with a maximum throughput rate of 420 tons of corn per hour, controlled by baghouse CE001, and exhausting through stack EP001. This consists of two (2) truck dump pits and one (1) railcar dump pit.
- (b) One (1) grain handling operation, constructed in 2006, controlled by baghouse CE001, exhausting through stack EP001, and consisting of the following:
  - (1) One (1) corn conveyor, identified as EU002, with a maximum throughput rate of 420 tons per hour.
  - (2) One (1) corn elevator, identified as EU003, with a maximum throughput rate of 420 tons per hour.
  - (3) Two (2) corn storage bins, identified as EU004 and EU005, each with a maximum capacity of 200,000 bushels and maximum throughput rate of 420 tons per hour.
  - (4) One (1) scalper, identified as EU006, with a maximum throughput rate of 140 tons per hour.
  - (5) One (1) surge bin, identified as EU007, with a maximum throughput rate of 140 tons per hour.
  - (6) Two (2) corn storage bins, identified as EU064 and EU065, each with a maximum capacity of 425,000 bushels and maximum throughput rate of 420 tons per hour.
- (c) Two (2) hammermills, identified as EU010 and EU011, constructed in 2006, each with a maximum throughput rate of 140 tons of corn per hour, controlled by baghouse CE003, and exhausting through stack EP003.
- (i) One (1) DDGS loadout operation, constructed in 2006 with a maximum throughput rate of 101 tons per hour, controlled by baghouse CE008, exhausting to stack EP008, and consisting of the following:
  - (1) One (1) DDGS dump pit, identified as EU040.
  - (2) One (1) DDGS elevator, identified as EU041.
  - (3) One (1) DDGS conveyor, identified as EU042.
  - (4) One (1) DDGS load spout, identified as EU043.

### Insignificant Activity:

- (f) Paved roads and parking lots with public access. [326 IAC 6-4]

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

THIS SECTION OF THE PERMIT IS BEING ISSUED UNDER THE PROVISIONS OF 326 IAC 2-1 AND 326 IAC 2-8-11.1, WITH CONDITIONS LISTED BELOW.

### **Construction Conditions**

#### **General Construction Conditions**

##### **D.1.1 Permit No Defense**

This permit to construct does not relieve the Permittee of the responsibility to comply with the provisions of the Indiana Environmental Management Law (IC 13-11 through 13-20; 13-22 through 13-25; and 13-30), the Air Pollution Control Law (IC 13-17) and the rules promulgated thereunder, as well as other applicable local, state, and federal requirements.

##### **D.1.2 Federally Enforceable State Operating Permit [326 IAC 2-8]**

The attached Affidavit of Construction shall be submitted to the Office of Air Quality (OAQ), Permit Administration & Development Section, verifying that the emission units were constructed as proposed in the application.

#### **Effective Date of the Permit**

##### **D.1.3 Effective Date of the Permit [IC 13-15-5-3]**

Pursuant to IC 13-15-5-3, this section of this permit becomes effective upon its issuance.

##### **D.1.4 Modification to Construction Conditions [326 IAC 2]**

All requirements of these construction conditions shall remain in effect unless modified in a manner consistent with procedures established for revisions pursuant to 326 IAC 2.

### **Operation Conditions**

#### **Emission Limitations and Standards [326 IAC 2-8-4(1)]**

##### **D.1.5 PM and PM10 Emissions [326 IAC 2-2] [326 IAC 2-8-4]**

The PM and PM10 emissions from the following units shall not exceed the emission limits listed in the table below.

Unit ID	Unit Description	Baghouse ID	PM/PM10 Emission Limit (lbs/hr)
EU001 – EU007	Grain Receiving and Handling Operations	CE001	1.67
EU010 and EU011	Hammermills	CE003	1.20
EU040 - EU043	DDGS Handling and Loadout Operations	CE008	0.16

Combined with the PM10 emissions from other emission units, the PM10 emissions from the entire source are limited to less than 100 tons/yr. Combined with the PM emissions from other emission units, the PM emissions from the entire source are limited to less than 250 tons/yr. Therefore, the requirements of 326 IAC 2-7 (Part 70 Program) and 326 IAC 2-2 (PSD) are not applicable.

##### **D.1.6 Particulate Emission Limitations [326 IAC 6-3-2]**

Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), particulate emissions from each of following operations shall not exceed the pound per hour limits listed in the table below:

Unit ID	Unit Description	Max. Throughput Rate (tons/hr)	Particulate Emission Limit (lbs/hr)
EU001	Each of the Corn Dump Pits	420	66.9

Unit ID	Unit Description	Max. Throughput Rate (tons/hr)	Particulate Emission Limit (lbs/hr)
EU002	Corn Conveyor	420	66.9
EU003	Corn Elevator	420	66.9
EU004	Corn Storage Bin	420	66.9
EU005	Corn Storage Bin	420	66.9
EU006	Scalper	140	54.7
EU007	Surge Bin	140	54.7
EU010	Hammermill	140	54.7
EU011	Hammermill	140	54.7
EU040	DDGS Dump pit	101	51.4
EU041	DDGS Elevator	101	51.4
EU042	DDGS Conveyor	101	51.4
EU043	DDGS Load Spout	101	51.4
EU064	Corn Storage Bin	420	66.9
EU065	Corn Storage Bin	420	66.9

The pounds per hour limitations were calculated using the following equation:

Interpolation and extrapolation of the data for the process weight rate in excess of sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 55.0 P^{0.11} - 40 \quad \text{where } E = \text{rate of emission in pounds per hour; and} \\ P = \text{process weight rate in tons per hour}$$

Pursuant to 326 IAC 6-3-2(e)(3), when the process weight exceeds 200 tons per hour, the maximum allowable emission may exceed the emission limits shown in the table above, provided the concentration of particulate matter in the gas discharged to the atmosphere is less than 0.10 pounds per 1,000 pounds of gases.

**D.1.7 Preventive Maintenance Plan [326 IAC 2-8-4(9)]**

A Preventive Maintenance Plan, in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for these facilities and any control devices.

**Compliance Determination Requirements**

**D.1.8 Particulate Control**

- (a) In order to comply with Conditions D.1.5(a) and D.1.6, each of the following emission units shall be controlled by the associated baghouse, as listed in the table below, when these units are in operation:

Unit ID	Unit Description	Baghouse ID
EU001 - EU007, EU064 and EU065	Grain Receiving and Handling Operations	CE001
EU010 and EU011	Hammermills	CE003
EU040 - EU043	DDGS Handling and Loadout Operations	CE008

- (b) In the event that bag failure is observed in a multi-compartment baghouse, if operations will continue for ten (10) days or more after the failure is observed before the failed units will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed units will be repaired or replaced. The notification shall also include the status of the applicable compliance monitoring parameters with respect to normal, and the results of any response actions taken up to the time of notification.

#### D.1.9 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11]

---

In order to demonstrate compliance with Conditions D.1.5(a) and D.1.6, the Permittee shall perform PM and PM10 testing for baghouses CE001, CE003, and CE008 within 60 days after achieving the maximum capacity, but not later than 180 days after initial startup, utilizing methods as approved by the Commissioner. These tests shall be repeated at least once every five (5) years from the date of this valid compliance demonstration. PM-10 includes filterable and condensable PM-10. Testing shall be conducted in accordance with Section C - Performance Testing.

#### Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

##### D.1.10 Visible Emissions Notations

---

- (a) Visible emission notations of the baghouse stack exhausts (stacks EP001, EP003, and EP008) shall be performed once per day during normal daylight operations. A trained employee shall record whether emissions are normal or abnormal.
- (b) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.
- (c) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- (d) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.
- (e) If abnormal emissions are observed, the Permittee shall take reasonable response steps in accordance with Section C- Response to Excursions or Exceedances. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances shall be considered a deviation from this permit.

##### D.1.11 Parametric Monitoring

---

The Permittee shall record the pressure drop across the baghouses used in conjunction with corn dump pits (EU001), the grain handling operation (EU002 through EU007, EU064, and EU065), the hammermills (EU010 and EU011), and the DDGS loadout operation (EU040 through EU043), at least once per day when these units are in operation. When for any one reading, the pressure drop across the baghouse is outside the normal range of 1.0 to 6.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances shall be considered a deviation from this permit.

The instrument used for determining the pressure shall comply with Section C - Instrument Specifications, of this permit, shall be subject to approval by IDEM, OAQ and shall be calibrated at least once every six (6) months.

##### D.1.12 Broken or Failed Bag Detection

---

- (a) For a single compartment baghouse controlling emissions from a process operated continuously, a failed unit and the associated process shall be shut down immediately until the failed unit has been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).
- (b) For a single compartment baghouse controlling emissions from a batch process, the feed to the process shall be shut down immediately until the failed unit has been repaired or replaced. The emissions unit shall be shut down no later than the completion of the

processing of the material in the line. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).

Bag failure can be indicated by a significant drop in the baghouse=s pressure reading with abnormal visible emissions, by an opacity violation, or by other means such as gas temperature, flow rate, air infiltration, leaks, dust traces or triboflows.

### **Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]**

#### **D.1.13 Record Keeping Requirements**

---

- (a) To document compliance with Condition D.1.10, the Permittee shall maintain records of daily visible emission notations of the baghouse stack exhausts. The Permittee shall include in its daily record when a visible emission notation is not taken and the reason for the lack of visible emission notation (e.g. the process did not operate that day).
- (b) To document compliance with Condition D.1.11, the Permittee shall maintain daily records of the pressure drop during normal operation. The Permittee shall include in its daily record when a pressure drop reading is not taken and the reason for the lack of a pressure drop reading (e.g. the process did not operate that day).
- (c) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

## SECTION D.2 FACILITY OPERATION CONDITIONS – Fermentation Process

### Facility Description [326 IAC 2-8-4(10)]:

- (d) One (1) fermentation process, constructed in 2006, with a maximum throughput rate of 7,060 gallons of ethanol per hour, controlled by CO<sub>2</sub> scrubber CE005, exhausting through stack EP005, and consisting of the following:
- (1) Five (5) fermenters, identified as EU016, EU017, EU018, EU019, and EU057.
  - (2) One (1) beer well, identified as EU020.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

THIS SECTION OF THE PERMIT IS BEING ISSUED UNDER THE PROVISIONS OF 326 IAC 2-1 AND 326 IAC 2-8-11.1, WITH CONDITIONS LISTED BELOW.

### ***Construction Conditions***

#### **General Construction Conditions**

##### D.2.1 Permit No Defense

This permit to construct does not relieve the Permittee of the responsibility to comply with the provisions of the Indiana Environmental Management Law (IC 13-11 through 13-20; 13-22 through 13-25; and 13-30), the Air Pollution Control Law (IC 13-17) and the rules promulgated thereunder, as well as other applicable local, state, and federal requirements.

##### D.2.2 Federally Enforceable State Operating Permit [326 IAC 2-8]

The attached Affidavit of Construction shall be submitted to the Office of Air Quality (OAQ), Permit Administration & Development Section, verifying that the emission units were constructed as proposed in the application.

#### **Effective Date of the Permit**

##### D.2.3 Effective Date of the Permit [IC 13-15-5-3]

Pursuant to IC 13-15-5-3, this section of this permit becomes effective upon its issuance.

##### D.2.4 Modification to Construction Conditions [326 IAC 2]

All requirements of these construction conditions shall remain in effect unless modified in a manner consistent with procedures established for revisions pursuant to 326 IAC 2.

### ***Operation Conditions***

#### **Emission Limitations and Standards [326 IAC 2-8-4(1)]**

##### D.2.5 VOC and HAP Emissions [326 IAC 2-2] [326 IAC 2-8-4] [326 IAC 2-4.1]

Pursuant to 326 IAC 2-8-4 (FESOP), emissions from wet scrubber CE005, which is used to control the emissions from the fermentation process shall comply with the following:

- (a) VOC emissions shall not exceed 7.62 lbs/hr.
- (b) Acetaldehyde emissions shall not exceed 1.72 lbs/hr.
- (c) Total HAP emissions shall not exceed 1.74 lbs/hr.

Combined with the VOC and HAP emissions from other units, the VOC emissions from the entire source are limited to less than 100 tons/yr, and the HAP emissions from the entire source are limited to less than 10 tons/yr for a single HAP and less than 25 tons/yr for total HAPs. Therefore,

the requirements of 326 IAC 2-7 (Part 70 Program), 326 IAC 2-2 (PSD), and 326 IAC 2-4.1 (MACT) are not applicable.

#### D.2.6 VOC Emissions [326 IAC 8-5-6]

---

Pursuant to 326 IAC 8-5-6 (Fuel Grade Ethanol Production at Dry Mills), the Permittee shall comply with the following:

- (a) The VOC emissions from the fermentation process shall be controlled by wet scrubber CE005.
- (b) The overall VOC control efficiency for the wet scrubber CE005 (including the capture efficiency and adsorption efficiency) shall be at least 98% or the VOC emissions from scrubber CE005 shall not exceed 20 ppmv.

#### D.2.7 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]

---

The provisions of 40 CFR 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the facility described in Condition D.2.8 except when otherwise specified in 40 CFR 60, Subpart VV.

#### D.2.8 Equipment Leaks of VOC [326 IAC 12][40 CFR 60, Subpart VV]

---

Pursuant to 40 CFR 60, Subpart VV, the Permittee shall comply with the requirement of - Section E.1 for pumps; compressors; pressure relief devices in gas/vapor service; sampling connection systems; open-ended valves or lines; and valves.

#### D.2.9 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

---

A Preventive Maintenance Plan, in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for these facilities and any control devices.

### **Compliance Determination Requirements**

#### D.2.10 VOC and HAP Control

---

In order to comply with Conditions D.2.5 and D.2.6, wet scrubber CE005 shall be in operation and control emissions from the fermentation process at all times that this process is in operation.

#### D.2.11 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11][326 IAC 8-5-6]

---

In order to verify compliance with Conditions D.2.5 and D.2.6, the Permittee shall perform VOC (including emission rate, adsorption efficiency, and capture efficiency) and acetaldehyde testing for scrubber CE005 within 60 days after achieving the maximum capacity, but not later than 180 days after initial startup, utilizing methods as approved by the Commissioner. These tests shall be repeated at least once every five (5) years from the date of this valid compliance demonstration. Testing shall be conducted in accordance with Section C - Performance Testing.

### **Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]**

#### D.2.12 Parametric Monitoring [326 IAC 8-5-6]

---

The Permittee shall monitor and record the pressure drop and flow rate of scrubber CE005, at least once per day when the associated fermentation process is in operation. When for any one reading, the pressure drop across the scrubber is outside the normal range of 1.0 and 6.0 inches of water, or a range established during the latest stack test, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. When for any one reading, the flow rate of any of the scrubbers is less than the minimum of 20 gallons per minute, or a minimum established during the latest stack test, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. A pressure reading that is outside the above mention range or a flow rate that is below the above mentioned minimum is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances shall be considered a deviation from this permit.

The instruments used for determining the pressure drop and flow rate shall comply with Section C - Instrument Specifications, of this permit, shall be subject to approval by IDEM, OAQ, and shall be calibrated at least once every six (6) months.

#### D.2.13 Scrubber Detection

---

In the event that a scrubber malfunction has been observed:

Failed units and the associated process will be shut down immediately until the failed units have been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions). Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances shall be considered a deviation from this permit.

### **Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]**

#### D.2.14 Record Keeping Requirements [326 IAC 8-5-6]

---

- (a) To document compliance with Condition D.2.12, the Permittee shall maintain daily records of pressure drop and flow rate for scrubber CE005 during normal operation. The Permittee shall include in its daily record when a pressure drop or flow rate reading is not taken and the reason for the lack of a pressure drop or flow rate reading (e.g. the process did not operate that day).
- (b) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

### SECTION D.3 FACILITY OPERATION CONDITIONS – TO/HRSG System and DDGS Drying Process

#### Facility Description [326 IAC 2-8-4(10)]:

- (e) One (1) thermal oxidizer with heat recovery steam generator (TO/HRSG) system, identified as CE007, constructed in 2006, with a maximum heat input capacity of 135 MMBtu/hr, using natural gas and process waste gases from the DDGS dryers as fuels, with emissions exhausted through stack EP007.
- (f) One (1) distillation process, constructed in 2006, with a maximum throughput rate of 6,850 gallons of ethanol per hour, controlled by TO/HRSG system CE007, exhausting through stack EP007, and consisting of the following:
  - (1) Two (2) slurry mixers, identified as EU049 and EU058.
  - (2) One (1) slurry tank, identified as EU050.
  - (3) Three (3) liquefaction tanks, identified as EU014, EU051, and EU059, each with a maximum capacity of 7,000 gallons per hour.
  - (4) One (1) cook tube, identified as EU052.
  - (5) One (1) flash tank, identified as EU053.
  - (6) One (1) yeast tank, identified as EU015.
  - (7) One (1) 190 proof condenser, identified as EU054.
  - (8) One (1) 200 proof condenser, identified as EU055.
  - (9) One (1) beer stripper, identified as EU021.
  - (10) One (1) side stripper, identified as EU022.
  - (11) One (1) rectifier, identified as EU023.
  - (12) Molecular sieve units, identified as EU024.
  - (13) Eight (8) evaporators, identified as EU025.
  - (14) Four (4) centrifuges, identified as EU026 through EU029.
- (g) Two (2) natural gas fired DDGS dryers, identified as EU035 and EU056, constructed in 2006, each with a maximum heat input rate of 45 MMBtu/hr and a maximum throughput rate of 34 tons of DDGS per hour, controlled by multiclone CE006, with emissions venting to TO/HRSG system CE007, and exhausting to stack EP007.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

THIS SECTION OF THE PERMIT IS BEING ISSUED UNDER THE PROVISIONS OF 326 IAC 2-1 AND 326 IAC 2-8-11.1, WITH CONDITIONS LISTED BELOW.

## **Construction Conditions**

### **General Construction Conditions**

#### **D.3.1 Permit No Defense**

---

This permit to construct does not relieve the Permittee of the responsibility to comply with the provisions of the Indiana Environmental Management Law (IC 13-11 through 13-20; 13-22 through 13-25; and 13-30), the Air Pollution Control Law (IC 13-17) and the rules promulgated thereunder, as well as other applicable local, state, and federal requirements.

#### **D.3.2 Federally Enforceable State Operating Permit [326 IAC 2-8]**

---

The attached Affidavit of Construction shall be submitted to the Office of Air Quality (OAQ), Permit Administration & Development Section, verifying that the emission units were constructed as proposed in the application.

### **Effective Date of the Permit**

#### **D.3.3 Effective Date of the Permit [IC 13-15-5-3]**

---

Pursuant to IC 13-15-5-3, this section of this permit becomes effective upon its issuance.

#### **D.3.4 Modification to Construction Conditions [326 IAC 2]**

---

All requirements of these construction conditions shall remain in effect unless modified in a manner consistent with procedures established for revisions pursuant to 326 IAC 2.

## **Operation Conditions**

### **Emission Limitations and Standards [326 IAC 2-8-4(1)]**

#### **D.3.5 FESOP Limits [326 IAC 2-2] [326 IAC 2-8-4] [326 IAC 2-4.1]**

---

Pursuant to 326 IAC 2-8-4 (FESOP) and in order to make the requirements of 326 IAC 2-2 (PSD) not applicable, emissions from TO/HRSG System CE007, which is used to control the DDGS dryers (EU035 and EU056) and the distillation process shall not exceed the following:

- (a) PM/PM10 emissions shall not exceed 8.0 lbs/hr.
- (b) VOC emissions shall not exceed 7.5 lbs/hr.
- (c) CO emissions shall not exceed 21.0 lbs/hr.
- (d) SO<sub>2</sub> emissions shall not exceed not exceed 8.5 lbs/hr.
- (e) NO<sub>x</sub> emissions shall not exceed 19.7 lbs/hr.
- (f) Acetaldehyde emissions shall not exceed 0.32 lbs/hr.
- (g) Total HAP emissions shall not exceed 0.69 lbs/hr.

Combined with the PM/PM10, VOC, SO<sub>2</sub>, CO, NO<sub>x</sub>, and HAP emissions from other units, the PM/PM10, SO<sub>2</sub>, VOC, CO, NO<sub>x</sub> emissions from the entire source are each limited to less than 100 tons/yr and the HAP emissions from the entire source are limited to less than 10 tons/yr for a single HAP and less than 25 tons/yr for total HAPs. Therefore, the requirements of 326 IAC 2-7 (Part 70 Program), 326 IAC 2-2 (PSD), and 326 IAC 2-4.1 (MACT) are not applicable.

#### **D.3.6 VOC Emissions [326 IAC 8-5-6]**

---

Pursuant to 326 IAC 8-5-6 (Fuel Grade Ethanol Production at Dry Mills), the Permittee shall comply with the following:

- (a) The VOC emissions from the DDGS dryers (EU035 and EU056) and the distillation process shall be controlled by TO/HRSG system CE007.

- (b) The overall efficiency for the thermal oxidizer CE007 (including the capture efficiency and destruction efficiency) shall be at least 98% or the maximum outlet VOC concentration shall not exceed 10 ppmv.

**D.3.7 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]**

---

The provisions of 40 CFR Part 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the TO/HRSG system CE007 except when otherwise specified in 40 CFR Part 60, Subpart Db.

**D.3.8 NOx Emissions [326 IAC 12-1][40 CFR 60, Subpart Db]**

---

- (a) Pursuant to 40 CFR 60.44b, the NOx emissions from the TO/HRSG system (CE007) shall not exceed 0.1 lbs/MMBtu.
- (b) Pursuant to 40 CFR 60.48b(b), except for 40 CFR 60.48b(g), (h), and (i), the Permittee shall install, calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring nitrogen oxides emissions discharged to the atmosphere.

**D.3.9 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]**

---

The provisions of 40 CFR 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the facility described in Condition D.3.10 except when otherwise specified in 40 CFR 60, Subpart VV.

**D.3.10 Equipment Leaks of VOC [326 IAC 12][40 CFR 60, Subpart VV]**

---

Pursuant to 40 CFR 60, Subpart VV, the Permittee shall comply with the requirement of Section E.1 for pumps; compressors; pressure relief devices in gas/vapor service; sampling connection systems; open-ended valves or lines; and valves.

**D.3.11 Particulate Emissions [326 IAC 6-2-4]**

---

Pursuant to 326 IAC 6-2-4 (Particulate Emission Limitations for Sources of Indirect Heating), particulate emissions from the 135 MMBtu/hr TO/HRSG system (CE007) shall be limited to 0.30 pounds per MMBtu heat input.

The limit was calculated using the following equation:

$$Pt = \frac{1.09}{Q^{0.26}}$$

Where Pt = emission rate limit (lbs/MMBtu)  
Q = total source heat input capacity (MMBtu/hr)

**D.3.12 Particulate Emission Limitations [326 IAC 6-3-2]**

---

Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), particulate emissions from each of following operations shall not exceed the pound per hour limits listed in the table below:

Unit ID	Unit Description	Max. Throughput Rate (tons/hr)	Particulate Emission Limit (lbs/hr)
EU035	DDGS Dryer	34	41.1
EU056	DDGS Dryer	34	41.1

The pounds per hour limitations were calculated using the following equations:

Interpolation and extrapolation of the data for the process weight rate in excess of sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 55.0 P^{0.11} - 40 \quad \text{where } E = \text{rate of emission in pounds per hour; and} \\ P = \text{process weight rate in tons per hour}$$

#### D.3.13 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

---

A Preventive Maintenance Plan, in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for these facilities and any control devices.

### Compliance Determination Requirements

#### D.3.14 PM and PM10 Control

---

In order to comply with Conditions D.3.5, D.3.11, and D.3.12, cyclone CE006 shall be in operation and control emissions from the DDGS dryers (EU035 and EU056) at all times that these units are in operation.

#### D.3.15 VOC and HAP Control

---

In order to comply with Conditions D.3.5 and D.3.6, thermal oxidizer CE007 shall be in operation and control emissions from the DDGS dryers (EU035 and EU056) and the distillation process at all times that these units are in operation.

#### D.3.16 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11 [326 IAC 2-2] [40 CFR 60, Subpart Db] [326 IAC 8-5-6]

---

- (a) In order to demonstrate compliance with Conditions D.3.5, D.3.6, D.3.11, and D.3.12, the Permittee shall perform PM, PM10, VOC (including emission rate, destruction efficiency, and capture efficiency), SO<sub>2</sub>, CO, NO<sub>x</sub>, and Acetaldehyde testing for thermal oxidizer CE007 within 60 days after achieving the maximum capacity, but not later than 180 days after initial startup, utilizing methods as approved by the Commissioner. PM-10 includes filterable and condensable PM-10. These tests shall be repeated at least once every five (5) years from the date of this valid compliance demonstration. Testing shall be conducted in accordance with Section C - Performance Testing.
- (b) In order to demonstrate compliance with Condition D.3.8(a) and pursuant to 40 CFR 60.46b(e), the Permittee shall conduct the performance test as required under 40 CFR 60.8 using the continuous system for monitoring nitrogen oxides under 40 CFR 60.48(b). For the initial compliance test, nitrogen oxides from the TO/HRSG system stack (EP007) are monitored for 30 successive steam generating unit operating days and the 30-day average emission rate is used to determine compliance with the nitrogen oxides emission standards under 40 CFR 60.44b. Following the date on which the initial performance test is completed, the Permittee shall upon request determine compliance with the nitrogen oxides standards under 40 CFR 60.44b through the use of a 30-day performance test.

### Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

#### D.3.17 Continuous Emissions Monitoring [326 IAC 3-5] [326 IAC 12] [40 CFR 60, Subpart Db]

---

- (a) Pursuant to 326 IAC 3-5 (Continuous Monitoring of Emissions) and 40 CFR 60.47b and 60.48b, a continuous monitoring system shall be calibrated, maintained, and operated for measuring NO<sub>x</sub>, which meets the performance specifications of 326 IAC 3-5-2.
- (b) Pursuant to 326 IAC 3-5-4, if revisions are made to the continuous monitoring standard operating procedures (SOP), the Permittee shall submit updates to the department biennially.
- (c) Nothing in this permit shall excuse the Permittee from complying with the requirements to operate a continuous emission monitoring system pursuant to 326 IAC 3-5, or 40 CFR 60.

#### D.3.18 Visible Emissions Notations

---

- (a) Visible emission notations of the stack exhaust from the TO/HRSG system stack EP007 shall be performed once per day during normal daylight operations. A trained employee shall record whether emissions are normal or abnormal.
- (b) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.
- (c) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- (d) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.
- (e) If abnormal emissions are observed, the Permittee shall take reasonable response steps in accordance with Section C- Response to Excursions or Exceedances. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances shall be considered a deviation from this permit.

#### D.3.19 Thermal Oxidizer Temperature [326 IAC 8-5-6]

---

- (a) A continuous monitoring system shall be calibrated, maintained, and operated on the TO/HRSG system (CE007) for measuring operating temperature. For the purpose of this condition, continuous means no less than once per minute. The output of this system shall be recorded as a 3-hour average. From the date of issuance of this permit until the approved stack test results are available, the Permittee shall operate the thermal oxidizer at or above the 3-hour average temperature of 1,400°F.
- (b) The Permittee shall determine the 3-hour average temperature from the most recent valid stack test that demonstrates compliance with limits in Conditions D.3.5 and D.3.6, as approved by IDEM.
- (c) On and after the date the approved stack test results are available, the Permittee shall operate the thermal oxidizer at or above the 3-hour average temperature as observed during the compliant stack test.

#### D.3.20 Parametric Monitoring [326 IAC 8-5-6]

---

- (a) The Permittee shall determine the appropriate duct pressure or fan amperage from the most recent valid stack test that demonstrates compliance with limits in Conditions D.3.5 and D.3.6, as approved by IDEM.
- (b) The duct pressure or fan amperage shall be observed at least once per day when the thermal oxidizer/heat recovery steam generator is in operation. On and after the date the approved stack test results are available, the duct pressure or fan amperage shall be maintained within the normal range as established in most recent compliant stack test.

### **Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]**

#### D.3.21 Record Keeping Requirements [326 IAC 8-5-6]

---

- (a) To document compliance with Conditions D.3.5(e), D.3.8(a), and D.3.17, the Permittee shall maintain records of the NOx emissions in accordance with 40 CFR 60.49b.
- (b) To document compliance with Condition D.3.18, the Permittee shall maintain records of daily visible emission notations of the stack EP007. The Permittee shall include in its daily record when a visible emission notation is not taken and the reason for the lack of visible emission notation (e.g. the process did not operate that day).

- (c) To document compliance with Condition D.3.19, the Permittee shall maintain continuous temperature records for the thermal oxidizer and the 3-hour average temperature used to demonstrate compliance during the most recent compliant stack test.
- (d) To document compliance with Condition D.3.20, the Permittee shall maintain daily records of the duct pressure or fan amperage for the TO/HRSG system CE007. The Permittee shall include in its daily record when a duct pressure or fan amperage reading is not taken and the reason for the lack of a duct pressure or fan amperage reading (e.g. the process did not operate that day).
- (e) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

D.3.22 Recordkeeping Requirements [40 CFR 60, Subpart Db] [326 IAC 12]

- (a) Pursuant to 40 CFR 60.49b(d), the Permittee shall record and maintain records of the amounts of each fuel combusted during each day and calculate the annual capacity factor individually for natural gas for the reporting period. The annual capacity factor is determined on a 12-month rolling average basis with a new annual capacity factor calculated at the end of each calendar month.
- (b) Pursuant to 40 CFR 60.49b(g), the Permittee shall maintain records of the following information for each steam generating unit operating day:
  - (1) Calendar date.
  - (2) The average hourly nitrogen oxides emission rates (expressed as NO<sub>2</sub>) (ng/J or lb/million Btu heat input) measured or predicted.
  - (3) The 30-day average nitrogen oxides emission rates (ng/J or lb/million Btu heat input) calculated at the end of each steam generating unit operating day from the measured or predicted hourly nitrogen oxide emission rates for the preceding 30 steam generating unit operating days.
  - (4) Identification of the steam generating unit operating days when the calculated 30-day average nitrogen oxides emission rates are in excess of the nitrogen oxides emissions standards under 40 CFR 60.44b, with the reasons for such excess emissions as well as a description of corrective actions taken.
  - (5) Identification of the steam generating unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken.
  - (6) Identification of the times when emission data have been excluded from the calculation of average emission rates and the reasons for excluding data.
  - (7) Identification of "F" factor used for calculations, method of determination, and type of fuel combusted.
  - (8) Identification of the times when the pollutant concentration exceeded full span of the continuous monitoring system.
  - (9) Description of any modifications to the continuous monitoring system that could affect the ability of the continuous monitoring system to comply with Performance Specification 2 or 3.
  - (10) Results of daily CEMS drift tests and quarterly accuracy assessments as required under appendix F, Procedure 1.

- (c) All records shall be maintained in accordance with Section C – General Recordkeeping Requirements, of this permit.

**D.3.23 Reporting Requirements [40 CFR 60, Subpart Db] [326 IAC 12]**

---

- (a) Pursuant to 40 CFR 60.49b(a), the Permittee shall submit notification of the date of initial startup, as provided by 40 CFR 60.7. This notification shall include the information specified in 40 CFR 60.49b(a)(1) through (4).
- (b) Pursuant to 40 CFR 60.49b(b), the Permittee shall submit the performance test data from the initial performance test and the performance evaluation of the CEMS using the applicable performance specifications in appendix B. The Permittee shall submit to the Administrator the maximum heat input capacity data from the demonstration of the maximum heat input capacity of the affected facility.
- (c) Pursuant to 40 CFR 60.49b(h), the Permittee shall submit excess emission reports for any excess emissions which occurred during the reporting period.
- (d) Pursuant to 40 CFR 60.49b(i), the Permittee shall submit reports containing the information recorded under 40 CFR 60.49b(g) and Condition D.3.22(b).
- (e) Pursuant to 40 CFR 60.49b(v), the Permittee may submit electronic quarterly reports for NO<sub>x</sub> in lieu of submitting the written reports required. The format of each quarterly electronic report shall be coordinated with IDEM, OAQ. The electronic report(s) shall be submitted no later than 30 days after the end of the calendar quarter and shall be accompanied by a certification statement from the owner or operator, indicating whether compliance with the applicable emission standards and minimum data requirements of this subpart was achieved during the reporting period. Before submitting reports in the electronic format, the Permittee shall coordinate with IDEM, OAQ to obtain their agreement to submit reports in this alternative format.
- (f) Pursuant to 40 CFR 60.49b(w), the Permittee is required to submit the above reports each six (6) month period. All reports shall be submitted to the Administrator and shall be postmarked by the 30th day following the end of the reporting period.

## SECTION D.4 FACILITY OPERATION CONDITIONS – DDGS Cooler

### Facility Description [326 IAC 2-8-4(10)] :

- (h) One (1) DDGS cooler, identified as EU036, constructed in 2006, with a maximum throughput rate of 34 tons/hr of DDGS, controlled by baghouse CE014, and exhausting to stack EP014.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

THIS SECTION OF THE PERMIT IS BEING ISSUED UNDER THE PROVISIONS OF 326 IAC 2-1 AND 326 IAC 2-8-11.1, WITH CONDITIONS LISTED BELOW.

### **Construction Conditions**

#### **General Construction Conditions**

##### D.4.1 Permit No Defense

This permit to construct does not relieve the Permittee of the responsibility to comply with the provisions of the Indiana Environmental Management Law (IC 13-11 through 13-20; 13-22 through 13-25; and 13-30), the Air Pollution Control Law (IC 13-17) and the rules promulgated thereunder, as well as other applicable local, state, and federal requirements.

##### D.4.2 Federally Enforceable State Operating Permit [326 IAC 2-8]

The attached Affidavit of Construction shall be submitted to the Office of Air Quality (OAQ), Permit Administration & Development Section, verifying that the emission units were constructed as proposed in the application.

#### **Effective Date of the Permit**

##### D.4.3 Effective Date of the Permit [IC 13-15-5-3]

Pursuant to IC 13-15-5-3, this section of this permit becomes effective upon its issuance.

##### D.4.4 Modification to Construction Conditions [326 IAC 2]

All requirements of these construction conditions shall remain in effect unless modified in a manner consistent with procedures established for revisions pursuant to 326 IAC 2.

### **Operation Conditions**

#### **Emission Limitations and Standards [326 IAC 2-8-4(1)]**

##### D.4.5 PM and PM10 Emissions [326 IAC 2-2] [326 IAC 2-8-4]

Pursuant to 326 IAC 2-8-4 (FESOP) and in order to render the requirements of 326 IAC 2-2 (PSD) not applicable, the Permittee shall comply with the following:

- (a) The PM/PM10 emissions from the DDGS cooler, which is controlled by baghouse CE014, shall not exceed the 0.94 lbs/hr.
- (b) The total DDGS produced shall not exceed 210,000 tons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (3) VOC emissions shall not exceed 0.065 pounds per ton of DDGS produced.

Combined with the PM/PM10 and VOC emissions from other emission units, the PM/PM10 and VOC emissions from the entire source are limited to less than 100 tons/yr. Therefore, the requirements of 326 IAC 2-7 (Part 70 Program) and 326 IAC 2-2 (PSD) are not applicable.

#### D.4.6 Particulate Emission Limitations [326 IAC 6-3-2]

---

Pursuant to 326 IAC 6-3-2, particulate emissions from the DDGS cooler (EU036) shall not exceed 41.1 pounds per hour when operating at the maximum process throughput rate of 34 tons per hour.

The pounds per hour limitation was calculated using the following equation:

Interpolation and extrapolation of the data for the process weight rate in excess of sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 55.0 P^{0.11} - 40 \quad \text{where } E = \text{rate of emission in pounds per hour; and} \\ P = \text{process weight rate in tons per hour}$$

#### D.4.7 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

---

A Preventive Maintenance Plan, in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for this facility and any control device.

### Compliance Determination Requirements

#### D.4.8 Particulate Control

---

- (a) In order to comply with Conditions D.4.5(a) and D.4.6, Baghouse CE014 shall be in operation and control emissions from the DDGS cooler (CE036) at all times that this unit is in operation.
- (b) In the event that bag failure is observed in a multi-compartment baghouse, if operations will continue for ten (10) days or more after the failure is observed before the failed units will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed units will be repaired or replaced. The notification shall also include the status of the applicable compliance monitoring parameters with respect to normal, and the results of any response actions taken up to the time of notification.

#### D.4.9 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11]

---

In order to demonstrate compliance with Conditions D.4.5 and D.4.6, the Permittee shall perform PM, PM10, and VOC testing for the DDGS cooler (EU036) within 60 days after achieving the maximum capacity, but not later than 180 days after initial startup, utilizing methods as approved by the Commissioner. These tests shall be repeated at least once every five (5) years from the date of this valid compliance demonstration. Testing shall be conducted in accordance with Section C - Performance Testing. PM10 includes filterable and condensable PM10.

### Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

#### D.4.10 Visible Emissions Notations

---

- (a) Visible emission notations of the baghouse stack exhaust (stack EP014) shall be performed once per day during normal daylight operations. A trained employee or a trained contractor shall record whether emissions are normal or abnormal.
- (b) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.
- (c) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- (d) A trained employee or contractor is a person who has worked or trained at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.
- (e) If abnormal emissions are observed, the Permittee shall take reasonable response steps in accordance with Section C- Response to Excursions or Exceedances. Failure to take

response steps in accordance with Section C - Response to Excursions or Exceedances shall be considered a deviation from this permit.

#### D.4.11 Parametric Monitoring

---

The Permittee shall record the pressure drop across the baghouse used in conjunction with the DDGS cooler (EU036) at least once per day when this unit is in operation. When for any one reading, the pressure drop across the baghouse is outside the normal range of 1.0 to 6.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances shall be considered a deviation from this permit.

The instrument used for determining the pressure shall comply with Section C - Instrument Specifications, of this permit, shall be subject to approval by IDEM, OAQ and shall be calibrated at least once every six (6) months.

#### D.4.12 Broken or Failed Bag Detection

---

- (a) For a single compartment baghouse controlling emissions from a process operated continuously, a failed unit and the associated process shall be shut down immediately until the failed unit has been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).
- (b) For a single compartment baghouse controlling emissions from a batch process, the feed to the process shall be shut down immediately until the failed unit has been repaired or replaced. The emissions unit shall be shut down no later than the completion of the processing of the material in the line. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).

Bag failure can be indicated by a significant drop in the baghouse's pressure reading with abnormal visible emissions, by an opacity violation, or by other means such as gas temperature, flow rate, air infiltration, leaks, dust traces or triboflows.

### **Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]**

#### D.4.13 Record Keeping Requirements

---

- (a) To document compliance with Condition D.4.5(b), the Permittee shall maintain monthly records of the amount of DDGS produced.
- (b) To document compliance with Condition D.4.10, the Permittee shall maintain records of daily visible emission notations of the baghouse stack exhausts. The Permittee shall include in its daily record when a visible emission notation is not taken and the reason for the lack of visible emission notation (e.g. the process did not operate that day).
- (c) To document compliance with Condition D.4.11, the Permittee shall maintain daily records of pressure drop for baghouses during normal operation. The Permittee shall include in its daily record when a pressure drop reading is not taken and the reason for the lack of a pressure drop reading (e.g. the process did not operate that day).
- (d) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

#### D.4.14 Reporting Requirements

---

A quarterly summary of the information to document compliance with Condition D.4.5(b) shall be submitted to the address listed in Section C - General Reporting Requirements, of this permit, using the reporting forms located at the end of this permit, or their equivalent, within thirty (30)

days after the end of the quarter being reported. The report submitted by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

## SECTION D.5 FACILITY OPERATION CONDITIONS – Ethanol Loading Racks

### Facility Description [326 IAC 2-8-4(10)]:

- (j) One (1) ethanol loading rack for trucks, identified as EU045A, constructed in 2006, with a maximum throughput rate of 48,000 gallons per hour. The truck loading process is controlled by the enclosed flare CE009, which is fueled by natural gas and has a maximum heat input capacity of 10.0 MMBtu/hr, and exhausts through stack EP009.
- (k) One (1) ethanol loading rack for railcars, identified as EU045B, constructed in 2006, with a maximum throughput rate of 60,000 gallons per hour. Railcars are dedicated to carrying denatured ethanol.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

THIS SECTION OF THE PERMIT IS BEING ISSUED UNDER THE PROVISIONS OF 326 IAC 2-1 AND 326 IAC 2-8-11.1, WITH CONDITIONS LISTED BELOW.

### ***Construction Conditions***

#### **General Construction Conditions**

##### D.5.1 Permit No Defense

This permit to construct does not relieve the Permittee of the responsibility to comply with the provisions of the Indiana Environmental Management Law (IC 13-11 through 13-20; 13-22 through 13-25; and 13-30), the Air Pollution Control Law (IC 13-17) and the rules promulgated thereunder, as well as other applicable local, state, and federal requirements.

##### D.5.2 Federally Enforceable State Operating Permit [326 IAC 2-8]

The attached Affidavit of Construction shall be submitted to the Office of Air Quality (OAQ), Permit Administration & Development Section, verifying that the emission units were constructed as proposed in the application.

#### **Effective Date of the Permit**

##### D.5.3 Effective Date of the Permit [IC 13-15-5-3]

Pursuant to IC 13-15-5-3, this section of this permit becomes effective upon its issuance.

##### D.5.4 Modification to Construction Conditions [326 IAC 2]

All requirements of these construction conditions shall remain in effect unless modified in a manner consistent with procedures established for revisions pursuant to 326 IAC 2.

### ***Operation Conditions***

#### **Emission Limitations and Standards [326 IAC 2-8-4(1)]**

##### D.5.5 FESOP Limits [326 IAC 2-2] [326 IAC 2-8-4] [326 IAC 2-4.1]

Pursuant to 326 IAC 2-8-4 (FESOP), the Permittee shall comply with the following:

- (a) The total combined denatured ethanol and blended ethanol load-out from loading racks EU045A and EU045B shall not exceed 64,900,000 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (b) The total denaturant used at the loading racks EU045A and EU045B shall not exceed 4,900,000 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.

- (c) The total denatured ethanol load-out into non-dedicated railcars shall not exceed 2,500,000 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (d) The blended ethanol shall not exceed a blend of 30% gasoline.
- (e) No ethanol that exceeds 5% gasoline shall be loaded out to non-dedicated railcars.
- (f) The Permittee shall use flare CE009 to control the emissions from the ethanol loading rack for trucks (EU045A).
- (g) CO emissions from flare CE009 shall not exceed 0.129 lbs/kgal.
- (h) NOx emissions from flare CE009 shall not exceed 0.077 lbs/kgal.
- (i) The ethanol loading racks (EU045A and EU045B) shall utilize submerged loading method.
- (j) The railcars and trucks shall not use vapor balance services.

Combined with the VOC, CO, NOx, and HAP emissions from other units, the VOC, NOx and CO emissions from the entire source are limited to less than 100 tons/yr, and total HAP emissions from the entire source are limited to less than 10 tons/yr for a single HAP and less than 25 tons/yr for total HAPs. Therefore, the requirements of 326 IAC 2-7 (Part 70 Program), 326 IAC 2-2 (PSD), and 326 IAC 2-4.1 (MACT) are not applicable.

#### D.5.6 VOC Emissions [326 IAC 8-5-6]

Pursuant to 326 IAC 8-5-6 (Fuel Grade Ethanol Production at Dry Mills), the Permittee shall comply with the following:

- (a) The VOC emissions from the ethanol loading rack for trucks (EU045A) shall be collected and controlled by enclosed flare CE009.
- (b) The overall efficiency for the enclosed flare CE009 (including the capture efficiency and destruction efficiency) shall be at least 98%.

#### D.5.7 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]

The provisions of 40 CFR 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the facility described in Condition D.5.8 except when otherwise specified in 40 CFR 60, Subpart VV.

#### D.5.8 Equipment Leaks of VOC [326 IAC 12][40 CFR 60, Subpart VV]

Pursuant to 40 CFR 60, Subpart VV, the Permittee shall comply with the requirement of Section E.1 for pumps; compressors; pressure relief devices in gas/vapor service; sampling connection systems; open-ended valves or lines; and valves.

#### D.5.9 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

A Preventive Maintenance Plan, in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for this facility and any control device.

### **Compliance Determination Requirements**

#### D.5.10 VOC and HAP Control

In order to comply with Conditions D.5.5 and D.5.6, enclosed flare CE009 shall be in operation and control emissions from the ethanol loading rack for trucks (EU045A) at all times when this rack is in operation.

**D.5.11 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11] [326 IAC 2-2] [326 IAC 8-5-6]**

---

In order to demonstrate compliance with Conditions D.5.5 and D.5.6, the Permittee shall perform VOC (including emission rate, capture efficiency, and destruction efficiency), CO, and NOx testing for enclosed flare CE009 within 60 days after achieving the maximum production, but not later than 180 days after initial startup, utilizing methods as approved by the Commissioner. These tests shall be repeated at least once every five (5) years from the date of this valid compliance demonstration. Testing shall be conducted in accordance with Section C - Performance Testing.

**Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]**

**D.5.12 Flare Pilot Flame [326 IAC 8-5-6]**

---

In order to comply with Conditions D.5.5 and D.5.6, the Permittee shall monitor the presence of a flare pilot flame using a thermocouple or any other equivalent device to detect the presence of a flame when ethanol loading rack EU045A is in operation.

**Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]**

**D.5.13 Record Keeping Requirements [326 IAC 8-5-6]**

---

- (a) To document compliance with Condition D.5.5(a), the Permittee shall maintain monthly records of the total amount of denatured ethanol and blended ethanol loaded out from loading racks EU045A and EU045B.
- (b) To document compliance with Condition D.5.5(b), the Permittee shall maintain monthly records of total denaturant used at loading racks EU045A and EU045B.
- (c) To document compliance with Condition D.5.5(c), the Permittee shall maintain monthly records of total denatured ethanol load-out into non-dedicated railcars.
- (d) To document compliance with Condition D.5.5(d) and (e), the Permittee shall maintain monthly records of the specifications of the blended ethanol loaded out to truck and rail.
- (e) To document compliance with Condition D.5.12, the Permittee shall maintain records of temperature or other parameters sufficient to demonstrate the presence of a pilot flame when loading rack EU045A is in operation.
- (f) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

**D.5.14 Reporting Requirements**

---

A quarterly summary of the information to document compliance with Condition D.5.5(a), (b), and (c) shall be submitted to the address listed in Section C - General Reporting Requirements, of this permit, using the reporting forms located at the end of this permit, or their equivalent, within thirty (30) days after the end of the quarter being reported. The report submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

## SECTION D.6 FACILITY OPERATION CONDITIONS – Fire Pump and Biomethanator

### Facility Description [326 IAC 2-8-4(10)]: Insignificant Activities

- (h) Stationary fire pumps, including one (1) diesel fire pump, identified as EU034, constructed in 2006, with a maximum power output rate of 300 horsepower, and exhausting to stack EP006. [326 IAC 2-8-4]
- (j) Other emission units, not regulated by a NESHAP, with PM<sub>10</sub>, NO<sub>x</sub>, and SO<sub>2</sub> emissions less than five (5) pounds per hour or twenty-five (25) pounds per day, CO emissions less than twenty-five (25) pounds per day, VOC emissions less than three (3) pounds per hour or fifteen (15) pounds per day, lead emissions less than six-tenths (0.6) tons per year or three and twenty-nine hundredths (3.29) pounds per day, and emitting greater than one (1) pound per day but less than five (5) pounds per day or one (1) ton per year of a single HAP, or emitting greater than one (1) pound per day but less than twelve and five tenths (12.5) pounds per day or two and five tenths (2.5) ton per year of any combination of HAPs:
  - (7) One (1) biomethanator, identified as EU048, constructed in 2006, controlled by 6.0 MMBtu/hr biomethanator flare CE013, and exhausting to stack EP013. [326 IAC 2-8-4]

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-8-4(1)]

#### D.6.1 FESOP Limits [326 IAC 2-2] [326 IAC 2-8-4] [326 IAC 2-4.1]

Pursuant to 326 IAC 2-8-4 (FESOP), the Permittee shall comply with the following:

- (a) The operating hours for the diesel fire pump (EU034) shall not exceed 500 hours per twelve (12) consecutive month period with compliance determined at the end of each month.
- (b) The biomethanator flare (CE013) shall not operate when any of the DDGS dryers (EU035 and EU056) are in operation.

Combined with the CO and NO<sub>x</sub> emissions from other emission units, the CO and NO<sub>x</sub> emissions from the entire source are each limited to less than 100 tons/yr. Therefore, the requirements of 326 IAC 2-7 (Part 70 Program) and 326 IAC 2-2 (PSD) are not applicable.

### Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

#### D.6.2 Record Keeping Requirements

- (a) To document compliance with Condition D.6.1(a), the Permittee shall maintain monthly records of the operating hours for the diesel fire pump (EU034).
- (b) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

#### D.6.3 Reporting Requirements

A quarterly summary of the information to document compliance with Condition D.6.1(a) shall be submitted to the address listed in Section C - General Reporting Requirements, of this permit, using the reporting forms located at the end of this permit, or their equivalent, within thirty (30) days after the end of the quarter being reported. The report submitted by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

## SECTION D.7 FACILITY OPERATION CONDITIONS – Storage Tanks

### Facility Description [326 IAC 2-8-4(10)]:

#### Insignificant Activities

- (j) Other emission units, not regulated by a NESHAP, with PM<sub>10</sub>, NO<sub>x</sub>, and SO<sub>2</sub> emissions less than five (5) pounds per hour or twenty-five (25) pounds per day, CO emissions less than twenty-five (25) pounds per day, VOC emissions less than three (3) pounds per hour or fifteen (15) pounds per day, lead emissions less than six-tenths (0.6) tons per year or three and twenty-nine hundredths (3.29) pounds per day, and emitting greater than one (1) pound per day but less than five (5) pounds per day or one (1) ton per year of a single HAP, or emitting greater than one (1) pound per day but less than twelve and five tenths (12.5) pounds per day or two and five tenths (2.5) ton per year of any combination of HAPs:
- (1) One (1) 190 proof tank, identified as T001, constructed in 2006, with a maximum capacity of 100,000 gallons. [40 CFR 60, Subpart Kb]
  - (2) One (1) 200 proof tank, identified as T002, constructed in 2006, with a maximum capacity of 100,000 gallons. [40 CFR 60, Subpart Kb]
  - (3) One (1) denaturant tank, identified as T003, constructed in 2006, with a maximum capacity of 100,000 gallons. [40 CFR 60, Subpart Kb] [326 IAC 8-4-3]
  - (4) Two (2) denatured ethanol tanks, identified as T004 and T005, constructed in 2006, each with a maximum capacity of 750,000 gallons. [40 CFR 60, Subpart Kb]

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-8-4(1)]

#### D.7.1 Volatile Organic Compounds (VOC) [326 IAC 8-9]

Pursuant to 326 IAC 8-4-3(d) (Petroleum Liquid Storage Facilities), the Permittee shall maintain the following records for a period of two (2) years for tank T003:

- (a) The types of volatile petroleum liquid stored;
- (b) The maximum true vapor pressure of the liquids as stored; and
- (c) The results of the inspections performed on the storage vessels.

The above records shall be made available to the IDEM, OAQ upon written request.

#### D.7.2 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]

The provisions of 40 CFR 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the facility described in this section except when otherwise specified in 40 CFR 60, Subpart Kb.

#### D.7.3 Storage Tanks [326 IAC 12][40 CFR 60, Subpart Kb]

Pursuant to 40 CFR 60, Subpart Kb, the Permittee shall install internal floating roofs with tanks T001 through T005 and shall comply with the following requirements in 40 CFR 60.112b

(a)(1) for the internal floating roofs:

- (a) The internal floating roof shall rest or float on the liquid surface (but not necessarily in complete contact with it) inside a storage vessel that has a fixed roof. The internal floating roof shall be floating on the liquid surface at all times, except during initial fill and during

those intervals when the storage vessel is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible.

- (b) Each internal floating roof shall be equipped with one of the following closure devices between the wall of the storage vessel and the edge of the internal floating roof:
  - (1) A foam- or liquid-filled seal mounted in contact with the liquid (liquid-mounted seal). A liquid-mounted seal means a foam- or liquid-filled seal mounted in contact with the liquid between the wall of the storage vessel and the floating roof continuously around the circumference of the tank.
  - (2) Two seals mounted one above the other so that each forms a continuous closure that completely covers the space between the wall of the storage vessel and the edge of the internal floating roof. The lower seal may be vapor-mounted, but both must be continuous.
  - (3) A mechanical shoe seal. A mechanical shoe seal is a metal sheet held vertically against the wall of the storage vessel by springs or weighted levers and is connected by braces to the floating roof. A flexible coated fabric (envelope) spans the annular space between the metal sheet and the floating roof.
- (c) Each opening in a noncontact internal floating roof except for automatic bleeder vents (vacuum breaker vents) and the rim space vents is to provide a projection below the liquid surface.
- (d) Each opening in the internal floating roof except for leg sleeves, automatic bleeder vents, rim space vents, column wells, ladder wells, sample wells, and stub drains is to be equipped with a cover or lid which is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use.
- (e) Automatic bleeder vents shall be equipped with a gasket and are to be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports.
- (f) Rim space vents shall be equipped with a gasket and are to be set to open only when the internal floating roof is not floating or at the manufacturer's recommended setting.
- (g) Each penetration of the internal floating roof for the purpose of sampling shall be a sample well. The sample well shall have a slit fabric cover that covers at least 90 percent of the opening.
- (h) Each penetration of the internal floating roof that allows for passage of a column supporting the fixed roof shall have a flexible fabric sleeve seal or a gasketed sliding cover.
- (i) Each penetration of the internal floating roof that allows for passage of a ladder shall have a gasketed sliding cover.

#### D.7.4 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

---

A Preventive Maintenance Plan, in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for these facilities and any control devices.

## Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

### D.7.5 Testing and Procedures [40 CFR 60, Subpart Kb] [326 IAC 12]

---

Pursuant to 40 CFR 60.113b, the Permittee shall comply with the following requirement:

- (a) Visually inspect the internal floating roof, the primary seal, and the secondary seal (if one is in service), prior to filling the storage vessel with VOL. If there are holes, tears, or other openings in the primary seal, the secondary seal, or the seal fabric or defects in the internal floating roof, or both, the owner or operator shall repair the items before filling the storage vessel.
- (b) For vessels equipped with a liquid-mounted or mechanical shoe primary seal, visually inspect the internal floating roof and the primary seal or the secondary seal (if one is in service) through manholes and roof hatches on the fixed roof at least once every 12 months after initial fill. If the internal floating roof is not resting on the surface of the VOL inside the storage vessel, or there is liquid accumulated on the roof, or the seal is detached, or there are holes or tears in the seal fabric, the owner or operator shall repair the items or empty and remove the storage vessel from service within 45 days. If a failure that is detected during inspections required in this paragraph cannot be repaired within 45 days and if the vessel cannot be emptied within 45 days, a 30-day extension may be requested from the Administrator in the inspection report required in 40 CFR 60.115b(a)(3). Such a request for an extension must document that alternate storage capacity is unavailable and specify a schedule of actions the company will take that will assure that the control equipment will be repaired or the vessel will be emptied as soon as possible.
- (c) For vessels equipped with a double-seal system as specified in 40 CFR 60.112b(a)(1)(ii)(B):
  - (1) Visually inspect the vessel as specified in paragraph (a)(4) of this section at least every 5 years; or
  - (2) Visually inspect the vessel as specified in 40 CFR 60.113(a)(2).
- (d) Visually inspect the internal floating roof, the primary seal, the secondary seal (if one is in service), gaskets, slotted membranes and sleeve seals (if any) each time the storage vessel is emptied and degassed. If the internal floating roof has defects, the primary seal has holes, tears, or other openings in the seal or the seal fabric, or the secondary seal has holes, tears, or other openings in the seal or the seal fabric, or the gaskets no longer close off the liquid surfaces from the atmosphere, or the slotted membrane has more than 10 percent open area, the owner or operator shall repair the items as necessary so that none of the conditions specified in this paragraph exist before refilling the storage vessel with VOL. In no event shall inspections conducted in accordance with this provision occur at intervals greater than 10 years in the case of vessels conducting the annual visual inspection as specified in 40 CFR 60.113(a)(2) and (a)(3)(ii) and at intervals no greater than 5 years in the case of vessels specified in 40 CFR 60.113(a)(3)(i).
- (e) Notify the IDEM, OAQ in writing at least 30 days prior to the filling or refilling of each storage vessel for which an inspection is required by 40 CFR 60.113(a)(1) and (a)(4) to afford IDEM, OAQ the opportunity to have an observer present. If the inspection required by 40 CFR 60.113 (a)(4) is not planned and the Permittee could not have known about the inspection 30 days in advance or refilling the tank, the Permittee shall notify the IDEM, OAQ at least seven (7) days prior to the refilling of the storage vessel. Notification shall be made by telephone immediately followed by written documentation demonstrating why the inspection was unplanned. Alternatively, this notification including the written documentation may be made in writing and sent by express mail so that it is received by the IDEM, OAQ at least seven (7) days prior to the refilling.

## **Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]**

### **D.7.6 Record Keeping Requirements**

---

- (a) To document compliance with Condition D.7.1, the Permittee shall maintain the following records for tank T003:
  - (1) The types of volatile petroleum liquid stored;
  - (2) The maximum true vapor pressure of the liquids as stored; and
  - (3) The results of the inspections performed on the storage vessels.
- (b) Pursuant to 40 CFR 60.116b, the Permittee shall maintain the following records:
  - (1) The dimension of the storage vessel and an analysis showing the capacity of the storage vessel for the life of the source; and
  - (2) The VOL stored, the period of storage, and the maximum true vapor pressure of that VOL during the respective storage period, for at least 2 years.
- (c) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

## **SECTION E.1 40 CFR 60, Subpart VV - Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry**

### **Emission Limitations and Standards [326 IAC 2-8-4(1)]**

#### **E.1.1 Standards: Pumps in Light Liquid Service [326 IAC 12][40 CFR 60, Subpart VV]**

Pursuant to 40 CFR 60.482-2 (Standards: Pumps in Light Liquid Service), the Permittee shall comply with the following requirements:

- (a) Each pump in light liquid service shall:
  - (1) be monitored monthly to detect leaks by the methods specified in Condition E.1.9, except as provided in this condition; and
  - (2) be checked by visual inspection each calendar week for indications of liquids dripping from the pump seal.
- (b) If an instrument reading of 10,000 ppm or greater is measured, a leak is detected. If there are indications of liquids dripping from the pump seal, a leak is detected.
- (c) When a leak is detected, it shall be repaired as soon as practicable, but not later than 15 calendar days after it is detected, except as provided in Condition E.1.8. A first attempt at repair shall be made no later than 5 calendar days after each leak is detected.
- (d) Each pump equipped with a dual mechanical seal system that includes a barrier fluid system is exempt from the requirements of Condition E.1.1(a), provided the following requirements are met:
  - (1) Each dual mechanical seal system is:
    - (A) Operated with the barrier fluid at a pressure that is at all times greater than the pump stuffing box pressure; or
    - (B) Equipment with a barrier fluid degassing reservoir that is routed to a process or fuel gas system or connected by a closed vent system to a control device that complies with the requirements of Condition E.1.7; or
    - (C) Equipped with a system that purges the barrier fluid into a process stream with zero VOC emissions to the atmosphere.
  - (2) The barrier fluid system is in heavy liquid service or is not in VOC service.
  - (3) Each barrier fluid system is equipped with a sensor that will detect failure of the seal system, the barrier fluid system, or both.
  - (4) Each pump is checked by visual inspection, each calendar week, for indications of liquids dripping from the pump seals.
  - (5) The following requirements are met:
    - (A) Each sensor as described in Condition E.1.1(d)(3) is checked daily or is equipped with an audible alarm;
    - (B) The Permittee determines, based on design considerations and operating experience, a criterion that indicates failure of the seal system, the barrier fluid system, or both.

- (6) If there are indications of liquids dripping from the pump seal or the sensor indicates failure of the seal system, the barrier fluid system, or both based on the criterion determined in Condition E.1.1(d)(5)(B), a leak is detected. When a leak is detected, it shall be repaired as soon as practicable, but not later than 15 calendar days after it is detected, except as provided in Condition E.1.8. A first attempt at repair shall be made no later than 5 calendar days after each leak is detected.
- (e) Any pump that is designated, as described in Condition E.1.10(d)(1) and (d)(2), for no detectable emission, as indicated by an instrument reading of less than 500 ppm above background, is exempt from the requirements of Conditions E.1.1(a), (c), and (d) if the pump:
  - (1) Has no externally actuated shaft penetrating the pump housing,
  - (2) Is demonstrated to be operating with no detectable emissions as indicated by an instrument reading of less than 500 ppm above background as measured by the methods specified in Condition E.1.9(b), and
  - (3) Is tested for compliance with Condition E.1.1(e)(2) initially upon designation, annually, and at other times requested by the Administrator.
- (f) If any pump is equipped with a closed vent system capable of capturing and transporting any leakage from the seal or seals to a process or to a fuel gas system or to a control device that complies with the requirements of Condition E.1.7, it is exempt from Conditions E.1.1(a) through (e).
- (g) Any pump that is designated, as described in Condition E.1.10(e)(1), as an unsafe-to-monitor pump is exempt from the monitoring and inspection requirements of Conditions E.1.1(a) and (d)(4) through (d)(6) if:
  - (1) The Permittee demonstrates that the pump is unsafe-to-monitor because monitoring personnel would be exposed to an immediate danger as a consequence of complying with Condition E.1.1(a); and
  - (2) The Permittee has a written plan that requires monitoring of the pump as frequently as practicable during safe-to-monitor times but not more frequently than the periodic monitoring schedule otherwise applicable, and repair of the equipment according to the procedures in Condition E.1.1(c) if a leak is detected.
- (h) Any pump that is located within the boundary of an unmanned plant site is exempt from the weekly visual inspection requirement of Conditions E.1.1(a)(2) and (d)(4), and the daily requirements of Condition E.1.1(d)(5), provided that each pump is visually inspected as often as practicable and at least monthly.

E.1.2 Standards: Pressure Relief Devices in Gas/Vapor Service [326 IAC 12][40 CFR 60, Subpart VV]  
Pursuant to 40 CFR 60.482-4 (Standards: Pressure Relief Devices in Gas/Vapor Service), the Permittee shall comply with the following requirements:

- (a) Except during pressure releases, each pressure relief device in gas/vapor service shall be operated with no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, as determined by the methods specified in Condition E.1.9(b).
- (b) After each pressure release, the pressure relief device shall be returned to a condition of no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, as soon as practicable, but no later than 5 calendar days after the pressure release, except as provided in Condition E.1.8. No later than 5 calendar days after the pressure release, the pressure relief device shall be monitored to confirm the

conditions of no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, by the methods specified in Condition E.1.9(b).

- (c) Any pressure relief device that is routed to a process or fuel gas system or equipped with a closed vent system capable of capturing and transporting leakage through the pressure relief device to a control device as described in Condition E.1.7 is exempted from the requirements of Conditions E.1.2(a) and (b).
- (d) Any pressure relief device that is equipped with a rupture disk upstream of the pressure relief device is exempt from the requirements of Conditions E.1.2(a) and (b), provided after each pressure release, a new rupture disk is installed upstream of the pressure relief device as soon as practicable, but no later than 5 calendar days after each pressure release, except as provided in Condition E.1.8.

#### E.1.3 Standards: Sampling Connection Systems [326 IAC 12][40 CFR 60, Subpart VV]

Pursuant to 40 CFR 60.482-5 (Standards: Sampling Connection Systems), the Permittee shall comply with the following requirements:

- (a) Each sampling connection system shall be equipped with a closed-purged, closed-loop, or closed-vent system. Gases displaced during filling of the sample container are not required to be collected or captured.
- (b) Each closed-purge, closed-loop, or closed-vent system as required in Condition E.1.3(a) shall comply with the following requirements:
  - (1) Return the purged process fluid directly to the process line; or
  - (2) Collect and recycle the purged process fluid to a process; or
  - (3) Be designed and operated to capture and transport all the purged process fluid to a control device that complies with the requirements of Condition E.1.7; or
  - (4) Collect, store, and transport the purged process fluid to any of the following systems or facilities:
    - (A) A waste management unit as defined in 40 CFR 63.111, if the waste management unit is subject to, and operated in compliance with the provisions of 40 CFR Part 63, Subpart G, applicable to Group 1 wastewater streams;
    - (B) A treatment, storage, or disposal facility subject to regulation under 40 CFR part 262, 264, 265, or 266; or
    - (C) A facility permitted, licensed, or registered by a State to manage municipal or industrial solid waste, if the process fluids are not hazardous waste as defined in 40 CFR Part 261.
- (c) In situ sampling systems and sampling systems without purges are exempt from the requirements of Conditions E.1.3(a) and (b).

#### E.1.4 Standards: Open-Ended Valves or Lines [326 IAC 12][40 CFR 60, Subpart VV]

Pursuant to 40 CFR 60.482-6 (Standards: Open-Ended Valves or Lines), the Permittee shall comply with the following requirements:

- (a) Each open-ended valve or line shall be equipped with a cap, blind flange, plug, or a second valve. The cap, blind flange, plug, or second valve shall seal the open end at all times except during operations requiring process fluid flow through the open-ended valve or line.

- (b) Each open-ended valve or line equipped with a second valve shall be operated in a manner such that the valve on the process fluid end is closed before the second valve is closed.
- (c) When a double block-and-bleed system is being used, the bleed valve or line may remain open during operations that require venting the line between the block valves but shall comply with Condition E.1.4(a) at all other times.
- (d) Open-ended valves or lines in an emergency shutdown system which are designed to open automatically in the event of a process upset are exempt from the requirements of Conditions E.1.4(a), (b) and (c).
- (e) Open-ended valves or lines containing materials which would autocatalytically polymerize or would present an explosion, serious overpressure, or other safety hazard if capped or equipped with a double block and bleed system as specified in Conditions E.1.4(a) through (c) are exempt from the requirements of Conditions E.1.4(a) through (c).

E.1.5 Standards: Valves in Gas/Vapor Service and in Light Liquid Service [326 IAC 12][40 CFR 60, Subpart VV]

---

Pursuant to 40 CFR 60.482-7 (Standards: Valves in Gas/Vapor Service and in Light Liquid Service), the Permittee shall comply with the following requirements:

- (a) Each valve shall be monitored monthly to detect leaks by the methods specified in Condition E.1.9(a) and shall comply with Conditions E.1.5(b) through (e), except as provided in Conditions E.1.5(f), (g), and (h).
- (b) If an instrument reading of 10,000 ppm or greater is measured, a leak is detected.
- (c) Any valve for which a leak is not detected for 2 successive months may be monitored the first month of every quarter, beginning with the next quarter, until a leak is detected. If a leak is detected, the valve shall be monitored monthly until a leak is not detected for 2 successive months.
- (d) When a leak is detected, it shall be repaired as soon as practicable, but no later than 15 calendar days after the leak is detected, except as provided in Condition E.1.8. A first attempt at repair shall be made no later than 5 calendar days after each leak is detected.
- (e) First attempts at repair include, but are not limited to, the following best practices where practicable:
  - (1) Tightening of bonnet bolts;
  - (2) Replacement of bonnet bolts;
  - (3) Tightening of packing gland nuts;
  - (4) Injection of lubricant into lubricated packing.
- (f) Any valve that is designated, as described in Condition E.1.10(d)(2), for no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, is exempt from the requirements of Condition E.1.5(a) if the valve:
  - (1) Has no external actuating mechanism in contact with the process fluid,
  - (2) Is operated with emissions less than 500 ppm above background as determined by the method specified in Condition E.1.9(b), and
  - (3) Is tested for compliance with Condition E.1.5(f)(2) of this section initially upon designation, annually, and at other times requested by the Administrator.

- (g) Any valve that is designated, as described in Condition E.1.10(e)(1), as an unsafe-to-monitor valve is exempt from the requirements of Condition E.1.5(a) if:
  - (1) The Permittee demonstrates that the valve is unsafe to monitor because monitoring personnel would be exposed to an immediate danger as a consequence of complying with Condition E.1.5(a), and
  - (2) The Permittee of the valve adheres to a written plan that requires monitoring of the valve as frequently as practicable during safe-to-monitor times.
- (h) Any valve that is designated, as described in Condition E.1.10(e)(2), as a difficult-to-monitor valve is exempt from the requirements of Condition E.1.5(a) if:
  - (1) The Permittee demonstrates that the valve cannot be monitored without elevating the monitoring personnel more than 2 meters above a support surface.
  - (2) The process unit within which the valve is located either becomes an affected facility through 40 CFR 60.14 or 40 CFR 60.15 or the Permittee designates less than 3.0 percent of the total number of valves as difficult-to-monitor, and
  - (3) The Permittee follows a written plan that requires monitoring of the valve at least once per calendar year.

**E.1.6 Standards: Pumps and Valves in Heavy Liquid Service, Pressure Relief Devices in Light Liquid or Heavy Liquid Service, and Connectors [326 IAC 12][40 CFR 60, Subpart VV]**

---

Pursuant to 40 CFR 60.482-8 (Standards: Pumps and Valves in Heavy Liquid Service, Pressure Relief Devices in Light Liquid or Heavy Liquid Service, and Connectors), the Permittee shall comply with the following requirements:

- (a) If evidence of a potential leak is found by visual, audible, olfactory, or any other detection method at pumps and valves in heavy liquid service, pressure relief devices in light liquid or heavy liquid service, and connectors, the Permittee shall follow either one of the following procedures:
  - (1) The Permittee shall monitor the equipment within 5 days by the method specified in Condition E.1.9(a) and shall comply with the requirements of Conditions E.1.6(b) through (d).
  - (2) The Permittee shall eliminate the visual, audible, olfactory, or other indication of a potential leak.
- (b) If an instrument reading of 10,000 ppm or greater is measured, a leak is detected.
- (c) When a leak is detected, it shall be repaired as soon as practicable, but not later than 15 calendar days after it is detected, except as provided in Condition E.1.8. The first attempt at repair shall be made no later than 5 calendar days after each leak is detected.
- (d) First attempts at repair include, but are not limited to, the best practices described under Condition E.1.5(e).

**E.1.7 Standards: Closed Vent Systems and Control Devices [326 IAC 12][40 CFR 60, Subpart VV]**

---

Pursuant to 40 CFR 60.482-10 (Standards: Closed Vent Systems and Control Devices), the Permittee shall comply with the following requirements:

- (a) For closed vent systems and control devices used to comply with the provisions of 40 CFR 60, Subpart VV, the Permittee shall comply with the provisions of this Condition.

- (b) Vapor recovery systems (for example, condensers and absorbers) shall be designed and operated to recover the VOC emissions vented to them with an efficiency of 95 percent or greater, or to an exit concentration of 20 parts per million by volume, whichever is less stringent.
- (c) Enclosed combustion devices shall be designed and operated to reduce the VOC emissions vented to them with an efficiency of 95 percent or greater, or to an exit concentration of 20 parts per million by volume, on a dry basis, corrected to 3 percent oxygen, whichever is less stringent or to provide a minimum residence time of 0.75 seconds at a minimum temperature of 816 °C.
- (d) Flares used to comply with this subpart shall comply with the requirements of 40 CFR 60.18.
- (e) For control devices used to comply with the provisions of 40 CFR 60, Subpart VV, the Permittee shall monitor these control devices to ensure that they are operated and maintained in conformance with their designs.
- (f) Except as provided in Conditions E.1.7(i) through (k), each closed vent system shall be inspected according to the procedures and schedule specified below:
  - (1) If the vapor collection system or closed vent system is constructed of hard-piping, the Permittee shall comply with the requirements specified in Conditions E.1.7(f)(1)(A) and (f)(1)(B):
    - (A) Conduct an initial inspection according to the procedures in Condition E.1.9(a); and
    - (B) Conduct annual visual inspections for visible, audible, or olfactory indications of leaks.
  - (2) If the vapor collection system or closed vent system is constructed of ductwork, the Permittee shall:
    - (A) Conduct an initial inspection according to the procedures in Condition E.1.9(a); and
    - (B) Conduct annual inspections according to the procedures in Condition E.1.9(a).
- (g) Leaks, as indicated by an instrument reading greater than 500 parts per million by volume above background or by visual inspections, shall be repaired as soon as practicable except as provided in Condition E.1.7(h).
  - (1) A first attempt at repair shall be made no later than 5 calendar days after the leak is detected.
  - (2) Repair shall be completed no later than 15 calendar days after the leak is detected.
- (h) Delay of repair of a closed vent system for which leaks have been detected is allowed if the repair is technically infeasible without a process unit shutdown or if the Permittee determines that emissions resulting from immediate repair would be greater than the fugitive emissions likely to result from delay of repair. Repair of such equipment shall be complete by the end of the next process unit shutdown.
- (i) If a vapor collection system or closed vent system is operated under a vacuum, it is exempt from the inspection requirements of Condition E.1.7(f)(1)(A) and (f)(2).

- (j) Any parts of the closed vent system that are designated, as described in Condition E.1.7(l)(1), as unsafe to inspect are exempt from the inspection requirements of Conditions E.1.7(f)(1)(A) and (f)(2) if they comply with the following requirements:
  - (1) The Permittee determines that the equipment is unsafe to inspect because inspecting personnel would be exposed to an imminent or potential danger as a consequence of complying with Conditions E.1.7(f)(1)(A) or (f)(2); and
  - (2) The Permittee has a written plan that requires inspection of the equipment as frequently as practicable during safe-to-inspect times.
  
- (k) Any parts of the closed vent system that are designated, as described in Condition E.1.7(l)(2), as difficult to inspect are exempt from the inspection requirements of Conditions E.1.7(f)(1)(A) and (f)(2) if they comply with the requirements specified below:
  - (1) The Permittee determines that the equipment cannot be inspected without elevating the inspecting personnel more than 2 meters above a support surface; and
  - (2) The Process unit within which the closed vent system is located becomes an affected facility through 40 CFR 60.14 and 60.15, or the Permittee designates less than 3.0 percent of the total number of closed vent system equipment as difficult to inspect; and
  - (3) The Permittee has a written plan that requires inspection of the equipment at least once every 5 years. A closed vent system is exempt from inspection if it is operated under a vacuum.
  
- (l) The Permittee shall record the information specified below:
  - (1) Identification of all parts of the closed vent system that are designated as unsafe to inspect, an explanation of why the equipment is unsafe to inspect, and the plan for inspecting the equipment.
  - (2) Identification of all parts of the closed vent system that are designated as difficult to inspect, an explanation of why the equipment is difficult to inspect, and the plan for inspecting the equipment.
  - (3) For each inspection during which a leak is detected, a record of the information specified in Condition E.1.10(b).
  - (4) For each inspection conducted in accordance with Condition E.1.9(a) during which no leaks are detected, a record that the inspection was performed, the date of the inspection, and a statement that no leaks were detected.
  - (5) For each visual inspection conducted in accordance with Condition E.1.7(f)(1)(B) during which no leaks are detected, a record that the inspection was performed, the date of the inspection, and a statement that no leaks were detected.
  
- (m) Closed vent systems and control devices used to comply with provisions of 40 CFR 60, Subpart VV shall be operated at all times when emissions may be vented to them.

**E.1.8 Standards: Delay of Repair [326 IAC 12][40 CFR 60, Subpart VV]**

Pursuant to 40 CFR 60.482-9 (Standards: Delay of Repair), the Permittee shall comply with the following requirements:

- (a) Delay of repair of equipment for which leaks have been detected will be allowed if repair within 15 days is technically infeasible without a process unit shutdown. Repair of this equipment shall occur before the end of the next process unit shutdown.

- (b) Delay of repair of equipment will be allowed for equipment which is isolated from the process and which does not remain in VOC service.
- (c) Delay of repair for valves will be allowed if:
  - (1) The Permittee demonstrates that emissions of purged material resulting from immediate repair are greater than the fugitive emissions likely to result from delay of repair, and
  - (2) When repair procedures are effected, the purged material is collected and destroyed or recovered in a control device complying with Condition E.1.7.
- (d) Delay of repair for pumps will be allowed if:
  - (1) Repair requires the use of a dual mechanical seal system that includes a barrier fluid system, and
  - (2) Repair is completed as soon as practicable, but not later than 6 months after the leak was detected.
- (e) Delay of repair beyond a process unit shutdown will be allowed for a valve, if valve assembly replacement is necessary during the process unit shutdown, valve assembly supplies have been depleted, and valve assembly supplies had been sufficiently stocked before the supplies were depleted. Delay of repair beyond the next process unit shutdown will not be allowed unless the next process unit shutdown occurs sooner than 6 months after the first process unit shutdown.

### Compliance Determination Requirements

#### E.1.9 Test Methods and Procedures [326 IAC 12][40 CFR 60, Subpart VV]

---

Pursuant to 40 CFR 60.485 (Test Methods and Procedures), the Permittee shall comply with the following requirements:

- (a) The Permittee shall determine compliance with the standards in Conditions E.1.1 through E.1.8 as follows:
  - (1) Method 21 shall be used to determine the presence of leaking sources. The instrument shall be calibrated before use each day of its use by the procedures specified in Method 21. The following calibration gases shall be used:
    - (A) Zero air (less than 10 ppm of hydrocarbon in air); and
    - (B) A mixture of methane or n-hexane and air at a concentration of about, but less than, 10,000 ppm methane or n-hexane.
- (b) The Permittee shall determine compliance with the no detectable emission standards in Conditions E.1.1(e), E.1.2, and E.1.5(f) as follows:
  - (1) The requirements of Condition E.1.10(a) shall apply.
  - (2) Method 21 shall be used to determine the background level. All potential leak interfaces shall be traversed as close to the interface as possible. The arithmetic difference between the maximum concentration indicated by the instrument and the background level is compared with 500 ppm for determining compliance.
- (c) The Permittee shall test each piece of equipment unless he demonstrates that a process unit is not in VOC service, i.e., that the VOC content would never be reasonably expected

to exceed 10 percent by weight. For purposes of this demonstration, the following methods and procedures shall be used:

- (1) Procedures that conform to the general methods in ASTM E260-73, 91, or 96, E168-67, 77, or 92, E169-63, 77, or 93 (incorporated by reference in 40 CFR 60.17) shall be used to determine the percent VOC content in the process fluid that is contained in or contacts a piece of equipment.
  - (2) Organic compounds that are considered by the Administrator to have negligible photochemical reactivity may be excluded from the total quantity of organic compounds in determining the VOC content of the process fluid.
  - (3) Engineering judgment may be used to estimate the VOC content, if a piece of equipment had not been shown previously to be in service. If the Administrator disagrees with the judgment, Conditions E.1.9(c) (1) and (2) shall be used to resolve the disagreement.
- (d) The Permittee shall demonstrate that equipment is in light liquid service by showing that all the following conditions apply:
- (1) The vapor pressure of one or more of the components is greater than 0.3 kPa at 20 °C (1.2 in. H<sub>2</sub>O at 68°F). Standard reference texts or ASTM D2879-83, 96, or 97 (incorporated by reference in 40 CFR 60.17) shall be used to determine the vapor pressures.
  - (2) The total concentration of the pure components having a vapor pressure greater than 0.3 kPa at 20 °C (1.2 in. H<sub>2</sub>O at 68 °F) is equal to or greater than 20 percent by weight.
  - (3) The fluid is a liquid at operating conditions.
- (e) Samples used in conjunction with Conditions E.1.9(c), (d), and (f) shall be representative of the process fluid that is contained in or contacts the equipment or the gas being combusted in the flare.
- (f) The Permittee shall determine compliance with the standards of flares as follows:
- (1) Method 22 shall be used to determine visible emissions.
  - (2) A thermocouple or any other equivalent device shall be used to monitor the presence of a pilot flame in the flare.
  - (3) The maximum permitted velocity for air assisted flares shall be computed using the following equation:

$$V_{\max} = K_1 + K_2 H_T$$

Where:

- $V_{\max}$  = Maximum permitted velocity, m/sec (ft/sec)  
 $H_T$  = Net heating value of the gas being combusted, MJ/scm (Btu/scf).  
 $K_1$  = 8.706 m/sec (metric units) = 28.56 ft/sec (English units)  
 $K_2$  = 0.7084 m<sup>4</sup>/(MJ-sec) (metric units) = 0.087 ft<sup>4</sup>/(Btu-sec) (English units)

- (4) The net heating value ( $H_T$ ) of the gas being combusted in a flare shall be computed using the following equation:

$$H_T = k \sum_{i=1}^n C_i H_i$$

Where:

- K = Conversion constant,  $1.740 \times 10^7$  (g-mole)(MJ)/ (ppm-scm-kcal)  
(metric units) =  $4.674 \times 10^8$  [(g-mole)(Btu)/(ppm-scf-kcal)]  
(English units)
- C<sub>i</sub> = Concentration of sample component "i," ppm
- H<sub>i</sub> = net heat of combustion of sample component "i" at 25°C and 760  
mm Hg (77°F and 14.7 psi), kcal/g-mole

- (5) Method 18 and ASTM D2504-67, 77, or 88 (Reapproved 1993) (incorporated by reference in 40 CFR 60.17) shall be used to determine the concentration of sample component "i."
- (6) ASTM D2382-76 or 88 or D4809-95 (incorporated by reference in 40 CFR 60.17) shall be used to determine the net heat of combustion of component "i" if published values are not available or cannot be calculated.
- (7) Method 2, 2A, 2C, or 2D, as appropriate, shall be used to determine the actual exit velocity of a flare. If needed, the unobstructed (free) cross-sectional area of the flare tip shall be used.

### **Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]**

#### E.1.10 Recordkeeping Requirements [326 IAC 12][40 CFR 60, Subpart VV]

Pursuant to 40 CFR 60.486 (Recordkeeping Requirements), the Permittee shall comply with the following requirements:

- (a) When each leak is detected as specified in Conditions E.1.1, E.1.5, and E.1.6, the following requirements apply:
  - (1) A weatherproof and readily visible identification, marked with the equipment identification number, shall be attached to the leaking equipment.
  - (2) The identification on a valve may be removed after it has been monitored for 2 successive months as specified in Condition E.1.5(c) and no leak has been detected during those 2 months.
  - (3) The identification on equipment except on a valve, may be removed after it has been repaired.
- (b) When each leak is detected as specified in Conditions E.1.1, E.1.5, and E.1.6, the following information shall be recorded in a log in a readily accessible location:
  - (1) The instrument and operator identification numbers and the equipment identification number.
  - (2) The date the leak was detected and the dates of each attempt to repair the leak.
  - (3) Repair methods applied in each attempt to repair the leak.
  - (4) "Above 10,000" if the maximum instrument reading measured by the methods specified in Condition E.1.9(a) after each repair attempt is equal to or greater than 10,000 ppm.
  - (5) "Repair delayed" and the reason for the delay if a leak is not repaired within 15 calendar days after discovery of the leak.
  - (6) The signature of the employee whose decision it was that repair could not be effected without a process shutdown.

- (7) The expected date of successful repair of the leak if a leak is not repaired within 15 days.
  - (8) Dates of process unit shutdowns that occur while the equipment is unrepaired.
  - (9) The date of successful repair of the leak.
- (c) The following information pertaining to the design requirements for closed vent systems and control devices described in Condition E.1.7 shall be recorded and kept in a readily accessible location:
- (1) Detailed schematics, design specifications, and piping and instrumentation diagrams.
  - (2) The dates and descriptions of any changes in the design specifications.
  - (3) A description of the parameter or parameters monitored, as required in Condition E.1.7(e), to ensure that control devices are operated and maintained in conformance with their design and an explanation of why that parameter (or parameters) was selected for the monitoring.
  - (4) Periods when the closed vent systems and control devices required in Conditions E.1.1, E.1.2, and E.1.3 are not operated as designed, including periods when a flare pilot light does not have a flame.
  - (5) Dates of startups and shutdowns of the closed vent systems and control devices required in Conditions E.1.1, E.1.2, and E.1.3.
- (d) The following information pertaining to all equipment subject to the requirements in Conditions E.1.1 through E.1.8 and 40 CFR 60.482-1 shall be recorded in a log that is kept in a readily accessible location:
- (1) A list of identification numbers for equipment subject to the requirements of 40 CFR 60, Subpart VV.
  - (2) A list of identification numbers for equipment that are designated for no detectable emissions under the provisions of Conditions E.1.1(e) and E.1.5(f) and the designation of equipment as subject to the requirements of Conditions E.1.1(e) or E.1.5(f) shall be signed by the Permittee.
  - (3) A list of equipment identification numbers for pressure relief devices required to comply with Condition E.1.2.
  - (4) The following information:
    - (A) The dates of each compliance test as required in Conditions E.1.1(e), E.1.2, and E.1.5(f);
    - (B) The background level measured during each compliance test;
    - (C) The maximum instrument reading measured at the equipment during each compliance test.
  - (5) A list of identification numbers for equipment in vacuum service.
- (e) The following information pertaining to all valves subject to the requirements of Conditions E.1.5(g) and (h) and to all pumps subject to the requirements of Conditions E.1.1(g) shall be recorded in a log that is kept in a readily accessible location:

- (1) A list of identification numbers for valves and pumps that are designated as unsafe-to-monitor, an explanation for each valve or pump stating why the valve or pump is unsafe-to-monitor, and the plan for monitoring each valve or pump.
  - (2) A list of identification numbers for valves that are designated as difficult-to-monitor, an explanation for each valve stating why the valve is difficult-to-monitor, and the schedule for monitoring each valve.
- (f) The following information shall be recorded for valves complying with Condition E.1.1:
- (1) A schedule of monitoring.
  - (2) The percent of valves found leaking during each monitoring period.
- (g) The following information shall be recorded in a log that is kept in a readily accessible location:
- (1) Design criterion required in Conditions E.1.1(d)(5) and explanation of the design criterion; and
  - (2) Any changes to this criterion and the reasons for the changes.
- (h) Information and data used to demonstrate that a piece of equipment is not in VOC service shall be recorded in a log that is kept in a readily accessible location.
- (i) The provisions of 40 CFR 60.7 (b) and (d) do not apply to affected facilities subject to this subpart.

#### E.1.11 Reporting Requirements [326 IAC 12][40 CFR 60, Subpart VV]

---

Pursuant to 40 CFR 60.487 (Reporting Requirements), the Permittee shall comply with the following requirements:

- (a) The Permittee shall submit semiannual reports to the Administrator.
- (b) All semiannual reports to IDEM, OAQ shall include the following information, summarized from the information required in Condition E.1.10.
  - (1) Process unit identification.
  - (2) For each month during the semiannual reporting period,
    - (A) Number of valves for which leaks were detected as described in Condition E.1.5(b),
    - (B) Number of valves for which leaks were not repaired as required in Condition E.1.5(d),
    - (C) Number of pumps for which leaks were detected as described in Conditions E.1.1(b) and E.1.1(d)(6),
    - (D) Number of pumps for which leaks were not repaired as required in Conditions E.1.1(c) and E.1.1(d)(6),
    - (E) The facts that explain each delay of repair and, where appropriate, why a process unit shutdown was technically infeasible.
  - (3) Dates of process unit shutdowns which occurred within the semiannual reporting period.

- (c) Revisions to items reported in the initial semiannual report if changes have occurred since the initial report or subsequent revisions to the initial report.

## INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT OFFICE OF AIR QUALITY

### FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP) CERTIFICATION

Source Name: Central Indiana Ethanol, LLC.  
Source Address: 2955 W. Delphi Pike, Marion, Indiana 46952  
Mailing Address: 2955 W. Delphi Pike, Marion, Indiana 46952  
FESOP No.: F053-21057-00062

**This certification shall be included when submitting monitoring, testing reports/results  
or other documents as required by this permit.**

Please check what document is being certified:

- Annual Compliance Certification Letter
- Test Result (specify)\_\_\_\_\_
- Report (specify)\_\_\_\_\_
- Notification (specify)\_\_\_\_\_
- Affidavit (specify)\_\_\_\_\_
- Other (specify)\_\_\_\_\_

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Signature:

Printed Name:

Title/Position:

Date:

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE BRANCH  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251  
Phone: 317-233-0178  
Fax: 317-233-6865**

**FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP)  
EMERGENCY OCCURRENCE REPORT**

Source Name: Central Indiana Ethanol, LLC.  
Source Address: 2955 W. Delphi Pike, Marion, Indiana 46952  
Mailing Address: 2955 W. Delphi Pike, Marion, Indiana 46952  
FESOP No.: F053-21057-00062

**This form consists of 2 pages**

**Page 1 of 2**

- |   |
|---|
| <input type="checkbox"/> This is an emergency as defined in 326 IAC 2-7-1(12) <ul style="list-style-type: none"><li>• The Permittee must notify the Office of Air Quality (OAQ), within four (4) business hours (1-800-451-6027 or 317-233-0178, ask for Compliance Section); and</li><li>• The Permittee must submit notice in writing or by facsimile within two (2) working days (Facsimile Number: 317-233-6865), and follow the other requirements of 326 IAC 2-7-16</li></ul> |
|---|

If any of the following are not applicable, mark N/A

Facility/Equipment/Operation:
Control Equipment:
Permit Condition or Operation Limitation in Permit:
Description of the Emergency:
Describe the cause of the Emergency:

If any of the following are not applicable, mark N/A

**Page 2 of 2**

Date/Time Emergency started:
Date/Time Emergency was corrected:
Was the facility being properly operated at the time of the emergency?    Y    N Describe:
Type of Pollutants Emitted: PM, PM10, SO <sub>2</sub> , VOC, NO <sub>x</sub> , CO, Pb, other:
Estimated amount of pollutant(s) emitted during emergency:
Describe the steps taken to mitigate the problem:
Describe the corrective actions/response steps taken:
Describe the measures taken to minimize emissions:
If applicable, describe the reasons why continued operation of the facilities are necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw materials of substantial economic value:

Form Completed by: \_\_\_\_\_  
Title / Position: \_\_\_\_\_  
Date: \_\_\_\_\_  
Phone: \_\_\_\_\_

A certification is not required for this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE DATA SECTION**

FESOP Quarterly Report

Source Name: Central Indiana Ethanol, LLC.  
Source Address: 2955 W. Delphi Pike, Marion, Indiana 46952  
Mailing Address: 2955 W. Delphi Pike, Marion, Indiana 46952  
FESOP No.: F053-21057-00062  
Facility: DDGS Cooler (EU036)  
Parameter: DDGS Production Rate  
Limit: Less than 210,000 tons per twelve (12) consecutive month period with compliance determined at the end of each month.

YEAR: \_\_\_\_\_

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

No deviation occurred in this quarter.

Deviation/s occurred in this quarter.

Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_

Title / Position: \_\_\_\_\_

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

Attach a signed certification to complete this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE DATA SECTION**

**FESOP Quarterly Report**

Source Name: Central Indiana Ethanol, LLC.  
Source Address: 2955 W. Delphi Pike, Marion, Indiana 46952  
Mailing Address: 2955 W. Delphi Pike, Marion, Indiana 46952  
FESOP No.: F053-21057-00062  
Facility: Ethanol Loading Racks (EU045A and EU045B)  
Parameter: Total combined denatured ethanol and blended ethanol loadout rate  
Limit: Less than 64,900,000 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.

YEAR: \_\_\_\_\_

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

No deviation occurred in this quarter.

Deviation/s occurred in this quarter.

Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_  
Title / Position: \_\_\_\_\_  
Signature: \_\_\_\_\_  
Date: \_\_\_\_\_  
Phone: \_\_\_\_\_

Attach a signed certification to complete this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE DATA SECTION**

**FESOP Quarterly Report**

Source Name: Central Indiana Ethanol, LLC.  
Source Address: 2955 W. Delphi Pike, Marion, Indiana 46952  
Mailing Address: 2955 W. Delphi Pike, Marion, Indiana 46952  
FESOP No.: F053-21057-00062  
Facility: Ethanol Loading Racks (EU045A and EU045B)  
Parameter: Total denaturant used  
Limit: Less than 4,900,000 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.

YEAR: \_\_\_\_\_

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

No deviation occurred in this quarter.

Deviation/s occurred in this quarter.

Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_  
Title / Position: \_\_\_\_\_  
Signature: \_\_\_\_\_  
Date: \_\_\_\_\_  
Phone: \_\_\_\_\_

Attach a signed certification to complete this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE DATA SECTION**

**FESOP Quarterly Report**

Source Name: Central Indiana Ethanol, LLC.  
Source Address: 2955 W. Delphi Pike, Marion, Indiana 46952  
Mailing Address: 2955 W. Delphi Pike, Marion, Indiana 46952  
FESOP No.: F053-21057-00062  
Facility: Ethanol Loading Rack (EU045B)  
Parameter: Total denatured ethanol load-out into non-dedicated railcars  
Limit: Less than 2,500,000 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.

YEAR: \_\_\_\_\_

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

No deviation occurred in this quarter.

Deviation/s occurred in this quarter.

Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_

Title / Position: \_\_\_\_\_

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

Attach a signed certification to complete this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE DATA SECTION**

**FESOP Quarterly Report**

Source Name: Central Indiana Ethanol, LLC.  
Source Address: 2955 W. Delphi Pike, Marion, Indiana 46952  
Mailing Address: 2955 W. Delphi Pike, Marion, Indiana 46952  
FESOP No.: F053-21057-00062  
Facility: Diesel Fire Pump (EU034)  
Parameter: Operating Hours  
Limit: Less than 500 hours per twelve (12) consecutive month period with compliance determined at the end of each month.

YEAR: \_\_\_\_\_

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

No deviation occurred in this quarter.

Deviation/s occurred in this quarter.

Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_

Title / Position: \_\_\_\_\_

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

Attach a signed certification to complete this report.

## INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT OFFICE OF AIR QUALITY COMPLIANCE DATA SECTION

### FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP) QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT

Source Name: Central Indiana Ethanol, LLC.  
Source Address: 2955 W. Delphi Pike, Marion, Indiana 46952  
Mailing Address: 2955 W. Delphi Pike, Marion, Indiana 46952  
FESOP No.: F053-21057-00062

Months: \_\_\_\_\_ to \_\_\_\_\_ Year: \_\_\_\_\_

Page 1 of 2

<p>This report shall be submitted quarterly based on a calendar year. Any deviation from the requirements, the date(s) of each deviation, the probable cause of the deviation, and the response steps taken must be reported. A deviation required to be reported pursuant to an applicable requirement that exists independent of the permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. Additional pages may be attached if necessary. If no deviations occurred, please specify in the box marked <b>NO deviations occurred this reporting period</b>.</p>	
<p><input type="checkbox"/> NO DEVIATIONS OCCURRED THIS REPORTING PERIOD.</p>	
<p><input type="checkbox"/> THE FOLLOWING DEVIATIONS OCCURRED THIS REPORTING PERIOD</p>	
<p><b>Permit Requirement</b> (specify permit condition #)</p>	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	
<b>Permit Requirement</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	

<b>Permit Requirement</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	
<b>Permit Requirement</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	
<b>Permit Requirement</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	

Form Completed By: \_\_\_\_\_

Title/Position: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

Attach a signed certification to complete this report.

# Indiana Department of Environmental Management Office of Air Quality

## Addendum to the Technical Support Document For a Significant Permit Revision to a Federally Enforceable State Operating Permit (FESOP)

### Source Background and Description

Source Name:	Central Indiana Ethanol, LLC
Source Location:	2955 W. Delphi Pike, Marion, Indiana 46952
County:	Grant
SIC Code:	2869
Operation Permit No.:	F053-21057-00062
Operation Permit Issuance Date:	August 4, 2005
Significant Permit Revision No.:	053-24415-00062
Permit Reviewer:	ERG/JR

On June 13, 2007, the Office of Air Quality (OAQ) had a notice published in the Marion Chronicle Tribune of Marion, Indiana stating that Central Indiana Ethanol, LLC (Central Indiana) had applied for a Significant Permit Revision to a Federally Enforceable State Operating Permit (FESOP). The notice also stated that OAQ proposed to issue a permit for this revision and provided information on how the public could review the proposed permit and other documentation. Finally, the notice informed interested parties that there was a period of thirty (30) days to provide comments on whether or not this permit should be issued as proposed.

Upon further review, IDEM has decided to make the following revisions to the permit (bolded language has been added, the language with a line through it has been deleted). The Table of Contents has been updated as necessary.

1. Effective July 2, 2007, U.S. EPA has revised the definition of a "major stationary source" under 40 CFR Parts 51 and 52 PSD and Nonattainment New Source Review, and the definition of a "major source" under 40 CFR parts 70 and 71 (State and Federal Operating Permits). U.S. EPA has reinterpreted the component term "chemical process plants" within the statutory definition of "major emitting facility" in section 169(1) of the CAA to exclude wet and dry corn milling facilities that produce ethanol for fuel, or produce ethanol through a natural fermentation process that involves the use of such things as corn, sugar beets, sugar cane or cellulosic biomass as a feedstock regardless of whether the ethanol is produced for human consumption, fuel, or for an industrial purpose. Therefore, ethanol plants are no longer required to count fugitive emissions for purposes of determining whether a source is a major source under the PSD, nonattainment NSR, or Title V programs unless there is an applicable New Source Performance Standard that was in effect on August 7, 1980 for the ethanol plant, or the ethanol plant has a "nested" source category. Central Indiana does not have a "nested" source category; therefore, the entire source does not fall under one of the 28 listed source categories and fugitive emissions are not counted towards determining whether the source is a major source under the PSD, nonattainment NSR, or Title V programs.

The calculations have been revised such that the potential to emit does not reflect fugitive emissions from grain and DDGS handling, paved and unpaved roads, and equipment leaks (see Appendix A - TSD Addendum). Therefore, the permit conditions in Section D.1 limiting the amount of grain received by the corn dump pits (EU001) and the amount of DDGS produced

have been removed. The condition requiring the Permittee to use wet suppression to control PM and PM10 emissions from the paved roads is also no longer necessary and has been removed from the permit. Since VOC emissions from the DDGS Cooler are based on 210,000 tons of DDGS produced per twelve (12) consecutive month period, Condition D.4.5(b) limiting the amount of DDGS produced remains in the permit, as well as the associated recordkeeping and reporting.

The following table summarizes the total potential to emit, reflecting all limits, of the source after control and upon startup of the ethanol production plant. The source remains a minor source under PSD rules and section 112 of the clean air act. The potential to emit of the criteria pollutants from the entire source is still limited to less than the Title V major source thresholds. Therefore, the requirements of 326 IAC 2-7 are not applicable to this source.

Process/Emission Unit	Potential To Emit (tons/year)						
	PM	PM10	SO <sub>2</sub>	VOC	CO	NO <sub>x</sub>	HAPs
Grain Receiving and Handling Operations	12.6	12.6	-	-	-	-	-
Fermentation Process and Distillation Process	-	-	-	33.4	-	-	7.64
Distillation, DDGS Dryers, and TO/HRSG System	35.0	35.0	37.2	32.9	92.0	86.3	4.88
DDGS Cooler	4.13	4.13	-	6.83	-	-	0.53
DDGS Handling and Loadout Operations	0.70	0.70	-	-	-	-	-
Wet Cake Storage*	-	-	-	See Note	-	-	See Note
Ethanol Loading Racks	Negligible	Negligible	Negligible	15.6	4.19	2.50	0.47
Cooling Tower (Insignificant)	12.3	12.3	-	-	-	-	-
Diesel Fire Pump (Insignificant)	0.17	0.17	0.15	0.19	0.50	2.33	Negligible
Storage Tanks (Insignificant)	-	-	-	2.67	-	-	Negligible
Corn Oil Storage	-	-	-	0.54	-	-	0.29
Biomethanator Flare** (Insignificant)	-	-	-	See Note	See Note	See Note	See Note
Insignificant Combustion	0.02	0.08	0.01	0.06	0.94	1.05	0.02
Other Insignificant Activities	1.0	1.0	-	1.0	-	-	-
Total PTE of the Entire Source	66.0	66.0	37.4	93.2	97.6	92.2	Less than 8.96 for a single HAP and 13.8 for total HAPs
PSD/TV Major Thresholds	100	100	100	100	100	100	10 for a single HAP and 25 for total HAPs

Note: "-" pollutant not emitted by the facility.

\* This plant is capable of producing both DDGS and MDGS. The emissions from DDGS production is the worst case scenario. Therefore, the PTE of wet cake storage is not included in the PTE for the entire source.

\*\* The Biomethanator flare will not operate when any of the DDGS dryers are in operation. The emissions from the DDGS dryers are the worst case scenario. Therefore, the PTE of the biomethanator flare is not included in the PTE for the entire source.

The following changes have been made to the permit:

A.1 General Information [326 IAC 2-8-3(b)]

---

The Permittee owns and operates a stationary ethanol production plant.

Source Address: 2955 W. Delphi Pike, Marion, Indiana 46952  
Mailing Address: 2955 W. Delphi Pike, Marion, Indiana 46952  
General Source Phone: (765) 384-4001  
SIC Code: 2869  
County Location: Grant County  
Source Location Status: Attainment for all other criteria pollutants  
Source Status: Federally Enforceable State Operating Permit (FESOP)  
Minor Source, under PSD Rules  
Minor Source, Section 112 of the Clean Air Act  
**Not 1 of 28 Source Categories**

C.2 Overall Source Limit [326 IAC 2-8]

---

The purpose of this permit is to limit this source's potential to emit to less than major source levels for the purpose of Section 502(a) of the Clean Air Act.

...

- (b) The potential to emit particulate matter (PM) from the entire source shall be limited to less than ~~one hundred (100)~~ **two hundred fifty (250)** tons per twelve (12) consecutive month period. This limitation shall make the requirements of 326 IAC 2-2 (Prevention of Significant Deterioration (PSD) not applicable.

...

D.1.5 PM and PM10 Emissions [326 IAC 2-2] [326 IAC 2-8-4]

---

- (a) The PM and PM10 emissions from the following units shall not exceed the emission limits listed in the table below.

Unit ID	Unit Description	Baghouse ID	PM/PM10 Emission Limit (lbs/hr)
EU001 – EU007	Grain Receiving and Handling Operations	CE001	1.67
EU010 and EU011	Hammermills	CE003	1.20
EU040 - EU043	DDGS Handling and Loadout Operations	CE008	0.16

- (b) ~~The total grain received by the corn dump pits (EU001) shall be limited to less than 646,800 tons per twelve (12) consecutive month period with compliance determined at the end of each month.~~
- (c) ~~The total DDGS produced shall not exceed 210,000 tons per twelve (12) consecutive month period with compliance determined at the end of each month.~~
- (d) ~~Permittee shall use wet suppression to control PM and PM10 emissions from the paved and unpaved roads. The suppressant shall be applied in a manner and at a frequency sufficient to ensure compliance with 326 IAC 2-2 and 326 IAC 2-8.~~

Combined with the PM/PM10 emissions from other emission units, the PM/PM10 emissions from the entire source are limited to less than 100 tons/yr. **Combined with the PM emissions from other emission units, the PM emissions from the entire source are limited to less than 250 tons/yr.** Therefore, the requirements of 326 IAC 2-7 (Part 70 Program) and 326 IAC 2-2 (PSD) are not applicable.

#### D.1.13 Record Keeping Requirements

---

- ~~(a) To document compliance with Condition D.1.5(b), the Permittee shall maintain monthly records of the total amount of corn received by corn dump pits EU001.~~
- ~~(b) To document compliance with Condition D.1.5(c), the Permittee shall maintain monthly records of the amount of DDGS produced.~~
- (ea) To document compliance with Condition D.1.10, the Permittee shall maintain records of daily visible emission notations of the baghouse stack exhausts. The Permittee shall include in its daily record when a visible emission notation is not taken and the reason for the lack of visible emission notation (e.g. the process did not operate that day).
- (db) To document compliance with Condition D.1.11, the Permittee shall maintain daily records of the pressure drop during normal operation. The Permittee shall include in its daily record when a pressure drop reading is not taken and the reason for the lack of a pressure drop reading (e.g. the process did not operate that day).
- (ec) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

#### D.1.14 Reporting Requirements

---

~~A quarterly summary of the information to document compliance with Conditions D.1.5(b) and D.1.5(c) shall be submitted to the address listed in Section C - General Reporting Requirements, of this permit, using the reporting forms located at the end of this permit, or their equivalent, within thirty (30) days after the end of the quarter being reported. The report submitted by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).~~

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE DATA SECTION**

**FESOP Quarterly Report**

Source Name: \_\_\_\_\_ Central Indiana Ethanol, LLC.  
Source Address: \_\_\_\_\_ 2955 W. Delphi Pike, Marion, Indiana 46952  
Mailing Address: \_\_\_\_\_ 2955 W. Delphi Pike, Marion, Indiana 46952  
FESOP No.: \_\_\_\_\_ F053-21057-00062  
Facility: \_\_\_\_\_ Corn Dump Pits (EU001)  
Parameter: \_\_\_\_\_ Total Corn Received  
Limit: \_\_\_\_\_ Less than 646,800 tons per twelve (12) consecutive month period with compliance determined at the end of each month.

YEAR: \_\_\_\_\_

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

\_\_\_\_\_  No deviation occurred in this quarter.

\_\_\_\_\_  Deviation/s occurred in this quarter.

\_\_\_\_\_ Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_

Title / Position: \_\_\_\_\_

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

Attach a signed certification to complete this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE DATA SECTION**

**FESOP Quarterly Report**

Source Name: Central Indiana Ethanol, LLC.  
Source Address: 2955 W. Delphi Pike, Marion, Indiana 46952  
Mailing Address: 2955 W. Delphi Pike, Marion, Indiana 46952  
FESOP No.: F053-21057-00062  
Facility: DDGS Cooler (EU036); ~~DDGS Handling and Loadout Operations (EU040 through EU043)~~  
Parameter: DDGS Production Rate  
Limit: Less than 210,000 tons per twelve (12) consecutive month period with compliance determined at the end of each month.

YEAR: \_\_\_\_\_

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

- No deviation occurred in this quarter.
- Deviation/s occurred in this quarter.  
Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_  
Title / Position: \_\_\_\_\_  
Signature: \_\_\_\_\_  
Date: \_\_\_\_\_  
Phone: \_\_\_\_\_

Attach a signed certification to complete this report.

2. In order to clarify recordkeeping requirements specific to parametric monitoring, Condition D.3.21(c) was revised. Temperature readings should be taken on a continuous basis.

D.3.21 Record Keeping Requirements

---

...

- (c) To document compliance with Condition D.3.19, the Permittee shall maintain continuous temperature records for the thermal oxidizer and the 3-hour average temperature used to demonstrate compliance during the most recent compliant stack test. ~~The Permittee shall include in its daily record when a temperature reading is not taken and the reason for the lack of a temperature reading (e.g. the process did not operate that day).~~

...

3. On February 20, 2007, IDEM, OAQ adopted a new rule (326 IAC 8-5-6) for fuel grade ethanol production at dry mills. Since the facility is modifying the fuel grade ethanol production plant after April 1, 2007 and has a combined potential VOC emissions from the fermentation process, distillation process, DDGS dryers, and ethanol loadout operation greater than 25 tons per year; the fermentation process, distillation process, DDGS dryers, and ethanol loadout operation at this source are subject to the requirements in 326 IAC 8-5-6 (Fuel Grade Ethanol Production at Dry Mills). Because the fermentation process, distillation process, DDGS dryers, and ethanol loadout operations are subject to the requirements in 326 IAC 8-5-6, these operations are not subject to the requirements of 326 IAC 8-1-6 (BACT).

D.2.6 VOC Emissions [326 IAC ~~8-1-6~~ **8-5-6**]

---

Pursuant to ~~326 IAC 8-1-6 (BACT)~~ **326 IAC 8-5-6 (Fuel Grade Ethanol Production at Dry Mills)**, the Permittee shall control the VOC emissions from the fermentation process with a Best Available Control Technology (BACT), which has been determined to be **comply with** the following:

...

- ~~(c) The VOC emissions from wet scrubber CE005 shall not exceed 7.62 lbs/hr.~~

D.2.11 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11] [**326 IAC 8-5-6**]

---

...

D.2.12 Parametric Monitoring [**326 IAC 8-5-6**]

---

...

D.2.14 Record Keeping Requirements [**326 IAC 8-5-6**]

---

...

D.3.6 VOC Emissions [326 IAC ~~8-1-6~~ **8-5-6**]

---

Pursuant to ~~326 IAC 8-1-6 (BACT)~~ **326 IAC 8-5-6 (Fuel Grade Ethanol Production at Dry Mills)**, the Permittee shall control the VOC emissions from the DDGS dryers (EU035 and EU056) and the distillation process with a Best Available Control Technology (BACT), which has been determined to be **comply with** the following:

...

- ~~(c) The VOC emissions from TO/HRSG system CE007 shall not exceed 7.5 lbs/hr.~~

D.3.16 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11 [326 IAC 2-2] [40 CFR 60, Subpart Db] [**326 IAC 8-5-6**]

---

...

D.3.19 Thermal Oxidizer Temperature [326 IAC 8-5-6]

---

...

D.3.20 Parametric Monitoring [326 IAC 8-5-6]

---

...

D.3.21 Record Keeping Requirements [326 IAC 8-5-6]

---

...

D.5.6 VOC Emissions [326 IAC 8-4-6 8-5-6]

---

Pursuant to ~~326 IAC 8-4-6 (BACT)~~ **326 IAC 8-5-6 (Fuel Grade Ethanol Production at Dry Mills)**, the Permittee shall collect and control the VOC emissions from the ethanol loading rack for trucks (EU045A), with a Best Available Control Technology (BACT). The BACT for this unit has been determined to be **comply with** the following:

...

(c) ~~The VOC emissions from enclosed flare CE009 shall not exceed 0.92 lbs/hr.~~

D.5.11 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11] [326 IAC 2-2] [326 IAC 8-5-6]

---

...

D.5.12 Flare Pilot Flame [326 IAC 8-5-6]

---

...

D.5.13 Record Keeping Requirements [326 IAC 8-5-6]

---

...

**Appendix A: Emission Calculations  
PM and PM10 Emissions  
From the Grain Receiving and Handling Operations**

**Company Name: Central Indiana Ethanol, LLC  
Address: 2955 W. Delphi Pike Marion, IN 46952  
SPR: 053-24415-00062  
Reviewer: ERG/JR  
Date: July 17, 2007**

**Potential to Emit PM/PM10 - Captured Emissions:**

Baghouse ID	Process Description	Control Device	Outlet Grain Loading (gr/dscf)	Maximum Air Flow Rate (scfm)	PTE of PM/PM10 after Control (lbs/hr)	PTE of PM/PM10 after Control (tons/yr)	Control Efficiency (%)	PTE of PM/PM10 before Control (tons/yr)
CE001	Grain Receiving and Handling EU001-EU007, EU064 and EU065	Baghouse	0.005	39,000	1.67	7.32	99%	732
CE003	Hammermills EU010 and EU011	Baghouse	0.005	28,000	1.20	5.26	99%	526
Total						12.6		1,258

Assume all PM emissions equal PM10 emissions.

**Methodology**

PTE of PM/PM10 after Control (lbs/hr) = Grain Loading (gr/dscf) x Max. Air Flow Rate (scfm) x 60 mins/hr x 1/7000 lb/gr

PTE of PM/PM10 after Control (tons/yr) = Grain Loading (gr/dscf) x Max. Air Flow Rate (scfm) x 60 mins/hr x 1/7000 lb/gr x 8760 hr/yr x 1 ton/2000 lbs

PTE of PM/PM10 before Control (tons/yr) = PTE of PM/PM10 after Control (tons/yr) / (1-Control Efficiency)

**Appendix A: Emission Calculations  
VOC and HAP Emissions  
From the Fermentation Process**

**Company Name: Central Indiana Ethanol, LLC  
Address: NW 1/4 Section 3, T24N, R7E  
SPR: 053-24415-00062  
Reviewer: ERG/JR  
Date: July 17, 2007**

**1. Process Description:**

Max. Throughput Rate: 60 MM gal/yr of ethanol  
Control Equipment: Wet Scrubber CE005

**2. Potential to Emit (PTE) of VOC and HAP:**

Pollutant	*Emission Rate after Control (lbs/hr)	PTE after Control (tons/yr)	**Control Efficiency (%)	PTE before Control (tons/yr)
VOC	7.62	33.4	98%	1,669
HAP				
Acetaldehyde	1.72	7.53	50%	15.1
Acrolein	0.01	0.04	0%	0.04
Formaldehyde	0.004	0.02	0%	0.02
Methanol	0.01	0.04	0%	0.04
<b>Total HAPs</b>	<b>1.74</b>	<b>7.64</b>		<b>15.2</b>

\* This is provided by the source based on multiple ethanol facilities' stack test results and scaled linearly based on production capacity.

The Permittee will perform stack testing to demonstrate compliance with the above emission rates.

\*\* The control efficiency information is based on the information from other similar plants.

**Methodology**

PTE after Control (tons/yr) = Emission Rate after Control (lbs/hr) x 8760 hr/yr x 1 ton/2000 lbs

PTE before Control (tons/yr) = PTE after Control (tons/yr) / (1 - Control Efficiency)

**Appendix A: Emission Calculations  
Criteria Pollutants  
From Two (2) 45 MMBtu/hr DDGS Dryers and One (1) 135 MMBtu/hr TO/HRSG System**

**Company Name: Central Indiana Ethanol, LLC  
Address: NW 1/4 Section 3, T24N, R7E  
SPR: 053-24415-00062  
Reviewer: ERG/JR  
Date: July 17, 2007**

	Pollutant					
Emission Factor	PM*	PM10*	SO <sub>2</sub> *	NOx*	VOC*	CO*
	8.00 (lbs/hr)	8.00 (lbs/hr)	8.50 (lbs/hr)	19.7 (lbs/hr)	7.50 (lbs/hr)	21.0 (lbs/hr)
<b>Potential to Emit in tons/yr</b>	<b>35.0</b>	<b>35.0</b>	<b>37.2</b>	<b>86.3</b>	<b>32.9</b>	<b>92.0</b>

\*Emission rates were estimated by the source based on the stack testing results from similar sources. These emission rates are the proposed emission limits in this permit and will be verified by stack testing.

**Methodology**

PTE (tons/yr) = Emission Factor (lbs/hr) x 8760 hr/yr x 1 ton/2000 lbs

**Appendix A: Emission Calculations**  
**HAP Emissions**  
**From Two (2) 45 MMBtu/hr DDGS Dryers and One (1) 135 MMBtu/hr TO/HRSG System**

**Company Name: Central Indiana Ethanol, LLC**  
**Address: NW 1/4 Section 3, T24N, R7E**  
**SPR: 053-24415-00062**  
**Reviewer: ERG/JR**  
**Date: July 17, 2007**

	Pollutant				
	Acetaldehyde	Acrolein	Formaldehyde	Methanol	Total
Emission Rate after Control (lbs/hr) *	0.32	0.10	0.15	0.12	0.69
<b>PTE after Control in tons/yr</b>	<b>1.40</b>	<b>0.44</b>	<b>0.66</b>	<b>0.53</b>	<b>3.02</b>

\*HAP emission rates were estimated by the source based on the stack testing results from a similar engineered site (Glacial Lakes Energy, MN) and scaled linearly based on production capacity. The Permittee will perform stack tests to verify the HAP emissions from these units.

**Methodology**

PTE after Control (tons/yr) = Emission Rate after Control (lbs/hr) x 8760 hr/yr x 1 ton/2000 lbs

**Appendix A: Emission Calculations  
HAP Emissions from Natural Gas Combustion  
From Two (2) 45 MMBtu/hr DDGS Dryers and One (1) 135 MMBtu/hr TO/HRSG System**

**Company Name: Central Indiana Ethanol, LLC  
Address: NW 1/4 Section 3, T24N, R7E  
SPR: 053-24415-00062  
Reviewer: ERG/JR  
Date: July 17, 2007**

Heat Input Capacity  
MMBtu/hr

Potential Throughput  
MMCF/yr

225 (3 units combined)

1971.0

Emission Factor in lbs/MMCF	Pollutant					Total HAPs
	Hexane 1.8E+00	Formaldehyde 7.5E-02	Toluene 3.4E-03	Benzene 2.1E-03	Nickel 2.1E-03	
<b>Potential to Emit in tons/yr</b>	1.77	0.07	3.35E-03	2.07E-03	2.07E-03	<b>1.86</b>

Emission factors are from AP-42, Chapter 1.4, Table 1.4-3 (AP-42, 03/98).

MMBtu = 1,000,000 Btu

MMCF = 1,000,000 Cubic Feet of Gas

**Methodology**

Potential Throughput (MMCF) = Heat Input Capacity (MMBtu/hr) x 8,760 hrs/yr x 1 MMCF/1,000 MMBtu

PTE (tons/yr) = Potential Throughput (MMCF/yr) x Emission Factor (lbs/MMCF) x 1 ton/2000 lbs

**Appendix A: Emission Calculations  
PM/PM10 and VOC Emissions  
From the DDGS Cooler**

**Company Name: Central Indiana Ethanol, LLC  
Address: NW 1/4 Section 3, T24N, R7E  
SPR: 053-24415-00062  
Reviewer: ERG/JR  
Date: July 17, 2007**

**1. Potential to Emit PM/PM10**

Baghouse ID	Process Description	Control Device	Outlet Grain Loading (gr/dscf)	Maximum Air Flow Rate (scfm)	PTE of PM/PM10 after Control (lbs/hr)	PTE of PM/PM10 after Control (tons/yr)	Control Efficiency (%)	PTE of PM/PM10 before Control (tons/yr)
CE014	DDGS Cooler	Baghouse	0.005	22,000	0.94	4.13	99%	413
Total						4.13		413

Assume all PM emissions equal PM10 emissions.

**Methodology**

PTE of PM/PM10 after Control (lbs/hr) = Grain Loading (gr/dscf) x Max. Air Flow Rate (scfm) x 60 mins/hr x 1/7000 lb/gr

PTE of PM/PM10 after Control (tons/yr) = Grain Loading (gr/dscf) x Max. Air Flow Rate (scfm) x 60 mins/hr x 1/7000 lb/gr x 8760 hr/yr x 1 ton/2000 lbs

PTE of PM/PM10 before Control (tons/yr) = PTE of PM/PM10 after Control (tons/yr) / (1-Control Efficiency)

**2. Potential to Emit VOC:**

Max. DDGS Production Rate: 34 tons/hr  
 Annual DDGS Production Limit: 210,000 tons/yr  
 VOC Emission Factor: 0.065 lbs/ton of DDGS (provided by the source based on the stack test results for Glacial Lakes)

PTE of VOC (tons/yr) = 210,000 tons/yr x 0.065 lbs/ton x 1 ton/2000 lbs = **6.83 tons/yr**

**3. Potential to Emit HAPs:**

Emission Rate after Control (lbs/hr) *	Pollutant				Total
	Acetaldehyde	Acrolein	Formaldehyde	Methanol	
7.50E-02	1.50E-02	1.50E-02	1.50E-02	1.50E-02	0.12
<b>PTE after Control in tons/yr</b>	<b>0.33</b>	<b>0.07</b>	<b>0.07</b>	<b>0.07</b>	<b>0.53</b>

\*HAP emission rates were estimated by the source based on the stack testing results from a similar engineered site (Glacial Lakes Energy, MN) and scaled linearly based on production capacity. The Permittee will perform stack tests to verify the HAP emissions from these units.

**Methodology**

PTE after Control (tons/yr) = Emission Rate after Control (lbs/hr) x 8760 hr/yr x 1 ton/2000 lbs

**Appendix A: Emission Calculations  
PM and PM10 Emissions  
From the DDGS Handling and Loadout Operation**

**Company Name: Central Indiana Ethanol, LLC  
Address: NW 1/4 Section 3, T24N, R7E  
SPR: 053-24415-00062  
Reviewer: ERG/JR  
Date: July 17, 2007**

**Potential to Emit PM/PM10 - Captured Emissions:**

Baghouse ID	Process Description	Control Device	Outlet Grain Loading (gr/dscf)	Maximum Air Flow Rate (scfm)	PTE of PM/PM10 after Control (lbs/hr)	PTE of PM/PM10 after Control (tons/yr)	Control Efficiency (%)	PTE of PM/PM10 before Control (tons/yr)
CE008	DDGS Handling and Loadout EU040-EU043	Baghouse	0.005	3,750	0.16	0.70	99%	70.4
Total						0.70		70.4

Assume all PM emissions equal PM10 emissions.

**Methodology**

PTE of PM/PM10 after Control (lbs/hr) = Grain Loading (gr/dscf) x Max. Air Flow Rate (scfm) x 60 mins/hr x 1/7000 lb/gr

PTE of PM/PM10 after Control (tons/yr) = Grain Loading (gr/dscf) x Max. Air Flow Rate (scfm) x 60 mins/hr x 1/7000 lb/gr x 8760 hr/yr x 1 ton/2000 lbs

PTE of PM/PM10 before Control (tons/yr) = PTE of PM/PM10 after Control (tons/yr) / (1-Control Efficiency)

**Appendix A: Emission Calculations  
VOC and HAP Emissions  
From the Wetcake Storage**

**Company Name: Central Indiana Ethanol, LLC  
Address: NW 1/4 Section 3, T24N, R7E  
SPR: 053-24415-00062  
Reviewer: ERG/JR  
Date: July 17, 2007**

**1. Process Description:**

Max. Throughput Rate: 40 tons/hr of wetcake (provided by the source)

**2. Potential to Emit (PTE) of VOC and HAP:**

Pollutant	*Emission Factor (lbs/ton)	PTE (tons/yr)
VOC	8.13E-03	<b>1.42</b>
HAP		
Acetaldehyde	1.23E-04	<b>0.02</b>
Acrolein	1.83E-05	<b>3.21E-03</b>
Formaldehyde	7.33E-04	<b>0.13</b>
Methanol	1.53E-04	<b>0.03</b>
<b>Total HAP</b>		<b>0.18</b>

\* This is provided by the source based on the stack test results for DENCO, LLC in Morris, MN.

**Methodology**

PTE (tons/yr) = Max. Throughput Rate (tons/hr) x Emission Factor (lbs/ton) x 8760 hr/yr x 1 ton/2000 lbs

**Appendix A: Emission Calculations  
VOC and HAP Emissions from Ethanol Loading Racks (EU045A and EU045B)**

**Company Name: Central Indiana Ethanol, LLC  
Address: 2955 W. Delphi Pike Marion, IN 46952  
SPR: 053-24415-00062  
Reviewer: ERG/JR  
Date: July 17, 2007**

**1. Emission Factors: AP-42**

Denatured and blended ethanol will be shipped by either truck loading rack EU045A or railcar loading rack EU045B. The railcars and trucks may each be used to carry gasoline prior to filling with ethanol. Both railcars and trucks will be filled by submerged loading process. Only the truck loadout rack (EU045A) will be controlled by flare CE12 which has a control efficiency of 98% for VOC and HAPs.

According to AP-42, Chapter 5.2 - Transportation and Marketing of Petroleum Liquids (01/95), the VOC emission factors for the truck and rail loading racks can be estimated from the following equation:

$$L = 12.46 \times (SPM)/T$$

where:

- L = loading loss (lbs/kgal)
- S = a saturation factor (see AP-42, Table 5.2-1)
- P = true vapor pressure of the liquid loaded (psia)
- M = molecular weight of vapors
- T = temperature of the bulk liquid loaded (degree R)

Previous Stored Liquid	*S	P (psia)	M (lbs/mole lbs)	T (degree R)	L (lbs/kgal)
Gasoline (normal)	1.0	6.2	62	512.3	9.35
Gasoline (clean cargo)	0.5	6.2	62	512.3	4.67
Denatured Ethanol (normal)	0.6	0.50	49.7	512.3	0.36
Denatured Ethanol (clean cargo)	0.5	0.50	49.7	512.3	0.30
Blended Ethanol (normal)	0.6	1.54	57.4	512.3	1.29
Blended Ethanol (clean cargo)	0.5	1.54	57.4	512.3	1.07

Note: Blended Ethanol based on E70 specifications from TANKS 4.09.

Therefore, the emission factor for loading denatured ethanol to the trucks and railcars which stored gasoline previously  
 = L (gasoline, normal) - L (gasoline, clean cargo) + L (denatured ethanol, clean cargo) = **4.98 (lbs/kgal)**

Therefore, the emission factor for loading blended ethanol to the trucks and railcars which stored gasoline previously  
 = L (gasoline, normal) - L (gasoline, clean cargo) + L (blended ethanol, clean cargo) = **5.75 (lbs/kgal)**

**2. Potential to Emit VOC Before Control (assuming all blended Ethanol loaded out):**

Max. Loading Rate for EU40A: **48 kgal/hr (for truck loading)**  
 PTE of VOC before Control (tons/yr) = 48 kgal/hr x 5.75 lbs/gal x 8760 hr/yr x 1 ton/2000 lbs = **1,209 tons/yr**

Max. Loading Rate EU40B: **60 kgal/hr (for railcar loading)**  
 PTE of VOC before Control (tons/yr) = 60 kgal/hr x 5.75 lbs/gal x 8760 hr/yr x 1 ton/2000 lbs = **1,511.0 tons/yr**

**Appendix A: Emission Calculations  
VOC and HAP Emissions from Ethanol Loading Racks (EU045A and EU045B)**

**Company Name: Central Indiana Ethanol, LLC  
Address: 2955 W. Delphi Pike Marion, IN 46952  
SPR: 053-24415-00062  
Reviewer: ERG/JR  
Date: July 17, 2007**

**3. Limited Potential to Emit:**

*The amount of loadout emissions are restricted by the 4,900 kgal/yr Denaturant Limit.*

Annual Denatured and Blended Ethanol Production Limit:	64,900 kgal/yr (for both railcar and truck loading)
Annual Denaturant Limit:	4,900 kgal/yr (for both railcar and truck loading)
Max. Amount of Blended Ethanol (based on denaturant limit and E70 blend):	16,333 kgal/yr
Denatured Ethanol Non-Dedicated Railcar Limit:	2,500 kgal/yr
Max. Amount denaturant needed to make 2,500 kgal/yr Denatured Ethanol:	125 kgal/yr
Max. Amount of Blended Ethanol (based on denaturant limit, E70 blend, and 2,500 kgal/y denatured ethanol):	15,917 kgal/yr
Flare Control Efficiency:	98% (only for truck loadout operation EU40A)

(1) Assume all blended ethanol is loaded to trucks (controlled by flare CE12): VOC (tons/yr) = (5.75 lbs/kgal x 16,333 kgal/yr) x (1-98%) x 1 ton/2000 lbs =	<b>0.94 tons/yr</b>
(2) Assume all blended ethanol is loaded to dedicated railcars (no control): VOC (tons/yr) = (1.07 lbs/kgal x 16,333 kgal/yr) x 1 ton/2000 lbs =	<b>8.78 tons/yr</b>
(3) Assume all denatured ethanol is loaded to trucks (controlled by flare CE12): VOC (tons/yr) = (4.98 lbs/kgal x 64,900 kgal/yr) x (1-98%) x 1 ton/2000 lbs =	<b>3.23 tons/yr</b>
(4) Assume all denatured ethanol is loaded to dedicated railcars (no control): VOC (tons/yr) = (0.30 lbs/kgal x 64,900 kgal/yr) x 1 ton/2000 lbs =	<b>9.81 tons/yr</b>
(5) Assume 15,917 kgal blended ethanol is loaded to dedicated railcars (no control) and 2,500 kgal denatured ethanol is loaded to non-dedicated railcars (no control): VOC (tons/yr) = (1.07 lbs/kgal x 15,917 kgal/yr)+(4.98 lbs/kgal x 2,500 kgal/yr) x 1 ton/2000 lbs =	<b>14.8 tons/yr</b>
(6) Assume 62,400 kgal denatured ethanol is loaded to dedicated railcars (no control) and 2,500 kgal denatured ethanol is loaded to non-dedicated railcars (no control): VOC (tons/yr) = (0.30 lbs/kgal x 62,400 kgal/yr)+(4.98 lbs/kgal x 2,500 kgal/yr) x 1 ton/2000 lbs =	<b>15.6 tons/yr</b>
(7) Assume 15,917 kgal blended ethanol is loaded to trucks (control) and 2,500 kgal denatured ethanol is loaded to non-dedicated railcars (no control): VOC (tons/yr) = ((5.75 lbs/kgal x 15,917 kgal/yr)*(1-98%))+ (4.98 lbs/kgal x 2,500 kgal/yr) x 1 ton/2000 lbs =	<b>7.1 tons/yr</b>
(8) Assume 62,400 kgal denatured ethanol is loaded to trucks (control) and 2,500 kgal denatured ethanol is loaded to non-dedicated railcars (no control): VOC (tons/yr) = ((4.98 lbs/kgal x 62,400 kgal/yr)*(1-98%))+ (4.98 lbs/kgal x 2,500 kgal/yr) x 1 ton/2000 lbs =	<b>9.3 tons/yr</b>
<b>Worst case scenario is when loading 62,400 kgal/yr denatured ethanol and 2,500 kgal of denatured ethanol to non-dedicated railcars.</b>	<b>Thus the worst case VOC emissions = 15.6 tons/yr</b>

**4. Potential to Emit HAPs:**

HAP emissions are mainly from the unloading process for trucks and railcars which may have been used to ship gasoline previously.

HAP	HAP Fraction*	PTE of HAP before Control (tons/yr)	Limited PTE of HAP after Control (tons/yr)
Benzene	2.50E-03	3.04	2.03E-02
Carbon Disulfide	2.00E-05	0.02	1.63E-04
Cumene	1.00E-04	0.12	8.13E-04
Ethyl benzene	5.00E-05	0.06	4.06E-04
n-Hexane	5.00E-02	60.80	4.06E-01
Toluene	5.00E-03	6.08	4.06E-02
Xylene	5.00E-04	0.61	4.06E-03
<b>Total</b>		<b>70.7</b>	<b>0.47</b>

\* This is the HAP fraction for gasoline vapors.

**Methodology**

PTE of HAP before Control (tons/yr) = PTE of VOC before Control (tons/yr) x HAP %

Limited PTE of HAP after Control (tons/yr) = (Limited PTE of VOC by Trucks (tons/yr) + (Non-Dedicated Rail Limit x 5.00 lbs/kgal x 1 ton/2000 lbs) x HAP %

**Appendix A: Emission Calculations  
Combustion Emissions  
From Flare CE009 for Ethanol Loading Rack for Trucks (EU045A)**

**Company Name: Central Indiana Ethanol, LLC  
Address: 2955 W. Delphi Pike Marion, IN 46952  
SPR: 053-24415-00062  
Reviewer: ERG/JR  
Date: July 17, 2007**

Heat Input Capacity  
MMBtu/hr

Max. Load-out Rate  
kgal/hr

Annual Production Limit  
kgal/yr

10.0

48.0

64,900

	Pollutant					
Emission Factor	*PM NA	*PM10 NA	*SO <sub>2</sub> NA	**NO <sub>x</sub> 0.077 (lbs/kgal)	***VOC -	**CO 0.129 (lbs/kgal)
<b>Unlimited Potential to Emit in tons/yr</b>	<b>NA</b>	<b>NA</b>	<b>NA</b>	<b>16.2</b>	<b>1,511</b>	<b>27.1</b>
<b>Limited Potential to Emit in tons/yr</b>	<b>NA</b>	<b>NA</b>	<b>NA</b>	<b>2.50</b>	<b>15.6</b>	<b>4.19</b>

\*PM, PM10, and SO<sub>2</sub> emission factors are negligible due to the smokeless design and minimal H<sub>2</sub>S levels.

\*\*Emission factors for NO<sub>x</sub> and CO are based on the information provided by the flare manufacturer (MRW Technologies, Inc.)

\*\*\* VOC emission calculations can be found in page 10 of this appendix.

**Methodology**

PTE of PM/PM10 and SO<sub>2</sub> (tons/yr) = Max. Heat Input (MMBtu/hr) x 1 MMCF/1,000 MMBtu x Emission Factor (lbs/MMCF) x 8760 hr/yr x 1 ton/2000 lbs

Unlimited PTE of NO<sub>x</sub> and CO (tons/yr) = Max. Load-out Rate (kgal/hr) x Emission Factor (lbs/kgal) x 8760 hr/yr x 1 ton/2000 lbs

Limited PTE of NO<sub>x</sub> and CO (tons/yr) = Annual Production Limit (kgal/yr) x Emission Factor (lbs/kgal) x 1 ton/2000 lbs

Limited PTE of PM/PM10 and SO<sub>2</sub> (tons/yr) = Unlimited PTE (tons/yr) x Annual Production Limit (kgal/yr) / (Max. Load-out Rate kgal/hr x 8760 hr/yr)

**Appendix A: Emission Calculations  
PM/PM10 Emissions  
From the the Cooling Tower (Insignificant Activity)**

**Company Name: Central Indiana Ethanol, LLC  
Address: NW 1/4 Section 3, T24N, R7E  
SPR: 053-24415-00062  
Reviewer: ERG/JR  
Date: July 17, 2007**

**1. Process Description:**

Type of Cooling Tower:	Induced Draft
Circulation Flow Rate:	45,000 gal/min
Total Drift:	0.005% of the circulating flow
Total Dissolved Solids:	2,500 ppm
Density:	8.345 lbs/gal

Note: The information above was provided by the cooling tower manufacturer for the same units located at a similar source.

**2. Potential to Emit PM/PM10:**

Assume all the dissolved solids become PM10 emissions and assume PM emissions are equal to PM10 emissions.

$$\text{PTE of PM/PM10 (lbs/hr)} = 45,000 \text{ gal/min} \times 60 \text{ min/hr} \times 0.005\% \times 8.345 \text{ lbs/gal} \times 2,500 \text{ ppm} \times 1/1,000,000 \text{ ppm} = \quad \mathbf{2.82 \text{ lbs/hr}}$$

$$\text{PTE of PM/PM10 (tons/yr)} = 2.82 \text{ lbs/hr} \times 8760 \text{ hr/yr} \times 1 \text{ ton}/2000 \text{ lbs} = \quad \mathbf{12.3 \text{ tons/yr}}$$

**Appendix A: Emission Calculations  
Criteria Pollutants  
From the Diesel Fire Pump (EU034)**

**Company Name: Central Indiana Ethanol, LLC  
Address: NW 1/4 Section 3, T24N, R7E  
SPR: 053-24415-00062  
Reviewer: ERG/JR  
Date: July 17, 2007**

Power Output  
Horse Power (HP)

Operation Limit  
hr/yr

300

500

Emission Factor in lb/HP-hr	Pollutant					
	PM*	PM10*	SO <sub>2</sub>	NO <sub>x</sub>	**VOC	CO
	2.20E-03	2.20E-03	2.05E-03	3.10E-02	2.47E-03	6.68E-03
<b>Potential to Emit in tons/yr</b>	<b>0.17</b>	<b>0.17</b>	<b>0.15</b>	<b>2.33</b>	<b>0.19</b>	<b>0.50</b>

\*Assume PM10 emissions are equal to PM emissions.

\*\* Assume TOC (total organic compounds) emissions are equal to VOC emissions.

Emission factors are from AP-42, Chapter 3.3, Table 3.3-1, SCC #2-02-001-02 and 2-03-001-01 (AP-42 Supplement B, 10/96).

**Methodology**

$$\text{PTE (tons/yr)} = \text{Power Output (HP)} \times \text{Emission Factor (lb/HP-hr)} \times \text{Operation Limit (hr/yr)} \times 1 \text{ ton}/2000 \text{ lbs}$$

**Appendix A: Emission Calculations  
Combustion Emissions  
From Biomethanator Flare CE013**

**Company Name: Central Indiana Ethanol, LLC  
Address: NW 1/4 Section 3, T24N, R7E  
SPR: 053-24415-00062  
Reviewer: ERG/JR  
Date: July 17, 2007**

\*This methanator flare only operates when the DDGS dryers are down.

Max. Heat Input  
MMBtu/hr

3.20
------

	Pollutant						
Emission Factor in lb/MMBtu	PM <sup>b</sup>	PM10 <sup>b</sup>	SO <sub>2</sub> <sup>b</sup>	NO <sub>x</sub> <sup>a</sup>	CO <sup>a</sup>	VOC <sup>a</sup>	HAP <sup>b</sup>
	-	-	-	0.068	0.37	0.052	-
<b>PTE (tons/yr)</b>	Negligible	Negligible	Negligible	<b>0.95</b>	<b>5.19</b>	<b>0.73</b>	Negligible

<sup>a</sup> Emission factors are from AP-42, Tables 13.5-1 and 13.5-2 (AP-42, 01/95).

<sup>b</sup> The Permittee stated that PM/PM10 emissions from this flare are negligible due to the smokeless design. The PTE of SO<sub>2</sub> and HAP are negligible due to negligible sulfur and HAP presence in the gas stream.

**Methodology**

PTE (tons/yr) = Max. Heat Input (MMBtu/hr) x Emission Factor (lbs/MMBtu) x 8760 hrs/yr x 1 ton/2000 lbs

**Appendix A: Emission Calculations  
Combustion Emissions  
Insignificant Combustion Activities**

**Company Name: Central Indiana Ethanol, LLC  
Address: 2955 W. Delphi Pike Marion, IN 46952  
SPR: 053-24415-00062  
Reviewer: ERG/JR  
Date: July 17, 2007**

Description of Insignificant Combustion Activities:

Natural gas fired space heaters with a total firing capacity of 2.5 MMBtu/hr.

Maximum Heat Input MMBtu/hr	Potential Throughput MMCF/yr
2.5	22.3

	Pollutant					
	PM	PM10	SO2	NO <sub>x</sub>	VOC	CO
Emission Factor* Units	1.9 lb/MMCF	7.6 lb/MMCF	0.6 lb/MMCF	94.0 lb/MMCF	5.5 lb/MMCF	84.0 lb/MMCF
Potential Emission in tons/yr	2.12E-02	8.49E-02	6.70E-03	1.05E+00	6.14E-02	9.38E-01

\* Emission factors from Fifth Edition AP-42, Section 1.4, "Natural Gas Combustion", 7/98.

**Methodology**

Potential Throughput (MMCF/yr) = Heat Input Capacity (MMBtu/hr) x 8,760 hrs/yr x 1 MMCF/1,020 MMBtu  
 Potential Emission in tons/yr = Potential Throughput (MMCF/yr) x Emission Factor (lb/MMCF) \* 1 ton/2000lbs

**HAPs - Organics**

	Benzene	Dichlorobenzene	Formaldehyde	Hexane	Toluene
Emission Factor in lb/MMCF	2.1E-03	1.2E-03	7.5E-02	1.8E+00	3.4E-03
Potential Emission in tons/yr	2.35E-05	1.34E-05	8.38E-04	2.01E-02	3.80E-05

**HAPs - Metals**

	Lead	Cadmium	Chromium	Manganese	Nickel
Emission Factor in lb/MMCF	5.0E-04	1.1E-03	1.4E-03	3.8E-04	2.1E-03
Potential Emission in tons/yr	5.58E-06	1.23E-05	1.56E-05	4.24E-06	2.35E-05

Emission Factors from AP-42, Chapter 1.4, Tables 1.4-1, 1.4-2, and 1.4-3, SCC #1-02-006-02, 1-01-006-02, 1-03-006-02, and 1-03-006-03 (AP-42 Supplement D 3/98)

The five highest organic and metal HAPs emission factors are provided above.  
 Additional HAPs emission factors are available in AP-42, Chapter 1.4.

**Methodology**

All Emission factors are based on normal firing.

Potential Throughput (MMCF/yr) = Heat Input Capacity (MMBtu/hr) x 8,760 hrs/yr x 1 MMCF/1,020 MMBtu  
 Potential Emission in tons/yr = Potential Throughput (MMCF/yr) x Emission Factor (lb/MMCF)/2,000 lb/ton  
 Limited Potential Emission in tons/yr = Limited Throughput (MMCF/yr) x Emission Factor (lb/MMCF)/2,000 lb/ton

**Appendix A: Emission Calculations  
VOC and HAP Emissions  
From the Corn Oil Separation Unit and Storage Tanks (EU061, EU062, and EU063)**

**Company Name: Central Indiana Ethanol, LLC  
Address: 2955 W. Delphi Pike Marion, IN 46952  
SPR: 053-24415-00062  
Reviewer: ERG/JR  
Date: July 17, 2007**

**Potential to Emit (PTE) for Corn Oil Separation Unit (EU061):**

The thin stillage will be processed through a separation process to collect and store excess corn oil. The separation process will be enclosed resulting in no emissions. Loadout and Truck Traffic emissions are negligible based on low annual throughput.

**Potential to Emit (PTE) for Storage Tanks (EU062 and EU063):**

Pollutant	PTE (lb/hr)	PTE (ton/yr)	HAP?	VOC?
Ethanol	0.04	0.19	Y	Y
Methanol**	0.0140	0.06	Y	Y
Ethylacetate**	0.0140	0.06	N	Y
2-furaldehyde	0.0001	4.38E-04	N	Y
Formaldehyde	0.0002	8.76E-04	Y	Y
Acetaldehyde	0.0002	8.76E-04	Y	Y
Acrolein	0.0001	4.38E-04	Y	Y
Formic Acid	0.0030	0.01	N	Y
Lactic Acid	0.0090	0.04	N	Y
Acetic Acid	0.0390	0.17	N	Y
Phosphorous**	0.0080	0.04	Y	N
<b>Total VOC</b>	<b>0.13</b>	<b>0.54</b>		
<b>Total HAP</b>	<b>0.07</b>	<b>0.29</b>		

\* These values were provided by the source based on analytical testing.

\*\* Concentration was reported as less than the detection limit; therefore the values half the detection limit.

**Appendix A: Emission Calculations**  
**Fugitive Emissions (To Determine 326 IAC 6-5 Applicability)**

Company Name: Central Indiana Ethanol, LLC  
 Address: 2955 W. Delphi Pike Marion, IN 46952  
 SPR: 053-24415-00062  
 Reviewer: ERG/JR  
 Date: July 17, 2007

**1. Emission Factors: AP-42**

According to AP-42, Chapter 13.2.1 - Paved Roads (12/03), the PM/PM10 emission factors for paved roads can be estimated from the following equation:

$$E = (k \times (sL/2)^a \times (w/3)^b - C) \times (1 - p / (4 \times 365))$$

where:

E = emission factor (lb/vehicle mile traveled)  
 sL (non-Winter) = road surface silt loading (g/m<sup>2</sup>) = 0.6 (g/m<sup>2</sup>) (AP-42, Table 13.2.1-3)  
 sL (Winter) = sL (non-Winter) x 4 (g/m<sup>2</sup>) = 2.4 (g/m<sup>2</sup>) (AP-42, Table 13.2.1-3)  
 w = mean vehicle weight (tons) = 29.0 tons  
 k = empirical constant = 0.082 for PM and 0.016 for PM10  
 a = empirical constant = 0.65  
 b = empirical constant = 1.5  
 C = emission factor for exhaust, brake and tire wear 0.00047 for PM and PM10  
 p = number of days per year with 0.01 inches precipitation 130

PM Emission Factor (non-Winter) =  $(0.082 \times (0.6/2)^{0.65} \times (27.5/3)^{1.5} - 0.00047) \times (1 - 120/1460) = 1.03$  lbs/mile  
 PM10 Emission Factor (non-Winter) =  $(0.016 \times (0.6/2)^{0.65} \times (27.5/3)^{1.5} - 0.00047) \times (1 - 120/1460) = 0.20$  lbs/mile  
 PM Emission Factor (Winter) =  $(0.082 \times (2.4/2)^{0.65} \times (27.5/3)^{1.5} - 0.00047) \times (1 - 120/1460) = 2.53$  lbs/mile  
 PM10 Emission Factor (Winter) =  $(0.016 \times (2.4/2)^{0.65} \times (27.5/3)^{1.5} - 0.00047) \times (1 - 120/1460) = 0.50$  lbs/mile  
 PM Emission Factor (Average Annual) = ((PM Emission Factor (non-Winter) x 9) + (PM Emission Factor (Winter) x 3))/12  
 PM Emission Factor (Average Annual) = 1.40 lbs/mile  
 PM10 Emission Factor (Average Annual) = ((PM10 Emission Factor (non-Winter) x 9) + (PM10 Emission Factor (Winter) x 3))/12  
 PM10 Emission Factor (Average Annual) = 0.28 lbs/mile

**2. Potential to Emit (PTE) of PM/PM10 from Paved Roads:**

Vehicle Type	Ave Weight of Vehicles* (tons)	Trip Number* (trips/yr)	Round Trip Distance* (mile/trip)	Vehicle Mile Traveled (VMT) (miles/yr)	Traffic Component (%)	Component Vehicle Weight (tons)	PTE of PM (tons/yr)	PTE of PM10 (tons/yr)
Grain Receiving	29.0	25,872	0.84	21,732	60.5%	17.55	15.2	2.99
DDGS Load Out	29.0	8,400	0.84	7,056	19.6%	5.70	4.9	0.97
Ethanol Load Out	29.0	8,112	0.84	6,814	19.0%	5.50	4.8	0.94
Denaturant Delivery	29.0	375	0.84	315	0.9%	0.25	0.2	0.04
<b>Total</b>				<b>35,918</b>	<b>100%</b>	<b>29.0</b>	<b>25.2</b>	<b>4.94</b>

\* This information is provided by the source.

**Methodology**

Vehicle Mile Traveled (miles/yr) = Trip Number (trips/yr) x Round Trip Distance (mile/trip)  
 Traffic Component (%) = VMT / Total VMT  
 Component Vehicle Weight = Ave. Weight of Vehicles (tons) x Traffic Component (%)  
 PTE of PM/PM10 before Control (tons/yr) = VMT (miles/yr) x PM/PM10 Emission Factors (Average Annual) x 1 ton/2000 lbs

**3. Unpaved Road Emission Factors: AP-42**

According to AP-42, Section 13.2.2 Unpaved Roads, November 2006, the PM/PM10 emission factors for unpaved roads can be estimated from the following equation:

$$\text{lbs/VMT Equation: } E = k (s/12)^a (W/3)^b \times (365-P)/365$$

Where:

Particle size multiplier k 4.9 dimensionless (PM-30 or TSP) 1.5 dimensionless PM-10  
 surface material silt content (%) s 8.5 Table 13.2.2-1  
 mean vehicle weight W 5.00 tons  
 Equation constants a 0.7 PM-30 or TSP Table 13.2.2-2 0.9 PM-10 Table 13.2.2-2  
 b 0.45 PM-30 or TSP Table 13.2.2-2 0.45 PM-10 Table 13.2.2-2  
 P 117

PM Emission Factor =  $(4.9) \times (8.5/12)^{0.7} \times (5/3)^{0.45} \times (365-117)/365 = 3.29$  lbs/mile  
 PM10 Emission Factor =  $(1.5) \times (8.5/12)^{0.9} \times (5/3)^{0.45} \times (365-117)/365 = 0.94$  lbs/mile

**4. Potential to Emit (PTE) of PM/PM10 from Unpaved Roads:**

Emission Area	Number of Trucks (Truck/yr)	Miles Traveled per Truck (miles/Truck)	Unpaved Total VMT	Total Vehicle Emissions (lb/yr)	Total Vehicle Emissions (tpy)
Maintenance Roads (PM)	730	0.20	146	481	0.24
Maintenance Roads (PM10)	730	0.20	146	137	0.07

**Methodology**

Total Vehicle Emissions (tons/yr) = Unpaved Total VMT (miles/yr) x PM/PM10 Emission Factors x 1 ton/2000 lbs

**5. Potential to Emit PM/PM10 from Grain Handling:**

Unit ID	Unit Description	Annual Throughput Limit (tons/yr)	Uncontrolled PM Emission Factor (lbs/ton)	Uncontrolled PM10 Emission Factor (lbs/ton)	Baghouse ID	Capture Efficiency (%)	Fugitive PM Emissions (tons/yr)	Fugitive PM10 Emissions (tons/yr)
EU001	Grain Receiving	646,800	0.035	0.0078	CE001	80%	2.26	0.50
EU040-EU042	DDGS Handling Operations	210,000	0.0610	0.0340	N/A	80%	1.28	0.71
EU043	DDGS Loadout Operation	210,000	0.0033	0.0008	N/A	80%	0.07	0.02
<b>Total</b>							<b>2.26</b>	<b>0.50</b>

Note: Emission factors are from AP-42, Chapter 9.9.1 - Grain Elevators, Table 9.9.1-1 (04/03). Assume all the grain receiving and loadout is by truck, which is the worst case scenario. The Permittee stated that there are no fugitive emissions from the grain handling operations because the emissions from these units are 100% captured.

**Methodology**

Fugitive PM/PM10 (tons/yr) = Annual Throughput Limit (tons/yr) x Uncontrolled Emission Factor (lbs/ton) x (1-Capture Efficiency%) x 1 ton/2000 lbs

**Appendix A: Emission Calculations  
PTE Summary**

**Company Name: Central Indiana Ethanol, LLC  
Address: NW 1/4 Section 3, T24N, R7E  
SPR: 053-24415-00062  
Reviewer: ERG/JR  
Date: March 29, 2006**

**Limited Potential To Emit after Control**

<b>Emission Units</b>	<b>PM</b>	<b>PM10</b>	<b>SO<sub>2</sub></b>	<b>*NO<sub>x</sub></b>	<b>VOC</b>	<b>CO</b>	<b>Total HAPs</b>
Grain Receiving and Handling	12.6	12.6	-	-	-	-	-
Fermentation	-	-	-	-	33.4	-	7.64
Dryers and RT/HRSG Sytems	35.0	35.0	37.2	86.3	32.9	92.0	4.88
DDGS Cooler	4.13	4.13	-	-	6.83	-	0.53
DDGS Handling and Loadout	0.70	0.70	-	-	-	-	-
Wet Cake Storage*	-	-	-	-	See Note	-	See Note
Ethanol Loadout and Flare	-	-	-	2.50	15.6	4.19	0.47
Cooling Tower	12.3	12.3	-	-	-	-	-
Diesel Fire Pump	0.17	0.17	0.15	2.33	0.19	0.50	Negligible
Storage Tanks**	-	-	-	-	2.67	-	Negligible
Corn Oil Storage	-	-	-	-	0.54	-	0.29
Biomethanator Flare***	-	-	-	See Note	See Note	See Note	See Note
Insignificant Combustion	0.02	0.08	0.01	1.05	0.06	0.94	0.02
Other Insignificant Activities	1.00	1.00	-	-	1.00	-	-
<b>Total PTE</b>	<b>66.0</b>	<b>66.0</b>	<b>37.4</b>	<b>92.2</b>	<b>93.2</b>	<b>97.6</b>	<b>13.8</b>

Note:

\* This plant is capable to produce both DDGS and MDGS. The emissions from the DDGS production is the worst case scenario. Therefore, the PTE of the wet cake storage is not included in the PTE for the entire source.

\*\* Emissions from the storage tanks were calculated by the Permittee using EPA TANKS software (version 4.09d) and have been verified.

\*\*\* Biomethanator flare only operates when the DDGS dryers are down. The operation of the DDGS dryers is the worst case senario for emissions and the emissions from the DDGS dryers have been included in the total PTE.

## Indiana Department of Environmental Management Office of Air Quality

### Technical Support Document (TSD) for a Significant Permit Revision to a Federally Enforceable State Operating Permit (FESOP)

<b>Source Background and Description</b>
--

Source Name:	Central Indiana Ethanol, LLC
Source Location:	2955 W. Delphi Pike, Marion, Indiana 46952
County:	Grant
SIC Code:	2869
Operation Permit No.:	F053-21057-00062
Operation Permit Issuance Date:	August 4, 2005
Significant Permit Revision No.:	053-24415-00062
Permit Reviewer:	ERG/JR

The Office of Air Quality (OAQ) has reviewed a revision application from Central Indiana Ethanol, LLC, relating a change in the construction and operation of an ethanol production plant.

<b>History</b>
----------------

Central Indiana Ethanol, LLC is an ethanol production plant and was permitted to construct and operate as a dry mill plant in FESOP No. 053-21057-00062, issued on August 4, 2005. The Permittee has not completed the construction of this plant. On March 8, 2007, Central Indiana Ethanol, LLC, submitted a permit revision application to IDEM, OAQ requesting the following changes to their FESOP:

- (a) Decrease the permitted capacity of the Corn Bins #1 and #2 (EU004 and EU005) from 802,000 bushels to 200,000 Bushels each.
- (b) Increase the permitted denatured ethanol loadout rate from 63,000 kgal per year to 64,900 kgal per year.
- (c) Allow for blended ethanol, a mixture of up to a maximum of 30% gasoline, to be loaded out at the loadout operation.
- (d) Accept a denaturant limit of 4,900 kgal per year.
- (e) Allow for the use of non-dedicated railcars at the loadout operation and accept a denatured ethanol loadout rate limit on the non-dedicated railcars of 2,500 kgal per year.
- (f) Construct the following additional process equipment:
  - (1) Two (2) 425,000 bushel corn storage bins, identified as EU064 and EU065.
  - (2) One (1) Fermenter, identified as EU057,
  - (3) One (1) Slurry Mixer, identified as EU058,
  - (4) One (1) Liquefaction Tank, identified as EU059,

- (5) One (1) corn oil separation unit, identified as EU061, and
- (6) Two (2) corn oil storage tanks, identified as EU062 and EU063.
- (g) The Permittee also revised the truck traffic road emissions to account for an increased silt load factor in the winter months, and provided emissions estimates for insignificant activities.
- (h) The source location has been corrected to "2955" from "2255" W. Delphi Pike.

**Existing Approvals**

The source was issued FESOP No. F053-21057-00062 on August 4, 2005. The source was issued a Significant Permit Revision No. 053-22564-00062 on July 20, 2006. There are no other air approvals issued to this source.

**Enforcement Issue**

There are no enforcement actions pending.

**Recommendation**

The staff recommends to the Commissioner that the Significant Permit Revision be approved. This recommendation is based on the following facts and conditions:

Unless otherwise stated, information used in this review was derived from the application and additional information submitted by the applicant.

An application for the purposes of this review was received on March 8, 2007.

**Emission Calculations**

See Appendix A of this document for detailed emissions calculations (pages 1 through 8).

**Potential To Emit of the Modification After Issuance**

Pursuant to 326 IAC 2-1.1-1(16), Potential to Emit is defined as the maximum capacity of a stationary source to emit any air pollutant under its physical and operational design. Any physical or operational limitation on the capacity of a source to emit an air pollutant, including air pollution control equipment and restrictions on hours of operation or type or amount of material combusted, stored, or processed shall be treated as part of its design if the limitation is enforceable by the U. S. EPA.

This table reflects the potential to emit (PTE) after controls, reflecting all limits at the emission units, for the modification. Control equipment is not considered federally enforceable until it has been required in a federally enforceable permit.

Process/Emission Unit	Potential To Emit (tons/year)						
	PM	PM10	SO <sub>2</sub>	VOC	CO	NO <sub>x</sub>	HAPs
Ethanol Loading Racks	Negligible	Negligible	Negligible	4.00	0.13	0.07	0.51
Paved Roads and Unpaved (Fugitive)	3.57	0.74	-	-	-	-	-
Corn Oil Storage	-	-	-	0.54	-	-	0.29
Insignificant Combustion	0.02	0.08	0.01	0.06	0.94	1.05	0.02
Modification Increases	3.59	0.82	0.01	4.60	1.07	1.12	Less than 0.03 for a single HAP and 0.82 for total HAPs

**Justification for Permit Revision**

Pursuant to 326 IAC 2-8-1.1(g)(2), the FESOP is being modified through a Significant Permit Revision, since this modification requires an adjustment to an emission cap limitation.

**Potential to Emit of Entire Source After Issuance**

The table below summarizes the total potential to emit of the entire source after controls, reflecting all limits. The control equipment is considered federally enforceable only after issuance of this Permit Revision. Emissions from modified processes and emission units are shown in strikethrough (before modification) and bold (after modification).

Process/Emission Unit	Potential To Emit (tons/year)						
	PM	PM10	SO <sub>2</sub>	VOC	CO	NO <sub>x</sub>	HAPs
Grain Receiving and Handling Operations	12.6	12.6	-	-	-	-	-
Grain Receiving – Fugitive	2.26	0.50	-	-	-	-	-
Fermentation Process and Distillation Process	-	-	-	33.4	-	-	7.64
Distillation, DDGS Dryers, and TO/HRSG System	35.0	35.0	37.2	32.9	92.0	86.3	4.88
DDGS Cooler	4.13	4.13	-	6.83	-	-	0.53
DDGS Handling and Loadout Operations	0.70	0.70	-	-	-	-	-
DDGS Loadout - Fugitive	1.35	0.73	-	-	-	-	-
Wet Cake Storage*	-	-	-	See Note	-	-	See Note
Ethanol Loading Racks	Negligible	Negligible	Negligible	<del>11.6</del> <b>15.6</b>	<del>4.06</del> <b>4.19</b>	<del>2.43</del> <b>2.50</b>	<del>0.04</del> <b>0.55</b>
Paved Roads and Unpaved (Fugitive)	<del>9.23</del> <b>12.8</b>	<del>4.80</del> <b>2.54</b>	-	-	-	-	-
<b>Corn Oil Storage</b>	-	-	-	<b>0.54</b>	-	-	<b>0.29</b>
Cooling Tower (Insignificant)	12.3	12.3	-	-	-	-	-
Diesel Fire Pump (Insignificant)	0.17	0.17	0.15	0.19	0.50	2.33	Negligible
Storage Tanks (Insignificant)	-	-	-	2.67	-	-	Negligible
Equipment Leaks (Fugitive)	-	-	-	5.34	-	-	0.31
Biomethanator Flare** (Insignificant)	-	-	-	See Note	See Note	See Note	-
<b>Insignificant Combustion</b>	<b>0.02</b>	<b>0.08</b>	<b>0.01</b>	<b>0.06</b>	<b>0.94</b>	<b>1.05</b>	<b>0.02</b>
Other Insignificant Activities	1.0	1.0	-	1.0	-	-	-
Total PTE of the Entire Source	<del>78.8</del> <b>82.3</b>	<del>69.0</del> <b>69.7</b>	37.4	<del>93.8</del> <b>98.5</b>	<del>96.5</del> <b>97.6</b>	<del>91.0</del> <b>92.2</b>	Less than <del>8.93</del> <b>8.96</b> for a single HAP and 13.4

Process/Emission Unit	Potential To Emit (tons/year)						
	PM	PM10	SO <sub>2</sub>	VOC	CO	NO <sub>x</sub>	HAPs
							14.2 for total HAPs
PSD/TV Major Thresholds	100	100	100	100	100	100	10 for a single HAP and 25 for total HAPs

Note: “-“ pollutant not emitted by the facility.

\* This plant is capable of producing both DDGS and MDGS. The emissions from DDGS production is the worst case scenario. Therefore, the PTE of wet cake storage is not included in the PTE for the entire source.

\*\* The Biomethanator flare will not operate when any of the DDGS dryers are in operation. The emissions from the DDGS dryers are the worst case scenario. Therefore, the PTE of the biomethanator flare is not included in the PTE for the entire source.

After making the changes proposed in this revision, the potential to emit of the criteria pollutants from the entire source is still limited to less than the Title V and PSD major source thresholds. Therefore, the requirements of 326 IAC 2-7 and 326 IAC 2-2 are not applicable to this source.

**County Attainment Status**

The source is located Grant County.

Pollutant	Status
PM	Attainment
PM10	Attainment
PM2.5	Attainment
SO <sub>2</sub>	Attainment
NO <sub>2</sub>	Attainment
8-hour Ozone	Attainment
CO	Attainment
Lead	Attainment

- (a) Volatile organic compounds (VOC) and Nitrogen Oxides are regulated under the Clean Air Act (CAA) for the purposes of attaining and maintaining the National Ambient Air Quality Standards (NAAQS) for ozone. Therefore, VOC and NO<sub>x</sub> emissions are considered when evaluating the rule applicability relating to the ozone standards. Grant County has been designated as attainment or unclassifiable for ozone. Therefore, VOC and NO<sub>x</sub> emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2.
- (b) Grant County has been classified as unclassifiable or attainment for PM 2.5. U.S. EPA has not yet established the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2 for PM 2.5 emissions. Therefore, until the U.S. EPA adopts specific provisions for PSD review for PM 2.5 emissions, it has directed states to regulate PM10 emissions as a surrogate for PM 2.5 emissions.
- (c) Grant County has been classified as attainment or unclassifiable in Indiana for all other criteria pollutants. Therefore, these emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2.
- (d) Fugitive Emissions  
 Since this type of operation is in one of the twenty-eight (28) listed source categories under 326 IAC 2-2, the fugitive particulate matter (PM) and volatile organic compound (VOC) emissions are counted toward determination of PSD applicability.

**Federal Rule Applicability for the Revision**

- (a) There are no New Source Performance Standards (NSPS)(326 IAC 12 and 40 CFR Part 60) included in this revision for this proposed modification.

- (1) Ethanol is one of the chemicals listed in 40 CFR 60.667. However, according to the EPA memorandum from Mr. George T. Czerniak dated December 6, 2002, the manufacture of ethanol using a fermentation process (biological synthesis) was excluded from the scope of NSPS, Subpart NNN. Therefore, the distillation unit at this new ethanol production plant is not subject to the requirements of New Source Performance Standards for Volatile Organic Liquid Storage Vessels VOC Emissions From Synthetic Organic Chemical Manufacturing Industry (SOCMI) Distillation Operations (326 IAC 12, 40 CFR 60.660 - 667, Subpart NNN).
  - (2) The requirements of New Source Performance Standards for Subpart XX, Standards of Performance for Bulk Gasoline Terminals (326 IAC 12, 40 CFR 60.500 - 506, Subpart XX) are not included in this permit for the ethanol and E85 loading rack for trucks EU045A or railcar loading rack EU045B. The loading racks are not considered a bulk gasoline terminal as defined in 40 CFR 60.501.
  - (3) The New Source Performance Standards for Volatile Organic Liquid Storage Vessels for which construction, reconstruction, or modification commenced after July 23, 1984 (326 IAC 12, 40 CFR 60.110b - 117b, Subpart Kb) are not included for storage vessels EU059, EU062, and EU063. Tanks EU059, EU062, and EU063 have capacities greater than 75 cubic meters (19,813 gallons) but less than 151 cubic meters (39,890 gallons) and the stored liquids have vapor pressures less than 15.0 kPa.
- (b) There are no National Emission Standards for Hazardous Air Pollutants (NESHAPs)(326 IAC 14 and 40 CFR Part 63) included in this revision for this proposed modification.
- (1) This source will comply with the FESOP limits to limit the HAP emissions from the entire source to less than 10 tons/yr for a single HAP and less than 25 tons/yr for total HAPs. Therefore, the requirements of the NESHAP for Reciprocating Internal Combustion Engines (40 CFR 63, Subpart ZZZZ) are not included in this permit.
  - (2) The requirements of 40 CFR Part 63, Subpart F (National Emission Standards for Organic Hazardous Air Pollutants From Synthetic Organic Chemical Manufacturing Industry), 40 CFR Part 63, Subpart G (National Emission Standards for Organic Hazardous Air Pollutants from Synthetic Organic Chemical Manufacturing Industry for Process Vents, Storage Vessels, Transfer Operations, and Wastewater), and 40 CFR Part 63, Subpart H (National Emission Standards for Organic Hazardous Air Pollutants for Equipment Leaks), are not included in this permit because (1) this source has accepted limits that make it a minor source of hazardous air pollutants; (2) the source does not manufacture as a primary product any of the chemicals listed in Table 1 of 40 CFR 63, Subpart F, Tetrahydro-benzaldehyde, or Crotonaldehyde; and (3) the source does not use as a reactant, manufacture as a product or co-product any of the chemicals listed in Table 2 of 40 CFR 63, Subpart F.
  - (3) The requirements of 40 CFR 63, Subpart I – National Emission Standards for Organic Hazardous Air Pollutants for Certain Processes Subject to the Negotiated Regulation for Equipment Leaks are not included in this permit. The source does not operate any of the processes specified in 40 CFR 63.190(b).
  - (4) This source is a minor source of HAPs. Therefore, the cooling towers at this source are not subject to the NESHAP for Industrial Process Cooling Towers (40 CFR 63, Subpart Q).
  - (5) This source is a minor source of HAPs. Therefore, this source is not subject to the requirements of the NESHAP for Organic Liquids Distribution (non-gasoline) (40 CFR 63, Subpart EEEE).

- (6) This source is a minor source of HAPs. Therefore, this source is not subject to the requirements of the NESHAP for Miscellaneous Organic Chemical Manufacturing (40 CFR 63, Subpart FFFF).

<b>State Rule Applicability - Entire Source</b>
---

**326 IAC 2-4.1 (New Sources of Hazardous Air Pollutants)**

This source was approved for constructed in 2006. The source has accepted FESOP limits on the HAP emissions from the entire source, such that the emissions from the source are limited to less than 10 tons/yr for a single HAP and less than 25 tons/yr for any combination of HAPs (see the discussion of 326 IAC 2-8-4 below). Therefore, the requirements of 326 IAC 2-4.1 are not applicable.

**326 IAC 2-8-4 (FESOP) and 326 IAC 2-2 (PSD)**

The potential to emit PM, PM10, VOC, CO, and NOx before control of the entire source is greater than 100 tons/yr. In addition, the potential to emit HAP before control from this source is greater than 10 tons/yr for a single HAP and greater than 25 tons/yr for total HAPs. The potential to emit PM and all criteria pollutants from all the existing permitted units is limited to less than 100 tons per year. Therefore, the requirements of 326 IAC 2-2 (PSD) and 326 IAC 2-7 (Part 70 Program) are not applicable. With the potential to emit VOC from the proposed increase of denatured and blended ethanol load-out, the potential to emit VOC from the entire source will exceed 100 tons per year. In order to retain their FESOP status, the Permittee has proposed to adjust the existing FESOP limits for the ethanol loading racks (EU045A and EU045B). The Permittee has agreed to comply with the following throughput limits and other requirements for the ethanol loading racks (EU045A and EU045B):

- (a) The total combined denatured ethanol and blended ethanol load-out from loading racks EU045A and EU045B shall not exceed 64,900,000 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (b) The total denaturant used at the loading racks EU045A and EU045B shall not exceed 4,900,000 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (c) The total denatured ethanol load-out into non-dedicated railcars shall not exceed 2,500,000 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (d) The blended ethanol shall not exceed a blend of 30% gasoline.
- (e) No ethanol that exceeds 5% gasoline shall be loaded to non-dedicated railcars.

Combined with the emissions from other permitted units, the potential to emit PM and criteria pollutants from the entire source is still limited to less than 100 tons per year (see the table in the "Potential to Emit of the Source after Revision" section). Therefore, this source will retain their FESOP status after this revision and the requirements of 326 IAC 2-2 (PSD) are not applicable.

**326 IAC 2-6 (Emission Reporting)**

This source is located in Grant County and is not required to operate under a Part 70 permit. Therefore, the requirements of 326 IAC 2-6 are not applicable to this source.

**326 IAC 5-1 (Opacity Limitations)**

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity for sources shall meet the following, unless otherwise stated in this permit:

- (a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.

- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

### State Rule Applicability - Corn Storage Bins

#### 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes)

Pursuant to 326 IAC 6-3-2, particulate emissions from each of the following operations shall not exceed the pound per hour limits listed in the table below:

Unit ID	Unit Description	Max. Throughput Rate (tons/hr)	Particulate Emission Limit (lbs/hr)
EU064	Corn Storage Bin	420	66.9
EU065	Corn Storage Bin	420	66.9

The pounds per hour limitations were calculated using the following equation:

Interpolation and extrapolation of the data for the process weight rate in excess of sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 55.0 P^{0.11} - 40 \quad \text{where } E = \text{rate of emission in pounds per hour; and} \\ P = \text{process weight rate in tons per hour}$$

Pursuant to 326 IAC 6-3-2(e)(3), when the process weight exceeds 200 tons per hour, the maximum allowable emission may exceed the emission limits shown in the table above, provided the concentration of particulate matter in the gas discharged to the atmosphere is less than 0.10 pounds per 1,000 pounds of gases.

As shown in the calculations in Appendix A, the potential to emit PM after control from the grain receiving and handling operations (which includes the proposed Corn Storage Bins) is less than the emission limits above. Therefore, these operations are capable of complying with 326 IAC 6-3-2. The use of the baghouses CE001 is necessary to ensure compliance with the limits above.

### Testing Requirements

There is no additional testing required for the proposed modification.

### Compliance Requirements

Permits issued under 326 IAC 2-8 are required to ensure that sources can demonstrate compliance with applicable state and federal rules on a more or less continuous basis. All state and federal rules contain compliance provisions, however, these provisions do not always fulfill the requirement for a more or less continuous demonstration. When this occurs IDEM, OAQ, in conjunction with the source, must develop specific conditions to satisfy 326 IAC 2-8-4. As a result, compliance requirements are divided into two sections: Compliance Determination Requirements and Compliance Monitoring Requirements.

Compliance Determination Requirements in Section D of the permit are those conditions that are found more or less directly within state and federal rules and the violation of which serves as grounds for enforcement action. If these conditions are not sufficient to demonstrate continuous compliance, they will be supplemented with Compliance Monitoring Requirements, also Section D of the permit. Unlike Compliance Determination Requirements, failure to meet Compliance Monitoring conditions would serve as a trigger for corrective actions and not grounds for enforcement action. However, a violation in relation to a compliance monitoring condition will arise through a source's failure to take the appropriate corrective actions within a specific time period.

1. The proposed corn storage bins (EU064 and EU065) have applicable compliance monitoring conditions as specified below. These units are controlled by baghouses CE001.
  - (a) Visible emission notations of the baghouse stack exhaust (stack EP001) shall be performed once per day during normal daylight operations. A trained employee shall record whether emissions are normal or abnormal. For processes operated continuously "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time. In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions. A trained employee or contractor is a person who has worked or trained at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process. Section C - Response to Excursions or Exceedances for this unit shall contain troubleshooting contingency and response steps for when an abnormal emission is observed. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances, shall be considered a deviation from this permit.
  - (b) The Permittee shall record the pressure drop across baghouse CE001 used in conjunction with the grain receiving and handling operations which includes the corn storage bins EU064 and EU065, at least once per day. When for any one reading, the pressure drop across baghouse CE001 is outside the normal range of 1.0 and 6.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances, shall be considered a deviation from this permit.
  - (c) In the event that bag failure has been observed:
    - (1) For a single compartment baghouse controlling emissions from a process operated continuously, a failed unit and the associated process shall be shut down immediately until the failed unit has been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).
    - (2) For a single compartment baghouse controlling emissions from a batch process, the feed to the process shall be shut down immediately until the failed unit has been repaired or replaced. The emissions unit shall be shut down no later than the completion of the processing of the material in the line. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).

Bag failure can be indicated by a significant drop in the baghouse's pressure reading with abnormal visible emissions, by an opacity violation, or by other means such as gas temperature, flow rate, air infiltration, leaks, dust traces or triboflows.

These monitoring conditions are necessary because the baghouse controlling the grain receiving and handling operations which includes the corn storage bins EU064 and EU065 must operate properly to ensure compliance with 326 IAC 2-2 (PSD), 326 IAC 2-8 (FESOP), and 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes).

**Proposed Changes**

The following changes have been made to the permit as a result of this Significant Permit Revision. Language with a line through it has been deleted, and bold language has been added. The Table of Contents has been updated as necessary.

Additionally, in order to reduce the number of administrative amendments, IDEM, OAQ has decided to remove the identification of the Responsible Official in Condition A.1. However, IDEM will continue to maintain records of the name, title, and contact information for the responsible official. IDEM, OAQ has also revised the source address and mailing address throughout the permit (including the reporting forms) to reflect the correct source location.

A.1 General Information [326 IAC 2-8-3(b)]

The Permittee owns and operates a stationary ethanol production plant.

Authorized individual: ~~President~~  
Source Address: ~~2255-2955 W. Delphi Pike, Marion, Indiana 46953~~ **46952**  
Mailing Address: ~~P.O. Box 650, Sweetser, Indiana 46987~~ **2955 W. Delphi Pike,  
Marion, Indiana 46952**  
General Source Phone: (765) 384-4001  
...

A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-8-3(c)(3)]

This stationary source consists of the following stationary emission units and pollution control devices:

...

- (b) One (1) grain handling operation, constructed in 2006, controlled by baghouse CE001, exhausting through stack EP001, and consisting of the following:

...

- (3) Two (2) corn storage bins, identified as EU004 and EU005, each with a maximum capacity of ~~802,000~~ **200,000** bushels and maximum throughput rate of 420 tons per hour.

...

- (6) Two (2) corn storage bins, identified as EU064 and EU065, each with a maximum capacity of 425,000 bushels and maximum throughput rate of 420 tons per hour.**

...

- (d) One (1) fermentation process, constructed in 2006, with a maximum throughput rate of 7,060 gallons of ethanol per hour, controlled by CO<sub>2</sub> scrubber CE005, exhausting through stack EP005, and consisting of the following:

- (1) ~~Four~~**Five (45)** fermenters, identified as EU016, EU017, EU018, ~~and~~ EU019, **and EU057.**

- (2) One (1) beer well, identified as EU020.

...

- (f) One (1) distillation process, constructed in 2006, with a maximum throughput rate of 6,850 gallons of ethanol per hour, controlled by TO/HRSG system CE007, exhausting through stack EP007, and consisting of the following:

- (1) ~~One~~**Two (12)** slurry mixers, identified as EU049 **and EU058**.
- (2) One (1) slurry tank, identified as EU050.
- (3) ~~Two~~**Three (23)** liquefaction tanks, identified as EU014, ~~and~~ EU051, **and EU059**, each with a maximum capacity of 7,000 gallons per hour.
- ...

**A.3 Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-8-3(c)(3)(I)]**

This stationary source also includes the following insignificant activities, as defined in 326 IAC 2-7-1(21):

- ...
- (j) Other emission units, not regulated by a NESHAP, with PM10, NOx, and SO<sub>2</sub> emissions less than five (5) pounds per hour or twenty-five (25) pounds per day, CO emissions less than twenty-five (25) pounds per day, VOC emissions less than three (3) pounds per hour or fifteen (15) pounds per day, lead emissions less than six-tenths (0.6) tons per year or three and twenty-nine hundredths (3.29) pounds per day, and emitting greater than one (1) pound per day but less than five (5) pounds per day or one (1) ton per year of a single HAP, or emitting greater than one (1) pound per day but less than twelve and five tenths (12.5) pounds per day or two and five tenths (2.5) ton per year of any combination of HAPs:
  - ...
  - (8) **One (1) corn oil separation unit, identified as EU061.**
  - (9) **Two (2) corn oil storage tanks, identified as EU062 and EU063, each with a maximum capacity of 35,000 gallons.**

**SECTION D.1 FACILITY OPERATION CONDITIONS – Grain Receiving and Handling Processes**

**Facility Description [326 IAC 2-8-4(10)] – Grain Receiving and Handling Processes:**

- ...
- (b) One (1) grain handling operation, constructed in 2006, controlled by baghouse CE001, exhausting through stack EP001, and consisting of the following:
  - ...
  - (3) Two (2) corn storage bins, identified as EU004 and EU005, each with a maximum capacity of ~~802,000~~ **200,000** bushels and maximum throughput rate of 420 tons per hour.
  - ...
  - (6) **Two (2) corn storage bins, identified as EU064 and EU065, each with a maximum capacity of 425,000 bushels and maximum throughput rate of 420 tons per hour.**
- ...

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

...

**D.1.6 Particulate Emission Limitations [326 IAC 6-3-2]**

Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), particulate emissions from each of following operations shall not exceed the pound per hour limits listed in the table below:

Unit ID	Unit Description	Max. Throughput Rate (tons/hr)	Particulate Emission Limit (lbs/hr)
EU001	Each of the Corn Dump Pits	420	66.9
EU002	Corn Conveyor	420	66.9
EU003	Corn Elevator	420	66.9
EU004	Corn Storage Bin	420	66.9
EU005	Corn Storage Bin	420	66.9
EU006	Scalper	140	54.7
EU007	Surge Bin	140	54.7
EU010	Hammermill	140	54.7
EU011	Hammermill	140	54.7
EU040	DDGS Dump pit	101	51.4
EU041	DDGS Elevator	101	51.4
EU042	DDGS Conveyor	101	51.4
EU043	DDGS Load Spout	101	51.4
<b>EU064</b>	<b>Corn Storage Bin</b>	<b>420</b>	<b>66.9</b>
<b>EU065</b>	<b>Corn Storage Bin</b>	<b>420</b>	<b>66.9</b>

...

### Compliance Determination Requirements

#### D.1.8 Particulate Control

- (a) In order to comply with Conditions D.1.5(a) and D.1.6, each of the following emission units shall be controlled by the associated baghouse, as listed in the table below, when these units are in operation:

Unit ID	Unit Description	Baghouse ID
EU001 - EU007, <b>EU064 and EU065</b>	Grain Receiving and Handling Operations	CE001
EU010 and EU011	Hammermills	CE003
EU040 - EU043	DDGS Handling and Loadout Operations	CE008

...

#### D.1.11 Parametric Monitoring

The Permittee shall record the pressure drop across the baghouses used in conjunction with corn dump pits (EU001), the grain handling operation (EU002 through EU007, **EU064, and EU065**), the hammermills (EU010 and EU011), and the DDGS loadout operation (EU040 through EU043), at least once per day when these units are in operation. When for any one reading, the pressure drop across the baghouse is outside the normal range of 1.0 to 6.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances shall be considered a deviation from this permit.

...

### SECTION D.2 FACILITY OPERATION CONDITIONS – Fermentation Process

#### Facility Description [326 IAC 2-8-4(10)]:

- (d) One (1) fermentation process, constructed in 2006, with a maximum throughput rate of 7,060 gallons of ethanol per hour, controlled by CO<sub>2</sub> scrubber CE005, exhausting through stack EP005, and consisting of the following:
- (1) ~~Four~~**Five (45)** fermenters, identified as EU016, EU017, EU018, ~~and~~ EU019, **and EU057**.
  - (2) One (1) beer well, identified as EU020.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### SECTION D.3 FACILITY OPERATION CONDITIONS – TO/HRSG System and DDGS Drying Process

#### Facility Description [326 IAC 2-8-4(10)]:

...

(f) One (1) distillation process, constructed in 2006, with a maximum throughput rate of 6,850 gallons of ethanol per hour, controlled by TO/HRSG system CE007, exhausting through stack EP007, and consisting of the following:

- (1) ~~One~~**Two (42)** slurry mixers, identified as EU049 **and EU058**.
- (2) One (1) slurry tank, identified as EU050.
- (3) ~~Two~~**Three (23)** liquefaction tanks, identified as EU014, ~~and~~ EU051, **and EU059**, each with a maximum capacity of 7,000 gallons per hour.

...

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### SECTION D.5 FACILITY OPERATION CONDITIONS – Ethanol Loading Racks

...

#### D.5.5 FESOP Limits [326 IAC 2-2] [326 IAC 2-8-4] [326 IAC 2-4.1]

Pursuant to 326 IAC 2-8-4 (FESOP), the Permittee shall comply with the following:

- (a) The total **combined** denatured ethanol **and blended ethanol** load-out from loading racks EU045A and EU045B shall not exceed ~~63,000,000~~ **64,900,000** gallons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (b) **The total denaturant used at the loading racks EU045A and EU045B shall not exceed 4,900,000 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.**
- (c) **The total denatured ethanol load-out into non-dedicated railcars shall not exceed 2,500,000 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.**
- (d) **The blended ethanol shall not exceed a blend of 30% gasoline.**
- (e) **No ethanol that exceeds 5% gasoline shall be loaded out to non-dedicated railcars.**
- (bf) The Permittee shall use flare CE009 to control the emissions from the ethanol loading rack for trucks (EU045A).
- (eg) CO emissions from flare CE009 shall not exceed 0.129 lbs/kgal.
- (eh) NOx emissions from flare CE009 shall not exceed 0.077 lbs/kgal.
- (ei) The ethanol loading racks (EU045A and EU045B) shall utilize submerged loading method.
- (fj) The railcars and trucks shall not use vapor balance services.

Combined with the VOC, CO, NO<sub>x</sub>, and HAP emissions from other units, the VOC, NO<sub>x</sub> and CO emissions from the entire source are limited to less than 100 tons/yr, and total HAP emissions from the entire source are limited to less than 10 tons/yr for a single HAP and less than 25 tons/yr for total HAPs. Therefore, the requirements of 326 IAC 2-7 (Part 70 Program), 326 IAC 2-2 (PSD), and 326 IAC 2-4.1 (MACT) are not applicable.

...

### **Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]**

#### **D.5.13 Record Keeping Requirements**

---

- (a) To document compliance with Condition D.5.5(a), the Permittee shall maintain monthly records of the total amount of denatured ethanol **and blended ethanol** loaded out from loading racks EU045A and EU045B.
- (b) **To document compliance with Condition D.5.5(b), the Permittee shall maintain monthly records of total denaturant used at loading racks EU045A and EU045B.**
- (c) **To document compliance with Condition D.5.5(c), the Permittee shall maintain monthly records of total denatured ethanol load-out into non-dedicated railcars.**
- (d) **To document compliance with Condition D.5.5(d) and (e), the Permittee shall maintain monthly records of the specifications of the blended ethanol loaded out to truck and rail.**
- (be) To document compliance with Condition D.5.12, the Permittee shall maintain records of temperature or other parameters sufficient to demonstrate the presence of a pilot flame when loading rack EU045A is in operation.
- (ef) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

#### **D.5.14 Reporting Requirements**

---

A quarterly summary of the information to document compliance with Condition D.5.5(a), **(b), and (c)** shall be submitted to the address listed in Section C - General Reporting Requirements, of this permit, using the reporting forms located at the end of this permit, or their equivalent, within thirty (30) days after the end of the quarter being reported. The report submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

...

## **INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT OFFICE OF AIR QUALITY**

### **FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP) CERTIFICATION**

Source Name: Central Indiana Ethanol, LLC.  
Source Address: 2255 **2955** W. Delphi Pike, Marion, Indiana 46953 **46952**  
Mailing Address: ~~P.O. Box 650, Sweetser, Indiana 46987~~ **2955 W. Delphi Pike, Marion, Indiana  
46952**  
FESOP No.: F053-21057-00062

...

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE BRANCH  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251  
Phone: 317-233-0178  
Fax: 317-233-6865**

**FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP)  
EMERGENCY OCCURRENCE REPORT**

Source Name: Central Indiana Ethanol, LLC.  
Source Address: 2255 2955 W. Delphi Pike, Marion, Indiana 46953 46952  
Mailing Address: ~~P.O. Box 650, Sweetser, Indiana 46987~~ 2955 W. Delphi Pike, Marion, Indiana  
46952  
FESOP No.: F053-21057-00062

...

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE DATA SECTION**

**FESOP Quarterly Report**

Source Name: Central Indiana Ethanol, LLC.  
Source Address: 2255 2955 W. Delphi Pike, Marion, Indiana 46953 46952  
Mailing Address: ~~P.O. Box 650, Sweetser, Indiana 46987~~ 2955 W. Delphi Pike, Marion, Indiana  
46952  
FESOP No.: F053-21057-00062  
Facility: Corn Dump Pits (EU001)  
Parameter: Total Corn Received  
Limit: Less than 646,800 tons per twelve (12) consecutive month period with  
compliance determined at the end of each month.

...

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE DATA SECTION**

**FESOP Quarterly Report**

Source Name: Central Indiana Ethanol, LLC.  
Source Address: 2255 2955 W. Delphi Pike, Marion, Indiana 46953 46952  
Mailing Address: ~~P.O. Box 650, Sweetser, Indiana 46987~~ 2955 W. Delphi Pike, Marion, Indiana  
46952  
FESOP No.: F053-21057-00062  
Facility: DDGS Cooler (EU036); DDGS Handling and Loadout Operations (EU040  
through EU043)  
Parameter: DDGS Production Rate  
Limit: Less than 210,000 tons per twelve (12) consecutive month period with  
compliance determined at the end of each month.

...

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE DATA SECTION**

**FESOP Quarterly Report**

Source Name: Central Indiana Ethanol, LLC.  
Source Address: ~~2255~~ **2955** W. Delphi Pike, Marion, Indiana ~~46953~~ **46952**  
Mailing Address: ~~P.O. Box 650, Sweetser, Indiana 46987~~ **2955 W. Delphi Pike, Marion, Indiana 46952**  
FESOP No.: F053-21057-00062  
Facility: Ethanol Loading Racks (EU045A and EU045B)  
Parameter: Total ~~Ethanol Loadout Rate~~ **combined denatured ethanol and blended ethanol loadout rate**  
Limit: Less than ~~63,000,000~~ **64,900,000** gallons per twelve (12) consecutive month period with compliance determined at the end of each month.

YEAR: \_\_\_\_\_

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

- No deviation occurred in this quarter.
- Deviation/s occurred in this quarter.  
Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_  
Title / Position: \_\_\_\_\_  
Signature: \_\_\_\_\_  
Date: \_\_\_\_\_  
Phone: \_\_\_\_\_

Attach a signed certification to complete this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE DATA SECTION**

**FESOP Quarterly Report**

**Source Name:** Central Indiana Ethanol, LLC.  
**Source Address:** 2955 W. Delphi Pike, Marion, Indiana 46952  
**Mailing Address:** 2955 W. Delphi Pike, Marion, Indiana 46952  
**FESOP No.:** F053-21057-00062  
**Facility:** Ethanol Loading Racks (EU045A and EU045B)  
**Parameter:** Total denaturant used  
**Limit:** Less than 4,900,000 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.

**YEAR:** \_\_\_\_\_

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

- No deviation occurred in this quarter.
- Deviation/s occurred in this quarter.  
Deviation has been reported on: \_\_\_\_\_

**Submitted by:** \_\_\_\_\_  
**Title / Position:** \_\_\_\_\_  
**Signature:** \_\_\_\_\_  
**Date:** \_\_\_\_\_  
**Phone:** \_\_\_\_\_

**Attach a signed certification to complete this report.**

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE DATA SECTION**

**FESOP Quarterly Report**

**Source Name:** Central Indiana Ethanol, LLC.  
**Source Address:** 2955 W. Delphi Pike, Marion, Indiana 46952  
**Mailing Address:** 2955 W. Delphi Pike, Marion, Indiana 46952  
**FESOP No.:** F053-21057-00062  
**Facility:** Ethanol Loading Rack (EU045B)  
**Parameter:** Total denatured ethanol load-out into non-dedicated railcars  
**Limit:** Less than 2,500,000 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.

**YEAR:** \_\_\_\_\_

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

- No deviation occurred in this quarter.
- Deviation/s occurred in this quarter.  
Deviation has been reported on: \_\_\_\_\_

**Submitted by:** \_\_\_\_\_  
**Title / Position:** \_\_\_\_\_  
**Signature:** \_\_\_\_\_  
**Date:** \_\_\_\_\_  
**Phone:** \_\_\_\_\_

**Attach a signed certification to complete this report.**

## INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT OFFICE OF AIR QUALITY COMPLIANCE DATA SECTION

### FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP) QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT

Source Name: Central Indiana Ethanol, LLC.  
Source Address: ~~2255~~ **2955** W. Delphi Pike, Marion, Indiana ~~46953~~ **46952**  
Mailing Address: ~~P.O. Box 650, Sweetser, Indiana 46987~~ **2955 W. Delphi Pike, Marion, Indiana 46952**  
FESOP No.: F053-21057-00062  
...

Upon further review, IDEM has decided to make the following revisions to the permit (bolded language has been added, the language with a line through it has been deleted):

1. In order to clarify recordkeeping requirements specific to parametric monitoring, Conditions D.1.13(c) and (d), D.2.14(a), D.3.21(b), (c), and (d), and D.4.13(b) and (c) were revised.

#### D.1.13 Record Keeping Requirements

---

...

- (c) To document compliance with Condition D.1.10, the Permittee shall maintain records of daily visible emission notations of the baghouse stack exhausts. **The Permittee shall include in its daily record when a visible emission notation is not taken and the reason for the lack of visible emission notation (e.g. the process did not operate that day).**
- (d) To document compliance with Condition D.1.11, the Permittee shall maintain daily records of the pressure drop during normal operation. **The Permittee shall include in its daily record when a pressure drop reading is not taken and the reason for the lack of a pressure drop reading (e.g. the process did not operate that day).**

...

#### D.2.14 Record Keeping Requirements

---

- (a) To document compliance with Condition D.2.12, the Permittee shall maintain daily records of pressure drop and flow rate for scrubber CE005 during normal operation. **The Permittee shall include in its daily record when a pressure drop or flow rate reading is not taken and the reason for the lack of a pressure drop or flow rate reading (e.g. the process did not operate that day).**

...

#### D.3.21 Record Keeping Requirements

---

...

- (b) To document compliance with Condition D.3.18, the Permittee shall maintain records of daily visible emission notations of the stack EP007. **The Permittee shall include in its daily record when a visible emission notation is not taken and the reason for the lack of visible emission notation (e.g. the process did not operate that day).**
- (c) To document compliance with Condition D.3.19, the Permittee shall maintain continuous temperature records for the thermal oxidizer and the 3-hour average temperature used to demonstrate compliance during the most recent compliant stack test. **The Permittee shall include in its daily record when a temperature reading is not taken and the reason for the lack of a temperature reading (e.g. the process did not operate that day).**

- (d) To document compliance with Condition D.3.20, the Permittee shall maintain daily records of the duct pressure or fan amperage for the TO/HRSG system CE007. **The Permittee shall include in its daily record when a duct pressure or fan amperage reading is not taken and the reason for the lack of a duct pressure or fan amperage reading (e.g. the process did not operate that day).**
- ...

#### D.4.13 Record Keeping Requirements

---

- (b) To document compliance with Condition D.4.10, the Permittee shall maintain records of daily visible emission notations of the baghouse stack exhausts. **The Permittee shall include in its daily record when a visible emission notation is not taken and the reason for the lack of visible emission notation (e.g. the process did not operate that day).**
- (c) To document compliance with Condition D.4.11, the Permittee shall maintain daily records of pressure drop for baghouses during normal operation. **The Permittee shall include in its daily record when a pressure drop reading is not taken and the reason for the lack of a pressure drop reading, (e.g. the process did not operate that day).**
- ...

2. The specific mail codes (MC) for each of the IDEM branches has been added to improve mail delivery, as follows:

Permits Branch: **MC 61-53 IGCN 1003**  
Compliance Branch: **MC 61-53 IGCN 1003**  
Asbestos Section: **MC 61-52 IGCN 1003**  
Technical Support and Modeling: **MC 61-50 IGCN 1003**

3. For Section B, Condition B.1 Permit No Defense has been moved from the B Section to the first page of the permit. In addition, IDEM has decided to include several updates to further address and clarify the permit term and the term of the conditions. This includes the addition of the condition: Term of Conditions [326 IAC 2-1.1-9.5] and changes to the following conditions: Permit Term, Prior Permits Superseded, Termination of Right to Operate, and Permit Renewal. Note that some conditions have been rearranged, in addition to adding the new one. Minor grammatical errors have also been corrected.

## SECTION B GENERAL CONDITIONS

### B.1 ~~Permit No Defense [IC 13]~~

---

~~Indiana statutes from IC 13 and rules from 326 IAC, quoted in conditions in this permit, are those applicable at the time the permit was issued. The issuance or possession of this permit shall not alone constitute a defense against an alleged violation of any law, regulation or standard, except for the requirement to obtain a FESOP under 326 IAC 2-8.~~

### B.2 B.1 Definitions [326 IAC 2-8-1]

---

...

### B.3 B.2 Permit Term [326 IAC 2-8-4(2)] [326 IAC 2-1.1-9.5]

---

- (a) This permit **F053-24415-00062** is issued for a fixed term of five (5) years from the issuance date of this permit, as determined in accordance with IC 4-21.5-3-5(f) and IC 13-15-5-3. Subsequent revisions, modifications, or amendments of this permit do not affect the expiration date **of this permit.**
- (b) **If IDEM, OAQ, upon receiving a timely and complete renewal permit application, fails to issue or deny the permit renewal prior to the expiration date of this permit,**

**this existing permit shall not expire and all terms and conditions shall continue in effect, until the renewal permit has been issued or denied.**

**B.3 Term of Conditions [326 IAC 2-1.1-9.5]**

---

**Notwithstanding the permit term of a permit to construct, a permit to operate, or a permit modification, any condition established in a permit issued pursuant to a permitting program approved in the state implementation plan shall remain in effect until:**

- (a) the condition is modified in a subsequent permit action pursuant to Title I of the Clean Air Act; or**
- (b) the emission unit to which the condition pertains permanently ceases operation.**

**B.4 Enforceability [326 IAC 2-8-6]**

---

...

~~B.5 Termination of Right to Operate [326 IAC 2-8-9] [326 IAC 2-8-3(h)]~~

---

~~The Permittee's right to operate this source terminates with the expiration of this permit unless a timely and complete renewal application is submitted at least nine (9) months prior to the date of expiration of the source's existing permit, consistent with 326 IAC 2-8-3(h) and 326 IAC 2-8-9.~~

~~B.6 B.5 Severability [326 IAC 2-8-4(4)]~~

---

...

~~B.7 B.6 Property Rights or Exclusive Privilege [326 IAC 2-8-4(5)(D)]~~

---

...

~~B.8 B.7 Duty to Provide Information [326 IAC 2-8-4(5)(E)]~~

---

- ~~(a) The Permittee shall furnish to IDEM, OAQ, within a reasonable time, any information that IDEM, OAQ, may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The submittal by the Permittee does require the certification by ~~the an~~ "authorized individual" as defined by 326 IAC 2-1.1-1(1). Upon request, the Permittee shall also furnish to IDEM, OAQ, copies of records required to be kept by this permit.~~
- ~~(b) For information furnished by the Permittee to IDEM, OAQ, the Permittee may include a claim of confidentiality in accordance with 326 IAC 17.1. ~~when~~ **When** furnishing copies of requested records directly to U.S. EPA, the Permittee may assert a claim of confidentiality in accordance with 40 CFR 2, Subpart B.~~

~~B.9 B.8 Compliance Order Issuance [326 IAC 2-8-5(b)]~~

---

...

~~B.10 B.9 Certification [326 IAC 2-8-3(d)] [326 IAC 2-8-4(3)(C)(i)] [326 IAC 2-8-5(1)]~~

---

...

~~B.11 B.10 Annual Compliance Certification [326 IAC 2-8-5(a)(1)]~~

---

...

- ~~(c) The annual compliance certification report shall include the following:~~

...

~~The notification which shall be submitted~~ **submittal** by the Permittee does require the certification by ~~the an~~ "authorized individual" as defined by 326 IAC 2-1.1-1(1).

~~B.12 B.11 Preventive Maintenance Plan [326 IAC 1-6-3] [326 IAC 2-8-4(9)] [326 IAC 2-8-5(a)(1)]~~

---

...

The PMP extension notification does not require the certification by ~~the~~ an “authorized individual” as defined by 326 IAC 2-1.1-1(1).

- (b) A copy of the PMPs shall be submitted to IDEM, OAQ, upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. IDEM, OAQ, may require the Permittee to revise its PMPs whenever lack of proper maintenance causes or is the primary contributor to an exceedance of any limitation on emissions or potential to emit. The PMPs do not require the certification by ~~the~~ an “authorized individual” as defined by 326 IAC 2-1.1-1(1).

~~B.13~~ **B.12** Emergency Provisions [326 IAC 2-8-12]

---

...

- (b) An emergency, as defined in 326 IAC 2-7-1(12), constitutes an affirmative defense to an action brought for noncompliance with a health-based or technology-based emission limitation if the affirmative defense of an emergency is demonstrated through properly signed, contemporaneous operating logs or other relevant evidence that describes the following:

...

- (4) For each emergency lasting one (1) hour or more, the Permittee notified IDEM, OAQ, within four (4) daytime business hours after the beginning of the emergency, or after the emergency was discovered or reasonably should have been discovered;

IDEM:

Telephone ~~No. Number~~: 1-800-451-6027 (ask for Office of Air Quality, Compliance Section) or,

Telephone ~~No. Number~~: 317-233-0178 (ask for Compliance Section)

Facsimile ~~No. Number~~: 317-233-6865

- (5) For each emergency lasting one (1) hour or more, the Permittee submitted the attached Emergency Occurrence Report Form or its equivalent, either by mail or facsimile to:

Indiana Department of Environmental Management  
Compliance Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

within two (2) working days of the time when emission limitations were exceeded due to the emergency.

The notice fulfills the requirement of 326 IAC 2-8-4(3)(C)(ii) and must contain the following:

- (A) A description of the emergency;
- (B) Any steps taken to mitigate the emissions; and
- (C) Corrective actions taken.

The notification which shall be submitted by the Permittee does not require the certification by ~~the~~ an “authorized individual” as defined by 326 IAC 2-1.1-1(1).

**B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5]**

---

- (a) All terms and conditions of permits established prior to 181-24072-00046 and issued pursuant to permitting programs approved into the state implementation plan have been either:
- (1) incorporated as originally stated,
  - (2) revised, or
  - (3) deleted.
- (b) All previous registrations and permits are superseded by this permit.

**B.14 Termination of Right to Operate [326 IAC 2-8-9][326 IAC 2-8-3(h)]**

---

The Permittee's right to operate this source terminates with the expiration of this permit unless a timely and complete renewal application is submitted at least nine (9) months prior to the date of expiration of the source's existing permit, consistent with 326 IAC 2-8-3(h) and 326 IAC 2-8-9.

**B.14 B.15 Deviations from Permit Requirements and Conditions [326 IAC 2-8-4(3)(C)(ii)]**

---

- (a) Deviations from any permit requirements (for emergencies see Section B - Emergency Provision), the probable cause of such deviations, and any response steps or preventive measures taken shall be reported to:

Indiana Department of Environmental Management  
Compliance Data Section, Office of Air Quality  
100 North Senate Avenue  
**MC 61-53 IGCN 1003**  
Indianapolis, Indiana 46204-2251

using the attached Quarterly Deviation and Compliance Monitoring Report, or its equivalent. A deviation required to be reported pursuant to an applicable requirement that exists independent of this permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report.

The Quarterly Deviation and Compliance Monitoring Report does require the certification by ~~the~~ an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

...

**B.14 B.16 Permit Modification, Reopening, Revocation and Reissuance, or Termination [326 IAC 2-8-4(5)(C)] [326 IAC 2-8-7(a)] [326 IAC 2-8-8]**

---

- (a) This permit may be modified, reopened, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a **Federally Enforceable State Operating Permit (FESOP)** modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any condition of this permit. [326 IAC 2-8-4(5)(C)] The notification by the Permittee does require the certification by ~~the~~ an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

**B.14 B.17 Permit Renewal [326 IAC 2-8-3(h)]**

---

- (a) The application for renewal shall be submitted using the application form or forms prescribed by IDEM, OAQ and shall include the information specified in 326 IAC 2-8-3. Such information shall be included in the application for each emission unit at this source, except those emission units included on the trivial or insignificant activities list contained in 326 IAC 2-7-1(21) and 326 IAC 2-7-1(40). The renewal application does require the certification by ~~the~~ an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

Request for renewal shall be submitted to:

Indiana Department of Environmental Management  
Permits Branch, Office of Air Quality  
100 North Senate Avenue  
**MC 61-53 IGCN 1003**  
Indianapolis, Indiana 46204-2251

(b) ~~Timely Submittal of Permit Renewal [326 IAC 2-8-3]~~

~~(1) — A timely renewal application is one that is:~~

~~(A)(1) Submitted at least nine (9) months prior to the date of the expiration of this permit; and~~

~~(B)(2) If the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.~~

~~(2) — If IDEM, OAQ, upon receiving a timely and complete permit application, fails to issue or deny the permit renewal prior to the expiration date of this permit, this existing permit shall not expire and all terms and conditions shall continue in effect until the renewal permit has been issued or denied.~~

(c) ~~Right to Operate After Application for Renewal [326 IAC 2-8-9]~~

~~If the Permittee submits a timely and complete application for renewal of this permit, the source's failure to have a permit is not a violation of 326 IAC 2-8 until IDEM, OAQ takes final action on the renewal application, except that this protection shall cease to apply if, subsequent to the completeness determination, the Permittee fails to submit by the deadline specified in writing by IDEM, OAQ any additional information identified as **being** needed to process the application.~~

**B.17 B.18** Permit Amendment or Revision [326 IAC 2-8-10] [326 IAC 2-8-11.1]

---

...

(b) Any application requesting an amendment or modification of this permit shall be submitted to:

Indiana Department of Environmental Management  
Permits Branch, Office of Air Quality  
100 North Senate Avenue  
**MC 61-53 IGCN 1003**  
Indianapolis, Indiana 46204-2251

Any such application shall be certified by ~~the~~ **an** "authorized individual" as defined by 326 IAC 2-1.1-1(1).

(c) The Permittee may implement ~~the~~ administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-8-10(b)(3)]

...

**B.18 B.19** Operational Flexibility [326 IAC 2-8-15] [326 IAC 2-8-11.1]

---

(a) The Permittee may make any change or changes at ~~this~~ **the** source that are described in 326 IAC 2-8-15(b) through (d); without **a** prior permit revision, if each of the following conditions is met:

...

- (5) The Permittee maintains records on-site, on a rolling five (5) year basis, which document, all such changes and emission trades that are subject to 326 IAC 2-8-15(b) through (d). The Permittee shall make such records available, upon reasonable request, ~~to~~ **for** public review.

...

~~B.19~~ **B.20** ~~Permit Revision~~ **Source Modification** Requirement [326 IAC 2-8-11.1]

---

...

~~B.20~~ **B.21** Inspection and Entry [326 IAC 2-8-5(a)(2)] [IC 13-14-2-2] [IC 13-17-3-2] [IC 13-30-3-1]

---

...

~~B.24~~ **B.22** Transfer of Ownership or Operational Control [326 IAC 2-8-10] [IC 13-17-3-2]

---

...

- (b) Any application requesting a change in the ownership or operational control of the source shall contain a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new Permittee. The application shall be submitted to:

Indiana Department of Environmental Management  
Permits Branch, Office of Air Quality  
100 North Senate Avenue  
**MC 61-53 IGCN 1003**  
Indianapolis, Indiana 46204-2251

The application which shall be submitted by the Permittee does require the certification by ~~the~~ **an** "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-8-10(b)(3)]

~~B.22~~ **B.23** Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-8-4(6)] [326 IAC 2-8-16] [326 IAC 2-1.1-7]

---

...

~~B.23~~ **B.24** Advanced Source Modification Approval [326 IAC 2-8-4(11)] [326 IAC 2-1.1-9]

---

...

~~B.24~~ **B.25** Credible Evidence [326 IAC 2-8-4(3)] [326 IAC 2-8-5] [62 FR 8314] [326 IAC 1-1-6]

---

...

4. Minor grammatical errors throughout Section C have been updated. In addition, the requirement to use an Indiana Accredited Asbestos inspector has been deleted from Condition C.7(g)

C.1 Particulate Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]

---

Pursuant to 326 IAC 6-3-2(e)(2), particulate emissions from any process not exempt under 326 IAC 6-3-1(b) or (c), **and** which has a maximum process weight rate less than one hundred (100) pounds per hour and the methods in 326 IAC 6-3-2(b) through (d) do not apply shall not exceed 0.551 pounds per hour.

C.2 Overall Source Limit [326 IAC 2-8] [326 IAC 2-2]

---

...

- (c) This condition shall include all emission points at this source including those that are insignificant as defined in 326 IAC 2-7-1(21). The source shall be allowed to add

insignificant activities not already listed in this permit, provided ~~that~~ the source's potential to emit does not exceed the above specified limits.

...

C.5 Incineration [326 IAC 4-2] [326 IAC 9-1-2(3)]

---

The Permittee shall not operate an incinerator or incinerate any waste or refuse except as provided in 326 IAC 4-2 and in 326 IAC 9-1-2.

C.7 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

---

...

- (d) The notice to be submitted shall include the information enumerated in 326 IAC 14-10-3(3).

All required notifications shall be submitted to:

Indiana Department of Environmental Management  
Asbestos Section, Office of Air Quality  
100 North Senate Avenue  
**MC 61-52 IGCN 1003**  
Indianapolis, Indiana 46204-2251

The notice shall include a signed certification from the owner or operator that the information provided in this notification is correct and that only Indiana licensed workers and project supervisors will be used to implement the asbestos removal project. The notifications do not require a certification by ~~the an~~ "authorized individual" as defined by 326 IAC 2-1.1-1(1).

...

- (g) Indiana Accredited Asbestos Inspector  
The Permittee shall comply with 326 IAC 14-10-1(a) that requires the owner or operator, prior to a renovation/demolition, to use an Indiana Accredited Asbestos Inspector to thoroughly inspect the affected portion of the facility for the presence of asbestos. ~~The requirement to use an Indiana Accredited Asbestos inspector is not federally enforceable.~~

C.8 Performance Testing [326 IAC 3-6]

---

- (a) All testing shall be performed according to the provisions of 326 IAC 3-6 (Source Sampling Procedures), except as provided elsewhere in this permit, utilizing any applicable procedures and analysis methods specified in 40 CFR 51, 40 CFR 60, 40 CFR 61, 40 CFR 63, 40 CFR 75, or other procedures approved by IDEM, OAQ.

A test protocol, except as provided elsewhere in this permit, shall be submitted to:

Indiana Department of Environmental Management  
Compliance Data Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

no later than thirty-five (35) days prior to the intended test date. The protocol submitted by the Permittee does not require certification by ~~the an~~ "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (b) The Permittee shall notify IDEM, OAQ of the actual test date at least fourteen (14) days prior to the actual test date. The notification submitted by the Permittee does not require certification by ~~the an~~ "authorized individual" as defined by 326 IAC 2-1.1-1(1).

C.10 Compliance Monitoring [326 IAC 2-8-4(3)] [326 IAC 2-8-5(a)(1)]

---

...

The notification which shall be submitted by the Permittee does require the certification by ~~the~~ an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

...

C.11 Monitoring Methods [326 IAC 3] [40 CFR 60] [40 CFR 63]

---

Any monitoring or testing required by Section D of this permit shall be performed according to the provisions of 326 IAC 3, 40 CFR 60, Appendix A, 40 CFR 60, Appendix B, 40 CFR 63, or other approved methods as specified in this permit.

C.12 Monitoring Methods [326 IAC 3] [40 CFR 60] [40 CFR 63]

---

Any monitoring or testing required by Section D of this permit shall be performed according to the provisions of 326 IAC 3, 40 CFR 60, Appendix A, 40 CFR 60, Appendix B, 40 CFR 63, or other approved methods as specified in this permit.

C.13 Emergency Reduction Plans [326 IAC 1-5-2] [326 IAC 1-5-3]

---

...

The ERP does require the certification by ~~the~~ an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

C.16 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-8-4] [326 IAC 2-8-5]

---

...

(b) A retest to demonstrate compliance shall be performed within one hundred twenty (120) days of receipt of the original test results. Should the Permittee demonstrate to IDEM, OAQ that retesting in one hundred and twenty (120) days is not practicable, IDEM, OAQ may extend the retesting deadline.

...

The response action documents submitted pursuant to this condition do require the certification by ~~the~~ an "authorized individual" as defined by 326 IAC 2-1.1-1(1)

C.18 General Reporting Requirements [326 IAC 2-8-4(3)(C)] [326 IAC 2-1.1-11]

---

(a) The Permittee shall submit the attached Quarterly Deviation and Compliance Monitoring Report or its equivalent. Any deviation from permit requirements, the date(s) of each deviation, the cause of the deviation, and the response steps taken must be reported. This report shall be submitted within thirty (30) days of the end of the reporting period. The Quarterly Deviation and Compliance Monitoring Report shall include the certification by ~~the~~ an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

...

(d) Unless otherwise specified in this permit, all reports required in Section D of this permit shall be submitted within thirty (30) days of the end of the reporting period. All reports do require the certification by ~~the~~ an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

...

**Conclusion**

The construction and operation of this ethanol production plant shall be subject to the conditions of the attached proposed FESOP Significant Permit Revision No. 053-24415-00062.

**Appendix A: Emission Calculations  
PM and PM10 Emissions  
From the Grain Receiving and Handling Operations**

**Company Name: Central Indiana Ethanol, LLC  
Address: 2955 W. Delphi Pike Marion, IN 46952  
SPR: 053-24415-00062  
Reviewer: ERG/JR  
Date: June 1, 2007**

**1. Potential to Emit PM/PM10 - Captured Emissions:**

Baghouse ID	Process Description	Control Device	Outlet Grain Loading (gr/dscf)	Maximum Air Flow Rate (scfm)	PTE of PM/PM10 after Control (lbs/hr)	PTE of PM/PM10 after Control (tons/yr)	Control Efficiency (%)	PTE of PM/PM10 before Control (tons/yr)
CE001	Grain Receiving and Handling EU001-EU007, EU064 and EU065	Baghouse	0.005	39,000	1.67	7.32	99%	732
CE003	Hammermills EU010 and EU011	Baghouse	0.005	28,000	1.20	5.26	99%	526
<b>Total</b>						<b>12.6</b>		<b>1,258</b>

Assume all PM emissions equal PM10 emissions.

**Methodology**

PTE of PM/PM10 after Control (lbs/hr) = Grain Loading (gr/dscf) x Max. Air Flow Rate (scfm) x 60 mins/hr x 1/7000 lb/gr

PTE of PM/PM10 after Control (tons/yr) = Grain Loading (gr/dscf) x Max. Air Flow Rate (scfm) x 60 mins/hr x 1/7000 lb/gr x 8760 hr/yr x 1 ton/2000 lbs

PTE of PM/PM10 before Control (tons/yr) = PTE of PM/PM10 after Control (tons/yr) / (1-Control Efficiency)

**2. Potential to Emit PM/PM10 - Fugitive Emissions:**

Unit ID	Unit Description	Annual Throughput Limit (tons/yr)	Uncontrolled PM Emission Factor (lbs/ton)	Uncontrolled PM10 Emission Factor (lbs/ton)	Baghouse ID	Capture Efficiency (%)	Fugitive PM Emissions (tons/yr)	Fugitive PM10 Emissions (tons/yr)
EU001	Grain Receiving	646,800	0.035	0.0078	CE001	80%	2.26	0.50
<b>Total</b>							<b>2.26</b>	<b>0.50</b>

Note: Emission factors are from AP-42, Chapter 9.9.1 - Grain Elevators, Table 9.9.1-1 (04/03). Assume all the grain receiving and loadout is by truck, which is the worst case scenario.

The Permittee stated that there are no fugitive emissions from the grain handling operations because the emissions from these units are 100% captured.

**Methodology**

Fugitive PM/PM10 (tons/yr) = Annual Throughput Limit (tons/yr) x Uncontrolled Emission Factor (lbs/ton) x (1-Capture Efficiency%) x 1 ton/2000 lbs

**Appendix A: Emission Calculations**  
**VOC and HAP Emissions from Ethanol Loading Racks (EU045A and EU045B)**

**Company Name: Central Indiana Ethanol, LLC**  
**Address: 2955 W. Delphi Pike Marion, IN 46952**  
**SPR: 053-24415-00062**  
**Reviewer: ERG/JR**  
**Date: June 1, 2007**

**1. Emission Factors: AP-42**

Denatured and blended ethanol will be shipped by either truck loading rack EU045A or railcar loading rack EU045B. The railcars and trucks may each be used to carry gasoline prior to filling with ethanol. Both railcars and trucks will be filled by submerged loading process. Only the truck loadout rack (EU045A) will be controlled by flare CE12 which has a control efficiency of 98% for VOC and HAPs.

According to AP-42, Chapter 5.2 - Transportation and Marketing of Petroleum Liquids (01/95), the VOC emission factors for the truck and rail loading racks can be estimated from the following equation:

$$L = 12.46 \times (SPM)/T$$

where:

L = loading loss (lbs/kgal)  
 S = a saturation factor (see AP-42, Table 5.2-1)  
 P = true vapor pressure of the liquid loaded (psia)  
 M = molecular weight of vapors  
 T = temperature of the bulk liquid loaded (degree R)

Previous Stored Liquid	*S	P (psia)	M (lbs/mole lbs)	T (degree R)	L (lbs/kgal)
Gasoline (normal)	1.0	6.2	62	512.3	9.35
Gasoline (clean cargo)	0.5	6.2	62	512.3	4.67
Denatured Ethanol (normal)	0.6	0.50	49.7	512.3	0.36
Denatured Ethanol (clean cargo)	0.5	0.50	49.7	512.3	0.30
Blended Ethanol (normal)	0.6	1.54	57.4	512.3	1.29
Blended Ethanol (clean cargo)	0.5	1.54	57.4	512.3	1.07

Note: Blended Ethanol based on E70 specifications from TANKS 4.09.

Therefore, the emission factor for loading denatured ethanol to the trucks and railcars which stored gasoline previously

$$= L (\text{gasoline, normal}) - L (\text{gasoline, clean cargo}) + L (\text{denatured ethanol, clean cargo}) =$$

4.98 (lbs/kgal)

Therefore, the emission factor for loading blended ethanol to the trucks and railcars which stored gasoline previously

$$= L (\text{gasoline, normal}) - L (\text{gasoline, clean cargo}) + L (\text{blended ethanol, clean cargo}) =$$

5.75 (lbs/kgal)

**2. Potential to Emit VOC Before Control (assuming all blended Ethanol loaded out):**

Max. Loading Rate for EU40A: 48 kgal/hr (for truck loading)

$$\text{PTE of VOC before Control (tons/yr)} = 48 \text{ kgal/hr} \times 5.75 \text{ lbs/gal} \times 8760 \text{ hr/yr} \times 1 \text{ ton/2000 lbs} =$$

**1,209 tons/yr**

Max. Loading Rate EU40B: 60 kgal/hr (for railcar loading)

$$\text{PTE of VOC before Control (tons/yr)} = 60 \text{ kgal/hr} \times 5.75 \text{ lbs/gal} \times 8760 \text{ hr/yr} \times 1 \text{ ton/2000 lbs} =$$

**1,511.0 tons/yr**

**Appendix A: Emission Calculations**  
**VOC and HAP Emissions from Ethanol Loading Racks (EU045A and EU045B)**

**Company Name: Central Indiana Ethanol, LLC**  
**Address: 2955 W. Delphi Pike Marion, IN 46952**  
**SPR: 053-24415-00062**  
**Reviewer: ERG/JR**  
**Date: June 1, 2007**

**3. Limited Potential to Emit:**

*The amount of loadout emissions are restricted by the 4,900 kgal/yr Denaturant Limit.*

Annual Denatured and Blended Ethanol Production Limit:	64,900 kgal/yr (for both railcar and truck loading)
Annual Denaturant Limit:	4,900 kgal/yr (for both railcar and truck loading)
Max. Amount of Blended Ethanol (based on denaturant limit and E70 blend):	16,333 kgal/yr
Denatured Ethanol Non-Dedicated Railcar Limit:	2,500 kgal/yr
Max. Amount denaturant needed to make 2,500 kgal/yr Denatured Ethanol:	125 kgal/yr
Max. Amount of Blended Ethanol (based on denaturant limit, E70 blend, and 2,500 kgal/y denatured ethanol):	15,917 kgal/yr
Flare Control Efficiency:	98% (only for truck loadout operation EU40A)

(1) Assume all blended ethanol is loaded to trucks (controlled by flare CE12): VOC (tons/yr) = (5.75 lbs/kgal x 16,333 kgal/yr) x (1-98%) x 1 ton/2000 lbs =	<b>0.94 tons/yr</b>
(2) Assume all blended ethanol is loaded to dedicated railcars (no control): VOC (tons/yr) = (1.07 lbs/kgal x 16,333 kgal/yr) x 1 ton/2000 lbs =	<b>8.78 tons/yr</b>
(3) Assume all denatured ethanol is loaded to trucks (controlled by flare CE12): VOC (tons/yr) = (4.98 lbs/kgal x 64,900 kgal/yr) x (1-98%) x 1 ton/2000 lbs =	<b>3.23 tons/yr</b>
(4) Assume all denatured ethanol is loaded to dedicated railcars (no control): VOC (tons/yr) = (0.30 lbs/kgal x 64,900 kgal/yr) x 1 ton/2000 lbs =	<b>9.81 tons/yr</b>
(5) Assume 15,917 kgal blended ethanol is loaded to dedicated railcars (no control) and 2,500 kgal denatured ethanol is loaded to non-dedicated railcars (no control): VOC (tons/yr) = (1.07 lbs/kgal x 15,917 kgal/yr)+(4.98 lbs/kgal x 2,500 kgal/yr) x 1 ton/2000 lbs =	<b>14.8 tons/yr</b>
(6) Assume 62,400 kgal denatured ethanol is loaded to dedicated railcars (no control) and 2,500 kgal denatured ethanol is loaded to non-dedicated railcars (no control): VOC (tons/yr) = (0.30 lbs/kgal x 62,400 kgal/yr)+(4.98 lbs/kgal x 2,500 kgal/yr) x 1 ton/2000 lbs =	<b>15.6 tons/yr</b>
(7) Assume 15,917 kgal blended ethanol is loaded to trucks (control) and 2,500 kgal denatured ethanol is loaded to non-dedicated railcars (no control): VOC (tons/yr) = ((5.75 lbs/kgal x 15,917 kgal/yr)*(1-98%))+((4.98 lbs/kgal x 2,500 kgal/yr) x 1 ton/2000 lbs) =	<b>7.1 tons/yr</b>
(8) Assume 62,400 kgal denatured ethanol is loaded to trucks (control) and 2,500 kgal denatured ethanol is loaded to non-dedicated railcars (no control): VOC (tons/yr) = ((4.98 lbs/kgal x 62,400 kgal/yr)*(1-98%))+((4.98 lbs/kgal x 2,500 kgal/yr) x 1 ton/2000 lbs) =	<b>9.3 tons/yr</b>
<b>Worst case scenario is when loading 62,400 kgal/yr denatured ethanol and 2,500 kgal of denatured ethanol to non-dedicated railcars.</b>	<b>Thus the worst case VOC emissions = 15.6 tons/yr</b>

**4. Potential to Emit HAPs:**

HAP emissions are mainly from the unloading process for trucks and railcars which may have been used to ship gasoline previously.

HAP	HAP Fraction*	PTE of HAP before Control (tons/yr)	Limited PTE of HAP after Control (tons/yr)
Benzene	2.50E-03	3.04	2.03E-02
Carbon Disulfide	2.00E-05	0.02	1.63E-04
Cumene	1.00E-04	0.12	8.13E-04
Ethyl benzene	5.00E-05	0.06	4.06E-04
n-Hexane	5.00E-02	60.80	4.06E-01
Toluene	5.00E-03	6.08	4.06E-02
Xylene	5.00E-04	0.61	4.06E-03
<b>Total</b>	<b>0.06</b>	<b>70.7</b>	<b>0.47</b>

\* This is the HAP fraction for gasoline vapors.

**Methodology**

PTE of HAP before Control (tons/yr) = PTE of VOC before Control (tons/yr) x HAP %

Limited PTE of HAP after Control (tons/yr) = (Limited PTE of VOC by Trucks (tons/yr) + (Non-Dedicated Rail Limit x 5.00 lbs/kgal x 1 ton/2000 lbs) x HAP %

**Appendix A: Emission Calculations  
Combustion Emissions  
From Flare CE009 for Ethanol Loading Rack for Trucks (EU045A)**

**Company Name: Central Indiana Ethanol, LLC  
Address: 2955 W. Delphi Pike Marion, IN 46952  
SPR: 053-24415-00062  
Reviewer: ERG/JR  
Date: June 1, 2007**

Heat Input Capacity  
MMBtu/hr

10.0

Max. Load-out Rate  
kgal/hr

48.0

Annual Production Limit  
kgal/yr

64,900

Emission Factor	Pollutant					
	*PM	*PM10	*SO <sub>2</sub>	**NO <sub>x</sub>	***VOC	**CO
	NA	NA	NA	0.077 (lbs/kgal)	-	0.129 (lbs/kgal)
<b>Unlimited Potential to Emit in tons/yr</b>	<b>NA</b>	<b>NA</b>	<b>NA</b>	<b>16.2</b>	<b>1,209</b>	<b>27.1</b>
<b>Limited Potential to Emit in tons/yr</b>	<b>NA</b>	<b>NA</b>	<b>NA</b>	<b>2.50</b>	<b>0.94</b>	<b>4.19</b>

\*PM, PM10, and SO<sub>2</sub> emission factors are negligible due to the smokeless design and minimal H<sub>2</sub>S levels.

\*\*Emission factors for NO<sub>x</sub> and CO are based on the information provided by the flare manufacturer (MRW Technologies, Inc.)

\*\*\* VOC emission calculations can be found in page 9 of this appendix.

### Methodology

PTE of PM/PM10 and SO<sub>2</sub> (tons/yr) = Max. Heat Input (MMBtu/hr) x 1 MMCF/1,000 MMBtu x Emission Factor (lbs/MMCF) x 8760 hr/yr x 1 ton/2000 lbs

Unlimited PTE of NO<sub>x</sub> and CO (tons/yr) = Max. Load-out Rate (kgal/hr) x Emission Factor (lbs/kgal) x 8760 hr/yr x 1 ton/2000 lbs

Limited PTE of NO<sub>x</sub> and CO (tons/yr) = Annual Production Limit (kgal/yr) x Emission Factor (lbs/kgal) x 1 ton/2000 lbs

Limited PTE of PM/PM10 and SO<sub>2</sub> (tons/yr) = Unlimited PTE (tons/yr) x Annual Production Limit (kgal/yr) / (Max. Load-out Rate kgal/hr x 8760 hr/yr)

**Appendix A: Emission Calculations  
Fugitive Emissions From Roads**

**Company Name: Central Indiana Ethanol, LLC**  
**Address: 2955 W. Delphi Pike Marion, IN 46952**  
**SPR: 053-24415-00062**  
**Reviewer: ERG/JR**  
**Date: June 1, 2007**

**1. Emission Factors: AP-42**

According to AP-42, Chapter 13.2.1 - Paved Roads (12/03), the PM/PM10 emission factors for paved roads can be estimated from the following equation:

$$E = (k \times (sL/2)^a \times (w/3)^b - C) \times (1 - p/(4 \times 365))$$

where:

E = emission factor (lb/vehicle mile traveled)		
sL (non-Winter) = road surface silt loading (g/m <sup>2</sup> ) =	0.6 (g/m <sup>2</sup> ) (AP-42, Table 13.2.1-3)	
sL (Winter) = sL (non-Winter) x 4 (g/m <sup>2</sup> ) =	2.4 (g/m <sup>2</sup> ) (AP-42, Table 13.2.1-3)	
w = mean vehicle weight (tons) =	29.0 tons	
k = empirical constant =	0.082 for PM and 0.016 for PM10	
a = empirical constant =	0.65	
b = empirical constant =	1.5	
C = emission factor for exhaust, brake and tire wear	0.00047 for PM and PM10	
p = number of days per year with 0.01 inches precipitation	130	
PM Emission Factor (non-Winter) =	$(0.082 \times (0.6/2)^{0.65} \times (27.5/3)^{1.5} - 0.00047) \times (1 - 120/1460) =$	<b>1.03 lbs/mile</b>
PM10 Emission Factor (non-Winter) =	$(0.016 \times (0.6/2)^{0.65} \times (27.5/3)^{1.5} - 0.00047) \times (1 - 120/1460) =$	<b>0.20 lbs/mile</b>
PM Emission Factor (Winter) =	$(0.082 \times (2.4/2)^{0.65} \times (27.5/3)^{1.5} - 0.00047) \times (1 - 120/1460) =$	<b>2.53 lbs/mile</b>
PM10 Emission Factor (Winter) =	$(0.016 \times (2.4/2)^{0.65} \times (27.5/3)^{1.5} - 0.00047) \times (1 - 120/1460) =$	<b>0.50 lbs/mile</b>
PM Emission Factor (Average Annual) = ((PM Emission Factor (non-Winter) x 9) + (PM Emission Factor (Winter) x 3))/12		
PM Emission Factor (Average Annual) =		<b>1.40 lbs/mile</b>
PM10 Emission Factor (Average Annual) = ((PM10 Emission Factor (non-Winter) x 9) + (PM10 Emission Factor (Winter) x 3))/12		
PM10 Emission Factor (Average Annual) =		<b>0.28 lbs/mile</b>

**2. Potential to Emit (PTE) of PM/PM10 from Paved Roads:**

Vehicle Type	Ave Weight of Vehicles* (tons)	Trip Number* (trips/yr)	Round Trip Distance* (mile/trip)	Vehicle Mile Traveled (VMT) (miles/yr)	Traffic Component (%)	Component Vehicle Weight (tons)	PTE of PM (tons/yr)	PTE of PM10 (tons/yr)
Grain Receiving	29.0	25,872	0.84	21,732	60.5%	17.55	15.2	2.99
DDGS Load Out	29.0	8,400	0.84	7,056	19.6%	5.70	4.9	0.97
Ethanol Load Out	29.0	8,112	0.84	6,814	19.0%	5.50	4.8	0.94
Denaturant Delivery	29.0	375	0.84	315	0.9%	0.25	0.2	0.04
<b>Total</b>				<b>35,918</b>	<b>100%</b>	<b>29.0</b>	<b>25.2</b>	<b>4.94</b>

\* This information is provided by the source.

**Methodology**

Vehicle Mile Traveled (miles/yr) = Trip Number (trips/yr) x Round Trip Distance (mile/trip)  
 Traffic Component (%) = VMT / Total VMT  
 Component Vehicle Weight = Ave. Weight of Vehicles (tons) x Traffic Component (%)  
 PTE of PM/PM10 before Control (tons/yr) = VMT (miles/yr) x PM/PM10 Emission Factors (Average Annual) x 1 ton/2000 lbs

**3. Potential to Emit (PTE) of PM/PM10 after Control from Paved Roads:**

The source will use periodic sweeping to control the fugitive dust emissions. The control efficiency from sweeping is assumed to be 50%.

PTE of PM after Control =	25.2 tons/yr x (1-50%) =	<b>12.6 tons/yr</b>
PTE of PM10 after Control =	4.94 tons/yr x (1-50%) =	<b>2.47 tons/yr</b>

**4. Unpaved Road Emission Factors: AP-42**

According to AP-42, Section 13.2.2 Unpaved Roads, November 2006, the PM/PM10 emission factors for unpaved roads can be estimated from the following equation:

$$\text{lbs/VMT Equation: } E = k (s/12)^a (W/3)^b \times (365-P)/365$$

Where:

Particle size multiplier k	4.9 dimensionless (PM-30 or TSP)	1.5 dimensionless PM-10
surface material silt content (%) s	8.5 Table 13.2.2-1	
mean vehicle weight W	5.00 tons	
Equation constants a	0.7 PM-30 or TSP Table 13.2.2-2	0.9 PM-10 Table 13.2.2-2
b	0.45 PM-30 or TSP Table 13.2.2-2	0.45 PM-10 Table 13.2.2-2
P	117	
PM Emission Factor =	$(4.9) \times (8.5/12)^{0.7} \times (5/3)^{0.45} \times (365-117)/365 =$	<b>3.29 lbs/mile</b>
PM10 Emission Factor =	$(1.5) \times (8.5/12)^{0.9} \times (5/3)^{0.45} \times (365-117)/365 =$	<b>0.94 lbs/mile</b>

**5. Potential to Emit (PTE) of PM/PM10 from unpaved Roads:**

Emission Area	Number of Trucks (Truck/yr)	Miles Traveled per Truck (miles/Truck)	Unpaved Total VMT	Total Vehicle Emissions (lb/yr)	Total Vehicle Emissions (tpy)
Maintenance Roads (PM)	730	0.20	146	481	<b>0.24</b>
Maintenance Roads (PM10)	730	0.20	146	137	<b>0.07</b>

**Methodology**

Total Vehicle Emissions (tons/yr) = Unpaved Total VMT (miles/yr) x PM/PM10 Emission Factors x 1 ton/2000 lbs

**Appendix A: Emission Calculations  
Combustion Emissions  
Insignificant Combustion Activities**

**Company Name: Central Indiana Ethanol, LLC  
Address: 2955 W. Delphi Pike Marion, IN 46952  
SPR: 053-24415-00062  
Reviewer: ERG/JR  
Date: June 1, 2007**

Description of Insignificant Combustion Activities:

Natural gas fired space heaters with a total firing capacity of 2.5 MMBtu/hr.

Maximum Heat Input MMBtu/hr	Potential Throughput MMCF/yr
2.5	22.3

	Pollutant					
	PM	PM10	SO <sub>2</sub>	NO <sub>x</sub>	VOC	CO
Emission Factor*	1.9	7.6	0.6	94.0	5.5	84.0
Units	lb/MMCF	lb/MMCF	lb/MMCF	lb/MMCF	lb/MMCF	lb/MMCF
Potential Emission in tons/yr	2.12E-02	8.49E-02	6.70E-03	1.05E+00	6.14E-02	9.38E-01

\* Emission factors from Fifth Edition AP-42, Section 1.4, "Natural Gas Combustion", 7/98.

**Methodology**

Potential Throughput (MMCF/yr) = Heat Input Capacity (MMBtu/hr) x 8,760 hrs/yr x 1 MMCF/1,020 MMBtu  
 Potential Emission in tons/yr = Potential Throughput (MMCF/yr) x Emission Factor (lb/MMCF) \* 1 ton/2000lbs

See next page for HAPs emissions calculations.

**Appendix A: Emission Calculations  
HAP Combustion Emissions  
Insignificant Combustion Activities**

**Company Name: Central Indiana Ethanol, LLC  
Address: 2955 W. Delphi Pike Marion, IN 46952  
SPR: 053-24415-00062  
Reviewer: ERG/JR  
Date: April 5, 2007**

Potential Throughput  
MMCF/yr

22.3
------

HAPs - Organics

Emission Factor in lb/MMCF	Benzene 2.1E-03	Dichlorobenzene 1.2E-03	Formaldehyde 7.5E-02	Hexane 1.8E+00	Toluene 3.4E-03
Potential Emission in tons/yr	2.35E-05	1.34E-05	8.38E-04	2.01E-02	3.80E-05

HAPs - Metals

Emission Factor in lb/MMCF	Lead 5.0E-04	Cadmium 1.1E-03	Chromium 1.4E-03	Manganese 3.8E-04	Nickel 2.1E-03
Potential Emission in tons/yr	5.58E-06	1.23E-05	1.56E-05	4.24E-06	2.35E-05

Emission Factors from AP-42, Chapter 1.4, Tables 1.4-1, 1.4-2, and 1.4-3, SCC #1-02-006-02, 1-01-006-02, 1-03-006-02, and 1-03-006-03 (AP-42 Supplement D 3/98)

The five highest organic and metal HAPs emission factors are provided above.

Additional HAPs emission factors are available in AP-42, Chapter 1.4.

**Methodology**

All Emission factors are based on normal firing.

Potential Throughput (MMCF/yr) = Heat Input Capacity (MMBtu/hr) x 8,760 hrs/yr x 1 MMCF/1,020 MMBtu

Potential Emission in tons/yr = Potential Throughput (MMCF/yr) x Emission Factor (lb/MMCF)/2,000 lb/ton

Limited Potential Emission in tons/yr = Limited Throughput (MMCF/yr) x Emission Factor (lb/MMCF)/2,000 lb/ton

**Appendix A: Emission Calculations**  
**VOC and HAP Emissions**  
**From the Corn Oil Separation Unit and Storage Tanks (EU061, EU062, and EU063)**

**Company Name: Central Indiana Ethanol, LLC**  
**Address: 2955 W. Delphi Pike Marion, IN 46952**  
**SPR: 053-24415-00062**  
**Reviewer: ERG/JR**  
**Date: June 1, 2007**

**Potential to Emit (PTE) for Corn Oil Separation Unit (EU061):**

The thin stillage will be processed through a separation process to collect and store excess corn oil. The separation process will be enclosed resulting in no emissions. Loadout and Truck Traffic emissions are negligible based on low annual throughput.

**Potential to Emit (PTE) for Storage Tanks (EU062 and EU063):**

Pollutant	PTE (lb/hr)	PTE (ton/yr)	HAP?	VOC?
Ethanol	0.04	0.19	Y	Y
Methanol**	0.0140	0.06	Y	Y
Ethylacetate**	0.0140	0.06	N	Y
2-furaldehyde	0.0001	4.38E-04	N	Y
Formaldehyde	0.0002	8.76E-04	Y	Y
Acetaldehyde	0.0002	8.76E-04	Y	Y
Acrolein	0.0001	4.38E-04	Y	Y
Formic Acid	0.0030	0.01	N	Y
Lactic Acid	0.0090	0.04	N	Y
Acetic Acid	0.0390	0.17	N	Y
Phosphorous**	0.0080	0.04	Y	N
<b>Total VOC</b>	<b>0.13</b>	<b>0.54</b>		
<b>Total HAP</b>	<b>0.07</b>	<b>0.29</b>		

\* These values were provided by the source based on analytical testing.

\*\* Concentration was reported as less than the detection limit; therefore the values half the detection limit.