



Mitchell E. Daniels, Jr.  
Governor

Thomas W. Easterly  
Commissioner

100 North Senate Avenue  
Indianapolis, Indiana 46204  
(317) 232-8603  
(800) 451-6027  
www.IN.gov/idem

TO: Interested Parties / Applicant  
DATE: December 13, 2007  
RE: BD / 063-24937-00060  
FROM: Matthew Stuckey, Deputy Branch Chief  
Permits Branch  
Office of Air Quality

### Notice of Decision: Approval - Effective Immediately

Please be advised that on behalf of the Commissioner of the Department of Environmental Management, I have issued a decision regarding the enclosed matter. Pursuant to IC 13-15-5-3, this permit is effective immediately, unless a petition for stay of effectiveness is filed and granted according to IC 13-15-6-3, and may be revoked or modified in accordance with the provisions of IC 13-15-7-1.

If you wish to challenge this decision, IC 4-21.5-3 and IC 13-15-6-1 require that you file a petition for administrative review. This petition may include a request for stay of effectiveness and must be submitted to the Office of Environmental Adjudication, 100 North Senate Avenue, Government Center North, Suite N 501E, Indianapolis, IN 46204, **within eighteen (18) calendar days of the mailing of this notice**. The filing of a petition for administrative review is complete on the earliest of the following dates that apply to the filing:

- (1) the date the document is delivered to the Office of Environmental Adjudication (OEA);
- (2) the date of the postmark on the envelope containing the document, if the document is mailed to OEA by U.S. mail; or
- (3) The date on which the document is deposited with a private carrier, as shown by receipt issued by the carrier, if the document is sent to the OEA by private carrier.

The petition must include facts demonstrating that you are either the applicant, a person aggrieved or adversely affected by the decision or otherwise entitled to review by law. Please identify the permit, decision, or other order for which you seek review by permit number, name of the applicant, location, date of this notice and all of the following:

- (1) the name and address of the person making the request;
- (2) the interest of the person making the request;
- (3) identification of any persons represented by the person making the request;
- (4) the reasons, with particularity, for the request;
- (5) the issues, with particularity, proposed for considerations at any hearing; and
- (6) identification of the terms and conditions which, in the judgment of the person making the request, would be appropriate in the case in question to satisfy the requirements of the law governing documents of the type issued by the Commissioner.

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178. Callers from within Indiana may call toll-free at 1-800-451-6027, ext. 3-0178.

Enclosures  
FNPER.dot12/03/07



Mitchell E. Daniels, Jr.  
Governor

Thomas W. Easterly  
Commissioner

100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251  
(317) 232-8603  
(800) 451-6027  
www.IN.gov/idem

**NEW SOURCE CONSTRUCTION PERMIT  
AND  
SOURCE SPECIFIC OPERATING AGREEMENT (SSOA)  
OFFICE OF AIR QUALITY**

**BD  
2350 Reeves Road  
Plainfield, Indiana 46168**

(herein known as the Permittee) is hereby authorized to construct and operate subject to the conditions contained herein, the source described in Section A (Source Summary) of this permit.

This permit is issued to the above mentioned company under the provisions of 326 IAC 2-1.1, 326 IAC 2-5.1, 326 IAC 2-6.1 and 40 CFR 52.780, with conditions listed on the attached pages.

Indiana statutes from IC 13 and rules from 326 IAC, quoted in conditions in this permit, are those applicable at the time the permit was issued. The issuance or possession of this permit shall not alone constitute a defense against an alleged violation of any law, regulation or standard, except for the requirement to obtain a MSOP under 326 IAC 2-6.1.

Operation Permit No.: 063-24937-00060	
Issued by:  <i>Original signed by</i> Matthew Stuckey, Deputy Branch Chief Permits Branch Office of Air Quality	Issuance Date: December 13, 2007

## TABLE OF CONTENTS

<b>A.</b>	<b>SOURCE SUMMARY</b> .....	<b>4</b>
A.1	General Information [326 IAC 2-5.1-3(c)][326 IAC 2-6.1-4(a)]	
A.2	Emission Units and Pollution Control Equipment Summary	
<b>B.</b>	<b>GENERAL CONDITIONS</b> .....	<b>5</b>
B.1	Definitions [326 IAC 2-1.1-1]	
B.2	Revocation of Permits [326 IAC 2-1.1-9(5)]	
B.3	Term of Conditions [326 IAC 2-1.1-9.5]	
B.4	Enforceability	
B.5	Severability	
B.6	Property Rights or Exclusive Privilege	
B.7	Duty to Provide Information	
B.8	Certification	
B.9	Annual Notification [326 IAC 2-6.1-5(a)(5)]	
B.10	Preventive Maintenance Plan [326 IAC 1-6-3]	
B.11	Prior Permits Superseded [326 IAC 2-1.1-9.5]	
B.12	Termination of Right to Operate [326 IAC 2-6.1-7(a)]	
B.13	Permit Renewal [326 IAC 2-6.1-7]	
B.14	Permit Amendment or Revision [326 IAC 2-5.1-3(e)(3)][326 IAC 2-6.1-6]	
B.15	Source Modification Requirement	
B.16	Inspection and Entry [326 IAC 2-5.1-3(e)(4)(B)][326 IAC 2-6.1-5(a)(4)][IC 13-14-2-2] [IC 13-17-3-2][IC 13-30-3-1]	
B.17	Transfer of Ownership or Operational Control [326 IAC 2-6.1-6]	
B.18	Annual Fee Payment [326 IAC 2-1.1-7]	
B.19	Credible Evidence [326 IAC 1-1-6]	
B.20	Source Specific Operating Agreement Program [326 IAC 2-9]	
<b>C.</b>	<b>SOURCE OPERATION CONDITIONS</b> .....	<b>10</b>
	<b>Emission Limitations and Standards [326 IAC 2-6.1-5(a)(1)]</b>	
C.1	Source Status [326 IAC 2-9]	
C.2	Permit Revocation [326 IAC 2-1.1-9]	
C.3	Opacity [326 IAC 5-1]	
C.4	Open Burning [326 IAC 4-1] [IC 13-17-9]	
C.5	Incineration [326 IAC 4-2] [326 IAC 9-1-2]	
C.6	Fugitive Dust Emissions [326 IAC 6-4]	
C.7	Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]	
	<b>Testing Requirements [326 IAC 2-6.1-5(a)(2)]</b>	
C.8	Performance Testing [326 IAC 3-6]	
	<b>Compliance Requirements [326 IAC 2-1.1-11]</b>	
C.9	Compliance Requirements [326 IAC 2-1.1-11]	
	<b>Compliance Monitoring Requirements [326 IAC 2-6.1-5(a)(2)]</b>	
C.10	Compliance Monitoring [326 IAC 2-1.1-11]	
C.11	Monitoring Methods [326 IAC 3] [40 CFR 60] [40 CFR 63]	
C.12	Instrument Specifications [326 IAC 2-1.1-11]	
	<b>Corrective Actions and Response Steps</b>	
C.13	Actions Related to Noncompliance Demonstrated by a Stack Test	

**TABLE OF CONTENTS (Continued)**

**Record Keeping and Reporting Requirements [326 IAC 2-6.1-5(a)(2)]**  
C.14 Malfunctions Report [326 IAC 1-6-2]  
C.15 General Record Keeping Requirements [326 IAC 2-6.1-5]  
C.16 General Reporting Requirements [326 IAC 2-1.1-11] [326 IAC 2-6.1-2]  
[IC 13-14-1-13]

**D.1 EMISSIONS UNIT OPERATION CONDITIONS..... 12**

**Emission Limitations and Standards [326 IAC 2-6.1-5(a)(1)]**  
D.1.1 Fuel Usage Limit [326 IAC 2-9-14(a)(2)]

**Record Keeping and Reporting Requirements [326 IAC 2-6.1-5(a)(2)]**  
D.1.2 Record Keeping Requirement [326 IAC 2-9-13]  
D.1.3 Annual Notification [326 IAC 2-9-14]  
D.1.4 Reporting Requirements [326 IAC 2-9-14]

**Annual Notification ..... 17**

## SECTION A SOURCE SUMMARY

This permit is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ). The information describing the source contained in conditions A.1 and A.2 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this permit pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

### A.1 General Information [326 IAC 2-5.1-3(c)][326 IAC 2-6.1-4(a)]

---

The Permittee owns and operates a stationary source with emergency generators.

Source Address:	2350 Reeves Road, Plainfield, Indiana 46168
Mailing Address:	2350 Reeves Road, Plainfield, Indiana 46168
General Source Phone Number:	(317) 561-2902
SIC Code:	3841
County Location:	Hendricks
Source Location Status:	Nonattainment for 8-hour ozone standard Nonattainment for PM 2.5 standard Attainment for all other criteria pollutants
Source Status:	Minor Source Operating Permit Program Minor Source, under PSD, Emission Offset Rules, and Nonattainment New Source Review Minor Source, Section 112 of the Clean Air Act Not 1 of 28 Source Categories

### A.2 Emission Units and Pollution Control Equipment Summary

---

This stationary source consists of the following emission units and pollution control devices:

- (a) Two (2) diesel-fired emergency generators, identified as EG1 and EG2, installed in 2006, each with a maximum power output rate of 2,220 horsepower.

### A.3 SSOA Applicability [326 IAC 2-9-1]

---

This stationary source, otherwise required to have a Minor Source Operating Permit as described in 326 IAC 2-6-1, has applied to the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ) for a Source Specific Operating Agreement (SSOA).

## **SECTION B GENERAL CONDITIONS**

### **B.1 Definitions [326 IAC 2-1.1-1]**

---

Terms in this permit shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, the applicable definitions found in the statutes or regulations (IC 13-11, 326 IAC 1-2 and 326 IAC 2-1.1-1) shall prevail.

### **B.2 Revocation of Permits [326 IAC 2-1.1-9(5)]**

---

Pursuant to 326 IAC 2-1.1-9(5)(Revocation of Permits), the Commissioner may revoke this permit if construction is not commenced within eighteen (18) months after receipt of this approval or if construction is suspended for a continuous period of one (1) year or more.

### **B.3 Term of Conditions [326 IAC 2-1.1-9.5]**

---

Notwithstanding the permit term of a permit to construct, a permit to operate, or a permit modification, any condition established in a permit issued pursuant to a permitting program approved in the state implementation plan shall remain in effect until:

- (a) the condition is modified in a subsequent permit action pursuant to Title I of the Clean Air Act; or
- (b) the emission unit to which the condition pertains permanently ceases operation.

### **B.4 Enforceability**

---

Unless otherwise stated, all terms and conditions in this permit, including any provisions designed to limit the source's potential to emit, are enforceable by IDEM, the United States Environmental Protection Agency (U.S. EPA) and by citizens in accordance with the Clean Air Act.

### **B.5 Severability**

---

The provisions of this permit are severable; a determination that any portion of this permit is invalid shall not affect the validity of the remainder of the permit.

### **B.6 Property Rights or Exclusive Privilege**

---

This permit does not convey any property rights of any sort or any exclusive privilege.

### **B.7 Duty to Provide Information**

---

- (a) The Permittee shall furnish to IDEM, OAQ, within a reasonable time, any information that IDEM, OAQ may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The submittal by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1). Upon request, the Permittee shall also furnish to IDEM, OAQ copies of records required to be kept by this permit.
- (b) For information furnished by the Permittee to IDEM, OAQ, the Permittee may include a claim of confidentiality in accordance with 326 IAC 17.1. When furnishing copies of requested records directly to U. S. EPA, the Permittee may assert a claim of confidentiality in accordance with 40 CFR 2, Subpart B.

### **B.8 Certification**

---

- (a) Where specifically designated by this permit or required by an applicable requirement, any application form, report, or compliance certification submitted shall contain certification by an "authorized individual" of truth, accuracy, and completeness. This certification shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
- (b) One (1) certification shall be included, using the attached Certification Form, with each submittal requiring certification. One (1) certification may cover multiple forms in one (1) submittal.

- (c) An "authorized individual" is defined at 326 IAC 2-1.1-1(1).

B.9 Annual Notification [326 IAC 2-6.1-5(a)(5)]

- (a) An annual notification shall be submitted by an authorized individual to the Office of Air Quality stating whether or not the source is in operation and in compliance with the terms and conditions contained in this permit.
- (b) The annual notice shall be submitted in the format attached no later than March 1 of each year to:
- Indiana Department of Environmental Management  
Compliance Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, IN 46204-2251
- (c) The notification shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.

B.10 Preventive Maintenance Plan [326 IAC 1-6-3]

- (a) If required by specific condition(s) in Section D of this permit, the Permittee shall prepare and maintain Preventive Maintenance Plans (PMPs) within ninety (90) days after issuance of this permit, including the following information on each facility:
- (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;
  - (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
  - (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

If, due to circumstances beyond the Permittee's control, the PMPs cannot be prepared and maintained within the above time frame, the Permittee may extend the date an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management  
Compliance Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

The PMP extension notification does not require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (b) A copy of the PMPs shall be submitted to IDEM, OAQ upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. IDEM, OAQ may require the Permittee to revise its PMPs whenever lack of proper maintenance causes or is the primary contributor to an exceedance of any limitation on emissions or potential to emit. The PMPs do not require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (c) To the extent the Permittee is required by 40 CFR Part 60/63 to have an Operation Maintenance, and Monitoring (OMM) Plan for a unit, such Plan is deemed to satisfy the PMP requirements of 326 IAC 1-6-3 for that unit.

B.11 Prior Permits Superseded [326 IAC 2-1.1-9.5]

- (a) All terms and conditions of permits established prior to S063-24937-00060 and issued pursuant to permitting programs approved into the state implementation plan have been either:
- (1) incorporated as originally stated,
  - (2) revised, or
  - (3) deleted.
- (b) All previous registrations and permits are superseded by this permit.

B.12 Termination of Right to Operate [326 IAC 2-6.1-7(a)]

The Permittee's right to operate this source terminates with the expiration of this permit unless a timely and complete renewal application is submitted at least ninety (90) days prior to the date of expiration of the source's existing permit, consistent with 326 IAC 2-6.1-7.

B.13 Permit Renewal [326 IAC 2-6.1-7]

- (a) The application for renewal shall be submitted using the application form or forms prescribed by IDEM, OAQ and shall include the information specified in 326 IAC 2-6.1-7. Such information shall be included in the application for each emission unit at this source. The renewal application does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

Request for renewal shall be submitted to:

Indiana Department of Environmental Management  
Permits Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

- (b) A timely renewal application is one that is:
- (1) Submitted at least ninety (90) days prior to the date of the expiration of this permit; and
  - (2) If the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
- (c) If the Permittee submits a timely and complete application for renewal of this permit, the source's failure to have a permit is not a violation of 326 IAC 2-6.1 until IDEM, OAQ takes final action on the renewal application, except that this protection shall cease to apply if, subsequent to the completeness determination, the Permittee fails to submit by the deadline specified in writing by IDEM, OAQ any additional information identified as being needed to process the application.

B.14 Permit Amendment or Revision [326 IAC 2-5.1-3(e)(3)][326 IAC 2-6.1-6]

- (a) Permit amendments and revisions are governed by the requirements of 326 IAC 2-6.1-6 whenever the Permittee seeks to amend or modify this permit.
- (b) Any application requesting an amendment or modification of this permit shall be submitted to:

Indiana Department of Environmental Management  
Permits Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

Any such application shall be certified by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (c) The Permittee shall notify the OAQ within thirty (30) calendar days of implementing a notice-only change. [326 IAC 2-6.1-6(d)]

**B.15 Source Modification Requirement**

---

A modification, construction, or reconstruction is governed by the requirements of 326 IAC 2.

**B.16 Inspection and Entry**

---

[326 IAC 2-5.1-3(e)(4)(B)][326 IAC 2-6.1-5(a)(4)][IC 13-14-2-2][IC 13-17-3-2][IC 13-30-3-1]

---

Upon presentation of proper identification cards, credentials, and other documents as may be required by law, and subject to the Permittee's right under all applicable laws and regulations to assert that the information collected by the agency is confidential and entitled to be treated as such, the Permittee shall allow IDEM, OAQ, U.S. EPA, or an authorized representative to perform the following:

- (a) Enter upon the Permittee's premises where a permitted source is located, or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
- (b) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- (c) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, inspect, at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit;
- (d) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with this permit or applicable requirements; and
- (e) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, utilize any photographic, recording, testing, monitoring, or other equipment for the purpose of assuring compliance with this permit or applicable requirements.

**B.17 Transfer of Ownership or Operational Control [326 IAC 2-6.1-6]**

---

- (a) The Permittee must comply with the requirements of 326 IAC 2-6.1-6 whenever the Permittee seeks to change the ownership or operational control of the source and no other change in the permit is necessary.
- (b) Any application requesting a change in the ownership or operational control of the source shall contain a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new Permittee. The application shall be submitted to:

Indiana Department of Environmental Management  
Permits Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

The application which shall be submitted by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (c) The Permittee may implement notice-only changes addressed in the request for a notice-only change immediately upon submittal of the request. [326 IAC 2-6.1-6(d)(3)]

**B.18 Annual Fee Payment [326 IAC 2-1.1-7]**

---

- (a) The Permittee shall pay annual fees to IDEM, OAQ within thirty (30) calendar days of receipt of a billing.
- (b) The Permittee may call the following telephone numbers: 1-800-451-6027 or 317-233-4230 (ask for OAQ, Billing, Licensing, and Training Section), to determine the appropriate permit fee.

**B.19 Credible Evidence [326 IAC 1-1-6]**

---

For the purpose of submitting compliance certifications or establishing whether or not the Permittee has violated or is in violation of any condition of this permit, nothing in this permit shall preclude the use, including the exclusive use, of any credible evidence or information relevant to whether the Permittee would have been in compliance with the condition of this permit if the appropriate performance or compliance test or procedure had been performed.

**B.20 Source Specific Operating Agreement Program [326 IAC 2-9]**

---

This document shall also become a source specific operating agreement pursuant to 326 IAC 2-9-1 when the following requirements are met:

- (a) The attached Affidavit of Construction shall be submitted to the Office of Air Quality (OAQ), Permit Administration & Development Section.
  - (1) If the Affidavit of Construction verifies that the facilities covered in this Construction Permit were constructed as proposed in the application, then the facilities may begin operating on the date the Affidavit of Construction is postmarked or hand delivered to IDEM.
  - (2) If actual construction of the emission units differs from the construction proposed in the application, the source may not begin operation until the permit has been revised pursuant to 326 IAC 2-9 and an Operation Permit Validation Letter is issued.
- (b) If construction is completed in phases; i.e., the entire construction is not done continuously, a separate affidavit must be submitted for each phase of construction. Any permit conditions associated with operation start up dates such as stack testing for New Source Performance Standards (NSPS) shall be applicable to each individual phase.
- (c) Upon receipt of the Operation Permit Validation Letter from the Chief of the Permit Administration & Development Section, the Permittee shall attach it to this document.
- (d) The operating agreement will be subject to a one time application fee of \$500 pursuant to 326 IAC 2-9-1(g) (Source Specific Operating Agreement Program).

## SECTION C SOURCE OPERATION CONDITIONS

Entire Source

### Emission Limitations and Standards [326 IAC 2-6.1-5(a)(1)]

#### C.1 Source Status [326 IAC 2-9]

- (a) The requirements of 326 IAC 2-9-14(a)(2) are applicable to this SSOA.
- (b) Pursuant to 326 IAC 2-9-1(g), the source may apply for up to four (4) different SSOAs contained in 326 IAC 2-9.

#### C.2 Permit Revocation [326 IAC 2-1.1-9]

Pursuant to 326 IAC 2-1.1-9 (Revocation of Permits), this permit to construct and to operate may be revoked for any of the following causes:

- (a) Violation of any conditions of this permit.
- (b) Failure to disclose all the relevant facts, or misrepresentation in obtaining this permit.
- (c) Changes in regulatory requirements that mandate either a temporary or permanent reduction of discharge of contaminants. However, the amendment of appropriate sections of this permit shall not require revocation of this permit.
- (d) Noncompliance with orders issued pursuant to 326 IAC 1-5 (Episode Alert Levels) to reduce emissions during an air pollution episode.
- (e) For any cause which establishes in the judgment of IDEM, the fact that continuance of this permit is not consistent with purposes of this article.

#### C.3 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

- (a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

#### C.4 Open Burning [326 IAC 4-1] [IC 13-17-9]

The Permittee shall not open burn any material except as provided in 326 IAC 4-1-3, 326 IAC 4-1-4 or 326 IAC 4-1-6. The previous sentence notwithstanding, the Permittee may open burn in accordance with an open burning approval issued by the Commissioner under 326 IAC 4-1-4.1.

#### C.5 Incineration [326 IAC 4-2] [326 IAC 9-1-2]

The Permittee shall not operate an incinerator or incinerate any waste or refuse except as provided in 326 IAC 4-2 and 326 IAC 9-1-2.

#### C.6 Fugitive Dust Emissions [326 IAC 6-4]

The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions).

C.7 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

---

- (a) Notification requirements apply to each owner or operator. If the combined amount of regulated asbestos containing material (RACM) to be stripped, removed or disturbed is at least 260 linear feet on pipes or 160 square feet on other facility components, or at least thirty-five (35) cubic feet on all facility components, then the notification requirements of 326 IAC 14-10-3 are mandatory. All demolition projects require notification whether or not asbestos is present.
- (b) The Permittee shall ensure that a written notification is sent on a form provided by the Commissioner at least ten (10) working days before asbestos stripping or removal work or before demolition begins, per 326 IAC 14-10-3, and shall update such notice as necessary, including, but not limited to the following:
  - (1) When the amount of affected asbestos containing material increases or decreases by at least twenty percent (20%); or
  - (2) If there is a change in the following:
    - (A) Asbestos removal or demolition start date;
    - (B) Removal or demolition contractor; or
    - (C) Waste disposal site.
- (c) The Permittee shall ensure that the notice is postmarked or delivered according to the guidelines set forth in 326 IAC 14-10-3(2).
- (d) The notice to be submitted shall include the information enumerated in 326 IAC 14-10-3(3).

All required notifications shall be submitted to:

Indiana Department of Environmental Management  
Asbestos Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-52 IGCN 1003  
Indianapolis, Indiana 46204-2251

The notice shall include a signed certification from the owner or operator that the information provided in this notification is correct and that only Indiana licensed workers and project supervisors will be used to implement the asbestos removal project. The notifications do not require a certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (e) **Procedures for Asbestos Emission Control**  
The Permittee shall comply with the applicable emission control procedures in 326 IAC 14-10-4 and 40 CFR 61.145(c). Per 326 IAC 14-10-1, emission control requirements are applicable for any removal or disturbance of RACM greater than three (3) linear feet on pipes or three (3) square feet on any other facility components or a total of at least 0.75 cubic feet on all facility components.
- (f) **Demolition and Renovation**  
The Permittee shall thoroughly inspect the affected facility or part of the facility where the demolition or renovation will occur for the presence of asbestos pursuant to 40 CFR 61.145(a).
- (g) **Indiana Accredited Asbestos Inspector**  
The Permittee shall comply with 326 IAC 14-10-1(a) that requires the owner or operator, prior to a renovation/demolition, to use an Indiana Accredited Asbestos Inspector to

thoroughly inspect the affected portion of the facility for the presence of asbestos. The requirement to use an Indiana Accredited Asbestos inspector is not federally enforceable.

### **Testing Requirements [326 IAC 2-6.1-5(a)(2)]**

#### **C.8 Performance Testing [326 IAC 3-6]**

---

- (a) Compliance testing on new emissions units shall be conducted within 60 days after achieving maximum production rate, but no later than 180 days after initial start-up, if specified in Section D of this approval. All testing shall be performed according to the provisions of 326 IAC 3-6 (Source Sampling Procedures), except as provided elsewhere in this permit, utilizing any applicable procedures and analysis methods specified in 40 CFR 51, 40 CFR 60, 40 CFR 61, 40 CFR 63, 40 CFR 75, or other procedures approved by IDEM, OAQ.

A test protocol, except as provided elsewhere in this permit, shall be submitted to:

Indiana Department of Environmental Management  
Compliance Data Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

no later than thirty-five (35) days prior to the intended test date. The protocol submitted by the Permittee does not require certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (b) The Permittee shall notify IDEM, OAQ of the actual test date at least fourteen (14) days prior to the actual test date. The notification submitted by the Permittee does not require certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (c) Pursuant to 326 IAC 3-6-4(b), all test reports must be received by IDEM, OAQ not later than forty-five (45) days after the completion of the testing. An extension may be granted by IDEM, OAQ if the Permittee submits to IDEM, OAQ, a reasonable written explanation not later than five (5) days prior to the end of the initial forty-five (45) day period.

### **Compliance Requirements [326 IAC 2-1.1-11]**

#### **C.9 Compliance Requirements [326 IAC 2-1.1-11]**

---

The commissioner may require stack testing, monitoring, or reporting at any time to assure compliance with all applicable requirements by issuing an order under 326 IAC 2-1.1-11. Any monitoring or testing shall be performed in accordance with 326 IAC 3 or other methods approved by the commissioner or the U. S. EPA.

### **Compliance Monitoring Requirements [326 IAC 2-6.1-5(a)(2)]**

#### **C.10 Compliance Monitoring [326 IAC 2-1.1-11]**

---

Compliance with applicable requirements shall be documented as required by this permit. The Permittee shall be responsible for installing any necessary equipment and initiating any required monitoring related to that equipment. All monitoring and record keeping requirements not already legally required shall be implemented when operation begins.

#### **C.11 Monitoring Methods [326 IAC 3] [40 CFR 60] [40 CFR 63]**

---

Any monitoring or testing required by Section D of this permit shall be performed according to the provisions of 326 IAC 3, 40 CFR 60, Appendix A, 40 CFR 60, Appendix B, 40 CFR 63, or other approved methods as specified in this permit.

#### **C.12 Instrument Specifications [326 IAC 2-1.1-11]**

---

- (a) When required by any condition of this permit, an analog instrument used to measure a parameter related to the operation of an air pollution control device shall have a scale

such that the expected maximum reading for the normal range shall be no less than twenty percent (20%) of full scale.

- (b) The Permittee may request that the IDEM, OAQ approve the use of an instrument that does not meet the above specifications provided the Permittee can demonstrate that an alternative instrument specification will adequately ensure compliance with permit conditions requiring the measurement of the parameters.

### **Corrective Actions and Response Steps**

#### **C.13 Actions Related to Noncompliance Demonstrated by a Stack Test**

---

- (a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this permit exceed the level specified in any condition of this permit, the Permittee shall take appropriate response actions. The Permittee shall submit a description of these response actions to IDEM, OAQ, within thirty (30) days of receipt of the test results. The Permittee shall take appropriate action to minimize excess emissions from the affected facility while the response actions are being implemented.
- (b) A retest to demonstrate compliance shall be performed within one hundred twenty (120) days of receipt of the original test results. Should the Permittee demonstrate to IDEM, OAQ that retesting in one hundred twenty (120) days is not practicable, IDEM, OAQ may extend the retesting deadline.
- (c) IDEM, OAQ reserves the authority to take any actions allowed under law in response to noncompliant stack tests.

The response action documents submitted pursuant to this condition do require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

### **Record Keeping and Reporting Requirements [326 IAC 2-6.1-5(a)(2)]**

#### **C.14 Malfunctions Report [326 IAC 1-6-2]**

---

Pursuant to 326 IAC 1-6-2 (Records; Notice of Malfunction):

- (a) A record of all malfunctions, including startups or shutdowns of any facility or emission control equipment, which result in violations of applicable air pollution control regulations or applicable emission limitations shall be kept and retained for a period of three (3) years and shall be made available to the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ) or appointed representative upon request.
- (b) When a malfunction of any facility or emission control equipment occurs which lasts more than one (1) hour, said condition shall be reported to OAQ, using the Malfunction Report Forms (2 pages). Notification shall be made by telephone or facsimile, as soon as practicable, but in no event later than four (4) daytime business hours after the beginning of said occurrence.
- (c) Failure to report a malfunction of any emission control equipment shall constitute a violation of 326 IAC 1-6, and any other applicable rules. Information of the scope and expected duration of the malfunction shall be provided, including the items specified in 326 IAC 1-6-2(a)(1) through (6).
- (d) Malfunction is defined as any sudden, unavoidable failure of any air pollution control equipment, process, or combustion or process equipment to operate in a normal and usual manner. [326 IAC 1-2-39]

#### **C.15 General Record Keeping Requirements [326 IAC 2-6.1-5]**

---

- (a) Records of all required monitoring data, reports and support information required by this permit shall be retained for a period of at least five (5) years from the date of monitoring sample, measurement, report, or application. These records shall be physically present

or electronically accessible at the source location for a minimum of three (3) years. The records may be stored elsewhere for the remaining two (2) years as long as they are available upon request. If the Commissioner makes a request for records to the Permittee, the Permittee shall furnish the records to the Commissioner within a reasonable time.

- (b) Unless otherwise specified in this permit, all record keeping requirements not already legally required shall be implemented within ninety (90) days of permit issuance.

C.16 General Reporting Requirements [326 IAC 2-1.1-11] [326 IAC 2-6.1-2] [IC 13-14-1-13]

- (a) Reports required by conditions in Section D of this permit shall be submitted to:

Indiana Department of Environmental Management  
Compliance Data Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

- (b) Unless otherwise specified in this permit, any notice, report, or other submission required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
- (c) Unless otherwise specified in this permit, all reports required in Section D of this permit shall be submitted within thirty (30) days of the end of the reporting period. All reports do require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (d) The first report shall cover the period commencing on the date of issuance of this permit and ending on the last day of the reporting period. Reporting periods are based on calendar years, unless otherwise specified in this permit. For the purpose of this permit "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.

## SECTION D.1 EMISSIONS UNIT OPERATION CONDITIONS

### Emissions Unit Description:

- (a) Two (2) diesel-fired emergency generators, identified as EG1 and EG2, installed in 2006, each with a maximum power output rate of 2,220 horsepower.

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards

#### D.1.1 Fuel Usage Limit [326 IAC 2-9-14(a)(2)]

Pursuant to 326 IAC 2-9-14(a)(2), the fuel usage for the internal combustion units at this source shall be less than three hundred seventy-six and seventy-two hundredths (376.72) kilogallons of diesel fuel for every twelve (12) consecutive month period.

### Record Keeping and Reporting Requirements [326 IAC 2-5.1-3(e)(2)] [326 IAC 2-6.1-5(a)(2)]

#### D.1.2 Record Keeping Requirements [326 IAC 2-9-13]

The Permittee shall maintain the following records for the internal combustion units at this source:

- (a) Hours operated for each combustion unit.
- (b) Records of annual fuel usage for the internal combustion units.
- (c) Routine maintenance records.

#### D.1.3 Annual Notification [326 IAC 2-9-14]

The Permittee shall provide an annual notice to the commissioner, stating that the source is in operation, and certifying that its operations are in compliance with the requirements of this Source Specific Operating Agreement. The above annual notice will be submitted to:

Compliance Data Section  
Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, IN 46204-2251

no later than January 30 of each year, with the annual notice being submitted in the format attached to the operating agreement.

#### D.1.4 Reporting Requirements [326 IAC 2-9-14]

Any exceedance of any requirement contained in this operating agreement shall be reported, in writing, within one (1) week of its occurrence. Said report shall include information on the actions taken to correct the exceedance, including measures to reduce emissions, in order to comply with the established limits. If an exceedance is the result of a malfunction, then the provisions of 326 IAC 1-6 apply.

<b>Source Specific Operating Agreement Annual Notification</b>
--

This form should be used to comply with the notification requirements under 326 IAC 2-9.

<b>Company Name:</b>	BD
<b>Address:</b>	2350 Reeves Road
<b>City:</b>	Plainfield, Indiana 46168
<b>Phone #:</b>	(317) 561-2909
<b>SSOA #:</b>	063-24937-00060

I hereby certify that BD is still in operation and is in compliance with the requirements of Source Specific Operating Agreement (SSOA) 063-24937-00060.

<b>Name (typed):</b>
<b>Title:</b>
<b>Signature:</b>
<b>Date:</b>

# Indiana Department of Environmental Management Office of Air Quality

## Addendum to the Technical Support Document For a New Source Construction Source Specific Operating Agreement (SSOA)

### Source Background and Description

Source Name:	BD
Source Location:	2350 Reeves Road, Plainfield, Indiana 46168
County:	Hendricks
SIC Code:	3841
Operation Permit No.:	S063-24937-00060
Permit Reviewer:	ERG/JR

On November 9, 2007, the Office of Air Quality (OAQ) had a notice published in the Hendricks County Flyer of Hendricks County, Indiana stating that BD had applied for a New Source Construction Source Specific Operating Agreement (SSOA). The notice also stated that OAQ proposed to issue a permit for this operation and provided information on how the public could review the proposed permit and other documentation. Finally, the notice informed interested parties that there was a period of thirty (30) days to provide comments on whether or not this permit should be issued as proposed.

Upon further review, IDEM has decided to make the following revision to the permit (the language with a line through it has been deleted):

1. IDEM has removed Condition B.3 because this permit is a New Source Construction Source Specific Operating Agreement (SSOA) permit which does not have a 5 year permit term. A SSOA is valid for the life of the source and does not require renewal. All subsequent conditions have been renumbered and the Table of Contents revised.

The following changes have been made to the permit:

~~B.3 Permit Term [326 IAC 2-6.1-7(a)][326 IAC 2-1.1-9.5][IC 13-15-3-6(a)]~~

- ~~(a) This permit, S063-24937-00060, is issued for a fixed term of five (5) years from the issuance date of this permit, as determined in accordance with IC 4-21.5-3-5(f) and IC 13-15-5-3. Subsequent revisions, modifications, or amendments of this permit do not affect the expiration date of this permit.~~
- ~~(b) If IDEM, OAQ, upon receiving a timely and complete renewal permit application, fails to issue or deny the permit renewal prior to the expiration date of this permit, this existing permit shall not expire and all terms and conditions shall continue in effect, until the renewal permit has been issued or denied.~~

# Indiana Department of Environmental Management Office of Air Quality

## Technical Support Document (TSD) for a New Source Construction and Source Specific Operating Agreement (SSOA)

### Source Background and Description

Source Name:	BD
Source Location:	2350 Reeves Road, Plainfield, Indiana 46168
County:	Hendricks
SIC Code:	3841
Operation Permit No.:	S063-24937-00060
Permit Reviewer:	ERG/JR

The Office of Air Quality (OAQ) has reviewed an application from BD relating to the construction and operation of two (2) emergency diesel-fired generators.

### Unpermitted Emission Units and Pollution Control Equipment

The source consists of the following unpermitted emission units:

- (a) Two (2) diesel-fired emergency generators, identified as EG1 and EG2, installed in 2006, each with a maximum power output rate of 2,220 horsepower.

### Enforcement Issue

- (a) IDEM is aware that equipment has been constructed and/or operated prior to receipt of the proper permit. The subject equipment is listed in this Technical Support Document under the condition entitled "Unpermitted Emission Units and Pollution Control Equipment".
- (b) IDEM is reviewing this matter and will take appropriate action. This proposed permit is intended to satisfy the requirements of the construction permit rules.

### Recommendation

The staff recommends to the Commissioner that the construction and operation be approved. This recommendation is based on the following facts and conditions:

Unless otherwise stated, information used in this review was derived from the application and additional information submitted by the applicant.

An application for the purposes of this review was received on June 15, 2007, with additional information received on August 29, 2007 and August 31, 2007.

### Emission Calculations

See Appendix A of this document for detailed emission calculations (Appendix A, page 1).

### Potential to Emit of the Source Before Controls

Pursuant to 326 IAC 2-1.1-1(16), Potential to Emit is defined as “the maximum capacity of a stationary source or emissions unit to emit any air pollutant under its physical and operational design. Any physical or operational limitation on the capacity of a source to emit an air pollutant, including air pollution control equipment and restrictions on hours of operation or type or amount of material combusted, stored, or processed shall be treated as part of its design if the limitation is enforceable by the U.S. EPA, the department, or the appropriate local air pollution control agency.”

Pollutant	Potential To Emit (tons/year) <sup>(1)</sup>
PM	0.78
PM10 <sup>(2)</sup>	0.78
SO <sub>2</sub>	4.44
VOC	0.78
CO	6.11
NO <sub>x</sub>	26.6

(1) The potential to emit is based on the emergency generators operating at a maximum of 500 hours per year.

(2) For the purposes of Nonattainment New Source Review, PM10 is regulated as a surrogate for PM2.5 (see discussion in paragraph (a) in “County Attainment Status” below for additional information).

HAPs	Potential To Emit (tons/year)
Single HAP	Less than 10
Total	Less than 25

The potential to emit (as defined in 326 IAC 2-1.1-1(16)) of pollutants are less than 100 tons per year and the potential to emit NO<sub>x</sub> is greater than 25 tons per year. The source has opted to limit operations pursuant to 326 IAC 2-9-14, Source Specific Operating Agreement (SSOA) for Internal Combustion Sources. Pursuant to 326 IAC 2-1.1-3(d), the source is not one of the listed type sources that is excluded from new source requirements; therefore, a New Source Construction Permit and SSOA will be issued.

### County Attainment Status

The source is located in Hendricks County.

Pollutant	Status
PM2.5	Nonattainment
PM10	Attainment
SO <sub>2</sub>	Attainment
NO <sub>2</sub>	Attainment
8-hour Ozone	Nonattainment
CO	Attainment
Lead	Attainment

**Note:** On October 25, 2006, the Indiana Air Pollution Control Board finalized a rule revision to 326 IAC 1-4-1 revoking the one-hour ozone standard in Indiana.

- (a) U.S.EPA in Federal Register Notice 70 FR 943 dated January 5, 2005 has designated Hendricks County as nonattainment for PM2.5. On March 7, 2005 the Indiana Attorney General’s Office on behalf of IDEM filed a law suit with the Court of Appeals for the District of Columbia Circuit challenging U.S. EPA’s designation of nonattainment areas without sufficient data. However, in order to ensure that sources are not potentially liable for violation of the Clean Air Act, the OAQ is following the U.S. EPA’s guidance to regulate

PM10 emissions as surrogate for PM2.5 emissions pursuant to the Nonattainment New Source Review requirements. See the State Rule Applicability section for the entire source.

- (b) Volatile organic compounds (VOC) and Nitrogen Oxides (NO<sub>x</sub>) are regulated under the Clean Air Act (CAA) for the purposes of attaining and maintaining the National Ambient Air Quality Standards (NAAQS) for ozone. Therefore, VOC and NO<sub>x</sub> emissions are considered when evaluating the rule applicability relating to the ozone standards. Hendricks County has been designated as nonattainment for the 8-hour ozone standard. Therefore, VOC and NO<sub>x</sub> emissions were reviewed pursuant to the requirements for Emission Offset, 326 IAC 2-3. See the State Rule Applicability section for the entire source.
- (c) Hendricks County has been classified as attainment or unclassifiable in Indiana for all other criteria pollutants. Therefore, these emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2. See the State Rule Applicability section for the entire source.
- (d) Fugitive Emissions  
Since this type of operation is not one of the 28 listed source categories under 326 IAC 2-2 or 2-3 and since there are no applicable New Source Performance Standards that were in effect on August 7, 1980, the fugitive particulate matter (PM) and volatile organic compound (VOC) emissions are not counted toward determination of PSD and Emission Offset applicability.

### Source Status

Source PSD Definition (emissions after controls, based on 8760 hours of operation per year at rated capacity and/or as otherwise limited):

Pollutant	Emissions (tons/yr)
PM	Less than 250
PM10	Less than 100
SO <sub>2</sub>	Less than 250
VOC	Less than 100
CO	Less than 250
NO <sub>x</sub>	Less than 100
Single HAP	Less than 10
Combination HAPs	Less than 25

- (a) This source is not a major stationary source, under PSD (326 IAC 2-2), because no regulated pollutant is emitted at a rate of 250 tons per year or more, and it is not one of the twenty-eight (28) listed source categories, as specified in 326 IAC 2-2-1(gg)(1).
- (b) This source is not a major stationary source under Emission Offset (326 IAC 2-3) or Nonattainment New Source Review (326 IAC 2-1.1-5) because no nonattainment regulated pollutant is emitted at a rate of 100 tons per year or more.
- (c) These emissions are based upon AP-42 emission factors for diesel combustion (see AP-42, Section 3.4 (10/1996), Table 3.4-1).

### Federal Rule Applicability

- (a) There are no New Source Performance Standards (NSPS) (326 IAC 12) included for this source.

- (b) The requirements of the New Source Performance Standards for Stationary Compression Ignition Internal Combustion Engines (326 IAC 12, 40 CFR 60.4200 - 4209, Subpart IIII) are not included in the permit. The emergency generators, identified as EG1 and EG2, commenced construction before July 11, 2005 and were manufactured before April 1, 2006.
- (c) There are no National Emission Standards for Hazardous Air Pollutants (NESHAP)(326 IAC 14, 20 and 40 CFR Part 61, 63) included for this source.

### **State Rule Applicability – Entire Source**

#### **326 IAC 1-5-2 (Emergency Reduction Plans)**

The source is not subject to the requirements of 326 IAC 1-5-2 (Emergency Reduction Plans) because it does not have the potential to emit one hundred (100) tons per year, or more, of any pollutant.

#### **326 IAC 2-2 (Prevention of Significant Deterioration)**

This source is not a major stationary source under 326 IAC 2-2 because no attainment pollutant is emitted at a rate of 250 tons per year or greater, and it is not one of the 28 listed source categories. Therefore, pursuant to 326 IAC 2-2, the PSD requirements do not apply.

#### **326 IAC 2-3 (Emission Offset)**

On April 15, 2004, the United States Environmental Protection Agency (U.S. EPA) named 23 Indiana counties, and one partial county, nonattainment for the new 8-hour ozone standard. The designations became effective on June 15, 2004. Hendricks County has been designated as nonattainment for the 8-hour ozone standard. The source has a potential to emit VOC and NO<sub>x</sub> less than one hundred (100) tons per year, each. Therefore, this is not a major source under 326 IAC 2-3 (Emission Offset).

#### **326 IAC 2-1.1-5 (Nonattainment New Source Review)**

Hendricks County has been designated as nonattainment for PM<sub>2.5</sub> in 70 FR 943 dated January 5, 2005. According to the April 5, 2005 EPA memo title "Implementation of New Source Review Requirements in PM<sub>2.5</sub> Nonattainment Areas" authored by Steve Page, Director of OAQPS, until EPA promulgates the PM<sub>2.5</sub> major NSR regulations, states should assume that a major stationary source's PM<sub>10</sub> emissions represent PM<sub>2.5</sub> emissions. IDEM will use the PM<sub>10</sub> nonattainment major NSR program as a surrogate to address the requirements of nonattainment major NSR for the PM<sub>2.5</sub> NAAQS. A major source in a nonattainment area is a source that emits or has the potential to emit one hundred (100) tons per year of any regulated pollutant. The source has a potential to emit PM<sub>10</sub> less than one hundred (100) tons per year. Therefore, assuming that PM<sub>10</sub> emissions represent PM<sub>2.5</sub> emissions. Nonattainment NSR does not apply.

#### **326 IAC 2-4.1(New Source Toxics Control)**

The source has the potential to emit less than 10 tons per year of a single HAP and less than 25 tons per year of a combination of HAPs. Therefore, 326 IAC 2-4.1 does not apply.

#### **326 IAC 2-6 (Emission Reporting)**

This source is located in Hendricks County, is not required to operate under a Part 70 permit, and emits less than five (5) tons per year of lead. Therefore, pursuant to 326 IAC 2-6-1(b), the source is only subject to additional information requests as provided in 436 IAC 2-6-5.

#### **326 IAC 5-1 (Opacity Limitations)**

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in the permit:

- (a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

#### 326 IAC 6-4 (Fugitive Dust Emissions)

The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions).

### **State Rule Applicability - Emergency Generators (EG1 and EG2)**

#### 326 IAC 2-9-14 (Internal Combustion Sources)

The emergency generators (EG1 and EG2) shall be granted a Source Specific Operating Agreement (SSOA) under 326 IAC 2-9-14(a)(2) provided that:

- (a) The following records are kept at the source:
  - (1) Hours operated for each combustion unit.
  - (2) Records of annual fuel usage for the internal combustion units.
  - (3) Routine maintenance records.
- (b) The fuel usage for the internal combustion units listed in this Source Specific Operating Agreement (SSOA) shall be limited to less than three hundred seventy-six and seventy-two hundredths (376.72) kilogallons of diesel fuel for every twelve (12) consecutive month period.

#### 326 IAC 7-1.1-1(Sulfur Dioxide Emissions)

326 IAC 7-1.1 (SO<sub>2</sub> Emissions Limitations) is not applicable to emergency generators EG1 and EG2 because each of these generators has a potential to emit sulfur dioxide of less than twenty-five (25) tons per year and 10 pounds per hour.

#### 326 IAC 8-1-6 (General Reduction Requirements for New Facilities)

The emergency generators EG1 and EG2 each have potential VOC emissions less than 25 tons per year. Therefore, EG1 and EG2 are not subject to the requirements of 326 IAC 8-1-6.

#### 326 IAC 9-1-2 (Carbon Monoxide Emission Requirements)

This source is not among the listed source categories in 326 IAC 9-1-2. Therefore, the emergency generators (EG1 and EG2) are not subject to the requirements of 326 IAC 9-1-2.

#### 326 IAC 10-1 (Nitrogen Oxide Emission Requirements)

This source is not located in Clark or Floyd County. Therefore, the emergency generators (EG1 and EG2) are not subject to the requirements of 326 IAC 10-1.

### **Conclusion**

The construction and operation of the emergency generators at this source shall be subject to the conditions of the attached New Source Construction Permit and SSOA No. 063-24937-00060.

**Appendix A: Emission Calculations**  
**Diesel fuel oil fired combustion**  
**>600 HP generator**  
**Emergency Generators (EG1 and EG2)**

**Company Name: BD**

**Address: 2350 Reeves Road, Plainfield, Indiana 46168**

**SSOA: 063-24937-00060**

**Reviewer: ERG/JR**

**Date: September 11, 2007**

Unit	Power Output (HP)
EG1	2220
EG2	2220
<b>Total</b>	<b>4440</b>

Potential Operating Hours (hrs/yr)	Weight % Sulfur (S)
500	0.5

	Pollutant					
	PM	PM10**	SO2	NOx	VOC	CO
>600 HP Emission Factor in lb/hp-hr*	0.0007	0.0007	0.004 8.09E-03S	0.024	0.000705	0.0055
EG1 Potential Emissions (lb/hr)	1.55	1.55	8.88	53.28	1.57	12.21
EG2 Potential Emissions (lb/hr)	1.55	1.55	8.88	53.28	1.57	12.21
<b>Total Potential Emissions (tons/yr)</b>	<b>0.78</b>	<b>0.78</b>	<b>4.44</b>	<b>26.6</b>	<b>0.78</b>	<b>6.11</b>

\* Diesel combustion AP-42 emission factors from AP-42, Section 3.4 (10/1996), Table 3.4-1.

\*\* Assume PM10 emissions are equal to PM emissions.

**Methodology**

EG1/EG2 Potential Emissions (lbs/hr) = Power Output (HP) / 2 x Emission Factor (lb/hp-hr)

Total Potential Emissions (tons/yr) = Power Output (HP) x Potential Operating Hours (hrs/yr) x Emission Factor (lb/hp-hr) x 1 ton/2000 lb