



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

TO: Interested Parties / Applicant

DATE: June 4, 2008

RE: Central Indiana Ethanol, LLC / 053-26544-00062

FROM: Matthew Stuckey, Branch Chief
Permits Branch
Office of Air Quality

Notice of Decision – Approval

Please be advised that on behalf of the Commissioner of the Department of Environmental Management, I have issued a decision regarding the enclosed matter. Pursuant to 326 IAC 2, this approval was effective immediately upon submittal of the application.

If you wish to challenge this decision, IC 4-21.5-3-7 requires that you file a petition for administrative review. This petition may include a request for stay of effectiveness and must be submitted to the Office of Environmental Adjudication, 100 North Senate Avenue, Government Center North, Suite N 501E, Indianapolis, IN 46204, **within eighteen (18) calendar days from the mailing of this notice**. The filing of a petition for administrative review is complete on the earliest of the following dates that apply to the filing:

- (1) the date the document is delivered to the Office of Environmental Adjudication (OEA);
- (2) the date of the postmark on the envelope containing the document, if the document is mailed to OEA by U.S. mail; or
- (3) The date on which the document is deposited with a private carrier, as shown by receipt issued by the carrier, if the document is sent to the OEA by private carrier.

The petition must include facts demonstrating that you are either the applicant, a person aggrieved or adversely affected by the decision or otherwise entitled to review by law. Please identify the permit, decision, or other order for which you seek review by permit number, name of the applicant, location, date of this notice and all of the following:

- (1) the name and address of the person making the request;
- (2) the interest of the person making the request;
- (3) identification of any persons represented by the person making the request;
- (4) the reasons, with particularity, for the request;
- (5) the issues, with particularity, proposed for considerations at any hearing; and
- (6) identification of the terms and conditions which, in the judgment of the person making the request, would be appropriate in the case in question to satisfy the requirements of the law governing documents of the type issued by the Commissioner.

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178. Callers from within Indiana may call toll-free at 1-800-451-6027, ext. 3-0178.

Enclosures
FNPER-AM.dot12/3/07



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels, Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

Mr. Gary Drook, General Manager
Central Indiana Ethanol, LLC
2955 W. Delphi Pike
Marion, IN 46952

June 4, 2008

Re: 053-26544-00062
First Administrative Amendment to
F053-21057-00062

Dear Mr. Drook:

Central Indiana Ethanol, LLC was issued a Federally Enforceable State Operating Permit (FESOP) No. F053-21057-00062 on August 4, 2005, for a stationary ethanol production operation located at 2955 W. Delphi Pike, Marion, Indiana 46952. On May 13, 2008, the Office of Air Quality (OAQ) received a letter from the source requesting to construct a new corn storage bin to replace two corn storage bins currently at the source and a change in the Authorized Individual. Pursuant to the provisions of 326 IAC 2-8-10, the permit is hereby administratively amended as follows with the deleted language as ~~strikeouts~~ and new language **bolded**.

1. The source is constructing a new corn storage bin, with a maximum capacity of 750,000 bushels to replace the two corn storage bins, units EU064 and EU065. The new corn storage bin (which is going to keep the emission ID: EU064) is of the same type and will comply with the same applicable requirements and permit terms and conditions as the existing bins. The new bin will have a smaller capacity than the total capacity of the two currently permitted bins, so the potential to emit will not increase. The addition of this unit to the permit is considered an administrative amendment pursuant to 326 IAC 2-8-10(a)(14). The addition of this unit will not cause the source's potential to emit to be greater than the threshold levels specified in 326 IAC 2-2 or 326 IAC 2-3. The change is being made to sections A.2(b)(6) and the same change to D.2(b)(6) which is not replicated here, D.1.6, D.1.8 and D.1.11.

A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-8-3(c)(3)]

This stationary source consists of the following stationary emission units and pollution control devices:

- (a) . . .
- (b) One (1) grain handling operation, constructed in 2006, controlled by baghouse CE001, exhausting through stack EP001, and consisting of the following:
 - (1) One (1) corn conveyor, identified as EU002, with a maximum throughput rate of 420 tons per hour.
 - (2) One (1) corn elevator, identified as EU003, with a maximum throughput rate of 420 tons per hour.
 - (3) Two (2) corn storage bins, identified as EU004 and EU005, each with a maximum capacity of 200,000 bushels and maximum throughput rate of 420 tons per hour.

- (4) One (1) scalper, identified as EU006, with a maximum throughput rate of 140 tons per hour.
- (5) One (1) surge bin, identified as EU007, with a maximum throughput rate of 140 tons per hour.
- (6) ~~Two (2)~~ **One (1)** corn storage bins, identified as EU064 and ~~EU065~~, **(approved for construction in 2008) each** with a maximum capacity of ~~425,000~~ **750,000** bushels and maximum throughput rate of 420 tons per hour.

...

D.1.6 Particulate Emission Limitations [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), particulate emissions from each of following operations shall not exceed the pound per hour limits listed in the table below:

Unit ID	Unit Description	Max. Throughput Rate (tons/hr)	Particulate Emission Limit (lbs/hr)
EU001	Each of the Corn Dump Pits	420	66.9
EU002	Corn Conveyor	420	66.9
EU003	Corn Elevator	420	66.9
EU004	Corn Storage Bin	420	66.9
EU005	Corn Storage Bin	420	66.9
EU006	Scalper	140	54.7
EU007	Surge Bin	140	54.7
EU010	Hammermill	140	54.7
EU011	Hammermill	140	54.7
EU040	DDGS Dump pit	101	51.4
EU041	DDGS Elevator	101	51.4
EU042	DDGS Conveyor	101	51.4
EU043	DDGS Load Spout	101	51.4
EU064	Corn Storage Bin	420	66.9
EU065	Corn Storage Bin	420	66.9

...

D.1.8 Particulate Control

- (a) In order to comply with Conditions D.1.5(a) and D.1.6, each of the following emission units shall be controlled by the associated baghouse, as listed in the table below, when these units are in operation:

Unit ID	Unit Description	Baghouse ID
EU001 - EU007, and EU064 and EU065	Grain Receiving and Handling Operations	CE001
EU010 and EU011	Hammermills	CE003
EU040 - EU043	DDGS Handling and Loadout Operations	CE008

...

D.1.11 Parametric Monitoring

The Permittee shall record the pressure drop across the baghouses used in conjunction with corn dump pits (EU001), the grain handling operation (EU002 through EU007, ~~and EU064, and EU065~~), the hammermills (EU010 and EU011), and the DDGS loadout operation (EU040 through EU043), at least once per day when these units are in operation. When for any one reading, the pressure drop across the baghouse is outside the normal range of 1.0 to 6.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances shall be considered a deviation from this permit.

The instrument used for determining the pressure shall comply with Section C - Instrument Specifications, of this permit, shall be subject to approval by IDEM, OAQ and shall be calibrated at least once every six (6) months.

2. IDEM no longer lists the name or title of the Authorized Individual (A.I.) in the permit document so no changes are being made to the permit but the information has been added to our database to change the contact person to Mr. Gary Drock, General Manager.

All other conditions of the permit shall remain unchanged and in effect. Attached please find the entire revised permit.

This decision is subject to the Indiana Administrative Orders and Procedures Act - IC 4-21.5-3-5. If you have any questions on this matter, please contact Janet Mobley, of my staff, at 317-234-5373 or 1-800-451-6027, and ask for extension 4-5373.

Sincerely/Original Signed By:

Iryn Calilung, Section Chief
Permits Branch
Office of Air Quality

IC/jm

Attachments: Updated Permit
and Revised Calculation Sheet

cc: File - Grant County
Grant County Health Department
U.S. EPA, Region V
Air Compliance Section
Compliance Data Section
Technical Support and Modeling
Permits Administrative and Development
Billing, Licensing and Training Section



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels, Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

FEDERALLY ENFORCEABLE STATE
OPERATING PERMIT (FESOP)
OFFICE OF AIR QUALITY

Central Indiana Ethanol, LLC
2955 W. Delphi Pike
Marion, Indiana 46952

(herein known as the Permittee) is hereby authorized to operate subject to the conditions contained herein, the source described in Section A (Source Summary) of this permit.

The Permittee must comply with all conditions of this permit. Noncompliance with any provision of this permit is grounds for enforcement action; permit termination, revocation and reissuance, or modification; and denial of a permit renewal application. It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. An emergency does constitute an affirmative defense in an enforcement action provided the Permittee complies with the applicable requirements set forth in Section B, Emergency Provisions.

This permit is issued in accordance with 326 IAC 2 and 40 CFR Part 70 Appendix A and contains the conditions and provisions specified in 326 IAC 2-8 as required by 42 U.S.C. 7401, et. seq. (Clean Air Act as amended by the 1990 Clean Air Act Amendments), 40 CFR Part 70.6, IC 13-15 and IC 13-17. This permit also addresses new source review requirements and is intended to fulfill the new source review procedures and permit revision requirements pursuant to 326 IAC 2-8-11.1, applicable to those conditions.

Indiana statutes from IC 13 and rules from 326 IAC, quoted in conditions in this permit, are those applicable at the time the permit was issued. The issuance or possession of this permit shall not alone constitute a defense against an alleged violation of any law, regulation or standard, except for the requirement to obtain a FESOP under 326 IAC 2-8.

Table with 2 columns: Issued by information (original signed by Paul Dubenetzky) and Issuance/Expiration Dates (August 4, 2005 and August 4, 2010).

First Significant Permit Revision No.: 053-22564-00062, issued July 20, 2006
Second Significant Permit Revision No.: 053-24415-00062, issued July 27, 2007

Table with 2 columns: Issued by information (Original Signed By: Iryn Calilung) and Issuance/Expiration Dates (June 4, 2008 and August 4, 2010).

TABLE OF CONTENTS

SECTION A	SOURCE SUMMARY	8
A.1	General Information [326 IAC 2-8-3(b)]	
A.2	Emission Units and Pollution Control Equipment Summary [326 IAC 2-8-3(c)(3)]	
A.3	Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-8-3(c)(3)(I)]	
A.4	FESOP Applicability [326 IAC 2-8-2]	
SECTION B	GENERAL CONDITIONS	12
B.1	Definitions [326 IAC 2-8-1]	
B.2	Permit Term [326 IAC 2-8-4(2)][326 IAC 2-1.1-9.5]	
B.3	Terms of Conditions [326 IAC 2-1.1-9.5]	
B.4	Enforceability [326 IAC 2-8-6]	
B.5	Severability [326 IAC 2-8-4(4)]	
B.6	Property Rights or Exclusive Privilege [326 IAC 2-8-4(5)(D)]	
B.7	Duty to Provide Information[326 IAC 2-8-4(5)(E)]	
B.8	Compliance Order Issuance [326 IAC 2-8-5(b)]	
B.8	Certification [326 IAC 2-8-3(d)] [326 IAC 2-8-4(3)(C)(i)] [326 IAC 2-8-5(1)]	
B.10	Annual Compliance Certification [326 IAC 2-8-5(a)(1)]	
B.11	Preventive Maintenance Plan [326 IAC 1-6-3][326 IAC 2-8-4(9)][326 IAC 2-8-5(a)(1)]	
B.12	Emergency Provisions [326 IAC 2-8-12]	
B.13	Prior Permits Superseded [326 IAC 2-1.1-9.5]	
B.14	Termination of Right to Operate [326 IAC 2-8-9][326 IAC 2-8-3(h)]	
B.15	Deviations from Permit Requirements and Conditions [326 IAC 2-8-4(3)(C)(ii)]	
B.16	Permit Modification, Reopening, Revocation and Reissuance, or Termination [326 IAC 2-8-4(5)(C)][326 IAC 2-8-7(a)][326 IAC 2-8-8]	
B.17	Permit Renewal [326 IAC 2-8-3(h)]	
B.18	Permit Amendment or Revision [326 IAC 2-8-10][326 IAC 2-8-11.1]	
B.19	Operational Flexibility [326 IAC 2-8-15][326 IAC 2-8-11.1]	
B.20	Source Modification Requirement [326 IAC 2-8-11.1]	
B.21	Inspection and Entry [326 IAC 2-8-5(a)(2)][IC 13-14-2-2][IC 13-17-3-2][IC 13-30-3-1]	
B.22	Transfer of Ownership or Operational Control [326 IAC 2-8-10]	
B.23	Annual Fee Payment [326 IAC 2-7-19][326 IAC 2-8-4(6)] [326 IAC 2-8-16] [326 IAC 2-1.1-7]	
B.24	Advanced Source Modification Approval [326 IAC 2-8-4(11)] [326 IAC 2-1.1-9]	
B.25	Credible Evidence [326 IAC 2-8-4(3)][326 IAC 2-8-5][62 FR 8314][326 IAC 1-1-6]	
SECTION C	SOURCE OPERATION CONDITIONS	21
	Emission Limitations and Standards [326 IAC 2-8-4(1)]	
C.1	Particulate Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) pounds per hour [326 IAC 6-3-2]	
C.2	Overall Source Limit [326 IAC 2-8] [326 IAC 2-2]	
C.3	Opacity [326 IAC 5-1]	
C.4	Open Burning [326 IAC 4-1][IC 13-17-9]	
C.5	Incineration [326 IAC 4-2] [326 IAC 9-1-2(3)]	
C.6	Fugitive Dust Emissions [326 IAC 6-4]	
C.7	Stack Height [326 IAC 1-7]	
C.8	Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61 Subpart M]	
	Testing Requirements [326 IAC 2-8-4(3)]	
C.9	Performance Testing [326 IAC 3-6]	
	Compliance Requirements [326 IAC 2-1.1-11]	
C.10	Compliance Requirements [326 IAC 2-1.1-11]	

TABLE OF CONTENTS (Continued)

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

- C.11 Compliance Monitoring [326 IAC 2-8-4(3)] [326 IAC 2-8-5(a)(1)]
- C.12 Monitoring Methods [326 IAC 3][40 CFR 60][40 CFR 63]
- C.13 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-8-4(3)] [326 IAC 2-8-5(1)]

Corrective Actions and Response Steps [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

- C.14 Risk Management Plan [326 IAC 2-8-4] [40 CFR 68]
- C.15 Response to Excursions or Exceedances [326 IAC 2-8-4][326 IAC 2-8-5]
- C.16 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-8-4] [326 IAC 2-8-5]

Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]

- C.17 General Record Keeping Requirements [326 IAC 2-8-4(3)][326 IAC 2-8-5]
- C.18 General Reporting Requirements [326 IAC 2-8-4(3)(C)] [326 IAC 2-1.1-11]

Stratospheric Ozone Protection

- C.19 Compliance with 40 CFR 82 and 326 IAC 22-1

SECTION D.1 FACILITY OPERATION CONDITIONS – Grain Receiving and Handling Processes	28
---	-----------

Construction Conditions

General Construction Conditions

- D.1.1 Permit No Defense
- D.1.2 Federally Enforceable State Operating Permit [326 IAC 2-8]

Effective Date of the Permit

- D.1.3 Effective Date of the Permit [IC 13-15-5-3]
- D.1.4 Modification to Construction Conditions [326 IAC 2]

Operation Conditions

Emission Limitations and Standards [326 IAC 2-8-4(1)]

- D.1.5 PM and PM10 Emissions [326 IAC 2-2] [326 IAC 2-8-4]
- D.1.6 Particulate Emission Limitations [326 IAC 6-3-2]
- D.1.7 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

Compliance Determination Requirements

- D.1.8 Particulate Control
- D.1.9 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11]

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

- D.1.10 Visible Emissions Notations
- D.1.11 Parametric Monitoring
- D.1.12 Broken or Failed Bag Detection

Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

- D.1.13 Record Keeping Requirements

TABLE OF CONTENTS (Continued)

SECTION D.2 FACILITY OPERATION CONDITIONS – Fermentation Process 33

Construction Conditions

General Construction Conditions

- D.2.1 Permit No Defense
- D.2.2 Federally Enforceable State Operating Permit [326 IAC 2-8]

Effective Date of the Permit

- D.2.3 Effective Date of the Permit [IC 13-15-5-3]
- D.2.4 Modification to Construction Conditions [326 IAC 2]

Operation Conditions

Emission Limitations and Standards [326 IAC 2-8-4(1)]

- D.2.5 VOC and HAP Emissions [326 IAC 2-2] [326 IAC 2-8-4] [326 IAC 2-4.1]
- D.2.6 VOC Emissions [326 IAC 8-5-6]
- D.2.7 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]
- D.2.8 Equipment Leaks of VOC [326 IAC 12][40 CFR 60, Subpart VV]
- D.2.9 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

Compliance Determination Requirements

- D.2.10 VOC and HAP Control
- D.2.11 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11] [326 IAC 8-5-6]

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

- D.2.12 Parametric Monitoring [326 IAC 8-5-6]
- D.2.13 Scrubber Detection

Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

- D.2.14 Record Keeping Requirements [326 IAC 8-5-6]

SECTION D.3 FACILITY OPERATION CONDITIONS – TO/HRSG System and DDGS Drying Process 36

Construction Conditions

General Construction Conditions

- D.3.1 Permit No Defense
- D.3.2 Federally Enforceable State Operating Permit [326 IAC 2-8]

Effective Date of the Permit

- D.3.3 Effective Date of the Permit [IC 13-15-5-3]
- D.3.4 Modification to Construction Conditions [326 IAC 2]

Operation Conditions

Emission Limitations and Standards [326 IAC 2-8-4(1)]

- D.3.5 FESOP Limits [326 IAC 2-2] [326 IAC 2-8-4] [326 IAC 2-4.1]
- D.3.6 VOC Emissions [326 IAC 8-5-6]
- D.3.7 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]
- D.3.8 NOx Emissions [326 IAC 12-1][40 CFR 60, Subpart Db]
- D.3.9 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]
- D.3.10 Equipment Leaks of VOC [326 IAC 12][40 CFR 60, Subpart VV]

TABLE OF CONTENTS (Continued)

- D.3.11 Particulate Emissions [326 IAC 6-2-4]
- D.3.12 Particulate Emission Limitations [326 IAC 6-3-2]
- D.3.13 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

Compliance Determination Requirements

- D.3.14 PM and PM10 Control
- D.3.15 VOC and HAP Control
- D.3.16 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11] [326 IAC 2-2] [40 CFR 60, Subpart Db] [326 IAC 8-5-6]

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

- D.3.17 Continuous Emissions Monitoring [326 IAC 3-5] [326 IAC 12] [40 CFR 60, Subpart Db]
- D.3.18 Visible Emissions Notations
- D.3.19 Thermal Oxidizer Temperature [326 IAC 8-5-6]
- D.3.20 Parametric Monitoring [326 IAC 8-5-6]

Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

- D.3.21 Record Keeping Requirements [326 IAC 8-5-6]
- D.3.22 Recordkeeping Requirements [40 CFR 60, Subpart Db] [326 IAC 12]
- D.3.23 Reporting Requirements [40 CFR 60, Subpart Db] [326 IAC 12]

SECTION D.4 FACILITY OPERATION CONDITIONS – DDGS Cooler 43

Construction Conditions

General Construction Conditions

- D.4.1 Permit No Defense
- D.4.2 Federally Enforceable State Operating Permit [326 IAC 2-8]

Effective Date of the Permit

- D.4.3 Effective Date of the Permit [IC 13-15-5-3]
- D.4.4 Modification to Construction Conditions [326 IAC 2]

Operation Conditions

Emission Limitations and Standards [326 IAC 2-8-4(1)]

- D.4.5 PM and PM10 Emissions [326 IAC 2-2] [326 IAC 2-8-4]
- D.4.6 Particulate Emission Limitations [326 IAC 6-3-2]
- D.4.7 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

Compliance Determination Requirements

- D.4.8 Particulate Control
- D.4.9 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11]

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

- D.4.10 Visible Emissions Notations
- D.4.11 Parametric Monitoring
- D.4.12 Broken or Failed Bag Detection

Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

- D.4.13 Record Keeping Requirements
- D.4.14 Reporting Requirements

TABLE OF CONTENTS (Continued)

SECTION D.5 FACILITY OPERATION CONDITIONS – Ethanol Loading Racks 47

Construction Conditions

General Construction Conditions

- D.5.1 Permit No Defense
- D.5.2 Federally Enforceable State Operating Permit [326 IAC 2-8]

Effective Date of the Permit

- D.5.3 Effective Date of the Permit [IC 13-15-5-3]
- D.5.4 Modification to Construction Conditions [326 IAC 2]

Operation Conditions

Emission Limitations and Standards [326 IAC 2-8-4(1)]

- D.5.5 FESOP Limits [326 IAC 2-2] [326 IAC 2-8-4] [326 IAC 2-4.1]
- D.5.6 VOC Emissions [326 IAC 8-5-6]
- D.5.7 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]
- D.5.8 Equipment Leaks of VOC [326 IAC 12][40 CFR 60, Subpart VV]
- D.5.9 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

Compliance Determination Requirements

- D.5.10 VOC and HAP Control
- D.5.11 Testing Requirements [326 IAC 2-8-5(a)(1), (4)][326 IAC 2-1.1-11][326 IAC 2-2] [326 IAC 8-5-6]

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

- D.5.12 Flare Pilot Flame [326 IAC 8-5-6]

Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

- D.5.13 Record Keeping Requirements [326 IAC 8-5-6]
- D.5.14 Reporting Requirements

SECTION D.6 FACILITY OPERATION CONDITIONS – Fire Pump and Biomethanator..... 50

Emission Limitations and Standards [326 IAC 2-8-4(1)]

- D.6.1 FESOP Limits [326 IAC 2-2] [326 IAC 2-8-4] [326 IAC 2-4.1]

Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

- D.6.2 Record Keeping Requirements
- D.6.3 Reporting Requirements

SECTION D.7 FACILITY OPERATION CONDITIONS – Storage Tanks 51

Emission Limitations and Standards [326 IAC 2-8-4(1)]

- D.7.1 Volatile Organic Compounds (VOC) [326 IAC 8-9]
- D.7.2 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]
- D.7.3 Storage Tanks [326 IAC 12][40 CFR 60, Subpart Kb]
- D.7.4 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

- D.7.5 Testing and Procedures [40 CFR 60, Subpart Kb] [326 IAC 12]

Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

- D.7.6 Record Keeping Requirements

TABLE OF CONTENTS (Continued)

SECTION E.1 40 CFR 60, Subpart VV - Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry 55

Emission Limitations and Standards [326 IAC 2-8-4(1)]

- E.1.1 Standards: Pumps in Light Liquid Service [326 IAC 12][40 CFR 60, Subpart VV]
- E.1.2 Standards: Pressure Relief Devices in Gas/Vapor Service [326 IAC 12][40 CFR 60, Subpart VV]
- E.1.3 Standards: Sampling Connection Systems [326 IAC 12][40 CFR 60, Subpart VV]
- E.1.4 Standards: Open-Ended Valves or Lines [326 IAC 12][40 CFR 60, Subpart VV]
- E.1.5 Standards: Valves in Gas/Vapor Service and in Light Liquid Service [326 IAC 12][40 CFR 60, Subpart VV]
- E.1.6 Standards: Pumps and Valves in Heavy Liquid Service, Pressure Relief Devices in Light Liquid or Heavy Liquid Service, and Connectors [326 IAC 12][40 CFR 60, Subpart VV]
- E.1.7 Standards: Closed Vent Systems and Control Devices [326 IAC 12][40 CFR 60, Subpart VV]
- E.1.8 Standards: Delay of Repair [326 IAC 12][40 CFR 60, Subpart VV]

Compliance Determination Requirements

- E.1.9 Test Methods and Procedures [326 IAC 12][40 CFR 60, Subpart VV]

Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

- E.1.10 Recordkeeping Requirements [326 IAC 12][40 CFR 60, Subpart VV]
- E.1.11 Reporting Requirements [326 IAC 12][40 CFR 60, Subpart VV]

Certification Form 68
Emergency Occurrence Form 69
Quarterly Report Form 71-75
Quarterly Deviation and Compliance Monitoring Report Form 76

SECTION A SOURCE SUMMARY

This permit is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ). The information describing the source contained in conditions A.1 through A.3 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this permit pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

A.1 General Information [326 IAC 2-8-3(b)]

The Permittee owns and operates a stationary ethanol production plant.

Source Address:	2955 W. Delphi Pike, Marion, Indiana 46952
Mailing Address:	2955 W. Delphi Pike, Marion, Indiana 46952
General Source Phone:	(765) 384-4001
SIC Code:	2869
County Location:	Grant County
Source Location Status:	Attainment for all other criteria pollutants
Source Status:	Federally Enforceable State Operating Permit (FESOP) Minor Source, under PSD Rules Minor Source, Section 112 of the Clean Air Act Not 1 of 28 Source Categories

A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-8-3(c)(3)]

This stationary source consists of the following stationary emission units and pollution control devices:

- (a) Three (3) corn dump pits, identified as EU001, constructed in 2006, each with a maximum throughput rate of 420 tons of corn per hour, controlled by baghouse CE001, and exhausting through stack EP001. This consists of two (2) truck dump pits and one (1) railcar dump pit.
- (b) One (1) grain handling operation, constructed in 2006, controlled by baghouse CE001, exhausting through stack EP001, and consisting of the following:
 - (1) One (1) corn conveyor, identified as EU002, with a maximum throughput rate of 420 tons per hour.
 - (2) One (1) corn elevator, identified as EU003, with a maximum throughput rate of 420 tons per hour.
 - (3) Two (2) corn storage bins, identified as EU004 and EU005, each with a maximum capacity of 200,000 bushels and maximum throughput rate of 420 tons per hour.
 - (4) One (1) scalper, identified as EU006, with a maximum throughput rate of 140 tons per hour.
 - (5) One (1) surge bin, identified as EU007, with a maximum throughput rate of 140 tons per hour.
 - (6) One (1) corn storage bin, identified as EU064, (approved for construction in 2008) with a maximum capacity of 750,000 bushels and maximum throughput rate of 420 tons per hour.
- (c) Two (2) hammermills, identified as EU010 and EU011, constructed in 2006, each with a maximum throughput rate of 140 tons of corn per hour, controlled by baghouse CE003, and exhausting through stack EP003.

- (d) One (1) fermentation process, constructed in 2006, with a maximum throughput rate of 7,060 gallons of ethanol per hour, controlled by CO₂ scrubber CE005, exhausting through stack EP005, and consisting of the following:
 - (1) Five (5) fermenters, identified as EU016, EU017, EU018, EU019, and EU057.
 - (2) One (1) beer well, identified as EU020.
- (e) One (1) thermal oxidizer with heat recovery steam generator (TO/HRSG) system, identified as CE007, constructed in 2006, with a maximum heat input capacity of 135 MMBtu/hr, using natural gas and process waste gases from the DDGS dryers as fuels, with emissions exhausted through stack EP007.
- (f) One (1) distillation process, constructed in 2006, with a maximum throughput rate of 6,850 gallons of ethanol per hour, controlled by TO/HRSG system CE007, exhausting through stack EP007, and consisting of the following:
 - (1) Two (2) slurry mixers, identified as EU049 and EU058.
 - (2) One (1) slurry tank, identified as EU050.
 - (3) Three (3) liquefaction tanks, identified as EU014, EU051, and EU059, each with a maximum capacity of 7,000 gallons per hour.
 - (4) One (1) cook tube, identified as EU052.
 - (5) One (1) flash tank, identified as EU053.
 - (6) One (1) yeast tank, identified as EU015.
 - (7) One (1) 190 proof condenser, identified as EU054.
 - (8) One (1) 200 proof condenser, identified as EU055.
 - (9) One (1) beer stripper, identified as EU021.
 - (10) One (1) side stripper, identified as EU022.
 - (11) One (1) rectifier, identified as EU023.
 - (12) Molecular sieve units, identified as EU024.
 - (13) Eight (8) evaporators, identified as EU025.
 - (14) Four (4) centrifuges, identified as EU026 through EU029.
- (g) Two (2) natural gas fired DDGS dryers, identified as EU035 and EU056, constructed in 2006, each with a maximum heat input rate of 45 MMBtu/hr and a maximum throughput rate of 34 tons of DDGS per hour, controlled by multiclone CE006, with emissions venting to TO/HRSG system CE007, and exhausting to stack EP007.
- (h) One (1) DDGS cooler, identified as EU036, constructed in 2006, with a maximum throughput rate of 34 tons/hr of DDGS, controlled by baghouse CE014, and exhausting to stack EP014.
- (i) One (1) DDGS loadout operation, constructed in 2006 with a maximum throughput rate of 101 tons per hour, controlled by baghouse CE008, exhausting to stack EP008, and consisting of the following:

- (1) One (1) DDGS dump pit, identified as EU040.
- (2) One (1) DDGS elevator, identified as EU041.
- (3) One (1) DDGS conveyor, identified as EU042.
- (4) One (1) DDGS load spout, identified as EU043.
- (j) One (1) ethanol loading rack for trucks, identified as EU045A, constructed in 2006, with a maximum throughput rate of 48,000 gallons per hour. The truck loading process is controlled by the enclosed flare CE009, which is fueled by natural gas and has a maximum heat input capacity of 10.0 MMBtu/hr, and exhausts through stack EP009.
- (k) One (1) ethanol loading rack for railcars, identified as EU045B, constructed in 2006, with a maximum throughput rate of 60,000 gallons per hour. Railcars are dedicated to carrying denatured ethanol.

A.3 Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-8-3(c)(3)(l)]

This stationary source also includes the following insignificant activities, as defined in 326 IAC 2-7-1(21):

- (a) Solvent recycling systems with batch capacity less than or equal to 100 gallons.
- (b) Forced and induced draft cooling tower system not regulated under a NESHAP.
- (c) Replacement or repair of electrostatic precipitators, bags in baghouses and filters in other air filtration equipment.
- (d) Heat exchanger cleaning and repair.
- (e) Process vessel degassing and cleaning to prepare for internal repairs.
- (f) Paved roads and parking lots with public access. [326 IAC 6-4]
- (g) Blowdown for any of the following: sight glass; boiler; compressors; pumps; and cooling tower.
- (h) Stationary fire pumps, including one (1) diesel fire pump, identified as EU034, constructed in 2006, with a maximum power output rate of 300 horsepower, and exhausting to stack EP006. [326 IAC 2-8-4]
- (i) Farm operations.
- (j) Other emission units, not regulated by a NESHAP, with PM₁₀, NO_x, and SO₂ emissions less than five (5) pounds per hour or twenty-five (25) pounds per day, CO emissions less than twenty-five (25) pounds per day, VOC emissions less than three (3) pounds per hour or fifteen (15) pounds per day, lead emissions less than six-tenths (0.6) tons per year or three and twenty-nine hundredths (3.29) pounds per day, and emitting greater than one (1) pound per day but less than five (5) pounds per day or one (1) ton per year of a single HAP, or emitting greater than one (1) pound per day but less than twelve and five tenths (12.5) pounds per day or two and five tenths (2.5) ton per year of any combination of HAPs:
 - (1) One (1) 190 proof tank, identified as T001, constructed in 2006, with a maximum capacity of 100,000 gallons. [40 CFR 60, Subpart Kb]
 - (2) One (1) 200 proof tank, identified as T002, constructed in 2006, with a maximum capacity of 100,000 gallons. [40 CFR 60, Subpart Kb]

- (3) One (1) denaturant tank, identified as T003, constructed in 2006, with a maximum capacity of 100,000 gallons. [40 CFR 60, Subpart Kb] [326 IAC 8-4-3]
- (4) Two (2) denatured ethanol tanks, identified as T004 and T005, constructed in 2006, each with a maximum capacity of 750,000 gallons. [40 CFR 60, Subpart Kb]
- (5) One (1) fuel additive tank, identified as T006, constructed in 2006, with a maximum storage capacity less than 2,300 gallons.
- (6) One (1) diesel storage tank, identified as T007, constructed in 2006, with a maximum storage capacity less than 1,000 gallons.
- (7) One (1) biomethanator, identified as EU048, constructed in 2006, controlled by 6.0 MMBtu/hr biomethanator flare CE013, and exhausting to stack EP013. [326 IAC 2-8-4]
- (8) One (1) corn oil separation unit, identified as EU061.
- (9) Two (2) corn oil storage tanks, identified as EU062 and EU063, each with a maximum capacity of 35,000 gallons.

A.4 FESOP Applicability [326 IAC 2-8-2]

This stationary source, otherwise required to have a Part 70 permit as described in 326 IAC 2-7-2(a), has applied to the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ) for a Federally Enforceable State Operating Permit (FESOP).

SECTION B GENERAL CONDITIONS

B.1 Definitions [326 IAC 2-8-1]

Terms in this permit shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, the applicable definitions found in the statutes or regulations (IC 13-11, 326 IAC 1-2, and 326 IAC 2-7) shall prevail.

B.2 Permit Term [326 IAC 2-8-4(2)] [326 IAC 2-1.1-9.5]

- (a) This permit F053-24415-00062 is issued for a fixed term of five (5) years from the issuance date of this permit, as determined in accordance with IC 4-21.5-3-5(f) and IC 13-15-5-3. Subsequent revisions, modifications, or amendments of this permit do not affect the expiration date of this permit.
- (b) If IDEM, OAQ, upon receiving a timely and complete renewal permit application, fails to issue or deny the permit renewal prior to the expiration date of this permit, this existing permit shall not expire and all terms and conditions shall continue in effect, until the renewal permit has been issued or denied.

B.3 Term of Conditions [326 IAC 2-1.1-9.5]

Notwithstanding the permit term of a permit to construct, a permit to operate, or a permit modification, any condition established in a permit issued pursuant to a permitting program approved in the state implementation plan shall remain in effect until:

- (a) the condition is modified in a subsequent permit action pursuant to Title I of the Clean Air Act; or
- (b) the emission unit to which the condition pertains permanently ceases operation.

B.4 Enforceability [326 IAC 2-8-6]

Unless otherwise stated, all terms and conditions in this permit, including any provisions designed to limit the source's potential to emit, are enforceable by IDEM, the United States Environmental Protection Agency (U.S. EPA) and by citizens in accordance with the Clean Air Act.

B.5 Severability [326 IAC 2-8-4(4)]

The provisions of this permit are severable; a determination that any portion of this permit is invalid shall not affect the validity of the remainder of the permit.

B.6 Property Rights or Exclusive Privilege [326 IAC 2-8-4(5)(D)]

This permit does not convey any property rights of any sort, or any exclusive privilege.

B.7 Duty to Provide Information [326 IAC 2-8-4(5)(E)]

- (a) The Permittee shall furnish to IDEM, OAQ, within a reasonable time, any information that IDEM, OAQ, may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The submittal by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1). Upon request, the Permittee shall also furnish to IDEM, OAQ, copies of records required to be kept by this permit.
- (b) For information furnished by the Permittee to IDEM, OAQ, the Permittee may include a claim of confidentiality in accordance with 326 IAC 17.1. When furnishing copies of requested records directly to U.S. EPA, the Permittee may assert a claim of confidentiality in accordance with 40 CFR 2, Subpart B.

B.8 Compliance Order Issuance [326 IAC 2-8-5(b)]

IDEM, OAQ may issue a compliance order to this Permittee upon discovery that this permit is in nonconformance with an applicable requirement. The order may require immediate compliance or contain a schedule for expeditious compliance with the applicable requirement.

B.9 Certification [326 IAC 2-8-3(d)] [326 IAC 2-8-4(3)(C)(i)] [326 IAC 2-8-5(1)]

- (a) Where specifically designated by this permit or required by an applicable requirement, any application form, report, or compliance certification submitted shall contain certification by an authorized individual of truth, accuracy, and completeness. This certification, shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
- (b) One (1) certification shall be included, using the attached Certification Form, with each submittal requiring certification. One (1) certification may cover multiple forms in one (1) submittal.
- (c) An authorized individual is defined at 326 IAC 2-1.1-1(1).

B.10 Annual Compliance Certification [326 IAC 2-8-5(a)(1)]

- (a) The Permittee shall annually submit a compliance certification report which addresses the status of the source's compliance with the terms and conditions contained in this permit, including emission limitations, standards, or work practices. The initial certification shall cover the time period from the date of final permit issuance through December 31 of the same year. All subsequent certifications shall cover the time period from January 1 to December 31 of the previous year, and shall be submitted in letter form no later than July 1 of each year to:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

- (b) The annual compliance certification report required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.
- (c) The annual compliance certification report shall include the following:
 - (1) The appropriate identification of each term or condition of this permit that is the basis of the certification;
 - (2) The compliance status;
 - (3) Whether compliance was continuous or intermittent;
 - (4) The methods used for determining the compliance status of the source, currently and over the reporting period consistent with 326 IAC 2-8-4(3); and
 - (5) Such other facts as specified in Sections D of this permit, IDEM, OAQ, may require to determine the compliance status of the source.

The submittal by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

B.11 Preventive Maintenance Plan [326 IAC 1-6-3] [326 IAC 2-8-4(9)] [326 IAC 2-8-5(a)(1)]

- (a) If required by specific condition(s) in Section D of this permit, the Permittee shall prepare and maintain Preventive Maintenance Plans (PMPs) within ninety (90) days after issuance of this permit, including the following information on each facility:
 - (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;

- (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
- (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

If due to circumstances beyond the Permittee's control, the PMPs cannot be prepared and maintained within the above time frame, the Permittee may extend the date an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

The PMP extension notification does not require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (b) A copy of the PMPs shall be submitted to IDEM, OAQ, upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. IDEM, OAQ, may require the Permittee to revise its PMPs whenever lack of proper maintenance causes or is the primary contributor to an exceedance of any limitation on emissions or potential to emit. The PMPs do not require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (c) To the extent the Permittee is required by 40 CFR Part 60/63 to have an Operation, Maintenance, and Monitoring (OMM) Plan for a unit, such Plan is deemed to satisfy the PMP requirements of 326 IAC 1-6-3 for that unit.

B.12 Emergency Provisions [326 IAC 2-8-12]

- (a) An emergency, as defined in 326 IAC 2-7-1(12), is not an affirmative defense for an action brought for noncompliance with a federal or state health-based emission limitation, except as provided in 326 IAC 2-8-12.
- (b) An emergency, as defined in 326 IAC 2-7-1(12), constitutes an affirmative defense to an action brought for noncompliance with a health-based or technology-based emission limitation if the affirmative defense of an emergency is demonstrated through properly signed, contemporaneous operating logs or other relevant evidence that describe the following:
 - (1) An emergency occurred and the Permittee can, to the extent possible, identify the causes of the emergency;
 - (2) The permitted facility was at the time being properly operated;
 - (3) During the period of an emergency, the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards or other requirements in this permit;
 - (4) For each emergency lasting one (1) hour or more, the Permittee notified IDEM, OAQ Indianapolis Offices, within four (4) daytime business hours after the beginning of the emergency, or after the emergency was discovered or reasonably should have been discovered;

Telephone Number: 1-800-451-6027 (ask for Office of Air Quality, Compliance Section) or,
Telephone Number: 317-233-5674 (ask for Compliance Section)

Facsimile Number: 317-233-5967
Indianapolis Offices: 317-232-8603

- (5) For each emergency lasting one (1) hour or more, the Permittee submitted the attached Emergency Occurrence Report Form or its equivalent, either by mail or facsimile to:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

within two (2) working days of the time when emission limitations were exceeded due to the emergency.

The notice fulfills the requirement of 326 IAC 2-8-4(3)(C)(ii) and must contain the following:

- (A) A description of the emergency;
- (B) Any steps taken to mitigate the emissions; and
- (C) Corrective actions taken.

The notification which shall be submitted by the Permittee does not require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (6) The Permittee immediately took all reasonable steps to correct the emergency.
- (c) In any enforcement proceeding, the Permittee seeking to establish the occurrence of an emergency has the burden of proof.
 - (d) This emergency provision supersedes 326 IAC 1-6 (Malfunctions). This permit condition is in addition to any emergency or upset provision contained in any applicable requirement.
 - (e) The Permittee seeking to establish the occurrence of an emergency shall make records available upon request to ensure that failure to implement a PMP did not cause or contribute to an exceedance of any limitations on emissions. However, IDEM, OAQ may require that the Preventive Maintenance Plans required under 326 IAC 2-8-3(c)(6) be revised in response to an emergency.
 - (f) Failure to notify IDEM, OAQ by telephone or facsimile of an emergency lasting more than one (1) hour in accordance with (b)(4) and (5) of this condition shall constitute a violation of 326 IAC 2-8 and any other applicable rules.
 - (g) Operations may continue during an emergency only if the following conditions are met:
 - (1) If the emergency situation causes a deviation from a technology-based limit, the Permittee may continue to operate the affected emitting facilities during the emergency provided the Permittee immediately takes all reasonable steps to correct the emergency and minimize emissions.
 - (2) If an emergency situation causes a deviation from a health-based limit, the Permittee may not continue to operate the affected emissions facilities unless:
 - (A) The Permittee immediately takes all reasonable steps to correct the emergency situation and to minimize emissions; and

- (B) Continued operation of the facilities is necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw material of substantial economic value.

Any operations shall continue no longer than the minimum time required to prevent the situations identified in (g)(2)(B) of this condition.

- (h) The Permittee shall include all emergencies in the Quarterly Deviation and Compliance Monitoring Report.

B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5]

- (a) All terms and conditions of permits established prior to 181-24072-00046 and issued pursuant to permitting programs approved into the state implementation plan have been either:
- (1) incorporated as originally stated,
 - (2) revised, or
 - (3) deleted.
- (b) All previous registrations and permits are superseded by this permit.

B.14 Termination of Right to Operate [326 IAC 2-8-9][326 IAC 2-8-3(h)]

The Permittee's right to operate this source terminates with the expiration of this permit unless a timely and complete renewal application is submitted at least nine (9) months prior to the date of expiration of the source's existing permit, consistent with 326 IAC 2-8-3(h) and 326 IAC 2-8-9.

B.15 Deviations from Permit Requirements and Conditions [326 IAC 2-8-4(3)(C)(ii)]

- (a) Deviations from any permit requirements (for emergencies see Section B - Emergency Provision), the probable cause of such deviations, and any response steps or preventive measures taken shall be reported to:

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

using the attached Quarterly Deviation and Compliance Monitoring Report, or its equivalent. A deviation required to be reported pursuant to an applicable requirement that exists independent of this permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report.

The Quarterly Deviation and Compliance Monitoring Report does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (b) A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit.

B.16 Permit Modification, Reopening, Revocation and Reissuance, or Termination [326 IAC 2-8-4(5)(C)] [326 IAC 2-8-7(a)] [326 IAC 2-8-8]

- (a) This permit may be modified, reopened, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a Federally Enforceable State Operating Permit (FESOP) modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any condition of this permit. [326 IAC 2-8-4(5)(C)] The notification by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (b) This permit shall be reopened and revised under any of the circumstances listed in IC 13-15-7-2 or if IDEM, OAQ determines any of the following:
 - (1) That this permit contains a material mistake.
 - (2) That inaccurate statements were made in establishing the emissions standards or other terms or conditions.
 - (3) That this permit must be revised or revoked to assure compliance with an applicable requirement. [326 IAC 2-8-8(a)]
- (c) Proceedings by IDEM, OAQ to reopen and revise this permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of this permit for which cause to reopen exists. Such reopening and revision shall be made as expeditiously as practicable. [326 IAC 2-8-8(b)]
- (d) The reopening and revision of this permit, under 326 IAC 2-8-8(a), shall not be initiated before notice of such intent is provided to the Permittee by IDEM, OAQ at least thirty (30) days in advance of the date this permit is to be reopened, except that IDEM, OAQ may provide a shorter time period in the case of an emergency. [326 IAC 2-8-8(c)]

B.17 Permit Renewal [326 IAC 2-8-3(h)]

- (a) The application for renewal shall be submitted using the application form or forms prescribed by IDEM, OAQ and shall include the information specified in 326 IAC 2-8-3. Such information shall be included in the application for each emission unit at this source, except those emission units included on the trivial or insignificant activities list contained in 326 IAC 2-7-1(21) and 326 IAC 2-7-1(40). The renewal application does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

Request for renewal shall be submitted to:

Indiana Department of Environmental Management
Permits Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

- (b) A timely renewal application is one that is:
 - (1) Submitted at least nine (9) months prior to the date of the expiration of this permit; and
 - (2) If the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
- (c) If the Permittee submits a timely and complete application for renewal of this permit, the source's failure to have a permit is not a violation of 326 IAC 2-8 until IDEM, OAQ takes final action on the renewal application, except that this protection shall cease to apply if, subsequent to the completeness determination, the Permittee fails to submit by the deadline specified in writing by IDEM, OAQ any additional information identified as being needed to process the application.

B.18 Permit Amendment or Revision [326 IAC 2-8-10] [326 IAC 2-8-11.1]

- (a) Permit amendments and revisions are governed by the requirements of 326 IAC 2-8-10 or 326 IAC 2-8-11.1 whenever the Permittee seeks to amend or modify this permit.

- (b) Any application requesting an amendment or modification of this permit shall be submitted to:

Indiana Department of Environmental Management
Permits Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

Any such application shall be certified by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-8-10(b)(3)]
- (d) No permit amendment or modification is required for the addition, operation or removal of a nonroad engine, as defined in 40 CFR 89.2.

B.19 Operational Flexibility [326 IAC 2-8-15] [326 IAC 2-8-11.1]

- (a) The Permittee may make any change or changes at the source that are described in 326 IAC 2-8-15(b) through (d) without a prior permit revision, if each of the following conditions is met:

- (1) The changes are not modifications under any provision of Title I of the Clean Air Act;
- (2) Any approval required by 326 IAC 2-8-11.1 has been obtained;
- (3) The changes do not result in emissions which exceed the limitations provided in this permit (whether expressed herein as a rate of emissions or in terms of total emissions);
- (4) The Permittee notifies the:

Indiana Department of Environmental Management
Permits Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V
Air and Radiation Division, Regulation Development Branch - Indiana (AR-18J)
77 West Jackson Boulevard
Chicago, Illinois 60604-3590

in advance of the change by written notification at least ten (10) days in advance of the proposed change. The Permittee shall attach every such notice to the Permittee's copy of this permit; and

- (5) The Permittee maintains records on-site, on a rolling five (5) year basis, which document, all such changes and emission trades that are subject to 326 IAC 2-8-15(b) through (d). The Permittee shall make such records available, upon reasonable request, for public review.

Such records shall consist of all information required to be submitted to IDEM, OAQ in the notices specified in 326 IAC 2-8-15(b)(2), (c)(1), and (d).

- (b) Emission Trades [326 IAC 2-8-15(c)]
The Permittee may trade emissions increases and decreases at the source, where the applicable SIP provides for such emission trades without requiring a permit revision, subject to the constraints of Section (a) of this condition and those in 326 IAC 2-8-15(c).
- (c) Alternative Operating Scenarios [326 IAC 2-8-15(d)]
The Permittee may make changes at the source within the range of alternative operating scenarios that are described in the terms and conditions of this permit in accordance with 326 IAC 2-8-4(7). No prior notification of IDEM, OAQ or U.S. EPA is required.
- (d) Backup fuel switches specifically addressed in, and limited under, Section D of this permit shall not be considered alternative operating scenarios. Therefore, the notification requirements of part (a) of this condition do not apply.

B.20 Source Modification Requirement [326 IAC 2-8-11.1]

A modification, construction, or reconstruction is governed by the requirements of 326 IAC 2 and 326 IAC 2-8-11.1.

B.21 Inspection and Entry [326 IAC 2-8-5(a)(2)] [IC 13-14-2-2] [IC 13-17-3-2] [IC 13-30-3-1]

Upon presentation of proper identification cards, credentials, and other documents as may be required by law, and subject to the Permittee's right under all applicable laws and regulations to assert that the information collected by the agency is confidential and entitled to be treated as such, the Permittee shall allow IDEM, OAQ, U.S. EPA, or an authorized representative to perform the following:

- (a) Enter upon the Permittee's premises where a FESOP source is located, or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
- (b) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- (c) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, inspect, at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit;
- (d) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with this permit or applicable requirements; and
- (e) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, utilize any photographic, recording, testing, monitoring, or other equipment for the purpose of assuring compliance with this permit or applicable requirements.

B.22 Transfer of Ownership or Operational Control [326 IAC 2-8-10]

- (a) The Permittee must comply with the requirements of 326 IAC 2-8-10 whenever the Permittee seeks to change the ownership or operational control of the source and no other change in the permit is necessary.
- (b) Any application requesting a change in the ownership or operational control of the source shall contain a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new Permittee. The application shall be submitted to:

Indiana Department of Environmental Management
Permits Branch, Office of Air Quality

100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

The application which shall be submitted by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-8-10(b)(3)]

B.23 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-8-4(6)] [326 IAC 2-8-16] [326 IAC 2-1.1-7]

- (a) The Permittee shall pay annual fees to IDEM, OAQ, within thirty (30) calendar days of receipt of a billing. Pursuant to 326 IAC 2-7-19(b), if the Permittee does not receive a bill from IDEM, OAQ the applicable fee is due April 1 of each year.
- (b) Failure to pay may result in administrative enforcement action, or revocation of this permit.
- (c) The Permittee may call the following telephone numbers: 1-800-451-6027 or 317-233-4230 (ask for OAQ, Billing, Licensing, and Training Section), to determine the appropriate permit fee.

B.24 Advanced Source Modification Approval [326 IAC 2-8-4(11)] [326 IAC 2-1.1-9]

- (a) The requirements to obtain a permit revision under 326 IAC 2-8-11.1 are satisfied by this permit for the proposed emission units, control equipment or insignificant activities in Sections A.2 and A.3.
- (b) Pursuant to 326 IAC 2-1.1-9 any permit authorizing construction may be revoked if construction of the emission unit has not commenced within eighteen (18) months from the date of issuance of the permit, or if during the construction work is suspended for a continuous period of one (1) year or more.

B.25 Credible Evidence [326 IAC 2-8-4(3)] [326 IAC 2-8-5] [62 FR 8314] [326 IAC 1-1-6]

For the purpose of submitting compliance certifications or establishing whether or not the Permittee has violated or is in violation of any condition of this permit, nothing in this permit shall preclude the use, including the exclusive use, of any credible evidence or information relevant to whether the Permittee would have been in compliance with the condition of this permit if the appropriate performance or compliance test or procedure had been performed.

SECTION C SOURCE OPERATION CONDITIONS

Entire Source

Emissions Limitations and Standards [326 IAC 2-8-4(1)]

C.1 Particulate Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2(e)(2), particulate emissions from any process not exempt under 326 IAC 6-3-1(b) or (c), and which has a maximum process weight rate less than 100 pounds per hour and the methods in 326 IAC 6-3-2(b) through (d) do not apply shall not exceed 0.551 pounds per hour.

C.2 Overall Source Limit [326 IAC 2-8] [326 IAC 2-2]

The purpose of this permit is to limit this source's potential to emit to less than major source levels for the purpose of Section 502(a) of the Clean Air Act.

(a) Pursuant to 326 IAC 2-8:

- (1) The potential to emit any regulated pollutant, except particulate matter (PM), from the entire source shall be limited to less than one-hundred (100) tons per twelve (12) consecutive month period. This limitation shall also make the requirements of 326 IAC 2-2 (Prevention of Significant Deterioration (PSD)) not applicable;
- (2) The potential to emit any individual hazardous air pollutant (HAP) from the entire source shall be limited to less than ten (10) tons per twelve (12) consecutive month period; and
- (3) The potential to emit any combination of HAPs from the entire source shall be limited to less than twenty-five (25) tons per twelve (12) consecutive month period.

(b) The potential to emit particulate matter (PM) from the entire source shall be limited to less than two hundred fifty (250) tons per twelve (12) consecutive month period. This limitation shall also make the requirements of 326 IAC 2-2 (Prevention of Significant Deterioration (PSD)) not applicable.

(c) This condition shall include all emission points at this source including those that are insignificant as defined in 326 IAC 2-7-1(21). The source shall be allowed to add insignificant activities not already listed in this permit, provided the source's potential to emit does not exceed the above specified limits.

(d) Section D of this permit contains independently enforceable provisions to satisfy this requirement.

C.3 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

- (a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A,

Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

C.4 Open Burning [326 IAC 4-1] [IC 13-17-9]

The Permittee shall not open burn any material except as provided in 326 IAC 4-1-3, 326 IAC 4-1-4 or 326 IAC 4-1-6. The previous sentence notwithstanding, the Permittee may open burn in accordance with an open burning approval issued by the Commissioner under 326 IAC 4-1-4.1.

C.5 Incineration [326 IAC 4-2] [326 IAC 9-1-2(3)]

The Permittee shall not operate an incinerator or incinerate any waste or refuse except as provided in 326 IAC 4-2 and 326 IAC 9-1-2.

C.6 Fugitive Dust Emissions [326 IAC 6-4]

The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions).

C.7 Stack Height [326 IAC 1-7]

The Permittee shall comply with the applicable provisions of 326 IAC 1-7 (Stack Height Provisions), for all exhaust stacks through which a potential (before controls) of twenty-five (25) tons per year or more of particulate matter or sulfur dioxide is emitted.

C.8 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

- (a) Notification requirements apply to each owner or operator. If the combined amount of regulated asbestos containing material (RACM) to be stripped, removed or disturbed is at least 260 linear feet on pipes or 160 square feet on other facility components, or at least thirty-five (35) cubic feet on all facility components, then the notification requirements of 326 IAC 14-10-3 are mandatory. All demolition projects require notification whether or not asbestos is present.
- (b) The Permittee shall ensure that a written notification is sent on a form provided by the Commissioner at least ten (10) working days before asbestos stripping or removal work or before demolition begins, per 326 IAC 14-10-3, and shall update such notice as necessary, including, but not limited to the following:
- (1) When the amount of affected asbestos containing material increases or decreases by at least twenty percent (20%); or
 - (2) If there is a change in the following:
 - (A) Asbestos removal or demolition start date;
 - (B) Removal or demolition contractor; or
 - (C) Waste disposal site.
- (c) The Permittee shall ensure that the notice is postmarked or delivered according to the guidelines set forth in 326 IAC 14-10-3(2).
- (d) The notice to be submitted shall include the information enumerated in 326 IAC 14-10-3(3).

All required notifications shall be submitted to:

Indiana Department of Environmental Management
Asbestos Section, Office of Air Quality
100 North Senate Avenue
MC 61-52 IGCN 1003
Indianapolis, Indiana 46204-2251

The notice shall include a signed certification from the owner or operator that the information provided in this notification is correct and that only Indiana licensed workers and project supervisors will be used to implement the asbestos removal project. The notifications do not require a certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (e) **Procedures for Asbestos Emission Control**
The Permittee shall comply with the applicable emission control procedures in 326 IAC 14-10-4 and 40 CFR 61.145(c). Per 326 IAC 14-10-1, emission control requirements are applicable for any removal or disturbance of RACM greater than three (3) linear feet on pipes or three (3) square feet on any other facility components or a total of at least 0.75 cubic feet on all facility components.
- (f) **Demolition and renovation**
The Permittee shall thoroughly inspect the affected facility or part of the facility where the demolition or renovation will occur for the presence of asbestos pursuant to 40 CFR 61.145(a).
- (g) **Indiana Accredited Asbestos Inspector**
The Permittee shall comply with 326 IAC 14-10-1(a) that requires the owner or operator, prior to a renovation/demolition, to use an Indiana Accredited Asbestos Inspector to thoroughly inspect the affected portion of the facility for the presence of asbestos.

Testing Requirements [326 IAC 2-8-4(3)]

C.9 Performance Testing [326 IAC 3-6]

- (a) All testing shall be performed according to the provisions of 326 IAC 3-6 (Source Sampling Procedures), except as provided elsewhere in this permit, utilizing any applicable procedures and analysis methods specified in 40 CFR 51, 40 CFR 60, 40 CFR 61, 40 CFR 63, 40 CFR 75, or other procedures approved by IDEM, OAQ.

A test protocol, except as provided elsewhere in this permit, shall be submitted to:

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

no later than thirty-five (35) days prior to the intended test date. The protocol submitted by the Permittee does not require certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (b) The Permittee shall notify IDEM, OAQ of the actual test date at least fourteen (14) days prior to the actual test date. The notification submitted by the Permittee does not require certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (c) Pursuant to 326 IAC 3-6-4(b), all test reports must be received by IDEM, OAQ not later than forty-five (45) days after the completion of the testing. An extension may be granted by IDEM, OAQ, if the Permittee submits to IDEM, OAQ, a reasonable written explanation not later than five (5) days prior to the end of the initial forty-five (45) day period.

Compliance Requirements [326 IAC 2-1.1-11]

C.10 Compliance Requirements [326 IAC 2-1.1-11]

The commissioner may require stack testing, monitoring, or reporting at any time to assure compliance with all applicable requirements by issuing an order under 326 IAC 2-1.1-11. Any

monitoring or testing shall be performed in accordance with 326 IAC 3 or other methods approved by the commissioner or the U. S. EPA.

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

C.11 Compliance Monitoring [326 IAC 2-8-4(3)] [326 IAC 2-8-5(a)(1)]

Unless otherwise specified in this permit, all monitoring and record keeping requirements not already legally required shall be implemented within ninety (90) days of permit issuance. If required by Section D, the Permittee shall be responsible for installing any necessary equipment and initiating any required monitoring related to that equipment. If due to circumstances beyond its control, that equipment cannot be installed and operated within ninety (90) days, the Permittee may extend the compliance schedule related to the equipment for an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

in writing, prior to the end of the initial ninety (90) day compliance schedule with full justification of the reasons for inability to meet this date.

The notification which shall be submitted by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

Unless otherwise specified in the approval for the new emissions unit, compliance monitoring for new emission units or emission units added through a permit revision shall be implemented when operation begins.

C.12 Monitoring Methods [326 IAC 3] [40 CFR 60] [40 CFR 63]

Any monitoring or testing required by Section D of this permit shall be performed according to the provisions of 326 IAC 3, 40 CFR 60, Appendix A, 40 CFR 60, Appendix B, 40 CFR 63, or other approved methods as specified in this permit.

C.13 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-8-4(3)] [326 IAC 2-8-5(1)]

- (a) When required by any condition of this permit, an analog instrument used to measure a parameter related to the operation of an air pollution control device shall have a scale such that the expected maximum reading shall be no less than twenty percent (20%) of full scale.
- (b) The Permittee may request that the IDEM, OAQ approve the use of an instrument that does not meet the above specifications provided the Permittee can demonstrate that an alternative instrument specification will adequately ensure compliance with permit conditions requiring the measurement of the parameters.

Corrective Actions and Response Steps [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

C.14 Risk Management Plan [326 IAC 2-8-4] [40 CFR 68]

If a regulated substance, as defined in 40 CFR 68, is present at a source in more than a threshold quantity, the Permittee must comply with the applicable requirements of 40 CFR 68.

C.15 Response to Excursions or Exceedances [326 IAC 2-8-4] [326 IAC 2-8-5]

- (a) Upon detecting an excursion or exceedance, the Permittee shall restore operation of the emissions unit (including any control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing emissions.

- (b) The response shall include minimizing the period of any startup, shutdown or malfunction and taking any necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of an excursion or exceedance (other than those caused by excused startup or shutdown conditions). Corrective actions may include, but are not limited to, the following:
 - (1) initial inspection and evaluation;
 - (2) recording that operations returned to normal without operator action (such as through response by a computerized distribution control system); or
 - (3) any necessary follow-up actions to return operation to within the indicator range, designated condition, or below the applicable emission limitation or standard, as applicable.
- (c) A determination of whether the Permittee has used acceptable procedures in response to an excursion or exceedance will be based on information available, which may include, but is not limited to, the following:
 - (1) monitoring results;
 - (2) review of operation and maintenance procedures and records;
 - (3) inspection of the control device, associated capture system, and the process.
- (d) Failure to take reasonable response steps shall be considered a deviation from the permit.
- (e) The Permittee shall maintain the following records:
 - (1) monitoring data; and
 - (2) monitor performance data, if applicable.
 - (3) corrective actions taken.

C.16 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-8-4][326 IAC 2-8-5]

- (a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this permit exceed the level specified in any condition of this permit, the Permittee shall take appropriate response actions. The Permittee shall submit a description of these response actions to IDEM, OAQ, within thirty (30) days of receipt of the test results. The Permittee shall take appropriate action to minimize excess emissions from the affected facility while the response actions are being implemented.
- (b) A retest to demonstrate compliance shall be performed within one hundred twenty (120) days of receipt of the original test results. Should the Permittee demonstrate to IDEM, OAQ that retesting in one hundred and twenty (120) days is not practicable, IDEM, OAQ may extend the retesting deadline.
- (c) IDEM, OAQ reserves the authority to take any actions allowed under law in response to noncompliant stack tests.

The response action documents submitted pursuant to this condition do require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]

C.17 General Record Keeping Requirements [326 IAC 2-8-4(3)] [326 IAC 2-8-5]

- (a) Records of all required monitoring data, reports and support information required by this permit shall be retained for a period of at least five (5) years from the date of monitoring sample, measurement, report, or application. These records shall be physically present or electronically accessible at the source location for a minimum of three (3) years. The records may be stored elsewhere for the remaining two (2) years as long as they are available upon request. If the Commissioner makes a request for records to the Permittee, the Permittee shall furnish the records to the Commissioner within a reasonable time.
- (b) Unless otherwise specified in this permit, all record keeping requirements not already legally required shall be implemented within ninety (90) days of permit issuance.

C.18 General Reporting Requirements [326 IAC 2-8-4(3)(C)] [326 IAC 2-1.1-11]

- (a) The source shall submit the attached Quarterly Deviation and Compliance Monitoring Report or its equivalent. Any deviation from permit requirements, the date(s) of each deviation, the cause of the deviation, and the response steps taken must be reported. This report shall be submitted within thirty (30) days of the end of the reporting period. The Quarterly Deviation and Compliance Monitoring Report shall include the certification by an "authorized individual" as defined by 326 IAC2-1.1-1(1).
- (b) The report required in (a) of this condition and reports required by conditions in Section D of this permit shall be submitted to:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251
- (c) Unless otherwise specified in this permit, any notice, report, or other submission required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.
- (d) Unless otherwise specified in this permit, all reports required in Section D of this permit shall be submitted within thirty (30) days of the end of the reporting period. All reports do require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (e) The first report covered the period commencing on the date of issuance of the original FESOP and ended on the last day of the reporting period. All subsequent reporting periods shall be based on calendar years, unless otherwise specified in this permit. For the purpose of this permit "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.

Stratospheric Ozone Protection

C.19 Compliance with 40 CFR 82 and 326 IAC 22-1

Pursuant to 40 CFR 82 (Protection of Stratospheric Ozone), Subpart F, except as provided for motor vehicle air conditioners in Subpart B, the Permittee shall comply with the standards for recycling and emissions reduction:

- (a) Persons opening appliances for maintenance, service, repair or disposal must comply with the required practices pursuant to 40 CFR 82.156

- (b) Equipment used during the maintenance, service, repair or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to 40 CFR 82.158.
- (c) Persons performing maintenance, service, repair or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161.

SECTION D.1 FACILITY OPERATION CONDITIONS – Grain Receiving and Handling Processes

Facility Description [326 IAC 2-8-4(10)] – Grain Receiving and Handling Processes:

- (a) Three (3) corn dump pits, identified as EU001, constructed in 2006, each with a maximum throughput rate of 420 tons of corn per hour, controlled by baghouse CE001, and exhausting through stack EP001. This consists of two (2) truck dump pits and one (1) railcar dump pit.
- (b) One (1) grain handling operation, constructed in 2006, controlled by baghouse CE001, exhausting through stack EP001, and consisting of the following:
 - (1) One (1) corn conveyor, identified as EU002, with a maximum throughput rate of 420 tons per hour.
 - (2) One (1) corn elevator, identified as EU003, with a maximum throughput rate of 420 tons per hour.
 - (3) Two (2) corn storage bins, identified as EU004 and EU005, each with a maximum capacity of 200,000 bushels and maximum throughput rate of 420 tons per hour.
 - (4) One (1) scalper, identified as EU006, with a maximum throughput rate of 140 tons per hour.
 - (5) One (1) surge bin, identified as EU007, with a maximum throughput rate of 140 tons per hour.
 - (6) One (1) corn storage bin, identified as EU064, (approved for construction in 2008) with a maximum capacity of 750,000 bushels and maximum throughput rate of 420 tons per hour.
- (c) Two (2) hammermills, identified as EU010 and EU011, constructed in 2006, each with a maximum throughput rate of 140 tons of corn per hour, controlled by baghouse CE003, and exhausting through stack EP003.
- (i) One (1) DDGS loadout operation, constructed in 2006 with a maximum throughput rate of 101 tons per hour, controlled by baghouse CE008, exhausting to stack EP008, and consisting of the following:
 - (1) One (1) DDGS dump pit, identified as EU040.
 - (2) One (1) DDGS elevator, identified as EU041.
 - (3) One (1) DDGS conveyor, identified as EU042.
 - (4) One (1) DDGS load spout, identified as EU043.

Insignificant Activity:

- (f) Paved roads and parking lots with public access. [326 IAC 6-4]

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

THIS SECTION OF THE PERMIT IS BEING ISSUED UNDER THE PROVISIONS OF 326 IAC 2-1 AND 326 IAC 2-8-11.1, WITH CONDITIONS LISTED BELOW.

Construction Conditions

General Construction Conditions

D.1.1 Permit No Defense

This permit to construct does not relieve the Permittee of the responsibility to comply with the provisions of the Indiana Environmental Management Law (IC 13-11 through 13-20; 13-22 through 13-25; and 13-30), the Air Pollution Control Law (IC 13-17) and the rules promulgated thereunder, as well as other applicable local, state, and federal requirements.

D.1.2 Federally Enforceable State Operating Permit [326 IAC 2-8]

The attached Affidavit of Construction shall be submitted to the Office of Air Quality (OAQ), Permit Administration & Development Section, verifying that the emission units were constructed as proposed in the application.

Effective Date of the Permit

D.1.3 Effective Date of the Permit [IC 13-15-5-3]

Pursuant to IC 13-15-5-3, this section of this permit becomes effective upon its issuance.

D.1.4 Modification to Construction Conditions [326 IAC 2]

All requirements of these construction conditions shall remain in effect unless modified in a manner consistent with procedures established for revisions pursuant to 326 IAC 2.

Operation Conditions

Emission Limitations and Standards [326 IAC 2-8-4(1)]

D.1.5 PM and PM10 Emissions [326 IAC 2-2] [326 IAC 2-8-4]

The PM and PM10 emissions from the following units shall not exceed the emission limits listed in the table below.

Unit ID	Unit Description	Baghouse ID	PM/PM10 Emission Limit (lbs/hr)
EU001 – EU007	Grain Receiving and Handling Operations	CE001	1.67
EU010 and EU011	Hammermills	CE003	1.20
EU040 - EU043	DDGS Handling and Loadout Operations	CE008	0.16

Combined with the PM10 emissions from other emission units, the PM10 emissions from the entire source are limited to less than 100 tons/yr. Combined with the PM emissions from other emission units, the PM emissions from the entire source are limited to less than 250 tons/yr. Therefore, the requirements of 326 IAC 2-7 (Part 70 Program) and 326 IAC 2-2 (PSD) are not applicable.

D.1.6 Particulate Emission Limitations [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), particulate emissions from each of following operations shall not exceed the pound per hour limits listed in the table below:

Unit ID	Unit Description	Max. Throughput Rate (tons/hr)	Particulate Emission Limit (lbs/hr)
EU001	Each of the Corn Dump Pits	420	66.9
EU002	Corn Conveyor	420	66.9
EU003	Corn Elevator	420	66.9
EU004	Corn Storage Bin	420	66.9
EU005	Corn Storage Bin	420	66.9
EU006	Scalper	140	54.7
EU007	Surge Bin	140	54.7
EU010	Hammermill	140	54.7
EU011	Hammermill	140	54.7
EU040	DDGS Dump pit	101	51.4
EU041	DDGS Elevator	101	51.4
EU042	DDGS Conveyor	101	51.4
EU043	DDGS Load Spout	101	51.4
EU064	Corn Storage Bin	420	66.9

The pounds per hour limitations were calculated using the following equation:

Interpolation and extrapolation of the data for the process weight rate in excess of sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 55.0 P^{0.11} - 40 \quad \text{where } E = \text{rate of emission in pounds per hour; and} \\ P = \text{process weight rate in tons per hour}$$

Pursuant to 326 IAC 6-3-2(e)(3), when the process weight exceeds 200 tons per hour, the maximum allowable emission may exceed the emission limits shown in the table above, provided the concentration of particulate matter in the gas discharged to the atmosphere is less than 0.10 pounds per 1,000 pounds of gases.

D.1.7 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

A Preventive Maintenance Plan, in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for these facilities and any control devices.

Compliance Determination Requirements

D.1.8 Particulate Control

- (a) In order to comply with Conditions D.1.5(a) and D.1.6, each of the following emission units shall be controlled by the associated baghouse, as listed in the table below, when these units are in operation:

Unit ID	Unit Description	Baghouse ID
EU001 - EU007 and EU064	Grain Receiving and Handling Operations	CE001
EU010 and EU011	Hammermills	CE003
EU040 - EU043	DDGS Handling and Loadout Operations	CE008

- (b) In the event that bag failure is observed in a multi-compartment baghouse, if operations will continue for ten (10) days or more after the failure is observed before the failed units will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed units will be repaired or replaced. The notification shall also include the status of the applicable compliance monitoring parameters with respect to normal, and the results of any response actions taken up to the time of notification.

D.1.9 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11]

In order to demonstrate compliance with Conditions D.1.5(a) and D.1.6, the Permittee shall perform PM and PM10 testing for baghouses CE001, CE003, and CE008 within 60 days after achieving the maximum capacity, but not later than 180 days after initial startup, utilizing methods as approved by the Commissioner. These tests shall be repeated at least once every five (5) years from the date of this valid compliance demonstration. PM-10 includes filterable and condensable PM-10. Testing shall be conducted in accordance with Section C - Performance Testing.

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

D.1.10 Visible Emissions Notations

- (a) Visible emission notations of the baghouse stack exhausts (stacks EP001, EP003, and EP008) shall be performed once per day during normal daylight operations. A trained employee shall record whether emissions are normal or abnormal.
- (b) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.
- (c) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- (d) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.
- (e) If abnormal emissions are observed, the Permittee shall take reasonable response steps in accordance with Section C- Response to Excursions or Exceedances. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances shall be considered a deviation from this permit.

D.1.11 Parametric Monitoring

The Permittee shall record the pressure drop across the baghouses used in conjunction with corn dump pits (EU001), the grain handling operation (EU002 through EU007 and EU064), the hammermills (EU010 and EU011), and the DDGS loadout operation (EU040 through EU043), at least once per day when these units are in operation. When for any one reading, the pressure drop across the baghouse is outside the normal range of 1.0 to 6.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances shall be considered a deviation from this permit.

The instrument used for determining the pressure shall comply with Section C - Instrument Specifications, of this permit, shall be subject to approval by IDEM, OAQ and shall be calibrated at least once every six (6) months.

D.1.12 Broken or Failed Bag Detection

- (a) For a single compartment baghouse controlling emissions from a process operated continuously, a failed unit and the associated process shall be shut down immediately until the failed unit has been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).
- (b) For a single compartment baghouse controlling emissions from a batch process, the feed to the process shall be shut down immediately until the failed unit has been repaired or replaced. The emissions unit shall be shut down no later than the completion of the

processing of the material in the line. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).

Bag failure can be indicated by a significant drop in the baghouse's pressure reading with abnormal visible emissions, by an opacity violation, or by other means such as gas temperature, flow rate, air infiltration, leaks, dust traces or triboflows.

Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

D.1.13 Record Keeping Requirements

- (a) To document compliance with Condition D.1.10, the Permittee shall maintain records of daily visible emission notations of the baghouse stack exhausts. The Permittee shall include in its daily record when a visible emission notation is not taken and the reason for the lack of visible emission notation (e.g. the process did not operate that day).
- (b) To document compliance with Condition D.1.11, the Permittee shall maintain daily records of the pressure drop during normal operation. The Permittee shall include in its daily record when a pressure drop reading is not taken and the reason for the lack of a pressure drop reading (e.g. the process did not operate that day).
- (c) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

SECTION D.2 FACILITY OPERATION CONDITIONS – Fermentation Process

Facility Description [326 IAC 2-8-4(10)]:

- (d) One (1) fermentation process, constructed in 2006, with a maximum throughput rate of 7,060 gallons of ethanol per hour, controlled by CO₂ scrubber CE005, exhausting through stack EP005, and consisting of the following:
- (1) Five (5) fermenters, identified as EU016, EU017, EU018, EU019, and EU057.
 - (2) One (1) beer well, identified as EU020.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

THIS SECTION OF THE PERMIT IS BEING ISSUED UNDER THE PROVISIONS OF 326 IAC 2-1 AND 326 IAC 2-8-11.1, WITH CONDITIONS LISTED BELOW.

Construction Conditions

General Construction Conditions

D.2.1 Permit No Defense

This permit to construct does not relieve the Permittee of the responsibility to comply with the provisions of the Indiana Environmental Management Law (IC 13-11 through 13-20; 13-22 through 13-25; and 13-30), the Air Pollution Control Law (IC 13-17) and the rules promulgated thereunder, as well as other applicable local, state, and federal requirements.

D.2.2 Federally Enforceable State Operating Permit [326 IAC 2-8]

The attached Affidavit of Construction shall be submitted to the Office of Air Quality (OAQ), Permit Administration & Development Section, verifying that the emission units were constructed as proposed in the application.

Effective Date of the Permit

D.2.3 Effective Date of the Permit [IC 13-15-5-3]

Pursuant to IC 13-15-5-3, this section of this permit becomes effective upon its issuance.

D.2.4 Modification to Construction Conditions [326 IAC 2]

All requirements of these construction conditions shall remain in effect unless modified in a manner consistent with procedures established for revisions pursuant to 326 IAC 2.

Operation Conditions

Emission Limitations and Standards [326 IAC 2-8-4(1)]

D.2.5 VOC and HAP Emissions [326 IAC 2-2] [326 IAC 2-8-4] [326 IAC 2-4.1]

Pursuant to 326 IAC 2-8-4 (FESOP), emissions from wet scrubber CE005, which is used to control the emissions from the fermentation process shall comply with the following:

- (a) VOC emissions shall not exceed 7.62 lbs/hr.
- (b) Acetaldehyde emissions shall not exceed 1.72 lbs/hr.
- (c) Total HAP emissions shall not exceed 1.74 lbs/hr.

Combined with the VOC and HAP emissions from other units, the VOC emissions from the entire source are limited to less than 100 tons/yr, and the HAP emissions from the entire source are limited to less than 10 tons/yr for a single HAP and less than 25 tons/yr for total HAPs. Therefore,

the requirements of 326 IAC 2-7 (Part 70 Program), 326 IAC 2-2 (PSD), and 326 IAC 2-4.1 (MACT) are not applicable.

D.2.6 VOC Emissions [326 IAC 8-5-6]

Pursuant to 326 IAC 8-5-6 (Fuel Grade Ethanol Production at Dry Mills), the Permittee shall comply with the following:

- (a) The VOC emissions from the fermentation process shall be controlled by wet scrubber CE005.
- (b) The overall VOC control efficiency for the wet scrubber CE005 (including the capture efficiency and adsorption efficiency) shall be at least 98% or the VOC emissions from scrubber CE005 shall not exceed 20 ppmv.

D.2.7 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]

The provisions of 40 CFR 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the facility described in Condition D.2.8 except when otherwise specified in 40 CFR 60, Subpart VV.

D.2.8 Equipment Leaks of VOC [326 IAC 12][40 CFR 60, Subpart VV]

Pursuant to 40 CFR 60, Subpart VV, the Permittee shall comply with the requirement of - Section E.1 for pumps; compressors; pressure relief devices in gas/vapor service; sampling connection systems; open-ended valves or lines; and valves.

D.2.9 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

A Preventive Maintenance Plan, in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for these facilities and any control devices.

Compliance Determination Requirements

D.2.10 VOC and HAP Control

In order to comply with Conditions D.2.5 and D.2.6, wet scrubber CE005 shall be in operation and control emissions from the fermentation process at all times that this process is in operation.

D.2.11 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11][326 IAC 8-5-6]

In order to verify compliance with Conditions D.2.5 and D.2.6, the Permittee shall perform VOC (including emission rate, adsorption efficiency, and capture efficiency) and acetaldehyde testing for scrubber CE005 within 60 days after achieving the maximum capacity, but not later than 180 days after initial startup, utilizing methods as approved by the Commissioner. These tests shall be repeated at least once every five (5) years from the date of this valid compliance demonstration. Testing shall be conducted in accordance with Section C - Performance Testing.

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

D.2.12 Parametric Monitoring [326 IAC 8-5-6]

The Permittee shall monitor and record the pressure drop and flow rate of scrubber CE005, at least once per day when the associated fermentation process is in operation. When for any one reading, the pressure drop across the scrubber is outside the normal range of 1.0 and 6.0 inches of water, or a range established during the latest stack test, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. When for any one reading, the flow rate of any of the scrubbers is less than the minimum of 20 gallons per minute, or a minimum established during the latest stack test, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. A pressure reading that is outside the above mention range or a flow rate that is below the above mentioned minimum is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances shall be considered a deviation from this permit.

The instruments used for determining the pressure drop and flow rate shall comply with Section C - Instrument Specifications, of this permit, shall be subject to approval by IDEM, OAQ, and shall be calibrated at least once every six (6) months.

D.2.13 Scrubber Detection

In the event that a scrubber malfunction has been observed:

Failed units and the associated process will be shut down immediately until the failed units have been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions). Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances shall be considered a deviation from this permit.

Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

D.2.14 Record Keeping Requirements [326 IAC 8-5-6]

- (a) To document compliance with Condition D.2.12, the Permittee shall maintain daily records of pressure drop and flow rate for scrubber CE005 during normal operation. The Permittee shall include in its daily record when a pressure drop or flow rate reading is not taken and the reason for the lack of a pressure drop or flow rate reading (e.g. the process did not operate that day).
- (b) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

SECTION D.3 FACILITY OPERATION CONDITIONS – TO/HRSG System and DDGS Drying Process

Facility Description [326 IAC 2-8-4(10)]:

- (e) One (1) thermal oxidizer with heat recovery steam generator (TO/HRSG) system, identified as CE007, constructed in 2006, with a maximum heat input capacity of 135 MMBtu/hr, using natural gas and process waste gases from the DDGS dryers as fuels, with emissions exhausted through stack EP007.
- (f) One (1) distillation process, constructed in 2006, with a maximum throughput rate of 6,850 gallons of ethanol per hour, controlled by TO/HRSG system CE007, exhausting through stack EP007, and consisting of the following:
 - (1) Two (2) slurry mixers, identified as EU049 and EU058.
 - (2) One (1) slurry tank, identified as EU050.
 - (3) Three (3) liquefaction tanks, identified as EU014, EU051, and EU059, each with a maximum capacity of 7,000 gallons per hour.
 - (4) One (1) cook tube, identified as EU052.
 - (5) One (1) flash tank, identified as EU053.
 - (6) One (1) yeast tank, identified as EU015.
 - (7) One (1) 190 proof condenser, identified as EU054.
 - (8) One (1) 200 proof condenser, identified as EU055.
 - (9) One (1) beer stripper, identified as EU021.
 - (10) One (1) side stripper, identified as EU022.
 - (11) One (1) rectifier, identified as EU023.
 - (12) Molecular sieve units, identified as EU024.
 - (13) Eight (8) evaporators, identified as EU025.
 - (14) Four (4) centrifuges, identified as EU026 through EU029.
- (g) Two (2) natural gas fired DDGS dryers, identified as EU035 and EU056, constructed in 2006, each with a maximum heat input rate of 45 MMBtu/hr and a maximum throughput rate of 34 tons of DDGS per hour, controlled by multiclone CE006, with emissions venting to TO/HRSG system CE007, and exhausting to stack EP007.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

THIS SECTION OF THE PERMIT IS BEING ISSUED UNDER THE PROVISIONS OF 326 IAC 2-1 AND 326 IAC 2-8-11.1, WITH CONDITIONS LISTED BELOW.

Construction Conditions

General Construction Conditions

D.3.1 Permit No Defense

This permit to construct does not relieve the Permittee of the responsibility to comply with the provisions of the Indiana Environmental Management Law (IC 13-11 through 13-20; 13-22 through 13-25; and 13-30), the Air Pollution Control Law (IC 13-17) and the rules promulgated thereunder, as well as other applicable local, state, and federal requirements.

D.3.2 Federally Enforceable State Operating Permit [326 IAC 2-8]

The attached Affidavit of Construction shall be submitted to the Office of Air Quality (OAQ), Permit Administration & Development Section, verifying that the emission units were constructed as proposed in the application.

Effective Date of the Permit

D.3.3 Effective Date of the Permit [IC 13-15-5-3]

Pursuant to IC 13-15-5-3, this section of this permit becomes effective upon its issuance.

D.3.4 Modification to Construction Conditions [326 IAC 2]

All requirements of these construction conditions shall remain in effect unless modified in a manner consistent with procedures established for revisions pursuant to 326 IAC 2.

Operation Conditions

Emission Limitations and Standards [326 IAC 2-8-4(1)]

D.3.5 FESOP Limits [326 IAC 2-2] [326 IAC 2-8-4] [326 IAC 2-4.1]

Pursuant to 326 IAC 2-8-4 (FESOP) and in order to make the requirements of 326 IAC 2-2 (PSD) not applicable, emissions from TO/HRSG System CE007, which is used to control the DDGS dryers (EU035 and EU056) and the distillation process shall not exceed the following:

- (a) PM/PM10 emissions shall not exceed 8.0 lbs/hr.
- (b) VOC emissions shall not exceed 7.5 lbs/hr.
- (c) CO emissions shall not exceed 21.0 lbs/hr.
- (d) SO₂ emissions shall not exceed not exceed 8.5 lbs/hr.
- (e) NO_x emissions shall not exceed 19.7 lbs/hr.
- (f) Acetaldehyde emissions shall not exceed 0.32 lbs/hr.
- (g) Total HAP emissions shall not exceed 0.69 lbs/hr.

Combined with the PM/PM10, VOC, SO₂, CO, NO_x, and HAP emissions from other units, the PM/PM10, SO₂, VOC, CO, NO_x emissions from the entire source are each limited to less than 100 tons/yr and the HAP emissions from the entire source are limited to less than 10 tons/yr for a single HAP and less than 25 tons/yr for total HAPs. Therefore, the requirements of 326 IAC 2-7 (Part 70 Program), 326 IAC 2-2 (PSD), and 326 IAC 2-4.1 (MACT) are not applicable.

D.3.6 VOC Emissions [326 IAC 8-5-6]

Pursuant to 326 IAC 8-5-6 (Fuel Grade Ethanol Production at Dry Mills), the Permittee shall comply with the following:

- (a) The VOC emissions from the DDGS dryers (EU035 and EU056) and the distillation process shall be controlled by TO/HRSG system CE007.

- (b) The overall efficiency for the thermal oxidizer CE007 (including the capture efficiency and destruction efficiency) shall be at least 98% or the maximum outlet VOC concentration shall not exceed 10 ppmv.

D.3.7 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]

The provisions of 40 CFR Part 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the TO/HRSG system CE007 except when otherwise specified in 40 CFR Part 60, Subpart Db.

D.3.8 NOx Emissions [326 IAC 12-1][40 CFR 60, Subpart Db]

- (a) Pursuant to 40 CFR 60.44b, the NOx emissions from the TO/HRSG system (CE007) shall not exceed 0.1 lbs/MMBtu.
- (b) Pursuant to 40 CFR 60.48b(b), except for 40 CFR 60.48b(g), (h), and (i), the Permittee shall install, calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring nitrogen oxides emissions discharged to the atmosphere.

D.3.9 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]

The provisions of 40 CFR 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the facility described in Condition D.3.10 except when otherwise specified in 40 CFR 60, Subpart VV.

D.3.10 Equipment Leaks of VOC [326 IAC 12][40 CFR 60, Subpart VV]

Pursuant to 40 CFR 60, Subpart VV, the Permittee shall comply with the requirement of Section E.1 for pumps; compressors; pressure relief devices in gas/vapor service; sampling connection systems; open-ended valves or lines; and valves.

D.3.11 Particulate Emissions [326 IAC 6-2-4]

Pursuant to 326 IAC 6-2-4 (Particulate Emission Limitations for Sources of Indirect Heating), particulate emissions from the 135 MMBtu/hr TO/HRSG system (CE007) shall be limited to 0.30 pounds per MMBtu heat input.

The limit was calculated using the following equation:

$$Pt = \frac{1.09}{Q^{0.26}}$$

Where Pt = emission rate limit (lbs/MMBtu)
Q = total source heat input capacity (MMBtu/hr)

D.3.12 Particulate Emission Limitations [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), particulate emissions from each of following operations shall not exceed the pound per hour limits listed in the table below:

Unit ID	Unit Description	Max. Throughput Rate (tons/hr)	Particulate Emission Limit (lbs/hr)
EU035	DDGS Dryer	34	41.1
EU056	DDGS Dryer	34	41.1

The pounds per hour limitations were calculated using the following equations:

Interpolation and extrapolation of the data for the process weight rate in excess of sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 55.0 P^{0.11} - 40 \quad \text{where } E = \text{rate of emission in pounds per hour; and} \\ P = \text{process weight rate in tons per hour}$$

D.3.13 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

A Preventive Maintenance Plan, in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for these facilities and any control devices.

Compliance Determination Requirements

D.3.14 PM and PM10 Control

In order to comply with Conditions D.3.5, D.3.11, and D.3.12, cyclone CE006 shall be in operation and control emissions from the DDGS dryers (EU035 and EU056) at all times that these units are in operation.

D.3.15 VOC and HAP Control

In order to comply with Conditions D.3.5 and D.3.6, thermal oxidizer CE007 shall be in operation and control emissions from the DDGS dryers (EU035 and EU056) and the distillation process at all times that these units are in operation.

D.3.16 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11 [326 IAC 2-2] [40 CFR 60, Subpart Db] [326 IAC 8-5-6]

- (a) In order to demonstrate compliance with Conditions D.3.5, D.3.6, D.3.11, and D.3.12, the Permittee shall perform PM, PM10, VOC (including emission rate, destruction efficiency, and capture efficiency), SO₂, CO, NO_x, and Acetaldehyde testing for thermal oxidizer CE007 within 60 days after achieving the maximum capacity, but not later than 180 days after initial startup, utilizing methods as approved by the Commissioner. PM-10 includes filterable and condensable PM-10. These tests shall be repeated at least once every five (5) years from the date of this valid compliance demonstration. Testing shall be conducted in accordance with Section C - Performance Testing.
- (b) In order to demonstrate compliance with Condition D.3.8(a) and pursuant to 40 CFR 60.46b(e), the Permittee shall conduct the performance test as required under 40 CFR 60.8 using the continuous system for monitoring nitrogen oxides under 40 CFR 60.48(b). For the initial compliance test, nitrogen oxides from the TO/HRSG system stack (EP007) are monitored for 30 successive steam generating unit operating days and the 30-day average emission rate is used to determine compliance with the nitrogen oxides emission standards under 40 CFR 60.44b. Following the date on which the initial performance test is completed, the Permittee shall upon request determine compliance with the nitrogen oxides standards under 40 CFR 60.44b through the use of a 30-day performance test.

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

D.3.17 Continuous Emissions Monitoring [326 IAC 3-5] [326 IAC 12] [40 CFR 60, Subpart Db]

- (a) Pursuant to 326 IAC 3-5 (Continuous Monitoring of Emissions) and 40 CFR 60.47b and 60.48b, a continuous monitoring system shall be calibrated, maintained, and operated for measuring NO_x, which meets the performance specifications of 326 IAC 3-5-2.
- (b) Pursuant to 326 IAC 3-5-4, if revisions are made to the continuous monitoring standard operating procedures (SOP), the Permittee shall submit updates to the department biennially.
- (c) Nothing in this permit shall excuse the Permittee from complying with the requirements to operate a continuous emission monitoring system pursuant to 326 IAC 3-5, or 40 CFR 60.

D.3.18 Visible Emissions Notations

- (a) Visible emission notations of the stack exhaust from the TO/HRSG system stack EP007 shall be performed once per day during normal daylight operations. A trained employee shall record whether emissions are normal or abnormal.
- (b) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.
- (c) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- (d) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.
- (e) If abnormal emissions are observed, the Permittee shall take reasonable response steps in accordance with Section C- Response to Excursions or Exceedances. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances shall be considered a deviation from this permit.

D.3.19 Thermal Oxidizer Temperature [326 IAC 8-5-6]

- (a) A continuous monitoring system shall be calibrated, maintained, and operated on the TO/HRSG system (CE007) for measuring operating temperature. For the purpose of this condition, continuous means no less than once per minute. The output of this system shall be recorded as a 3-hour average. From the date of issuance of this permit until the approved stack test results are available, the Permittee shall operate the thermal oxidizer at or above the 3-hour average temperature of 1,400°F.
- (b) The Permittee shall determine the 3-hour average temperature from the most recent valid stack test that demonstrates compliance with limits in Conditions D.3.5 and D.3.6, as approved by IDEM.
- (c) On and after the date the approved stack test results are available, the Permittee shall operate the thermal oxidizer at or above the 3-hour average temperature as observed during the compliant stack test.

D.3.20 Parametric Monitoring [326 IAC 8-5-6]

- (a) The Permittee shall determine the appropriate duct pressure or fan amperage from the most recent valid stack test that demonstrates compliance with limits in Conditions D.3.5 and D.3.6, as approved by IDEM.
- (b) The duct pressure or fan amperage shall be observed at least once per day when the thermal oxidizer/heat recovery steam generator is in operation. On and after the date the approved stack test results are available, the duct pressure or fan amperage shall be maintained within the normal range as established in most recent compliant stack test.

Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

D.3.21 Record Keeping Requirements [326 IAC 8-5-6]

- (a) To document compliance with Conditions D.3.5(e), D.3.8(a), and D.3.17, the Permittee shall maintain records of the NOx emissions in accordance with 40 CFR 60.49b.
- (b) To document compliance with Condition D.3.18, the Permittee shall maintain records of daily visible emission notations of the stack EP007. The Permittee shall include in its daily record when a visible emission notation is not taken and the reason for the lack of visible emission notation (e.g. the process did not operate that day).

- (c) To document compliance with Condition D.3.19, the Permittee shall maintain continuous temperature records for the thermal oxidizer and the 3-hour average temperature used to demonstrate compliance during the most recent compliant stack test.
- (d) To document compliance with Condition D.3.20, the Permittee shall maintain daily records of the duct pressure or fan amperage for the TO/HRSG system CE007. The Permittee shall include in its daily record when a duct pressure or fan amperage reading is not taken and the reason for the lack of a duct pressure or fan amperage reading (e.g. the process did not operate that day).
- (e) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

D.3.22 Recordkeeping Requirements [40 CFR 60, Subpart Db] [326 IAC 12]

- (a) Pursuant to 40 CFR 60.49b(d), the Permittee shall record and maintain records of the amounts of each fuel combusted during each day and calculate the annual capacity factor individually for natural gas for the reporting period. The annual capacity factor is determined on a 12-month rolling average basis with a new annual capacity factor calculated at the end of each calendar month.
- (b) Pursuant to 40 CFR 60.49b(g), the Permittee shall maintain records of the following information for each steam generating unit operating day:
 - (1) Calendar date.
 - (2) The average hourly nitrogen oxides emission rates (expressed as NO₂) (ng/J or lb/million Btu heat input) measured or predicted.
 - (3) The 30-day average nitrogen oxides emission rates (ng/J or lb/million Btu heat input) calculated at the end of each steam generating unit operating day from the measured or predicted hourly nitrogen oxide emission rates for the preceding 30 steam generating unit operating days.
 - (4) Identification of the steam generating unit operating days when the calculated 30-day average nitrogen oxides emission rates are in excess of the nitrogen oxides emissions standards under 40 CFR 60.44b, with the reasons for such excess emissions as well as a description of corrective actions taken.
 - (5) Identification of the steam generating unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken.
 - (6) Identification of the times when emission data have been excluded from the calculation of average emission rates and the reasons for excluding data.
 - (7) Identification of "F" factor used for calculations, method of determination, and type of fuel combusted.
 - (8) Identification of the times when the pollutant concentration exceeded full span of the continuous monitoring system.
 - (9) Description of any modifications to the continuous monitoring system that could affect the ability of the continuous monitoring system to comply with Performance Specification 2 or 3.
 - (10) Results of daily CEMS drift tests and quarterly accuracy assessments as required under appendix F, Procedure 1.

- (c) All records shall be maintained in accordance with Section C – General Recordkeeping Requirements, of this permit.

D.3.23 Reporting Requirements [40 CFR 60, Subpart Db] [326 IAC 12]

- (a) Pursuant to 40 CFR 60.49b(a), the Permittee shall submit notification of the date of initial startup, as provided by 40 CFR 60.7. This notification shall include the information specified in 40 CFR 60.49b(a)(1) through (4).
- (b) Pursuant to 40 CFR 60.49b(b), the Permittee shall submit the performance test data from the initial performance test and the performance evaluation of the CEMS using the applicable performance specifications in appendix B. The Permittee shall submit to the Administrator the maximum heat input capacity data from the demonstration of the maximum heat input capacity of the affected facility.
- (c) Pursuant to 40 CFR 60.49b(h), the Permittee shall submit excess emission reports for any excess emissions which occurred during the reporting period.
- (d) Pursuant to 40 CFR 60.49b(i), the Permittee shall submit reports containing the information recorded under 40 CFR 60.49b(g) and Condition D.3.22(b).
- (e) Pursuant to 40 CFR 60.49b(v), the Permittee may submit electronic quarterly reports for NO_x in lieu of submitting the written reports required. The format of each quarterly electronic report shall be coordinated with IDEM, OAQ. The electronic report(s) shall be submitted no later than 30 days after the end of the calendar quarter and shall be accompanied by a certification statement from the owner or operator, indicating whether compliance with the applicable emission standards and minimum data requirements of this subpart was achieved during the reporting period. Before submitting reports in the electronic format, the Permittee shall coordinate with IDEM, OAQ to obtain their agreement to submit reports in this alternative format.
- (f) Pursuant to 40 CFR 60.49b(w), the Permittee is required to submit the above reports each six (6) month period. All reports shall be submitted to the Administrator and shall be postmarked by the 30th day following the end of the reporting period.

SECTION D.4 FACILITY OPERATION CONDITIONS – DDGS Cooler

Facility Description [326 IAC 2-8-4(10)] :

- (h) One (1) DDGS cooler, identified as EU036, constructed in 2006, with a maximum throughput rate of 34 tons/hr of DDGS, controlled by baghouse CE014, and exhausting to stack EP014.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

THIS SECTION OF THE PERMIT IS BEING ISSUED UNDER THE PROVISIONS OF 326 IAC 2-1 AND 326 IAC 2-8-11.1, WITH CONDITIONS LISTED BELOW.

Construction Conditions

General Construction Conditions

D.4.1 Permit No Defense

This permit to construct does not relieve the Permittee of the responsibility to comply with the provisions of the Indiana Environmental Management Law (IC 13-11 through 13-20; 13-22 through 13-25; and 13-30), the Air Pollution Control Law (IC 13-17) and the rules promulgated thereunder, as well as other applicable local, state, and federal requirements.

D.4.2 Federally Enforceable State Operating Permit [326 IAC 2-8]

The attached Affidavit of Construction shall be submitted to the Office of Air Quality (OAQ), Permit Administration & Development Section, verifying that the emission units were constructed as proposed in the application.

Effective Date of the Permit

D.4.3 Effective Date of the Permit [IC 13-15-5-3]

Pursuant to IC 13-15-5-3, this section of this permit becomes effective upon its issuance.

D.4.4 Modification to Construction Conditions [326 IAC 2]

All requirements of these construction conditions shall remain in effect unless modified in a manner consistent with procedures established for revisions pursuant to 326 IAC 2.

Operation Conditions

Emission Limitations and Standards [326 IAC 2-8-4(1)]

D.4.5 PM and PM10 Emissions [326 IAC 2-2] [326 IAC 2-8-4]

Pursuant to 326 IAC 2-8-4 (FESOP) and in order to render the requirements of 326 IAC 2-2 (PSD) not applicable, the Permittee shall comply with the following:

- (a) The PM/PM10 emissions from the DDGS cooler, which is controlled by baghouse CE014, shall not exceed the 0.94 lbs/hr.
- (b) The total DDGS produced shall not exceed 210,000 tons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (3) VOC emissions shall not exceed 0.065 pounds per ton of DDGS produced.

Combined with the PM/PM10 and VOC emissions from other emission units, the PM/PM10 and VOC emissions from the entire source are limited to less than 100 tons/yr. Therefore, the requirements of 326 IAC 2-7 (Part 70 Program) and 326 IAC 2-2 (PSD) are not applicable.

D.4.6 Particulate Emission Limitations [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2, particulate emissions from the DDGS cooler (EU036) shall not exceed 41.1 pounds per hour when operating at the maximum process throughput rate of 34 tons per hour.

The pounds per hour limitation was calculated using the following equation:

Interpolation and extrapolation of the data for the process weight rate in excess of sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 55.0 P^{0.11} - 40 \quad \text{where } E = \text{rate of emission in pounds per hour; and} \\ P = \text{process weight rate in tons per hour}$$

D.4.7 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

A Preventive Maintenance Plan, in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for this facility and any control device.

Compliance Determination Requirements

D.4.8 Particulate Control

- (a) In order to comply with Conditions D.4.5(a) and D.4.6, Baghouse CE014 shall be in operation and control emissions from the DDGS cooler (CE036) at all times that this unit is in operation.
- (b) In the event that bag failure is observed in a multi-compartment baghouse, if operations will continue for ten (10) days or more after the failure is observed before the failed units will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed units will be repaired or replaced. The notification shall also include the status of the applicable compliance monitoring parameters with respect to normal, and the results of any response actions taken up to the time of notification.

D.4.9 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11]

In order to demonstrate compliance with Conditions D.4.5 and D.4.6, the Permittee shall perform PM, PM10, and VOC testing for the DDGS cooler (EU036) within 60 days after achieving the maximum capacity, but not later than 180 days after initial startup, utilizing methods as approved by the Commissioner. These tests shall be repeated at least once every five (5) years from the date of this valid compliance demonstration. Testing shall be conducted in accordance with Section C - Performance Testing. PM10 includes filterable and condensible PM10.

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

D.4.10 Visible Emissions Notations

- (a) Visible emission notations of the baghouse stack exhaust (stack EP014) shall be performed once per day during normal daylight operations. A trained employee or a trained contractor shall record whether emissions are normal or abnormal.
- (b) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.
- (c) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- (d) A trained employee or contractor is a person who has worked or trained at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.
- (e) If abnormal emissions are observed, the Permittee shall take reasonable response steps in accordance with Section C- Response to Excursions or Exceedances. Failure to take

response steps in accordance with Section C - Response to Excursions or Exceedances shall be considered a deviation from this permit.

D.4.11 Parametric Monitoring

The Permittee shall record the pressure drop across the baghouse used in conjunction with the DDGS cooler (EU036) at least once per day when this unit is in operation. When for any one reading, the pressure drop across the baghouse is outside the normal range of 1.0 to 6.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances shall be considered a deviation from this permit.

The instrument used for determining the pressure shall comply with Section C - Instrument Specifications, of this permit, shall be subject to approval by IDEM, OAQ and shall be calibrated at least once every six (6) months.

D.4.12 Broken or Failed Bag Detection

- (a) For a single compartment baghouse controlling emissions from a process operated continuously, a failed unit and the associated process shall be shut down immediately until the failed unit has been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).
- (b) For a single compartment baghouse controlling emissions from a batch process, the feed to the process shall be shut down immediately until the failed unit has been repaired or replaced. The emissions unit shall be shut down no later than the completion of the processing of the material in the line. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).

Bag failure can be indicated by a significant drop in the baghouse's pressure reading with abnormal visible emissions, by an opacity violation, or by other means such as gas temperature, flow rate, air infiltration, leaks, dust traces or triboflows.

Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

D.4.13 Record Keeping Requirements

- (a) To document compliance with Condition D.4.5(b), the Permittee shall maintain monthly records of the amount of DDGS produced.
- (b) To document compliance with Condition D.4.10, the Permittee shall maintain records of daily visible emission notations of the baghouse stack exhausts. The Permittee shall include in its daily record when a visible emission notation is not taken and the reason for the lack of visible emission notation (e.g. the process did not operate that day).
- (c) To document compliance with Condition D.4.11, the Permittee shall maintain daily records of pressure drop for baghouses during normal operation. The Permittee shall include in its daily record when a pressure drop reading is not taken and the reason for the lack of a pressure drop reading (e.g. the process did not operate that day).
- (d) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

D.4.14 Reporting Requirements

A quarterly summary of the information to document compliance with Condition D.4.5(b) shall be submitted to the address listed in Section C - General Reporting Requirements, of this permit, using the reporting forms located at the end of this permit, or their equivalent, within thirty (30)

days after the end of the quarter being reported. The report submitted by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

SECTION D.5 FACILITY OPERATION CONDITIONS – Ethanol Loading Racks

Facility Description [326 IAC 2-8-4(10)]:

- (j) One (1) ethanol loading rack for trucks, identified as EU045A, constructed in 2006, with a maximum throughput rate of 48,000 gallons per hour. The truck loading process is controlled by the enclosed flare CE009, which is fueled by natural gas and has a maximum heat input capacity of 10.0 MMBtu/hr, and exhausts through stack EP009.
- (k) One (1) ethanol loading rack for railcars, identified as EU045B, constructed in 2006, with a maximum throughput rate of 60,000 gallons per hour. Railcars are dedicated to carrying denatured ethanol.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

THIS SECTION OF THE PERMIT IS BEING ISSUED UNDER THE PROVISIONS OF 326 IAC 2-1 AND 326 IAC 2-8-11.1, WITH CONDITIONS LISTED BELOW.

Construction Conditions

General Construction Conditions

D.5.1 Permit No Defense

This permit to construct does not relieve the Permittee of the responsibility to comply with the provisions of the Indiana Environmental Management Law (IC 13-11 through 13-20; 13-22 through 13-25; and 13-30), the Air Pollution Control Law (IC 13-17) and the rules promulgated thereunder, as well as other applicable local, state, and federal requirements.

D.5.2 Federally Enforceable State Operating Permit [326 IAC 2-8]

The attached Affidavit of Construction shall be submitted to the Office of Air Quality (OAQ), Permit Administration & Development Section, verifying that the emission units were constructed as proposed in the application.

Effective Date of the Permit

D.5.3 Effective Date of the Permit [IC 13-15-5-3]

Pursuant to IC 13-15-5-3, this section of this permit becomes effective upon its issuance.

D.5.4 Modification to Construction Conditions [326 IAC 2]

All requirements of these construction conditions shall remain in effect unless modified in a manner consistent with procedures established for revisions pursuant to 326 IAC 2.

Operation Conditions

Emission Limitations and Standards [326 IAC 2-8-4(1)]

D.5.5 FESOP Limits [326 IAC 2-2] [326 IAC 2-8-4] [326 IAC 2-4.1]

Pursuant to 326 IAC 2-8-4 (FESOP), the Permittee shall comply with the following:

- (a) The total combined denatured ethanol and blended ethanol load-out from loading racks EU045A and EU045B shall not exceed 64,900,000 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (b) The total denaturant used at the loading racks EU045A and EU045B shall not exceed 4,900,000 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.

- (c) The total denatured ethanol load-out into non-dedicated railcars shall not exceed 2,500,000 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (d) The blended ethanol shall not exceed a blend of 30% gasoline.
- (e) No ethanol that exceeds 5% gasoline shall be loaded out to non-dedicated railcars.
- (f) The Permittee shall use flare CE009 to control the emissions from the ethanol loading rack for trucks (EU045A).
- (g) CO emissions from flare CE009 shall not exceed 0.129 lbs/kgal.
- (h) NOx emissions from flare CE009 shall not exceed 0.077 lbs/kgal.
- (i) The ethanol loading racks (EU045A and EU045B) shall utilize submerged loading method.
- (j) The railcars and trucks shall not use vapor balance services.

Combined with the VOC, CO, NOx, and HAP emissions from other units, the VOC, NOx and CO emissions from the entire source are limited to less than 100 tons/yr, and total HAP emissions from the entire source are limited to less than 10 tons/yr for a single HAP and less than 25 tons/yr for total HAPs. Therefore, the requirements of 326 IAC 2-7 (Part 70 Program), 326 IAC 2-2 (PSD), and 326 IAC 2-4.1 (MACT) are not applicable.

D.5.6 VOC Emissions [326 IAC 8-5-6]

Pursuant to 326 IAC 8-5-6 (Fuel Grade Ethanol Production at Dry Mills), the Permittee shall comply with the following:

- (a) The VOC emissions from the ethanol loading rack for trucks (EU045A) shall be collected and controlled by enclosed flare CE009.
- (b) The overall efficiency for the enclosed flare CE009 (including the capture efficiency and destruction efficiency) shall be at least 98%.

D.5.7 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]

The provisions of 40 CFR 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the facility described in Condition D.5.8 except when otherwise specified in 40 CFR 60, Subpart VV.

D.5.8 Equipment Leaks of VOC [326 IAC 12][40 CFR 60, Subpart VV]

Pursuant to 40 CFR 60, Subpart VV, the Permittee shall comply with the requirement of Section E.1 for pumps; compressors; pressure relief devices in gas/vapor service; sampling connection systems; open-ended valves or lines; and valves.

D.5.9 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

A Preventive Maintenance Plan, in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for this facility and any control device.

Compliance Determination Requirements

D.5.10 VOC and HAP Control

In order to comply with Conditions D.5.5 and D.5.6, enclosed flare CE009 shall be in operation and control emissions from the ethanol loading rack for trucks (EU045A) at all times when this rack is in operation.

D.5.11 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11] [326 IAC 2-2] [326 IAC 8-5-6]

In order to demonstrate compliance with Conditions D.5.5 and D.5.6, the Permittee shall perform VOC (including emission rate, capture efficiency, and destruction efficiency), CO, and NOx testing for enclosed flare CE009 within 60 days after achieving the maximum production, but not later than 180 days after initial startup, utilizing methods as approved by the Commissioner. These tests shall be repeated at least once every five (5) years from the date of this valid compliance demonstration. Testing shall be conducted in accordance with Section C - Performance Testing.

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

D.5.12 Flare Pilot Flame [326 IAC 8-5-6]

In order to comply with Conditions D.5.5 and D.5.6, the Permittee shall monitor the presence of a flare pilot flame using a thermocouple or any other equivalent device to detect the presence of a flame when ethanol loading rack EU045A is in operation.

Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

D.5.13 Record Keeping Requirements [326 IAC 8-5-6]

- (a) To document compliance with Condition D.5.5(a), the Permittee shall maintain monthly records of the total amount of denatured ethanol and blended ethanol loaded out from loading racks EU045A and EU045B.
- (b) To document compliance with Condition D.5.5(b), the Permittee shall maintain monthly records of total denaturant used at loading racks EU045A and EU045B.
- (c) To document compliance with Condition D.5.5(c), the Permittee shall maintain monthly records of total denatured ethanol load-out into non-dedicated railcars.
- (d) To document compliance with Condition D.5.5(d) and (e), the Permittee shall maintain monthly records of the specifications of the blended ethanol loaded out to truck and rail.
- (e) To document compliance with Condition D.5.12, the Permittee shall maintain records of temperature or other parameters sufficient to demonstrate the presence of a pilot flame when loading rack EU045A is in operation.
- (f) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

D.5.14 Reporting Requirements

A quarterly summary of the information to document compliance with Condition D.5.5(a), (b), and (c) shall be submitted to the address listed in Section C - General Reporting Requirements, of this permit, using the reporting forms located at the end of this permit, or their equivalent, within thirty (30) days after the end of the quarter being reported. The report submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

SECTION D.6 FACILITY OPERATION CONDITIONS – Fire Pump and Biomethanator

Facility Description [326 IAC 2-8-4(10)]: Insignificant Activities

- (h) Stationary fire pumps, including one (1) diesel fire pump, identified as EU034, constructed in 2006, with a maximum power output rate of 300 horsepower, and exhausting to stack EP006. [326 IAC 2-8-4]
- (j) Other emission units, not regulated by a NESHAP, with PM₁₀, NO_x, and SO₂ emissions less than five (5) pounds per hour or twenty-five (25) pounds per day, CO emissions less than twenty-five (25) pounds per day, VOC emissions less than three (3) pounds per hour or fifteen (15) pounds per day, lead emissions less than six-tenths (0.6) tons per year or three and twenty-nine hundredths (3.29) pounds per day, and emitting greater than one (1) pound per day but less than five (5) pounds per day or one (1) ton per year of a single HAP, or emitting greater than one (1) pound per day but less than twelve and five tenths (12.5) pounds per day or two and five tenths (2.5) ton per year of any combination of HAPs:
 - (7) One (1) biomethanator, identified as EU048, constructed in 2006, controlled by 6.0 MMBtu/hr biomethanator flare CE013, and exhausting to stack EP013. [326 IAC 2-8-4]

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-8-4(1)]

D.6.1 FESOP Limits [326 IAC 2-2] [326 IAC 2-8-4] [326 IAC 2-4.1]

Pursuant to 326 IAC 2-8-4 (FESOP), the Permittee shall comply with the following:

- (a) The operating hours for the diesel fire pump (EU034) shall not exceed 500 hours per twelve (12) consecutive month period with compliance determined at the end of each month.
- (b) The biomethanator flare (CE013) shall not operate when any of the DDGS dryers (EU035 and EU056) are in operation.

Combined with the CO and NO_x emissions from other emission units, the CO and NO_x emissions from the entire source are each limited to less than 100 tons/yr. Therefore, the requirements of 326 IAC 2-7 (Part 70 Program) and 326 IAC 2-2 (PSD) are not applicable.

Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

D.6.2 Record Keeping Requirements

- (a) To document compliance with Condition D.6.1(a), the Permittee shall maintain monthly records of the operating hours for the diesel fire pump (EU034).
- (b) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

D.6.3 Reporting Requirements

A quarterly summary of the information to document compliance with Condition D.6.1(a) shall be submitted to the address listed in Section C - General Reporting Requirements, of this permit, using the reporting forms located at the end of this permit, or their equivalent, within thirty (30) days after the end of the quarter being reported. The report submitted by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

SECTION D.7 FACILITY OPERATION CONDITIONS – Storage Tanks

Facility Description [326 IAC 2-8-4(10)]:

Insignificant Activities

- (j) Other emission units, not regulated by a NESHAP, with PM₁₀, NO_x, and SO₂ emissions less than five (5) pounds per hour or twenty-five (25) pounds per day, CO emissions less than twenty-five (25) pounds per day, VOC emissions less than three (3) pounds per hour or fifteen (15) pounds per day, lead emissions less than six-tenths (0.6) tons per year or three and twenty-nine hundredths (3.29) pounds per day, and emitting greater than one (1) pound per day but less than five (5) pounds per day or one (1) ton per year of a single HAP, or emitting greater than one (1) pound per day but less than twelve and five tenths (12.5) pounds per day or two and five tenths (2.5) ton per year of any combination of HAPs:
- (1) One (1) 190 proof tank, identified as T001, constructed in 2006, with a maximum capacity of 100,000 gallons. [40 CFR 60, Subpart Kb]
 - (2) One (1) 200 proof tank, identified as T002, constructed in 2006, with a maximum capacity of 100,000 gallons. [40 CFR 60, Subpart Kb]
 - (3) One (1) denaturant tank, identified as T003, constructed in 2006, with a maximum capacity of 100,000 gallons. [40 CFR 60, Subpart Kb] [326 IAC 8-4-3]
 - (4) Two (2) denatured ethanol tanks, identified as T004 and T005, constructed in 2006, each with a maximum capacity of 750,000 gallons. [40 CFR 60, Subpart Kb]

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-8-4(1)]

D.7.1 Volatile Organic Compounds (VOC) [326 IAC 8-9]

Pursuant to 326 IAC 8-4-3(d) (Petroleum Liquid Storage Facilities), the Permittee shall maintain the following records for a period of two (2) years for tank T003:

- (a) The types of volatile petroleum liquid stored;
- (b) The maximum true vapor pressure of the liquids as stored; and
- (c) The results of the inspections performed on the storage vessels.

The above records shall be made available to the IDEM, OAQ upon written request.

D.7.2 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]

The provisions of 40 CFR 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the facility described in this section except when otherwise specified in 40 CFR 60, Subpart Kb.

D.7.3 Storage Tanks [326 IAC 12][40 CFR 60, Subpart Kb]

Pursuant to 40 CFR 60, Subpart Kb, the Permittee shall install internal floating roofs with tanks T001 through T005 and the shall comply with the following requirements in 40 CFR 60.112b

(a)(1) for the internal floating roofs:

- (a) The internal floating roof shall rest or float on the liquid surface (but not necessarily in complete contact with it) inside a storage vessel that has a fixed roof. The internal floating roof shall be floating on the liquid surface at all times, except during initial fill and during

those intervals when the storage vessel is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible.

- (b) Each internal floating roof shall be equipped with one of the following closure devices between the wall of the storage vessel and the edge of the internal floating roof:
 - (1) A foam- or liquid-filled seal mounted in contact with the liquid (liquid-mounted seal). A liquid-mounted seal means a foam- or liquid-filled seal mounted in contact with the liquid between the wall of the storage vessel and the floating roof continuously around the circumference of the tank.
 - (2) Two seals mounted one above the other so that each forms a continuous closure that completely covers the space between the wall of the storage vessel and the edge of the internal floating roof. The lower seal may be vapor-mounted, but both must be continuous.
 - (3) A mechanical shoe seal. A mechanical shoe seal is a metal sheet held vertically against the wall of the storage vessel by springs or weighted levers and is connected by braces to the floating roof. A flexible coated fabric (envelope) spans the annular space between the metal sheet and the floating roof.
- (c) Each opening in a noncontact internal floating roof except for automatic bleeder vents (vacuum breaker vents) and the rim space vents is to provide a projection below the liquid surface.
- (d) Each opening in the internal floating roof except for leg sleeves, automatic bleeder vents, rim space vents, column wells, ladder wells, sample wells, and stub drains is to be equipped with a cover or lid which is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use.
- (e) Automatic bleeder vents shall be equipped with a gasket and are to be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports.
- (f) Rim space vents shall be equipped with a gasket and are to be set to open only when the internal floating roof is not floating or at the manufacturer's recommended setting.
- (g) Each penetration of the internal floating roof for the purpose of sampling shall be a sample well. The sample well shall have a slit fabric cover that covers at least 90 percent of the opening.
- (h) Each penetration of the internal floating roof that allows for passage of a column supporting the fixed roof shall have a flexible fabric sleeve seal or a gasketed sliding cover.
- (i) Each penetration of the internal floating roof that allows for passage of a ladder shall have a gasketed sliding cover.

D.7.4 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

A Preventive Maintenance Plan, in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for these facilities and any control devices.

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

D.7.5 Testing and Procedures [40 CFR 60, Subpart Kb] [326 IAC 12]

Pursuant to 40 CFR 60.113b, the Permittee shall comply with the following requirement:

- (a) Visually inspect the internal floating roof, the primary seal, and the secondary seal (if one is in service), prior to filling the storage vessel with VOL. If there are holes, tears, or other openings in the primary seal, the secondary seal, or the seal fabric or defects in the internal floating roof, or both, the owner or operator shall repair the items before filling the storage vessel.
- (b) For vessels equipped with a liquid-mounted or mechanical shoe primary seal, visually inspect the internal floating roof and the primary seal or the secondary seal (if one is in service) through manholes and roof hatches on the fixed roof at least once every 12 months after initial fill. If the internal floating roof is not resting on the surface of the VOL inside the storage vessel, or there is liquid accumulated on the roof, or the seal is detached, or there are holes or tears in the seal fabric, the owner or operator shall repair the items or empty and remove the storage vessel from service within 45 days. If a failure that is detected during inspections required in this paragraph cannot be repaired within 45 days and if the vessel cannot be emptied within 45 days, a 30-day extension may be requested from the Administrator in the inspection report required in 40 CFR 60.115b(a)(3). Such a request for an extension must document that alternate storage capacity is unavailable and specify a schedule of actions the company will take that will assure that the control equipment will be repaired or the vessel will be emptied as soon as possible.
- (c) For vessels equipped with a double-seal system as specified in 40 CFR 60.112b(a)(1)(ii)(B):
 - (1) Visually inspect the vessel as specified in paragraph (a)(4) of this section at least every 5 years; or
 - (2) Visually inspect the vessel as specified in 40 CFR 60.113(a)(2).
- (d) Visually inspect the internal floating roof, the primary seal, the secondary seal (if one is in service), gaskets, slotted membranes and sleeve seals (if any) each time the storage vessel is emptied and degassed. If the internal floating roof has defects, the primary seal has holes, tears, or other openings in the seal or the seal fabric, or the secondary seal has holes, tears, or other openings in the seal or the seal fabric, or the gaskets no longer close off the liquid surfaces from the atmosphere, or the slotted membrane has more than 10 percent open area, the owner or operator shall repair the items as necessary so that none of the conditions specified in this paragraph exist before refilling the storage vessel with VOL. In no event shall inspections conducted in accordance with this provision occur at intervals greater than 10 years in the case of vessels conducting the annual visual inspection as specified in 40 CFR 60.113(a)(2) and (a)(3)(ii) and at intervals no greater than 5 years in the case of vessels specified in 40 CFR 60.113(a)(3)(i).
- (e) Notify the IDEM, OAQ in writing at least 30 days prior to the filling or refilling of each storage vessel for which an inspection is required by 40 CFR 60.113(a)(1) and (a)(4) to afford IDEM, OAQ the opportunity to have an observer present. If the inspection required by 40 CFR 60.113 (a)(4) is not planned and the Permittee could not have known about the inspection 30 days in advance or refilling the tank, the Permittee shall notify the IDEM, OAQ at least seven (7) days prior to the refilling of the storage vessel. Notification shall be made by telephone immediately followed by written documentation demonstrating why the inspection was unplanned. Alternatively, this notification including the written documentation may be made in writing and sent by express mail so that it is received by the IDEM, OAQ at least seven (7) days prior to the refilling.

Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

D.7.6 Record Keeping Requirements

- (a) To document compliance with Condition D.7.1, the Permittee shall maintain the following records for tank T003:
 - (1) The types of volatile petroleum liquid stored;
 - (2) The maximum true vapor pressure of the liquids as stored; and
 - (3) The results of the inspections performed on the storage vessels.
- (b) Pursuant to 40 CFR 60.116b, the Permittee shall maintain the following records:
 - (1) The dimension of the storage vessel and an analysis showing the capacity of the storage vessel for the life of the source; and
 - (2) The VOL stored, the period of storage, and the maximum true vapor pressure of that VOL during the respective storage period, for at least 2 years.
- (c) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

SECTION E.1 40 CFR 60, Subpart VV - Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry

Emission Limitations and Standards [326 IAC 2-8-4(1)]

E.1.1 Standards: Pumps in Light Liquid Service [326 IAC 12][40 CFR 60, Subpart VV]

Pursuant to 40 CFR 60.482-2 (Standards: Pumps in Light Liquid Service), the Permittee shall comply with the following requirements:

- (a) Each pump in light liquid service shall:
 - (1) be monitored monthly to detect leaks by the methods specified in Condition E.1.9, except as provided in this condition; and
 - (2) be checked by visual inspection each calendar week for indications of liquids dripping from the pump seal.
- (b) If an instrument reading of 10,000 ppm or greater is measured, a leak is detected. If there are indications of liquids dripping from the pump seal, a leak is detected.
- (c) When a leak is detected, it shall be repaired as soon as practicable, but not later than 15 calendar days after it is detected, except as provided in Condition E.1.8. A first attempt at repair shall be made no later than 5 calendar days after each leak is detected.
- (d) Each pump equipped with a dual mechanical seal system that includes a barrier fluid system is exempt from the requirements of Condition E.1.1(a), provided the following requirements are met:
 - (1) Each dual mechanical seal system is:
 - (A) Operated with the barrier fluid at a pressure that is at all times greater than the pump stuffing box pressure; or
 - (B) Equipment with a barrier fluid degassing reservoir that is routed to a process or fuel gas system or connected by a closed vent system to a control device that complies with the requirements of Condition E.1.7; or
 - (C) Equipped with a system that purges the barrier fluid into a process stream with zero VOC emissions to the atmosphere.
 - (2) The barrier fluid system is in heavy liquid service or is not in VOC service.
 - (3) Each barrier fluid system is equipped with a sensor that will detect failure of the seal system, the barrier fluid system, or both.
 - (4) Each pump is checked by visual inspection, each calendar week, for indications of liquids dripping from the pump seals.
 - (5) The following requirements are met:
 - (A) Each sensor as described in Condition E.1.1(d)(3) is checked daily or is equipped with an audible alarm;
 - (B) The Permittee determines, based on design considerations and operating experience, a criterion that indicates failure of the seal system, the barrier fluid system, or both.

- (6) If there are indications of liquids dripping from the pump seal or the sensor indicates failure of the seal system, the barrier fluid system, or both based on the criterion determined in Condition E.1.1(d)(5)(B), a leak is detected. When a leak is detected, it shall be repaired as soon as practicable, but not later than 15 calendar days after it is detected, except as provided in Condition E.1.8. A first attempt at repair shall be made no later than 5 calendar days after each leak is detected.
- (e) Any pump that is designated, as described in Condition E.1.10(d)(1) and (d)(2), for no detectable emission, as indicated by an instrument reading of less than 500 ppm above background, is exempt from the requirements of Conditions E.1.1(a), (c), and (d) if the pump:
 - (1) Has no externally actuated shaft penetrating the pump housing,
 - (2) Is demonstrated to be operating with no detectable emissions as indicated by an instrument reading of less than 500 ppm above background as measured by the methods specified in Condition E.1.9(b), and
 - (3) Is tested for compliance with Condition E.1.1(e)(2) initially upon designation, annually, and at other times requested by the Administrator.
- (f) If any pump is equipped with a closed vent system capable of capturing and transporting any leakage from the seal or seals to a process or to a fuel gas system or to a control device that complies with the requirements of Condition E.1.7, it is exempt from Conditions E.1.1(a) through (e).
- (g) Any pump that is designated, as described in Condition E.1.10(e)(1), as an unsafe-to-monitor pump is exempt from the monitoring and inspection requirements of Conditions E.1.1(a) and (d)(4) through (d)(6) if:
 - (1) The Permittee demonstrates that the pump is unsafe-to-monitor because monitoring personnel would be exposed to an immediate danger as a consequence of complying with Condition E.1.1(a); and
 - (2) The Permittee has a written plan that requires monitoring of the pump as frequently as practicable during safe-to-monitor times but not more frequently than the periodic monitoring schedule otherwise applicable, and repair of the equipment according to the procedures in Condition E.1.1(c) if a leak is detected.
- (h) Any pump that is located within the boundary of an unmanned plant site is exempt from the weekly visual inspection requirement of Conditions E.1.1(a)(2) and (d)(4), and the daily requirements of Condition E.1.1(d)(5), provided that each pump is visually inspected as often as practicable and at least monthly.

E.1.2 Standards: Pressure Relief Devices in Gas/Vapor Service [326 IAC 12][40 CFR 60, Subpart VV]
Pursuant to 40 CFR 60.482-4 (Standards: Pressure Relief Devices in Gas/Vapor Service), the Permittee shall comply with the following requirements:

- (a) Except during pressure releases, each pressure relief device in gas/vapor service shall be operated with no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, as determined by the methods specified in Condition E.1.9(b).
- (b) After each pressure release, the pressure relief device shall be returned to a condition of no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, as soon as practicable, but no later than 5 calendar days after the pressure release, except as provided in Condition E.1.8. No later than 5 calendar days after the pressure release, the pressure relief device shall be monitored to confirm the

conditions of no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, by the methods specified in Condition E.1.9(b).

- (c) Any pressure relief device that is routed to a process or fuel gas system or equipped with a closed vent system capable of capturing and transporting leakage through the pressure relief device to a control device as described in Condition E.1.7 is exempted from the requirements of Conditions E.1.2(a) and (b).
- (d) Any pressure relief device that is equipped with a rupture disk upstream of the pressure relief device is exempt from the requirements of Conditions E.1.2(a) and (b), provided after each pressure release, a new rupture disk is installed upstream of the pressure relief device as soon as practicable, but no later than 5 calendar days after each pressure release, except as provided in Condition E.1.8.

E.1.3 Standards: Sampling Connection Systems [326 IAC 12][40 CFR 60, Subpart VV]

Pursuant to 40 CFR 60.482-5 (Standards: Sampling Connection Systems), the Permittee shall comply with the following requirements:

- (a) Each sampling connection system shall be equipped with a closed-purged, closed-loop, or closed-vent system. Gases displaced during filling of the sample container are not required to be collected or captured.
- (b) Each closed-purge, closed-loop, or closed-vent system as required in Condition E.1.3(a) shall comply with the following requirements:
 - (1) Return the purged process fluid directly to the process line; or
 - (2) Collect and recycle the purged process fluid to a process; or
 - (3) Be designed and operated to capture and transport all the purged process fluid to a control device that complies with the requirements of Condition E.1.7; or
 - (4) Collect, store, and transport the purged process fluid to any of the following systems or facilities:
 - (A) A waste management unit as defined in 40 CFR 63.111, if the waste management unit is subject to, and operated in compliance with the provisions of 40 CFR Part 63, Subpart G, applicable to Group 1 wastewater streams;
 - (B) A treatment, storage, or disposal facility subject to regulation under 40 CFR part 262, 264, 265, or 266; or
 - (C) A facility permitted, licensed, or registered by a State to manage municipal or industrial solid waste, if the process fluids are not hazardous waste as defined in 40 CFR Part 261.
- (c) In situ sampling systems and sampling systems without purges are exempt from the requirements of Conditions E.1.3(a) and (b).

E.1.4 Standards: Open-Ended Valves or Lines [326 IAC 12][40 CFR 60, Subpart VV]

Pursuant to 40 CFR 60.482-6 (Standards: Open-Ended Valves or Lines), the Permittee shall comply with the following requirements:

- (a) Each open-ended valve or line shall be equipped with a cap, blind flange, plug, or a second valve. The cap, blind flange, plug, or second valve shall seal the open end at all times except during operations requiring process fluid flow through the open-ended valve or line.

- (b) Each open-ended valve or line equipped with a second valve shall be operated in a manner such that the valve on the process fluid end is closed before the second valve is closed.
- (c) When a double block-and-bleed system is being used, the bleed valve or line may remain open during operations that require venting the line between the block valves but shall comply with Condition E.1.4(a) at all other times.
- (d) Open-ended valves or lines in an emergency shutdown system which are designed to open automatically in the event of a process upset are exempt from the requirements of Conditions E.1.4(a), (b) and (c).
- (e) Open-ended valves or lines containing materials which would autocatalytically polymerize or would present an explosion, serious overpressure, or other safety hazard if capped or equipped with a double block and bleed system as specified in Conditions E.1.4(a) through (c) are exempt from the requirements of Conditions E.1.4(a) through (c).

E.1.5 Standards: Valves in Gas/Vapor Service and in Light Liquid Service [326 IAC 12][40 CFR 60, Subpart VV]

Pursuant to 40 CFR 60.482-7 (Standards: Valves in Gas/Vapor Service and in Light Liquid Service), the Permittee shall comply with the following requirements:

- (a) Each valve shall be monitored monthly to detect leaks by the methods specified in Condition E.1.9(a) and shall comply with Conditions E.1.5(b) through (e), except as provided in Conditions E.1.5(f), (g), and (h).
- (b) If an instrument reading of 10,000 ppm or greater is measured, a leak is detected.
- (c) Any valve for which a leak is not detected for 2 successive months may be monitored the first month of every quarter, beginning with the next quarter, until a leak is detected. If a leak is detected, the valve shall be monitored monthly until a leak is not detected for 2 successive months.
- (d) When a leak is detected, it shall be repaired as soon as practicable, but no later than 15 calendar days after the leak is detected, except as provided in Condition E.1.8. A first attempt at repair shall be made no later than 5 calendar days after each leak is detected.
- (e) First attempts at repair include, but are not limited to, the following best practices where practicable:
 - (1) Tightening of bonnet bolts;
 - (2) Replacement of bonnet bolts;
 - (3) Tightening of packing gland nuts;
 - (4) Injection of lubricant into lubricated packing.
- (f) Any valve that is designated, as described in Condition E.1.10(d)(2), for no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, is exempt from the requirements of Condition E.1.5(a) if the valve:
 - (1) Has no external actuating mechanism in contact with the process fluid,
 - (2) Is operated with emissions less than 500 ppm above background as determined by the method specified in Condition E.1.9(b), and
 - (3) Is tested for compliance with Condition E.1.5(f)(2) of this section initially upon designation, annually, and at other times requested by the Administrator.

- (g) Any valve that is designated, as described in Condition E.1.10(e)(1), as an unsafe-to-monitor valve is exempt from the requirements of Condition E.1.5(a) if:
 - (1) The Permittee demonstrates that the valve is unsafe to monitor because monitoring personnel would be exposed to an immediate danger as a consequence of complying with Condition E.1.5(a), and
 - (2) The Permittee of the valve adheres to a written plan that requires monitoring of the valve as frequently as practicable during safe-to-monitor times.
- (h) Any valve that is designated, as described in Condition E.1.10(e)(2), as a difficult-to-monitor valve is exempt from the requirements of Condition E.1.5(a) if:
 - (1) The Permittee demonstrates that the valve cannot be monitored without elevating the monitoring personnel more than 2 meters above a support surface.
 - (2) The process unit within which the valve is located either becomes an affected facility through 40 CFR 60.14 or 40 CFR 60.15 or the Permittee designates less than 3.0 percent of the total number of valves as difficult-to-monitor, and
 - (3) The Permittee follows a written plan that requires monitoring of the valve at least once per calendar year.

E.1.6 Standards: Pumps and Valves in Heavy Liquid Service, Pressure Relief Devices in Light Liquid or Heavy Liquid Service, and Connectors [326 IAC 12][40 CFR 60, Subpart VV]

Pursuant to 40 CFR 60.482-8 (Standards: Pumps and Valves in Heavy Liquid Service, Pressure Relief Devices in Light Liquid or Heavy Liquid Service, and Connectors), the Permittee shall comply with the following requirements:

- (a) If evidence of a potential leak is found by visual, audible, olfactory, or any other detection method at pumps and valves in heavy liquid service, pressure relief devices in light liquid or heavy liquid service, and connectors, the Permittee shall follow either one of the following procedures:
 - (1) The Permittee shall monitor the equipment within 5 days by the method specified in Condition E.1.9(a) and shall comply with the requirements of Conditions E.1.6(b) through (d).
 - (2) The Permittee shall eliminate the visual, audible, olfactory, or other indication of a potential leak.
- (b) If an instrument reading of 10,000 ppm or greater is measured, a leak is detected.
- (c) When a leak is detected, it shall be repaired as soon as practicable, but not later than 15 calendar days after it is detected, except as provided in Condition E.1.8. The first attempt at repair shall be made no later than 5 calendar days after each leak is detected.
- (d) First attempts at repair include, but are not limited to, the best practices described under Condition E.1.5(e).

E.1.7 Standards: Closed Vent Systems and Control Devices [326 IAC 12][40 CFR 60, Subpart VV]

Pursuant to 40 CFR 60.482-10 (Standards: Closed Vent Systems and Control Devices), the Permittee shall comply with the following requirements:

- (a) For closed vent systems and control devices used to comply with the provisions of 40 CFR 60, Subpart VV, the Permittee shall comply with the provisions of this Condition.

- (b) Vapor recovery systems (for example, condensers and absorbers) shall be designed and operated to recover the VOC emissions vented to them with an efficiency of 95 percent or greater, or to an exit concentration of 20 parts per million by volume, whichever is less stringent.
- (c) Enclosed combustion devices shall be designed and operated to reduce the VOC emissions vented to them with an efficiency of 95 percent or greater, or to an exit concentration of 20 parts per million by volume, on a dry basis, corrected to 3 percent oxygen, whichever is less stringent or to provide a minimum residence time of 0.75 seconds at a minimum temperature of 816 °C.
- (d) Flares used to comply with this subpart shall comply with the requirements of 40 CFR 60.18.
- (e) For control devices used to comply with the provisions of 40 CFR 60, Subpart VV, the Permittee shall monitor these control devices to ensure that they are operated and maintained in conformance with their designs.
- (f) Except as provided in Conditions E.1.7(i) through (k), each closed vent system shall be inspected according to the procedures and schedule specified below:
 - (1) If the vapor collection system or closed vent system is constructed of hard-piping, the Permittee shall comply with the requirements specified in Conditions E.1.7(f)(1)(A) and (f)(1)(B):
 - (A) Conduct an initial inspection according to the procedures in Condition E.1.9(a); and
 - (B) Conduct annual visual inspections for visible, audible, or olfactory indications of leaks.
 - (2) If the vapor collection system or closed vent system is constructed of ductwork, the Permittee shall:
 - (A) Conduct an initial inspection according to the procedures in Condition E.1.9(a); and
 - (B) Conduct annual inspections according to the procedures in Condition E.1.9(a).
- (g) Leaks, as indicated by an instrument reading greater than 500 parts per million by volume above background or by visual inspections, shall be repaired as soon as practicable except as provided in Condition E.1.7(h).
 - (1) A first attempt at repair shall be made no later than 5 calendar days after the leak is detected.
 - (2) Repair shall be completed no later than 15 calendar days after the leak is detected.
- (h) Delay of repair of a closed vent system for which leaks have been detected is allowed if the repair is technically infeasible without a process unit shutdown or if the Permittee determines that emissions resulting from immediate repair would be greater than the fugitive emissions likely to result from delay of repair. Repair of such equipment shall be complete by the end of the next process unit shutdown.
- (i) If a vapor collection system or closed vent system is operated under a vacuum, it is exempt from the inspection requirements of Condition E.1.7(f)(1)(A) and (f)(2).

- (j) Any parts of the closed vent system that are designated, as described in Condition E.1.7(l)(1), as unsafe to inspect are exempt from the inspection requirements of Conditions E.1.7(f)(1)(A) and (f)(2) if they comply with the following requirements:
 - (1) The Permittee determines that the equipment is unsafe to inspect because inspecting personnel would be exposed to an imminent or potential danger as a consequence of complying with Conditions E.1.7(f)(1)(A) or (f)(2); and
 - (2) The Permittee has a written plan that requires inspection of the equipment as frequently as practicable during safe-to-inspect times.
- (k) Any parts of the closed vent system that are designated, as described in Condition E.1.7(l)(2), as difficult to inspect are exempt from the inspection requirements of Conditions E.1.7(f)(1)(A) and (f)(2) if they comply with the requirements specified below:
 - (1) The Permittee determines that the equipment cannot be inspected without elevating the inspecting personnel more than 2 meters above a support surface; and
 - (2) The Process unit within which the closed vent system is located becomes an affected facility through 40 CFR 60.14 and 60.15, or the Permittee designates less than 3.0 percent of the total number of closed vent system equipment as difficult to inspect; and
 - (3) The Permittee has a written plan that requires inspection of the equipment at least once every 5 years. A closed vent system is exempt from inspection if it is operated under a vacuum.
- (l) The Permittee shall record the information specified below:
 - (1) Identification of all parts of the closed vent system that are designated as unsafe to inspect, an explanation of why the equipment is unsafe to inspect, and the plan for inspecting the equipment.
 - (2) Identification of all parts of the closed vent system that are designated as difficult to inspect, an explanation of why the equipment is difficult to inspect, and the plan for inspecting the equipment.
 - (3) For each inspection during which a leak is detected, a record of the information specified in Condition E.1.10(b).
 - (4) For each inspection conducted in accordance with Condition E.1.9(a) during which no leaks are detected, a record that the inspection was performed, the date of the inspection, and a statement that no leaks were detected.
 - (5) For each visual inspection conducted in accordance with Condition E.1.7(f)(1)(B) during which no leaks are detected, a record that the inspection was performed, the date of the inspection, and a statement that no leaks were detected.
- (m) Closed vent systems and control devices used to comply with provisions of 40 CFR 60, Subpart VV shall be operated at all times when emissions may be vented to them.

E.1.8 Standards: Delay of Repair [326 IAC 12][40 CFR 60, Subpart VV]

Pursuant to 40 CFR 60.482-9 (Standards: Delay of Repair), the Permittee shall comply with the following requirements:

- (a) Delay of repair of equipment for which leaks have been detected will be allowed if repair within 15 days is technically infeasible without a process unit shutdown. Repair of this equipment shall occur before the end of the next process unit shutdown.

- (b) Delay of repair of equipment will be allowed for equipment which is isolated from the process and which does not remain in VOC service.
- (c) Delay of repair for valves will be allowed if:
 - (1) The Permittee demonstrates that emissions of purged material resulting from immediate repair are greater than the fugitive emissions likely to result from delay of repair, and
 - (2) When repair procedures are effected, the purged material is collected and destroyed or recovered in a control device complying with Condition E.1.7.
- (d) Delay of repair for pumps will be allowed if:
 - (1) Repair requires the use of a dual mechanical seal system that includes a barrier fluid system, and
 - (2) Repair is completed as soon as practicable, but not later than 6 months after the leak was detected.
- (e) Delay of repair beyond a process unit shutdown will be allowed for a valve, if valve assembly replacement is necessary during the process unit shutdown, valve assembly supplies have been depleted, and valve assembly supplies had been sufficiently stocked before the supplies were depleted. Delay of repair beyond the next process unit shutdown will not be allowed unless the next process unit shutdown occurs sooner than 6 months after the first process unit shutdown.

Compliance Determination Requirements

E.1.9 Test Methods and Procedures [326 IAC 12][40 CFR 60, Subpart VV]

Pursuant to 40 CFR 60.485 (Test Methods and Procedures), the Permittee shall comply with the following requirements:

- (a) The Permittee shall determine compliance with the standards in Conditions E.1.1 through E.1.8 as follows:
 - (1) Method 21 shall be used to determine the presence of leaking sources. The instrument shall be calibrated before use each day of its use by the procedures specified in Method 21. The following calibration gases shall be used:
 - (A) Zero air (less than 10 ppm of hydrocarbon in air); and
 - (B) A mixture of methane or n-hexane and air at a concentration of about, but less than, 10,000 ppm methane or n-hexane.
- (b) The Permittee shall determine compliance with the no detectable emission standards in Conditions E.1.1(e), E.1.2, and E.1.5(f) as follows:
 - (1) The requirements of Condition E.1.10(a) shall apply.
 - (2) Method 21 shall be used to determine the background level. All potential leak interfaces shall be traversed as close to the interface as possible. The arithmetic difference between the maximum concentration indicated by the instrument and the background level is compared with 500 ppm for determining compliance.
- (c) The Permittee shall test each piece of equipment unless he demonstrates that a process unit is not in VOC service, i.e., that the VOC content would never be reasonably expected

to exceed 10 percent by weight. For purposes of this demonstration, the following methods and procedures shall be used:

- (1) Procedures that conform to the general methods in ASTM E260-73, 91, or 96, E168-67, 77, or 92, E169-63, 77, or 93 (incorporated by reference in 40 CFR 60.17) shall be used to determine the percent VOC content in the process fluid that is contained in or contacts a piece of equipment.
 - (2) Organic compounds that are considered by the Administrator to have negligible photochemical reactivity may be excluded from the total quantity of organic compounds in determining the VOC content of the process fluid.
 - (3) Engineering judgment may be used to estimate the VOC content, if a piece of equipment had not been shown previously to be in service. If the Administrator disagrees with the judgment, Conditions E.1.9(c) (1) and (2) shall be used to resolve the disagreement.
- (d) The Permittee shall demonstrate that equipment is in light liquid service by showing that all the following conditions apply:
- (1) The vapor pressure of one or more of the components is greater than 0.3 kPa at 20 °C (1.2 in. H₂O at 68°F). Standard reference texts or ASTM D2879-83, 96, or 97 (incorporated by reference in 40 CFR 60.17) shall be used to determine the vapor pressures.
 - (2) The total concentration of the pure components having a vapor pressure greater than 0.3 kPa at 20 °C (1.2 in. H₂O at 68 °F) is equal to or greater than 20 percent by weight.
 - (3) The fluid is a liquid at operating conditions.
- (e) Samples used in conjunction with Conditions E.1.9(c), (d), and (f) shall be representative of the process fluid that is contained in or contacts the equipment or the gas being combusted in the flare.
- (f) The Permittee shall determine compliance with the standards of flares as follows:
- (1) Method 22 shall be used to determine visible emissions.
 - (2) A thermocouple or any other equivalent device shall be used to monitor the presence of a pilot flame in the flare.
 - (3) The maximum permitted velocity for air assisted flares shall be computed using the following equation:

$$V_{\max} = K_1 + K_2 H_T$$

Where:

- V_{\max} = Maximum permitted velocity, m/sec (ft/sec)
 H_T = Net heating value of the gas being combusted, MJ/scm (Btu/scf).
 K_1 = 8.706 m/sec (metric units) = 28.56 ft/sec (English units)
 K_2 = 0.7084 m⁴/(MJ-sec) (metric units) = 0.087 ft⁴/(Btu-sec) (English units)

- (4) The net heating value (H_T) of the gas being combusted in a flare shall be computed using the following equation:

$$H_T = k \sum_{i=1}^n C_i H_i$$

Where:

- K = Conversion constant, 1.740×10^7 (g-mole)(MJ)/ (ppm-scm-kcal)
(metric units) = 4.674×10^8 [(g-mole)(Btu)/(ppm-scf-kcal)]
(English units)
C_i = Concentration of sample component "i," ppm
H_i = net heat of combustion of sample component "i" at 25°C and 760
mm Hg (77°F and 14.7 psi), kcal/g-mole

- (5) Method 18 and ASTM D2504-67, 77, or 88 (Reapproved 1993) (incorporated by reference in 40 CFR 60.17) shall be used to determine the concentration of sample component "i."
- (6) ASTM D2382-76 or 88 or D4809-95 (incorporated by reference in 40 CFR 60.17) shall be used to determine the net heat of combustion of component "i" if published values are not available or cannot be calculated.
- (7) Method 2, 2A, 2C, or 2D, as appropriate, shall be used to determine the actual exit velocity of a flare. If needed, the unobstructed (free) cross-sectional area of the flare tip shall be used.

Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

E.1.10 Recordkeeping Requirements [326 IAC 12][40 CFR 60, Subpart VV]

Pursuant to 40 CFR 60.486 (Recordkeeping Requirements), the Permittee shall comply with the following requirements:

- (a) When each leak is detected as specified in Conditions E.1.1, E.1.5, and E.1.6, the following requirements apply:
 - (1) A weatherproof and readily visible identification, marked with the equipment identification number, shall be attached to the leaking equipment.
 - (2) The identification on a valve may be removed after it has been monitored for 2 successive months as specified in Condition E.1.5(c) and no leak has been detected during those 2 months.
 - (3) The identification on equipment except on a valve, may be removed after it has been repaired.
- (b) When each leak is detected as specified in Conditions E.1.1, E.1.5, and E.1.6, the following information shall be recorded in a log in a readily accessible location:
 - (1) The instrument and operator identification numbers and the equipment identification number.
 - (2) The date the leak was detected and the dates of each attempt to repair the leak.
 - (3) Repair methods applied in each attempt to repair the leak.
 - (4) "Above 10,000" if the maximum instrument reading measured by the methods specified in Condition E.1.9(a) after each repair attempt is equal to or greater than 10,000 ppm.
 - (5) "Repair delayed" and the reason for the delay if a leak is not repaired within 15 calendar days after discovery of the leak.
 - (6) The signature of the employee whose decision it was that repair could not be effected without a process shutdown.

- (7) The expected date of successful repair of the leak if a leak is not repaired within 15 days.
 - (8) Dates of process unit shutdowns that occur while the equipment is unrepaired.
 - (9) The date of successful repair of the leak.
- (c) The following information pertaining to the design requirements for closed vent systems and control devices described in Condition E.1.7 shall be recorded and kept in a readily accessible location:
- (1) Detailed schematics, design specifications, and piping and instrumentation diagrams.
 - (2) The dates and descriptions of any changes in the design specifications.
 - (3) A description of the parameter or parameters monitored, as required in Condition E.1.7(e), to ensure that control devices are operated and maintained in conformance with their design and an explanation of why that parameter (or parameters) was selected for the monitoring.
 - (4) Periods when the closed vent systems and control devices required in Conditions E.1.1, E.1.2, and E.1.3 are not operated as designed, including periods when a flare pilot light does not have a flame.
 - (5) Dates of startups and shutdowns of the closed vent systems and control devices required in Conditions E.1.1, E.1.2, and E.1.3.
- (d) The following information pertaining to all equipment subject to the requirements in Conditions E.1.1 through E.1.8 and 40 CFR 60.482-1 shall be recorded in a log that is kept in a readily accessible location:
- (1) A list of identification numbers for equipment subject to the requirements of 40 CFR 60, Subpart VV.
 - (2) A list of identification numbers for equipment that are designated for no detectable emissions under the provisions of Conditions E.1.1(e) and E.1.5(f) and the designation of equipment as subject to the requirements of Conditions E.1.1(e) or E.1.5(f) shall be signed by the Permittee.
 - (3) A list of equipment identification numbers for pressure relief devices required to comply with Condition E.1.2.
 - (4) The following information:
 - (A) The dates of each compliance test as required in Conditions E.1.1(e), E.1.2, and E.1.5(f);
 - (B) The background level measured during each compliance test;
 - (C) The maximum instrument reading measured at the equipment during each compliance test.
 - (5) A list of identification numbers for equipment in vacuum service.
- (e) The following information pertaining to all valves subject to the requirements of Conditions E.1.5(g) and (h) and to all pumps subject to the requirements of Conditions E.1.1(g) shall be recorded in a log that is kept in a readily accessible location:

- (1) A list of identification numbers for valves and pumps that are designated as unsafe-to-monitor, an explanation for each valve or pump stating why the valve or pump is unsafe-to-monitor, and the plan for monitoring each valve or pump.
 - (2) A list of identification numbers for valves that are designated as difficult-to-monitor, an explanation for each valve stating why the valve is difficult-to-monitor, and the schedule for monitoring each valve.
- (f) The following information shall be recorded for valves complying with Condition E.1.1:
- (1) A schedule of monitoring.
 - (2) The percent of valves found leaking during each monitoring period.
- (g) The following information shall be recorded in a log that is kept in a readily accessible location:
- (1) Design criterion required in Conditions E.1.1(d)(5) and explanation of the design criterion; and
 - (2) Any changes to this criterion and the reasons for the changes.
- (h) Information and data used to demonstrate that a piece of equipment is not in VOC service shall be recorded in a log that is kept in a readily accessible location.
- (i) The provisions of 40 CFR 60.7 (b) and (d) do not apply to affected facilities subject to this subpart.

E.1.11 Reporting Requirements [326 IAC 12][40 CFR 60, Subpart VV]

Pursuant to 40 CFR 60.487 (Reporting Requirements), the Permittee shall comply with the following requirements:

- (a) The Permittee shall submit semiannual reports to the Administrator.
- (b) All semiannual reports to IDEM, OAQ shall include the following information, summarized from the information required in Condition E.1.10.
 - (1) Process unit identification.
 - (2) For each month during the semiannual reporting period,
 - (A) Number of valves for which leaks were detected as described in Condition E.1.5(b),
 - (B) Number of valves for which leaks were not repaired as required in Condition E.1.5(d),
 - (C) Number of pumps for which leaks were detected as described in Conditions E.1.1(b) and E.1.1(d)(6),
 - (D) Number of pumps for which leaks were not repaired as required in Conditions E.1.1(c) and E.1.1(d)(6),
 - (E) The facts that explain each delay of repair and, where appropriate, why a process unit shutdown was technically infeasible.
 - (3) Dates of process unit shutdowns which occurred within the semiannual reporting period.

- (c) Revisions to items reported in the initial semiannual report if changes have occurred since the initial report or subsequent revisions to the initial report.

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT OFFICE OF AIR QUALITY

FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP) CERTIFICATION

Source Name: Central Indiana Ethanol, LLC.
Source Address: 2955 W. Delphi Pike, Marion, Indiana 46952
Mailing Address: 2955 W. Delphi Pike, Marion, Indiana 46952
FESOP No.: F053-21057-00062

**This certification shall be included when submitting monitoring, testing reports/results
or other documents as required by this permit.**

Please check what document is being certified:

- Annual Compliance Certification Letter
- Test Result (specify) _____
- Report (specify) _____
- Notification (specify) _____
- Affidavit (specify) _____
- Other (specify) _____

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Signature:

Printed Name:

Title/Position:

Date:

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE BRANCH
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251
Phone: 317-233-0178
Fax: 317-233-6865**

**FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP)
EMERGENCY OCCURRENCE REPORT**

Source Name: Central Indiana Ethanol, LLC.
Source Address: 2955 W. Delphi Pike, Marion, Indiana 46952
Mailing Address: 2955 W. Delphi Pike, Marion, Indiana 46952
FESOP No.: F053-21057-00062

This form consists of 2 pages

Page 1 of 2

- This is an emergency as defined in 326 IAC 2-7-1(12)
- The Permittee must notify the Office of Air Quality (OAQ), within four (4) business hours (1-800-451-6027 or 317-233-0178, ask for Compliance Section); and
 - The Permittee must submit notice in writing or by facsimile within two (2) working days (Facsimile Number: 317-233-6865), and follow the other requirements of 326 IAC 2-7-16

If any of the following are not applicable, mark N/A

Facility/Equipment/Operation:

Control Equipment:

Permit Condition or Operation Limitation in Permit:

Description of the Emergency:

Describe the cause of the Emergency:

If any of the following are not applicable, mark N/A

Page 2 of 2

Date/Time Emergency started:
Date/Time Emergency was corrected:
Was the facility being properly operated at the time of the emergency? Y N Describe:
Type of Pollutants Emitted: PM, PM10, SO ₂ , VOC, NO _x , CO, Pb, other:
Estimated amount of pollutant(s) emitted during emergency:
Describe the steps taken to mitigate the problem:
Describe the corrective actions/response steps taken:
Describe the measures taken to minimize emissions:
If applicable, describe the reasons why continued operation of the facilities are necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw materials of substantial economic value:

Form Completed by: _____
Title / Position: _____
Date: _____
Phone: _____

A certification is not required for this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE DATA SECTION**

FESOP Quarterly Report

Source Name: Central Indiana Ethanol, LLC.
Source Address: 2955 W. Delphi Pike, Marion, Indiana 46952
Mailing Address: 2955 W. Delphi Pike, Marion, Indiana 46952
FESOP No.: F053-21057-00062
Facility: DDGS Cooler (EU036)
Parameter: DDGS Production Rate
Limit: Less than 210,000 tons per twelve (12) consecutive month period with compliance determined at the end of each month.

YEAR: _____

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

No deviation occurred in this quarter.

Deviation/s occurred in this quarter.

Deviation has been reported on: _____

Submitted by: _____

Title / Position: _____

Signature: _____

Date: _____

Phone: _____

Attach a signed certification to complete this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE DATA SECTION**

FESOP Quarterly Report

Source Name: Central Indiana Ethanol, LLC.
Source Address: 2955 W. Delphi Pike, Marion, Indiana 46952
Mailing Address: 2955 W. Delphi Pike, Marion, Indiana 46952
FESOP No.: F053-21057-00062
Facility: Ethanol Loading Racks (EU045A and EU045B)
Parameter: Total combined denatured ethanol and blended ethanol loadout rate
Limit: Less than 64,900,000 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.

YEAR: _____

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

No deviation occurred in this quarter.

Deviation/s occurred in this quarter.

Deviation has been reported on: _____

Submitted by: _____
Title / Position: _____
Signature: _____
Date: _____
Phone: _____

Attach a signed certification to complete this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE DATA SECTION**

FESOP Quarterly Report

Source Name: Central Indiana Ethanol, LLC.
Source Address: 2955 W. Delphi Pike, Marion, Indiana 46952
Mailing Address: 2955 W. Delphi Pike, Marion, Indiana 46952
FESOP No.: F053-21057-00062
Facility: Ethanol Loading Racks (EU045A and EU045B)
Parameter: Total denaturant used
Limit: Less than 4,900,000 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.

YEAR: _____

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

No deviation occurred in this quarter.

Deviation/s occurred in this quarter.

Deviation has been reported on: _____

Submitted by: _____

Title / Position: _____

Signature: _____

Date: _____

Phone: _____

Attach a signed certification to complete this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE DATA SECTION**

FESOP Quarterly Report

Source Name: Central Indiana Ethanol, LLC.
Source Address: 2955 W. Delphi Pike, Marion, Indiana 46952
Mailing Address: 2955 W. Delphi Pike, Marion, Indiana 46952
FESOP No.: F053-21057-00062
Facility: Ethanol Loading Rack (EU045B)
Parameter: Total denatured ethanol load-out into non-dedicated railcars
Limit: Less than 2,500,000 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.

YEAR: _____

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

No deviation occurred in this quarter.

Deviation/s occurred in this quarter.

Deviation has been reported on: _____

Submitted by: _____

Title / Position: _____

Signature: _____

Date: _____

Phone: _____

Attach a signed certification to complete this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE DATA SECTION**

FESOP Quarterly Report

Source Name: Central Indiana Ethanol, LLC.
Source Address: 2955 W. Delphi Pike, Marion, Indiana 46952
Mailing Address: 2955 W. Delphi Pike, Marion, Indiana 46952
FESOP No.: F053-21057-00062
Facility: Diesel Fire Pump (EU034)
Parameter: Operating Hours
Limit: Less than 500 hours per twelve (12) consecutive month period with compliance determined at the end of each month.

YEAR: _____

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

No deviation occurred in this quarter.

Deviation/s occurred in this quarter.

Deviation has been reported on: _____

Submitted by: _____

Title / Position: _____

Signature: _____

Date: _____

Phone: _____

Attach a signed certification to complete this report.

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT OFFICE OF AIR QUALITY COMPLIANCE DATA SECTION

FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP) QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT

Source Name: Central Indiana Ethanol, LLC.
Source Address: 2955 W. Delphi Pike, Marion, Indiana 46952
Mailing Address: 2955 W. Delphi Pike, Marion, Indiana 46952
FESOP No.: F053-21057-00062

Months: _____ to _____ Year: _____

Page 1 of 2

<p>This report shall be submitted quarterly based on a calendar year. Any deviation from the requirements, the date(s) of each deviation, the probable cause of the deviation, and the response steps taken must be reported. A deviation required to be reported pursuant to an applicable requirement that exists independent of the permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. Additional pages may be attached if necessary. If no deviations occurred, please specify in the box marked "No deviations occurred this reporting period".</p>	
<p><input type="checkbox"/> NO DEVIATIONS OCCURRED THIS REPORTING PERIOD.</p>	
<p><input type="checkbox"/> THE FOLLOWING DEVIATIONS OCCURRED THIS REPORTING PERIOD</p>	
<p>Permit Requirement (specify permit condition #)</p>	
<p>Date of Deviation:</p>	<p>Duration of Deviation:</p>
<p>Number of Deviations:</p>	
<p>Probable Cause of Deviation:</p>	
<p>Response Steps Taken:</p>	
<p>Permit Requirement (specify permit condition #)</p>	
<p>Date of Deviation:</p>	<p>Duration of Deviation:</p>
<p>Number of Deviations:</p>	
<p>Probable Cause of Deviation:</p>	
<p>Response Steps Taken:</p>	

Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	

Form Completed By: _____

Title/Position: _____

Date: _____

Phone: _____

Attach a signed certification to complete this report.

Appendix A: Emission Calculations
 PM and PM10 Emissions
 From the Grain Receiving and Handling Operations

Company Name: Central Indiana Ethanol, LLC
 Address: 2955 W. Delphi Pike Marion, IN 46952
 Amendment: 053-26544-00062
 Reviewer: Janet Mobley
 Date: June 3, 2008

Potential to Emit PM/PM10 - Captured Emissions:

Baghouse ID	Process Description	Control Device	Outlet Grain Loading (gr/dscf)	Maximum Air Flow Rate (scfm)	PTE of PM/PM10 after Control (lbs/hr)	PTE of PM/PM10 after Control (tons/yr)	Control Efficiency (%)	PTE of PM/PM10 before Control (tons/yr)
CE001	Grain Receiving and Handling EU001- EU007 and EU064	Baghouse	0.005	39,000	1.67	7.32	99%	732
CE003	Hammermills EU010 and EU011	Baghouse	0.005	28,000	1.20	5.26	99%	526
Total						12.6		1,258

Assume all PM emissions equal PM10 emissions.

Methodology

$PTE\ of\ PM/PM10\ after\ Control\ (lbs/hr) = Grain\ Loading\ (gr/dscf) \times Max.\ Air\ Flow\ Rate\ (scfm) \times 60\ mins/hr \times 1/7000\ lb/gr$

$PTE\ of\ PM/PM10\ after\ Control\ (tons/yr) = Grain\ Loading\ (gr/dscf) \times Max.\ Air\ Flow\ Rate\ (scfm) \times 60\ mins/hr \times 1/7000\ lb/gr \times 8760\ hr/yr \times 1\ ton/2000\ lbs$

$PTE\ of\ PM/PM10\ before\ Control\ (tons/yr) = PTE\ of\ PM/PM10\ after\ Control\ (tons/yr) / (1 - Control\ Efficiency)$