



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

TO: Interested Parties / Applicant

DATE: April 8, 2009

RE: Pendleton Correctional / 095 - 27581 - 00006

FROM: Matthew Stuckey, Branch Chief
Permits Branch
Office of Air Quality

Notice of Decision – Approval

Please be advised that on behalf of the Commissioner of the Department of Environmental Management, I have issued a decision regarding the enclosed matter. Pursuant to 326 IAC 2, this approval was effective immediately upon submittal of the application.

If you wish to challenge this decision, IC 4-21.5-3-7 requires that you file a petition for administrative review. This petition may include a request for stay of effectiveness and must be submitted to the Office of Environmental Adjudication, 100 North Senate Avenue, Government Center North, Suite N 501E, Indianapolis, IN 46204, **within eighteen (18) calendar days from the mailing of this notice.** The filing of a petition for administrative review is complete on the earliest of the following dates that apply to the filing:

- (1) the date the document is delivered to the Office of Environmental Adjudication (OEA);
- (2) the date of the postmark on the envelope containing the document, if the document is mailed to OEA by U.S. mail; or
- (3) The date on which the document is deposited with a private carrier, as shown by receipt issued by the carrier, if the document is sent to the OEA by private carrier.

The petition must include facts demonstrating that you are either the applicant, a person aggrieved or adversely affected by the decision or otherwise entitled to review by law. Please identify the permit, decision, or other order for which you seek review by permit number, name of the applicant, location, date of this notice and all of the following:

- (1) the name and address of the person making the request;
- (2) the interest of the person making the request;
- (3) identification of any persons represented by the person making the request;
- (4) the reasons, with particularity, for the request;
- (5) the issues, with particularity, proposed for considerations at any hearing; and
- (6) identification of the terms and conditions which, in the judgment of the person making the request, would be appropriate in the case in question to satisfy the requirements of the law governing documents of the type issued by the Commissioner.

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178. Callers from within Indiana may call toll-free at 1-800-451-6027, ext. 3-0178.

Enclosures
FNPER-AM.dot12/3/07



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

Mr. Charles Rinehart
Pendleton Correctional Facility
4490 W. Reformatory Road
Pendleton, Indiana 46064

April 8, 2009

Re: 095-27581-00006
First Administrative Amendment to
F095-16603-00006

Dear Mr. Rinehart:

Pendleton Correctional Facility (Permittee) was issued a Federally Enforceable State Operating Permit Renewal (FESOP) No. F095-16603-00006 on October 28, 2003 for a stationary correctional facility located at 4490 West Reformatory Road, Pendleton, Indiana 46064. On March 6, 2009, the Office of Air Quality (OAQ) received an application from the source requesting that the permit be revised to remove all requirements related to local air pollution control agencies. Local agencies no longer have effective authority to implement state and federal requirements for IDEM. Therefore, IDEM has removed all references to local agencies from the permit. IDEM has determined that this change to the permit will be processed as an administrative amendment pursuant to 326 IAC 2-8-10.

The revised permit specifies that all reports, notices, applications, and any other required submittals shall be submitted to IDEM. The Permittee should note that the local agency could have its own requirements beyond the state and federal requirements contained in the permit. Please contact the local agency for further information.

Pursuant to the provisions of 326 IAC 2-8-10, the permit is hereby administratively amended as follows with the deleted language as ~~strikeouts~~ and new language **bolded**.

1. All references to local agencies have been removed from the permit.
2. The following conditions have been revised to clarify the requirements of the permit.

B.4 Enforceability [326 IAC 2-8-6]

- (a) Unless otherwise stated, all terms and conditions in this permit, including any provisions designed to limit the source's potential to emit, are enforceable by IDEM and AAMD, the United States Environmental Protection Agency (U.S. EPA) and by citizens in accordance with the Clean Air Act.
- (b) ~~Unless otherwise stated, all terms and conditions in this permit that are local requirements, including any provisions designed to limit the source's potential to emit, are enforceable by AAMD.~~
3. Several of IDEM's branches and sections have been renamed. Therefore, IDEM has updated the addresses listed in the permit. References to "Permit Administration and Development Section" and the "Permits Branch" have been changed to "Permit Administration and Support Section". References to "Asbestos Section", "Compliance Data Section", "Air Compliance Section", and "Compliance Branch" have been changed to "Compliance and Enforcement Branch". The permit has been revised as follows:

Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

All other conditions of the permit shall remain unchanged and in effect. Attached please find the entire revised permit. A copy of the permit is available on the Internet at: <http://www.in.gov/ai/appfiles/idem-caats/>. For additional information about air permits and how the public and interested parties can participate, refer to the IDEM's Guide for Citizen Participation and Permit Guide on the Internet at: www.idem.in.gov

This decision is subject to the Indiana Administrative Orders and Procedures Act - IC 4-21.5-3-5. If you have any questions on this matter, please contact Gary Freeman, of my staff, at 317-233-5334 or 1-800-451-6027, and ask for extension 3-5334.

Sincerely,



Alfred C. Dumauval, Ph. D., Section Chief
Permits Branch
Office of Air Quality

Attachments: Updated Permit

ACD/gkf

cc: File - Madison County
Madison County Health Department
U.S. EPA, Region V
Compliance and Enforcement Branch
Billing, Licensing and Training Section



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP) RENEWAL OFFICE OF AIR QUALITY

**Pendleton Correctional Facility
4490 West Reformatory Rd
Pendleton, Indiana 46064**

(herein known as the Permittee) is hereby authorized to operate subject to the conditions contained herein, the source described in Section A (Source Summary) of this permit.


The Permittee must comply with all conditions of this permit. Noncompliance with any provision of this permit is grounds for enforcement action; permit termination, revocation and reissuance, or modification; and denial of a permit renewal application. It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. An emergency does constitute an affirmative defense in an enforcement action provided the Permittee complies with the applicable requirements set forth in Section B, Emergency Provisions.

Indiana statutes from IC 13 and rules from 326 IAC, quoted in conditions in this permit, are those applicable at the time the permit was issued. The issuance or possession of this permit shall not alone constitute a defense against an alleged violation of any law, regulation or standard, except for the requirement to obtain a FESOP under 326 IAC 2-8.

This permit is issued in accordance with 326 IAC 2 and 40 CFR Part 70 Appendix A and contains the conditions and provisions specified in 326 IAC 2-8 as required by 42 U.S.C. 7401, et. seq. (Clean Air Act as amended by the 1990 Clean Air Act Amendments), 40 CFR Part 70.6, IC 13-15 and IC 13-17.

Operation Permit No.: F095-16603-00006	
Issued by: Original signed by Paul Dubenetzky, Branch Chief Office of Air Quality	Issuance Date: October 28, 2003 Expiration Date: October 28, 2013

First Significant Permit Revision No.: 095-24743-00006, issued November 30, 2007
Second Significant Permit Revision No.: 095-26417-00006, issued July 16, 2008

First Administrative Amendment No: 095-27581-00006	
Original signed by:  Alfred C. Dumauval, Ph.D, Section Chief Permits Branch Office of Air Quality	Issuance Date: April 8, 2009 Expiration Date: October 28, 2013



SECTION A	SOURCE SUMMARY	5
A.1	General Information [326 IAC 2-8-3(b)]	
A.2	Emission Units and Pollution Control Equipment Summary [326 IAC 2-8-3(c)(3)]	
A.3	Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-8-3(c)(3)(I)]	
A.4	FESOP Applicability [326 IAC 2-8-2]	
SECTION B	GENERAL CONDITIONS	7
B.1	Definitions [326 IAC 2-8-1]	
B.2	Permit Term [326 IAC 2-8-4(2)][326 IAC 2-1.1-9.5][IC 13-15-3-6(a)]	
B.3	Term of Conditions [326 IAC 2-1.1-9.5]	
B.4	Enforceability [326 IAC 2-8-6]	
B.5	Severability [326 IAC 2-8-4(4)]	
B.6	Property Rights or Exclusive Privilege [326 IAC 2-8-4(5)(D)]	
B.7	Duty to Provide Information[326 IAC 2-8-4(5)(E)]	
B.8	Compliance Order Issuance [326 IAC 2-8-5(b)]	
B.9	Certification [326 IAC 2-8-3(d)] [326 IAC 2-8-4(3)(C)(i)] [326 IAC 2-8-5(1)]	
B.10	Annual Compliance Certification [326 IAC 2-8-5(a)(1)]	
B.11	Preventive Maintenance Plan [326 IAC 1-6-3][326 IAC 2-8-4(9)][326 IAC 2-8-5(a)(1)]	
B.12	Emergency Provisions [326 IAC 2-8-12]	
B.13	Prior Permits Superseded [326 IAC 2-1.1-9.5]	
B.14	Termination of Right to Operate [326 IAC 2-8-9][326 IAC 2-8-3(h)]	
B.15	Deviations from Permit Requirements and Conditions [326 IAC 2-8-4(3)(C)(ii)]	
B.16	Permit Modification, Reopening, Revocation and Reissuance, or Termination [326 IAC 2-8-4(5)(C)][326 IAC 2-8-7(a)][326 IAC 2-8-8]	
B.17	Permit Renewal [326 IAC 2-8-3(h)]	
B.18	Permit Amendment or Revision [326 IAC 2-8-10][326 IAC 2-8-11.1]	
B.19	Operational Flexibility [326 IAC 2-8-15][326 IAC 2-8-11.1]	
B.20	Source Modification Requirement [326 IAC 2-8-11.1]	
B.21	Inspection and Entry [326 IAC 2-8-5(a)(2)][IC13-14-2-2][IC 13-17-3-2][IC13-30-3-1]	
B.22	Transfer of Ownership or Operational Control [326 IAC 2-8-10]	
B.23	Annual Fee Payment [326 IAC 2-7-19][326 IAC 2-8-4(6)] [326 IAC 2-8-16] [326 IAC 2-1.1-7]	
B.24	Credible Evidence [326 IAC 2-8-4(3)][326 IAC 2-8-5][62 FR 8314] [326 IAC 1-1-6]	
SECTION C	SOURCE OPERATION CONDITIONS	16
	Emission Limitations and Standards [326 IAC 2-8-4(1)]	
C.1	Particulate Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]	
C.2	Overall Source Limit [326 IAC 2-8] [326 IAC 2-2] [326 IAC 2-3]	
C.3	Opacity [326 IAC 5-1]	
C.4	Open Burning [326 IAC 4-1][IC 13-17-9]	
C.5	Incineration [326 IAC 4-2] [326 IAC 9-1-2(3)]	
C.6	Fugitive Dust Emissions [326 IAC 6-4]	
C.7	Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61 Subpart M]	
	Testing Requirements [326 IAC 2-8-4(3)]	
C.8	Performance Testing [326 IAC 3-6]	
	Compliance Requirements [326 IAC 2-1.1-11]	
C.9	Compliance Requirements [326 IAC 2-1.1-11]	
	Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]	
C.10	Compliance Monitoring [326 IAC 2-8-4(3)] [326 IAC 2-8-5(a)(1)]	
C.11	Monitoring Methods [326 IAC 3][40 CFR 60][40 CFR 63]	

Corrective Actions and Response Steps [326 IAC 2-8-4] [326 IAC 2-8-5]

- C.12 Risk Management Plan [326 IAC 2-8-4] [40 CFR 68]
- C.13 Response to Excursions or Exceedances [326 IAC 2-8-4] [326 IAC 2-8-5]
- C.14 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-8-4] [326 IAC 2-8-5]

Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]

- C.15 General Record Keeping Requirements [326 IAC 2-8-4(3)][326 IAC 2-8-5]
- C.16 General Reporting Requirements [326 IAC 2-8-4(3)(C)] [326 IAC 2-1.1-11]

Stratospheric Ozone Protection

- C.17 Compliance with 40 CFR 82 and 326 IAC 22-1

SECTION D.1 FACILITY OPERATION CONDITIONS

Five (5) Boilers, B-1 through B-6..... 23

Emission Limitations and Standards [326 IAC 2-8-4(1)]

- D.1.1 Fuel Usage [326 IAC 2-8-4] [326 IAC 2-2]
- D.1.2 Particulate [326 IAC 6-2-4]
- D.1.3 Sulfur Dioxide (SO₂) [326 IAC 7-1.1-1] [326 IAC 7-2-1]
- D.1.4 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

Compliance Determination Requirements

- D.1.5 Particulate Control
- D.1.6 Nitrogen Oxide Emissions
- D.1.7 Carbon Monoxide Emissions
- D.1.8 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11]
- D.1.9 Sulfur Dioxide Emissions and Sulfur Content

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

- D.1.10 Visible Emissions Notations
- D.1.11 Cyclone Failure Detection

Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

- D.1.12 Record Keeping Requirements
- D.1.13 Reporting Requirements

New Source Performance Standards (NSPS) Requirements [326 IAC 2-7-5(1)]

- D.1.14 General Provisions Relating to New Source Performance Standards (NSPS) for Small Industrial-Commercial-Institutional Steam Generating Units [326 IAC 12 1][40 CFR Part 60, Subpart A] [40 CFR Part 60, Subpart Dc]
- D.1.15 New Source Performance Standards (NSPS) for Small Industrial-Commercial-Institutional Steam Generating Units [40 CFR Part 60, Subpart Dc]

SECTION D.2 FACILITY OPERATION CONDITIONS

Biomass and Ash Handling 34

Emission Limitations and Standards [326 IAC 2-8-4(1)]

- D.2.1 Particulate [326 IAC 6-3-2]
- D.2.2 PM₁₀ Limitations [326 IAC 2-8-4]
- D.2.3 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

Compliance Determination Requirements

- D.2.4 Particulate Control

Compliance Monitoring Requirements [326 IAC 2-8-4] [3256 IAC 2-8-5(a)(1)]

D.2.5 Visible Emissions Notations

D.2.6 Parametric Monitoring

D.2.7 Broken or Failed Bag Detection

Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

D.2.8 Record Keeping Requirements

SECTION D.3 FACILITY OPERATION CONDITIONS

Insignificant Activities 37

Emission Limitations and Standards [326 IAC 2-8-4(1)]

D.3.1 Particulate (PM) [326 IAC 6-3-2]

D.3.2 Volatile Organic Compounds (VOC) [326 IAC 8-3-2]

D.3.3 Volatile Organic Compounds (VOC) [326 IAC 8-3-5]

Certification Form..... 39

Emergency Occurrence Form..... 40

Natural Gas-Fired Boiler Certification 42

Quarterly Reports 43

Quarterly Deviation and Compliance Monitoring Report Form 46

SECTION A

SOURCE SUMMARY

This permit is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ). The information describing the source contained in conditions A.1 through A.3 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this permit pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

A.1 General Information [326 IAC 2-8-3(b)]

The Permittee owns and operates a stationary correctional facility.

Source Address:	4490 West Reformatory Road, Pendleton, Indiana 46064
Mailing Address:	4490 West Reformatory Road, Pendleton, Indiana 46064
General Source Phone Number:	765- 778-2107
SIC Code:	9223
County Location:	Madison
Source Location Status:	Attainment for all criteria pollutants
Source Status:	Federally Enforceable State Operating Permit (FESOP) Minor Source, under PSD and Emission Offset Rules Minor Source, Section 112 of the Clean Air Act

A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-8-3(c)(3)]

This stationary source consists of the following emission units and pollution control devices:

- (a) One (1) biomass-fired boiler system including one (1) boiler identified as boiler B-1, constructed in 1967, approved for modification in 2007 and modified in 2008, capable of combusting untreated corn, wood (including bark), wood pellets, switchgrass, and clean, untreated construction debris, with a maximum heat input capacity of 27.5 million British thermal units per hour, and one (1) natural-gas ignition burner with a maximum heat input capacity of 1.075 MMBtu/hr for cold boiler starts with emissions controlled by a cyclone, and exhausting to a stack.
- (b) One (1) natural gas-fired boiler, constructed in 1968 as a coal-fired boiler, and modified in 1998 to burn natural gas, identified as boiler B-2, with a maximum heat input capacity of 79.13 million British thermal units per hour, with emissions exhausting to stack S-B-2.
- (c) One (1) natural gas-fired boiler, constructed in 1968 as a coal-fired boiler, and modified in 1998 to burn natural gas, identified as boiler B-3, with a maximum heat input capacity of 98.9 million British thermal units per hour, with emissions exhausting to stack S-B-3.
- (d) One (1) natural gas and No. 2 fuel oil-fired boiler, identified as boiler B-4, constructed in 1985, with a maximum heat input capacity of 37.5 million British thermal units per hour, with emissions exhausting to stack S-B-4.
- (e) One (1) natural gas and No. 2 fuel oil-fired boiler, constructed in 1995, identified as boiler B-5, with a maximum heat input capacity of 56.25 million British thermal units per hour, with emissions exhausting to stack S-B-5.
- (f) One (1) biomass handling and storage operation, approved for construction in 2007 and modified in 2008 consisting of the following:
 - (1) One (1) truck unloading operation with a maximum throughput of 224,000 pounds of biomass per hour.

- (2) One (1) biomass storage silo, with a maximum storage capacity of 762,552 pounds of biomass (volumetric capacity 15,987 cubic feet), with emissions controlled by a baghouse.
- (3) One (1) biomass handling system with a maximum throughput of 252,000 pounds per hour, with emissions controlled by a baghouse including: six (6) augers, one (1) conveyor, one (1) bucket elevator, and one (1) metering bin.
- (g) One (1) ash disposal system, approved for construction in 2007, with a maximum throughput of 500 pounds of ash per hour, with emissions controlled by a cyclone including: three (3) augers.

A.3 Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-8-3(c)(3)(I)]

This stationary source also includes the following insignificant activities, as defined in 326 IAC 2-7-1(21):

- (a) A gasoline fuel transfer and dispensing operation handling less than or equal to 1,300 gallons per day, such as filling of tanks, locomotives, automobiles, having a storage capacity less than or equal to 10,500 gallons;
- (b) A petroleum fuel, other than gasoline, having a storage capacity less than or equal to 10,500 gallons, and dispensing less than or equal to 230,000 gallons per month;
- (c) Degreasing operations that do not exceed 145 gallons per 12 months, except if subject to 326 IAC 20-6; [326 IAC 8-3-2] [326 IAC 8-3-5]
- (d) The following equipment related to manufacturing activities not resulting in the emission of HAPs: brazing equipment, cutting torches, soldering equipment, welding equipment; [26 IAC 6-3-2]
- (e) Paved and unpaved roads and parking lots with public access;
- (f) Covered conveyors for coal or coke conveying of less than or equal to 360 tons per day;
- (g) Blowdown for any of the following: sight glass, boiler, compressors, pumps and cooling tower;
- (h) On-site fire and emergency response training approved by the department;
- (i) Diesel generators not exceeding 1600 horsepower; and
- (j) Stationary fire pumps.

A.4 FESOP Applicability [326 IAC 2-8-2]

This stationary source, otherwise required to have a Part 70 permit as described in 326 IAC 2-7-2(a), has applied to the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ) to renew a Federally Enforceable State Operating Permit (FESOP).

SECTION B GENERAL CONDITIONS

B.1 Definitions [326 IAC 2-8-1]

Terms in this permit shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, the applicable definitions found in the statutes or regulations (IC 13-11, 326 IAC 1-2 and 326 IAC 2-7) shall prevail.

B.2 Permit Term [326 IAC 2-8-4(2)][326 IAC 2-1.1-9.5][IC 13-15-3-6(a)]

- (a) This permit, F095-16603-00006, is issued for a fixed term of ten (10) years from the issuance date of this permit, as determined in accordance with IC 4-21.5-3-5(f) and IC 13-15-5-3. Subsequent revisions, modifications, or amendments of this permit do not affect the expiration date of this permit.
- (b) If IDEM, OAQ, upon receiving a timely and complete renewal permit application, fails to issue or deny the permit renewal prior to the expiration date of this permit, this existing permit shall not expire and all terms and conditions shall continue in effect, until the renewal permit has been issued or denied.

B.3 Term of Conditions [326 IAC 2-1.1-9.5]

Notwithstanding the permit term of a permit to construct, a permit to operate, or a permit modification, any condition established in a permit issued pursuant to a permitting program approved in the state implementation plan shall remain in effect until:

- (a) the condition is modified in a subsequent permit action pursuant to Title I of the Clean Air Act; or
- (b) the emission unit to which the condition pertains permanently ceases operation.

B.4 Enforceability [326 IAC 2-8-6]

Unless otherwise stated, all terms and conditions in this permit, including any provisions designed to limit the source's potential to emit, are enforceable by IDEM, the United States Environmental Protection Agency (U.S. EPA) and by citizens in accordance with the Clean Air Act.

B.5 Severability [326 IAC 2-8-4(4)]

The provisions of this permit are severable; a determination that any portion of this permit is invalid shall not affect the validity of the remainder of the permit.

B.6 Property Rights or Exclusive Privilege [326 IAC 2-8-4(5)(D)]

This permit does not convey any property rights of any sort or any exclusive privilege.

B.7 Duty to Provide Information [326 IAC 2-8-4(5)(E)]

- (a) The Permittee shall furnish to IDEM, OAQ, within a reasonable time, any information that IDEM, OAQ may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The submittal by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1). Upon request, the Permittee shall also furnish to IDEM, OAQ copies of records required to be kept by this permit.
- (b) For information furnished by the Permittee to IDEM, OAQ, the Permittee may include a claim of confidentiality in accordance with 326 IAC 17.1. When furnishing copies of requested records directly to U. S. EPA, the Permittee may assert a claim of confidentiality in accordance with 40 CFR 2, Subpart B.

B.8 Compliance Order Issuance [326 IAC 2-8-5(b)]

IDEM, OAQ may issue a compliance order to this Permittee upon discovery that this permit is in nonconformance with an applicable requirement. The order may require immediate compliance or contain a schedule for expeditious compliance with the applicable requirement.

B.9 Certification [326 IAC 2-8-3(d)][326 IAC 2-8-4(3)(C)(i)][326 IAC 2-8-5(1)]

- (a) Where specifically designated by this permit or required by an applicable requirement, any application form, report, or compliance certification submitted shall contain certification by an "authorized individual" of truth, accuracy, and completeness. This certification shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
- (b) One (1) certification shall be included, using the attached Certification Form or its equivalent, with each submittal requiring certification. One (1) certification may cover multiple forms in one (1) submittal.
- (c) An "authorized individual" is defined at 326 IAC 2-1.1-1(1).

B.10 Annual Compliance Certification [326 IAC 2-8-5(a)(1)]

- (a) The Permittee shall annually submit a compliance certification report which addresses the status of the source's compliance with the terms and conditions contained in this permit, including emission limitations, standards, or work practices. All certifications shall cover the time period from January 1 to December 31 of the previous year, and shall be submitted no later than July 1 of each year to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

- (b) The annual compliance certification report required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
- (c) The annual compliance certification report shall include the following:
 - (1) The appropriate identification of each term or condition of this permit that is the basis of the certification;
 - (2) The compliance status;
 - (3) Whether compliance was continuous or intermittent;
 - (4) The methods used for determining the compliance status of the source, currently and over the reporting period consistent with 326 IAC 2-8-4(3); and
 - (5) Such other facts, as specified in Sections D of this permit, as IDEM, OAQ may require to determine the compliance status of the source.

The submittal by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

B.11 Preventive Maintenance Plan [326 IAC 1-6-3][326 IAC 2-8-4(9)][326 IAC 2-8-5(a)(1)]

- (a) If required by specific condition(s) in Section D of this permit, the Permittee shall maintain and implement Preventive Maintenance Plans (PMPs) including the following information on each facility:
- (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;
 - (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
 - (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

If, due to circumstances beyond the Permittee's control, the PMPs cannot be prepared and maintained within the above time frame, the Permittee may extend the date an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

The PMP extension notification does not require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (b) A copy of the PMPs shall be submitted to IDEM, OAQ upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. IDEM, OAQ may require the Permittee to revise its PMPs whenever lack of proper maintenance causes or is the primary contributor to an exceedance of any limitation on emissions or potential to emit. The PMPs do not require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (c) To the extent the Permittee is required by 40 CFR Part 60/63 to have an Operation Maintenance, and Monitoring (OMM) Plan for a unit, such Plan is deemed to satisfy the PMP requirements of 326 IAC 1-6-3 for that unit.

B.12 Emergency Provisions [326 IAC 2-8-12]

- (a) An emergency, as defined in 326 IAC 2-7-1(12), is not an affirmative defense for an action brought for noncompliance with a federal or state health-based emission limitation except as provided in 326 IAC 2-8-12.
- (b) An emergency, as defined in 326 IAC 2-7-1(12), constitutes an affirmative defense to an action brought for noncompliance with a health-based or technology-based emission limitation if the affirmative defense of an emergency is demonstrated through properly signed, contemporaneous operating logs or other relevant evidence that describe the following:
- (1) An emergency occurred and the Permittee can, to the extent possible, identify the causes of the emergency;
 - (2) The permitted facility was at the time being properly operated;

- (3) During the period of an emergency, the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards or other requirements in this permit;
- (4) For each emergency lasting one (1) hour or more, the Permittee notified IDEM, OAQ, within four (4) daytime business hours after the beginning of the emergency, or after the emergency was discovered or reasonably should have been discovered;

Telephone Number: 1-800-451-6027 (ask for Office of Air Quality, Compliance and Enforcement Branch), or
Telephone Number: 317-233-0178 (ask for Compliance and Enforcement Branch)
Facsimile Number: 317-233-6865

- (5) For each emergency lasting one (1) hour or more, the Permittee submitted the attached Emergency Occurrence Report Form or its equivalent, either by mail or facsimile to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

within two (2) working days of the time when emission limitations were exceeded due to the emergency.

The notice fulfills the requirement of 326 IAC 2-8-4(3)(C)(ii) and must contain the following:

- (A) A description of the emergency;
- (B) Any steps taken to mitigate the emissions; and
- (C) Corrective actions taken.

The notification which shall be submitted by the Permittee does not require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (6) The Permittee immediately took all reasonable steps to correct the emergency.
- (c) In any enforcement proceeding, the Permittee seeking to establish the occurrence of an emergency has the burden of proof.
- (d) This emergency provision supersedes 326 IAC 1-6 (Malfunctions). This permit condition is in addition to any emergency or upset provision contained in any applicable requirement.
- (e) The Permittee seeking to establish the occurrence of an emergency shall make records available upon request to ensure that failure to implement a PMP did not cause or contribute to an exceedance of any limitations on emissions. However, IDEM, OAQ may require that the Preventive Maintenance Plans required under 326 IAC 2-8-3(c)(6) be revised in response to an emergency.

- (f) Failure to notify IDEM, OAQ by telephone or facsimile of an emergency lasting more than one (1) hour in accordance with (b)(4) and (5) of this condition shall constitute a violation of 326 IAC 2-8 and any other applicable rules.
- (g) Operations may continue during an emergency only if the following conditions are met:
 - (1) If the emergency situation causes a deviation from a technology-based limit, the Permittee may continue to operate the affected emitting facilities during the emergency provided the Permittee immediately takes all reasonable steps to correct the emergency and minimize emissions.
 - (2) If an emergency situation causes a deviation from a health-based limit, the Permittee may not continue to operate the affected emissions facilities unless:
 - (A) The Permittee immediately takes all reasonable steps to correct the emergency situation and to minimize emissions; and
 - (B) Continued operation of the facilities is necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw material of substantial economic value.

Any operations shall continue no longer than the minimum time required to prevent the situations identified in (g)(2)(B) of this condition.
- (h) The Permittee shall include all emergencies in the Quarterly Deviation and Compliance Monitoring Report.

B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5]

- (a) All terms and conditions of permits established prior to F095-16603-00006 and issued pursuant to permitting programs approved into the state implementation plan have been either:
 - (1) incorporated as originally stated,
 - (2) revised, or
 - (3) deleted.
- (b) All previous registrations and permits are superseded by this permit.

B.14 Termination of Right to Operate [326 IAC 2-8-9][326 IAC 2-8-3(h)]

The Permittee's right to operate this source terminates with the expiration of this permit unless a timely and complete renewal application is submitted at least nine (9) months prior to the date of expiration of the source's existing permit, consistent with 326 IAC 2-8-3(h) and 326 IAC 2-8-9.

B.15 Deviations from Permit Requirements and Conditions [326 IAC 2-8-4(3)(C)(ii)]

- (a) Deviations from any permit requirements (for emergencies see Section B - Emergency Provisions), the probable cause of such deviations, and any response steps or preventive measures taken shall be reported to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

using the attached Quarterly Deviation and Compliance Monitoring Report, or its equivalent. A deviation required to be reported pursuant to an applicable requirement that exists independent of this permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report.

The Quarterly Deviation and Compliance Monitoring Report does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (b) A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit.

B.16 Permit Modification, Reopening, Revocation and Reissuance, or Termination
[326 IAC 2-8-4(5)(C)][326 IAC 2-8-7(a)][326 IAC 2-8-8]

- (a) This permit may be modified, reopened, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a Federally Enforceable State Operating Permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any condition of this permit. [326 IAC 2-8-4(5)(C)] The notification by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (b) This permit shall be reopened and revised under any of the circumstances listed in IC 13-15-7-2 or if IDEM, OAQ determines any of the following:
- (1) That this permit contains a material mistake.
 - (2) That inaccurate statements were made in establishing the emissions standards or other terms or conditions.
 - (3) That this permit must be revised or revoked to assure compliance with an applicable requirement. [326 IAC 2-8-8(a)]
- (c) Proceedings by IDEM, OAQ to reopen and revise this permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of this permit for which cause to reopen exists. Such reopening and revision shall be made as expeditiously as practicable. [326 IAC 2-8-8(b)]
- (d) The reopening and revision of this permit, under 326 IAC 2-8-8(a), shall not be initiated before notice of such intent is provided to the Permittee by IDEM, OAQ, at least thirty (30) days in advance of the date this permit is to be reopened, except that IDEM, OAQ may provide a shorter time period in the case of an emergency. [326 IAC 2-8-8(c)]

B.17 Permit Renewal [326 IAC 2-8-3(h)]

- (a) The application for renewal shall be submitted using the application form or forms prescribed by IDEM, OAQ and shall include the information specified in 326 IAC 2-8-3. Such information shall be included in the application for each emission unit at this source, except those emission units included on the trivial or insignificant activities list contained in 326 IAC 2-7-1(21) and 326 IAC 2-7-1(40). The renewal application does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

Request for renewal shall be submitted to:

Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

- (b) A timely renewal application is one that is:
- (1) Submitted at least nine (9) months prior to the date of the expiration of this permit; and
 - (2) If the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.
- (c) If the Permittee submits a timely and complete application for renewal of this permit, the source's failure to have a permit is not a violation of 326 IAC 2-8 until IDEM, OAQ takes final action on the renewal application, except that this protection shall cease to apply if, subsequent to the completeness determination, the Permittee fails to submit by the deadline specified in writing by IDEM, OAQ any additional information identified as being needed to process the application.

B.18 Permit Amendment or Revision [326 IAC 2-8-10][326 IAC 2-8-11.1]

- (a) Permit amendments and revisions are governed by the requirements of 326 IAC 2-8-10 or 326 IAC 2-8-11.1 whenever the Permittee seeks to amend or modify this permit.
- (b) Any application requesting an amendment or modification of this permit shall be submitted to:
- Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251
- Any such application shall be certified by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-8-10(b)(3)]

B.19 Operational Flexibility [326 IAC 2-8-15][326 IAC 2-8-11.1]

- (a) The Permittee may make any change or changes at the source that are described in 326 IAC 2-8-15(b) through (d) without a prior permit revision, if each of the following conditions is met:
- (1) The changes are not modifications under any provision of Title I of the Clean Air Act;
 - (2) Any approval required by 326 IAC 2-8-11.1 has been obtained;

(3) The changes do not result in emissions which exceed the limitations provided in this permit (whether expressed herein as a rate of emissions or in terms of total emissions);

(4) The Permittee notifies the:

Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

in advance of the change by written notification at least ten (10) days in advance of the proposed change. The Permittee shall attach every such notice to the Permittee's copy of this permit; and

(5) The Permittee maintains records on-site, on a rolling five (5) year basis, which document all such changes and emission trades that are subject to 326 IAC 2-8-15(b) through (d). The Permittee shall make such records available, upon reasonable request, for public review.

Such records shall consist of all information required to be submitted to IDEM, OAQ in the notices specified in 326 IAC 2-8-15(b)(2), (c)(1), and (d).

- (b) Emission Trades [326 IAC 2-8-15(c)]
The Permittee may trade emissions increases and decreases at the source, where the applicable SIP provides for such emission trades without requiring a permit revision, subject to the constraints of Section (a) of this condition and those in 326 IAC 2-8-15(c).
- (c) Alternative Operating Scenarios [326 IAC 2-8-15(d)]
The Permittee may make changes at the source within the range of alternative operating scenarios that are described in the terms and conditions of this permit in accordance with 326 IAC 2-8-4(7). No prior notification of IDEM, OAQ, or U.S. EPA is required.
- (d) Backup fuel switches specifically addressed in, and limited under, Section D of this permit shall not be considered alternative operating scenarios. Therefore, the notification requirements of part (a) of this condition do not apply.

B.20 Source Modification Requirement [326 IAC 2-8-11.1]

A modification, construction, or reconstruction is governed by the requirements of 326 IAC 2 and 326 IAC 2-8-11.1.

B.21 Inspection and Entry [326 IAC 2-8-5(a)(2)][IC 13-14-2-2][IC 13-17-3-2][IC13-30-3-1]

Upon presentation of proper identification cards, credentials, and other documents as may be required by law, and subject to the Permittee's right under all applicable laws and regulations to assert that the information collected by the agency is confidential and entitled to be treated as such, the Permittee shall allow IDEM, OAQ, U.S. EPA, or an authorized representative to perform the following:

- (a) Enter upon the Permittee's premises where a FESOP source is located, or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
- (b) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;

- (c) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, inspect, at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit;
- (d) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with this permit or applicable requirements; and
- (e) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, utilize any photographic, recording, testing, monitoring, or other equipment for the purpose of assuring compliance with this permit or applicable requirements.

B.22 Transfer of Ownership or Operational Control [326 IAC 2-8-10]

- (a) The Permittee must comply with the requirements of 326 IAC 2-8-10 whenever the Permittee seeks to change the ownership or operational control of the source and no other change in the permit is necessary.
- (b) Any application requesting a change in the ownership or operational control of the source shall contain a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new Permittee. The application shall be submitted to:

Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

The application which shall be submitted by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-8-10(b)(3)]

B.23 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-8-4(6)] [326 IAC 2-8-16][326 IAC 2-1.1-7]

- (a) The Permittee shall pay annual fees to IDEM, OAQ, within thirty (30) calendar days of receipt of a billing. Pursuant to 326 IAC 2-7-19(b), if the Permittee does not receive a bill from IDEM, OAQ, the applicable fee is due April 1 of each year.
- (b) Failure to pay may result in administrative enforcement action or revocation of this permit.
- (c) The Permittee may call the following telephone numbers: 1-800-451-6027 or 317-233-4230 (ask for OAQ, Billing, Licensing, and Training Section), to determine the appropriate permit fee.

B.24 Credible Evidence [326 IAC 2-8-4(3)][326 IAC 2-8-5][62 FR 8314] [326 IAC 1-1-6]

For the purpose of submitting compliance certifications or establishing whether or not the Permittee has violated or is in violation of any condition of this permit, nothing in this permit shall preclude the use, including the exclusive use, of any credible evidence or information relevant to whether the Permittee would have been in compliance with the condition of this permit if the appropriate performance or compliance test or procedure had been performed.

SECTION C

SOURCE OPERATION CONDITIONS

Entire Source

Emissions Limitations and Standards [326 IAC 2-8-4(1)]

C.1 Particulate Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2(e)(2), particulate emissions from any process not exempt under 326 IAC 6-3-1(b) or (c) which has a maximum process weight rate less than 100 pounds per hour and the methods in 326 IAC 6-3-2(b) through (d) do not apply shall not exceed 0.551 pounds per hour.

C.2 Overall Source Limit [326 IAC 2-8] [326 IAC 2-2] [326 IAC 2-3]

The purpose of this permit is to limit this source's potential to emit to less than major source levels for the purpose of Section 502(a) of the Clean Air Act.

(a) Pursuant to 326 IAC 2-8:

- (1) The potential to emit any regulated pollutant, except particulate matter (PM), from the entire source shall be limited to less than one-hundred (100) tons per twelve (12) consecutive month period. This limitation shall also make the requirements of 326 IAC 2-2 (Prevention of Significant Deterioration (PSD)) and 326 IAC 2-3 (Emission Offset) not applicable;
- (2) The potential to emit any individual hazardous air pollutant (HAP) from the entire source shall be limited to less than ten (10) tons per twelve (12) consecutive month period; and
- (3) The potential to emit any combination of HAPs from the entire source shall be limited to less than twenty-five (25) tons per twelve (12) consecutive month period.

(b) The potential to emit particulate matter (PM) from the entire source shall be limited to less than two hundred fifty (250) tons per twelve (12) consecutive month period. This limitation shall make the requirements of 326 IAC 2-2 (Prevention of Significant Deterioration (PSD)) not applicable.

(c) This condition shall include all emission points at this source including those that are insignificant as defined in 326 IAC 2-7-1(21). The source shall be allowed to add insignificant activities not already listed in this permit, provided that the source's potential to emit does not exceed the above specified limits.

(d) Section D of this permit contains independently enforceable provisions to satisfy this requirement.

C.3 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

- (a) Opacity shall not exceed an average of thirty percent (30%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.

- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

C.4 Open Burning [326 IAC 4-1] [IC 13-17-9]

The Permittee shall not open burn any material except as provided in 326 IAC 4-1-3, 326 IAC 4-1-4 or 326 IAC 4-1-6. The previous sentence notwithstanding, the Permittee may open burn in accordance with an open burning approval issued by the Commissioner under 326 IAC 4-1-4.1.

C.5 Incineration [326 IAC 4-2] [326 IAC 9-1-2(3)]

The Permittee shall not operate an incinerator or incinerate any waste or refuse except as provided in 326 IAC 4-2 and in 326 IAC 9-1-2.

C.6 Fugitive Dust Emissions [326 IAC 6-4]

The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions).

C.7 Stack Height [326 IAC 1-7]

The Permittee shall comply with the applicable provisions of 326 IAC 1-7 (Stack Height Provisions), for all exhaust stacks through which a potential (before controls) of twenty-five (25) tons per year or more of particulate matter or sulfur dioxide is emitted.

C.8 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

- (a) Notification requirements apply to each owner or operator. If the combined amount of regulated asbestos containing material (RACM) to be stripped, removed or disturbed is at least 260 linear feet on pipes or 160 square feet on other facility components, or at least thirty-five (35) cubic feet on all facility components, then the notification requirements of 326 IAC 14-10-3 are mandatory. All demolition projects require notification whether or not asbestos is present.
- (b) The Permittee shall ensure that a written notification is sent on a form provided by the Commissioner at least ten (10) working days before asbestos stripping or removal work or before demolition begins, per 326 IAC 14-10-3, and shall update such notice as necessary, including, but not limited to the following:
 - (1) When the amount of affected asbestos containing material increases or decreases by at least twenty percent (20%); or
 - (2) If there is a change in the following:
 - (A) Asbestos removal or demolition start date;
 - (B) Removal or demolition contractor; or
 - (C) Waste disposal site.
- (c) The Permittee shall ensure that the notice is postmarked or delivered according to the guidelines set forth in 326 IAC 14-10-3(2).
- (d) The notice to be submitted shall include the information enumerated in 326 IAC 14-10-3(3).

All required notifications shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

The notice shall include a signed certification from the owner or operator that the information provided in this notification is correct and that only Indiana licensed workers and project supervisors will be used to implement the asbestos removal project. The notifications do not require a certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (e) **Procedures for Asbestos Emission Control**
The Permittee shall comply with the applicable emission control procedures in 326 IAC 14-10-4 and 40 CFR 61.145(c). Per 326 IAC 14-10-1, emission control requirements are applicable for any removal or disturbance of RACM greater than three (3) linear feet on pipes or three (3) square feet on any other facility components or a total of at least 0.75 cubic feet on all facility components.
- (f) **Demolition and Renovation**
The Permittee shall thoroughly inspect the affected facility or part of the facility where the demolition or renovation will occur for the presence of asbestos pursuant to 40 CFR 61.145(a).
- (g) **Indiana Accredited Asbestos Inspector**
The Permittee shall comply with 326 IAC 14-10-1(a) that requires the owner or operator, prior to a renovation/demolition, to use an Indiana Accredited Asbestos Inspector to thoroughly inspect the affected portion of the facility for the presence of asbestos.

Testing Requirements [326 IAC 2-8-4(3)]

C.9 Performance Testing [326 IAC 3-6]

- (a) All testing shall be performed according to the provisions of 326 IAC 3-6 (Source Sampling Procedures), except as provided elsewhere in this permit, utilizing any applicable procedures and analysis methods specified in 40 CFR 51, 40 CFR 60, 40 CFR 61, 40 CFR 63, 40 CFR 75, or other procedures approved by IDEM, OAQ.

A test protocol, except as provided elsewhere in this permit, shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

no later than thirty-five (35) days prior to the intended test date. The protocol submitted by the Permittee does not require certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (b) The Permittee shall notify IDEM, OAQ of the actual test date at least fourteen (14) days prior to the actual test date. The notification submitted by the Permittee does not require certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (c) Pursuant to 326 IAC 3-6-4(b), all test reports must be received by IDEM, OAQ not later than forty-five (45) days after the completion of the testing. An extension may be granted by IDEM, OAQ if the Permittee submits to IDEM, OAQ, a reasonable written explanation not later than five (5) days prior to the end of the initial forty-five (45) day period.

Compliance Requirements [326 IAC 2-1.1-11]

C.10 Compliance Requirements [326 IAC 2-1.1-11]

The commissioner may require stack testing, monitoring, or reporting at any time to assure compliance with all applicable requirements by issuing an order under 326 IAC 2-1.1-11. Any monitoring or testing shall be performed in accordance with 326 IAC 3 or other methods approved by the commissioner or the U. S. EPA.

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

C.11 Compliance Monitoring [326 IAC 2-8-4(3)] [326 IAC 2-8-5(a)(1)]

Unless otherwise specified in this permit, all monitoring and record keeping requirements not already legally required shall be implemented within ninety (90) days of permit issuance. If required by Section D, the Permittee shall be responsible for installing any necessary equipment and initiating any required monitoring related to that equipment. If due to circumstances beyond its control, that equipment cannot be installed and operated within ninety (90) days, the Permittee may extend the compliance schedule related to the equipment for an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

in writing, prior to the end of the initial ninety (90) day compliance schedule, with full justification of the reasons for the inability to meet this date.

The notification which shall be submitted by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

Unless otherwise specified in the approval for the new emission unit(s), compliance monitoring for new emission units or emission units added through a permit revision shall be implemented when operation begins.

C.12 Monitoring Methods [326 IAC 3] [40 CFR 60] [40 CFR 63]

Any monitoring or testing required by Section D of this permit shall be performed according to the provisions of 326 IAC 3, 40 CFR 60, Appendix A, 40 CFR 60, Appendix B, 40 CFR 63, or other approved methods as specified in this permit.

C.13 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-8-4(3)][326 IAC 2-8-5(1)]

- (a) When required by any condition of this permit, an analog instrument used to measure a parameter related to the operation of an air pollution control device shall have a scale such that the expected maximum reading for the normal range shall be no less than twenty percent (20%) of full scale.

- (b) The Permittee may request that the IDEM, OAQ approve the use of an instrument that does not meet the above specifications provided the Permittee can demonstrate that an alternative instrument specification will adequately ensure compliance with permit conditions requiring the measurement of the parameters.

Corrective Actions and Response Steps [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

C.14 Risk Management Plan [326 IAC 2-8-4] [40 CFR 68]

If a regulated substance, as defined in 40 CFR 68, is present at a source in more than a threshold quantity, the Permittee must comply with the applicable requirements of 40 CFR 68.

C.15 Response to Excursions or Exceedances [326 IAC 2-8-4] [326 IAC 2-8-5]

- (a) Upon detecting an excursion or exceedance, the Permittee shall restore operation of the emissions unit (including any control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing emissions.
- (b) The response shall include minimizing the period of any startup, shutdown or malfunction and taking any necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of an excursion or exceedance (other than those caused by excused startup or shutdown conditions). Corrective actions may include, but are not limited to, the following:
- (1) initial inspection and evaluation;
 - (2) recording that operations returned to normal without operator action (such as through response by a computerized distribution control system); or
 - (3) any necessary follow-up actions to return operation to within the indicator range, designated condition, or below the applicable emission limitation or standard, as applicable.
- (c) A determination of whether the Permittee has used acceptable procedures in response to an excursion or exceedance will be based on information available, which may include, but is not limited to, the following:
- (1) monitoring results;
 - (2) review of operation and maintenance procedures and records;
 - (3) inspection of the control device, associated capture system, and the process.
- (d) Failure to take reasonable response steps shall be considered a deviation from the permit.
- (e) The Permittee shall maintain the following records:
- (1) monitoring data;
 - (2) monitor performance data, if applicable; and
 - (3) corrective actions taken.

C.16 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-8-4] [326 IAC 2-8-5]

- (a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this permit exceed the level specified in any condition of this permit, the Permittee shall take appropriate response actions. The Permittee shall submit a description of these response actions to IDEM, OAQ, within thirty (30) days of receipt of the test results. The Permittee shall take appropriate action to minimize excess emissions from the affected facility while the response actions are being implemented.
- (b) A retest to demonstrate compliance shall be performed within one hundred twenty (120) days of receipt of the original test results. Should the Permittee demonstrate to IDEM, OAQ that retesting in one hundred twenty (120) days is not practicable, IDEM, OAQ may extend the retesting deadline.
- (c) IDEM, OAQ reserves the authority to take any actions allowed under law in response to noncompliant stack tests.

The response action documents submitted pursuant to this condition do require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]

C.17 General Record Keeping Requirements [326 IAC 2-8-4(3)] [326 IAC 2-8-5]

- (a) Records of all required monitoring data, reports and support information required by this permit shall be retained for a period of at least five (5) years from the date of monitoring sample, measurement, report, or application. These records shall be physically present or electronically accessible at the source location for a minimum of three (3) years. The records may be stored elsewhere for the remaining two (2) years as long as they are available upon request. If the Commissioner makes a request for records to the Permittee, the Permittee shall furnish the records to the Commissioner within a reasonable time.
- (b) Unless otherwise specified in this permit, all record keeping requirements not already legally required shall be implemented within ninety (90) days of permit issuance.

C.18 General Reporting Requirements [326 IAC 2-8-4(3)(C)] [326 IAC 2-1.1-11]

- (a) The Permittee shall submit the attached Quarterly Deviation and Compliance Monitoring Report or its equivalent. Any deviation from permit requirements, the date(s) of each deviation, the cause of the deviation, and the response steps taken must be reported. This report shall be submitted within thirty (30) days of the end of the reporting period. The Quarterly Deviation and Compliance Monitoring Report shall include the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (b) The report required in (a) of this condition and reports required by conditions in Section D of this permit shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

- (c) Unless otherwise specified in this permit, any notice, report, or other submission required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.
- (d) Unless otherwise specified in this permit, all reports required in Section D of this permit shall be submitted within thirty (30) days of the end of the reporting period. All reports do require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (e) Reporting periods are based on calendar years, unless otherwise specified in this permit. For the purpose of this permit "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.

Stratospheric Ozone Protection

C.19 Compliance with 40 CFR 82 and 326 IAC 22-1

Pursuant to 40 CFR 82 (Protection of Stratospheric Ozone), Subpart F, except as provided for motor vehicle air conditioners in Subpart B, the Permittee shall comply with the standards for recycling and emissions reduction:

- (a) Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to 40 CFR 82.156.
- (b) Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to 40 CFR 82.158.
- (c) Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161.

SECTION D.1 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-8-4(10)]:

- (a) One (1) biomass-fired boiler system including one (1) boiler identified as Boiler B-1, constructed in 1967, approved for modification in 2007 and modified in 2008 capable of combusting untreated corn, wood (including bark), wood pellets, switchgrass, and clean, untreated construction debris, with a maximum heat input capacity of 27.5 million British thermal units per hour, and one (1) natural-gas ignition burner with a maximum heat input capacity of 1.075 MMBtu/hr for cold boiler starts with emissions controlled by a cyclone, and exhausting to a stack.
- (b) One (1) natural gas-fired boiler, constructed in 1968 as a coal-fired boiler, and modified in 1998 to burn natural gas, identified as boiler B-2, with a maximum heat input capacity of 79.13 million British thermal units per hour, with emissions exhausting to stack S-B-2.
- (c) One (1) natural gas-fired boiler, constructed in 1968 as a coal-fired boiler, and modified in 1998 to burn natural gas, identified as boiler B-3, with a maximum heat input capacity of 98.9 million British thermal units per hour, with emissions exhausting to stack S-B-3.
- (d) One (1) natural gas and No. 2 fuel oil-fired boiler, identified as boiler B-4, constructed in 1985, with a maximum heat input capacity of 37.5 million British thermal units per hour, with emissions exhausting to stack S-B-4.
- (e) One (1) natural gas and No. 2 fuel oil-fired boiler, constructed in 1995, identified as boiler B-5, with a maximum heat input capacity of 56.25 million British thermal units per hour, with emissions exhausting to stack S-B-5.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-8-4(1)]

D.1.1 Fuel Usage [326 IAC 2-8-4] [326 IAC 2-2]

Pursuant to 326 IAC 2-8-4(1), the following limits shall apply:

- (a) The total amount of biomass and natural gas burned by Boilers B-1, B-2, B-3, B-4 and B-5 shall be limited such that NO_x emissions shall not exceed 91.0 tons per twelve (12) consecutive month period,
- (b) The total amount of biomass and natural gas fuel burned by Boilers B-1, B-2, B-3, B-4 and B-5 shall be limited such that CO emissions shall not exceed 90.0 tons per twelve (12) consecutive month period, and
- (c) The total No. 2 distillate fuel oil input to Boilers B-4 and B-5 shall be limited to less than 500,000 U.S. gallons per year. This fuel usage limit will limit the NO_x emissions to less than 5.0 tons per year, the CO emissions to 1.25 tons per year and the SO₂ emissions to 17.8 tons per year.
- (d) When burning corn in Boiler B-1, the Permittee shall only burn untreated corn. When burning construction debris in Boiler B-1, the Permittee shall only burn clean, untreated construction debris.

The above listed emission limitations for Boilers B-1, B-2, B-3, B-4 and B-5 will limit the source-wide potential to emit of SO₂, NO_x and CO to less than 100 tons per twelve (12) consecutive month period each. Compliance with these limits makes 326 IAC 2-7 (Part 70) not applicable and classifies the Pendleton Correctional Facility as an existing minor source under 326 IAC 2-2 (PSD).

D.1.2 Particulate [326 IAC 6-2-4]

Pursuant to 326 IAC 6-2-4 (Particulate Emissions Limitations for Facilities Constructed after September 21, 1983):

- (a) The allowable PM emissions from the one (1) biomass-fired boiler, identified as B-1, shall not exceed 0.247 pound per million British thermal units heat input.
- (b) The allowable PM emissions from the two (2) natural gas fired boilers, identified as B-2 and B-3, shall not exceed 0.254 pound per million British thermal units heat input.
- (c) The allowable PM emissions from the one (1) natural gas and No. 2 fuel oil fired boiler, identified as B-4, shall not exceed 0.425 pound per million British thermal units heat input.
- (d) The allowable PM emissions from the one (1) natural gas and No. 2 fuel oil fired boiler, identified as B-5, shall not exceed 0.335 pound per million British thermal units heat input.

These limitations are based on the following equation:

$$Pt = \frac{1.09}{Q^{0.26}}$$

where

Pt = emission rate limit (lbs/MMBtu)

Q = total source heat input capacity (MMBtu/hr)

D.1.3 Sulfur Dioxide (SO₂) [326 IAC 7-1.1-1] [326 IAC 7-2-1]

Pursuant to 326 IAC 7-1.1 (SO₂ Emissions Limitations) the SO₂ emissions from the boilers, identified as B-4 and B-5 shall not exceed five tenths (0.5) pounds per MMBtu heat input while combusting fuel oil. Pursuant to 326 IAC 7-2-1, compliance shall be demonstrated on a calendar month average.

D.1.4 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

A Preventive Maintenance Plan, in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for the five (5) boilers identified as B-1 through B-5.

Compliance Determination Requirements

D.1.5 Particulate Control

The cyclone for particulate control shall be in operation and control emissions from the biomass-fired boiler (B-1) at all times that the biomass-fired boiler is in operation.

D.1.6 Nitrogen Oxides Emissions

Compliance with the NOx emissions limit in Condition D.1.3(a) shall be demonstrated by the summation of twelve (12) consecutive monthly emission rates calculated by the following equation:

$$E_{NOx} = \frac{(CE_{Corn} * Q_{Corn}) + (CE_{SG} * Q_{SG}) + (2.9 * Q_{Bark}) + (7.92 * Q_{Wood}) + (100 * Q_{NG})}{2000 \text{ lbs/ton}}$$

Where:

E_{NOx}	=	Emissions of NOx in tons per month
CE_{Corn}	=	Compliance emission factor for NOx shall be 10.2 pounds NOx per ton corn until an IDEM approved stack test is conducted. After a stack test is conducted, the emission factor shall be the lb/ton value as established by the stack test
Q_{Corn}	=	Corn consumption in tons per month
CE_{SG}	=	Compliance emission factor for NOx shall be 10.2 pounds NOx per ton switchgrass until an IDEM approved stack test is conducted. After a stack test is conducted, the emission factor shall be the lb/ton value as established by the stack test
Q_{SG}	=	Switchgrass consumption in tons per month
Q_{Bark}	=	Wood (including bark and clean, untreated construction debris) consumption in tons per month
Q_{Wood}	=	Wood pellets consumption in tons per month
Q_{NG}	=	Natural Gas consumption in MMCF per month

D.1.7 Carbon Monoxide Emissions

Compliance with the CO emissions limit in Condition D.1.3(a) shall be demonstrated by the summation of twelve (12) consecutive monthly emission rates calculated by the following equation:

$$E_{CO} = \frac{(CE_{Corn} * Q_{Corn}) + (CE_{SG} * Q_{SG}) + (7.74 * Q_{Bark}) + (9.48 * Q_{Wood}) + (84 * Q_{NG})}{2000 \text{ lbs/ton}}$$

Where

E_{CO}	=	Emissions of CO in tons per month
CE_{Corn}	=	Compliance Emission Factor for CO shall be 8.16 pounds CO per ton Corn until an IDEM approved stack test is conducted. After a stack test is conducted, the emission factor shall be the lb/ton value as established by the stack test
Q_{Corn}	=	Corn consumption in tons per month.
CE_{SG}	=	Compliance emission factor for NOx shall be 10.2 pounds NOx per ton switchgrass until an IDEM approved stack test is conducted. After a stack test is conducted, the emission factor shall be the lb/ton value as established by the stack test
Q_{SG}	=	Switchgrass consumption in tons per month
Q_{Bark}	=	Wood (including bark and clean, untreated construction debris) consumption in tons per month
Q_{Wood}	=	Wood pellets consumption in tons per month
Q_{NG}	=	Natural Gas consumption in MMCF per month

D.1.8 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11]

- (a) Unless the Commissioner determines that valid stack test results from a similar boiler operated by the Indiana Department of Corrections is representative of emissions from Boiler B-1, within one hundred and eighty (180) days after initial usage of untreated corn as a fuel in Boiler B-1 the Permittee shall perform PM, PM10, SO₂, NOx, CO, VOC, and

HCl testing for Boiler B-1 when burning untreated corn utilizing methods as approved by the Commissioner. PM-10 includes filterable and condensable PM-10. If the Commissioner determines that valid stack test results from a similar boiler operated by the Indiana Department of Corrections is not representative of emissions from Boiler B-1, stack tests shall be repeated at least once every five (5) years from the date of this valid compliance demonstration. Testing shall be conducted in accordance with Section C - Performance Testing.

- (b) Unless the Commissioner determines that valid stack test results from a similar boiler operated by the Indiana Department of Corrections is representative of emissions from Boiler B-1, within one hundred eighty (180) days after initial usage of switchgrass as a fuel in Boiler B-1, the Permittee shall perform PM, PM10, SO₂, NOx, CO and VOC testing for Boiler B-1 when burning switchgrass utilizing methods as approved by the Commissioner. PM10 includes filterable and condensable PM10. If the Commissioner determines that valid stack test results from a similar boiler operated by the Indiana Department of Corrections is not representative of emissions from Boiler B-1, stack tests shall be repeated at least once every five (5) years from the date of this valid compliance demonstration. Testing shall be conducted in accordance with Section C - Performance Testing.

D.1.9 Sulfur Dioxide Emissions and Sulfur Content

Compliance with Condition D.1.3 shall be determined utilizing one of the following options:

- (a) Pursuant to 326 IAC 3-7-4, the Permittee shall demonstrate that the sulfur dioxide emissions do not exceed five-tenths (0.5) pound per million Btu heat input by:
- (1) Providing vendor analysis of fuel delivered, if accompanied by a vendor certification, or;
 - (2) Analyzing the oil sample to determine the sulfur content of the oil via the procedures in 40 CFR 60, Appendix A, Method 19.
 - (A) Oil samples may be collected from the fuel tank immediately after the fuel tank is filled and before any oil is combusted; and
 - (B) If a partially empty fuel tank is refilled, a new sample and analysis would be required upon filling.
- (b) Compliance may also be determined by conducting a stack test for sulfur dioxide emissions from the boiler using 40 CFR 60, Appendix A, Method 6 in accordance with the procedures in 326 IAC 3-6.

A determination of noncompliance pursuant to any of the methods specified in (a) or (b) above shall not be refuted by evidence of compliance pursuant to the other method.

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

D.1.10 Visible Emissions Notations

- (a) When combusting fuel oil, visible emission notations of the boilers, identified as B-4 and B-5 stack exhaust shall be performed daily during normal daylight operations. A trained employee shall record whether emissions are normal or abnormal.
- (b) When combusting biomass, visible emission notations of Boiler B-1 stack exhaust shall be performed daily during normal daylight operations. A trained employee shall record whether emissions are normal or abnormal.

- (c) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.
- (d) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- (e) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.
- (f) If abnormal emissions are observed, the Permittee shall take reasonable response steps in accordance with Section C- Response to Excursions or Exceedances. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances shall be considered a deviation from this permit.

D.1.11 Cyclone Failure Detection

In the event that cyclone failure has been observed:

Failed units and the associated process will be shut down immediately until the failed units have been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions). Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances, shall be considered a deviation from this permit.

Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

D.1.12 Record Keeping Requirements

- (a) To document compliance with Conditions D.1.1, D.1.2 and D.1.3, the Permittee shall maintain records of the amount of each type of fuel (untreated corn, wood (including bark), wood pellets, switchgrass, clean, untreated construction debris, No. 2 distillate fuel oil and natural gas) burned in the boilers, as well as the calculated twelve (12) consecutive month NO_x and CO emissions in accordance with (1) through (6) below. Records maintained for (1) through (6) shall be taken monthly and shall be complete and sufficient to establish compliance with the SO₂, NO_x and CO emission limits established in Conditions D.1.1, D.1.2 and D.1.3.
 - (1) Calendar dates covered in the compliance determination period;
 - (2) Actual fuel oil usage since last compliance determination period and equivalent sulfur dioxide emissions;
 - (3) A certification, signed by the owner or operator, that the records of the fuel supplier certifications represent all of the fuel combusted during the period. The natural gas fired boiler certification does require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1); and

If the fuel supplier certification is used to demonstrate compliance the following, as a minimum, shall be maintained:

 - (4) Fuel supplier certifications;
 - (5) The name of the fuel supplier; and
 - (6) A statement from the fuel supplier that certifies the sulfur content of the fuel oil.

- (b) Pursuant to 326 IAC 12, the Permittee shall maintain daily records of the amount and type of fuel combusted by the boilers. This condition expires when the transitions made to 40 CFR 60, Subpart Dc as amended on February 27, 2006, becomes an Indiana law. This condition is not federally enforceable.
- (c) To document compliance with Condition D.1.10, the Permittee shall maintain records of visible emission notations of Boilers B-1, B-4, and B-5 stack exhausts while combusting fuel oil and biomass. The Permittee shall include in its daily record when a visible emission notation is not taken and the reason for the lack of visible emission notation, (i.e. the process did not operate that day).
- (d) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

D.1.13 Reporting Requirements

- (a) A quarterly summary of the information to document compliance with Condition D.1.1 shall be submitted to the address listed in Section C - General Reporting Requirements, of this permit, using the reporting forms located at the end of this permit, or their equivalent, within thirty (30) days after the end of the quarter being reported. The report submitted by the Permittee does require the certification by the "authorized individual" as defined by 326 IAC 2-1-1(1).
- (b) The Permittee shall certify, on the form provided, that natural gas was fired in the boiler at all times during each quarter. Alternatively, the Permittee shall report the number of days during which an alternate fuel was burned during each quarter.

New Source Performance Standards (NSPS) Requirements [326 IAC 2-7-5(1)]

D.1.14 General Provisions Relating to New Source Performance Standards (NSPS) for Small Industrial-Commercial-Institutional Steam Generating Units [326 IAC 12-1][40 CFR Part 60, Subpart A] [40 CFR Part 60, Subpart Dc]

Pursuant to 40 CFR 60, Subpart Dc, the Permittee shall comply with the provisions of 40 CFR Part 60, Subpart A – General Provisions, which are incorporated by reference as 326 IAC 12-1-1 for the for the boilers (B-1 and B-5) as specified in Appendix A of 40 CFR Part 60, in accordance with the schedule in 40 CFR 60, Subpart Dc.

D.1.15 New Source Performance Standards (NSPS) for Small Industrial-Commercial-Institutional Steam Generating Units [40 CFR Part 60, Subpart Dc]

Pursuant to 40 CFR Part 60, Subpart Dc, the Permittee shall comply with the provisions of 40 CFR Part 60, Subpart Dc, which are incorporated by reference as 326 IAC 12-1 for the boilers (B-1 and B-5) as specified as follows:

§ 60.40c Applicability and delegation of authority.

(a) Except as provided in paragraph (d) of this section, the affected facility to which this subpart applies is each steam generating unit for which construction, modification, or reconstruction is commenced after June 9, 1989 and that has a maximum design heat input capacity of 29 megawatts (MW) (100 million British thermal units per hour (MMBtu/hr)) or less, but greater than or equal to 2.9 MW (10 MMBtu/hr).

(b) In delegating implementation and enforcement authority to a State under section 111(c) of the Clean Air Act, Sec. 60.48c(a)(4) shall be retained by the Administrator and not transferred to a State.

(c) Steam generating units that meet the applicability requirements in paragraph (a) of this section are not subject to the sulfur dioxide (SO₂) or particulate matter (PM) emission limits, performance testing requirements, or monitoring requirements under this subpart (Sec. Sec. 60.42c, 60.43c, 60.44c, 60.45c, 60.46c, or 60.47c) during periods of combustion research, as defined in Sec. 60.41c.

(d) Any temporary change to an existing steam generating unit for the purpose of conducting combustion research is not considered a modification under Sec. 60.14.

§ 60.41c Definitions.

As used in this subpart, all terms not defined herein shall have the meaning given them in the Clean Air Act and in subpart A of this part.

Annual capacity factor means the ratio between the actual heat input to a steam generating unit from an individual fuel or combination of fuels during a period of 12 consecutive calendar months and the potential heat input to the steam generating unit from all fuels had the steam generating unit been operated for 8,760 hours during that 12-month period at the maximum design heat input capacity. In the case of steam generating units that are rented or leased, the actual heat input shall be determined based on the combined heat input from all operations of the affected facility during a period of 12 consecutive calendar months.

Coal means all solid fuels classified as anthracite, bituminous, subbituminous, or lignite by the American Society of Testing and Materials in ASTM D388 (incorporated by reference, see Sec. 60.17), coal refuse, and petroleum coke. Coal-derived synthetic fuels derived from coal for the purposes of creating useful heat, including but not limited to solvent refined coal, gasified coal, coal-oil mixtures, and coal-water mixtures, are also included in this definition for the purposes of this subpart.

Coal refuse means any by-product of coal mining or coal cleaning operations with an ash content greater than 50 percent (by weight) and a heating value less than 13,900 kilojoules per kilogram (kJ/kg) (6,000 Btu per pound (Btu/lb) on a dry basis.

Cogeneration steam generating unit means a steam generating unit that simultaneously produces both electrical (or mechanical) and thermal energy from the same primary energy source.

Combined cycle system means a system in which a separate source (such as a stationary gas turbine, internal combustion engine, or kiln) provides exhaust gas to a steam generating unit.

Combustion research means the experimental firing of any fuel or combination of fuels in a steam generating unit for the purpose of conducting research and development of more efficient combustion or more effective prevention or control of air pollutant emissions from combustion, provided that, during these periods of research and development, the heat generated is not used for any purpose other than preheating combustion air for use by that steam generating unit (i.e., the heat generated is released to the atmosphere without being used for space heating, process heating, driving pumps, preheating combustion air for other units, generating electricity, or any other purpose).

Conventional technology means wet flue gas desulfurization technology, dry flue gas desulfurization technology, atmospheric fluidized bed combustion technology, and oil hydrodesulfurization technology.

Distillate oil means fuel oil that complies with the specifications for fuel oil numbers 1 or 2, as defined by the American Society for Testing and Materials in ASTM D396 (incorporated by reference, see Sec. 60.17).

Dry flue gas desulfurization technology means a SO₂ control system that is located between the steam generating unit and the exhaust vent or stack, and that removes sulfur oxides from the combustion gases of the steam generating unit by contacting the combustion gases with an alkaline reagent and water, whether introduced separately or as a premixed slurry or solution and forming a dry powder material. This definition includes devices where the dry powder material is subsequently converted to another form. Alkaline reagents used in dry flue gas desulfurization systems include, but are not limited to, lime and sodium compounds.

Duct burner means a device that combusts fuel and that is placed in the exhaust duct from another source (such as a stationary gas turbine, internal combustion engine, kiln, etc.) to allow the firing of additional fuel to heat the exhaust gases before the exhaust gases enter a steam generating unit.

Emerging technology means any SO₂ control system that is not defined as a conventional technology under this section, and for which the owner or operator of the affected facility has received approval from the Administrator to operate as an emerging technology under Sec. 60.48c(a)(4).

Federally enforceable means all limitations and conditions that are enforceable by the Administrator, including the requirements of 40 CFR parts 60 and 61, requirements within any applicable State implementation plan, and any permit requirements established under 40 CFR 52.21 or under 40 CFR 51.18 and 51.24.

Fluidized bed combustion technology means a device wherein fuel is distributed onto a bed (or series of beds) of limestone aggregate (or other sorbent materials) for combustion; and these materials are forced upward in the device by the flow of combustion air and the gaseous products of combustion. Fluidized bed combustion technology includes, but is not limited to, bubbling bed units and circulating bed units.

Fuel pretreatment means a process that removes a portion of the sulfur in a fuel before combustion of the fuel in a steam generating unit.

Heat input means heat derived from combustion of fuel in a steam generating unit and does not include the heat derived from preheated combustion air, recirculated flue gases, or exhaust gases from other sources (such as stationary gas turbines, internal combustion engines, and kilns).

Heat transfer medium means any material that is used to transfer heat from one point to another point.

Maximum design heat input capacity means the ability of a steam generating unit to combust a stated maximum amount of fuel (or combination of fuels) on a steady state basis as determined by the physical design and characteristics of the steam generating unit.

Natural gas means: (1) A naturally occurring mixture of hydrocarbon and nonhydrocarbon gases found in geologic formations beneath the earth's surface, of which the principal constituent is methane; or (2) liquefied petroleum (LP) gas, as defined by the American Society for Testing and Materials in ASTM D1835 (incorporated by reference, see Sec. 60.17).

Noncontinental area means the State of Hawaii, the Virgin Islands, Guam, American Samoa, the Commonwealth of Puerto Rico, or the Northern Mariana Islands.

Oil means crude oil or petroleum, or a liquid fuel derived from crude oil or petroleum, including distillate oil and residual oil.

Potential sulfur dioxide emission rate means the theoretical SO₂ emissions (nanograms per joule (ng/J) or lb/MMBtu heat input) that would result from combusting fuel in an uncleaned state and without using emission control systems.

Process heater means a device that is primarily used to heat a material to initiate or promote a chemical reaction in which the material participates as a reactant or catalyst.

Residual oil means crude oil, fuel oil that does not comply with the specifications under the definition of distillate oil, and all fuel oil numbers 4, 5, and 6, as defined by the American Society for Testing and Materials in ASTM D396 (incorporated by reference, see Sec. 60.17).

Steam generating unit means a device that combusts any fuel and produces steam or heats water or any other heat transfer medium. This term includes any duct burner that combusts fuel and is part of a combined cycle system. This term does not include process heaters as defined in this subpart.

Steam generating unit operating day means a 24-hour period between 12:00 midnight and the following midnight during which any fuel is combusted at any time in the steam generating unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period.

Wet flue gas desulfurization technology means an SO₂ control system that is located between the steam generating unit and the exhaust vent or stack, and that removes sulfur oxides from the combustion gases of the steam generating unit by contacting the combustion gases with an alkaline slurry or solution and forming a liquid material. This definition includes devices where the liquid material is subsequently converted to another form. Alkaline reagents used in wet flue gas desulfurization systems include, but are not limited to, lime, limestone, and sodium compounds.

Wet scrubber system means any emission control device that mixes an aqueous stream or slurry with the exhaust gases from a steam generating unit to control emissions of PM or SO₂.

Wood means wood, wood residue, bark, or any derivative fuel or residue thereof, in any form, including but not limited to sawdust, sanderdust, wood chips, scraps, slabs, millings, shavings, and processed pellets made from wood or other forest residues.

§ 60.42c Standard for sulfur dioxide.

(d) On and after the date on which the initial performance test is completed or required to be completed under Sec. 60.8, whichever date comes first, no owner or operator of an affected facility that combusts oil shall cause to be discharged into the atmosphere from that affected facility any gases that contain SO₂ in excess of 215 ng/J (0.50 lb/MMBtu) heat input; or, as an alternative, no owner or operator of an affected facility that combusts oil shall combust oil in the affected facility that contains greater than 0.5 weight percent sulfur. The percent reduction requirements are not applicable to affected facilities under this paragraph.

(g) Except as provided in paragraph (h) of this section, compliance with the percent reduction requirements, fuel oil sulfur limits, and emission limits of this section shall be determined on a 30-day rolling average basis.

(h) For affected facilities listed under paragraphs (h)(1), (2), or (3) of this section, compliance with the emission limits or fuel oil sulfur limits under this section may be determined based on a certification from the fuel supplier, as described under Sec. 60.48c(f), as applicable.

(1) Distillate oil-fired affected facilities with heat input capacities between 2.9 and 29 MW (10 and 100 MMBtu/hr).

(i) The SO₂ emission limits, fuel oil sulfur limits, and percent reduction requirements under this section apply at all times, including periods of startup, shutdown, and malfunction.

(j) Only the heat input supplied to the affected facility from the combustion of coal and oil is counted under this section. No credit is provided for the heat input to the affected facility from wood or other fuels or for heat derived from exhaust gases from other sources, such as stationary gas turbines, internal combustion engines, and kilns.

§ 60.44c Compliance and performance test methods and procedures for sulfur dioxide.

(a) Except as provided in paragraphs (g) and (h) of this section and Sec. 60.8(b), performance tests required under Sec. 60.8 shall be conducted following the procedures specified in paragraphs (b), (c), (d), (e), and (f) of this section, as applicable. Section 60.8(f) does not apply to this section. The 30-day notice required in Sec. 60.8(d) applies only to the initial performance test unless otherwise specified by the Administrator.

(b) The initial performance test required under Sec. 60.8 shall be conducted over 30 consecutive operating days of the steam generating unit. Compliance with the percent reduction requirements and

SO₂ emission limits under Sec. 60.42c shall be determined using a 30-day average. The first operating day included in the initial performance test shall be scheduled within 30 days after achieving the maximum production rate at which the affected facility will be operated, but not later than 180 days after the initial startup of the facility. The steam generating unit load during the 30-day period does not have to be the maximum design heat input capacity, but must be representative of future operating conditions.

(g) For oil-fired affected facilities where the owner or operator seeks to demonstrate compliance with the fuel oil sulfur limits under Sec. 60.42c based on shipment fuel sampling, the initial performance test shall consist of sampling and analyzing the oil in the initial tank of oil to be fired in the steam generating unit to demonstrate that the oil contains 0.5 weight percent sulfur or less. Thereafter, the owner or operator of the affected facility shall sample the oil in the fuel tank after each new shipment of oil is received, as described under Sec. 60.46c(d)(2).

(h) For affected facilities subject to Sec. 60.42c(h)(1), (2), or (3) where the owner or operator seeks to demonstrate compliance with the SO₂ standards based on fuel supplier certification, the performance test shall consist of the certification, the certification from the fuel supplier, as described under Sec. 60.48c(f), as applicable.

§ 60.46c Emission monitoring for sulfur dioxide

(e) The monitoring requirements of paragraphs (a) and (d) of this section shall not apply to affected facilities subject to Sec. 60.42c(h) (1), (2), or (3) where the owner or operator of the affected facility seeks to demonstrate compliance with the SO₂ standards based on fuel supplier certification, as described under Sec. 60.48c(f), as applicable.

§ 60.48c Reporting and recordkeeping requirements.

(a) The owner or operator of each affected facility shall submit notification of the date of construction or reconstruction and actual startup, as provided by Sec. 60.7 of this part. This notification shall include:

(1) The design heat input capacity of the affected facility and identification of fuels to be combusted in the affected facility.

(2) If applicable, a copy of any federally enforceable requirement that limits the annual capacity factor for any fuel or mixture of fuels under Sec. 60.42c, or Sec. 60.43c.

(3) The annual capacity factor at which the owner or operator anticipates operating the affected facility based on all fuels fired and based on each individual fuel fired.

(4) Notification if an emerging technology will be used for controlling SO₂ emissions. The Administrator will examine the description of the control device and will determine whether the technology qualifies as an emerging technology. In making this determination, the Administrator may require the owner or operator of the affected facility to submit additional information concerning the control device. The affected facility is subject to the provisions of Sec. 60.42c(a) or (b)(1), unless and until this determination is made by the Administrator.

(b) The owner or operator of each affected facility subject to the SO₂ emission limits of Sec. 60.42c, or the PM or opacity limits of Sec. 60.43c, shall submit to the Administrator the performance test data from the initial and any subsequent performance tests and, if applicable, the performance evaluation of the CEMS and/or COMS using the applicable performance specifications in appendix B of this part.

(d) The owner or operator of each affected facility subject to the SO₂ emission limits, fuel oil sulfur limits, or percent reduction requirements under Sec. 60.42c shall submit reports to the Administrator.

(e) The owner or operator of each affected facility subject to the SO₂ emission limits, fuel oil sulfur limits, or percent reduction requirements under Sec. 60.42c shall keep records and submit reports as required under paragraph (d) of this section, including the following information, as applicable.

(1) Calendar dates covered in the reporting period.

(2) Each 30-day average SO₂ emission rate (ng/J or lb/MMBtu), or 30-day average sulfur content (weight percent), calculated during the reporting period, ending with the last 30-day period; reasons for any noncompliance with the emission standards; and a description of corrective actions taken.

(3) Each 30-day average percent of potential SO₂ emission rate calculated during the reporting period, ending with the last 30-day period; reasons for any noncompliance with the emission standards; and a description of the corrective actions taken.

(4) Identification of any steam generating unit operating days for which SO₂ or diluent (O₂ or CO₂) data have not been obtained by an approved method for at least 75 percent of the operating hours; justification for not obtaining sufficient data; and a description of corrective actions taken.

(5) Identification of any times when emissions data have been excluded from the calculation of average emission rates; justification for excluding data; and a description of corrective actions taken if data have been excluded for periods other than those during which coal or oil were not combusted in the steam generating unit.

(6) Identification of the F factor used in calculations, method of determination, and type of fuel combusted.

(11) If fuel supplier certification is used to demonstrate compliance, records of fuel supplier certification is used to demonstrate compliance, records of fuel supplier certification as described under paragraph (f)(1), (2), (3), or (4) of this section, as applicable. In addition to records of fuel supplier certifications, the report shall include a certified statement signed by the owner or operator of the affected facility that the records of fuel supplier certifications submitted represent all of the fuel combusted during the reporting period.

(f) Fuel supplier certification shall include the following information:

(1) For distillate oil:

(i) The name of the oil supplier;

(ii) A statement from the oil supplier that the oil complies with the specifications under the definition of distillate oil in Sec. 60.41c; and

(iii) The sulfur content of the oil.

g)(1) Except as provided under paragraphs (g)(2) and (g)(3) of this section, the owner or operator of each affected facility shall record and maintain records of the amount of each fuel combusted during each operating day.

(2) As an alternative to meeting the requirements of paragraph (g)(1) of this section, the owner or operator of an affected facility that combusts only natural gas, wood, fuels using fuel certification in Sec. 60.48c(f) to demonstrate compliance with the SO₂ standard, fuels not subject to an emissions standard (excluding opacity), or a mixture of these fuels may elect to record and maintain records of the amount of each fuel combusted during each calendar month.

(i) All records required under this section shall be maintained by the owner or operator of the affected facility for a period of two years following the date of such record.

(j) The reporting period for the reports required under this subpart is each six-month period. All reports shall be submitted to the Administrator and shall be postmarked by the 30th day following the end of the reporting period.

SECTION D.2

FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-8-4(10)]:

- (f) One (1) biomass handling and storage operation, approved for construction in 2007 and modified in 2008, consisting of the following:
 - (1) One (1) truck unloading operation with a maximum throughput of 224,000 pounds of biomass per hour.
 - (2) One (1) biomass storage silo, with a maximum storage capacity of 762,552 pounds of biomass (volumetric capacity 15,987 cubic feet), with emissions controlled by a baghouse.
 - (3) One (1) biomass handling system with a maximum throughput of 252,000 pounds per hour, with emissions controlled by a baghouse including: five (5) augers, one (1) conveyor, one (1) bucket elevator, and one (1) metering bin.
- (g) One (1) ash disposal system, approved for construction in 2007, with a maximum throughput of 500 pounds of ash per hour, with emissions controlled by a cyclone including: three (3) augers.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-8-4(1)]

D.2.1 Particulate [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacture Processes), the allowable particulate emission rate from each process shall be limited by using either of the following equations:

Interpolation of the data for the process weight rate up to sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 4.10 P^{0.67} \quad \text{where } E = \text{rate of emission in pounds per hour and } P = \text{process weight rate in tons per hour}$$

or

Interpolation and extrapolation of the data for the process weight rate in excess of 60,000 pounds per hour shall be accomplished by use of the equation:

$$E = 55.0 P^{0.11} - 40 \quad \text{where } E = \text{rate of emission in pounds per hour and } P = \text{process weight rate in tons per hour}$$

The following table shows the maximum process weight rate and allowable particulate emission rate for each emission unit:

Emission Unit	Process Weight Rate (tons/hour)	Particulate Emission Limit (lbs/hr)
Truck Unloading Operation	112	52.4
Biomass Handling System	126	53.6
Ash handling System	0.25	1.62

D.2.2 PM₁₀ Limitations [326 IAC 2-8-4]

The PM₁₀ emissions from the baghouse controlling the emissions from biomass handling operations shall not exceed 10.81 pounds per hour. Compliance with this limit, combined with the PM₁₀ emissions from the other emission units at this source shall limit the source-wide potential to emit PM₁₀ to less than 100 tons per twelve (12) consecutive month period, and render 326 IAC 2-7 (Part 70 Program) not applicable.

D.2.3 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

A Preventive Maintenance Plan, in accordance with Section B - Preventive Maintenance Plan, of this permit is required for these facilities and any control devices.

Compliance Determination Requirements

D.2.4 Particulate Control

- (a) In order to comply with Condition D.2.2, the biomass handling operation shall be controlled by a baghouse when these units are in operation.
- (b) In the event that bag failure is observed in a multi-compartment baghouse, if operations will continue for ten (10) days or more after the failure is observed before the failed units will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed units will be repaired or replaced. The notification shall also include the status of the applicable compliance monitoring parameters with respect to normal, and the results of any response actions taken up to the time of notification.

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

D.2.5 Visible Emissions Notations

- (a) Visible emission notations of the baghouse stack exhausts shall be performed once per day during normal daylight operations. A trained employee shall record whether emissions are normal or abnormal.
- (b) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eight percent (80%) of the time the process is in operation, not counting startup or shutdown time.
- (c) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- (d) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.
- (e) If abnormal emissions are observed, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances shall be considered a deviation from this permit.

D.2.6 Parametric Monitoring

- (a) The Permittee shall record the pressure drop across the baghouse used in conjunction with the biomass handling operations at least once per day when these units are in operation. When for any one reading, the pressure drop across the baghouse is outside the normal range of 1.0 to 6.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take

response steps in accordance with Section C - Response to Excursions or Exceedances shall be considered a deviation from this permit.

- (b) The instrument used for determining the pressure shall comply with Section C - Instrument Specifications, of this permit, shall be subject to approval by IDEM, OAQ and shall be calibrated at least once every six (6) months.

D.2.7 Broken or Failed Bag Detection

- (a) For a single compartment baghouse controlling emissions from a process operated continuously, a failed unit and the associated process shall be shut down immediately until the failed unit has been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).
- (b) For a single compartment baghouse controlling emissions from a batch process, the feed to the process shall be shut down immediately until the failed unit has been repaired or replaced. The emissions unit shall be shut down no later than the completion of the processing of the material in the line. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).

Bag failure can be a significant drop in the baghouse's pressure reading with abnormal visible emissions, by an opacity violation, or by other means such as gas temperature, flow rate, air infiltration, leaks, dust traces or triboflows.

Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

D.2.8 Record Keeping Requirements

- (a) To document compliance with D.2.5, the Permittee shall maintain records of daily visible emission notations of the baghouse stack exhausts. The Permittee shall include its daily record when a visible emission notation is not taken and the reason for the lack of visible emission notation (e.g. the process did not operate that day).
- (b) To document compliance with D.2.6, the Permittee shall maintain daily records of pressure drop for baghouses during normal operation. The Permittee shall include in its daily record when a pressure drop reading is not taken and the reason for the lack of a pressure drop reading (e.g. the process did not operate that day).
- (c) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

SECTION D.3

FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-8-4(10)]:

- (c) Degreasing operations that do not exceed 145 gallons per 12 months, except if subject to 326 IAC 20-6; (326 IAC 8-3-2) (326 IAC 8-3-5)
- (d) The following equipment related to manufacturing activities not resulting in the emission of HAPs: brazing equipment, cutting torches, soldering equipment, welding equipment; (326 IAC 6-3-2)

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards

D.3.1 Particulate (PM) [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), the allowable particulate emission rate from the brazing, cutting, soldering, and welding, operations shall not exceed the allowable PM emission rate based on the following equation:

Interpolation of the data for the process weight rate up to 60,000 pounds per hour shall be accomplished by use of the equation:

$$E = 4.10 P^{0.67} \quad \text{where } E = \text{rate of emission in pounds per hour; and} \\ P = \text{process weight rate in tons per hour.}$$

D.3.2 Volatile Organic Compounds (VOC) [326 IAC 8-3-2]

The insignificant degreasing operations are subject to the provisions of 326 IAC 8-3-2 (Organic solvent degreasing operations: cold cleaner operations). Pursuant to this rule, the owner or operator shall:

- (a) equip the cleaner with a cover;
- (b) equip the cleaner with a facility for draining cleaned parts;
- (c) close the degreaser cover whenever parts are not being handled in the cleaner;
- (d) drain cleaned parts for at least fifteen (15) seconds or until dripping ceases;
- (e) provide a permanent, conspicuous label summarizing the operating requirements;
- (f) store waste solvent only in covered containers and not dispose of waste solvent or transfer it to another party, in such a manner that greater than twenty percent (20%) of the waste solvent (by weight) can evaporate into the atmosphere.

D.3.3 Volatile Organic Compounds (VOC) [326 IAC 8-3-5]

(a) Pursuant to 326 IAC 8-3-5(a) (Cold Cleaner Degreaser Operation and Control), the owner or operator shall ensure that the following control equipment requirements are met:

- (1) Equip the degreaser with a cover. The cover must be designed so that it can be easily operated with one (1) hand if:

- (A) The solvent volatility is greater than two (2) kiloPascals (fifteen (15) millimeters of mercury or three-tenths (0.3) pounds per square inch) measured at thirty-eight degrees Celsius (38°C) (one hundred degrees Fahrenheit (100°F));
 - (B) The solvent is agitated; or
 - (C) The solvent is heated.
- (2) Equip the degreaser with a facility for draining cleaned articles. If the solvent volatility is greater than four and three-tenths (4.3) kiloPascals (thirty-two (32) millimeters of mercury or six-tenths (0.6) pounds per square inch) measured at thirty-eight degrees Celsius (38°C) (one hundred degrees Fahrenheit (100°F)), then the drainage facility must be internal such that articles are enclosed under the cover while draining. The drainage facility may be external for applications where an internal type cannot fit into the cleaning system.
- (3) Provide a permanent, conspicuous label which lists the operating requirements outlined in subsection (b).
- (4) The solvent spray, if used, must be a solid, fluid stream and shall be applied at a pressure which does not cause excessive splashing.
- (5) Equip the degreaser with one (1) of the following control devices if the solvent volatility is greater than four and three-tenths (4.3) kiloPascals (thirty-two (32) millimeters of mercury or six-tenths (0.6) pounds per square inch) measured at thirty-eight degrees Celsius (38°C) (one hundred degrees Fahrenheit (100°F)), or if the solvent is heated to a temperature greater than forty-eight and nine-tenths degrees Celsius (48.9°C) (one hundred twenty degrees Fahrenheit (120°F)):
- (A) A freeboard that attains a freeboard ratio of seventy-five hundredths (0.75) or greater.
 - (B) A water cover when solvent is used is insoluble in, and heavier than, water.
 - (C) Other systems of demonstrated equivalent control such as a refrigerated chiller or carbon adsorption. Such systems shall be submitted to the U.S. EPA as a SIP revision.
- (b) Pursuant to 326 IAC 8-3-5(b) (Cold Cleaner Degreaser Operation and Control), the owner or operator of a cold cleaning facility construction of which commenced after July 1, 1990, shall ensure that the following operating requirements are met:
- (1) Close the cover whenever articles are not being handled in the degreaser.
 - (2) Drain cleaned articles for at least fifteen (15) seconds or until dripping ceases.
 - (3) Store waste solvent only in covered containers and prohibit the disposal or transfer of waste solvent in any manner in which greater than twenty percent (20%) of the waste solvent by weight could evaporate.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH**

**FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP)
CERTIFICATION**

Source Name: Pendleton Correctional Facility
Source Address: 4490 West Reformatory Road, Pendleton, IN 46064
Mailing Address: 4490 West Reformatory Road, Pendleton, IN 46064
FESOP No.: F095-16603-00006

This certification shall be included when submitting monitoring, testing reports/results or other documents as required by this permit.

Please check what document is being certified:

- Annual Compliance Certification Letter
- Test Result (specify) _____
- Report (specify) _____
- Notification (specify) _____
- Affidavit (specify) _____
- Other (specify) _____

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Signature:

Printed Name:

Title/Position:

Date:

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251
Phone: 317-233-0178
Fax: 317-233-6865**

**FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP)
EMERGENCY OCCURRENCE REPORT**

Source Name: Pendleton Correctional Facility
Source Address: 4490 West Reformatory Road, Pendleton, IN 46064
Mailing Address: 4490 West Reformatory Road, Pendleton, IN 46064
FESOP No.: F095-16603-00006

This form consists of 2 pages

Page 1 of 2

- This is an emergency as defined in 326 IAC 2-7-1(12)
- The Permittee must notify the Office of Air Quality (OAQ), within four (4) business hours (1-800-451-6027 or 317-233-0178, ask for Compliance and Enforcement Branch); and
 - The Permittee must submit notice in writing or by facsimile within two (2) working days (Facsimile Number: 317-233-6865), and follow the other requirements of 326 IAC 2-7-16

If any of the following are not applicable, mark N/A

Facility/Equipment/Operation:
Control Equipment:
Permit Condition or Operation Limitation in Permit:
Description of the Emergency:
Describe the cause of the Emergency:

If any of the following are not applicable, mark N/A

Page 2 of 2

Date/Time Emergency started:
Date/Time Emergency was corrected:
Was the facility being properly operated at the time of the emergency? Y N Describe:
Type of Pollutants Emitted: TSP, PM-10, SO ₂ , VOC, NO _x , CO, Pb, other:
Estimated amount of pollutant(s) emitted during emergency:
Describe the steps taken to mitigate the problem:
Describe the corrective actions/response steps taken:
Describe the measures taken to minimize emissions:
If applicable, describe the reasons why continued operation of the facilities are necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw materials of substantial economic value:

Form Completed by: _____
Title / Position: _____
Date: _____
Phone: _____

A certification is not required for this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH**

**FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP)
SEMI- ANNUAL NATURAL GAS FIRED BOILER CERTIFICATION**

Source Name: Pendleton Correctional Facility
Source Address: 4490 West Reformatory Road, Pendleton, IN 46064
Mailing Address: 4490 West Reformatory Road, Pendleton, IN 46064
FESOP No.: F095-16603-00006

Natural Gas Only
 Alternate Fuel burned
From: _____ To: _____

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Signature:

Printed Name:

Title/Position:

Date:

Attach a signed certification to complete this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH**

FESOP Quarterly Report

Source Name: Pendleton Correctional Facility
Source Address: 4490 West Reformatory Road, Pendleton, IN 46064
Mailing Address: 4490 West Reformatory Road, Pendleton, IN 46064
FESOP No.: F095-16603-00006
Facility: Two (2) natural gas and No. 2 fuel oil boilers, identified as boiler B-4 and B-5
Parameter: Kilo Gallons of No. 2 fuel oil burned
Limit: 500 kilo gallons of No. 2 distillate fuel oil or equivalent fuel per twelve (12) consecutive month period, with compliance determined at the end of each month.

YEAR: _____

Month	Kilo Gallons of No. 2 fuel oil burned	Kilo Gallons of No. 2 fuel oil burned	Kilo Gallons of No. 2 fuel oil burned
	This Month	Previous 11 Months	12 Month Total

No deviation occurred in this quarter.

Deviation/s occurred in this quarter.

Deviation has been reported on: _____

Submitted by: _____

Title / Position: _____

Signature: _____

Date: _____

Phone: _____

Attach a signed certification to complete this report.

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT OFFICE OF AIR QUALITY COMPLIANCE AND ENFORCMENT BRANCH

FESOP Quarterly Report

Source Name: Pendleton Correctional Facility
Source Address: 4490 West Reformatory Road, Pendleton, IN 46064
Mailing Address: 4490 West Reformatory Road, Pendleton, IN 46064
FESOP No.: F095-16603-00006
Facility: Boilers B-1 through B-5
Parameter: Biomass or equivalent fuel usage
Limit: (a) The total amount of fuel (untreated corn, wood (including bark), wood pellets, switchgrass, clean, untreated construction debris and natural gas) burned by Boiler #1, Boiler # 2, Boiler # 3, Boiler # 4 shall be limited such that NOx emissions shall not exceed 90.3 tons per twelve (12) consecutive month period with compliance determined at the end of each month based on the following equation.
(b) The total amount of fuel (untreated corn, wood (including bark), wood pellets, switchgrass, clean, untreated construction debris and natural gas) burned by Boiler #1, Boiler # 2, Boiler # 3, Boiler # 4 shall be limited such that CO emissions shall not exceed 97.0 tons per twelve (12) consecutive month period with compliance determined at the end of each month based on the following equation.

$$E_{NOx} = \frac{(CE_{Corn} * Q_{Corn}) + (CE_{SG} * Q_{SG}) + (2.9 * Q_{Bark}) + (7.92 * Q_{Wood}) + (100 * Q_{NG})}{2000 \text{ lbs/ton}}$$

Where:

E_{NOx} = Emissions of NOx in tons per month
 CE_{Corn} = Compliance emission factor for NOx shall be 10.2 pounds NOx per ton corn until an IDEM approved stack test is conducted. After a stack test is conducted, the emission factor shall be the lb/ton value as established by the stack test
 Q_{Corn} = Corn consumption in tons per month
 CE_{SG} = Compliance emission factor for NOx shall be 10.2 pounds NOx per ton switchgrass until an IDEM approved stack test is conducted. After a stack test is conducted, the emission factor shall be the lb/ton value as established by the stack test
 Q_{SG} = Switchgrass consumption in tons per month
 Q_{Bark} = Wood (including bark and clean, untreated construction debris) consumption in tons per month
 Q_{Wood} = Wood pellets consumption in tons per month
 Q_{NG} = Natural Gas consumption in MMCF per month

$$E_{CO} = \frac{(CE_{Corn} * Q_{Corn}) + (CE_{SG} * Q_{SG}) + (7.74 * Q_{Bark}) + (9.48 * Q_{Wood}) + (84 * Q_{NG})}{2000 \text{ lbs/ton}}$$

Where:

E_{CO} = Emissions of CO in tons per month
 CE_{Corn} = Compliance Emission Factor for CO shall be 8.16 pounds CO per ton Corn until an IDEM approved stack test is conducted. After a stack test is conducted, the emission factor shall be the lb/ton value as established by the stack test
 Q_{Corn} = Corn consumption in tons per month.
 CE_{SG} = Compliance emission factor for NOx shall be 10.2 pounds NOx per ton switchgrass until an IDEM approved stack test is conducted. After a stack test is conducted, the emission factor shall be the lb/ton value as established by the stack test
 Q_{SG} = Switchgrass consumption in tons per month
 Q_{Bark} = Wood (including bark and clean, untreated construction debris) consumption in tons per month
 Q_{Wood} = Wood pellets consumption in tons per month
 Q_{NG} = Natural Gas consumption in MMCF per month

This FESOP Quarterly Report consists of 2 pages.

YEAR: _____

Month	NOx Emissions	NOx Emissions	NOx Emissions
	This Month	Previous 11 Months	12 Month Total

Month	CO Emissions	CO Emissions	CO Emissions
	This Month	Previous 11 Months	12 Month Total

No deviation occurred in this quarter.

Deviation/s occurred in this quarter.

Deviation has been reported on: _____

Submitted by: _____

Title / Position: _____

Signature: _____

Date: _____

Phone: _____

Attach a signed certification to complete this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH**

**FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP)
QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT**

Source Name: Pendleton Correctional Facility
Source Address: 4490 West Reformatory Road, Pendleton, IN 46064
Mailing Address: 4490 West Reformatory Road, Pendleton, IN 46064
FESOP No.: F095-16603-00006

Months: _____ to _____ Year: _____

Page 1 of 2

<p>This report shall be submitted quarterly based on a calendar year. Any deviation from the requirements, the date(s) of each deviation, the probable cause of the deviation, and the response steps taken must be reported. A deviation required to be reported pursuant to an applicable requirement that exists independent of the permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. Additional pages may be attached if necessary. If no deviations occurred, please specify in the box marked "No deviations occurred this reporting period".</p>	
<input type="checkbox"/> NO DEVIATIONS OCCURRED THIS REPORTING PERIOD.	
<input type="checkbox"/> THE FOLLOWING DEVIATIONS OCCURRED THIS REPORTING PERIOD	
Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	

Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	

Form Completed By: _____

Title/Position: _____

Date: _____

Phone: _____

Attach a signed certification to complete this report.