



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

TO: Interested Parties / Applicant

DATE: Sept. 21, 2009

RE: St. Francis Hospital & Health Centers / 097-28398-00304

FROM: Matthew Stuckey, Branch Chief
Permits Branch
Office of Air Quality

Notice of Decision – Approval

Please be advised that on behalf of the Commissioner of the Department of Environmental Management, I have issued a decision regarding the enclosed matter. Pursuant to 326 IAC 2, this approval was effective immediately upon submittal of the application.

If you wish to challenge this decision, IC 4-21.5-3-7 requires that you file a petition for administrative review. This petition may include a request for stay of effectiveness and must be submitted to the Office of Environmental Adjudication, 100 North Senate Avenue, Government Center North, Suite N 501E, Indianapolis, IN 46204, **within eighteen (18) calendar days from the mailing of this notice**. The filing of a petition for administrative review is complete on the earliest of the following dates that apply to the filing:

- (1) the date the document is delivered to the Office of Environmental Adjudication (OEA);
- (2) the date of the postmark on the envelope containing the document, if the document is mailed to OEA by U.S. mail; or
- (3) The date on which the document is deposited with a private carrier, as shown by receipt issued by the carrier, if the document is sent to the OEA by private carrier.

The petition must include facts demonstrating that you are either the applicant, a person aggrieved or adversely affected by the decision or otherwise entitled to review by law. Please identify the permit, decision, or other order for which you seek review by permit number, name of the applicant, location, date of this notice and all of the following:

- (1) the name and address of the person making the request;
- (2) the interest of the person making the request;
- (3) identification of any persons represented by the person making the request;
- (4) the reasons, with particularity, for the request;
- (5) the issues, with particularity, proposed for considerations at any hearing; and
- (6) identification of the terms and conditions which, in the judgment of the person making the request, would be appropriate in the case in question to satisfy the requirements of the law governing documents of the type issued by the Commissioner.

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178. Callers from within Indiana may call toll-free at 1-800-451-6027, ext. 3-0178.

Enclosures
FNPER-AM.dot12/3/07



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

Mr. Marc Hyde
St. Francis Hospital and Health Centers
1600 Albany Street
Beech Grove, Indiana 46107

Sept. 21, 2009

Re: 097-28398-00304
First Notice-Only Change to
M097-19550-00304

Dear Mr. Hyde:

St. Francis Hospital and Health Centers was issued a Minor Source Operating Permit (MSOP) No. M097-19550-00304 on January 18, 2006 for stationary combustion units located at 8111 S. Emerson Avenue, Indianapolis, Indiana 46237. On August 31, 2009, the Office of Air Quality (OAQ) received an application from the source requesting that the permit be revised to remove all requirements related to local air pollution control agencies. Local agencies no longer have effective authority to implement state and federal requirements for IDEM. Therefore, IDEM has removed all references to local agencies from the permit. IDEM has determined that this change to the permit will be processed as a notice-only change pursuant to 326 IAC 2-6.1-6(d).

The revised permit specifies that all reports, notices, applications, and any other required submittals shall be submitted to IDEM. The Permittee should note that the local agency could have its own requirements beyond the state and federal requirements contained in the permit. Please contact the local agency for further information.

Pursuant to the provisions of 326 IAC 2-6.1-6, the permit is hereby revised as follows with the deleted language as ~~strikeouts~~ and new language **bolded**.

1. All references to local agencies have been removed from the permit.
2. IDEM has decided to add the following condition to the permit.

B.5 Enforceability

Unless otherwise stated, all terms and conditions in this permit, including any provisions designed to limit the source's potential to emit are enforceable by IDEM, the United States Environmental Protection Agency (U.S. EPA) and by citizens in accordance with the Clean Air Act.

2. The following conditions have been revised to add clarity to the permit.

B.12 Annual Fee Payment [326 IAC 2-1.1-7]

- (a) The Permittee shall pay annual fees to ~~OES~~ **IDEM OAQ** within thirty (30) calendar days of receipt of a billing.

- (b) The Permittee may call the following telephone number: ~~317-327-2234 (ask for Air Compliance)~~, **1-800-451-6207 or 317-233-4230 (as for OAQ, Billing, Licensing, and Training Section)**, to determine the appropriate permit fee.
4. Several of IDEM's branches and sections have been renamed. Therefore, IDEM has updated the addresses listed in the permit. References to "Permit Administration and Development Section" and the "Permits Branch" have been changed to "Permit Administration and Support Section". References to "Asbestos Section", "Compliance Data Section", "Air Compliance Section", and "Compliance Branch" have been changed to "Compliance and Enforcement Branch". The permit has been revised as follows:

Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

5. All occurrences of IDEM mailing addresses have been revised to include a mail code (MC) as follows:

Compliance and Enforcement Branch:	MC 61-53 IGCN 1003
Permit Administration and Support Section:	MC 61-53 IGCN 1003
Technical Support and Modeling Section:	MC 61-50 IGCN 1003

6. IDEM has begun implementing a new procedure and will no longer list the name or title of the Authorized Individual (A.I.) in the permit document. Section A.1 has been updated as follows:

Authorized Individual: _____ ????????????????????

7. The Compliance and Enforcement Branch facsimile number has been revised to 317-233-~~5967~~
6865.

All other conditions of the permit shall remain unchanged and in effect. Attached please find the entire revised permit. A copy of the permit is available on the Internet at: <http://www.in.gov/ai/appfiles/idem-caats/>. For additional information about air permits and how the public and interested parties can participate, refer to the IDEM's Guide for Citizen Participation and Permit Guide on the Internet at: www.idem.in.gov

This decision is subject to the Indiana Administrative Orders and Procedures Act - IC 4-21.5-3-5.
If you have any questions on this matter, please contact Gary Freeman, of my staff, at 317-233-5334 or 1-800-451-6027, and ask for extension 3-5334.

Sincerely,


Alfred C. Dumaul, Ph. D., Section Chief
Permits Branch
Office of Air Quality

Attachments: Updated Permit

ACD/gkf

cc: File - Marion County
Marion County Health Department
U.S. EPA, Region V
Compliance and Enforcement Branch
Billing, Licensing and Training Section



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

MINOR SOURCE OPERATING PERMIT INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT OFFICE OF AIR QUALITY

**St. Francis Hospital and Health Centers
8111 South Emerson Avenue
Indianapolis, Indiana 46237**

(herein known as the Permittee) is hereby authorized to operate subject to the conditions contained herein, the emission units described in Section A (Source Summary) of this permit.

This permit is issued to the above mentioned company under the provisions of 326 IAC 2-1.1, 326 IAC 2-5.1, 326 IAC 2-6.1 and 40 CFR 52.780, with conditions listed on the attached pages.

Operation Permit No.: MSOP 097-19550-00304	
Original issued and signed by: Felicia A. Robinson, Manager of Environmental Planning Indianapolis Office of Environmental Services	Issuance Date: January 18, 2006 Expiration Date: January 17, 2011
1 st Notice-Only Change No.: 097-28398-00304	
Issued by:  Alfred C. Dumaul, Ph. D, Section Chief Permits Branch Office of Air Quality	Issuance Date: Sept. 21, 2009 Expiration Date: January 17, 2011

TABLE OF CONTENTS

A	SOURCE SUMMARY	3
A.1	General Information [326 IAC 2-5.1-3(c)] [326 IAC 2-6.1-4(a)]	
A.2	Emission Units and Pollution Control Equipment Summary	
B	GENERAL CONDITIONS	4
B.1	Permit No Defense [IC 13]	
B.2	Definitions	
B.3	Effective Date of the Permit [IC 13-15-5-3]	
B.4	Permit Term and Renewal [326 IAC 2-6.1-7(a)][326 IAC 2-1.1-9.5]	
B.5	Enforceability	
B.6	Modification to Permit [326 IAC 2]	
B.7	Annual Notification [326 IAC 2-6.1-5(a)(5)]	
B.8	Preventive Maintenance Plan [326 IAC 1-6-3]	
B.9	Permit Revision [326 IAC 2-5.1-3(e)(3)][326 IAC 2-6.1-6]	
B.10	Inspection and Entry [326 IAC 2-5.1-3(e)(4)(B)][326 IAC 2-6.1-5(a)(4)][IC 13-14-2-2] [IC 13-17-3-2][IC 13-30-3-1]	
B.11	Transfer of Ownership or Operation [326 IAC 2-6.1-6(d)(3)]	
B.12	Annual Fee Payment [326 IAC 2-1.1-7]	
B.13	Credible Evidence [326 IAC 1-1-6]	
C	SOURCE OPERATION CONDITIONS	8
C.1	Permit Revocation [326 IAC 2-1.1-9]	
C.2	Opacity [326 IAC 5-1]	
C.3	Fugitive Dust Emissions [326 IAC 6-4]	
C.4	Asbestos Abatement Projects [326 IAC 14-10][326 IAC 18][40 CFR 61, Subpart M]	
C.5	Performance Testing [326 IAC 3-6]	
C.6	Compliance Requirements [326 IAC 2-1.1-11]	
C.7	Monitoring Methods [326 IAC 3][40 CFR 60][40 CFR 63]	
	Record Keeping and Reporting Requirements	
C.8	Malfunctions Report [326 IAC 1-6-2]	
C.9	General Record Keeping Requirements [326 IAC 2-6.1-2]	
C.10	General Reporting Requirements [326 IAC 2-1.1-11] [326 IAC 2-6.1-2] [IC 13-14-1-13]	
D.1	EMISSIONS UNIT OPERATION CONDITIONS	12
	Emission Limitations and Standards	
D.1.1	Particulate Emission Limitations for Sources of Indirect Heating [326 IAC 6-2-4]	
D.1.2	General Provision Relating to NSPS [326 IAC 12-1] [40 CFR 60, Subpart A]	
D.1.3	Sulfur Dioxide (SO ₂) [326 IAC 12-1] [40CFR 60, Subpart Dc]	
D.1.4	Preventive Maintenance Plan [326 IAC 1-6-3]	
	Compliance Determination Requirements	
D.1.5	Natural Gas	
D.1.6	Sulfur Dioxide Emissions and Sulfur Content [326 IAC 12-1] [40 CFR 60, Subpart A]	
	Compliance Monitoring Requirements:	
D.1.7	Visible Emissions Notations	
	Record Keeping and Reporting Requirement [326 IAC 2-5.1-3(e)(2)] [326 IAC 2-6.1-5(a)(2)]	
D.1.8	Record Keeping Requirements	
	Annual Notification	15
	Malfunction Report	16
	Semi-Annual Natural Gas Fired Boiler Certification	18

SECTION A SOURCE SUMMARY

This permit is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ), and Indianapolis Office of Environmental Services (OES). The information describing the source contained in conditions A.1 and A.2 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this permit pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

A.1 General Information [326 IAC 2-5.1-3(c)] [326 IAC 2-6.1-4(a)]

The Permittee owns and operates combustion units at a hospital.

Source Address: 8111 South Emerson Avenue, Indianapolis, Indiana 46237
Mailing Address: 1600 Albany Street, Beech Grove, Indiana 46107
General Source Phone: (317) 783-8257
SIC Code: 8062
County Location: Marion County
County Status: Source Location Status: Nonattainment for PM 2.5 standard
Attainment for all other criteria pollutants
Source Status: Minor Source Operating Permit
Minor Source, under PSD and Emission Offset Rules
Minor Source, Section 112 of the Clean Air Act
Not 1 of 28 Source Categories

A.2 Emissions Units and Pollution Control Equipment Summary

This stationary source is approved to operate the following emissions units and pollution control devices:

- (a) One (1) boiler, identified as 001, installed in 1995, burning natural gas, with a maximum heat input capacity of 16.74 million Btu per hour (MMBtu/hr), and exhausting to stack 001.
- (b) Two (2) boilers, identified as 002 and 003, both installed in 1995, burning natural gas and fuel oil #2, each with a maximum heat input capacity of 16.74 million Btu per hour (MMBtu/hr), and exhausting to stacks 002 and 003, respectively.

SECTION B GENERAL CONDITIONS

THIS SECTION OF THE PERMIT IS BEING ISSUED UNDER THE PROVISIONS OF 326 IAC 2-1.1 AND 40 CFR 52.780, WITH CONDITIONS LISTED BELOW.

B.1 Permit No Defense [IC 13]

This permit to operate does not relieve the Permittee of the responsibility to comply with the provisions of the Indiana Environmental Management Law (IC 13-11 through 13-20; 13-22 through 13-25; and 13-30), the Air Pollution Control Law (IC 13-17) and the rules promulgated thereunder, as well as other applicable local, state, and federal requirements.

B.2 Definitions

Terms in this permit shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, the applicable definitions found in the statutes or regulations IC 13-11, 326 IAC 1-2, and 326 IAC 2-1.1-1 shall prevail.

B.3 Effective Date of the Permit [IC13-15-5-3]

Pursuant to IC 13-15-5-3, this permit becomes effective upon its issuance.

B.4 Permit Term and Renewal [326 IAC 2-6.1-7(a)][326 IAC 2-1.1-9.5]

This permit is issued for a fixed term of five (5) years from the issuance date of this permit, as determined in accordance with IC 4-21.5-3-5(f) and IC 13-15-5-3. Subsequent revisions of this permit do not affect the expiration date.

The Permittee shall apply for an operation permit renewal at least ninety (90) days prior to the expiration date. If a timely and sufficient permit application for a renewal has been made, this permit shall not expire and all terms and conditions shall continue in effect until the renewal permit has been issued or denied.

B.5 Enforceability

Unless otherwise stated, all terms and conditions in this permit, including any provisions designed to limit the source's potential to emit are enforceable by IDEM, the United States Environmental Protection Agency (U.S. EPA) and by citizens in accordance with the Clean Air Act.

B.6 Modification to Permit [326 IAC 2]

All requirements and conditions of this operating permit shall remain in effect unless modified in a manner consistent with procedures established for modifications of construction permits pursuant to 326 IAC 2 (Permit Review Rules).

B.7 Annual Notification [326 IAC 2-6.1-5(a)(5)]

- (a) Annual notification shall be submitted to the Office of Air Quality stating whether or not the source is in operation and in compliance with the terms and conditions contained in this permit.
- (b) Noncompliance with any condition must be specifically identified. If there are any permit conditions or requirements for which the source is not in compliance at any time during the year, the Permittee must provide a narrative description of how the source did or will achieve compliance and the date compliance was, or will be, achieved. The notification must be signed by an authorized individual.
- (c) The annual notice shall cover the time period from January 1 to December 31 of the previous year, and shall be submitted in the format attached no later than March 1 of each year to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, IN 46204-2251

- (d) The notification shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.

B.8 Preventive Maintenance Plan [326 IAC 1-6-3]

- (a) If required by specific condition(s) in Section D of this permit, the Permittee shall prepare and maintain Preventive Maintenance Plans (PMPs) within ninety (90) days after issuance of this permit, including the following information on each facility:
- (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;
 - (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
 - (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.
- (b) A copy of the PMPs shall be submitted to IDEM, OAQ, upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. IDEM, OAQ, may require the Permittee to revise its PMPs whenever lack of proper maintenance causes or is the primary contributor to an exceedance of any limitation on emissions or potential to emit. The PMPs do not require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).
- (c) To the extent the Permittee is required by 40 CFR Part 60/63 to have an Operation Maintenance, and Monitoring (OMM) Plan for a unit, such Plan is deemed to satisfy the PMP requirements of 326 IAC 1-6-3 for that unit.

B.9 Permit Revision [326 IAC 2-5.1-3(e)(3)] [326 IAC 2-6.1-6]

- (a) Permit revisions are governed by the requirements of 326 IAC 2-6.1-6.
- (b) Any application requesting an amendment or modification of this permit shall be submitted to:
- Indiana Department of Environmental Management
Permit Administration and Support Section
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251
- Any such application shall be certified by an "authorized individual" as defined by 326 IAC 2-1.1-1.
- (c) The Permittee shall notify the OAQ within thirty (30) calendar days of implementing a notice-only change. [326 IAC 2-6.1-6(d)]

- (d) No permit amendment or modification is required for the addition, operation or removal of a non-road engine, as defined in 40 CFR 89.2.

B.10 Inspection and Entry [326 IAC 2-5.1-3(e)(4)(B)] [326 IAC 2-6.1-5(a)(4)] [IC 13-14-2-2] [IC13-17-3-2][IC 13-30-3-1]

Upon presentation of proper identification cards, credentials, and other documents as may be required by law, and subject to the Permittee's right under all applicable laws and regulations to assert that the information collected by the agency is confidential and entitled to be treated as such, the Permittee shall allow IDEM, OAQ, U.S. EPA, or an authorized representative to perform the following:

- (a) Enter upon the Permittee's premises where a permitted source is located, or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
- (b) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, have access to and copy, at reasonable times, any records that must be kept under this title or the conditions of this permit or any operating permit revisions;
- (c) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, inspect, at reasonable times, any processes, emissions units (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit or any operating permit revisions;
- (d) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with this permit or applicable requirements; and
- (e) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, utilize any photographic, recording, testing, monitoring, or other equipment for the purpose of assuring compliance with this permit or applicable requirements.

B.11 Transfer of Ownership or Operation [326 IAC 2-6.1-6(d)(3)]

Pursuant to [326 IAC 2-6.1-6(d)(3)]:

- (a) In the event that ownership of this source is changed, the Permittee shall notify IDEM, OAQ, Permit Administration and Support Section within thirty (30) days of the change.
- (b) The written notification shall be sufficient to transfer the permit to the new owner by a notice-only change pursuant to 326 IAC 2-6.1-6(d)(3).
- (c) IDEM, OAQ, shall issue a revised permit.

The notification which shall be submitted by the Permittee does require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1.

B.12 Annual Fee Payment [326 IAC 2-1.1-7]

- (a) The Permittee shall pay annual fees to IDEM OAQ within thirty (30) calendar days of receipt of a billing.
- (b) The Permittee may call the following telephone number 1-800-451-6207 or 317-233-4230 (ask for OAQ, Billing, Licensing, and Training Section), to determine the appropriate permit fee.

B.13 Credible Evidence [326 IAC 1-1-6]

For the purpose of submitting compliance certifications or establishing whether or not the Permittee has violated or is in violation of any condition of this permit, nothing in this permit shall preclude the use, including the exclusive use, of any credible evidence or information relevant to whether the Permittee would have been in compliance with the condition of this permit if the appropriate performance or compliance test or procedure had been performed.

SECTION C

SOURCE OPERATION CONDITIONS

Entire Source

C.1 Permit Revocation [326 IAC 2-1.1-9]

Pursuant to 326 IAC 2-1.1-9 (Revocation of Permits), this permit to construct and operate may be revoked for any of the following causes:

- (a) Violation of any conditions of this permit.
- (b) Failure to disclose all the relevant facts, or misrepresentation in obtaining this permit.
- (c) Changes in regulatory requirements that mandate either a temporary or permanent reduction of discharge of contaminants. However, the amendment of appropriate sections of this permit shall not require revocation of this permit.
- (d) Noncompliance with orders issued pursuant to 326 IAC 1-5 (Episode Alert Levels) to reduce emissions during an air pollution episode.
- (e) For any cause which establishes in the judgment of IDEM, the fact that continuance of this permit is not consistent with purposes of this article.

C.2 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

- (a) Opacity shall not exceed an average of thirty percent (30%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9, or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

C.3 Fugitive Dust Emissions [326 IAC 6-4]

The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions).

C.4 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

- (a) Notification requirements apply to each owner or operator. If the combined amount of regulated asbestos containing material (RACM) to be stripped, removed or disturbed is at least 260 linear feet on pipes or 160 square feet on other facility components, or at least thirty-five (35) cubic feet on all facility components, then the notification requirements of 326 IAC 14-10-3 are mandatory. All demolition projects require notification whether or not asbestos is present.
- (b) The Permittee shall ensure that a written notification is sent on a form provided by the Commissioner at least ten (10) working days before asbestos stripping or removal work or before demolition begins, per 326 IAC 14-10-3, and shall update such notice as necessary, including, but not limited to the following:

- (1) When the amount of affected asbestos containing material increases or decreases by at least twenty percent (20%); or
- (2) If there is a change in the following:
 - (A) Asbestos removal or demolition start date;
 - (B) Removal or demolition contractor; or
 - (C) Waste disposal site.
- (c) The Permittee shall ensure that the notice is postmarked or delivered according to the guidelines set forth in 326 IAC 14-10-3(2).
- (d) The notice to be submitted shall include the information enumerated in 326 IAC 14-10-3(3).

All required notifications shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

The notice shall include a signed certification from the owner or operator that the information provided in this notification is correct and that only Indiana licensed workers and project supervisors will be used to implement the asbestos removal project. The notifications do not require a certification by an "authorized individual" as defined by 326 IAC 2-7-1(34).

- (e) **Procedures for Asbestos Emission Control**
The Permittee shall comply with the applicable emission control procedures in 326 IAC 14-10-4 and 40 CFR 61.145(c). Per 326 IAC 14-10-1, emission control requirements are applicable for any removal or disturbance of RACM greater than three (3) linear feet on pipes or three (3) square feet on any other facility components or a total of at least 0.75 cubic feet on all facility components.
- (f) **Demolition and renovation**
The Permittee shall thoroughly inspect the affected facility or part of the facility where the demolition or renovation will occur for the presence of asbestos pursuant to 40 CFR 61.145(a).
- (g) **Indiana Accredited Asbestos Inspector**
The Permittee shall comply with 326 IAC 14-10-1(a) that requires the owner or operator, prior to a renovation/demolition, to use an Indiana Accredited Asbestos Inspector to thoroughly inspect the affected portion of the facility for the presence of asbestos. The requirement to use an Indiana Accredited Asbestos inspector is not federally enforceable.

Testing Requirements

C.5 Performance Testing [326 IAC 3-6]

- (a) Compliance testing on new emissions units shall be conducted within 60 days after achieving maximum production rate, but no later than 180 days after initial start-up, if specified in Section D of this approval. All testing shall be performed according to the provisions of 326 IAC 3-6 (Source Sampling Procedures), except as provided elsewhere in this permit, utilizing any applicable procedures and analysis methods specified in 40 CFR 51, 40 CFR 60, 40 CFR 61, 40 CFR 63, 40 CFR 75, or other procedures approved by IDEM, OAQ, and OES.

A test protocol, except as provided elsewhere in this permit, shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, IN 46204-2251

no later than thirty-five (35) days prior to the intended test date.

- (b) The Permittee shall notify IDEM, OAQ, of the actual test date at least fourteen (14) days prior to the actual date.
- (c) Pursuant to 326 IAC 3-6-4(b), all test reports must be received by IDEM, OAQ, not later than forty-five (45) days after the completion of the testing. An extension may be granted by the IDEM, OAQ, if the Permittee submits to IDEM, OAQ, a reasonable written explanation not later than five (5) days prior to the end of the initial forty-five (45) day period.

Compliance Requirements [326 IAC 2-1.1-11]

C.6 Compliance Requirements [326 IAC 2-1.1-11]

The commissioner may require stack testing, monitoring, or reporting at any time to assure compliance with all applicable requirements by issuing an order under 326 IAC 2-1.1-11. Any monitoring or testing shall be performed in accordance with 326 IAC 3 or other methods approved by the IDEM commissioner or the U.S. EPA.

Compliance Monitoring Requirements

C.7 Monitoring Methods [326 IAC 3][40 CFR 60][40 CFR 63]

Any monitoring or testing required by Section D of this permit shall be performed according to the provisions of 326 IAC 3, 40 CFR 60, Appendix A, 40 CFR 60, Appendix B, 40 CFR 63, or other approved methods as specified in this permit.

Record Keeping and Reporting Requirements

C.8 Malfunctions Report [326 IAC 1-6-2]

Pursuant to 326 IAC 1-6-2 (Records; Notice of Malfunction):

- (a) A record of all malfunctions, including startups or shutdowns of any facility or emission control equipment, which result in violations of applicable air pollution control regulations or applicable emission limitations shall be kept and retained for a period of three (3) years and shall be made available to IDEM, OAQ or appointed representative upon request.

- (b) When a malfunction of any facility or emission control equipment occurs which lasts more than one (1) hour, said condition shall be reported to IDEM, OAQ, using the Malfunction Report Forms (2 pages). Notification shall be made by telephone or facsimile, as soon as practicable, but in no event later than four (4) daytime business hours after the beginning of said occurrence.
- (c) Failure to report a malfunction of any emission control equipment shall constitute a violation of 326 IAC 1-6, and any other applicable rules. Information of the scope and expected duration of the malfunction shall be provided, including the items specified in 326 IAC 1-6-2(a)(1) through (6).
- (d) Malfunction is defined as any sudden, unavoidable failure of any air pollution control equipment, process, or combustion or process equipment to operate in a normal and usual manner. [326 IAC 1-2-39]

C.9 General Record Keeping Requirements [326 IAC 2-6.1-5]

- (a) Records of all required monitoring data, reports and support information required by this permit shall be retained for a period of at least five (5) years from the date of monitoring sample, measurement, report, or application. These records shall be physically present or electronically accessible at the source location for a minimum of three (3) years. The records may be stored elsewhere for the remaining two (2) years as long as they are available upon request. If the IDEM Commissioner makes a request for records to the Permittee, the Permittee shall furnish the records to the IDEM Commissioner within a reasonable time.
- (b) Unless otherwise specified in this permit, all record keeping requirements not already legally required shall be implemented when operation begins.

C.10 General Reporting Requirements [326 IAC 2-1.1-11] [326 IAC 2-6.1-2] [IC 13-14-1-13]

- (a) Reports required by conditions in Section D of this permit shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, IN 46204-2251
- (b) Unless otherwise specified in this permit, any notice, report, or other submission required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.
- (c) Unless otherwise specified in this permit, any quarterly or semi-annual report required in Section D of this permit shall be submitted within thirty (30) days of the end of the reporting period. The report does not require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (d) The first report shall cover the period commencing on the date of issuance of this permit and ending on the last day of the reporting period. Reporting periods are based on calendar years, unless otherwise specified in this permit. For the purpose of this permit "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.

SECTION D.1 EMISSIONS UNITS OPERATION CONDITIONS

Emissions Unit Description:

- (a) One (1) boiler, identified as 001, to be installed in 1995, burning natural gas, with a maximum heat input capacity of 16.74 million Btu per hour (MMBtu/hr), and exhausting to stack 001.
- (b) Two (2) boilers, identified as 002 and 003, both installed in 1995, burning natural gas and fuel oil #2, each with a maximum heat input capacity of 16.74 million Btu per hour (MMBtu/hr), and exhausting to stacks 002 and 003, respectively.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards

D.1.1 Particulate Emission Limitations for Sources of Indirect Heating [326 IAC 6-2-4]

Pursuant to this rule, particulate emissions from these facilities shall be limited by the following equation:

$$Pt = 1.09/Q^{0.26} \quad \text{where } Pt = \text{Pounds of particulate matter emitted per million Btu (lb/mmBtu) heat input; and}$$

Q = Total source maximum operating capacity rating in million Btu per hour (MMBtu/hr) heat input.

Boilers, 001, 002, and 003, shall each be limited to 0.39 pounds of particulate matter emitted per million Btu (lb/mmBtu) heat input.

D.1.2 General Provision Relating to NSPS [326 IAC 12-1] [40 CFR 60, Subpart A]

The provisions of 40 CFR 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the facility described in this section except when otherwise specified in 40 CFR 60, Subpart Dc.

D.1.3 Sulfur Dioxide (SO₂) [326 IAC 12-1] [40 CFR 60, Subpart Dc]

Pursuant to 40 CFR 60, Subpart Dc (Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units):

- (a) The SO₂ emissions from boilers 002 and 003 shall not exceed five tenths (0.5) pounds per million Btu heat input; or
- (b) The sulfur content of the fuel oil shall not exceed five-tenths percent (0.5%) by weight. [40 CFR 60.42c(d)]

Pursuant to 40 CFR 60 Subpart Dc, the fuel oil sulfur content limit applies at all times, including periods of startup, shutdown, and malfunction.

D.1.4 Preventive Maintenance Plan [326 IAC 1-6-3]

A Preventive Maintenance Plan, in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for these facilities.

Compliance Determination Requirements

D.1.5 Natural Gas

In order to demonstrate compliance with D.1.1, boiler 001 shall burn only natural gas.

D.1.6 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 12-1] [40 CFR 60, Subpart Dc]

For boilers 002 and 003, compliance shall be determined utilizing one of the following options:

- (a) Pursuant to 40 CFR 60.42c(h), the Permittee shall demonstrate compliance with D.1.3 by:
 - (1) Providing vendor analysis of fossil fuel oil delivered, if accompanied by a certification; or
 - (2) Analyzing the oil sample to determine the sulfur content of the fossil fuel oil via the procedures in 40 CFR 60, Appendix A, Method 19.
 - (A) Oil samples may be collected from the fuel tank immediately after the fuel tank is filled and before any oil is combusted; and
 - (B) If a partially empty fuel tank is refilled, a new sample and analysis would be required upon filling; or
- (b) Compliance may also be determined by conducting a stack test for sulfur dioxide emissions from the boilers, using 40 CFR 60, Appendix A, Method 6 in accordance with the procedures in 326 IAC 3-6.

A determination of noncompliance pursuant to either of the methods specified in (a) or (b) above shall not be refuted by evidence of compliance pursuant to the other method.

Compliance Monitoring Requirements

D.1.7 Visible Emissions Notations

- (a) Visible emission notations of boilers 002 and 003 stack exhaust shall be performed once per day during normal daylight operations when burning fuel oil. A trained employee shall record whether emissions are normal or abnormal.
- (b) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.
- (c) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- (d) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.
- (e) The Compliance Response Plan for this unit shall contain troubleshooting contingency and response steps for when an abnormal emission is observed. Failure to take response steps in accordance with Section C - Compliance Response Plan - Preparation, Implementation, Records, and Reports, shall be considered a deviation from this permit.

Record Keeping and Reporting Requirement [326 IAC 2-5.1-3(e)(2)] [326 IAC 2-6.1-5(a)(2)]

D.1.8 Record Keeping Requirements

- (a) That pursuant to 40 CFR Part 60.48c (Reporting and Recordkeeping Requirements) records shall be maintained of the amounts of fuel combusted during each month by the natural gas fired boiler 001.
- (b) To document compliance with Condition D.1.3, the Permittee shall maintain records in accordance with (1) through (6) below.
 - (1) Calendar dates covered in the compliance determination period;
 - (2) Actual fossil fuel oil usage since last compliance determination period and equivalent sulfur dioxide emissions;
 - (3) To certify compliance when burning natural gas only, the Permittee shall maintain records of fuel used.

If the fossil fuel supplier certification is used to demonstrate compliance, when burning alternate fuels and not determining compliance pursuant to 326 IAC 3-7-4, the following, as a minimum, shall be maintained:

- (4) Fuel supplier certifications;
- (5) The name of the fuel supplier; and
- (6) A statement from the fuel supplier that certifies the sulfur content of the fuel oil.

The Permittee shall retain records of all recording/monitoring data and support information for a period of five (5) years, or longer if specified elsewhere in this permit, from the date of the monitoring sample, measurement, or report. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit.

- (c) To document compliance with Condition D.1.7, the Permittee shall maintain daily records of visible emission notations of boilers 001, 002, and 003 stack exhaust during normal daylight operations when burning fossil fuel oil.
- (d) To document compliance with Condition D.1.4, the Permittee shall maintain records of any additional inspections prescribed by the Preventive Maintenance Plan.
- (e) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

**Indiana Department of Environmental Management
Office of Air Quality
Compliance and Enforcement Branch**

**MINOR SOURCE OPERATING PERMIT
ANNUAL NOTIFICATION**

This form should be used to comply with the notification requirements under 326 IAC 2-6.1-5(a)(5).

Company Name:	St. Francis Hospital and Health Centers
Address:	8111 South Emerson Avenue
City:	Indianapolis, Indiana 46237
Phone #:	(317) 415-7607
MSOP #:	097-19550-00304

I hereby certify that St. Francis Hospital and Health Centers is still in operation.
 no longer in operation.

I hereby certify that St. Francis Hospital and Health Centers is in compliance with the requirements of MSOP 097-19550-00304.
 not in compliance with the requirements of MSOP 097-19550-00304.

Authorized Individual (typed):
Title:
Signature:
Date:

If there are any conditions or requirements for which the source is not in compliance, provide a narrative description of how the source did or will achieve compliance and the date compliance was, or will be achieved.

Noncompliance:

Indiana Department of Environmental Management
Office of Air Quality
Compliance and Enforcement Branch
FAX NUMBER – 317-233-6865

MALFUNCTION REPORT

PAGE 1 OF 2

This form should only be used to report malfunctions applicable to Rule 326 IAC 1-6 and to qualify for the exemption under 326 IAC 1-6-4.

THIS FACILITY MEETS THE APPLICABILITY REQUIREMENTS BECAUSE IT HAS POTENTIAL TO EMIT 25 TONS/YEAR PARTICULATE MATTER ?____, 25 TONS/YEAR SULFUR DIOXIDE ?____, 25 TONS/YEAR NITROGEN OXIDES?____, 25 TONS/YEAR VOC ?____, 25 TONS/YEAR HYDROGEN SULFIDE ?____, 25 TONS/YEAR TOTAL REDUCED SULFUR ?____, 25 TONS/YEAR REDUCED SULFUR COMPOUNDS ?____, 25 TONS/YEAR FLUORIDES ?____, 100TONS/YEAR CARBON MONOXIDE ?____, 10 TONS/YEAR ANY SINGLE HAZARDOUS AIR POLLUTANT ?____, 25 TONS/YEAR ANY COMBINATION HAZARDOUS AIR POLLUTANT ?____, 1 TON/YEAR LEAD OR LEAD COMPOUNDS MEASURED AS ELEMENTAL LEAD ?____, OR IS A SOURCE LISTED UNDER 326 IAC 2-5.1-3(2) ?____. EMISSIONS FROM MALFUNCTIONING CONTROL EQUIPMENT OR PROCESS EQUIPMENT CAUSED EMISSIONS IN EXCESS OF APPLICABLE LIMITATION _____.

THIS MALFUNCTION RESULTED IN A VIOLATION OF: 326 IAC _____ OR, PERMIT CONDITION # _____ AND/OR PERM LIMIT OF _____

THIS INCIDENT MEETS THE DEFINITION OF >MALFUNCTION= AS LISTED ON REVERSE SIDE ? Y N

THIS MALFUNCTION IS OR WILL BE LONGER THAN THE ONE (1) HOUR REPORTING REQUIREMENT ? Y N

COMPANY: _____ PHONE NO. () _____
LOCATION: (CITY AND COUNTY) _____
PERMIT NO. _____ AFS PLANT ID: _____ AFS POINT ID: _____ INSP: _____
CONTROL/PROCESS DEVICE WHICH MALFUNCTIONED AND REASON: _____

DATE/TIME MALFUNCTION STARTED: ____/____/20____ _____ AM / PM

ESTIMATED HOURS OF OPERATION WITH MALFUNCTION CONDITION: _____

DATE/TIME CONTROL EQUIPMENT BACK-IN SERVICE ____/____/19____ _____ AM/PM

TYPE OF POLLUTANTS EMITTED: TSP, PM-10, SO2, VOC, OTHER: _____

ESTIMATED AMOUNT OF POLLUTANT EMITTED DURING MALFUNCTION: _____

MEASURES TAKEN TO MINIMIZE EMISSIONS: _____

REASONS WHY FACILITY CANNOT BE SHUTDOWN DURING REPAIRS:

CONTINUED OPERATION REQUIRED TO PROVIDE ESSENTIAL* SERVICES: _____

CONTINUED OPERATION NECESSARY TO PREVENT INJURY TO PERSONS: _____

CONTINUED OPERATION NECESSARY TO PREVENT SEVERE DAMAGE TO EQUIPMENT: _____

***SEE PAGE 2**

INTERIM CONTROL MEASURES: (IF APPLICABLE) _____

MALFUNCTION REPORTED BY: _____ TITLE: _____
(SIGNATURE IF FAXED)

MALFUNCTION RECORDED BY: _____ DATE: _____ TIME: _____

Please note - This form should only be used to report malfunctions applicable to Rule 326 IAC 1-6 and to qualify for the exemption under 326 IAC 1-6-4.

326 IAC 1-6-1 Applicability of rule

Sec. 1. This rule applies to the owner or operator of any facility required to obtain a permit under 326 IAC 2-5.1 or 326 IAC 2-6.1.

326 IAC 1-2-39 "Malfunction" definition

Sec. 39. Any sudden, unavoidable failure of any air pollution control equipment, process, or combustion or process equipment to operate in a normal and usual manner.

***Essential services** are interpreted to mean those operations, such as, the providing of electricity by power plants. Continued operation solely for the economic benefit of the owner or operator shall not be sufficient reason why a facility cannot be shutdown during a control equipment shutdown.

If this item is checked on the front, please explain rationale:

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH**

**PART 70 OPERATING PERMIT
SEMI-ANNUAL NATURAL GAS FIRED BOILER CERTIFICATION**

Source Name: St. Francis Hospital and Health Centers
Source Address: 8111 South Emerson Avenue, Indianapolis, Indiana 46237
Mailing Address: 1600 Albany Street, Beech Grove, Indiana 46107
MSOP No.: 097-19550-00304

<input type="checkbox"/> Natural Gas Only <input type="checkbox"/> Alternate Fuel burned From: _____ To: _____
--

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
Signature:
Printed Name:
Title/Position:
Phone:
Date:

A certification by the authorized individual as defined by 326 IAC 2-1.1-1(1) is required for this report.



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

SENT VIA U.S. MAIL: CONFIRMED DELIVERY AND SIGNATURE REQUESTED

TO: Marc Hyde
St. Francis Hospital & Health Centers
1600 Albany St.
Beech Grove IN 46107

DATE: Sept. 21, 2009

FROM: Matt Stuckey, Branch Chief
Permits Branch
Office of Air Quality

SUBJECT: Final Decision
Notice Only Change
097-29398-00304

Enclosed is the final decision and supporting materials for the air permit application referenced above. Please note that this packet contains the original, signed, permit documents.

The final decision is being sent to you because our records indicate that you are the contact person for this application. However, if you are not the appropriate person within your company to receive this document, please forward it to the correct person.

A copy of the final decision and supporting materials has also been sent via standard mail to:
Roger Barksdale VP Ancillary Svs. St. Francis Hospital & Health Centers
OAQ Permits Branch Interested Parties List

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178, or toll-free at 1-800-451-6027 (ext. 3-0178), and ask to speak to the permit reviewer who prepared the permit. If you think you have received this document in error, please contact Joanne Smiddie-Brush of my staff at 1-800-451-6027 (ext 3-0185), or via e-mail at jbrush@idem.IN.gov.

Final Applicant Cover letter.dot 11/30/07

Mail Code 61-53

IDEM Staff	BMILLER 9/21/2009 St Francis Hospital & Health Ctrs 097-28398-00304 (final)			AFFIX STAMP HERE IF USED AS CERTIFICATE OF MAILING
Name and address of Sender	▶	Indiana Department of Environmental Management Office of Air Quality – Permits Branch 100 N. Senate Indianapolis, IN 46204	Type of Mail: CERTIFICATE OF MAILING ONLY	

Line	Article Number	Name, Address, Street and Post Office Address	Postage	Handing Charges	Act. Value (If Registered)	Insured Value	Due Send if COD	R.R. Fee	S.D. Fee	S.H. Fee	Rest. Del. Fee
											Remarks
1		Marc Hyde St Francis Hospital & Health Ctrs 1600 Albany St Beech Grove IN 46107 (Source CAATS) <i>Via Confirmed Delivery</i>									
2		Roger Barksdale VP - Ancillary Svcs St Francis Hospital & Health Ctrs 1600 Albany St Beech Grove IN 46107 (RO CAATS)									
3		Marion County Health Department 3838 N, Rural St Indianapolis IN 46205-2930 (Health Department)									
4		Mrs. Sandra Lee Watson 7834 E 100 S Marion IN 46953 (Affected Party)									
5		Indianapolis City Council and Mayors Office 200 East Washington Street, Room E Indianapolis IN 46204 (Local Official)									
6		Marion County Commissioners 200 E. Washington St. City County Bldg., Suite 801 Indianapolis IN 46204 (Local Official)									
7		Ms. Janet McCabe Improving Kids Environment 3951 N Meridian Street Suite 160 Indianapolis IN 46208-4062 (Affected Party)									
8		Matt Mosier Office of Sustainability 2700 South Belmont Ave. Administration Bldg. Indianapolis IN 46221 (Local Official)									
9											
10											
11											
12											
13											
14											
15											

Total number of pieces Listed by Sender	Total number of Pieces Received at Post Office	Postmaster, Per (Name of Receiving employee)	The full declaration of value is required on all domestic and international registered mail. The maximum indemnity payable for the reconstruction of nonnegotiable documents under Express Mail document reconstructing insurance is \$50,000 per piece subject to a limit of \$50, 000 per occurrence. The maximum indemnity payable on Express mil merchandise insurance is \$500. The maximum indemnity payable is \$25,000 for registered mail, sent with optional postal insurance. See Domestic Mail Manual R900, S913, and S921 for limitations of coverage on inured and COD mail. See International Mail Manual for limitations o coverage on international mail. Special handling charges apply only to Standard Mail (A) and Standard Mail (B) parcels.
---	--	--	--