



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

TO: Interested Parties / Applicant

DATE: March 22, 2010

RE: Hoosier Energy REC - Frank E. Watts Generating Station / 125-28810-00001

FROM: Matthew Stuckey, Branch Chief
Permits Branch
Office of Air Quality

Notice of Decision: Approval - Effective Immediately

Please be advised that on behalf of the Commissioner of the Department of Environmental Management, I have issued a decision regarding the enclosed matter. Pursuant to IC 13-15-5-3, this permit is effective immediately, unless a petition for stay of effectiveness is filed and granted according to IC 13-15-6-3, and may be revoked or modified in accordance with the provisions of IC 13-15-7-1.

If you wish to challenge this decision, IC 4-21.5-3 and IC 13-15-6-1 require that you file a petition for administrative review. This petition may include a request for stay of effectiveness and must be submitted to the Office of Environmental Adjudication, 100 North Senate Avenue, Government Center North, Suite N 501E, Indianapolis, IN 46204, **within eighteen (18) calendar days of the mailing of this notice**. The filing of a petition for administrative review is complete on the earliest of the following dates that apply to the filing:

- (1) the date the document is delivered to the Office of Environmental Adjudication (OEA);
- (2) the date of the postmark on the envelope containing the document, if the document is mailed to OEA by U.S. mail; or
- (3) The date on which the document is deposited with a private carrier, as shown by receipt issued by the carrier, if the document is sent to the OEA by private carrier.

The petition must include facts demonstrating that you are either the applicant, a person aggrieved or adversely affected by the decision or otherwise entitled to review by law. Please identify the permit, decision, or other order for which you seek review by permit number, name of the applicant, location, date of this notice and all of the following:

- (1) the name and address of the person making the request;
- (2) the interest of the person making the request;
- (3) identification of any persons represented by the person making the request;
- (4) the reasons, with particularity, for the request;
- (5) the issues, with particularity, proposed for considerations at any hearing; and
- (6) identification of the terms and conditions which, in the judgment of the person making the request, would be appropriate in the case in question to satisfy the requirements of the law governing documents of the type issued by the Commissioner.

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178. Callers from within Indiana may call toll-free at 1-800-451-6027, ext. 3-0178.

Enclosures
FNPER.dot12/03/07



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels, Jr.

Governor

Thomas W. Easterly

Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

TITLE IV (ACID RAIN) PERMIT RENEWAL OFFICE OF AIR QUALITY

**Hoosier Energy Rural Electric Company (REC), Inc.
Frank E. Ratts Generating Station
6825 North Blackburn Road
Petersburg, Indiana 47567**

ORIS: 1043

The owners and operators (hereinafter collectively known as the Permittee) of the above source are issued this permit under the provisions of 326 Indiana Administrative Code (IAC) 21 with conditions listed on the attached pages.

Operation Permit No.: AR 125-28810-00001	
Issued by: <i>Tripurari P. Sinha</i> Tripurari P. Sinha, Ph.D., Section Chief Permits Branch Office of Air Quality	Issuance Date: March 22, 2010 Expiration Date: March 22, 2015

Title IV Operating Conditions

Title IV Source Description:

- (a) One (1) pulverized coal-fired, dry bottom wall-fired boiler identified as Unit 1SG1 (Boiler #1 in the Title V permit), rated at 1,160 million Btu per hour (MMBtu/hr) energy input, used to generate up to 132 megawatts (gross) of electricity. Particulate matter (PM) emissions are controlled by an electrostatic precipitator (ESP), and nitrogen oxides (NOx) emissions are inhibited by a low-NOx burner. Unit 1SG1 is equipped with a continuous opacity monitor (COM) and is exhausted through a 300-foot tall chimney with an 11-foot exit diameter.
- (b) One (1) pulverized coal-fired, dry bottom wall-fired boiler identified as Unit 2SG1 (Boiler #2 in the Title V permit), rated at 1160 MMBtu/hr energy input, used to generate up to 132 megawatts (gross) of electricity. Particulate matter (PM) emissions are controlled by an electrostatic precipitator (ESP), and nitrogen oxides (NOx) emissions are inhibited by a low-NOx burner. Unit 2SG1 is equipped with a continuous opacity monitor (COM) and is exhausted through a 300-foot tall chimney with an 11-foot exit diameter.

(The information contained in this box is descriptive information and does not constitute enforceable conditions.)

1. Statutory and Regulatory Authorities

In accordance with IC 13-17-3-4 and IC 13-17-3-11 as well as Titles IV and V of the Clean Air Act, the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ) issues this permit pursuant to 326 IAC 2 and 326 IAC 21 (incorporates by reference 40 Code of Federal Regulations (CFR) 72 through 78).

2. Standard Permit Requirements [326 IAC 21]

- (a) The designated representative has submitted a complete acid rain permit application in accordance with 40 CFR 72.30.
- (b) The Permittee shall operate Units 1SG1 and 2SG1 in compliance with this permit.

3. Monitoring Requirements [326 IAC 21]

- (a) The Permittee and, to the extent applicable, the designated representative of Units 1SG1 and 2SG1 shall comply with the monitoring requirements as provided in 40 CFR 75 and 76.
- (b) The emissions measurements recorded and reported in accordance with 40 CFR 75 and 76 shall be used to determine compliance by Units 1SG1 and 2SG1 with the acid rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (c) The requirements of 40 CFR 75 and 76 shall not affect the responsibility of the Permittee to monitor emissions of other pollutants or other emissions characteristics at Units 1SG1 and 2SG1 under other applicable requirements of the Clean Air Act and other provisions of the operating permit for the source.

4. Sulfur Dioxide Requirements [326 IAC 21]

- (a) The Permittee shall:
 - (1) Hold allowances, as of the allowance transfer deadline (as defined in 40 CFR 72.2), in the compliance subaccount of Units 1SG1 and 2SG1, after deductions under 40 CFR 73.34(c), not less than the total annual emissions of sulfur dioxide for the previous calendar year from Units 1SG1 and 2SG1; and,
 - (2) Comply with the applicable acid rain emissions limitations for sulfur dioxide.

- (b) Each ton of sulfur dioxide emitted in excess of the acid rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Clean Air Act.
- (c) Units 1SG1 and 2SG1 shall be subject to the requirements under paragraph 4(a) of the sulfur dioxide requirements as follows:
 - (1) Starting January 1, 2000, an affected unit under 40 CFR 72.6(a)(2); or,
 - (2) Starting on the latter of January 1, 2000, or the deadline for monitor certification under 40 CFR 75, an affected unit under 40 CFR 72.6(a)(3).
- (d) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (e) An allowance shall not be deducted in order to comply with the requirements under paragraph 4(a) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (f) An allowance allocated by the U.S. EPA under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the acid rain permit application, the acid rain permit, the acid rain portion of an operating permit, or the written exemption under 40 CFR 72.7 and 72.8 and 326 IAC 21, and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (g) An allowance allocated by U.S. EPA under the Acid Rain Program does not constitute a property right.
- (h) No permit revision may be required for increases in emissions that are authorized by allowances acquired pursuant to the Acid Rain Program, provided that the increases do not require a permit revision under any other applicable requirement. [326 IAC 2-7-5(4)(A)]
- (i) No limit shall be placed on the number of allowances held by the Permittee. The Permittee may not, however, use allowances as a defense to noncompliance with any applicable requirement other than the requirements of the Acid Rain Program. [326 IAC 2-7-5(4)(B)]

5. Nitrogen Oxides Requirements [326 IAC 21]

- (a) The Permittee shall comply with the applicable acid rain emissions limitation of nitrogen oxides (NO_x) for Units 1SG1 and 2SG1.
- (b) NO_x Emission Averaging Plan for Unit 1SG1:
 - (1) Pursuant to 40 CFR 76.11, the Indiana Department of Environmental Management, Office of Air Quality approves a NO_x emission averaging plan for Unit 1SG1, effective from calendar year 2010 through 2015. Under the plan the NO_x emissions from Unit 1SG1 shall not exceed the annual average alternative contemporaneous emission limitation (ACEL) of 0.46 lb/MMBtu. In addition, Unit 1SG1 shall not have an annual heat input greater than 10,000,000 MMBtu.
 - (2) Under the plan, the actual Btu-weighted annual average NO_x emission rate for all the units in the plan shall be less than or equal to the Btu-weighted annual average NO_x emission rate for the same units had they each been operated, during the same period of time, in compliance with the applicable emission limitations under 40 CFR 76.5. If the designated representative demonstrates that the requirement of the prior sentence (as set forth in 40 CFR 76.11(d)(1)(ii)(A)) is met for a year under the plan, then Unit 1SG1 shall be deemed to be in compliance for that year with its annual ACEL and annual heat input limit.

- (c) NOx Emission Averaging Plan for Unit 2SG1:
- (1) Pursuant to 40 CFR 76.11, the Indiana Department of Environmental Management, Office of Air Quality approves a NOx emission averaging plan for Unit 2SG1, effective from calendar year 2010 through 2015. Under the plan, the NOx emissions from Unit 2SG1 shall not exceed the annual average ACEL of 0.46 lb/MMBtu.
 - (2) Under the plan, the actual Btu-weighted annual average NOx emission rate for all the units in the plan shall be less than or equal to the Btu-weighted annual average NOx emission rate for the same units had they each been operated, during the same period of time, in compliance with the applicable emission limitations under 40 CFR 76.5. If the designated representative demonstrates that the requirement of the prior sentence (as set forth in 40 CFR 76.11(d)(1)(ii)(A)) is met for a year under the plan, then Unit 2SG1 shall be deemed to be in compliance for that year with its annual ACEL and annual heat input limit.
- (d) In addition to the described NOx compliance plan, Units 1SG1 and 2SG1 shall comply with all other applicable requirements of 40 CFR 76, including the duty to reapply for a NOx compliance plan and requirements covering excess emissions.

6. Excess Emissions Requirements [40 CFR 77] [326 IAC 21]

- (a) If Unit 1SG1 or 2SG1 has excess emissions of sulfur dioxide in any calendar year, the designated representative shall submit a proposed offset plan to U.S. EPA and IDEM, OAQ as required under 40 CFR 77 and 326 IAC 21.
- (b) The designated representative shall submit required information to:
- Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
Indianapolis, IN 46204-2251
- and
- U.S. Environmental Protection Agency
Clean Air Markets Division
1200 Pennsylvania Avenue, NW
Mail Code (6204N)
Washington, DC 20460
- (c) If Unit 1SG1 or 2SG1 has excess emissions, as defined in 40 CFR 72.2, in any calendar year the Permittee shall:
- (1) Pay to U.S. EPA without demand the penalty required, and pay to U.S. EPA upon demand the interest on that penalty, as required by 40 CFR 77 and 326 IAC 21; and,
 - (2) Comply with the terms of an approved sulfur dioxide offset plan, as required by 40 CFR 77 and 326 IAC 21.

7. Record Keeping and Reporting Requirements [326 IAC 21]

- (a) Unless otherwise provided, the Permittee shall keep on site each of the following documents for a period of 5 years, as required by 40 CFR 72.9(f), from the date the document is created. This period may be extended for cause, at any time prior to the end of the 5 years, in writing by U.S. EPA or IDEM, OAQ:
- (1) The certificate of representation for the designated representative of Units 1SG1 and 2SG1 and all documents that demonstrate the truth of the statements in the

certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site at the source beyond such 5 year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;

- (2) All emissions monitoring information collected in accordance with 40 CFR 75 shall be retained on site for three (3) years;
 - (3) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,
 - (4) Copies of all documents used to complete an acid rain permit application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.
- (b) The designated representative of Units 1SG1 and 2SG1 shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 72.90, Subpart I, 40 CFR 75, and 326 IAC 21. The required information is to be submitted to the appropriate authority(ies) as specified in 40 CFR 72.90, Subpart I, and 40 CFR 75.

8. Submissions [326 IAC 21]

- (a) The designated representative of Units 1SG1 and 2SG1 shall submit a certificate of representation, and any superseding certificate of representation, to U.S. EPA and IDEM, OAQ in accordance with 40 CFR 72 and 326 IAC 21.
- (b) The designated representative shall submit required information to:
- Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
Indianapolis, IN 46204-2251
- and
- U.S. Environmental Protection Agency
Clean Air Markets Division
1200 Pennsylvania Avenue, NW
Mail Code (6204N)
Washington, DC 20460
- (c) Each such submission under the Acid Rain Program shall be submitted, signed and certified by the designated representative for all sources on behalf of which the submission is made.
- (d) In each submission under the Acid Rain Program, the designated representative shall certify, by his or her signature, the following statements which shall be included verbatim in the submission:
- (1) "I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made."; and,
 - (2) "I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."

- (e) The designated representative of Units 1SG1 and 2SG1 shall notify the Permittee:
 - (1) By the date of submission, of any Acid Rain Program submissions by the designated representative;
 - (2) Within 10 business days of receipt of any written determination by U.S. EPA or IDEM, OAQ; and,
 - (3) Provided that the submission or determination covers Unit 1SG1 or 2SG1.
- (f) The designated representative of Units 1SG1 and 2SG1 shall provide the Permittee a copy of any submission or determination under paragraph 8(e), unless the Permittee expressly waives the right to receive a copy.

9. Severability [326 IAC 21]

Invalidation of the acid rain portion of an operating permit does not affect the continuing validity of the rest of the operating permit, nor shall invalidation of any other portion of the operating permit affect the continuing validity of the acid rain portion of the permit. [40 CFR 72.72(b), 326 IAC 21, and 326 IAC 2-7-5(5)]

10. Liability [326 IAC 21]

- (a) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, an acid rain permit, an acid rain portion of an operation permit, or a written exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement by U.S. EPA pursuant to Section 113(c) of the Clean Air Act and shall be subject to enforcement by IDEM pursuant to 326 IAC 21 and IC 13-30-3.
- (b) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to Section 113(c) of the Clean Air Act, 18 U.S.C. 1001 and IDEM pursuant to 326 IAC 21 and IC 13-30-6-2.
- (c) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
- (d) Units 1SG1 and 2SG1 shall meet the requirements of the Acid Rain Program.
- (e) Any provision of the Acid Rain Program that applies to Unit 1SG1 or 2SG1, including a provision applicable to the designated representative of Unit 1SG1 or 2SG1, shall also apply to the Permittee.
- (f) Any provision of the Acid Rain Program that applies to Unit 1SG1 or 2SG1, including a provision applicable to the designated representative, shall also apply to the Permittee. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans) and 40 CFR 76.11 (NOx averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR 75, including 40 CFR 75.16, 75.17, and 75.18, the Permittee and the designated representative of one affected unit shall not be liable for any violation by any other affected unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.
- (g) Each violation of a provision of 40 CFR 72, 73, 75, 76, 77, and 78 by Unit 1SG1 or 2SG1, or by the Permittee or designated representative, shall be a separate violation of the Clean Air Act.

11. Effect on Other Authorities [326 IAC 21]

No provision of the Acid Rain Program, an acid rain permit application, an acid rain permit, an acid rain portion of an operation permit, or a written exemption under 40 CFR 72.7 or 72.8 shall be construed as:

- (a) Except as expressly provided in Title IV of the Clean Air Act (42 USC 7651 to 7651(o)), exempting or excluding the Permittee and, to the extent applicable, the designated representative of Unit 1SG1 or 2SG1 from compliance with any other provision of the Clean Air Act, including the provisions of Title I of the Clean Air Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;
- (b) Limiting the number of allowances a unit can hold; provided, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Clean Air Act;
- (c) Requiring a change of any kind in any state law regulating electric utility rates and charges, affecting any state law regarding such state regulation, or limiting such state regulation, including any prudence review requirements under such state law;
- (d) Modifying the Federal Power Act (16 USC 791(a) et seq.) or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
- (e) Interfering with or impairing any program for competitive bidding for power supply in a state in which such a program is established.

Indiana Department of Environmental Management Office of Air Quality

Technical Support Document
For a Phase II Acid Rain Permit Renewal

Source Background and Description

Source Name:	Frank E. Ratts Generating Station
Source Location:	6825 N. Blackburn Road, Petersburg, Indiana, 47567
Mailing Address:	P.O. Box 908, Bloomington, Indiana, 47402
County:	Pike
Operated By:	Hoosier Energy REC
Designated Representative:	Michalene Reilly
ORIS Code:	1043
Previous Phase II Permit No.:	AR 125-19345-00001
Phase II Renewal Permit No.:	AR 125-28810-00001
Permit Reviewer:	Deborah Cole

The Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ) has reviewed a Phase II Acid Rain permit renewal application submitted by Hoosier Energy REC on December 23, 2009. The application is for the operation of the following affected units at a station located at 6825 N. Blackburn Road, Petersburg, Indiana.

Two (2) dry bottom, wall-fired coal burning boilers identified as 1SG1 and 2SG1.

This permit renewal AR 125-28810-00001 covers calendar years 2010 to 2015 involving the same affected units as indicated in the initial Phase II permit AR 125-19345-00001

Existing Approvals

The source has been operating under the following previous Phase II approvals:

AR 125-19345-00001, issued on May 3, 2006.

Program Description

The following information is provided to explain the Acid Rain Program.

- (a) **Goal of the Program**
The goal of the 1990 Clean Air Act (CAA) Amendments, Acid Rain Program is to reduce the impact of man-made emissions of sulfur dioxide (SO₂) and nitrogen oxide (NO_x) on lakes, streams, forests, crops and, most important, the health of the public, by a nationwide SO₂ allocation of emissions from power plants. While it may not seem to be a local problem, the information collected shows a need for this reduction. This is because these emissions can be transported great distances. Results of the SO₂ and NO_x program, along with past, present and future plans, can be found on the Internet at <http://www.epa.gov/airmarkets/arp/>. Additional information in the form of maps showing the results of the SO₂ and NO_x limitations can be found on the Internet at <http://nadp.sws.uiuc.edu/>.

The U.S. EPA has set a limit on the amount of sulfur dioxide emissions and the emission rate of nitrogen oxides for all regulated power plants. In 1993, U.S. EPA allocated a certain amount of sulfur dioxide emissions allowances to each power plant regulated by Phase II of the Acid Rain Program. Emissions of nitrogen oxides are being reduced by at

least 2 million tons per year, by setting limits on the emission rate of nitrogen oxides from coal-fired power plant boilers.

(b) Federal Rules

The emission allowances and conditions in this draft Phase II permit were taken from the limits developed by the U.S. EPA for the Acid Rain Program pursuant to Title IV of the Clean Air Act, 42 United States Code 7401, as amended by Public Law 101-5049 (November 15, 1990). Parts 72 through 78 of Title 40 of the Code of Federal Regulations (CFR), 61 Federal Register (FR) 59142, 61 FR 67111, 61 FR 68821, and 62 FR 3463, apply to regulated power plants.

(c) Indiana's Rules

Title 326 of the Indiana Administrative Code (IAC) Article 21, Acid Deposition Control, has adopted the federal rule by referencing 40 CFR 72 through 78, 61 FR 59142, 61 FR 67111, 61 FR 68821, and 62 FR 3463. The rule incorporates the requirements of Title IV, Clean Air Act Acid Rain Program, of the 1990 Clean Air Act (CAA).

(d) Sulfur Dioxide (SO₂) Emission Allocations

Beginning in 2010, the Clean Air Act has placed a cap at 8.95 on the number of allowances issued to units each year. No allocations were made for new sources. New regulated power plants have to obtain sulfur dioxide emission allocations by purchasing them from pre-existing power plants that have received U.S. EPA allocations. A regulated power plant may have emission allocations to sell because the plant purchased newer, less polluting, equipment. The U.S. EPA keeps track of the transfer of all sulfur dioxide emission allocations in an official accounting system.

(e) Nitrogen Oxide Emission (NO_x) Limitations

Pursuant to 40 CFR 76, nitrogen oxide (NO_x) emission limitations are applicable only to coal-fired utility and coal-fired substitution units that are subject to Phase I and Phase II sulfur dioxide (SO₂) reduction requirements.

Specific Sulfur Dioxide (SO₂) Emission Allocations
--

There are two (2) affected units, identified as Units 1SG1, and 2SG1, in this generating station. Table 1 below summarizes the SO₂ Allowance Allocations for these units.

Table 1	
SO ₂ Annual Allowance Allocations (tons/year) for Calendar Year 2010 and Beyond	
Unit 1SG1	3600
Unit 2SG1	3666

Specific NO_x Compliance and Averaging Plan

There are two (2) affected units, identified as Units 1SG1, and 2SG1, in this generating station. Table 2 and 3 below summarize the NO_x compliance and averaging plan for these units.

Table 2			
Calendar Years 2010 and Beyond	Emission Limitation per 40 CFR 76.5, 76.6 or 76.7 (lb/MMBTU)	Alternative Limit (lb/MMBTU)	Heat Input Limit (MMBTU)
Unit 1SG1	0.46	.46	10,000,000
Unit 2SG1	0.46	.46	10,000,000
The BTU weighted annual emission rate average over the units if they are operated in accordance with the proposed averaging plans = BTU weighted annual average emission rate for same units operated in compliance with 40 CFR 76 = 0.46			

Table 3	
List of Sources Participating in the NO _x Averaging Plan Calendar Years 2010 and Beyond	
Source Names	No. of Units
Frank E. Ratts Station	2
Merom Generating Station	2

Emissions Monitoring Requirements

The Permittee and, to the extent applicable, the designated representative for the source must comply with the monitoring requirements set out in 40 CFR 75 and 72.9(b)(1) and (2). The source must measure and record its emissions of sulfur dioxide. The source must report these measurements to IDEM and U.S. EPA. These records and reports are used to determine if the source is in compliance with the sulfur dioxide allocation program. The requirements of the Phase II permit do not affect the source's responsibility to monitor emissions of other pollutants or other emissions characteristics required by the Clean Air Act and other operating permit provisions. Monitoring requirements outlined in the source's Phase II permit renewal application are considered as part of the Phase II renewal permit.

Other Record Keeping and Reporting Requirements

The source must keep copies of all reports and compliance certifications that it submits to demonstrate compliance with the requirements of the Phase II permit for five years. The source must submit the reports and compliance certifications required by the Phase II permit to the U.S. EPA and IDEM, OAQ. Record keeping and reporting requirements outlined in the Phase II renewal application are considered part of the Phase II renewal permit.

Submissions

The designated representative for each emissions unit must sign and certify every report or other submission required by the Phase II renewal permit. The designated representative must include the following certification statement in every submission:

"I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."

The designated representative must send each owner and operator of the source a notification regarding every submission. The designated representative must also notify each owner and operator of the source within ten (10) business days of the receipt of any written determination made by U.S. EPA or IDEM.

Draft Phase II Permit Renewal

Based on the information IDEM received from the proposed operator, IDEM has preliminarily determined that the source meets the requirement of Indiana Code (IC) 13-17-3-4, IC 13-17-3-11, IC 13-17-8-1, and IC 13-17-8-2, as well as Title IV of the Clean Air Act. IDEM proposes this draft Phase II permit renewal pursuant to 326 IAC 21.

Recommendation

The staff recommends to the IDEM's Commissioner that the Title IV Acid Rain permit renewal be approved. This recommendation is based on the following facts and conditions:

Unless otherwise stated, information used in this review was derived from the application and additional information submitted by the applicant.

A Phase II Acid Rain permit renewal application for the purposes of this review was received on December 23, 2009.

IDEM Contact

- (a) **Permit**
Questions regarding the proposed Phase II renewal permit can be directed to Deborah Cole at the Indiana Department Environmental Management (IDEM), Office of Air Quality (OAQ), 100 North Senate Avenue, P.O. Box 6015, Indianapolis, Indiana 46206-6015 or by telephone at (317) 234-5300 or toll free at 1-800-451-6027 extension 4-5300 or dcole@idem.in.gov.
- (b) **Compliance Inspection**
The source will be inspected by IDEM's compliance inspection staff. Persons seeking to obtain information regarding the source's compliance status or to report any potential violation of any permit condition should contact Dan Hancock at the Office of Air Quality (OAQ) address or by telephone at (317) 232-8429 or toll free at 1-800-451-6027 extension 232-8429.

- c) Copies
Copies of the Code of Federal Regulations (CFR) referenced in the permit may be obtained from:

Indiana Department of Environmental Management
Office of Air Quality
100 North Senate Avenue
Indianapolis, Indiana 46206-6015

or

Government Printing Office website at
<http://www.access.gpo.gov/nara/cfr/index.html>



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

SENT VIA U.S. MAIL: CONFIRMED DELIVERY AND SIGNATURE REQUESTED

TO: Darrell Bayless
Hoosier REC, Inc - Frank E. Ratts Generating Station
P.O. Box 908
Bloomington, IN 47402

DATE: March 22, 2010

FROM: Matt Stuckey, Branch Chief
Permits Branch
Office of Air Quality

SUBJECT: Final Decision
Acid Rain - Renewal
125-28810-00001

Enclosed is the final decision and supporting materials for the air permit application referenced above. Please note that this packet contains the original, signed, permit documents.

The final decision is being sent to you because our records indicate that you are the contact person for this application. However, if you are not the appropriate person within your company to receive this document, please forward it to the correct person.

A copy of the final decision and supporting materials has also been sent via standard mail to:
Chuck Norris (Manager – Ratts Generating Station)
OAQ Permits Branch Interested Parties List

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178, or toll-free at 1-800-451-6027 (ext. 3-0178), and ask to speak to the permit reviewer who prepared the permit. If you think you have received this document in error, please contact Joanne Smiddie-Brush of my staff at 1-800-451-6027 (ext 3-0185), or via e-mail at jbrush@idem.IN.gov.

Final Applicant Cover letter.dot 11/30/07



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

March 22, 2010

TO: Pike County Public Library

From: Matthew Stuckey, Branch Chief
Permits Branch
Office of Air Quality

Subject: **Important Information for Display Regarding a Final Determination**

Station
Applicant Name: HoosierEnergy REC, Inc - Frank E. Ratts Generating
Permit Number: 125-28810-00001

You previously received information to make available to the public during the public comment period of a draft permit. Enclosed is a copy of the final decision and supporting materials for the same project. Please place the enclosed information along with the information you previously received. To ensure that your patrons have ample opportunity to review the enclosed permit, **we ask that you retain this document for at least 60 days.**

The applicant is responsible for placing a copy of the application in your library. If the permit application is not on file, or if you have any questions concerning this public review process, please contact Joanne Smiddie-Brush, OAQ Permits Administration Section at 1-800-451-6027, extension 3-0185.

Enclosures
Final Library.dot 11/30/07

Mail Code 61-53

IDEM Staff	MIDENNEY 3/22/2010 Hoosier Energy REC, Inc. - Frank E. Ratts Gen. Station 125-28810-00001 (final)		AFFIX STAMP HERE IF USED AS CERTIFICATE OF MAILING	
Name and address of Sender		Indiana Department of Environmental Management Office of Air Quality – Permits Branch 100 N. Senate Indianapolis, IN 46204	Type of Mail: CERTIFICATE OF MAILING ONLY	

Line	Article Number	Name, Address, Street and Post Office Address	Postage	Handing Charges	Act. Value (If Registered)	Insured Value	Due Send if COD	R.R. Fee	S.D. Fee	S.H. Fee	Rest. Del. Fee	Remarks
1		Darrell Bayless Hoosier Energy REC, Inc. - Frank E. Ratts Generati PO Box 908 Bloomington IN 47402 (Source CAATS) via confirmed delivery										
2		Chris Norris Ratts Station Mgr Hoosier Energy REC, Inc. - Frank E. Ratts Generati 6825 N Blackburn Rd Petersburg IN 47567 (RO CAATS)										
3		Mr. Randy Brown Plumbers & Steam Fitters Union, Local 136 2300 St. Joe Industrial Park Dr Evansville IN 47720 (Affected Party)										
4		Mr. Paul Lake 2364 South CR 750 E. Winslow IN 47598 (Affected Party)										
5		Ms. Andrea Wood 4565 E CR 750 N Petersburg IN 47567 (Affected Party)										
6		Pike County Commissioners 801 Main Street Petersburg IN 47567 (Local Official)										
7		Petersburg City Council and Mayors Office 704 Main St, City Hall Petersburg IN 47567 (Local Official)										
8		Pike County Health Department 801 Main St, Courthouse Petersburg IN 47567-1298 (Health Department)										
9		Pike County Public Library 1104 Main St Petersburg IN 47567-1337 (Library)										
10		Mr. Meyer Larry 4715 S. CR 175 E. Winslow IN 47598 (Affected Party)										
11		Mr. Gary Leavitt 502 S. Lakeview Dr. Petersburg IN 47567 (Affected Party)										
12		Tom & Sandy Loveless 138 Nichols Ave Petersburg IN 47567 (Affected Party)										
13		C.J. & Betty Meadors 5582 N CR 500 E Petersburg IN 47567 (Affected Party)										
14		Rachel Lewis 12710 N Green River Rd Evansville In 47725 (Affected Party)										
15		Mr. John Blair 800 Adams Ave Evansville IN 47713 (Affected Party)										

Total number of pieces Listed by Sender			
14	Total number of Pieces Received at Post Office	Postmaster, Per (Name of Receiving employee)	The full declaration of value is required on all domestic and international registered mail. The maximum indemnity payable for the reconstruction of nonnegotiable documents under Express Mail document reconstructing insurance is \$50,000 per piece subject to a limit of \$50,000 per occurrence. The maximum indemnity payable on Express mil merchandise insurance is \$500. The maximum indemnity payable is \$25,000 for registered mail, sent with optional postal insurance. See Domestic Mail Manual R900, S913, and S921 for limitations of coverage on inured and COD mail. See International Mail Manual for limitations o coverage on international mail. Special handling charges apply only to Standard Mail (A) and Standard Mail (B) parcels.