INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

TO: Interested Parties / Applicant

DATE: April 30, 2010

RE: Indiana University / 105-28915-00005

FROM: Matthew Stuckey, Branch Chief
Permits Branch
Office of Air Quality

Notice of Decision: Approval – Effective Immediately

Please be advised that on behalf of the Commissioner of the Department of Environmental Management, I have issued a decision regarding the enclosed matter. Pursuant to IC 13-15-5-3, this permit is effective immediately, unless a petition for stay of effectiveness is filed and granted, and may be revoked or modified in accordance with the provisions of IC 13-15-7-1.

If you wish to challenge this decision, IC 4-21.5-3-7 and IC 13-15-6-1(b) or IC 13-15-6-1(a) require that you file a petition for administrative review. This petition may include a request for stay of effectiveness and must be submitted to the Office of Environmental Adjudication, 100 North Senate Avenue, Government Center North, Suite N 501E, Indianapolis, IN 46204.

For an **initial Title V Operating Permit**, a petition for administrative review must be submitted to the Office of Environmental Adjudication within **thirty (30)** days from the receipt of this notice provided under IC 13-15-5-3, pursuant to IC 13-15-6-1(b).

For a **Title V Operating Permit renewal**, a petition for administrative review must be submitted to the Office of Environmental Adjudication within **fifteen (15)** days from the receipt of this notice provided under IC 13-15-5-3, pursuant to IC 13-15-6-1(a).

The filing of a petition for administrative review is complete on the earliest of the following dates that apply to the filing:

(1) the date the document is delivered to the Office of Environmental Adjudication (OEA);
(2) the date of the postmark on the envelope containing the document, if the document is mailed to OEA by U.S. mail; or
(3) The date on which the document is deposited with a private carrier, as shown by receipt issued by the carrier, if the document is sent to the OEA by private carrier.

The petition must include facts demonstrating that you are either the applicant, a person aggrieved or adversely affected by the decision or otherwise entitled to review by law. Please identify the permit, decision, or other order for which you seek review by permit number, name of the applicant, location, date of this notice and all of the following:

Recycled Paper An Equal Opportunity Employer *Please Recycle*

(1) the name and address of the person making the request;
(2) the interest of the person making the request;
(3) identification of any persons represented by the person making the request;
(4) the reasons, with particularity, for the request;
(5) the issues, with particularity, proposed for considerations at any hearing; and
(6) identification of the terms and conditions which, in the judgment of the person making the request, would be appropriate in the case in question to satisfy the requirements of the law governing documents of the type issued by the Commissioner.

Pursuant to 326 IAC 2-7-18(d), any person may petition the U.S. EPA to object to the issuance of an initial Title V operating permit, permit renewal, or modification within sixty (60) days of the end of the forty-five (45) day EPA review period. Such an objection must be based only on issues that were raised with reasonable specificity during the public comment period, unless the petitioner demonstrates that it was impractible to raise such issues, or if the grounds for such objection arose after the comment period.

To petition the U.S. EPA to object to the issuance of a Title V operating permit, contact:

U.S. Environmental Protection Agency
401 M Street
Washington, D.C. 20406

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178. Callers from within Indiana may call toll-free at 1-800-451-6027, ext. 3-0178.

Enclosures
FNTVOP.dot12/3/07

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

PART 70 OPERATING PERMIT RENEWAL
OFFICE OF AIR QUALITY

Indiana University
820 N. Walnut Grove Avenue
Bloomington, Indiana 47405

(herein known as the Permittee) is hereby authorized to operate subject to the conditions contained herein, the source described in Section A (Source Summary) of this permit.

The Permittee must comply with all conditions of this permit. Noncompliance with any provisions of this permit is grounds for enforcement action; permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. Noncompliance with any provision of this permit, except any provision specifically designated as not federally enforceable, constitutes a violation of the Clean Air Act. It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. An emergency does constitute an affirmative defense in an enforcement action provided the Permittee complies with the applicable requirements set forth in Section B, Emergency Provisions.

This permit is issued in accordance with 326 IAC 2 and 40 CFR Part 70 Appendix A and contains the conditions and provisions specified in 326 IAC 2-7 as required by 42 U.S.C. 7401, et. seq. (Clean Air Act as amended by the 1990 Clean Air Act Amendments), 40 CFR Part 70.6, IC 13-15 and IC 13-17.

Operation Permit Renewal No.: T 105-28296-00005	
Issued by: Tripurari P. Sinha, Ph. D., Section Chief Permits Branch Office of Air Quality	Issuance Date: October 23, 2009 Expiration Date: October 23, 2014

Significant Permit Modification No.: T 105-28915-00005	
Issued by: Matthew Stuckey, Branch Chief Permits Branch Office of Air Quality	Issuance Date: April 30, 2010 Expiration Date: October 23, 2014

TABLE OF CONTENTS

A SOURCE SUMMARY 6

A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)] [326 IAC 2-7-1(22)]
A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)] [326 IAC 2-7-5(15)]
A.3 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)]
A.4 Part 70 Permit Applicability [326 IAC 2-7-2]

B GENERAL CONDITIONS 9

B.1 Definitions [326 IAC 2-7-1]
B.2 Permit Term [326 IAC 2-7-5(2)] [326 IAC 2-1.1-9.5] [326 IAC 2-7-4(a)(1)(D)] [IC 13-15-3-6(a)]
B.3 Term of Conditions [326 IAC 2-1.1-9.5]
B.4 Enforceability [326 IAC 2-7-7] [IC 13-17-12]
B.5 Severability [326 IAC 2-7-5(5)]
B.6 Property Rights or Exclusive Privilege [326 IAC 2-7-5(6)(D)]
B.7 Duty to Provide Information [326 IAC 2-7-5(6)(E)]
B.8 Certification [326 IAC 2-7-4(f)] [326 IAC 2-7-6(1)] [326 IAC 2-7-5(3)(C)]
B.9 Annual Compliance Certification [326 IAC 2-7-6(5)]
B.10 Preventive Maintenance Plan [326 IAC 2-7-5(1),(3) and (13)] [326 IAC 2-7-6(1) and (6)] [326 IAC 1-6-3]
B.11 Emergency Provisions [326 IAC 2-7-16]
B.12 Permit Shield [326 IAC 2-7-15] [326 IAC 2-7-20] [326 IAC 2-7-12]
B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5] [326 IAC 2-7-10.5]
B.14 Termination of Right to Operate [326 IAC 2-7-10] [326 IAC 2-7-4(a)]
B.15 Deviations from Permit Requirements and Conditions [326 IAC 2-7-5(3)(C)(ii)]
B.16 Permit Modification, Reopening, Revocation and Reissuance, or Termination [326 IAC 2-7-5(6)(C)] [326 IAC 2-7-8(a)] [326 IAC 2-7-9]
B.17 Permit Renewal [326 IAC 2-7-3] [326 IAC 2-7-4] [326 IAC 2-7-8(e)]
B.18 Permit Amendment or Modification [326 IAC 2-7-11] [326 IAC 2-7-12]
B.19 Permit Revision Under Economic Incentives and Other Programs [326 IAC 2-7-5(8)] [326 IAC 2-7-12(b)(2)]
B.20 Operational Flexibility [326 IAC 2-7-20] [326 IAC 2-7-10.5]
B.21 Source Modification Requirement [326 IAC 2-7-10.5]
B.22 Inspection and Entry [326 IAC 2-7-6] [IC 13-14-2-2] [IC 13-30-3-1] [IC 13-17-3-2]
B.23 Transfer of Ownership or Operational Control [326 IAC 2-7-11]
B.24 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-7-5(7)] [326 IAC 2-1.1-7]
B.25 Credible Evidence [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [62 FR 8314] [326 IAC 1-1-6]

C SOURCE OPERATION CONDITIONS 20

Emission Limitations and Standards [326 IAC 2-7-5(1)]
C.1 Particulate Emission Limitations for Processes with Process Weight Rates Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]
C.2 Opacity [326 IAC 5-1]
C.3 Open Burning [326 IAC 4-1] [IC 13-17-9]
C.4 Incineration [326 IAC 4-2] [326 IAC 9-1-2]
C.5 Fugitive Dust Emissions [326 IAC 6-4]
C.6 Stack Height [326 IAC 1-7]
C.7 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

Testing Requirements [326 IAC 2-7-6(1)]
C.8 Performance Testing [326 IAC 3-6]

Compliance Requirements [326 IAC 2-1.1-11]
C.9 Compliance Requirements [326 IAC 2-1.1-11]

Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]
C.10 Compliance Monitoring [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]
C.11 Maintenance of Continuous Opacity Monitoring Equipment [326 IAC 2-7-5(3)(A)(iii)]
C.12 Monitoring Methods [326 IAC 3] [40 CFR 60] [40 CFR 63]
C.13 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

Corrective Actions and Response Steps [326 IAC 2-7-5] [326 IAC 2-7-6]
C.14 Emergency Reduction Plans [326 IAC 1-5-2] [326 IAC 1-5-3]
C.15 Risk Management Plan [326 IAC 2-7-5(12)] [40 CFR 68]
C.16 Response to Excursions or Exceedances [326 IAC 2-7-5] [326 IAC 2-7-6]
C.17 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5] [326 IAC 2-7-6]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
C.18 Emission Statement [326 IAC 2-7-5(3)(C)(iii)] [326 IAC 2-7-5(7)] [326 IAC 2-7-19(c)] [326 IAC 2-6]
C.19 General Record Keeping Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [326 IAC 2-2] [326 IAC 2-3]
C.20 General Reporting Requirements [326 IAC 2-7-5(3)(C)] [326 IAC 2-1.1-11] [326 IAC 2-2]

Stratospheric Ozone Protection
C.21 Compliance with 40 CFR 82 and 326 IAC 22-1

D.1 EMISSIONS UNIT OPERATION CONDITIONS Boilers EU-07 29

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.1.1 PSD Minor Limit [326 IAC 2-2]
D.1.2 Sulfur Dioxide (SO2) [326 IAC 7-1.1]
D.1.3 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

Compliance Determination Requirements
D.1.4 Sulfur Dioxide Emissions and Sulfur Content

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.1.5 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.1.6 Maintenance of Continuous Emission Monitoring Equipment [326 IAC 2-7-5(3)(A)(iii)]

Recordkeeping and Reporting Requirements [326 IAC 2-7-5(3) [326 IAC 2-7-19]
D.1.7 Record Keeping Requirements
D.1.8 Reporting Requirements

D.2 FACILITY OPERATION CONDITIONS - Boilers EU-03, EU-04 and EU-05 33

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.2.1 Particulate Matter Limitation (PM) [326 IAC 6-2-3]
D.2.2 Sulfur Dioxide (SO2) [326 IAC 7-1.1]
D.2.3 Heat Input Capacity Limitations
D.2.4 PSD Minor Limit [326 IAC 2-2]
D.2.5 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

Compliance Determination Requirements
D.2.6 Testing Requirements [326 IAC 2-7-6(1),(6)] [326 IAC 2-1.1-11]
D.2.7 Particulate Control [326 IAC 2-7-6(6)]
D.2.8 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3-7] [326 IAC 7-2] [326 IAC 7-1.1-2]
D.2.9 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3-7] [326 IAC 7-2] [326 IAC 7-1.1-2]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.2.10 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.2.11 Monitoring: Multiclones [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.2.12 Multiclone Failure Detection [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.2.13 Bag Leak Detection System (BLDS)

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
D.2.14 Record Keeping Requirements
D.2.15 Reporting Requirements

D.3 FACILITY OPERATION CONDITIONS - Boiler EU-06 40

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.3.1 Particulate Matter Limitation (PM) [326 IAC 6-2-3]
D.3.2 Sulfur Dioxide (SO2) [326 IAC 7-1.1]
D.3.3 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

Compliance Determination Requirements
D.3.4 Testing Requirements [326 IAC 2-7-6(1),(6)] [326 IAC 2-1.1-11]
D.3.5 Particulate and Opacity Control [326 IAC 2-7-6(6)]
D.3.6 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3-7] [326 IAC 7-2] [326 IAC 7-1.1-2]
D.3.7 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3-7] [326 IAC 7-2] [326 IAC 7-1.1-2]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.3.8 Bag Leak Detection System (BLDS)

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
D.3.9 Record Keeping Requirements
D.3.10 Reporting Requirements

D.4 FACILITY OPERATION CONDITIONS - Coal Storage and Handling System 46

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.4.1 Particulate Matter (PM) [326 IAC 6-3]
D.4.2 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

Compliance Determination Requirements
D.4.3 Particulate Matter (PM)

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.4.4 Baghouse Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.4.5 Visible Emissions Notations

Record Keeping and Reporting Requirement [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
D.4.6 Record Keeping Requirements

D.5 FACILITY OPERATION CONDITIONS - Insignificant Operations **49**

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.5.1 PSD Minor Limits [326 IAC 2-2]
D.5.2 Particulate Emission Limitations for Sources of Indirect Heating [326 IAC 6-2]
D.5.3 Particulate Emission Limitations for Manufacturing Processes (PM) [326 IAC 6-3]
D.5.4 Volatile Organic Compounds (VOC) [326 IAC 8-3-2]
D.5.5 Volatile Organic Compounds (VOC) [326 IAC 8-3-5]

Record Keeping and Reporting Requirement [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
D.5.6 Record Keeping Requirements
D.5.7 Reporting Requirements

E.1 FACILITY OPERATION CONDITIONS **51**

New Source Performance Standards (NSPS) Requirements: [326 IAC 2-7-5(1)]
E.1.1 General Provisions Relating to New Source Performance Standards (NSPS) [326 IAC 12-1] [40 CFR 60, Subpart A] [326 IAC 12]
E.1.2 New Source Performance Standards (NSPS) [326 IAC 12] [40 CFR 60, Subpart Db] [326 IAC 12]

E.2 FACILITY OPERATION CONDITIONS **53**

New Source Performance Standards (NSPS) Requirements: [326 IAC 2-7-5(1)]
E.2.1 General Provisions Relating to New Source Performance Standards (NSPS) [326 IAC 12-1] [40 CFR 60, Subpart A] [326 IAC 12]
E.2.2 New Source Performance Standards (NSPS) [326 IAC 12] [40 CFR 60, Subpart IIII] [326 IAC 12]

E.3 FACILITY OPERATION CONDITIONS **54**

New Source Performance Standards (NSPS) Requirements: [326 IAC 2-7-5(1)]
E.3.1 General Provisions Relating to National Emission Standards for Hazardous Air Pollutants (NESHAP) [326 IAC 20-82 [40 CFR 63, Subpart A]
E.3.2 Stationary Combustion Turbines NESHAP [326 IAC 20-82] [40 CFR 63, Subpart ZZZZ]

Certification **54**

Emergency Occurrence Report **55**

Quarterly Reports **57-62**

Quarterly Deviation and Compliance Monitoring Report **63**

Attachment A New Source Performance Standards: Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units [40 CFR Part 60, Subpart Db] [326 IAC 12]

Attachment B New Source Performance Standards: Standards of Performance for Stationary Compression Ignition Internal Combustion Engines [40 CFR Part 60, Subpart IIII] [326 IAC 12]

Attachment C National Emission Standards for Hazardous Air Pollutants (NESHAP) for Performance for Stationary Reciprocating Internal Combustion Engines [40 CFR 63, Subpart ZZZZ] [326 IAC 20-82]

SECTION A SOURCE SUMMARY

This permit is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ). The information describing the source contained in conditions A.1 through A.3 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this permit pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)] [326 IAC 2-7-1(22)]

The Permittee owns and operates a stationary power plant that supplies campus with process heat from boilers.

Source Address:	820 N. Walnut Grove Avenue, Bloomington, IN 47405
Mailing Address:	1514 East 3rd Street, Bloomington, IN 47405
General Source Phone Number:	(812) 855-3231
SIC Code:	8221
County Location:	Monroe
Source Location Status:	Attainment for all criteria pollutants
Source Status:	Part 70 Operating Permit Program Major Source, under PSD Rules Major Source, Section 112 of the Clean Air Act 1 of 28 Source Categories

A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)] [326 IAC 2-7-5(15)]

This stationary source consists of the following emission units and pollution control devices:

(a) One (1) natural gas, low-sulfur No. 1 or No. 2 fuel oil fired boiler, identified as EU-07, approved for construction in 2007, including a mud drum heat exchanger, with a maximum design capacity of 217 MMBtu per hour when combusting natural gas and 208 MMBtu per hour when combusting fuel oil, and equipped with low NOx burners and induced flue gas recirculation for NOx control, with continuous monitors for monitoring carbon monoxide and NOx, exhausting to stack 002. Under 40 CFR Subpart Db, this is a new affected source.

(b) Two (2) coal, natural gas, No. 1 or No. 2 fuel oil fired boilers, identified as EU-03 and EU-04, both constructed in 1959, with economizers replaced in 2010, with a maximum design capacity of 125 MMBtu per hour heat input each (operating at a maximum capacity of 100 MMBtu per hour heat input each when combusting coal or a combination of fuels), and with a maximum design capacity of 80 MMBtu per hour heat input each when combusting natural gas and/or fuel oil, each equipped with low NOx burners for natural gas and/or fuel oil, and each with a multiclone and a jet pulse baghouse, identified as Boiler 3 Bag and Boiler 4 Bag, for particulate control, permitted in 2008, when combusting coal and/or fuel oil, both exhausting at stack 002. In addition, the stack exhaust from boilers EU-03 and EU-04 can be treated by an activated carbon injection system for mercury control and a lime injection system for hydrogen chloride control.

(c) One (1) natural gas, No. 1 or No. 2 fuel oil fired boiler, identified as EU-05, constructed in 1964 and modified in 1989, with a maximum design capacity of 190 MMBtu per hour heat input, equipped with low NOx burners (two natural gas fired burners at 75 MMBtu per hour heat input each) for natural gas and/or fuel oil, and a multiclone for particulate control when combusting fuel oil, exhausting to stack 002 or 003.

(d) One (1) coal, natural gas, No. 1 or No. 2 fuel oil fired boiler, identified as EU-06, constructed in 1970, with economizers replaced in 2010, with a maximum design capacity of 190 MMBtu per hour heat input when combusting coal and/or fuel oil, and 150 MMBtu per hour heat input (two natural gas fired burners rated at 75 MMBtu per hour heat input each) when combusting natural gas, equipped with low NOx burners for natural gas and/or fuel oil, a multiclone and a jet pulse baghouse, identified as Boiler 6 Bag, for particulate control when combusting coal and/or fuel oil, permitted in 2008, and a continuous opacity monitor for monitoring opacity, exhausting to stack 003. In addition, the stack exhaust from boiler EU-06 can be treated by an activated carbon injection system for mercury control and a lime injection system for hydrogen chloride control.

(e) One (1) coal storage and handling system, with a maximum design throughput of 200 tons of coal per hour, consisting of the following:

(1) One (1) coal truck receiving system, consisting of an interior wet suppression system to control coal dust emissions during coal receiving, and two (2) truck hoppers.

(2) Four (4) enclosed belt conveyors, and one (1) enclosed bucket conveyor, with particulate emissions controlled by a fabric filter system, with four (4) dust collectors, identified as DC1 through 4, located internally at various points along the enclosed conveyor system, with all dust collectors exhausting internally.

(3) One (1) coal storage silo with a storage capacity of 1,000 tons of coal, with particulate emissions controlled by one (1) dust collector, identified as DC6, exhausting externally at vent 6.

A.3 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)]

This stationary source also includes the following insignificant activities which are specifically regulated, as defined in 326 IAC 2-7-1(21):

(a) Natural gas-fired combustion sources with heat input equal to or less than ten (10) million Btu per hour heat input [326 IAC 6-2]:

(1) Twenty-two (22) boilers constructed before 1972, with a combined total heat input of 29.130 MMBtu per hour. [326 IAC 6-2-3(b) and (d)]

(2) One (1) boiler constructed in 1977, with a heat input of 0.60 MMBtu per hour. [326 IAC 6-2-3(c)]

(3) One (1) boiler constructed in 1981, with a heat input of 0.110 MMBtu per hour. [326 IAC 6-2-3(c)]

(4) Sixty-six (66) boilers constructed after 1983, with a combined heat input of 145.25 MMBtu per hour. [326 IAC 6-2-4(a) and (b)]

(b) Degreasing operations that do not exceed 145 gallons per 12 months, except if subject to 326 IAC 20-6. [326 IAC 8-3]

(c) Oil fired emergency generators not exceeding 1,600 horsepower:

(1) One (1) emergency generator, identified as MSB 1, permitted in 2007, rated at 1200 horsepower.

(d) Two (2) pneumatic ash handling legs, identified as Ash Leg #1 and Ash Leg #2, permitted in 2008, with a maximum throughput capacity of 0.71 tons of fly ash per hour, emissions are controlled by water spray.

(e) One (1) activated carbon injection system, constructed in 2008, consisting of one (1) activated carbon storage silo, with a maximum storage capacity of 52 tons and throughput of 1,200 lbs/hr, identified as Carbon Silo, controlled by a bin vent baghouse, identified as CS Bag, exhausting indoors to stack CS Vent.

(f) One (1) lime injection system, constructed in 2008, consisting of one (1) lime storage silo, with a maximum storage capacity of 25 tons and throughput of 30 lbs/hr, identified as Lime Silo, controlled by a bin vent baghouse, identified as LS Bag, exhausting indoors to stack LS Vent.

(g) Fifteen (15) Diesel Emergency Generators:

(1) AHSB-1, 300 kW, installed in 2008
(2) FQHSB-1, 240 kW, installed in 2006
(3) HAPSB-1, 30 kW, installed in 2007
(4) HCSB-1, 750 kW, installed in 2008
(5) IUPD-1, 150 kW, installed in 2007
(6) JHSB-1, 155 kW, installed in 2007
(7) MHSB-1, 27 kW, installed in 2009
(8) SBSB-1, 40 kW, installed in 2007
(9) DCSB-1, 1500 kW, installed in 2009
(10) DCSB-2, 1500 kW, installed in 2009
(11) TQSB-1, 315 kW, installed in 2007
(12) SRSB-1, 101 kW, installed in 2007
(13) CBSB-1, 35 kW, installed in 2004
(14) MSB-1, 1000 kW, installed in 2007
(15) TTASB-1, 240 kW, installed in 2006

(h) Woodworking area, installed in 2007, equipped with a baghouse with an exhaust flow rate of 11,700 CFM.

A.4 Part 70 Permit Applicability [326 IAC 2-7-2]

This stationary source is required to have a Part 70 permit by 326 IAC 2-7-2 (Applicability) because:

(a) It is a major source, as defined in 326 IAC 2-7-1(22);

(b) It is a source in a source category designated by the United States Environmental Protection Agency (U.S. EPA) under 40 CFR 70.3 (Part 70 - Applicability).

SECTION B GENERAL CONDITIONS

B.1 Definitions [326 IAC 2-7-1]

Terms in this permit shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, the applicable definitions found in the statutes or regulations (IC 13-11, 326 IAC 1-2 and 326 IAC 2-7) shall prevail.

B.2 Permit Term [326 IAC 2-7-5(2)] [326 IAC 2-1.1-9.5] [326 IAC 2-7-4(a)(1)(D)] [IC 13-15-3-6(a)]

(a) This permit, T 105-28296-00005, is issued for a fixed term of five (5) years from the issuance date of this permit, as determined in accordance with IC 4-21.5-3-5(f) and IC 13-15-5-3. Subsequent revisions, modifications, or amendments of this permit do not affect the expiration date of this permit.

(b) If IDEM, OAQ, upon receiving a timely and complete renewal permit application, fails to issue or deny the permit renewal prior to the expiration date of this permit, this existing permit shall not expire and all terms and conditions shall continue in effect, including any permit shield provided in 326 IAC 2-7-15, until the renewal permit has been issued or denied.

B.3 Term of Conditions [326 IAC 2-1.1-9.5]

Notwithstanding the permit term of a permit to construct, a permit to operate, or a permit modification, any condition established in a permit issued pursuant to a permitting program approved in the state implementation plan shall remain in effect until:

(a) the condition is modified in a subsequent permit action pursuant to Title I of the Clean Air Act; or

(b) the emission unit to which the condition pertains permanently ceases operation.

B.4 Enforceability [326 IAC 2-7-7] [IC 13-17-12]

Unless otherwise stated, all terms and conditions in this permit, including any provisions designed to limit the source's potential to emit, are enforceable by IDEM, the United States Environmental Protection Agency (U.S. EPA) and by citizens in accordance with the Clean Air Act.

B.5 Severability [326 IAC 2-7-5(5)]

The provisions of this permit are severable; a determination that any portion of this permit is invalid shall not affect the validity of the remainder of the permit.

B.6 Property Rights or Exclusive Privilege [326 IAC 2-7-5(6)(D)]

This permit does not convey any property rights of any sort or any exclusive privilege.

B.7 Duty to Provide Information [326 IAC 2-7-5(6)(E)]

(a) The Permittee shall furnish to IDEM, OAQ, within a reasonable time, any information that IDEM, OAQ may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The submittal by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34). Upon request, the Permittee shall also furnish to IDEM, OAQ copies of records required to be kept by this permit.

(b) For information furnished by the Permittee to IDEM, OAQ, the Permittee may include a claim of confidentiality in accordance with 326 IAC 17.1. When furnishing copies of requested records directly to U. S. EPA, the Permittee may assert a claim of confidentiality in accordance with 40 CFR 2, Subpart B.

B.8 Certification [326 IAC 2-7-4(f)] [326 IAC 2-7-6(1)] [326 IAC 2-7-5(3)(C)]

(a) Where specifically designated by this permit or required by an applicable requirement, any application form, report, or compliance certification submitted shall contain certification by the "responsible official" of truth, accuracy, and completeness. This certification shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

(b) One (1) certification shall be included, using the attached Certification Form, with each submittal requiring certification. One (1) certification may cover multiple forms in one (1) submittal.

(c) A "responsible official" is defined at 326 IAC 2-7-1(34).

B.9 Annual Compliance Certification [326 IAC 2-7-6(5)]

(a) The Permittee shall annually submit a compliance certification report which addresses the status of the source's compliance with the terms and conditions contained in this permit, including emission limitations, standards, or work practices. All certifications shall cover the time period from January 1 to December 31 of the previous year, and shall be submitted no later than July 1 of each year to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V
Air and Radiation Division, Air Enforcement Branch - Indiana (AE-17J)
77 West Jackson Boulevard
Chicago, Illinois 60604-3590

(b) The annual compliance certification report required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.

(c) The annual compliance certification report shall include the following:

(1) The appropriate identification of each term or condition of this permit that is the basis of the certification;

(2) The compliance status;

(3) Whether compliance was continuous or intermittent;

(4) The methods used for determining the compliance status of the source, currently and over the reporting period consistent with 326 IAC 2-7-5(3); and

(5) Such other facts, as specified in Sections D of this permit, as IDEM, OAQ may require to determine the compliance status of the source.

The submittal by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

B.10 Preventive Maintenance Plan [326 IAC 2-7-5(1),(3) and (13)] [326 IAC 2-7-6(1) and (6)] [326 IAC 1-6-3]

(a) If required by specific condition(s) in Section D of this permit, the Permittee shall maintain and implement Preventive Maintenance Plans (PMPs) including the following information on each facility:

(1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;

(2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and

(3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

(b) A copy of the PMPs shall be submitted to IDEM, OAQ upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. IDEM, OAQ may require the Permittee to revise its PMPs whenever lack of proper maintenance causes or is the primary contributor to an exceedance of any limitation on emissions or potential to emit. The PMPs do not require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

(c) To the extent the Permittee is required by 40 CFR Part 60/63 to have an Operation Maintenance, and Monitoring (OMM) Plan for a unit, such Plan is deemed to satisfy the PMP requirements of 326 IAC 1-6-3 for that unit.

B.11 Emergency Provisions [326 IAC 2-7-16]

(a) An emergency, as defined in 326 IAC 2-7-1(12), is not an affirmative defense for an action brought for noncompliance with a federal or state health-based emission limitation.

(b) An emergency, as defined in 326 IAC 2-7-1(12), constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limitation if the affirmative defense of an emergency is demonstrated through properly signed, contemporaneous operating logs or other relevant evidence that describe the following:

(1) An emergency occurred and the Permittee can, to the extent possible, identify the causes of the emergency;

(2) The permitted facility was at the time being properly operated;

(3) During the period of an emergency, the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards or other requirements in this permit;

(4) For each emergency lasting one (1) hour or more, the Permittee notified IDEM, OAQ, within four (4) daytime business hours after the beginning of the emergency, or after the emergency was discovered or reasonably should have been discovered;

Telephone Number: 1-800-451-6027 (ask for Office of Air Quality, Compliance and Enforcement Branch), or
Telephone Number: 317-233-0178 (ask for Compliance and Enforcement Branch)
Facsimile Number: 317-233-6865

(5) For each emergency lasting one (1) hour or more, the Permittee submitted the attached Emergency Occurrence Report Form or its equivalent, either by mail or facsimile to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

within two (2) working days of the time when emission limitations were exceeded due to the emergency.

The notice fulfills the requirement of 326 IAC 2-7-5(3)(C)(ii) and must contain the following:

(A) A description of the emergency;

(B) Any steps taken to mitigate the emissions; and

(C) Corrective actions taken.

The notification which shall be submitted by the Permittee does not require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

(6) The Permittee immediately took all reasonable steps to correct the emergency.

(c) In any enforcement proceeding, the Permittee seeking to establish the occurrence of an emergency has the burden of proof.

(d) This emergency provision supersedes 326 IAC 1-6 (Malfunctions). This permit condition is in addition to any emergency or upset provision contained in any applicable requirement.

(e) The Permittee seeking to establish the occurrence of an emergency shall make records available upon request to ensure that failure to implement a PMP did not cause or contribute to an exceedance of any limitations on emissions. However, IDEM, OAQ may require that the Preventive Maintenance Plans required under 326 IAC 2-7-4(c)(9) be revised in response to an emergency.

(f) Failure to notify IDEM, OAQ by telephone or facsimile of an emergency lasting more than one (1) hour in accordance with (b)(4) and (5) of this condition shall constitute a violation of 326 IAC 2-7 and any other applicable rules.

(g) If the emergency situation causes a deviation from a technology-based limit, the Permittee may continue to operate the affected emitting facilities during the emergency provided the Permittee immediately takes all reasonable steps to correct the emergency and minimize emissions.

(h) The Permittee shall include all emergencies in the Quarterly Deviation and Compliance Monitoring Report. Any emergencies that have been previously reported pursuant to paragraph (b)(5) of this condition and certified by the "responsible official" need only referenced by the date of the original report.

B.12 Permit Shield [326 IAC 2-7-15] [326 IAC 2-7-20] [326 IAC 2-7-12]

(a) Pursuant to 326 IAC 2-7-15, the Permittee has been granted a permit shield. The permit shield provides that compliance with the conditions of this permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that either the applicable requirements are included and specifically identified in this permit or the permit contains an explicit determination or concise summary of a determination that other specifically identified requirements are not applicable. The Indiana statutes from IC 13 and rules from 326 IAC, referenced in conditions in this permit, are those applicable at the time the permit was issued. The issuance or possession of this permit shall not alone constitute a defense against an alleged violation of any law, regulation or standard, except for the requirement to obtain a Part 70 permit under 326 IAC 2-7 or for applicable requirements for which a permit shield has been granted.

This permit shield does not extend to applicable requirements which are promulgated after the date of issuance of this permit unless this permit has been modified to reflect such new requirements.

(b) If, after issuance of this permit, it is determined that the permit is in nonconformance with an applicable requirement that applied to the source on the date of permit issuance, IDEM, OAQ, shall immediately take steps to reopen and revise this permit and issue a compliance order to the Permittee to ensure expeditious compliance with the applicable requirement until the permit is reissued. The permit shield shall continue in effect so long as the Permittee is in compliance with the compliance order.

(c) No permit shield shall apply to any permit term or condition that is determined after issuance of this permit to have been based on erroneous information supplied in the permit application. Erroneous information means information that the Permittee knew to be false, or in the exercise of reasonable care should have been known to be false, at the time the information was submitted.

(d) Nothing in 326 IAC 2-7-15 or in this permit shall alter or affect the following:

(1) The provisions of Section 303 of the Clean Air Act (emergency orders), including the authority of the U.S. EPA under Section 303 of the Clean Air Act;

(2) The liability of the Permittee for any violation of applicable requirements prior to or at the time of this permit's issuance;

(3) The applicable requirements of the acid rain program, consistent with Section 408(a) of the Clean Air Act; and

(4) The ability of U.S. EPA to obtain information from the Permittee under Section 114 of the Clean Air Act.

(e) This permit shield is not applicable to any change made under 326 IAC 2-7-20(b)(2) (Sections 502(b)(10) of the Clean Air Act changes) and 326 IAC 2-7-20(c)(2) (trading based on State Implementation Plan (SIP) provisions).

(f) This permit shield is not applicable to modifications eligible for group processing until after IDEM, OAQ, has issued the modifications. [326 IAC 2-7-12(c)(7)]

(g) This permit shield is not applicable to minor Part 70 permit modifications until after IDEM, OAQ, has issued the modification. [326 IAC 2-7-12(b)(8)]

B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5] [326 IAC 2-7-10.5]

(a) All terms and conditions of permits established prior to T 105-28296-00005 and issued pursuant to permitting programs approved into the state implementation plan have been either:

(1) incorporated as originally stated,

(2) revised under 326 IAC 2-7-10.5, or

(3) deleted under 326 IAC 2-7-10.5.

(b) Provided that all terms and conditions are accurately reflected in this permit, all previous registrations and permits are superseded by this Part 70 operating permit.

B.14 Termination of Right to Operate [326 IAC 2-7-10] [326 IAC 2-7-4(a)]

The Permittee's right to operate this source terminates with the expiration of this permit unless a timely and complete renewal application is submitted at least nine (9) months prior to the date of expiration of the source's existing permit, consistent with 326 IAC 2-7-3 and 326 IAC 2-7-4(a).

B.15 Deviations from Permit Requirements and Conditions [326 IAC 2-7-5(3)(C)(ii)]

(a) Deviations from any permit requirements (for emergencies see Section B - Emergency Provisions), the probable cause of such deviations, and any response steps or preventive measures taken shall be reported to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

using the attached Quarterly Deviation and Compliance Monitoring Report, or its equivalent. A deviation required to be reported pursuant to an applicable requirement that exists independent of this permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report.

The Quarterly Deviation and Compliance Monitoring Report does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

(b) A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit.

B.16 Permit Modification, Reopening, Revocation and Reissuance, or Termination [326 IAC 2-7-5(6)(C)] [326 IAC 2-7-8(a)] [326 IAC 2-7-9]

(a) This permit may be modified, reopened, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a Part 70 Operating Permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any condition of this permit.
[326 IAC 2-7-5(6)(C)] The notification by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

(b) This permit shall be reopened and revised under any of the circumstances listed in IC 13-15-7-2 or if IDEM, OAQ determines any of the following:

(1) That this permit contains a material mistake.

(2) That inaccurate statements were made in establishing the emissions standards or other terms or conditions.

(3) That this permit must be revised or revoked to assure compliance with an applicable requirement. [326 IAC 2-7-9(a)(3)]

(c) Proceedings by IDEM, OAQ to reopen and revise this permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of this permit for which cause to reopen exists. Such reopening and revision shall be made as expeditiously as practicable. [326 IAC 2-7-9(b)]

(d) The reopening and revision of this permit, under 326 IAC 2-7-9(a), shall not be initiated before notice of such intent is provided to the Permittee by IDEM, OAQ at least thirty (30) days in advance of the date this permit is to be reopened, except that IDEM, OAQ may provide a shorter time period in the case of an emergency. [326 IAC 2-7-9(c)]

B.17 Permit Renewal [326 IAC 2-7-3] [326 IAC 2-7-4] [326 IAC 2-7-8(e)]

(a) The application for renewal shall be submitted using the application form or forms prescribed by IDEM, OAQ and shall include the information specified in 326 IAC 2-7-4. Such information shall be included in the application for each emission unit at this source, except those emission units included on the trivial or insignificant activities list contained in 326 IAC 2-7-1(21) and 326 IAC 2-7-1(40). The renewal application does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

Request for renewal shall be submitted to:

Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

(b) A timely renewal application is one that is:

(1) Submitted at least nine (9) months prior to the date of the expiration of this permit; and

(2) If the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.

(c) If the Permittee submits a timely and complete application for renewal of this permit, the source's failure to have a permit is not a violation of 326 IAC 2-7 until IDEM, OAQ takes final action on the renewal application, except that this protection shall cease to apply if, subsequent to the completeness determination, the Permittee fails to submit by the deadline specified in writing by IDEM, OAQ any additional information identified as being needed to process the application.

B.18 Permit Amendment or Modification [326 IAC 2-7-11] [326 IAC 2-7-12]

(a) Permit amendments and modifications are governed by the requirements of 326 IAC 2-7-11 or 326 IAC 2-7-12 whenever the Permittee seeks to amend or modify this permit.

(b) Any application requesting an amendment or modification of this permit shall be submitted to:

Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

Any such application shall be certified by the "responsible official" as defined by 326 IAC 2-7-1(34).

(c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-7-11(c)(3)]

B.19 Permit Revision Under Economic Incentives and Other Programs [326 IAC 2-7-5(8)] [326 IAC 2-7-12(b)(2)]

(a) No Part 70 permit revision shall be required under any approved economic incentives, marketable Part 70 permits, emissions trading, and other similar programs or processes for changes that are provided for in a Part 70 permit.

(b) Notwithstanding 326 IAC 2-7-12(b)(1) and 326 IAC 2-7-12(c)(1), minor Part 70 permit modification procedures may be used for Part 70 modifications involving the use of economic incentives, marketable Part 70 permits, emissions trading, and other similar approaches to the extent that such minor Part 70 permit modification procedures are explicitly provided for in the applicable State Implementation Plan (SIP) or in applicable requirements promulgated or approved by the U.S. EPA.

B.20 Operational Flexibility [326 IAC 2-7-20] [326 IAC 2-7-10.5]

(a) The Permittee may make any change or changes at the source that are described in 326 IAC 2-7-20(b),(c), or (e) without a prior permit revision, if each of the following conditions is met:

(1) The changes are not modifications under any provision of Title I of the Clean Air Act;

(2) Any preconstruction approval required by 326 IAC 2-7-10.5 has been obtained;

(3) The changes do not result in emissions which exceed the limitations provided in this permit (whether expressed herein as a rate of emissions or in terms of total emissions);

(4) The Permittee notifies the:

Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V
Air and Radiation Division, Regulation Development Branch - Indiana (AR-18J)
77 West Jackson Boulevard
Chicago, Illinois 60604-3590

in advance of the change by written notification at least ten (10) days in advance of the proposed change. The Permittee shall attach every such notice to the Permittee's copy of this permit; and

(5) The Permittee maintains records on-site, on a rolling five (5) year basis, which document all such changes and emission trades that are subject to 326 IAC 2-7-20(b),(c), or (e). The Permittee shall make such records available, upon reasonable request, for public review.

Such records shall consist of all information required to be submitted to IDEM, OAQ in the notices specified in 326 IAC 2-7-20(b)(1), (c)(1), and (e)(2).

(b) The Permittee may make Section 502(b)(10) of the Clean Air Act changes (this term is defined at 326 IAC 2-7-1(36)) without a permit revision, subject to the constraint of 326 IAC 2-7-20(a). For each such Section 502(b)(10) of the Clean Air Act change, the required written notification shall include the following:

(1) A brief description of the change within the source;

(2) The date on which the change will occur;

(3) Any change in emissions; and

(4) Any permit term or condition that is no longer applicable as a result of the change.

The notification which shall be submitted is not considered an application form, report or compliance certification. Therefore, the notification by the Permittee does not require the certification by the “responsible official” as defined by 326 IAC 2-7-1(34).

(c) Emission Trades [326 IAC 2-7-20(c)]
The Permittee may trade emissions increases and decreases at the source, where the applicable SIP provides for such emission trades without requiring a permit revision, subject to the constraints of Section (a) of this condition and those in 326 IAC 2-7-20(c).

(d) Alternative Operating Scenarios [326 IAC 2-7-20(d)]
The Permittee may make changes at the source within the range of alternative operating scenarios that are described in the terms and conditions of this permit in accordance with 326 IAC 2-7-5(9). No prior notification of IDEM, OAQ, or U.S. EPA is required.

(e) Backup fuel switches specifically addressed in, and limited under, Section D of this permit shall not be considered alternative operating scenarios. Therefore, the notification requirements of part (a) of this condition do not apply.

B.21 Source Modification Requirement [326 IAC 2-7-10.5]

A modification, construction, or reconstruction is governed by the requirements of 326 IAC 2.

B.22 Inspection and Entry [326 IAC 2-7-6] [IC 13-14-2-2] [IC 13-30-3-1] [IC 13-17-3-2]

Upon presentation of proper identification cards, credentials, and other documents as may be required by law, and subject to the Permittee’s right under all applicable laws and regulations to assert that the information collected by the agency is confidential and entitled to be treated as such, the Permittee shall allow IDEM, OAQ, U.S. EPA, or an authorized representative to perform the following:

(a) Enter upon the Permittee's premises where a Part 70 source is located, or emissions related activity is conducted, or where records must be kept under the conditions of this permit;

(b) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, have access to and copy any records that must be kept under the conditions of this permit;

(c) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, inspect any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit;

(d) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, sample or monitor substances or parameters for the purpose of assuring compliance with this permit or applicable requirements; and

(e) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, utilize any photographic, recording, testing, monitoring, or other equipment for the purpose of assuring compliance with this permit or applicable requirements.

B.23 Transfer of Ownership or Operational Control [326 IAC 2-7-11]

(a) The Permittee must comply with the requirements of 326 IAC 2-7-11 whenever the Permittee seeks to change the ownership or operational control of the source and no other change in the permit is necessary.

(b) Any application requesting a change in the ownership or operational control of the source shall contain a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new Permittee. The application shall be submitted to:

Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

The application which shall be submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

(c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-7-11(c)(3)]

B.24 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-7-5(7)] [326 IAC 2-1.1-7]

(a) The Permittee shall pay annual fees to IDEM, OAQ within thirty (30) calendar days of receipt of a billing. Pursuant to 326 IAC 2-7-19(b), if the Permittee does not receive a bill from IDEM, OAQ the applicable fee is due April 1 of each year.

(b) Except as provided in 326 IAC 2-7-19(e), failure to pay may result in administrative enforcement action or revocation of this permit.

(c) The Permittee may call the following telephone numbers: 1-800-451-6027 or 317-233-4230 (ask for OAQ, Billing, Licensing, and Training Section), to determine the appropriate permit fee.

B.25 Credible Evidence [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [62 FR 8314] [326 IAC 1-1-6]

For the purpose of submitting compliance certifications or establishing whether or not the Permittee has violated or is in violation of any condition of this permit, nothing in this permit shall preclude the use, including the exclusive use, of any credible evidence or information relevant to whether the Permittee would have been in compliance with the condition of this permit if the appropriate performance or compliance test or procedure had been performed.

SECTION C SOURCE OPERATION CONDITIONS

Entire Source

Emission Limitations and Standards [326 IAC 2-7-5(1)]

C.1 Particulate Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2(e)(2), particulate emissions from any process not exempt under 326 IAC 6-3-1(b) or (c) which has a maximum process weight rate less than 100 pounds per hour and the methods in 326 IAC 6-3-2(b) through (d) do not apply shall not exceed 0.551 pounds per hour.

C.2 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

(a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.

(b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

C.3 Open Burning [326 IAC 4-1] [IC 13-17-9]

The Permittee shall not open burn any material except as provided in 326 IAC 4-1-3, 326 IAC 4-1-4 or 326 IAC 4-1-6. The previous sentence notwithstanding, the Permittee may open burn in accordance with an open burning approval issued by the Commissioner under 326 IAC 4-1-4.1.

C.4 Incineration [326 IAC 4-2] [326 IAC 9-1-2]

The Permittee shall not operate an incinerator or incinerate any waste or refuse except as provided in 326 IAC 4-2 and 326 IAC 9-1-2.

C.5 Fugitive Dust Emissions [326 IAC 6-4]

The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions). 326 IAC 6-4-2(4) is not federally enforceable.

C.6 Stack Height [326 IAC 1-7]

The Permittee shall comply with the applicable provisions of 326 IAC 1-7 (Stack Height Provisions), for all exhaust stacks through which a potential (before controls) of twenty-five (25) tons per year or more of particulate matter or sulfur dioxide is emitted by using ambient air quality modeling pursuant to 326 IAC 1-7-4. The provisions of 326 IAC 1-7-1(3), 326 IAC 1-7-2, 326 IAC 1-7-3(c) and (d), 326 IAC 1-7-4, and 326 IAC 1-7-5(a), (b), and (d) are not federally enforceable.

C.7 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

(a) Notification requirements apply to each owner or operator. If the combined amount of regulated asbestos containing material (RACM) to be stripped, removed or disturbed is at least 260 linear feet on pipes or 160 square feet on other facility components, or at least thirty-five (35) cubic feet on all facility components, then the notification requirements of 326 IAC 14-10-3 are mandatory. All demolition projects require notification whether or not asbestos is present.

(b) The Permittee shall ensure that a written notification is sent on a form provided by the Commissioner at least ten (10) working days before asbestos stripping or removal work or before demolition begins, per 326 IAC 14-10-3, and shall update such notice as necessary, including, but not limited to the following:

(1) When the amount of affected asbestos containing material increases or decreases by at least twenty percent (20%); or

(2) If there is a change in the following:

(A) Asbestos removal or demolition start date;

(B) Removal or demolition contractor; or

(C) Waste disposal site.

(c) The Permittee shall ensure that the notice is postmarked or delivered according to the guidelines set forth in 326 IAC 14-10-3(2).

(d) The notice to be submitted shall include the information enumerated in 326 IAC 14-10-3(3).

All required notifications shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

The notice shall include a signed certification from the owner or operator that the information provided in this notification is correct and that only Indiana licensed workers and project supervisors will be used to implement the asbestos removal project. The notifications do not require a certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

(e) Procedures for Asbestos Emission Control
The Permittee shall comply with the applicable emission control procedures in 326 IAC 14-10-4 and 40 CFR 61.145(c). Per 326 IAC 14-10-1, emission control requirements are applicable for any removal or disturbance of RACM greater than three (3) linear feet on pipes or three (3) square feet on any other facility components or a total of at least 0.75 cubic feet on all facility components.

(f) Demolition and Renovation
The Permittee shall thoroughly inspect the affected facility or part of the facility where the demolition or renovation will occur for the presence of asbestos pursuant to 40 CFR 61.145(a).

(g) Indiana Licensed Asbestos Inspector
The Permittee shall comply with 326 IAC 14-10-1(a) that requires the owner or operator, prior to a renovation/demolition, to use an Indiana Licensed Asbestos Inspector to thoroughly inspect the affected portion of the facility for the presence of asbestos. The requirement to use an Indiana Licensed Asbestos inspector is not federally enforceable.

Testing Requirements [326 IAC 2-7-6(1)]

C.8 Performance Testing [326 IAC 3-6]

(a) All testing shall be performed according to the provisions of 326 IAC 3-6 (Source Sampling Procedures), except as provided elsewhere in this permit, utilizing any applicable procedures and analysis methods specified in 40 CFR 51, 40 CFR 60, 40 CFR 61, 40 CFR 63, 40 CFR 75, or other procedures approved by IDEM, OAQ.

A test protocol, except as provided elsewhere in this permit, shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

no later than thirty-five (35) days prior to the intended test date. The protocol submitted by the Permittee does not require certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

(b) The Permittee shall notify IDEM, OAQ of the actual test date at least fourteen (14) days prior to the actual test date. The notification submitted by the Permittee does not require certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

(c) Pursuant to 326 IAC 3-6-4(b), all test reports must be received by IDEM, OAQ not later than forty-five (45) days after the completion of the testing. An extension may be granted by IDEM, OAQ if the Permittee submits to IDEM, OAQ a reasonable written explanation not later than five (5) days prior to the end of the initial forty-five (45) day period.

Compliance Requirements [326 IAC 2-1.1-11]

C.9 Compliance Requirements [326 IAC 2-1.1-11]

The commissioner may require stack testing, monitoring, or reporting at any time to assure compliance with all applicable requirements by issuing an order under 326 IAC 2-1.1-11. Any monitoring or testing shall be performed in accordance with 326 IAC 3 or other methods approved by the commissioner or the U. S. EPA.

Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]

C.10 Compliance Monitoring [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

Unless otherwise specified in this permit, all monitoring and record keeping requirements not already legally required shall be implemented within ninety (90) days of permit issuance or ninety (90) days of initial start-up, whichever is later. If required by Section D, the Permittee shall be responsible for installing any necessary equipment and initiating any required monitoring related to that equipment. If due to circumstances beyond its control, that equipment cannot be installed and operated within ninety (90) days, the Permittee may extend the compliance schedule related to the equipment for an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

in writing, prior to the end of the initial ninety (90) day compliance schedule, with full justification of the reasons for the inability to meet this date.

The notification which shall be submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

Unless otherwise specified in the approval for the new emission unit(s), compliance monitoring for new emission units or emission units added through a source modification shall be implemented when operation begins.

C.11 Maintenance of Continuous Opacity Monitoring Equipment [326 IAC 2-7-5(3)(A)(iii)]

(a) The Permittee shall install, calibrate, maintain, and operate all necessary continuous opacity monitoring systems (COMS) and related equipment. For a boiler, the COMS shall be in operation at all times that the induced draft fan is in operation.

(b) All COMS shall meet the performance specifications of 40 CFR 60, Appendix B, Performance Specification No. 1, and are subject to monitor system certification requirements pursuant to 326 IAC 3-5.

(c) In the event that a breakdown of a COMS occurs, a record shall be made of the times and reasons of the breakdown and efforts made to correct the problem.

(d) Whenever a COMS is malfunctioning or is down for maintenance or repairs for a period of twenty-four (24) hours or more and a backup COMS is not online within twenty-four (24) hours of shutdown or malfunction of the primary COMS, the Permittee shall provide a certified opacity reader, who may be an employee of the Permittee or an independent contractor, to self-monitor the emissions from the emission unit stack.

(1) Visible emission readings shall be performed in accordance with 40 CFR 60, Appendix A, Method 9, for a minimum of five (5) consecutive six (6) minute averaging periods beginning not more than twenty-four (24) hours after the start of the malfunction or down time.

(2) Method 9 opacity readings shall be repeated for a minimum of five (5) consecutive six (6) minute averaging periods at least twice per day during daylight operations, with at least four (4) hours between each set of readings, until a COMS is online.

(3) Method 9 readings may be discontinued once a COMS is online.

(4) Any opacity exceedances determined by Method 9 readings shall be reported with the Quarterly Opacity Exceedances Reports.

(e) Nothing in this permit shall excuse the Permittee from complying with the requirements to operate a continuous opacity monitoring system pursuant to 326 IAC 3-5, (and 40 CFR 60 and/or 40 CFR 63).

C.12 Monitoring Methods [326 IAC 3] [40 CFR 60] [40 CFR 63]

Any monitoring or testing required by Section D of this permit shall be performed according to the provisions of 326 IAC 3, 40 CFR 60, Appendix A, 40 CFR 60, Appendix B, 40 CFR 63, or other approved methods as specified in this permit.

C.13 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

(a) When required by any condition of this permit, an analog instrument used to measure a parameter related to the operation of an air pollution control device shall have a scale such that the expected maximum reading for the normal range shall be no less than twenty percent (20%) of full scale.

(b) The Permittee may request that the IDEM, OAQ approve the use of an instrument that does not meet the above specifications provided the Permittee can demonstrate that an alternative instrument specification will adequately ensure compliance with permit conditions requiring the measurement of the parameters.

Corrective Actions and Response Steps [326 IAC 2-7-5] [326 IAC 2-7-6]

C.14 Emergency Reduction Plans [326 IAC 1-5-2] [326 IAC 1-5-3]

Pursuant to 326 IAC 1-5-2 (Emergency Reduction Plans; Submission):

(a) The Permittee shall maintain the most recently submitted written emergency reduction plans (ERPs) consistent with safe operating procedures.

(b) Upon direct notification by IDEM, OAQ that a specific air pollution episode level is in effect, the Permittee shall immediately put into effect the actions stipulated in the approved ERP for the appropriate episode level. [326 IAC 1-5-3]

C.15 Risk Management Plan [326 IAC 2-7-5(12)] [40 CFR 68]

If a regulated substance, as defined in 40 CFR 68, is present at a source in more than a threshold quantity, the Permittee must comply with the applicable requirements of 40 CFR 68.

C.16 Response to Excursions or Exceedances [326 IAC 2-7-5] [326 IAC 2-7-6]

(a) Upon detecting an excursion or exceedance, the Permittee shall restore operation of the emissions unit (including any control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing emissions.

(b) The response shall include minimizing the period of any startup, shutdown or malfunction and taking any necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of an excursion or exceedance (other than those caused by excused startup or shutdown conditions). Corrective actions may include, but are not limited to, the following:

(1) initial inspection and evaluation;

(2) recording that operations returned to normal without operator action (such as through response by a computerized distribution control system); or

(3) any necessary follow-up actions to return operation to within the indicator range, designated condition, or below the applicable emission limitation or standard, as applicable.

(c) A determination of whether the Permittee has used acceptable procedures in response to an excursion or exceedance will be based on information available, which may include, but is not limited to, the following:

(1) monitoring results;

(2) review of operation and maintenance procedures and records; and/or

(3) inspection of the control device, associated capture system, and the process.

(d) Failure to take reasonable response steps shall be considered a deviation from the permit.

(e) The Permittee shall maintain the following records:

(1) monitoring data;

(2) monitor performance data, if applicable; and

(3) corrective actions taken.

C.17 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5] [326 IAC 2-7-6]

(a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this permit exceed the level specified in any condition of this permit, the Permittee shall take appropriate response actions. The Permittee shall submit a description of these response actions to IDEM, OAQ, within thirty (30) days of receipt of the test results. The Permittee shall take appropriate action to minimize excess emissions from the affected facility while the response actions are being implemented.

(b) A retest to demonstrate compliance shall be performed within one hundred twenty (120) days of receipt of the original test results. Should the Permittee demonstrate to IDEM, OAQ that retesting in one hundred twenty (120) days is not practicable, IDEM, OAQ may extend the retesting deadline.

(c) IDEM, OAQ reserves the authority to take any actions allowed under law in response to noncompliant stack tests.

The response action documents submitted pursuant to this condition do require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

C.18 Emission Statement [326 IAC 2-7-5(3)(C)(iii)] [326 IAC 2-7-5(7)] [326 IAC 2-7-19(c)] [326 IAC 2-6]

(a) Pursuant to 326 IAC 2-6-3(a)(1), the Permittee shall submit by July 1 of each year an emission statement covering the previous calendar year. The emission statement shall contain, at a minimum, the information specified in 326 IAC 2-6-4(c) and shall meet the following requirements:

(1) Indicate estimated actual emissions of all pollutants listed in 326 IAC 2-6-4(a);

(2) Indicate estimated actual emissions of regulated pollutants as defined by 326 IAC 2-7-1(32) (“Regulated pollutant, which is used only for purposes of Section 19 of this rule”) from the source, for purpose of fee assessment.

The statement must be submitted to:

Indiana Department of Environmental Management
Technical Support and Modeling Section, Office of Air Quality
100 North Senate Avenue

MC 61-50 IGCN 1003
Indianapolis, Indiana 46204-2251

The emission statement does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

(b) The emission statement required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.

C.19 General Record Keeping Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [326 IAC 2-2] [326 IAC 2-3]

(a) Records of all required monitoring data, reports and support information required by this permit shall be retained for a period of at least five (5) years from the date of monitoring sample, measurement, report, or application. These records shall be physically present or electronically accessible at the source location for a minimum of three (3) years. The records may be stored elsewhere for the remaining two (2) years as long as they are available upon request. If the Commissioner makes a request for records to the Permittee, the Permittee shall furnish the records to the Commissioner within a reasonable time.

(b) Unless otherwise specified in this permit, all record keeping requirements not already legally required shall be implemented within ninety (90) days of permit issuance or ninety (90) days of initial start-up, whichever is later.

(c) If there is a reasonable possibility (as defined in 40 CFR 51.165(a)(6)(vi)(A), 40 CFR 51.165(a)(6)(vi)(B), 40 CFR 51.166(r)(6)(vi)(a), and/or 40 CFR 51.166(r)(6)(vi)(b)) that a "project" (as defined in 326 IAC 2-2-1(qq) and/or 326 IAC 2-3-1(ll)) at an existing emissions unit, other than projects at a source with a Plantwide Applicability Limitation (PAL), which is not part of a "major modification" (as defined in 326 IAC 2-2-1(ee) and/or 326 IAC 2-3-1(z)) may result in significant emissions increase and the Permittee elects to utilize the "projected actual emissions" (as defined in 326 IAC 2-2-1(rr) and/or 326 IAC 2-3-1(mm)), the Permittee shall comply with following:

(1) Before beginning actual construction of the "project" (as defined in 326 IAC 2-2-1(qq) and/or 326 IAC 2-3-1(ll)) at an existing emissions unit, document and maintain the following records:

(A) A description of the project.

(B) Identification of any emissions unit whose emissions of a regulated new source review pollutant could be affected by the project.

(C) A description of the applicability test used to determine that the project is not a major modification for any regulated NSR pollutant, including:

(i) Baseline actual emissions;

(ii) Projected actual emissions;

(iii) Amount of emissions excluded under section 326 IAC 2-2-1(rr)(2)(A)(iii) and/or 326 IAC 2-3-1 (mm)(2)(A)(iii); and

(iv) An explanation for why the amount was excluded, and any netting calculations, if applicable.

(d) If there is a reasonable possibility (as defined in 40 CFR 51.165(a)(6)(vi)(A) and/or 40 CFR 51.166(r)(6)(vi)(a)) that a "project" (as defined in 326 IAC 2-2-1(qq) and/or 326 IAC 2-3-1(ll)) at an existing emissions unit, other than projects at a source with a Plantwide Applicability Limitation (PAL), which is not part of a "major modification" (as defined in 326 IAC 2-2-1(ee) and/or 326 IAC 2-3-1(z)) may result in significant emissions increase and the Permittee elects to utilize the "projected actual emissions" (as defined in 326 IAC 2-2-1(rr) and/or 326 IAC 2-3-1(mm)), the Permittee shall comply with following:

(1) Monitor the emissions of any regulated NSR pollutant that could increase as a result of the project and that is emitted by any existing emissions unit identified in (1)(B) above; and

(2) Calculate and maintain a record of the annual emissions, in tons per year on a calendar year basis, for a period of five (5) years following resumption of regular operations after the change, or for a period of ten (10) years following resumption of regular operations after the change if the project increases the design capacity of or the potential to emit that regulated NSR pollutant at the emissions unit.

C.20 General Reporting Requirements [326 IAC 2-7-5(3)(C)] [326 IAC 2-1.1-11] [326 IAC 2-2]

(a) The Permittee shall submit the attached Quarterly Deviation and Compliance Monitoring Report or its equivalent. Any deviation from permit requirements, the date(s) of each deviation, the cause of the deviation, and the response steps taken must be reported. This report shall be submitted within thirty (30) days of the end of the reporting period. The Quarterly Deviation and Compliance Monitoring Report shall include the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

(b) The report required in (a) of this condition and reports required by conditions in Section D of this permit shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

(c) Unless otherwise specified in this permit, any notice, report, or other submission required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.

(d) Unless otherwise specified in this permit, all reports required in Section D of this permit shall be submitted within thirty (30) days of the end of the reporting period. All reports do require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

(e) Reporting periods are based on calendar years, unless otherwise specified in this permit. For the purpose of this permit "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.

(f) If the Permittee is required to comply with the recordkeeping provisions of (d) in Section C - General Record Keeping Requirements for any "project" (as defined in 326 IAC 2-2-1 (qq) and/or 326 IAC 2-3-1 (ll)) at an existing emissions unit, and the project meets the following criteria, then the Permittee shall submit a report to IDEM, OAQ:

(1) The annual emissions, in tons per year, from the project identified in (c)(1) in Section C- General Record Keeping Requirements exceed the baseline actual emissions, as documented and maintained under Section C- General Record Keeping Requirements (c)(1)(C)(i), by a significant amount, as defined in 326 IAC 2-2-1 (xx) and/or 326 IAC 2-3-1 (qq), for that regulated NSR pollutant, and

(2) The emissions differ from the preconstruction projection as documented and maintained under Section C - General Record Keeping Requirements (c)(1)(C)(ii).

(g) The report for project at an existing emissions unit shall be submitted within sixty (60) days after the end of the year and contain the following:

(1) The name, address, and telephone number of the major stationary source.

(2) The annual emissions calculated in accordance with (d)(1) and (2) in Section C - General Record Keeping Requirements.

(3) The emissions calculated under the actual-to-projected actual test stated in 326 IAC 2-2-2(d)(3) and/or 326 IAC 2-3-2(c)(3).

(4) Any other information that the Permittee deems fit to include in this report.

Reports required in this part shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

(h) The Permittee shall make the information required to be documented and maintained in accordance with (c) in Section C- General Record Keeping Requirements available for review upon a request for inspection by IDEM, OAQ. The general public may request this information from the IDEM, OAQ under 326 IAC 17.1.

Stratospheric Ozone Protection

C.21 Compliance with 40 CFR 82 and 326 IAC 22-1

Pursuant to 40 CFR 82 (Protection of Stratospheric Ozone), Subpart F, except as provided for motor vehicle air conditioners in Subpart B, the Permittee shall comply with the standards for recycling and emissions reduction:

(a) Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to 40 CFR 82.156.

(b) Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to 40 CFR 82.158.

(c) Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161.

SECTION D.1 EMISSIONS UNIT OPERATION CONDITIONS

Emissions Unit Description:

(a) One (1) natural gas, low-sulfur No. 1 or No. 2 fuel oil fired boiler, identified as EU-07, permitted in 2007, including a mud drum heat exchanger, with a maximum design capacity of 217 MMBtu per hour when combusting natural gas and 208 MMBtu per hour when combusting fuel oil, and equipped with low NOx burners and induced flue gas recirculation for NOx control, with continuous monitors for monitoring carbon monoxide and NOx, exhausting to stack 002. Under 40 CFR 60, Subpart Db, this is a new affected source.

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.1.1 PSD Minor Limit [326 IAC 2-2]

In order to render 326 IAC 2-2 not applicable, Boiler EU-07 shall be limited as follows:

(a) Fuel Oil Usage Limit
The input of No. 1 and No. 2 fuel to the new boiler shall be limited to less than 329,000 gallons per twelve (12) consecutive month period, with compliance determined at the end of each month.

(b) SO_2
The sulfur content in the No. 1 or No. 2 fuel oil used in Boiler EU-07 shall not exceed 0.1 percent.

(c) The emissions of PM_{10} while burning No. 1 or No. 2 fuel oil shall not exceed 3.3 pounds per 1,000 gallons of No. 1 or No. 2 fuel oil burned.

(d) NOx
The emissions of NOx while burning natural gas shall not exeed 36.72 lb/MMCF. The emissions of NOx while burning No. 1 or No. 2 fuel oil shall not exceed 12.51 lb/Kgal.

Compliance with these limits and Condition D.5.1 will limit SO_2 emissions to less than 40 tons per year, PM emissions to less than 25 tons per year, PM_{10} emissions to less than 15 tons per year, and NOx emissions to less than 40 tons per year from the modification and will render the requirements of 326 IAC 2-2 (PSD) not applicable to the modification, permitted under SSM 105-24626-00005, for EU-07 and MSB 1.

D.1.2 Sulfur Dioxide (SO_2) [326 IAC 7-1.1]

Pursuant to 326 IAC 7-1.1-2, sulfur dioxide emissions shall not exceed 0.5 pounds per million British thermal units (lb/MMBtu) of heat input from boiler EU-07 when combusting No. 1 or No. 2 fuel oil.

D.1.3 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

A Preventive Maintenance Plan (PMP), in accordance with Section B, Preventive Maintenance Plan, of this permit, is required for these facilities and its control devices.

Compliance Determination Requirements

D.1.4 Sulfur Dioxide Emissions and Sulfur Content

Compliance with Condition D.1.1(c) and D.1.2 shall be determined utilizing one of the following options:

(a) Pursuant to 326 IAC 3-7-4, the Permittee shall demonstrate that the sulfur dioxide emissions do not exceed five-tenths (0.5) pounds per million Btu heat input for distillate oil combustion or does not exceed a sulfur content of 0.1 percent by:

(1) Providing vendor analysis of fuel delivered, if accompanied by a vendor certification; or

(2) Analyzing the oil sample to determine the sulfur content of the oil via the procedures in 40 CFR 60, Appendix A, Method 19.

(A) Oil samples may be collected from the fuel tank immediately after the fuel tank is filled and before any oil is combusted; and

(B) If a partially empty fuel tank is refilled, a new sample and analysis would be required upon filling.

(b) Compliance may also be determined by conducting a stack test for sulfur dioxide emissions from boiler EU-07, using 40 CFR 60, Appendix A, Method 6 in accordance with the procedures in 326 IAC 3-6.

A determination of noncompliance pursuant to any of the methods specified in (a) or (b) above shall not be refuted by evidence of compliance pursuant to the other method.

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.1.5 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

(a) Visible emission (VE) notations of stack exhaust 002 shall be performed once per day during normal daylight operations while boiler EU-07 combusts fuel oil. A trained employee shall record whether emissions are normal or abnormal.

(b) If abnormal emissions are observed at exhaust 002 while boiler EU-07 combusts fuel oil, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. Observation of abnormal emissions that do not violate an applicable opacity limit is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances, shall be considered a deviation from this permit.

(c) “Normal” means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.

(d) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for the boilers.

D.1.6 Maintenance of Continuous Emission Monitoring Equipment [326 IAC 2-7-5(3)(A)(iii)]

(a) The Permittee shall install, calibrate, maintain, and operate all necessary continuous emission monitoring systems (CEMS) and related equipment.

(b) In the event that a breakdown of a continuous emission monitoring system occurs, a record shall be made of the times and reasons of the breakdown and efforts made to correct the problem.

(c) Nothing in this permit shall excuse the Permittee from complying with the requirements to operate a continuous emission monitoring system pursuant to 326 IAC 3-5, 40 CFR 60, 40 CFR 63 or 40 CFR 75.

Recordkeeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.1.7 Record Keeping Requirements

(a) To document compliance with Condition D.1.1, the Permittee shall maintain records of monthly fuel usage for natural gas, No. 1 and No. 2 fuel oil combusted in the boiler.

(b) To document compliance with Conditions D.1.1, D.1.2, and D.1.4, the Permittee shall maintain records in accordance with (1) through (7) below.

(1) Calendar dates covered in the compliance determination period;

(2) No. 1 and No. 2 fuel oil usage and natural gas usage since last compliance determination period and NOx and SO_2 emissions.

(3) A certification, signed by the owner or operator, that the records of the fuel supplier certifications represent all of the fuel combusted during the period, the natural gas fired boiler certification does require the certification by the "Responsible Official" as defined by 326 IAC 2-7-1(34); and

(4) All fuel sampling and analysis data, pursuant to 326 IAC 7-2, and data collected in accordance with Condition D.1.4.

If the fuel supplier certification is used to demonstrate compliance the following, as a minimum, shall be maintained:

(5) Fuel supplier certifications.

(6) The name of the fuel supplier; and

(7) A statement from the fuel supplier that certifies the sulfur content of the fuel oil.

The Permittee shall retain records of all recording/monitoring data and support information for a period of five (5) years, or longer if specified elsewhere in this permit, from the date of the monitoring sample, measurement, or report. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit.

(c) To document compliance with Condition D.1.1(d), the Permittee shall maintain records of the emission rates of NOx in pounds per MMCF and pounds per Kgal based on CEMS data.

(d) To document compliance with Condition D.1.5, the Permittee shall maintain records of daily visible emission notations of the stack 002 exhaust, during times when fuels other than natural gas are combusted. The Permittee shall include in its daily record when a visible emission notation is not taken and the reason for the lack of a visible emission notation (e.g. the process did not operate that day).

(e) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

D.1.8 Reporting Requirements

A quarterly summary of the information to document compliance with Condition D.1.1(a) shall be submitted to the address listed in Section C - General Reporting Requirements, using the reporting forms located at the end of this permit, or their equivalent, within thirty (30) days after the end of the quarter being reported. The report submitted by the Permittee does require the certification by the “responsible official” as defined by 326 IAC 2-7-1(34).

SECTION D.2 **FACILITY OPERATION CONDITIONS**

Facility Description [326 IAC 2-7-5(15)]:

(b) Two (2) coal, natural gas, No. 1 or No. 2 fuel oil fired boilers, identified as EU-03 and EU-04, both constructed in 1959, with economizers replaced in 2010, with a maximum design capacity of 125 MMBtu per hour heat input each (operating at a maximum capacity of 100 MMBtu per hour heat input each when combusting coal or a combination of fuels), and with a maximum design capacity of 80 MMBtu per hour heat input each when combusting natural gas and/or fuel oil, each equipped with low NOx burners for natural gas and/or fuel oil, and each with a multiclone and a jet pulse baghouse, identified as Boiler 3 Bag and Boiler 4 Bag including a bag leak detection system, for particulate control, permitted in 2008, when combusting coal and/or fuel oil, both exhausting at stack 002. In addition, the stack exhaust from boilers EU-03 and EU-04 can be treated by an activated carbon injection system for mercury control and a lime injection system for hydrogen chloride control.

(c) One (1) natural gas, No. 1 or No. 2 fuel oil fired boiler, identified as EU-05, constructed in 1964 and modified in 1989, with a maximum design capacity of 190 MMBtu per hour heat input, equipped with low NOx burners (two natural gas fired burners at 75 MMBtu per hour heat input each) for natural gas and/or fuel oil, and a multiclone for particulate control when combusting fuel oil, exhausting to stack 002 or 003.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.2.1 Particulate Matter Limitation (PM) [326 IAC 6-2-3]

Pursuant to 326 IAC 6-2-3(b)(Particulate emission limitations for sources of indirect heating: emission limitations for facilities specified in 326 IAC 6-2-1(c)), the PM emissions from EU-03, EU-04, and EU-05, shall not exceed 0.38 pounds of particulate matter per million British thermal units heat input each. This limitation is based on the following equation:

$$P_t = \frac{(C * a * h)}{(76.5 * Q^{0.75} * N^{0.25})}$$

where: P_t - PM limit in pounds per MMBtu
C - Maximum ground level concentration
a - Plume rise factor
h - Stack height in feet
Q - total source permitted capacity in MMBtu/hr
= 740 MMBtu/hr for EU-03, EU-04 & EU-05
N - Number of stacks

D.2.2 Sulfur Dioxide (SO_2) [326 IAC 7-1.1]

(a) Pursuant to 326 IAC 7-1.1-2, sulfur dioxide emissions from each boiler, EU-03 and EU-04, shall not exceed 6.0 pounds per million British thermal units (lb/MMBtu) of heat input when combusting coal, and when combusting coal and oil simultaneously, and 0.5 pounds per million British thermal units (lb/MMBtu) of heat input when combusting No. 1 or No. 2 fuel oil.

(b) Pursuant to 326 IAC 7-1.1-2, sulfur dioxide emissions shall not exceed 0.5 pounds per million British thermal units (lb/MMBtu) of heat input from boiler EU-05 when combusting No. 1 or No. 2 fuel oil.

D.2.3 Heat Input Capacity Limitations

Pursuant to 1265 Exemption Qualification 105-8180, issued February 24, 1997, the total heat input to boilers EU-03 and EU-04 when burning coal, natural gas, No. 1 fuel oil or No. 2 fuel oil, or any combination of these three fuels shall not exceed 100 million British thermal units per hour for each boiler.

D.2.4 PSD Minor Limit [326 IAC 2-2]

(a) The total input of natural gas to boiler EU-05 shall be less than 870 MMCF per twelve consecutive month period, rolled on a monthly basis. For purposes of determining compliance, every 3.84 kilo-gallons of No. 1 or No. 2 fuel oil combusted shall be equivalent to 1 MMCF of natural gas based on NOx emissions and 0.08% sulfur content of No. 1 fuel oil and 0.49% sulfur content of No. 2 fuel oil. The amount of natural gas and natural gas equivalents used shall be determined as follows:

Amount of natural gas and natural gas equivalents used = ((EU-05 No. 1 fuel oil usage in kgal/yr)/(3.84 kgal/MMCF)) + ((EU-05 No. 2 fuel oil usage in kgal/yr)/(3.84 kgal/MMCF)) + (EU-05 natural gas usage in MMCF/yr)

(b) The total input of No. 2 fuel oil to boiler EU-05 shall be less than 1,120 kgals per twelve consecutive month period, rolled on a monthly basis. For purposes of determining compliance, every kilo-gallon of No. 1 fuel oil combusted shall be equivalent to 5.89 kgal of No. 2 fuel oil based on SO_2 emissions and 0.08% sulfur content of No. 1 fuel oil and 0.49% sulfur content of No. 2 fuel oil, and every MMCF of natural gas burned shall be equivalent to 0.009 kgal of No. 2 fuel oil based on SO_2 emissions and 0.49% sulfur content of No. 2 fuel oil. The amount of No. 2 fuel oil and No. 2 fuel oil equivalents used shall be determined as follows:

Amount of No. 2 fuel oil and No. 2 fuel oil equivalents used = (EU-05 No. 1 fuel oil usage in kgal/yr * 5.89 kgal of No. 2 fuel oil/kgal of No. 1 fuel oil) + (EU-05 No. 2 fuel oil usage in kgal/yr) + (EU-05 natural gas usage in MMCF/yr * 0.009 kgal No. 2 fuel oil/MMCF natural gas)

Compliance with the above limits NOx and SO_2 to less than 40 tons per twelve consecutive month period with compliance determined at the end of each month and renders 326 IAC 2-2 not applicable to the 1989 modification of EU-05.

D.2.5 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

A Preventive Maintenance Plan (PMP), in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for these facilities and its control devices.

Compliance Determination Requirements

D.2.6 Testing Requirements [326 IAC 2-7-6(1),(6)] [326 IAC 2-1.1-11]

In order to determine compliance with condition D.2.1, the Permittee shall perform PM testing for the coal-fired boilers, identified as EU-03 and EU-04, utilizing methods as approved by the Commissioner.

These tests shall be repeated at least once every five (5) calendar years following this valid compliance demonstration. Testing shall be conducted in accordance with Section C - Performance Testing.

D.2.7 Particulate Control [326 IAC 2-7-6(6)] [40 CFR 64]

Except as otherwise provided by statute or rule, or in this permit;

(a) The multiclones for particulate control shall be in operation at all times when boilers EU-03 and EU-04 are combusting coal.

(b) The baghouses for particulate control shall be in operation at all times (except periods of boiler statup) boilers EU-03 and/or EU-04 are in operation and combusting coal.

(c) In the event that bag failure is observed in a multi-compartment baghouse, if operations will continue for ten (10) days or more after the failure is observed before the failed units will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed units will be repaired or replaced. The notification shall also include the status of the applicable compliance monitoring parameters with respect to normal, and the results of any response actions taken up to the time of notification.

D.2.8 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3-7] [326 IAC 7-2] [326 IAC 7-1.1-2]

(a) Pursuant to 326 IAC 7-2-1(c), the Permittee shall demonstrate that the sulfur dioxide emissions do not exceed six (6.0) pounds per MMBtu using a calendar month average when EU-03 and EU-04 are combusting coal, or coal in combination with another fuel.

(b) Pursuant to 326 IAC 7-2-1(e) and 326 IAC 3-7, coal sampling and analysis data shall be collected as follows:

(1) Coal sampling shall be performed using the methods specified in 326 IAC 3-7-2(a), and sample preparation and analysis shall be performed as specified in 326 IAC 3-7-2(c), (d), and (e); or

(2) Pursuant to 326 IAC 3-7-2(b)(2) and 326 IAC 3-7-3, manual or other non-ASTM automatic sampling and analysis procedures may be used upon a demonstration, submitted to the department for approval, that such procedures provide sulfur dioxide emission estimates representative either of estimates based on coal sampling and analysis procedures specified in 326 IAC 3-7-2 or of continuous emissions monitoring; or

(3) The Permittee shall meet the minimum sampling requirements specified in 326 IAC 3-7-2(b)(3), and sample preparation and analysis shall be performed as specified in 326 IAC 3-7-2(c), (d), and (e).

(c) Upon written notification to IDEM by a facility owner or operator, continuous emission monitoring data collected and reported pursuant to 326 IAC 3-5 may be used as the means for determining compliance with the emission limitations in 326 IAC 7. Upon such notification, the other requirements of 326 IAC 7-2 shall not apply. [326 IAC 7-2-1(g)]

D.2.9 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3-7] [326 IAC 7-2] [326 IAC 7-1.1-2]

When EU-03, EU-04, and EU-05 are combusting fuel oil, or fuel oil in combination with natural gas, compliance shall be determined utilizing one of the following options:

(a) Pursuant to 326 IAC 3-7-4, 326 IAC 7-2, and 326 IAC 7-1.1-2, the Permittee shall demonstrate that the sulfur dioxide do not exceed the equivalent of 0.5 pounds per MMBtu, using a calendar month average.

(b) Pursuant to 326 IAC 7-2-1(e) and 326 IAC 3-7-4, fuel sampling and analysis data shall be collected as follows:

(1) The Permittee may rely upon vendor analysis of fuel delivered, if accompanied by a vendor certification [326 IAC 3-7-4(b)]; or,

(2) The Permittee shall perform sampling and analysis of fuel oil samples in accordance with 326 IAC 3-7-4(a).

(A) Oil samples shall be collected from the tanker truck load prior to transferring fuel to the storage tank; or

(B) Oil samples shall be collected from the storage tank immediately after each addition of fuel to the tank.

(c) Upon written notification to IDEM by a facility owner or operator, continuous emission monitoring data collected and reported pursuant to 326 IAC 3-5 may be used as the means for determining compliance with the emission limitations in 326 IAC 7. Upon such notification, the other requirements of 326 IAC 7-2 shall not apply. [326 IAC 7-2-1(g)]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.2.10 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)] [40 CFR 64]

(a) Visible emission (VE) notations of stack exhaust 002 shall be performed once per day during normal daylight operations while boilers EU-03 and EU-04 combust coal and/or fuel oil and the Bag Leak Detection System (BLDS) is not in operation. A trained employee shall record whether emissions are normal or abnormal.

(b) Visible emission (VE) notations of stack exhaust of EU-05 shall be performed once per day during normal daylight operations while boiler EU-05 combusts fuel oil. A trained employee shall record whether emissions are normal or abnormal.

(c) If abnormal emissions are observed at exhaust 002 while boilers EU-03 and EU-04 combust coal and/or fuel oil, or while EU-05 combusts fuel oil, or if abnormal emissions are observed at exhaust 003 while EU-05 combusts fuel oil after EU-05 begins exhausting to exhaust 003, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. Observation of abnormal emissions that do not violate an applicable opacity limit is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances, shall be considered a deviation from this permit.

(d) "Normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.

(e) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for the boilers.

D.2.11 Bag Leak Detection System (BLDS) [40 CFR 64]

(a) The Permittee shall operate a continuous bag leak detection system (BLDS) for both pulse jet fabric filter baghouses, identified as Boiler 3 Bag and Boiler 4 Bag. The bag leak detection system shall meet the following requirements:

(i) The Permittee must operate a bag leak detection system for each exhaust stack of the fabric filter.

(ii) The bag leak detection system must be installed, operated, calibrated, and maintained in a manner consistent with the manufacturer's written specifications and recommendations and in accordance with the guidance provided in EPA–454/R–98–015, September 1997.

(iii) The bag leak detection system shall be capable of detecting particulate matter emissions at concentrations of 10 milligrams per actual cubic meter or less.

(iv) The bag leak detection system sensor must provide output of relative or absolute particulate matter loadings.

(v) The bag leak detection system must be equipped with a device to continuously record the output signal from the sensor.

(vi) The bag leak detection system must be equipped with an alarm system that will sound automatically when an increase in relative particulate matter emissions over a preset level is detected. The alarm must be located where it is easily heard by plant operating personnel.

(vii) For positive pressure fabric filter systems that do not duct all compartments of cells to a common stack, a bag leak detection system must be installed in each baghouse compartment or cell.

(viii) Where multiple bag leak detectors are required, the system's instrumentation and alarm may be shared among detectors.

(b) If operations continue after bag failure is observed and it will be 10 days or more after the failure is observed before the failed units will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed units will be repaired or replaced. The notification shall also include the status of the applicable compliance monitoring parameters with respect to normal, and the results of any response actions taken up to the time of notification.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.2.12 Record Keeping Requirements

(a) To document compliance with Conditions D.2.2, D.2.9 and D.2.10, the Permittee shall maintain records in accordance with (1) through (4) below. Records maintained for (1) through (4) shall be taken monthly and shall be complete and sufficient to establish compliance with the SO_2 emission limits established in Condition D.2.2. Records necessary to demonstrate compliance shall be available within 30 days of the end of each compliance period.

(1) Calendar dates covered in the compliance determination period;

(2) Actual coal and fuel oil usage since last compliance determination period;

(3) Sulfur content and heat content;

(4) Sulfur dioxide emission rates.

(b) To document compliance with Section C - Opacity and Conditions D.2.1, D.2.7, D.2.8, and D.2.10, the Permittee shall maintain records in accordance with (1) through (3) below. Records shall be complete and sufficient to establish compliance with the limits established in Section C - Opacity, and in Condition D.2.1. Records necessary to demonstrate compliance shall be available within 30 days of the end of each compliance period.

(1) Data and results from the most recent stack tests;

(2) All parametric monitoring readings;

(3) Records of the dates and times of all bag leak detection system alarms, the cause of each alarm, and an explanation of all corrective actions taken.

(c) To document compliance with Conditions D.2.3, the Permittee shall maintain records of monthly average heat input (MMBtu per hour) for EU-03 and EU-04.

(d) To document compliance with Condition D.2.4, the Permittee shall maintain records of fuel usage for boiler EU-05.

(e) To document compliance with Condition D.2.10, the Permittee shall maintain records of daily visible emission notations of the boiler stack exhausts during operating conditions described in D.2.12. The Permittee shall include in its daily record when a visible emission notation is not taken and the reason for the lack of a visible emission notation (e.g. the process did not operate that day).

(f) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

D.2.13 Reporting Requirements

(a) A quarterly summary of the information to document compliance with Condition D.2.2 in any compliance period when coal or oil was combusted shall be submitted to the address listed in Section C - General Reporting Requirements, using the reporting forms located at the end of this permit, or their equivalent, within thirty (30) days after the end of the quarter being reported.

(b) A quarterly summary of the information to document compliance with Condition D.2.4 shall be submitted to the address listed in Section C - General Reporting Requirements, using the reporting forms located at the end of this permit, or their equivalent, within thirty (30) days after the end of the quarter being reported.

SECTION D.3 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]:

(d) One (1) coal, natural gas, No. 1 or No. 2 fuel oil fired boiler, identified as EU-06, constructed in 1970, with economizers replaced in 2010, with a maximum design capacity of 190 MMBtu per hour heat input when combusting coal and/or fuel oil, and 150 MMBtu per hour heat input (two natural gas fired burners rated at 75 MMBtu per hour heat input each) when combusting natural gas, equipped with low NOx burners for natural gas and/or fuel oil, a multiclone and a jet pulse baghouse, identified as Boiler 6 Bag including a bag leak detection system, for particulate control when combusting coal and/or fuel oil, permitted in 2008, and a continuous opacity monitor for monitoring opacity, exhausting to stack 003. In addition, the stack exhaust from boiler EU-06 can be treated by an activated carbon injection system for mercury control and a lime injection system for hydrogen chloride control.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.3.1 Particulate Matter Limitation (PM) [326 IAC 6-2-3]

Pursuant to 326 IAC 6-2-3(d) (Particulate emission limitations for sources of indirect heating: emission limitations for facilities specified in 326 IAC 6-2-1(b)), the PM emissions from EU-06 shall not exceed 0.38 pounds of particulate matter per million British thermal units heat input. This limitation is based on the following equation:

$$P_t = \frac{(C * a * h)}{(76.5 * Q^{0.75} * N^{0.25})}$$

where: P_t - PM limit in pounds per MMBtu
C - Maximum ground level concentration
a - Plume rise factor
h - Stack height in feet
Q - total source permitted capacity in MMBtu/hr
= 740 MMBtu/hr for EU-06
N - Number of stacks

D.3.2 Sulfur Dioxide (SO_2) [326 IAC 7-1.1]

(a) Pursuant to 326 IAC 7-1.1-2, sulfur dioxide emissions from boiler EU-06 shall not exceed 6.0 pounds per million British thermal units (lb/MMBtu) of heat input when combusting coal.

(b) Pursuant to 326 IAC 7-1.1-2, for facilities (EU-06) combusting coal and oil simultaneously, sulfur dioxide emissions shall not exceed six and zero-tenths (6.0) pounds per million British thermal units (lb/MMBtu) of heat input, and when EU-06 is combusting No. 1 or No. 2 fuel oil, solely, sulfur dioxide emissions shall not exceed 0.5 pounds per million British thermal units (lb/MMBtu) of heat input.

D.3.3 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

A Preventive Maintenance Plan (PMP), in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for these facilities and its control devices.

Compliance Determination Requirements

D.3.4 Testing Requirements [326 IAC 2-7-6(1),(6)] [326 IAC 2-1.1-11]

In order to determine compliance with the PM limitation, the Permittee shall perform PM testing for the coal-fired boiler, identified as EU-06, utilizing methods as approved by the Commissioner. This test shall be repeated at least once every five (5) calendar years following this valid compliance demonstration. Testing shall be conducted in accordance with Section C - Performance Testing.

D.3.5 Particulate and Opacity Control [326 IAC 2-7-6(6)] [40 CFR 64]

Except as otherwise provided by statute or rule, or in this permit;

(a) The multiclones for particulate control shall be in operation at all times when boiler EU-06 is in operation and EU-06 is combusting coal.

(b) The baghouses for particulate control shall be in operation at all times (except periods of boiler statup) boiler EU-06 is in operation and combusting coal.

(c) In the event that bag failure is observed in a multi-compartment baghouse, if operations will continue for ten (10) days or more after the failure is observed before the failed units will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed units will be repaired or replaced. The notification shall also include the status of the applicable compliance monitoring parameters with respect to normal, and the results of any response actions taken up to the time of notification.

(d) The ability of EU-06 Bag to control particulate emissions shall be monitored continuously, when boiler EU-06 is in operation and combusting coal, by measuring and recording the opacity of emissions with a certified continuous opacity monitor.

D.3.6 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3-7] [326 IAC 7-2] [326 IAC 7-1.1-2]

(a) Pursuant to 326 IAC 7-2-1(c), the Permittee shall demonstrate that the sulfur dioxide emissions do not exceed six (6.0) pounds per MMBtu using a calendar month average when EU-06 is combusting coal, or coal in combination with another fuel.

(b) Pursuant to 326 IAC 7-2-1(e) and 326 IAC 3-7, coal sampling and analysis data shall be collected as follows:

(1) Coal sampling shall be performed using the methods specified in 326 IAC 3-7-2(a), and sample preparation and analysis shall be performed as specified in 326 IAC 3-7-2(c), (d), and (e); or

(2) Pursuant to 326 IAC 3-7-2(b)(2) and 326 IAC 3-7-3, manual or other non-ASTM automatic sampling and analysis procedures may be used upon a demonstration, submitted to the department for approval, that such procedures provide sulfur dioxide emission estimates representative either of estimates based on coal sampling and analysis procedures specified in 326 IAC 3-7-2 or of continuous emissions monitoring; or

(3) The Permittee shall meet the minimum sampling requirements specified in 326 IAC 3-7-2(b)(3), and sample preparation and analysis shall be performed as specified in 326 IAC 3-7-2(c), (d), and (e).

(c) Upon written notification to IDEM by a facility owner or operator, continuous emission monitoring data collected and reported pursuant to 326 IAC 3-5 may be used as the means for determining compliance with the emission limitations in 326 IAC 7. Upon such notification, the other requirements of 326 IAC 7-2 shall not apply. [326 IAC 7-2-1(g)]

D.3.7 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3-7] [326 IAC 7-2] [326 IAC 7-1.1-2]

When EU-06 is combusting fuel oil, but not simultaneously with coal, compliance shall be determined utilizing one of the following options.

(a) Pursuant to 326 IAC 3-7-4, 326 IAC 7-2, and 326 IAC 7-1.1-2, the Permittee shall demonstrate that the sulfur dioxide do not exceed the equivalent of 0.5 pounds per MMBtu, demonstrated on a calendar month average.

(b) Pursuant to 326 IAC 7-2-1(e) and 326 IAC 3-7-4, fuel sampling and analysis data shall be collected as follows:

(1) The Permittee may rely upon vendor analysis of fuel delivered, if accompanied by a vendor certification [326 IAC 3-7-4(b)]; or,

(2) The Permittee shall perform sampling and analysis of fuel oil samples in accordance with 326 IAC 3-7-4(a).

(A) Oil samples shall be collected from the tanker truck load prior to transferring fuel to the storage tank; or

(B) Oil samples shall be collected from the storage tank immediately after each addition of fuel to the tank.

(c) Upon written notification to IDEM by a facility owner or operator, continuous emission monitoring data collected and reported pursuant to 326 IAC 3-5 may be used as the means for determining compliance with the emission limitations in 326 IAC 7. Upon such notification, the other requirements of 326 IAC 7-2 shall not apply. [326 IAC 7-2-1(g)]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.3.8 Bag Leak Detection System (BLDS) [40 CFR 64]

(a) After installation of the baghouse controlling emissions from boiler EU-06 is complete, the Permittee shall install and operate a continuous bag leak detection system (BLDS) for pulse jet fabric filter baghouse EU-06 Bag. The bag leak detection system shall meet the following requirements:

(i) The Permittee must install and operate a bag leak detection system for each exhaust stack of the fabric filter.

(ii) The bag leak detection system must be installed, operated, calibrated, and maintained in a manner consistent with the manufacturer's written specifications and recommendations and in accordance with the guidance provided in EPA–454/R–98–015, September 1997.

(iii) The bag leak detection system shall be capable of detecting particulate matter emissions at concentrations of 10 milligrams per actual cubic meter or less.

(iv) The bag leak detection system sensor must provide output of relative or absolute particulate matter loadings.

(v) The bag leak detection system must be equipped with a device to continuously record the output signal from the sensor.

(vi) The bag leak detection system must be equipped with an alarm system that will sound automatically when an increase in relative particulate matter emissions over a preset level is detected. The alarm must be located where it is easily heard by plant operating personnel.

(vii) For positive pressure fabric filter systems that do not duct all compartments of cells to a common stack, a bag leak detection system must be installed in each baghouse compartment or cell.

(viii) Where multiple bag leak detectors are required, the system's instrumentation and alarm may be shared among detectors.

(b) If operations continue after bag failure is observed and it will be 10 days or more after the failure is observed before the failed units will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed units will be repaired or replaced. The notification shall also include the status of the applicable compliance monitoring parameters with respect to normal, and the results of any response actions taken up to the time of notification.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.3.9 Record Keeping Requirements

(a) To document compliance with Condition D.3.2, the Permittee shall maintain records in accordance with (1) through (6) below. Records necessary to demonstrate compliance shall be available within 30 days of the end of each compliance period.

(1) Calendar dates covered in the compliance determination period;

(2) Actual fuel oil usage since last compliance determination period and equivalent sulfur dioxide and particulate matter emission rates;

(3) A certification, signed by the owner or operator, that the records of the fuel supplier certifications represent all of the fuel combusted during the period; and

If the fuel supplier certification is used to demonstrate compliance the following, as a minimum, shall be maintained:

(4) Fuel supplier certifications;

(5) The name of the fuel supplier; and

(6) A statement from the fuel supplier that certifies the sulfur content and heat content of the fuel oil.

The Permittee shall retain records of all recording/monitoring data and support information for a period of five (5) years, or longer if specified elsewhere in this permit, from the date of the monitoring sample, measurement, or report. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit.

(b) To document compliance with Condition D.3.2, the Permittee shall maintain records in accordance with (1) through (4) below. Records maintained for (1) through (4) shall be taken monthly and shall be complete and sufficient to establish compliance with the SO_2 emission limits established in D.3.2. Records necessary to demonstrate compliance shall be available within 30 days of the end of each compliance period.

(1) Calendar dates covered in the compliance determination period;

(2) Actual coal usage since last compliance determination period;

(3) Sulfur content, heat content;

(4) Sulfur dioxide emission rates.

(c) To document compliance with Section C - Opacity and Conditions D.3.1, D.3.4, D.3.5 and D.3.8, the Permittee shall maintain records in accordance with (1) through (3) below. Records shall be complete and sufficient to establish compliance with the limits established in Section C - Opacity, and in Condition D.3.1. Records necessary to demonstrate compliance shall be available within 30 days of the end of each compliance period.

(1) Data and results from the most recent stack test(s).

(2) All continuous monitoring data, pursuant to 326 IAC 3-5.

(3) Records of the dates and times of all bag leak detection system alarms, the cause of each alarm, and an explanation of all corrective actions taken.

(d) Pursuant to 326 IAC 3-7-5(a), the Permittee shall develop a standard operating procedure (SOP) to be followed for sampling, handling, analysis, quality control, quality assurance, and data reporting of the information collected pursuant to 326 IAC 3-7-2 through 326 IAC 3-7-4. In addition, any revision to the SOP shall be submitted to IDEM, OAQ.

(e) All records shall be maintained in accordance with Section C- General Record Keeping Requirements, of this permit.

D.3.10 Reporting Requirements

(a) A quarterly summary of the information to document compliance with Conditions D.3.2, D.3.6 and D.3.7 in any compliance period when coal, natural gas, or fuel oil was combusted shall be submitted to the address listed in Section C - General Reporting Requirements, using the reporting forms located at the end of this permit, or their equivalent, within thirty (30) days after the end of the quarter being reported. The report submitted by the Permittee does require the certification by the “responsible official” as defined by 326 IAC 2-7-1(34).

(b) Quarterly report of opacity exceedances shall be submitted to the address listed in Section C - General Reporting Requirements, of this permit, within thirty (30) days after the end of the quarter being reported. The report submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

SECTION D.4 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]:

(e) One (1) coal storage and handling system, with a maximum design throughput of 200 tons of coal per hour, consisting of the following:

(1) One (1) coal truck receiving system, consisting of an interior wet suppression system to control coal dust emissions during coal receiving, and two (2) truck hoppers.

(2) Four (4) enclosed belt conveyors, and one (1) enclosed bucket conveyor, with particulate emissions controlled by a fabric filter system, with four (4) dust collectors, identified as DC1 through 4, located internally at various points along the enclosed conveyor system, with all dust collectors exhausting internally.

(3) One (1) coal storage silo with a storage capacity of 1,000 tons of coal, with particulate emissions controlled by one (1) dust collector, identified as DC6, exhausting externally at vent 6.

(The information describing the process contained in this facility description box is descriptive and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.4.1 Particulate Matter (PM) [326 IAC 6-3]

Pursuant to 326 IAC 6-3 (Process Operations), the allowable PM emission rate from the coal storage and handling system shall not exceed 58.5 pounds per hour when operating at a process weight rate of 400,000 pounds per hour as established in the following formula:

Interpolation and extrapolation of the data for the process weight rate in excess of sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$E = 55.0\ P^{0.11} - 40$ where E = rate of emission in pounds per hour; and
P = process weight rate in tons per hour

Pursuant to 326 IAC 6-3-2(e)(3) (Particulate Emission Limitations for Manufacturing Processes), for any process weight rate greater than 200 tons per hour, the concentration of particulate in the discharge gases to the atmosphere shall be less than 0.10 pounds per one thousand (1,000) pounds of gases.

D.4.2 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

A Preventive Maintenance Plan (PMP), in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for these facilities and their control devices.

Compliance Determination Requirements

D.4.3 Particulate Matter (PM) [40 CFR 64]

(a) The coal truck receiving interior wet suppression system shall be in operation and control the PM emissions from the associated equipment at all times that the coal receiving system is in operation.

(b) The dust collectors (DC1 through DC4), all for PM control, shall be in operation and control the PM emissions from their associated equipment at all times that the coal storage and handling system is in operation.

(c) All equipment exhausting internally (DC1 through DC4) for the coal storage and handling system shall not exhaust to the atmosphere at any time the system is in operation.

(d) Dust collector DC6, for PM control, shall be in operation and control the PM emissions from the silo when it is receiving coal.

(e) In the event that bag failure is observed in a multi-compartment baghouse, if operations will continue for ten (10) days or more after the failure is observed before the failed units will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed units will be repaired or replaced. The notification shall also include the status of the applicable compliance monitoring parameters with respect to normal, and the results of any response actions taken up to the time of notification.

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.4.4 Baghouse Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

(a) The Permittee shall record the pressure drop across dust collectors DC-1, DC-2, DC-3, DC-4 and DC-6 used in conjunction with the coal transfer drop points at least once per week when coal is being transferred. When for any one reading, the pressure drop across the dust collectors is outside the normal range of 1.0 and 8.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps in accordance with Section C- Response to Excursions or Exceedances. A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances, shall be considered a deviation from this permit.

(b) The instrument used for determining the pressure shall comply with Section C - Instrument Specifications, of this permit, shall be subject to approval by IDEM, OAQ and shall be calibrated at least once every six (6) months.

D.4.5 Visible Emissions Notations [40 CFR 64]

(a) Once per week visible emission notations of the dust collector DC6 vent exhaust shall be performed during normal daylight operations, and when the silo is receiving coal. A trained employee shall record whether emissions are normal or abnormal.

(b) Once per week visible emission notations of the coal truck receiving system shall be performed during normal daylight operations when either of the two (2) truck hoppers are receiving coal. A trained employee shall record whether emissions are normal or abnormal.

(c) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.

(d) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.

(e) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.

(f) If any visible emissions of dust are observed from the coal storage and handling system, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. Observation of visible emissions that do not violate 326 IAC 6-4 (Fugitive Dust Emissions) or an applicable opacity limit is not a deviation from this permit.

(g) If abnormal emissions are observed from the coal storage and handling system, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. Observation of abnormal emissions that do not violate 326 IAC 6-4 (Fugitive Dust Emissions) or an applicable opacity limit is not a deviation from this permit.

(h) If abnormal emissions are observed, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances, shall be considered a deviation from this permit.

Record Keeping and Reporting Requirement [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.4.6 Record Keeping Requirements

(a) To document compliance with Condition D.4.4 the Permittee shall maintain weekly records of the pressure drop across each dust collector. The Permittee shall include in its weekly record when a pressure drop reading is not taken and the reason for the lack of a pressure drop reading, (i.e., the process did not operate that week).

(b) To document compliance with Condition D.4.5, the Permittee shall maintain records of visible emission notations of the dust collector vent for DC-6, and of the coal truck receiving system at each time when coal is being received by the silo and either of the truck hoppers, respectively. The Permittee shall include in its weekly record when a visible emission notation is not taken and the reason for the lack of visible emission notation (e.g. the process did not operate that day).

(c) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

SECTION D.5 FACILITY OPERATION CONDITIONS - Insignificant Operations

Facility Description [326 IAC 2-7-5(15)]: Insignificant Activities

(a) Natural gas-fired combustion sources with heat input equal to or less than ten (10) million Btu per hour [326 IAC 6-2]:

(1) Twenty-two (22) boilers constructed before 1972, with a combined total heat input of 29.130 MMBtu per hour.

(2) One (1) boiler constructed in 1977, with a heat input of 0.60 MMBtu per hour.

(3) One (1) boiler constructed in 1981, with a heat input of 0.110 MMBtu per hour.

(4) Sixty-six (66) boilers constructed after 1983, with a combined heat input of 145.25 MMBtu per hour. [326 IAC 6-2-4(a) and (b)]

(b) Degreasing operations that do not exceed 145 gallons per 12 months, except if subject to 326 IAC 20-6.

(c) Oil fired emergency generators not exceeding 1,600 horsepower:

(1) One (1) emergency generator, identified as MSB 1, permitted in 2007, rated at 1200 horsepower.

(d) Two (2) pneumatic ash handling legs, identified as Ash Leg #1 and Ash Leg #2, permitted in 2008, with a maximum throughput capacity of 0.71 tons of fly ash per hour, emissions are controlled by water spray [326 IAC 6-3-2].

(e) One (1) activated carbon injection system, constructed in 2008, consisting of one (1) activated carbon storage silo, with a maximum storage capacity of 52 tons and throughput of 1,200 lbs/hr, identified as Carbon Silo, controlled by a bin vent baghouse, identified as CS Bag, exhausting indoors to stack CS Vent [326 IAC 6-3-2].

(f) One (1) lime injection system, constructed in 2008, consisting of one (1) lime storage silo, with a maximum storage capacity of 25 tons and throughput of 30 lbs/hr, identified as Lime Silo, controlled by a bin vent baghouse, identified as LS Bag, exhausting indoors to stack LS Vent [326 IAC 6-3-2].

(The information describing the process contained in this facility description box is descriptive and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.5.1 PSD Minor Limits [326 IAC 2-2]

(a) The operating hours for the emergency generator MSB 1 shall not exceed 250 hours per twelve (12) consecutive month period with compliance determined at the end of each month.

(b) The emission of NOx shall not exceed 0.024 lb/hp-hr.

Compliance with these limits and condition D.1.2 will limit SO_2 emissions to less than 40 tons per year, PM_{10} emissions to less than 15 tons per year, and NOx emissions to less than 40 tons per year from the modification and will render the requirements of 326 IAC 2-2 (PSD) not applicable to this modification, permitted under SSM 105-24626-00005, for EU-07 and MSB 1.

D.5.2 Particulate Emission Limitations for Sources of Indirect Heating [326 IAC 6-2]

(a) Pursuant to 326 IAC 6-2-3 (Particulate Emission Limitations for Sources of Indirect Heating: Emission limitations for facilities specified in 326 IAC 6-2-1(c)), part (b), the emission limitations for those indirect heating facilities which were existing and in operation on or before June 8, 1972, shall not exceed the pound per million Btu heat input (lb/MMBtu) calculated using the following equation:

$$Pt = \frac{(C)\,(a)\,(h)}{76.5\ (Q^{0.75})\ (N^{0.25})}$$

Where C = 50 $\mu g/m^3$
Q = total source capacity (MMBtu/hr)
N = number of stacks
a = 0.67
h = average stack height (feet)

Pursuant to 326 IAC 6-2-3(b), the emission limitations for those indirect heating facilities which were existing and in operation on or before June 8, 1972, shall be calculated using the above equation where Q, N, and h include the parameters for all facilities in operation on June 8, 1972.

(b) Pursuant to 326 IAC 6-2-3(c), the emission limitations for those indirect heating facilities which began operation after June 8, 1972, and before September 21, 1983, shall be calculated using the above equation where Q, N, and h include the parameters for the facility in question and for those facilities which were previously constructed.

(c) Pursuant to 326 IAC 6-2-3(d), particulate emissions from all facilities used for indirect heating purposes which were existing and in operation on or before June 8, 1972, shall in no case exceed 0.8 lb/MMBtu heat input.

(d) Pursuant to 326 IAC 6-2-4 (Particulate Emission Limitations for Sources of Indirect Heating: Emission limitations for facilities specified in 326 IAC 6-2-1(d)), the PM emissions from indirect heating facilities constructed after September 21, 1983, shall not exceed the pound per million Btu heat input (lb/MMBtu) calculated using the following equation:

$$Pt = \frac{1.09}{Q^{0.26}}$$

Where Q = total source capacity (MMBtu/hr)

D.5.3 Particulate Emission Limitations for Manufacturing Processes (PM) [326 IAC 6-3]

Pursuant to 326 IAC 6-3-2, the particulate matter (PM) emissions from Ash Leg #1 and Ash Leg #2 shall not exceed 3.26 pound per hour each when operating at a process weight rate of 0.71 ton/hr.

The pound per hour limitation was calculated with the following equation:

$$E = 4.10\ P^{0.67}$$

where E = rate of emission in pounds per hour; and
P = process weight rate in tons per hour

D.5.4 Volatile Organic Compounds (VOC) [326 IAC 8-3-2]

Pursuant to 326 IAC 8-3-2 (Cold Cleaner Operations), the owner or operator shall:

(a) Equip the cleaner with a cover;

(b) Equip the cleaner with a facility for draining cleaned parts;

(c) Close the degreaser cover whenever parts are not being handled in the cleaner;

(d) Drain cleaned parts for at least fifteen (15) seconds or until dripping ceases;

(e) Provide a permanent, conspicuous label summarizing the operation requirements;

(f) Store waste solvent only in covered containers and not dispose of waste solvent or transfer it to another party, in such a manner that greater than twenty percent (20%) of the waste solvent (by weight) can evaporate into the atmosphere.

D.5.5 Volatile Organic Compounds (VOC) [326 IAC 8-3-5]

(a) Pursuant to 326 IAC 8-3-5(a) (Cold Cleaner Degreaser Operation and Control), the owner or operator of a cold cleaner degreaser facility shall ensure that the following control equipment requirements are met:

(1) Equip the degreaser with a cover. The cover must be designed so that it can be easily operated with one (1) hand if:

(A) The solvent volatility is greater than two (2) kiloPascals (fifteen (15) millimeters of mercury or three-tenths (0.3) pounds per square inch) measured at thirty-eight degrees Celsius (38°C) (one hundred degrees Fahrenheit (100°F));

(B) The solvent is agitated; or

(C) The solvent is heated.

(2) Equip the degreaser with a facility for draining cleaned articles. If the solvent volatility is greater than four and three-tenths (4.3) kiloPascals (thirty-two (32) millimeters of mercury or six-tenths (0.6) pounds per square inch) measured at thirty-eight degrees Celsius (38°C) (one hundred degrees Fahrenheit (100°F)), then the drainage facility must be internal such that articles are enclosed under the cover while draining. The drainage facility may be external for applications where an internal type cannot fit into the cleaning system.

(3) Provide a permanent, conspicuous label which lists the operating requirements outlined in subsection (b).

(4) The solvent spray, if used, must be a solid, fluid stream and shall be applied at a pressure which does not cause excessive splashing.

(5) Equip the degreaser with one (1) of the following control devices if the solvent volatility is greater than four and three-tenths (4.3) kiloPascals (thirty-two (32) millimeters of mercury or six-tenths (0.6) pounds per square inch) measured at thirty-eight degrees Celsius (38°C) (one hundred degrees Fahrenheit (100°F)), or if the solvent is heated to a temperature greater than forty-eight and nine-tenths degrees Celsius (48.9^{O}C) (one hundred twenty degrees Fahrenheit (120°F)):

(A) A freeboard that attains a freeboard ratio of seventy-five hundredths (0.75) or greater.

(B) A water cover when solvent is used is insoluble in, and heavier than, water.

(C) Other systems of demonstrated equivalent control such as a refrigerated chiller of carbon adsorption. Such systems shall be submitted to the U.S. EPA as a SIP revision.

(b) Pursuant to 326 IAC 8-3-5(b) (Cold Cleaner Degreaser Operation and Control), the owner or operator of a cold cleaning facility shall ensure that the following operating requirements are met:

(1) Close the cover whenever articles are not being handled in the degreaser.

(2) Drain cleaned articles for at least fifteen (15) seconds or until dripping ceases.

(3) Store waste solvent only in covered containers and prohibit the disposal or transfer of waste solvent in any manner in which greater than twenty percent (20%) of the waste solvent by weight could evaporate.

Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

D.5.6 Record Keeping Requirements

(a) To document compliance with Condition D.5.1, the Permittee shall maintain monthly records of the operating hours for the emergency generator MSB 1.

(b) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

D.5.7 Reporting Requirements

A quarterly summary of the information to document compliance with Condition D.5.1 shall be submitted to the address listed in Section C - General Reporting Requirements, using the reporting forms located at the end of this permit, or their equivalent, within thirty (30) days after the end of the quarter being reported. The report submitted by the Permittee does require the certification by the “responsible official” as defined by 326 IAC 2-7-1(34).

SECTION E.1 EMISSIONS UNIT OPERATION CONDITIONS

Emissions Unit Description:

(a) One (1) natural gas, low-sulfur No. 1 or No. 2 fuel oil fired boiler, identified as EU-07, permitted in 2007, with a maximum design capacity of 217 MMBtu per hour when combusting natural gas and 208 MMBtu per hour when combusting fuel oil, and equipped with low NOx burners and induced flue gas recirculation for NOx control, with continuous monitors for monitoring carbon monoxide and NOx, exhausting to stack 002. Under 40 CFR 60, Subpart Db, this is a new affected source.

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

E.1.1 General Provisions Relating to New Source Performance Standards (NSPS) [326 IAC 12-1] [40 CFR 60, Subpart A] [326 IAC 12]

The provisions of 40 CFR 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to EU-07 except when otherwise specified in 40 CFR 60, Subpart Db.

E.1.2 New Source Performance Standards (NSPS) [326 IAC 12] [40 CFR 60, Subpart Db] [326 IAC 12]

Pursuant to 40 CFR 60 Subpart Db, the Permittee shall comply with the provisions of 40 CFR 60 Subpart Db, which are incorporated as 326 IAC 12-1 for EU-07, as specified as follows:

(1) 40 CFR 60.40b(a) and (j)
(2) 40 CFR 60.41b
(3) 40 CFR 60.42b(e),(j) and (k)(1) and (2)
(4) 40 CFR 60.43b(f), (g), and (h)(5)
(5) 40 CFR 60.44b(a), (h), (i), (l)(1)
(6) 40 CFR 60.45b(j) and (k)
(7) 40 CFR 60.46b(a), (c), (e)(1) and (4), and (i)
(8) 40 CFR 60.47b(f) and (g)
(9) 40 CFR 60.48b(a), (b)(1), (c), (d), (e)(2) and (3), (f), and (j)
(10) 40 CFR 60.49b(a)(1), (2), and (3), (b), (d), (g)(1) through (g)(10), (h)(1) and (2), (i), (o), and (r)

SECTION E.2 EMISSIONS UNIT OPERATION CONDITIONS

Emissions Unit Description:

(i) Twelve (12) Diesel Emergency Generators:

(1) AHSB-1, 300 kW, installed in 2008
(2) FQHSB-1, 240 kW, installed in 2006
(3) HAPSB-1, 30 kW, installed in 2007
(4) HCSB-1, 750 kW, installed in 2008
(5) IUPD-1, 150 kW, installed in 2007
(6) JHSB-1, 155 kW, installed in 2007
(7) MHSB-1, 27 kW, installed in 2009
(8) SBSB-1, 40 kW, installed in 2007
(9) DCSB-1, 1500 kW, installed in 2009
(10) DCSB-2, 1500 kW, installed in 2009
(11) TQSB-1, 315 kW, installed in 2007
(12) SRSB-1, 101 kW, installed in 2007

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

E.2.1 General Provisions Relating to New Source Performance Standards (NSPS) [326 IAC 12-1] [40 CFR 60, Subpart A] [326 IAC 12]

The provisions of 40 CFR 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to Emergency generators AHSB-1, FQHSB-1, HAPSB-1, HCSB-1, IUPD-1, JHSB-1, MHSB-1, SBSB-1, DCSB-1, DCSB-2, TQSB-1 and SRSB-1 except when otherwise specified in 40 CFR 60, Subpart IIII.

E.2.2 New Source Performance Standards (NSPS) [326 IAC 12] [40 CFR 60, Subpart IIII] [326 IAC 12]

Pursuant to 40 CFR 60 Subpart IIII, the Permittee shall comply with the provisions of 40 CFR 60 Subpart IIII, which are incorporated as 326 IAC 12-1 for Emergency generators AHSB-1, FQHSB-1, HAPSB-1, HCSB-1, IUPD-1, JHSB-1, MHSB-1, SBSB-1, DCSB-1, DCSB-2, TQSB-1 and SRSB-1, as specified as follows:

(1) 40 CFR 60.4202(a)
(2) 40 CFR 60.4205(a)&(b)
(3) 40 CFR 60.4206
(4) 40 CFR 60.4207(a)
(5) 40 CFR 60.4209(a)&(b)
(6) 40 CFR 60.4211(a),(b),(d)(1)-(3)
(7) 40 CFR 60.4212(a)-(d)
(8) 40 CFR 60.4214(b)
(9) 40 CFR 60.4218

SECTION E.3 EMISSIONS UNIT OPERATION CONDITIONS

Emissions Unit Description:

(j) Twelve (12) Diesel Emergency Generators:

(1) AHSB-1, 300 kW, installed in 2008
(2) FQHSB-1, 240 kW, installed in 2006
(3) HAPSB-1, 30 kW, installed in 2007
(4) HCSB-1, 750 kW, installed in 2008
(5) IUPD-1, 150 kW, installed in 2007
(6) JHSB-1, 155 kW, installed in 2007
(7) MHSB-1, 27 kW, installed in 2009
(8) SBSB-1, 40 kW, installed in 2007
(9) DCSB-1, 1500 kW, installed in 2009
(10) DCSB-2, 1500 kW, installed in 2009
(11) TQSB-1, 315 kW, installed in 2007
(12) SRSB-1, 101 kW, installed in 2007

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

E.3.1 General Provisions Relating to National Emission Standards for Hazardous Air Pollutants (NESHAP) [326 IAC 20-82 [40 CFR 63, Subpart A]

The provisions of 40 CFR 63, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 20-82, apply to Emergency generators AHSB-1, FQHSB-1, HAPSB-1, HCSB-1, IUPD-1, JHSB-1, MHSB-1, SBSB-1, DCSB-1, DCSB-2, TQSB-1 and SRSB-1 except when otherwise specified in 40 CFR 63, Subpart ZZZZ.

E.3.2 Stationary Combustion Turbines NESHAP [326 IAC 20-82] [40 CFR 63, Subpart ZZZZ]

Pursuant to 40 CFR 63 Subpart ZZZZ, the Permittee shall comply with the provisions of 40 CFR 63 Subpart ZZZZ, which are incorporated as 326 IAC 20-82 for Emergency generators AHSB-1, FQHSB-1, HAPSB-1, HCSB-1, IUPD-1, JHSB-1, MHSB-1, SBSB-1, DCSB-1, DCSB-2, TQSB-1 and SRSB-1, as specified as follows:

(1) 40 CFR 63.6590(b)(1)(i)&(c)
40 CFR 63.6645(f)

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
PART 70 OPERATING PERMIT
CERTIFICATION

Source Name:	Indiana University
Source Address:	820 N. Walnut Grove Avenue, Bloomington, IN 47405
Mailing Address:	820 N. Walnut Grove Avenue, Bloomington, IN 47405,
Part 70 Permit No.:	T 105-28296-00005

This certification shall be included when submitting monitoring, testing reports/results or other documents as required by this permit.

Please check what document is being certified:

☐ Annual Compliance Certification Letter

☐ Test Result (specify)

☐ Report (specify)

☐ Notification (specify)

☐ Affidavit (specify)

☐ Other (specify)

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
Signature:
Printed Name:
Title/Position:
Phone:
Date:

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY

COMPLIANCE AND ENFORCEMENT BRANCH
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251
Phone: (317) 233-0178
Fax: (317) 233-6865

PART 70 OPERATING PERMIT
EMERGENCY OCCURRENCE REPORT

Source Name:	Indiana University
Source Address:	820 N. Walnut Grove Avenue, Bloomington, IN 47405
Mailing Address:	820 N. Walnut Grove Avenue, Bloomington, IN 47405,
Part 70 Permit No.:	T 105-28296-00005

This form consists of 2 pages **Page 1 of 2**

□ This is an emergency as defined in 326 IAC 2-7-1(12)

- The Permittee must notify the Office of Air Quality (OAQ), within four (**4**) daytime business hours (1-800-451-6027 or 317-233-0178, ask for Compliance Section); and
- The Permittee must submit notice in writing or by facsimile within two (**2**) working days (Facsimile Number: 317-233-6865), and follow the other requirements of 326 IAC 2-7-16.

If any of the following are not applicable, mark N/A

Facility/Equipment/Operation:
Control Equipment:
Permit Condition or Operation Limitation in Permit:
Description of the Emergency:
Describe the cause of the Emergency:

If any of the following are not applicable, mark N/A **Page 2 of 2**

Date/Time Emergency started:
Date/Time Emergency was corrected:
Was the facility being properly operated at the time of the emergency? Y N
Type of Pollutants Emitted: TSP, PM-10, SO_2, VOC, NO_X, CO, Pb, other:
Estimated amount of pollutant(s) emitted during emergency:
Describe the steps taken to mitigate the problem:
Describe the corrective actions/response steps taken:
Describe the measures taken to minimize emissions:
If applicable, describe the reasons why continued operation of the facilities are necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw materials of substantial economic value:

Form Completed by:_____

Title / Position: _____

Date:_____

Phone: _____

A certification is not required for this report.

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH

Part 70 Quarterly Report for Boilers EU-03 and EU-04

Source Name:	Indiana University
Source Address:	820 North Walnut Grove, Bloomington, Indiana 47405-2206
Mailing Address:	1514 East 3rd Street, Bloomington, Indiana 47405-2206
Permit No.:	T105-28296-00005
Facility:	Boilers EU-03 and EU-04
Parameter:	Heat input from all fuels used
Limit:	100 MMBtu per hour heat input to each boiler

QUARTER/YEAR: _____ MONTH: _____

Fuel Type	Amount of fuel burned this month	High heat value of fuel burned this month	Total heat input from fuel this month (MMBtu/mo)	Hours of boiler operation this month (hrs/mo)	Average monthly heat input from fuel this month (MMBtu/hr)
Boiler EU-03					
coal	_____ tons/mo	_____ MMBtu/ton			
natural gas	_____ MMCF/mo	1050 MMBtu/MMCF			
fuel oil	_____ gals/mo	0.139 MMBtu/gal			
Average monthly heat input from all fuels this month (MMBtu/hr)					
Boiler EU-04					
coal	_____ tons/mo	_____ MMBtu/ton			
natural gas	_____ MMCF/mo	1050 MMBtu/MMCF			
fuel oil	_____ gals/mo	0.139 MMBtu/gal			
Average monthly heat input from all fuels this month (MMBtu/hr)					

☐ No deviation occurred in this quarter.

☐ Deviation(s) occurred in this quarter. Deviation has been reported on: _____

Submitted by: _____

Title / Position: _____

Signature: _____

Date: _____

Phone: _____

Attach a signed certification to complete this report.

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH

Part 70 Quarterly Report for Boiler EU-05

Source Name: Indiana University
Source Address: 820 North Walnut Grove, Bloomington, Indiana 47405-2206
Mailing Address: 1514 East 3rd Street, Bloomington, Indiana 47405-2206
Part 70 Permit No.: T105-28296-00005
Facility: Boiler EU-05
Parameters: natural gas usage
Limits: less than 870 MMCF per twelve consecutive month period

For purposes of determining compliance, every 3.84 kilo-gallons of No.1 or No.2 fuel oil combusted shall be equivalent to 1 MMCF of natural gas based on NOx emissions and 0.08% sulfur content of No.1 fuel oil and 0.49% sulfur content of No.2 fuel oil. The amount of natural gas and natural gas equivalents used shall be determined as follows:

Amount of natural gas and natural gas equivalents used = ((EU-05 No.1 fuel oil usage in kgal/yr)/(3.84 kgal/MMCF)) + ((EU-05 No.2 fuel oil usage in kgal/yr)/ (3.84 kgal/MMCF)) + (EU-05 natural gas usage in MMCF/yr)

QUARTER: _____ YEAR: _____

				Column 1	Column 2	Column 1 + Column 2
				This Month	Previous 11 Months	12 Month Total
Month	**A** No.1 Oil Usage per month (kgals)	**B** No.2 Oil Usage per month (kgals)	**C** Nat. Gas Usage per month (MMCF)	**NOx** (A/3.84)+(B/3.84)+C	**NOx**	**NOx**

☐ No deviation occurred in this quarter.

☐ Deviation(s) occurred in this quarter. Deviation has been reported on: _____

Submitted by: _____

Title / Position: _____

Signature: _____

Date: _____

Phone: _____

Attach a signed certification to complete this report.

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH

Part 70 Quarterly Report for Boiler EU-05

Source Name: Indiana University
Source Address: 820 North Walnut Grove, Bloomington, Indiana 47405-2206
Mailing Address: 1514 East 3rd Street, Bloomington, Indiana 47405-2206
Part 70 Permit No.: T105-28296-00005
Facility: Boiler EU-05
Parameters: No. 2 fuel oil usage
Limits: less than 1,120 kgals per twelve consecutive month period

For purposes of determining compliance, every kilo-gallon of No.1 fuel oil combusted shall be equivalent to 5.89 kgal of No. 2 fuel oil based on SO2 emissions and 0.08% sulfur content of No. 1 fuel oil and 0.49% sulfur content of No. 2 fuel oil, and every MMCF of natural gas burned shall be equivalent to 0.009 kgal of No. 2 fuel oil based on SO2 emissions and 0.49% sulfur content of No. 2 fuel oil. The amount of No. 2 fuel oil and No. 2 fuel oil equivalents used shall be determined as follows:

Amount of No. 2 fuel oil and No. 2 fuel oil equivalents used = (EU-05 No.1 fuel oil usage in kgal/yr * 5.89 kgal of No. 2 fuel oil/kgal of No. 1 fuel oil) + (EU-05 No.2 fuel oil usage in kgal/yr) + (EU-05 natural gas usage in MMCF/yr * 0.009 kgal No. 2 fuel oil/MMCF natural gas)

QUARTER: _____ YEAR: _____

				Column 1	Column 2	Column 1 + Column 2
				This Month	Previous 11 Months	12 Month Total
Month	A No.1 Oil Usage per month (kgals)	B No.2 Oil Usage per month (kgals)	C Nat. Gas Usage per month (MMCF)	kgal of oil	kgal of oil	kgal of oil

☐ No deviation occurred in this quarter.

☐ Deviation(s) occurred in this quarter. Deviation has been reported on: _____

Submitted by: _____

Title / Position: _____

Signature: _____

Date: _____

Phone: _____

Attach a signed certification to complete this report.

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH

Part 70 Quarterly Report for Boiler EU-06

Source Name: Indiana University
Source Address: 820 North Walnut Grove, Bloomington, Indiana 47405-2206
Mailing Address: 1514 East 3rd Street, Bloomington, Indiana 47405-2206
Part 70 Permit No.: T105-28296-00005
Facility: Boiler EU-06
Parameters: SO_2 emissions, coal usage & analysis
Limits: SO_2 emissions shall not exceed 6.0 pounds per million Btu when combusting coal, and when coal and fuel oil are used simultaneously; and
SO_2 emissions shall not exceed 0.5 pounds per million Btu when combusting fuel oil

QUARTER: _____ YEAR: _____

Month	Coal Usage (tons)	Monthly Average Heat Content (MMBtu/lb)		Monthly Average Sulfur Content (%)		SO_2 Emission Rate (lbs/MMBtu)	
		coal	oil	coal	oil	coal	oil
# of Deviations							

☐ No deviation occurred in this quarter.
☐ Deviation(s) occurred in this quarter.

Deviation has been reported on: _____

Submitted by: _____

Title / Position: _____

Signature: _____

Date: _____

Phone: _____

Attach a signed certification to complete this report.

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH

Part 70 Quarterly Report for Boiler EU-07

Source Name:	Indiana University
Source Address:	820 North Walnut Grove, Bloomington, Indiana 47405-2206
Mailing Address:	1514 East 3rd Street, Bloomington, Indiana 47405-2206
Part 70 Permit No.:	T105-28296-00005
Facility:	Boiler EU-07
Parameter:	No. 1 and No. 2 fuel oil
Limit:	329,000 gallons per twelve (12) consecutive month period, with compliance determined at the end of each month.

QUARTER:_____ YEAR:_____

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

☐ No deviation occurred in this quarter.

☐ Deviation/s occurred in this quarter.
Deviation has been reported on:_____

Submitted by: _____

Title / Position: _____

Signature: _____

Date: _____

Phone: _____

Attach a signed certification to complete this report.

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH

PART 70 Quarterly Report for MSB 1

Source Name: Indiana University
Source Address: 820 North Walnut Grove, Bloomington, Indiana 47405-2206
Mailing Address: 1514 East 3rd Street, Bloomington, Indiana 47405-2206
Part 70 Permit No.: T105-28296-00005
Facility: Emergency Generator MSB 1
Parameter: Operating Hours
Limit: Less than 250 hours per twelve (12) consecutive month period with compliance determined at the end of each month.

QUARTER:_____ YEAR:_____

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

☐ No deviation occurred in this quarter.

☐ Deviation/s occurred in this quarter.
Deviation has been reported on:_____

Submitted by: _____

Title / Position: _____

Signature: _____

Date: _____

Phone: _____

Attach a signed certification to complete this report.

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH
PART 70 OPERATING PERMIT
QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT

Source Name: Indiana University
Source Address: 820 N. Walnut Grove Avenue, Bloomington, IN 47405
Mailing Address: 820 N. Walnut Grove Avenue, Bloomington, IN 47405,
Part 70 Permit No.: T 105-28296-00005

Months: _____ to _____ Year: _____

Page 1 of 2

This report shall be submitted quarterly based on a calendar year. Any deviation from the requirements, the date(s) of each deviation, the probable cause of the deviation, and the response steps taken must be reported. A deviation required to be reported pursuant to an applicable requirement that exists independent of the permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. Additional pages may be attached if necessary. If no deviations occurred, please specify in the box marked "No deviations occurred this reporting period".	
☐ NO DEVIATIONS OCCURRED THIS REPORTING PERIOD.	
☐ THE FOLLOWING DEVIATIONS OCCURRED THIS REPORTING PERIOD	
Permit Requirement (specify permit condition #)	
Date of Deviation:	**Duration of Deviation:**
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	**Duration of Deviation:**
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	

Page 2 of 2

Permit Requirement (specify permit condition #)	
Date of Deviation:	**Duration of Deviation:**
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	**Duration of Deviation:**
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	**Duration of Deviation:**
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	

Form Completed by:_____

Title / Position: _____

Date:_____

Phone: _____

Attach a signed certification to complete this report.

Attachment A –New Source Performance Standards: Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units [40 CFR Part 60, Subpart Db] [326 IAC 12]

Source Description and Location

Source Name:	Indiana University
Source Location:	820 N. Walnut Grove Avenue, Bloomington, Indiana 47405
County:	Monroe
SIC Code:	8221
Operation Permit Renewal No.:	T 105-28296-00005
Operation Permit Renewal Issuance Date:	October 23, 2009
Significant Source Modification No.:	105-28904-00005
Significant Permit Modification No.:	105-28915-00005
Permit Reviewer:	Jillian Bertram

NSPS [40 CFR Part 60, Subpart Db]

Subpart Db—Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units

Source: 72 FR 32742, June 13, 2007, unless otherwise noted.

§ 60.40b Applicability and delegation of authority.

(a) The affected facility to which this subpart applies is each steam generating unit that commences construction, modification, or reconstruction after June 19, 1984, and that has a heat input capacity from fuels combusted in the steam generating unit of greater than 29 MW (100 million Btu/hour).

(j) Any affected facility meeting the applicability requirements under paragraph (a) of this section and commencing construction, modification, or reconstruction after June 19, 1986 is not subject to subpart D (Standards of Performance for Fossil-Fuel-Fired Steam Generators, §60.40).

§ 60.41b Definitions.

As used in this subpart, all terms not defined herein shall have the meaning given them in the Clean Air Act and in subpart A of this part.

Annual capacity factor means the ratio between the actual heat input to a steam generating unit from the fuels listed in §60.42b(a), §60.43b(a), or §60.44b(a), as applicable, during a calendar year and the potential heat input to the steam generating unit had it been operated for 8,760 hours during a calendar year at the maximum steady state design heat input capacity. In the case of steam generating units that are rented or leased, the actual heat input shall be determined based on the combined heat input from all operations of the affected facility in a calendar year.

Byproduct/waste means any liquid or gaseous substance produced at chemical manufacturing plants, petroleum refineries, or pulp and paper mills (except natural gas, distillate oil, or residual oil) and combusted in a steam generating unit for heat recovery or for disposal. Gaseous substances with carbon dioxide (CO_2) levels greater than 50 percent or carbon monoxide levels greater than 10 percent are not byproduct/waste for the purpose of this subpart.

Chemical manufacturing plants mean industrial plants that are classified by the Department of Commerce under Standard Industrial Classification (SIC) Code 28.

Coal means all solid fuels classified as anthracite, bituminous, subbituminous, or lignite by the American Society of Testing and Materials in ASTM D388 (incorporated by reference, see §60.17), coal refuse, and petroleum coke. Coal-derived synthetic fuels, including but not limited to solvent refined coal, gasified coal, coal-oil mixtures, coke oven gas, and coal-water mixtures, are also included in this definition for the purposes of this subpart.

Coal refuse means any byproduct of coal mining or coal cleaning operations with an ash content greater than 50 percent, by weight, and a heating value less than 13,900 kJ/kg (6,000 Btu/lb) on a dry basis.

Cogeneration , also known as combined heat and power, means a facility that simultaneously produces both electric (or mechanical) and useful thermal energy from the same primary energy source.

Coke oven gas means the volatile constituents generated in the gaseous exhaust during the carbonization of bituminous coal to form coke.

Combined cycle system means a system in which a separate source, such as a gas turbine, internal combustion engine, kiln, etc., provides exhaust gas to a steam generating unit.

Conventional technology means wet flue gas desulfurization (FGD) technology, dry FGD technology, atmospheric fluidized bed combustion technology, and oil hydrodesulfurization technology.

Distillate oil means fuel oils that contain 0.05 weight percent nitrogen or less and comply with the specifications for fuel oil numbers 1 and 2, as defined by the American Society of Testing and Materials in ASTM D396 (incorporated by reference, see §60.17).

Dry flue gas desulfurization technology means a SO_2control system that is located downstream of the steam generating unit and removes sulfur oxides from the combustion gases of the steam generating unit by contacting the combustion gases with an alkaline reagent and water, whether introduced separately or as a premixed slurry or solution and forming a dry powder material. This definition includes devices where the dry powder material is subsequently converted to another form. Alkaline slurries or solutions used in dry flue gas desulfurization technology include but are not limited to lime and sodium.

Duct burner means a device that combusts fuel and that is placed in the exhaust duct from another source, such as a stationary gas turbine, internal combustion engine, kiln, etc., to allow the firing of additional fuel to heat the exhaust gases before the exhaust gases enter a steam generating unit.

Emerging technology means any SO_2control system that is not defined as a conventional technology under this section, and for which the owner or operator of the facility has applied to the Administrator and received approval to operate as an emerging technology under §60.49b(a)(4).

Federally enforceable means all limitations and conditions that are enforceable by the Administrator, including the requirements of 40 CFR parts 60 and 61, requirements within any applicable State Implementation Plan, and any permit requirements established under 40 CFR 52.21 or under 40 CFR 51.18 and 51.24.

Fluidized bed combustion technology means combustion of fuel in a bed or series of beds (including but not limited to bubbling bed units and circulating bed units) of limestone aggregate (or other sorbent materials) in which these materials are forced upward by the flow of combustion air and the gaseous products of combustion.

Fuel pretreatment means a process that removes a portion of the sulfur in a fuel before combustion of the fuel in a steam generating unit.

Full capacity means operation of the steam generating unit at 90 percent or more of the maximum steady-state design heat input capacity.

Gaseous fuel means any fuel that is present as a gas at ISO conditions.

Gross output means the gross useful work performed by the steam generated. For units generating only electricity, the gross useful work performed is the gross electrical output from the turbine/generator set.

For cogeneration units, the gross useful work performed is the gross electrical or mechanical output plus 75 percent of the useful thermal output measured relative to ISO conditions that is not used to generate additional electrical or mechanical output (i.e., steam delivered to an industrial process).

Heat input means heat derived from combustion of fuel in a steam generating unit and does not include the heat derived from preheated combustion air, recirculated flue gases, or exhaust gases from other sources, such as gas turbines, internal combustion engines, kilns, etc.

Heat release rate means the steam generating unit design heat input capacity (in MW or Btu/hr) divided by the furnace volume (in cubic meters or cubic feet); the furnace volume is that volume bounded by the front furnace wall where the burner is located, the furnace side waterwall, and extending to the level just below or in front of the first row of convection pass tubes.

Heat transfer medium means any material that is used to transfer heat from one point to another point.

High heat release rate means a heat release rate greater than 730,000 J/sec-m^3 (70,000 Btu/hr-ft^3).

ISO Conditions means a temperature of 288 Kelvin, a relative humidity of 60 percent, and a pressure of 101.3 kilopascals.

Lignite means a type of coal classified as lignite A or lignite B by the American Society of Testing and Materials in ASTM D388 (incorporated by reference, see §60.17).

Low heat release rate means a heat release rate of 730,000 J/sec-m^3 (70,000 Btu/hr-ft^3) or less.

Mass-feed stoker steam generating unit means a steam generating unit where solid fuel is introduced directly into a retort or is fed directly onto a grate where it is combusted.

Maximum heat input capacity means the ability of a steam generating unit to combust a stated maximum amount of fuel on a steady state basis, as determined by the physical design and characteristics of the steam generating unit.

Municipal-type solid waste means refuse, more than 50 percent of which is waste consisting of a mixture of paper, wood, yard wastes, food wastes, plastics, leather, rubber, and other combustible materials, and noncombustible materials such as glass and rock.

Natural gas means: (1) A naturally occurring mixture of hydrocarbon and nonhydrocarbon gases found in geologic formations beneath the earth's surface, of which the principal constituent is methane; or (2) liquefied petroleum gas, as defined by the American Society for Testing and Materials in ASTM D1835 (incorporated by reference, see §60.17).

Noncontinental area means the State of Hawaii, the Virgin Islands, Guam, American Samoa, the Commonwealth of Puerto Rico, or the Northern Mariana Islands.

Oil means crude oil or petroleum or a liquid fuel derived from crude oil or petroleum, including distillate and residual oil.

Petroleum refinery means industrial plants as classified by the Department of Commerce under Standard Industrial Classification (SIC) Code 29.

Potential sulfur dioxide emission rate means the theoretical SO_2emissions (nanograms per joule (ng/J) or lb/MMBtu heat input) that would result from combusting fuel in an uncleaned state and without using emission control systems.

Process heater means a device that is primarily used to heat a material to initiate or promote a chemical reaction in which the material participates as a reactant or catalyst.

Pulp and paper mills means industrial plants that are classified by the Department of Commerce under North American Industry Classification System (NAICS) Code 322 or Standard Industrial Classification (SIC) Code 26.

Pulverized coal-fired steam generating unit means a steam generating unit in which pulverized coal is introduced into an air stream that carries the coal to the combustion chamber of the steam generating unit where it is fired in suspension. This includes both conventional pulverized coal-fired and micropulverized coal-fired steam generating units. Residual oil means crude oil, fuel oil numbers 1 and 2 that have a nitrogen content greater than 0.05 weight percent, and all fuel oil numbers 4, 5 and 6, as defined by the American Society of Testing and Materials in ASTM D396 (incorporated by reference, see §60.17).

Spreader stoker steam generating unit means a steam generating unit in which solid fuel is introduced to the combustion zone by a mechanism that throws the fuel onto a grate from above. Combustion takes place both in suspension and on the grate.

Steam generating unit means a device that combusts any fuel or byproduct/waste and produces steam or heats water or any other heat transfer medium. This term includes any municipal-type solid waste incinerator with a heat recovery steam generating unit or any steam generating unit that combusts fuel and is part of a cogeneration system or a combined cycle system. This term does not include process heaters as they are defined in this subpart.

Steam generating unit operating day means a 24-hour period between 12:00 midnight and the following midnight during which any fuel is combusted at any time in the steam generating unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period.

Very low sulfur oil means for units constructed, reconstructed, or modified on or before February 28, 2005, an oil that contains no more than 0.5 weight percent sulfur or that, when combusted without SO_2emission control, has a SO_2emission rate equal to or less than 215 ng/J (0.5 lb/MMBtu) heat input. For units constructed, reconstructed, or modified after February 28, 2005, *very low sulfur oil* means an oil that contains no more than 0.3 weight percent sulfur or that, when combusted without SO_2emission control, has a SO_2emission rate equal to or less than 140 ng/J (0.32 lb/MMBtu) heat input.

Wet flue gas desulfurization technology means a SO_2control system that is located downstream of the steam generating unit and removes sulfur oxides from the combustion gases of the steam generating unit by contacting the combustion gas with an alkaline slurry or solution and forming a liquid material. This definition applies to devices where the aqueous liquid material product of this contact is subsequently converted to other forms. Alkaline reagents used in wet flue gas desulfurization technology include, but are not limited to, lime, limestone, and sodium.

Wet scrubber system means any emission control device that mixes an aqueous stream or slurry with the exhaust gases from a steam generating unit to control emissions of PM or SO_2.

Wood means wood, wood residue, bark, or any derivative fuel or residue thereof, in any form, including, but not limited to, sawdust, sanderdust, wood chips, scraps, slabs, millings, shavings, and processed pellets made from wood or other forest residues.

§ 60.42b Standard for sulfur dioxide.

(e) Except as provided in paragraph (f) of this section, compliance with the emission limits, fuel oil sulfur limits, and/or percent reduction requirements under this section are determined on a 30-day rolling average basis.

(j) Percent reduction requirements are not applicable to affected facilities combusting only very low sulfur oil. The owner or operator of an affected facility combusting very low sulfur oil shall demonstrate that the oil meets the definition of very low sulfur oil by: (1) Following the performance testing procedures as described in §60.45b(c) or §60.45b(d), and following the monitoring procedures as described in §60.47b(a) or §60.47b(b) to determine SO_2emission rate or fuel oil sulfur content; or (2) maintaining fuel records as described in §60.49b(r).

(k)(1) Except as provided in paragraphs (k)(2), (k)(3), and (k)(4) of this section, on and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that commences construction, reconstruction, or modification after February 28, 2005, and that combusts coal, oil, natural gas, a mixture of these fuels,

or a mixture of these fuels with any other fuels shall cause to be discharged into the atmosphere any gases that contain SO_2in excess of 87 ng/J (0.20 lb/MMBtu) heat input or 8 percent (0.08) of the potential SO_2emission rate (92 percent reduction) and 520 ng/J (1.2 lb/MMBtu) heat input.

(2) Units firing only very low sulfur oil and/or a mixture of gaseous fuels with a potential SO_2emission rate of 140 ng/J (0.32 lb/MMBtu) heat input or less are exempt from the SO_2emissions limit in paragraph 60.42b(k)(1).

§ 60.43b Standard for particulate matter.

(f) On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that combusts coal, oil, wood, or mixtures of these fuels with any other fuels shall cause to be discharged into the atmosphere any gases that exhibit greater than 20 percent opacity (6-minute average), except for one 6-minute period per hour of not more than 27 percent opacity.

(g) The PM and opacity standards apply at all times, except during periods of startup, shutdown or malfunction.

(h)(5) On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, an owner or operator of an affected facility that commences construction, reconstruction, or modification after February 28, 2005, and that combusts only oil that contains no more than 0.3 weight percent sulfur, coke oven gas, a mixture of these fuels, or either fuel (or a mixture of these fuels) in combination with other fuels not subject to a PM standard under §60.43b and not using a post-combustion technology (except a wet scrubber) to reduce SO_2or PM emissions is not subject to the PM limits under §60.43b(h)(1).

§ 60.44b Standard for nitrogen oxides.

(a) Except as provided under paragraphs (k) and (l) of this section, on and after the date on which the initial performance test is completed or is required to be completed under §60.8 of this part, whichever date comes first, no owner or operator of an affected facility that is subject to the provisions of this section and that combusts only coal, oil, or natural gas shall cause to be discharged into the atmosphere from that affected facility any gases that contain nitrogen oxides (expressed as NO_2) in excess of the following emission limits:

Fuel/Steam generating unit type	**Nitrogen oxide emission limits ng/J (lb/million Btu) (expressed as NO_2) heat input**
(1) Natural gas and distillate oil, except (4):	
(i) Low heat release rate	43 (0.10)
(ii) High heat release rate	86 (0.20)
(2) Residual oil:	
(i) Low heat release rate	130 (0.30)
(ii) High heat release rate	170 (0.40)
(3) Coal:	
(i) Mass-feed stoker	210 (0.50)
(ii) Spreader stoker and fluidized bed combustion	260 (0.60)
(iii) Pulverized coal	300 (0.70)
(iv) Lignite, except (v)	260 (0.60)

Fuel/Steam generating unit type	Nitrogen oxide emission limits ng/J (lb/million Btu) (expressed as NO_2) heat input
(v) Lignite mined in North Dakota, South Dakota, or Montana and combusted in a slag tap furnace	340 (0.80)
(vi) Coal-derived synthetic fuels	210 (0.50)
(4) Duct burner used in a combined cycle system:	
(i) Natural gas and distillate oil	86 (0.20)
(ii) Residual oil	170 (0.40)

(h) For purposes of paragraph (i) of this section, the nitrogen oxide standards under this section apply at all times including periods of startup, shutdown, or malfunction.

(i) Except as provided under paragraph (j) of this section, compliance with the emission limits under this section is determined on a 30-day rolling average basis.

(l) On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that commenced construction or reconstruction after July 9, 1997 shall cause to be discharged into the atmosphere from that affected facility any gases that contain NO_X(expressed as NO_2) in excess of the following limits:

(1) If the affected facility combusts coal, oil, or natural gas, or a mixture of these fuels, or with any other fuels: A limit of 86 ng/J (0.20 lb/MMBtu) heat input unless the affected facility has an annual capacity factor for coal, oil, and natural gas of 10 percent (0.10) or less and is subject to a federally enforceable requirement that limits operation of the facility to an annual capacity factor of 10 percent (0.10) or less for coal, oil, and natural gas; or

§ 60.45b Compliance and performance test methods and procedures for sulfur dioxide.

(j) The owner or operator of an affected facility that combusts very low sulfur oil is not subject to the compliance and performance testing requirements of this section if the owner or operator obtains fuel receipts as described in §60.49b(r).

(k) Units that burn only oil that contains no more than 0.3 weight percent sulfur or fuels with potential sulfur dioxide emission rates of 140 ng/J (0.32 lb/MMBtu) heat input or less may demonstrate compliance by maintaining records of fuel supplier certifications of sulfur content of the fuels burned.

§ 60.46b Compliance and performance test methods and procedures for particulate matter and nitrogen oxides.

(a) The PM emission standards and opacity limits under §60.43b apply at all times except during periods of startup, shutdown, or malfunction. The NO_X emission standards under §60.44b apply at all times.

(c) Compliance with the NO_X emission standards under §60.44b shall be determined through performance testing under paragraph (e) or (f), or under paragraphs (g) and (h) of this section, as applicable.

(e) To determine compliance with the emission limits for NO_X required under §60.44b, the owner or operator of an affected facility shall conduct the performance test as required under §60.8 using the continuous system for monitoring NO_X under §60.48(b).

(1) For the initial compliance test, NO_X from the steam generating unit are monitored for 30 successive steam generating unit operating days and the 30-day average emission rate is used to determine compliance with the NO_X emission standards under §60.44b. The 30-day average emission rate is calculated as the average of all hourly emissions data recorded by the monitoring system during the 30-day test period.

(4) Following the date on which the initial performance test is completed or required to be completed under §60.8, whichever date comes first, the owner or operator of an affected facility that has a heat input capacity of 73 MW (250 MMBtu/hr) or less and that combusts natural gas, distillate oil, or residual oil having a nitrogen content of 0.30 weight percent or less shall upon request determine compliance with the NO_X standards under §60.44b through the use of a 30-day performance test. During periods when performance tests are not requested, NO_X emissions data collected pursuant to §60.48b(g)(1) or §60.48b(g)(2) are used to calculate a 30-day rolling average emission rate on a daily basis and used to prepare excess emission reports, but will not be used to determine compliance with the NO_X emission standards. A new 30-day rolling average emission rate is calculated each steam generating unit operating day as the average of all of the hourly NO_X emission data for the preceding 30 steam generating unit operating days.

(i) Units burning only oil that contains no more than 0.3 weight percent sulfur or liquid or gaseous fuels with a potential sulfur dioxide emission rates of 140 ng/J (0.32 lb/MMBtu) heat input or less may demonstrate compliance by maintaining fuel supplier certifications of the sulfur content of the fuels burned.

§ 60.47b Emission monitoring for sulfur dioxide.

(f) The owner or operator of an affected facility that combusts very low sulfur oil is not subject to the emission monitoring requirements of this section if the owner or operator obtains fuel receipts as described in §60.49b(r).

(g) Units burning any fuel with a potential sulfur dioxide emission rate of 140 ng/J (0.32 lb/MMBtu) heat input or less are not required to conduct emissions monitoring if they maintain fuel supplier certifications of the sulfur content of the fuels burned.

§ 60.48b Emission monitoring for particulate matter and nitrogen oxides.

(a) The particulate matter emission standards and opacity limits under §60.43b apply at all times except during periods of startup, shutdown, or malfunction, and as specified in paragraphs (i) and (j) of this section. The nitrogen oxides emission standards under §60.44b apply at all times.

(b) Except as provided under paragraphs (g), (h), and (i) of this section, the owner or operator of an affected facility subject to a NO_X standard under §60.44b shall comply with either paragraphs (b)(1) or (b)(2) of this section.

(1) Install, calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring nitrogen oxides emissions discharged to the atmosphere; or

(c) The CEMS required under paragraph (b) of this section shall be operated and data recorded during all periods of operation of the affected facility except for CEMS breakdowns and repairs. Data is recorded during calibration checks, and zero and span adjustments.

(d) The 1-hour average nitrogen oxides emission rates measured by the continuous nitrogen oxides monitor required by paragraph (b) of this section and required under §60.13(h) shall be expressed in ng/J or lb/MMBtu heat input and shall be used to calculate the average emission rates under §60.44b. The 1-hour averages shall be calculated using the data points required under §60.13(h)(2).

(e) The procedures under §60.13 shall be followed for installation, evaluation, and operation of the continuous monitoring systems.

(2) For affected facilities combusting coal, oil, or natural gas, the span value for nitrogen oxides is determined as follows:

Fuel	Span values for nitrogen oxides (PPM)
Natural gas	500

Fuel	Span values for nitrogen oxides (PPM)
Oil	500
Coal	1,000
Mixtures	500(x+y)+1,000z

where:

x is the fraction of total heat input derived from natural gas,
y is the fraction of total heat input derived from oil, and
z is the fraction of total heat input derived from coal.

(ii) As an alternative to meeting the requirements of paragraph (e)(2)(i) of this section, the owner or operator of an affected facility may elect to use the NO_X span values determined according to section 2.1.2 in appendix A to part 75 of this chapter.

(3) All span values computed under paragraph (e)(2)(i) of this section for combusting mixtures of regulated fuels are rounded to the nearest 500 ppm. Span values computed under paragraph (e)(2)(ii) of this section shall be rounded off according to section 2.1.2 in appendix A to part 75 of this chapter.

(f) When NO_X emission data are not obtained because of CEMS breakdowns, repairs, calibration checks and zero and span adjustments, emission data will be obtained by using standby monitoring systems, Method 7, Method 7A, or other approved reference methods to provide emission data for a minimum of 75 percent of the operating hours in each steam generating unit operating day, in at least 22 out of 30 successive steam generating unit operating days.

(j) The owner or operator of an affected facility that meets the conditions in either paragraph (j)(1), (2), (3), (4), or (5) of this section is not required to install or operate a COMS for measuring opacity if:

(5) The affected facility burns only gaseous fuels or fuel oils that contain less than or equal to 0.30 weight percent sulfur and operates according to a written site-specific monitoring plan approved by the appropriate delegated permitting authority. This monitoring plan must include procedures and criteria for establishing and monitoring specific parameters for the affected facility indicative of compliance with the opacity standard.

§ 60.49b Reporting and recordkeeping requirements.

(a) The owner or operator of each affected facility shall submit notification of the date of initial startup, as provided by §60.7. This notification shall include:

(1) The design heat input capacity of the affected facility and identification of the fuels to be combusted in the affected facility,

(2) If applicable, a copy of any Federally enforceable requirement that limits the annual capacity factor for any fuel or mixture of fuels under §§60.42b(d)(1), 60.43b(a)(2), (a)(3)(iii), (c)(2)(ii), (d)(2)(iii), 60.44b(c), (d), (e), (i), (j), (k), 60.45b(d), (g), 60.46b(h), or 60.48b(i),

(3) The annual capacity factor at which the owner or operator anticipates operating the facility based on all fuels fired and based on each individual fuel fired,

(b) The owner or operator of each affected facility subject to the sulfur dioxide, particulate matter, and/or nitrogen oxides emission limits under §§60.42b, 60.43b, and 60.44b shall submit to the Administrator the performance test data from the initial performance test and the performance evaluation of the CEMS using the applicable performance specifications in appendix B. The owner or operator of each affected facility described in §60.44b(j) or §60.44b(k) shall submit to the Administrator the maximum heat input capacity data from the demonstration of the maximum heat input capacity of the affected facility.

(d) The owner or operator of an affected facility shall record and maintain records of the amounts of each fuel combusted during each day and calculate the annual capacity factor individually for coal, distillate oil,

residual oil, natural gas, wood, and municipal-type solid waste for the reporting period. The annual capacity factor is determined on a 12-month rolling average basis with a new annual capacity factor calculated at the end of each calendar month.

(g) Except as provided under paragraph (p) of this section, the owner or operator of an affected facility subject to the nitrogen oxides standards under §60.44b shall maintain records of the following information for each steam generating unit operating day:

(1) Calendar date.

(2) The average hourly nitrogen oxides emission rates (expressed as NO_2) (ng/J or lb/million Btu heat input) measured or predicted.

(3) The 30-day average nitrogen oxides emission rates (ng/J or lb/million Btu heat input) calculated at the end of each steam generating unit operating day from the measured or predicted hourly nitrogen oxide emission rates for the preceding 30 steam generating unit operating days.

(4) Identification of the steam generating unit operating days when the calculated 30-day average nitrogen oxides emission rates are in excess of the nitrogen oxides emissions standards under §60.44b, with the reasons for such excess emissions as well as a description of corrective actions taken.

(5) Identification of the steam generating unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken.

(6) Identification of the times when emission data have been excluded from the calculation of average emission rates and the reasons for excluding data.

(7) Identification of “F” factor used for calculations, method of determination, and type of fuel combusted.

(8) Identification of the times when the pollutant concentration exceeded full span of the continuous monitoring system.

(9) Description of any modifications to the continuous monitoring system that could affect the ability of the continuous monitoring system to comply with Performance Specification 2 or 3.

(10) Results of daily CEMS drift tests and quarterly accuracy assessments as required under appendix F, Procedure 1.

(h) The owner or operator of any affected facility in any category listed in paragraphs (h) (1) or (2) of this section is required to submit excess emission reports for any excess emissions which occurred during the reporting period.

(1) Any affected facility subject to the opacity standards under §60.43b(e) or to the operating parameter monitoring requirements under §60.13(i)(1).

(2) Any affected facility that is subject to the nitrogen oxides standard of §60.44b, and that

(i) Combusts natural gas, distillate oil, or residual oil with a nitrogen content of 0.3 weight percent or less, or

(ii) Has a heat input capacity of 73 MW (250 million Btu/hour) or less and is required to monitor nitrogen oxides emissions on a continuous basis under §60.48b(g)(1) or steam generating unit operating conditions under §60.48b(g)(2).

(i) The owner or operator of any affected facility subject to the continuous monitoring requirements for nitrogen oxides under §60.48(b) shall submit reports containing the information recorded under paragraph (g) of this section.

(o) All records required under this section shall be maintained by the owner or operator of the affected facility for a period of 2 years following the date of such record.

(r) The owner or operator of an affected facility who elects to use the fuel based compliance alternatives in §60.42b or §60.43b shall either:

(1) The owner or operator of an affected facility who elects to demonstrate that the affected facility combusts only very low sulfur oil under §60.42b(j)(2) or §60.42b(k)(2) shall obtain and maintain at the affected facility fuel receipts from the fuel supplier that certify that the oil meets the definition of distillate oil as defined in §60.41b and the applicable sulfur limit. For the purposes of this section, the distillate oil need not meet the fuel nitrogen content specification in the definition of distillate oil. Reports shall be submitted to the Administrator certifying that only very low sulfur oil meeting this definition and/or pipeline quality natural gas was combusted in the affected facility during the reporting period; or

(2) The owner or operator of an affected facility who elects to demonstrate compliance based on fuel analysis in §60.42b or §60.43b shall develop and submit a site-specific fuel analysis plan to the Administrator for review and approval no later than 60 days before the date you intend to demonstrate compliance. Each fuel analysis plan shall include a minimum initial requirement of weekly testing and each analysis report shall contain, at a minimum, the following information:

(i) The potential sulfur emissions rate of the representative fuel mixture in ng/J heat input;

(ii) The method used to determine the potential sulfur emissions rate of each constituent of the mixture. For distillate oil and natural gas a fuel receipt or tariff sheet is acceptable;

(iii) The ratio of different fuels in the mixture; and

(iv) The owner or operator can petition the Administrator to approve monthly or quarterly sampling in place of weekly sampling.

Attachment B – New Source Performance Standards: Standards of Performance for Stationary Compression Ignition Internal Combustion Engines [40 CFR Part 60, Subpart IIII] [326 IAC 12]

Source Description and Location

Source Name:	Indiana University
Source Location:	820 N. Walnut Grove Avenue, Bloomington, Indiana 47405
County:	Monroe
SIC Code:	8221
Operation Permit Renewal No.:	T 105-28296-00005
Operation Permit Renewal Issuance Date:	October 23, 2009
Significant Source Modification No.:	105-28904-00005
Significant Permit Modification No.:	105-28915-00005
Permit Reviewer:	Jillian Bertram

NSPS [40 CFR Part 60, Subpart IIII]

Subpart IIII—Standards of Performance for Stationary Compression Ignition Internal Combustion Engines

Source: 71 FR 39172, July 11, 2006, unless otherwise noted.

What This Subpart Covers

§ 60.4200 Am I subject to this subpart?

(a) The provisions of this subpart are applicable to manufacturers, owners, and operators of stationary compression ignition (CI) internal combustion engines (ICE) as specified in paragraphs (a)(1) through (3) of this section. For the purposes of this subpart, the date that construction commences is the date the engine is ordered by the owner or operator.

(1) Manufacturers of stationary CI ICE with a displacement of less than 30 liters per cylinder where the model year is:

(i) 2007 or later, for engines that are not fire pump engines,

(ii) The model year listed in table 3 to this subpart or later model year, for fire pump engines.

(2) Owners and operators of stationary CI ICE that commence construction after July 11, 2005 where the stationary CI ICE are:

(i) Manufactured after April 1, 2006 and are not fire pump engines, or

(ii) Manufactured as a certified National Fire Protection Association (NFPA) fire pump engine after July 1, 2006.

(3) Owners and operators of stationary CI ICE that modify or reconstruct their stationary CI ICE after July 11, 2005.

(b) The provisions of this subpart are not applicable to stationary CI ICE being tested at a stationary CI ICE test cell/stand.

(c) If you are an owner or operator of an area source subject to this subpart, you are exempt from the obligation to obtain a permit under 40 CFR part 70 or 40 CFR part 71, provided you are not required to obtain a permit under 40 CFR 70.3(a) or 40 CFR 71.3(a) for a reason other than your status as an area source under this subpart. Notwithstanding the previous sentence, you must continue to comply with the provisions of this subpart applicable to area sources.

(d) Stationary CI ICE may be eligible for exemption from the requirements of this subpart as described in 40 CFR part 1068, subpart C (or the exemptions described in 40 CFR part 89, subpart J and 40 CFR part 94, subpart J, for engines that would need to be certified to standards in those parts), except that owners and operators, as well as manufacturers, may be eligible to request an exemption for national security.

Emission Standards for Manufacturers

§ 60.4201 What emission standards must I meet for non-emergency engines if I am a stationary CI internal combustion engine manufacturer?

(a) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later non-emergency stationary CI ICE with a maximum engine power less than or equal to 2,237 kilowatt (KW) (3,000 horsepower (HP)) and a displacement of less than 10 liters per cylinder to the certification emission standards for new nonroad CI engines in 40 CFR 89.112, 40 CFR 89.113, 40 CFR 1039.101, 40 CFR 1039.102, 40 CFR 1039.104, 40 CFR 1039.105, 40 CFR 1039.107, and 40 CFR 1039.115, as applicable, for all pollutants, for the same model year and maximum engine power.

(b) Stationary CI internal combustion engine manufacturers must certify their 2007 through 2010 model year non-emergency stationary CI ICE with a maximum engine power greater than 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder to the emission standards in table 1 to this subpart, for all pollutants, for the same maximum engine power.

(c) Stationary CI internal combustion engine manufacturers must certify their 2011 model year and later non-emergency stationary CI ICE with a maximum engine power greater than 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder to the certification emission standards for new nonroad CI engines in 40 CFR 1039.101, 40 CFR 1039.102, 40 CFR 1039.104, 40 CFR 1039.105, 40 CFR 1039.107, and 40 CFR 1039.115, as applicable, for all pollutants, for the same maximum engine power.

(d) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later non-emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder to the certification emission standards for new marine CI engines in 40 CFR 94.8, as applicable, for all pollutants, for the same displacement and maximum engine power.

§ 60.4202 What emission standards must I meet for emergency engines if I am a stationary CI internal combustion engine manufacturer?

(a) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a maximum engine power less than or equal to 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder that are not fire pump engines to the emission standards specified in paragraphs (a)(1) through (2) of this section.

(1) For engines with a maximum engine power less than 37 KW (50 HP):

(i) The certification emission standards for new nonroad CI engines for the same model year and maximum engine power in 40 CFR 89.112 and 40 CFR 89.113 for all pollutants for model year 2007 engines, and

(ii) The certification emission standards for new nonroad CI engines in 40 CFR 1039.104, 40 CFR 1039.105, 40 CFR 1039.107, 40 CFR 1039.115, and table 2 to this subpart, for 2008 model year and later engines.

(2) For engines with a maximum engine power greater than or equal to 37 KW (50 HP), the certification emission standards for new nonroad CI engines for the same model year and maximum engine power in 40 CFR 89.112 and 40 CFR 89.113 for all pollutants beginning in model year 2007.

(b) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a maximum engine power greater than 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder that are not fire pump engines to the emission standards specified in paragraphs (b)(1) through (2) of this section.

(1) For 2007 through 2010 model years, the emission standards in table 1 to this subpart, for all pollutants, for the same maximum engine power.

(2) For 2011 model year and later, the certification emission standards for new nonroad CI engines for engines of the same model year and maximum engine power in 40 CFR 89.112 and 40 CFR 89.113 for all pollutants.

(c) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder that are not fire pump engines to the certification emission standards for new marine CI engines in 40 CFR 94.8, as applicable, for all pollutants, for the same displacement and maximum engine power.

(d) Beginning with the model years in table 3 to this subpart, stationary CI internal combustion engine manufacturers must certify their fire pump stationary CI ICE to the emission standards in table 4 to this subpart, for all pollutants, for the same model year and NFPA nameplate power.

§ 60.4203 How long must my engines meet the emission standards if I am a stationary CI internal combustion engine manufacturer?

Engines manufactured by stationary CI internal combustion engine manufacturers must meet the emission standards as required in §§60.4201 and 60.4202 during the useful life of the engines.

Emission Standards for Owners and Operators

§ 60.4204 What emission standards must I meet for non-emergency engines if I am an owner or operator of a stationary CI internal combustion engine?

(a) Owners and operators of pre-2007 model year non-emergency stationary CI ICE with a displacement of less than 10 liters per cylinder must comply with the emission standards in table 1 to this subpart. Owners and operators of pre-2007 model year non-emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder must comply with the emission standards in 40 CFR 94.8(a)(1).

(b) Owners and operators of 2007 model year and later non-emergency stationary CI ICE with a displacement of less than 30 liters per cylinder must comply with the emission standards for new CI engines in §60.4201 for their 2007 model year and later stationary CI ICE, as applicable.

(c) Owners and operators of non-emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder must meet the requirements in paragraphs (c)(1) and (2) of this section.

(1) Reduce nitrogen oxides (NO_X) emissions by 90 percent or more, or limit the emissions of NO_Xin the stationary CI internal combustion engine exhaust to 1.6 grams per KW-hour (g/KW-hr) (1.2 grams per HP-hour (g/HP-hr)).

(2) Reduce particulate matter (PM) emissions by 60 percent or more, or limit the emissions of PM in the stationary CI internal combustion engine exhaust to 0.15 g/KW-hr (0.11 g/HP-hr).

§ 60.4205 What emission standards must I meet for emergency engines if I am an owner or operator of a stationary CI internal combustion engine?

(a) Owners and operators of pre-2007 model year emergency stationary CI ICE with a displacement of less than 10 liters per cylinder that are not fire pump engines must comply with the emission standards in table 1 to this subpart. Owners and operators of pre-2007 model year non-emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards in 40 CFR 94.8(a)(1).

(b) Owners and operators of 2007 model year and later emergency stationary CI ICE with a displacement of less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards for new nonroad CI engines in §60.4202, for all pollutants, for the same model year and maximum engine power for their 2007 model year and later emergency stationary CI ICE.

(c) Owners and operators of fire pump engines with a displacement of less than 30 liters per cylinder must comply with the emission standards in table 4 to this subpart, for all pollutants.

(d) Owners and operators of emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder must meet the requirements in paragraphs (d)(1) and (2) of this section.

(1) Reduce NO_Xemissions by 90 percent or more, or limit the emissions of NO_Xin the stationary CI internal combustion engine exhaust to 1.6 grams per KW-hour (1.2 grams per HP-hour).

(2) Reduce PM emissions by 60 percent or more, or limit the emissions of PM in the stationary CI internal combustion engine exhaust to 0.15 g/KW-hr (0.11 g/HP-hr).

§ 60.4206 How long must I meet the emission standards if I am an owner or operator of a stationary CI internal combustion engine?

Owners and operators of stationary CI ICE must operate and maintain stationary CI ICE that achieve the emission standards as required in §§60.4204 and 60.4205 according to the manufacturer's written instructions or procedures developed by the owner or operator that are approved by the engine manufacturer, over the entire life of the engine.

Fuel Requirements for Owners and Operators

§ 60.4207 What fuel requirements must I meet if I am an owner or operator of a stationary CI internal combustion engine subject to this subpart?

(a) Beginning October 1, 2007, owners and operators of stationary CI ICE subject to this subpart that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 80.510(a).

(b) Beginning October 1, 2010, owners and operators of stationary CI ICE subject to this subpart with a displacement of less than 30 liters per cylinder that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 80.510(b) for nonroad diesel fuel.

(c) Owners and operators of pre-2011 model year stationary CI ICE subject to this subpart may petition the Administrator for approval to use remaining non-compliant fuel that does not meet the fuel requirements of paragraphs (a) and (b) of this section beyond the dates required for the purpose of using up existing fuel inventories. If approved, the petition will be valid for a period of up to 6 months. If additional time is needed, the owner or operator is required to submit a new petition to the Administrator.

(d) Owners and operators of pre-2011 model year stationary CI ICE subject to this subpart that are located in areas of Alaska not accessible by the Federal Aid Highway System may petition the Administrator for approval to use any fuels mixed with used lubricating oil that do not meet the fuel requirements of paragraphs (a) and (b) of this section. Owners and operators must demonstrate in their petition to the Administrator that there is no other place to use the lubricating oil. If approved, the petition will be valid for a period of up to 6 months. If additional time is needed, the owner or operator is required to submit a new petition to the Administrator.

(e) Stationary CI ICE that have a national security exemption under §60.4200(d) are also exempt from the fuel requirements in this section.

Other Requirements for Owners and Operators

§ 60.4208 What is the deadline for importing or installing stationary CI ICE produced in the previous model year?

(a) After December 31, 2008, owners and operators may not install stationary CI ICE (excluding fire pump engines) that do not meet the applicable requirements for 2007 model year engines.

(b) After December 31, 2009, owners and operators may not install stationary CI ICE with a maximum engine power of less than 19 KW (25 HP) (excluding fire pump engines) that do not meet the applicable requirements for 2008 model year engines.

(c) After December 31, 2014, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power of greater than or equal to 19 KW (25 HP) and less than 56 KW (75 HP) that do not meet the applicable requirements for 2013 model year non-emergency engines.

(d) After December 31, 2013, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power of greater than or equal to 56 KW (75 HP) and less than 130 KW (175 HP) that do not meet the applicable requirements for 2012 model year non-emergency engines.

(e) After December 31, 2012, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power of greater than or equal to 130 KW (175 HP), including those above 560 KW (750 HP), that do not meet the applicable requirements for 2011 model year non-emergency engines.

(f) After December 31, 2016, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power of greater than or equal to 560 KW (750 HP) that do not meet the applicable requirements for 2015 model year non-emergency engines.

(g) In addition to the requirements specified in §§60.4201, 60.4202, 60.4204, and 60.4205, it is prohibited to import stationary CI ICE with a displacement of less than 30 liters per cylinder that do not meet the applicable requirements specified in paragraphs (a) through (f) of this section after the dates specified in paragraphs (a) through (f) of this section.

(h) The requirements of this section do not apply to owners or operators of stationary CI ICE that have been modified, reconstructed, and do not apply to engines that were removed from one existing location and reinstalled at a new location.

§ 60.4209 What are the monitoring requirements if I am an owner or operator of a stationary CI internal combustion engine?

If you are an owner or operator, you must meet the monitoring requirements of this section. In addition, you must also meet the monitoring requirements specified in §60.4211.

(a) If you are an owner or operator of an emergency stationary CI internal combustion engine, you must install a non-resettable hour meter prior to startup of the engine.

(b) If you are an owner or operator of a stationary CI internal combustion engine equipped with a diesel particulate filter to comply with the emission standards in §60.4204, the diesel particulate filter must be installed with a backpressure monitor that notifies the owner or operator when the high backpressure limit of the engine is approached.

Compliance Requirements

§ 60.4210 What are my compliance requirements if I am a stationary CI internal combustion engine manufacturer?

(a) Stationary CI internal combustion engine manufacturers must certify their stationary CI ICE with a displacement of less than 10 liters per cylinder to the emission standards specified in §60.4201(a) through (c) and §60.4202(a), (b) and (d) using the certification procedures required in 40 CFR part 89, subpart B, or 40 CFR part 1039, subpart C, as applicable, and must test their engines as specified in those parts. For the purposes of this subpart, engines certified to the standards in table 1 to this subpart shall be subject to the same requirements as engines certified to the standards in 40 CFR part 89. For the purposes of this subpart, engines certified to the standards in table 4 to this subpart shall be subject to the same requirements as engines certified to the standards in 40 CFR part 89, except that engines with NFPA nameplate power of less than 37 KW (50 HP) certified to model year 2011 or later standards shall be subject to the same requirements as engines certified to the standards in 40 CFR part 1039.

(b) Stationary CI internal combustion engine manufacturers must certify their stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder to the emission standards specified in §60.4201(d) and §60.4202(c) using the certification procedures required in 40 CFR part 94 subpart C, and must test their engines as specified in 40 CFR part 94.

(c) Stationary CI internal combustion engine manufacturers must meet the requirements of 40 CFR 1039.120, 40 CFR 1039.125, 40 CFR 1039.130, 40 CFR 1039.135, and 40 CFR part 1068 for engines that are certified to the emission standards in 40 CFR part 1039. Stationary CI internal combustion engine manufacturers must meet the corresponding provisions of 40 CFR part 89 or 40 CFR part 94 for engines that would be covered by that part if they were nonroad (including marine) engines. Labels on such engines must refer to stationary engines, rather than or in addition to nonroad or marine engines, as appropriate. Stationary CI internal combustion engine manufacturers must label their engines according to paragraphs (c)(1) through (3) of this section.

(1) Stationary CI internal combustion engines manufactured from January 1, 2006 to March 31, 2006 (January 1, 2006 to June 30, 2006 for fire pump engines), other than those that are part of certified engine families under the nonroad CI engine regulations, must be labeled according to 40 CFR 1039.20.

(2) Stationary CI internal combustion engines manufactured from April 1, 2006 to December 31, 2006 (or, for fire pump engines, July 1, 2006 to December 31 of the year preceding the year listed in table 3 to this subpart) must be labeled according to paragraphs (c)(2)(i) through (iii) of this section:

(i) Stationary CI internal combustion engines that are part of certified engine families under the nonroad regulations must meet the labeling requirements for nonroad CI engines, but do not have to meet the labeling requirements in 40 CFR 1039.20.

(ii) Stationary CI internal combustion engines that meet Tier 1 requirements (or requirements for fire pumps) under this subpart, but do not meet the requirements applicable to nonroad CI engines must be labeled according to 40 CFR 1039.20. The engine manufacturer may add language to the label clarifying that the engine meets Tier 1 requirements (or requirements for fire pumps) of this subpart.

(iii) Stationary CI internal combustion engines manufactured after April 1, 2006 that do not meet Tier 1 requirements of this subpart, or fire pumps engines manufactured after July 1, 2006 that do not meet the requirements for fire pumps under this subpart, may not be used in the U.S. If any such engines are manufactured in the U.S. after April 1, 2006 (July 1, 2006 for fire pump engines), they must be exported or must be brought into compliance with the appropriate standards prior to initial operation. The export provisions of 40 CFR 1068.230 would apply to engines for export and the manufacturers must label such engines according to 40 CFR 1068.230.

(3) Stationary CI internal combustion engines manufactured after January 1, 2007 (for fire pump engines, after January 1 of the year listed in table 3 to this subpart, as applicable) must be labeled according to paragraphs (c)(3)(i) through (iii) of this section.

(i) Stationary CI internal combustion engines that meet the requirements of this subpart and the corresponding requirements for nonroad (including marine) engines of the same model year and HP must be labeled according to the provisions in part 89, 94 or 1039, as appropriate.

(ii) Stationary CI internal combustion engines that meet the requirements of this subpart, but are not certified to the standards applicable to nonroad (including marine) engines of the same model year and HP must be labeled according to the provisions in part 89, 94 or 1039, as appropriate, but the words “stationary” must be included instead of “nonroad” or “marine” on the label. In addition, such engines must be labeled according to 40 CFR 1039.20.

(iii) Stationary CI internal combustion engines that do not meet the requirements of this subpart must be labeled according to 40 CFR 1068.230 and must be exported under the provisions of 40 CFR 1068.230.

(d) An engine manufacturer certifying an engine family or families to standards under this subpart that are identical to standards applicable under parts 89, 94, or 1039 for that model year may certify any such family that contains both nonroad (including marine) and stationary engines as a single engine family and/or may include any such family containing stationary engines in the averaging, banking and trading provisions applicable for such engines under those parts.

(e) Manufacturers of engine families discussed in paragraph (d) of this section may meet the labeling requirements referred to in paragraph (c) of this section for stationary CI ICE by either adding a separate label containing the information required in paragraph (c) of this section or by adding the words “and stationary” after the word “nonroad” or “marine,” as appropriate, to the label.

(f) Starting with the model years shown in table 5 to this subpart, stationary CI internal combustion engine manufacturers must add a permanent label stating that the engine is for stationary emergency use only to each new emergency stationary CI internal combustion engine greater than or equal to 19 KW (25 HP) that meets all the emission standards for emergency engines in §60.4202 but does not meet all the emission standards for non-emergency engines in §60.4201. The label must be added according to the labeling requirements specified in 40 CFR 1039.135(b). Engine manufacturers must specify in the owner's manual that operation of emergency engines is limited to emergency operations and required maintenance and testing.

(g) Manufacturers of fire pump engines may use the test cycle in table 6 to this subpart for testing fire pump engines and may test at the NFPA certified nameplate HP, provided that the engine is labeled as “Fire Pump Applications Only”.

(h) Engine manufacturers, including importers, may introduce into commerce uncertified engines or engines certified to earlier standards that were manufactured before the new or changed standards took effect until inventories are depleted, as long as such engines are part of normal inventory. For example, if the engine manufacturers' normal industry practice is to keep on hand a one-month supply of engines based on its projected sales, and a new tier of standards starts to apply for the 2009 model year, the engine manufacturer may manufacture engines based on the normal inventory requirements late in the 2008 model year, and sell those engines for installation. The engine manufacturer may not circumvent the provisions of §§60.4201 or 60.4202 by stockpiling engines that are built before new or changed standards take effect. Stockpiling of such engines beyond normal industry practice is a violation of this subpart.

(i) The replacement engine provisions of 40 CFR 89.1003(b)(7), 40 CFR 94.1103(b)(3), 40 CFR 94.1103(b)(4) and 40 CFR 1068.240 are applicable to stationary CI engines replacing existing equipment that is less than 15 years old.

§ 60.4211 What are my compliance requirements if I am an owner or operator of a stationary CI internal combustion engine?

(a) If you are an owner or operator and must comply with the emission standards specified in this subpart, you must operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's written instructions or procedures developed by the owner or operator that are approved by the engine manufacturer. In addition, owners and operators may only change those settings that are permitted by the manufacturer. You must also meet the requirements of 40 CFR parts 89, 94 and/or 1068, as they apply to you.

(b) If you are an owner or operator of a pre-2007 model year stationary CI internal combustion engine and must comply with the emission standards specified in §§60.4204(a) or 60.4205(a), or if you are an owner or operator of a CI fire pump engine that is manufactured prior to the model years in table 3 to this subpart and must comply with the emission standards specified in §60.4205(c), you must demonstrate compliance according to one of the methods specified in paragraphs (b)(1) through (5) of this section.

(1) Purchasing an engine certified according to 40 CFR part 89 or 40 CFR part 94, as applicable, for the same model year and maximum engine power. The engine must be installed and configured according to the manufacturer's specifications.

(2) Keeping records of performance test results for each pollutant for a test conducted on a similar engine. The test must have been conducted using the same methods specified in this subpart and these methods must have been followed correctly.

(3) Keeping records of engine manufacturer data indicating compliance with the standards.

(4) Keeping records of control device vendor data indicating compliance with the standards.

(5) Conducting an initial performance test to demonstrate compliance with the emission standards according to the requirements specified in §60.4212, as applicable.

(c) If you are an owner or operator of a 2007 model year and later stationary CI internal combustion engine and must comply with the emission standards specified in §60.4204(b) or §60.4205(b), or if you are an owner or operator of a CI fire pump engine that is manufactured during or after the model year that applies to your fire pump engine power rating in table 3 to this subpart and must comply with the emission standards specified in §60.4205(c), you must comply by purchasing an engine certified to the emission standards in §60.4204(b), or §60.4205(b) or (c), as applicable, for the same model year and maximum (or in the case of fire pumps, NFPA nameplate) engine power. The engine must be installed and configured according to the manufacturer's specifications.

(d) If you are an owner or operator and must comply with the emission standards specified in §60.4204(c) or §60.4205(d), you must demonstrate compliance according to the requirements specified in paragraphs (d)(1) through (3) of this section.

(1) Conducting an initial performance test to demonstrate initial compliance with the emission standards as specified in §60.4213.

(2) Establishing operating parameters to be monitored continuously to ensure the stationary internal combustion engine continues to meet the emission standards. The owner or operator must petition the Administrator for approval of operating parameters to be monitored continuously. The petition must include the information described in paragraphs (d)(2)(i) through (v) of this section.

(i) Identification of the specific parameters you propose to monitor continuously;

(ii) A discussion of the relationship between these parameters and $NO_X$and PM emissions, identifying how the emissions of these pollutants change with changes in these parameters, and how limitations on these parameters will serve to limit $NO_X$and PM emissions;

(iii) A discussion of how you will establish the upper and/or lower values for these parameters which will establish the limits on these parameters in the operating limitations;

(iv) A discussion identifying the methods and the instruments you will use to monitor these parameters, as well as the relative accuracy and precision of these methods and instruments; and

(v) A discussion identifying the frequency and methods for recalibrating the instruments you will use for monitoring these parameters.

(3) For non-emergency engines with a displacement of greater than or equal to 30 liters per cylinder, conducting annual performance tests to demonstrate continuous compliance with the emission standards as specified in §60.4213.

(e) Emergency stationary ICE may be operated for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by Federal, State, or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of such units is limited to 100 hours per year. There is no time limit on the use of emergency stationary ICE in emergency situations. Anyone may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency ICE beyond 100 hours per year. For owners and operators

of emergency engines meeting standards under §60.4205 but not §60.4204, any operation other than emergency operation, and maintenance and testing as permitted in this section, is prohibited.

Testing Requirements for Owners and Operators

§ 60.4212 What test methods and other procedures must I use if I am an owner or operator of a stationary CI internal combustion engine with a displacement of less than 30 liters per cylinder?

Owners and operators of stationary CI ICE with a displacement of less than 30 liters per cylinder who conduct performance tests pursuant to this subpart must do so according to paragraphs (a) through (d) of this section.

(a) The performance test must be conducted according to the in-use testing procedures in 40 CFR part 1039, subpart F.

(b) Exhaust emissions from stationary CI ICE that are complying with the emission standards for new CI engines in 40 CFR part 1039 must not exceed the not-to-exceed (NTE) standards for the same model year and maximum engine power as required in 40 CFR 1039.101(e) and 40 CFR 1039.102(g)(1), except as specified in 40 CFR 1039.104(d). This requirement starts when NTE requirements take effect for nonroad diesel engines under 40 CFR part 1039.

(c) Exhaust emissions from stationary CI ICE that are complying with the emission standards for new CI engines in 40 CFR 89.112 or 40 CFR 94.8, as applicable, must not exceed the NTE numerical requirements, rounded to the same number of decimal places as the applicable standard in 40 CFR 89.112 or 40 CFR 94.8, as applicable, determined from the following equation:

$$\text{NTE requirement for each pollutant} = (1.25) \times (\text{STD}) \qquad \text{(Eq. 1)}$$

Where:

STD = The standard specified for that pollutant in 40 CFR 89.112 or 40 CFR 94.8, as applicable.

Alternatively, stationary CI ICE that are complying with the emission standards for new CI engines in 40 CFR 89.112 or 40 CFR 94.8 may follow the testing procedures specified in §60.4213 of this subpart, as appropriate.

(d) Exhaust emissions from stationary CI ICE that are complying with the emission standards for pre-2007 model year engines in §60.4204(a), §60.4205(a), or §60.4205(c) must not exceed the NTE numerical requirements, rounded to the same number of decimal places as the applicable standard in §60.4204(a), §60.4205(a), or §60.4205(c), determined from the equation in paragraph (c) of this section.

Where:

STD = The standard specified for that pollutant in §60.4204(a), §60.4205(a), or §60.4205(c).

Alternatively, stationary CI ICE that are complying with the emission standards for pre-2007 model year engines in §60.4204(a), §60.4205(a), or §60.4205(c) may follow the testing procedures specified in §60.4213, as appropriate.

§ 60.4213 What test methods and other procedures must I use if I am an owner or operator of a stationary CI internal combustion engine with a displacement of greater than or equal to 30 liters per cylinder?

Owners and operators of stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder must conduct performance tests according to paragraphs (a) through (d) of this section.

(a) Each performance test must be conducted according to the requirements in §60.8 and under the specific conditions that this subpart specifies in table 7. The test must be conducted within 10 percent of 100 percent peak (or the highest achievable) load.

(b) You may not conduct performance tests during periods of startup, shutdown, or malfunction, as specified in §60.8(c).

(c) You must conduct three separate test runs for each performance test required in this section, as specified in §60.8(f). Each test run must last at least 1 hour.

(d) To determine compliance with the percent reduction requirement, you must follow the requirements as specified in paragraphs (d)(1) through (3) of this section.

(1) You must use Equation 2 of this section to determine compliance with the percent reduction requirement:

$$\frac{C_i - C_o}{C_i} \times 100 = R \qquad \text{(Eq. 2)}$$

Where:

C_i= concentration of NO_Xor PM at the control device inlet,

C_o= concentration of NO_Xor PM at the control device outlet, and

R = percent reduction of NO_Xor PM emissions.

(2) You must normalize the NO_Xor PM concentrations at the inlet and outlet of the control device to a dry basis and to 15 percent oxygen (O_2) using Equation 3 of this section, or an equivalent percent carbon dioxide (CO_2) using the procedures described in paragraph (d)(3) of this section.

$$C_{adj} = C_d \frac{5.9}{20.9 - \% O_2} \qquad \text{(Eq. 3)}$$

Where:

C_{adj}= Calculated NO_Xor PM concentration adjusted to 15 percent O_2.

C_d= Measured concentration of NO_Xor PM, uncorrected.

5.9 = 20.9 percent O_2−15 percent O_2, the defined O_2correction value, percent.

$\%O_2$= Measured O_2concentration, dry basis, percent.

(3) If pollutant concentrations are to be corrected to 15 percent $O_2$and CO_2concentration is measured in lieu of O_2concentration measurement, a CO_2correction factor is needed. Calculate the CO_2correction factor as described in paragraphs (d)(3)(i) through (iii) of this section.

(i) Calculate the fuel-specific $F_o$value for the fuel burned during the test using values obtained from Method 19, Section 5.2, and the following equation:

$$F_o = \frac{0.209_{H}}{F_c} \qquad \text{(Eq. 4)}$$

Where:

F_o= Fuel factor based on the ratio of O_2volume to the ultimate CO_2volume produced by the fuel at zero percent excess air.

0.209 = Fraction of air that is O_2, percent/100.

F_d= Ratio of the volume of dry effluent gas to the gross calorific value of the fuel from Method 19, dsm^3 /J (dscf/10^6 Btu).

F_c= Ratio of the volume of CO_2produced to the gross calorific value of the fuel from Method 19, dsm^3 /J (dscf/10^6 Btu).

(ii) Calculate the CO_2correction factor for correcting measurement data to 15 percent O_2, as follows:

$$X_{CO_2} = \frac{5.9}{F_o} \qquad \text{(Eq. 5)}$$

Where:

X_{CO2}= CO_2correction factor, percent.

5.9 = 20.9 percent O_2−15 percent O_2, the defined O_2correction value, percent.

(iii) Calculate the $NO_X$and PM gas concentrations adjusted to 15 percent O_2using CO_2as follows:

$$C_{adj} = C_d \frac{X_{CO_2}}{\%CO_2} \qquad \text{(Eq. 6)}$$

Where:

C_{adj}= Calculated NO_Xor PM concentration adjusted to 15 percent O_2.

C_d= Measured concentration of NO_Xor PM, uncorrected.

$\%CO_2$= Measured CO_2concentration, dry basis, percent.

(e) To determine compliance with the NO_Xmass per unit output emission limitation, convert the concentration of NO_Xin the engine exhaust using Equation 7 of this section:

$$ER = \frac{C_d \times 1.912 \times 10^{-3} \times Q \times T}{\text{KW-hour}} \qquad \text{(Eq. 7)}$$

Where:

ER = Emission rate in grams per KW-hour.

C_d= Measured NO_Xconcentration in ppm.

$1.912x10^{-3}$= Conversion constant for ppm $NO_X$to grams per standard cubic meter at 25 degrees Celsius.

Q = Stack gas volumetric flow rate, in standard cubic meter per hour.

T = Time of test run, in hours.

KW-hour = Brake work of the engine, in KW-hour.

(f) To determine compliance with the PM mass per unit output emission limitation, convert the concentration of PM in the engine exhaust using Equation 8 of this section:

$$ER = \frac{C_{adj} \times Q \times T}{\text{KW-hour}} \qquad \text{(Eq. 8)}$$

Where:

ER = Emission rate in grams per KW-hour.

C_{adj}= Calculated PM concentration in grams per standard cubic meter.

Q = Stack gas volumetric flow rate, in standard cubic meter per hour.

T = Time of test run, in hours.

KW-hour = Energy output of the engine, in KW.

Notification, Reports, and Records for Owners and Operators

§ 60.4214 What are my notification, reporting, and recordkeeping requirements if I am an owner or operator of a stationary CI internal combustion engine?

(a) Owners and operators of non-emergency stationary CI ICE that are greater than 2,237 KW (3,000 HP), or have a displacement of greater than or equal to 10 liters per cylinder, or are pre-2007 model year engines that are greater than 130 KW (175 HP) and not certified, must meet the requirements of paragraphs (a)(1) and (2) of this section.

(1) Submit an initial notification as required in §60.7(a)(1). The notification must include the information in paragraphs (a)(1)(i) through (v) of this section.

(i) Name and address of the owner or operator;

(ii) The address of the affected source;

(iii) Engine information including make, model, engine family, serial number, model year, maximum engine power, and engine displacement;

(iv) Emission control equipment; and

(v) Fuel used.

(2) Keep records of the information in paragraphs (a)(2)(i) through (iv) of this section.

(i) All notifications submitted to comply with this subpart and all documentation supporting any notification.

(ii) Maintenance conducted on the engine.

(iii) If the stationary CI internal combustion is a certified engine, documentation from the manufacturer that the engine is certified to meet the emission standards.

(iv) If the stationary CI internal combustion is not a certified engine, documentation that the engine meets the emission standards.

(b) If the stationary CI internal combustion engine is an emergency stationary internal combustion engine, the owner or operator is not required to submit an initial notification. Starting with the model years in table 5 to this subpart, if the emergency engine does not meet the standards applicable to non-emergency engines in the applicable model year, the owner or operator must keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time.

(c) If the stationary CI internal combustion engine is equipped with a diesel particulate filter, the owner or operator must keep records of any corrective action taken after the backpressure monitor has notified the owner or operator that the high backpressure limit of the engine is approached.

Special Requirements

§ 60.4215 What requirements must I meet for engines used in Guam, American Samoa, or the Commonwealth of the Northern Mariana Islands?

(a) Stationary CI ICE that are used in Guam, American Samoa, or the Commonwealth of the Northern Mariana Islands are required to meet the applicable emission standards in §60.4205. Non-emergency stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder, must meet the applicable emission standards in §60.4204(c).

(b) Stationary CI ICE that are used in Guam, American Samoa, or the Commonwealth of the Northern Mariana Islands are not required to meet the fuel requirements in §60.4207.

§ 60.4216 What requirements must I meet for engines used in Alaska?

(a) Prior to December 1, 2010, owners and operators of stationary CI engines located in areas of Alaska not accessible by the Federal Aid Highway System should refer to 40 CFR part 69 to determine the diesel fuel requirements applicable to such engines.

(b) The Governor of Alaska may submit for EPA approval, by no later than January 11, 2008, an alternative plan for implementing the requirements of 40 CFR part 60, subpart IIII, for public-sector electrical utilities located in rural areas of Alaska not accessible by the Federal Aid Highway System. This alternative plan must be based on the requirements of section 111 of the Clean Air Act including any increased risks to human health and the environment and must also be based on the unique circumstances related to remote power generation, climatic conditions, and serious economic impacts resulting from implementation of 40 CFR part 60, subpart IIII. If EPA approves by rulemaking process an alternative plan, the provisions as approved by EPA under that plan shall apply to the diesel engines used in new stationary internal combustion engines subject to this paragraph.

§ 60.4217 What emission standards must I meet if I am an owner or operator of a stationary internal combustion engine using special fuels?

(a) Owners and operators of stationary CI ICE that do not use diesel fuel, or who have been given authority by the Administrator under §60.4207(d) of this subpart to use fuels that do not meet the fuel requirements of paragraphs (a) and (b) of §60.4207, may petition the Administrator for approval of alternative emission standards, if they can

demonstrate that they use a fuel that is not the fuel on which the manufacturer of the engine certified the engine and that the engine cannot meet the applicable standards required in §60.4202 or §60.4203 using such fuels.

(b) [Reserved]

General Provisions

§ 60.4218 What parts of the General Provisions apply to me?

Table 8 to this subpart shows which parts of the General Provisions in §§60.1 through 60.19 apply to you.

Definitions

§ 60.4219 What definitions apply to this subpart?

As used in this subpart, all terms not defined herein shall have the meaning given them in the CAA and in subpart A of this part.

Combustion turbine means all equipment, including but not limited to the turbine, the fuel, air, lubrication and exhaust gas systems, control systems (except emissions control equipment), and any ancillary components and sub-components comprising any simple cycle combustion turbine, any regenerative/recuperative cycle combustion turbine, the combustion turbine portion of any cogeneration cycle combustion system, or the combustion turbine portion of any combined cycle steam/electric generating system.

Compression ignition means relating to a type of stationary internal combustion engine that is not a spark ignition engine.

Diesel fuel means any liquid obtained from the distillation of petroleum with a boiling point of approximately 150 to 360 degrees Celsius. One commonly used form is number 2 distillate oil.

Diesel particulate filter means an emission control technology that reduces PM emissions by trapping the particles in a flow filter substrate and periodically removes the collected particles by either physical action or by oxidizing (burning off) the particles in a process called regeneration.

Emergency stationary internal combustion engine means any stationary internal combustion engine whose operation is limited to emergency situations and required testing and maintenance. Examples include stationary ICE used to produce power for critical networks or equipment (including power supplied to portions of a facility) when electric power from the local utility (or the normal power source, if the facility runs on its own power production) is interrupted, or stationary ICE used to pump water in the case of fire or flood, etc. Stationary CI ICE used to supply power to an electric grid or that supply power as part of a financial arrangement with another entity are not considered to be emergency engines.

Engine manufacturer means the manufacturer of the engine. See the definition of “manufacturer” in this section.

Fire pump engine means an emergency stationary internal combustion engine certified to NFPA requirements that is used to provide power to pump water for fire suppression or protection.

Manufacturer has the meaning given in section 216(1) of the Act. In general, this term includes any person who manufactures a stationary engine for sale in the United States or otherwise introduces a new stationary engine into commerce in the United States. This includes importers who import stationary engines for sale or resale.

Maximum engine power means maximum engine power as defined in 40 CFR 1039.801.

Model year means either:

(1) The calendar year in which the engine was originally produced, or

(2) The annual new model production period of the engine manufacturer if it is different than the calendar year. This must include January 1 of the calendar year for which the model year is named. It may not begin before January 2 of the previous calendar year and it must end by December 31 of the named calendar year. For an engine that is converted to a stationary engine after being placed into service as a nonroad or other non-stationary engine, model year means the calendar year or new model production period in which the engine was originally produced.

Other internal combustion engine means any internal combustion engine, except combustion turbines, which is not a reciprocating internal combustion engine or rotary internal combustion engine.

Reciprocating internal combustion engine means any internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work.

Rotary internal combustion engine means any internal combustion engine which uses rotary motion to convert heat energy into mechanical work.

Spark ignition means relating to a gasoline, natural gas, or liquefied petroleum gas fueled engine or any other type of engine with a spark plug (or other sparking device) and with operating characteristics significantly similar to the theoretical Otto combustion cycle. Spark ignition engines usually use a throttle to regulate intake air flow to control power during normal operation. Dual-fuel engines in which a liquid fuel (typically diesel fuel) is used for CI and gaseous fuel (typically natural gas) is used as the primary fuel at an annual average ratio of less than 2 parts diesel fuel to 100 parts total fuel on an energy equivalent basis are spark ignition engines.

Stationary internal combustion engine means any internal combustion engine, except combustion turbines, that converts heat energy into mechanical work and is not mobile. Stationary ICE differ from mobile ICE in that a stationary internal combustion engine is not a nonroad engine as defined at 40 CFR 1068.30 (excluding paragraph (2)(ii) of that definition), and is not used to propel a motor vehicle or a vehicle used solely for competition. Stationary ICE include reciprocating ICE, rotary ICE, and other ICE, except combustion turbines.

Attachment C – National Emission Standards for Hazardous Air Pollutants (NESHAP) for Performance for Stationary Reciprocating Internal Combustion Engines [40 CFR 63, Subpart ZZZZ] [326 IAC 20-82]

Source Description and Location

Source Name:	Indiana University
Source Location:	820 N. Walnut Grove Avenue, Bloomington, Indiana 47405
County:	Monroe
SIC Code:	8221
Operation Permit Renewal No.:	T 105-28296-00005
Operation Permit Renewal Issuance Date:	October 23, 2009
Significant Source Modification No.:	105-28904-00005
Significant Permit Modification No.:	105-28915-00005
Permit Reviewer:	Jillian Bertram

NESHAP [40 CFR Part 63, Subpart ZZZZ]

Subpart ZZZZ—Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units

Source: 72 FR 32742, June 13, 2007, unless otherwise noted.

Source: 69 FR 33506, June 15, 2004, unless otherwise noted.

What This Subpart Covers

§ 63.6580 What is the purpose of subpart ZZZZ?

Subpart ZZZZ establishes national emission limitations and operating limitations for hazardous air pollutants (HAP) emitted from stationary reciprocating internal combustion engines (RICE) located at major and area sources of HAP emissions. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emission limitations and operating limitations.

[73 FR 3603, Jan. 18, 2008]

§ 63.6585 Am I subject to this subpart?

You are subject to this subpart if you own or operate a stationary RICE at a major or area source of HAP emissions, except if the stationary RICE is being tested at a stationary RICE test cell/stand.

(a) A stationary RICE is any internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work and which is not mobile. Stationary RICE differ from mobile RICE in that a stationary RICE is not a non-road engine as defined at 40 CFR 1068.30, and is not used to propel a motor vehicle or a vehicle used solely for competition.

(b) A major source of HAP emissions is a plant site that emits or has the potential to emit any single HAP at a rate of 10 tons (9.07 megagrams) or more per year or any combination of HAP at a rate of 25 tons (22.68 megagrams) or more per year, except that for oil and gas production facilities, a major source of HAP emissions is determined for each surface site.

(c) An area source of HAP emissions is a source that is not a major source.

(d) If you are an owner or operator of an area source subject to this subpart, your status as an entity subject to a standard or other requirements under this subpart does not subject you to the obligation to obtain a permit under 40 CFR part 70 or 71, provided you are not required to obtain a permit under 40 CFR 70.3(a) or 40 CFR 71.3(a) for a reason other than your status as an area source under this subpart. Notwithstanding the previous sentence, you must continue to comply with the provisions of this subpart as applicable.

(e) If you are an owner or operator of a stationary RICE used for national security purposes, you may be eligible to request an exemption from the requirements of this subpart as described in 40 CFR part 1068, subpart C.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3603, Jan. 18, 2008]

§ 63.6590 What parts of my plant does this subpart cover?

This subpart applies to each affected source.

(a) *Affected source.* An affected source is any existing, new, or reconstructed stationary RICE located at a major or area source of HAP emissions, excluding stationary RICE being tested at a stationary RICE test cell/stand.

(1) *Existing stationary RICE.*

(i) For stationary RICE with a site rating of more than 500 brake horsepower (HP) located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before December 19, 2002.

(ii) For stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.

(iii) For stationary RICE located at an area source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.

(iv) A change in ownership of an existing stationary RICE does not make that stationary RICE a new or reconstructed stationary RICE.

(2) *New stationary RICE.* (i) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions is new if you commenced construction of the stationary RICE on or after December 19, 2002.

(ii) A stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.

(iii) A stationary RICE located at an area source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.

(3) *Reconstructed stationary RICE.* (i) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions is reconstructed if you meet the definition of reconstruction in §63.2 and reconstruction is commenced on or after December 19, 2002.

(ii) A stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions is reconstructed if you meet the definition of reconstruction in §63.2 and reconstruction is commenced on or after June 12, 2006.

(iii) A stationary RICE located at an area source of HAP emissions is reconstructed if you meet the definition of reconstruction in §63.2 and reconstruction is commenced on or after June 12, 2006.

(b) *Stationary RICE subject to limited requirements.* (1) An affected source which meets either of the criteria in paragraph (b)(1)(i) through (ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of §63.6645(h).

(i) The stationary RICE is a new or reconstructed emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions; or

(ii) The stationary RICE is a new or reconstructed limited use stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.

(2) A new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis must meet the initial notification requirements of §63.6645(h) and the requirements of §§63.6625(c), 63.6650(g), and 63.6655(c). These stationary RICE do not have to meet the emission limitations and operating limitations of this subpart.

(3) A stationary RICE which is an existing spark ignition 4 stroke rich burn (4SRB) stationary RICE located at an area source, an existing spark ignition 4SRB stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source, an existing spark ignition 2 stroke lean burn (2SLB) stationary RICE, an existing spark ignition 4 stroke lean burn (4SLB) stationary RICE, an existing compression ignition (CI) stationary RICE, an existing emergency stationary RICE, an existing limited use stationary RICE, or an existing stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, does not have to meet the requirements of this subpart and of subpart A of this part. No initial notification is necessary.

(c) *Stationary RICE subject to Regulations under 40 CFR Part 60.* An affected source that is a new or reconstructed stationary RICE located at an area source, or is a new or reconstructed stationary RICE located at a major source of HAP emissions and is a spark ignition 2 stroke lean burn (2SLB) stationary RICE with a site rating of less than 500 brake HP, a spark ignition 4 stroke lean burn (4SLB) stationary RICE with a site rating of less than 250 brake HP, or a 4 stroke rich burn (4SRB) stationary RICE with a site rating of less than or equal to 500 brake HP, a stationary RICE with a site rating of less than or equal to 500 brake HP which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, an emergency or limited use stationary RICE with a site rating of less than or equal to 500 brake HP, or a compression ignition (CI) stationary RICE with a site rating of less than or equal to 500 brake HP, must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines. No further requirements apply for such engines under this part.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008]

§ 63.6595 When do I have to comply with this subpart?

(a) *Affected Sources.* (1) If you have an existing stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the applicable emission limitations and operating limitations no later than June 15, 2007.

(2) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions before August 16, 2004, you must comply with the applicable emission limitations and operating limitations in this subpart no later than August 16, 2004.

(3) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions after August 16, 2004, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(4) If you start up your new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions before January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart no later than January 18, 2008.

(5) If you start up your new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions after January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(6) If you start up your new or reconstructed stationary RICE located at an area source of HAP emissions before January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart no later than January 18, 2008.

(7) If you start up your new or reconstructed stationary RICE located at an area source of HAP emissions after January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(b) *Area sources that become major sources.* If you have an area source that increases its emissions or its potential to emit such that it becomes a major source of HAP, the compliance dates in paragraphs (b)(1) and (2) of this section apply to you.

(1) Any stationary RICE for which construction or reconstruction is commenced after the date when your area source becomes a major source of HAP must be in compliance with this subpart upon startup of your affected source.

(2) Any stationary RICE for which construction or reconstruction is commenced before your area source becomes a major source of HAP must be in compliance with the provisions of this subpart that are applicable to RICE located at major sources within 3 years after your area source becomes a major source of HAP.

(c) If you own or operate an affected source, you must meet the applicable notification requirements in §63.6645 and in 40 CFR part 63, subpart A.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008]

Notifications, Reports, and Records

§ 63.6645 What notifications must I submit and when?

(a) If you own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions or a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 HP located at a major source of HAP emissions, you must submit all of the notifications in §§63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), 63.9(b) through (e), and (g) and (h) that apply to you by the dates specified.

(b) As specified in §63.9(b)(2), if you start up your stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions before the effective date of this subpart, you must submit an Initial Notification not later than December 13, 2004.

(c) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions on or after August 16, 2004, you must submit an Initial Notification not later than 120 days after you become subject to this subpart.

(d) As specified in §63.9(b)(2), if you start up your stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions before the effective date of this subpart and you are required to submit an initial notification, you must submit an Initial Notification not later than July 16, 2008.

(e) If you start up your new or reconstructed stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions on or after March 18, 2008 and you are required to submit an initial notification, you must submit an Initial Notification not later than 120 days after you become subject to this subpart.

(f) If you are required to submit an Initial Notification but are otherwise not affected by the requirements of this subpart, in accordance with §63.6590(b), your notification should include the information in §63.9(b)(2)(i) through (v), and a statement that your stationary RICE has no additional requirements and explain the basis of the exclusion (for

example, that it operates exclusively as an emergency stationary RICE if it has a site rating of more than 500 brake HP located at a major source of HAP emissions).

(g) If you are required to conduct a performance test, you must submit a Notification of Intent to conduct a performance test at least 60 days before the performance test is scheduled to begin as required in §63.7(b)(1).

(h) If you are required to conduct a performance test or other initial compliance demonstration as specified in Tables 4 and 5 to this subpart, you must submit a Notification of Compliance Status according to §63.9(h)(2)(ii).

(1) For each initial compliance demonstration required in Table 5 to this subpart that does not include a performance test, you must submit the Notification of Compliance Status before the close of business on the 30th day following the completion of the initial compliance demonstration.

(2) For each initial compliance demonstration required in Table 5 to this subpart that includes a performance test conducted according to the requirements in Table 3 to this subpart, you must submit the Notification of Compliance Status, including the performance test results, before the close of business on the 60th day following the completion of the performance test according to §63.10(d)(2).

[73 FR 3606, Jan. 18, 2008]

Indiana Department of Environmental Management
Office of Air Quality

Technical Support Document (TSD)
for a Part 70 Significant Source Modification and
a Part 70 Significant Permit Modification

Source Description and Location

Source Name:	Indiana University
Source Location:	820 N. Walnut Grove Avenue, Bloomington, Indiana 47405
County:	Monroe
SIC Code:	8221
Operation Permit Renewal No.:	T 105-28296-00005
Operation Permit Renewal Issuance Date:	October 23, 2009
Significant Source Modification No.:	105-28904-00005
Significant Permit Modification No.:	105-28915-00005
Permit Reviewer:	Jillian Bertram

Existing Approvals

The source was issued Part 70 Operating Permit Renewal No. T 105-28296-00005 on October 23, 2009.

County Attainment Status

The source is located in Monroe County.

Pollutant	Designation
SO_2	Better than national standards.
CO	Unclassifiable or attainment effective November 15, 1990.
O_3	Unclassifiable or attainment effective June 15, 2004, for the 8-hour ozone standard.[1]
PM_{10}	Unclassifiable effective November 15, 1990.
NO_2	Cannot be classified or better than national standards.
Pb	Not designated.
[1]Unclassifiable or attainment effective October 18, 2000, for the 1-hour ozone standard which was revoked effective June 15, 2005. Unclassifiable or attainment effective April 5, 2005, for PM2.5.	

(a) Volatile organic compounds (VOC) and Nitrogen Oxides (NO_X) are regulated under the Clean Air Act (CAA) for the purposes of attaining and maintaining the National Ambient Air Quality Standards (NAAQS) for ozone. Therefore, VOC emissions and NO_X emissions are considered when evaluating the rule applicability relating to ozone. Monroe County has been designated as attainment or unclassifiable for ozone. Therefore, VOC emissions and NO_X emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2. See the State Rule Applicability – Entire Source section.

(b) $PM_{2.5}$

Monroe County has been classified as attainment for $PM_{2.5}$. On May 8, 2008, U.S. EPA promulgated the requirements for Prevention of Significant Deterioration (PSD) for $PM_{2.5}$ emissions, and the effective date of these rules was July 15th, 2008. Indiana has three years from the publication of these rules to revise its PSD rules, 326 IAC 2-2, to include those requirements. The May 8, 2008 rule revisions require IDEM to regulate PM_{10} emissions as a surrogate for $PM_{2.5}$ emissions until 326 IAC 2-2 is revised.

(c) Monroe County has been classified as attainment or unclassifiable for PM_{10}, SO_2, NO_2, CO, and Lead. Therefore, these emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2.

(d) Since this source consists of fossil fuel boilers (or combinations thereof) totaling more than two hundred fifty million (250,000,000) British thermal units per hour heat input, it is considered one of the twenty-eight (28) listed source categories, as specified in 326 IAC 2-2-1(gg)(1).

(e) Fugitive Emissions
Since this type of operation is in one of the twenty-eight (28) listed source categories under 326 IAC 2-2 or 326 IAC 2-3, fugitive emissions are counted toward the determination of PSD and Emission Offset applicability.

Source Status

The table below summarizes the potential to emit of the entire source, prior to the proposed modification, after consideration of all enforceable limits established in the effective permits:

Pollutant	tons/year
PM	> 100
PM_{10}	> 100
$PM_{2.5}$	> 100
SO_2	> 100
VOC	< 100
CO	> 100
NO_x	> 100

HAPs	tons/year
Hydrogen Chloride (HCL)	> 10
Hydrogen Fluoride (HF)	> 10
Total	> 25

(a) This existing source is a major stationary source, under PSD (326 IAC 2-2), because a regulated pollutant is emitted at a rate of 100 tons per year or more, and it is one of the twenty-eight (28) listed source categories, as specified in 326 IAC 2-2-1(gg)(1).

(b) This existing source is a major source of HAPs, as defined in 40 CFR 63.41, because HAP emissions are greater than ten (10) tons per year for a single HAP and greater than twenty-five (25) tons per year for a combination of HAPs. Therefore, this source is a major source under Section 112 of the Clean Air Act (CAA).

Description of Proposed Modification

The Office of Air Quality (OAQ) has reviewed a modification application, submitted by Indiana University on January 22, 2010, relating to the replacement of economizers on Boiler 3, 4, and 6. The following is a list of the modified emission units and pollution control devices:

(a) Two (2) coal, natural gas, No. 1 or No. 2 fuel oil fired boilers, identified as EU-03 and EU-04, both constructed in 1959, with economizers replaced in 2010, with a maximum design capacity of 125 MMBtu per hour heat input each (operating at a maximum capacity of 100 MMBtu per hour heat input each when combusting coal or a combination of fuels), and with a maximum design capacity of 80 MMBtu per hour heat input each when combusting natural gas and/or fuel oil, each equipped with low NOx burners for natural gas and/or fuel oil, and each with a multiclone and a jet pulse baghouse, identified as Boiler 3 Bag and Boiler 4 Bag, for particulate control, permitted in 2008, when combusting coal and/or fuel oil, both exhausting at stack 002. In addition, the stack exhaust from boilers EU-03 and EU-04 can be treated by an activated carbon injection system for mercury control and a lime injection system for hydrogen chloride control.

(b) One (1) coal, natural gas, No. 1 or No. 2 fuel oil fired boiler, identified as EU-06, constructed in 1970, with economizers replaced in 2010, with a maximum design capacity of 190 MMBtu per hour heat input when combusting coal and/or fuel oil, and 150 MMBtu per hour heat input (two natural gas fired burners rated at 75 MMBtu per hour heat input each) when combusting natural gas, equipped with low NOx burners for natural gas and/or fuel oil, a multiclone and a jet pulse baghouse, identified as Boiler 6 Bag, for particulate control when combusting coal and/or fuel oil, permitted in 2008, and a continuous opacity monitor for monitoring opacity, exhausting to stack 003. In addition, the stack exhaust from boiler EU-06 can be treated by an activated carbon injection system for mercury control and a lime injection system for hydrogen chloride control.

Enforcement Issues

There are no pending enforcement actions related to this modification.

Stack Summary

There are no new or modified stacks due to this modification

Emission Calculations

There is no increase in the potential to emit due to this modification

Permit Level Determination – Part 70

Pursuant to 326 IAC 2-1.1-1(16), Potential to Emit is defined as “the maximum capacity of a stationary source or emission unit to emit any air pollutant under its physical and operational design. Any physical or operational limitation on the capacity of a source to emit an air pollutant, including air pollution control equipment and restrictions on hours of operation or type or amount of material combusted, stored, or processed shall be treated as part of its design if the limitation is enforceable by the U. S. EPA, IDEM, or the appropriate local air pollution control agency.”

The following table is used to determine the appropriate permit level under 326 IAC 2-7-10.5. This table reflects the PTE before controls. Control equipment is not considered federally enforceable until it has been required in a federally enforceable permit.

Table 1: PTE Change of the Modified Process			
Pollutant	**PTE Before Modification** (ton/yr)	**PTE After Modification** (ton/yr)	**Net Difference** (ton/yr)
PM	649.12	649.12	0.00
PM_{10}	649.12	649.12	0.00
$PM_{2.5}$	649.12	649.12	0.00
CO	355.88	355.88	0.00
NOx	782.93	782.93	0.00
SO_2	10249.20	10249.20	0.00
VOC	3.55	3.55	0.00
HAPs	40.03	40.03	0.00

The applicant has provided calculations which indicate that there will be no increase in PTE from this project. However, to ensure that the source has met all applicable requirements the source is requesting that IDEM permit the project as a major modification under 326 IAC 2-2. Therefore, this source modification is subject to 326 IAC 2-7-10.5(f)(1), Significant Source Modification because it is subject to Prevention of Significant Deterioration (PSD) review under 326 IAC 2-2.

This PSD/Significant Source Modification Permit will be incorporated into the Part 70 Operating Permit under 326 IAC 2-7-12, Significant Permit Modification because it is subject to Prevention of Significant Deterioration (PSD) review under 326 IAC 2-2.

Permit Level Determination – PSD

The Permittee has provided information as part of the application for this approval that based on Actual to Projected Actual test in 326 IAC 2-2-2(d)(3) this modification at a major stationary source will not be major for Prevention of Significant Deterioration under 326 IAC 2-2-1. IDEM, OAQ has not reviewed this information and will not be making any determination in this regard as part of this approval. The applicant will be required to keep records and report in accordance with Source obligation in 326 IAC 2-2-8. The table below summarizes the results of the actual to projected actual test, see Appendix A for detailed calculations.

	Table 2: Projected Change in Actual Emissions (ton/yr)					
Process / Emission Unit	**CO**	**NO_X**	**PM**	**PM_{10}**	**SO_2**	**VOC**
EU03	0	0	0	0	0	0
EU04	0	0	0	0	0	0
EU06	0	0	0	0	0	0
Total for Modification	**0**	**0**	**0**	**0**	**0**	**0**
Significant Level	100	40	25	15	40	40

The applicant has determined that based on ATPA evaluation, there will be no increase in emissions from this modification. However, to ensure that the source has met all applicable requirements, the source is requesting to go through PSD review. Pursuant to 326 IAC 2-2-2(h), the source is exempt from certain requirements of 326 IAC 2-2, including Best Available Control Techonology Analysis (BACT), pre-construction ambient air quality monitoring, and additional impact analysis because the source is a non-profit educational institution.

Federal Rule Applicability Determination

There are no National Emission Standards for Hazardous Air Pollutants (NESHAPs) (326 IAC 20 and 40 CFR Part 63) included in the permit for this proposed modification.

EU-3, EU-4, and EU-6 would have been subject to the requirements of the National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers and Process Heaters, 40 CFR 63, Subpart DDDDD. However, on June 8, 2007, the United States Court of appeals for the District of Columbia Circuit (in NRDC v. EPA, no. 04-1386) vacated in its entirety the National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers and Process Heaters, 40 CFR 63, Subpart DDDDD. Additionally, since the state rule at 326 IAC 20-95 incorporated the requirements of the NESHAP 40 CFR 63, Subpart DDDDD by reference, the requirements of 326 IAC 20-95 are no longer effective. Therefore, the requirements of 40 CFR 63, Subpart DDDDD and 326 IAC 20-95 are not included in the permit.

State Rule Applicability Determination

326 IAC 2-2-3 (Control Technology Review; Requirements), 326 IAC 2-2-4 (Air Quality Analysis; Requirements), and 326 IAC 2-2-7 (Additional Analysis; Requirements)

IDEM has determined that the source is a non-profit educational institution. Therefore, pursuant to 326 IAC 2-2-2(h), the source is exempt from the requirements of 326 IAC 2-2-3, 326 IAC 2-2-4, and 326 IAC 2-2-7.

326 IAC 2-2-5 (Air Quality Impacts Analysis)

The source completed a modeling analysis for the modification to ensure that no NAAQS standards would be violated. Indiana University is replacing the economizers on Boilers 3, 4, and 6. These are equivalent to existing equipment and would not increase emissions. In fact by definition, installing efficient economizers on boilers will actually reduce fuel consumption compared to existing economizers. Being thoroughly conservative, an increase in emissions of 0.01 lb/hr was modeled for each of the pollutants which resulted in an impact of 0.0 ug/m3 for each pollutant in all time-averaging periods.

326 IAC 2-2-6 (Increment Consumption; Requirements)

Based on modeling results, as required by 326 IAC 2-2-5, the proposed modification does not demonstrate emissions increases that exceed eighty percent (80%) of the available maximum allowable increases (MAI) over the baseline concentrations for sulfur dioxide, particulate matter, and nitrogen dioxide. Emission increases demonstrated by all pollutants are equal to 0.0 ug/m3, well below the MAI thresholds listed in 326 IAC 2-2-6(b)(1).

Compliance Determination and Monitoring Requirements

Permits issued under 326 IAC 2-7 are required to ensure that sources can demonstrate compliance with all applicable state and federal rules on a continuous basis. All state and federal rules contain compliance provisions; however, these provisions do not always fulfill the requirement for a continuous demonstration. When this occurs, IDEM, OAQ, in conjunction with the source, must develop specific conditions to satisfy 326 IAC 2-7-5. As a result, Compliance Determination Requirements are included in the permit. The Compliance Determination Requirements in Section D of the permit are those conditions that are found directly within state and federal rules and the violation of which serves as grounds for enforcement action.

If the Compliance Determination Requirements are not sufficient to demonstrate continuous compliance, they will be supplemented with Compliance Monitoring Requirements, also in Section D of the permit. Unlike Compliance Determination Requirements, failure to meet Compliance Monitoring conditions would serve as a trigger for corrective actions and not grounds for enforcement action. However, a violation in relation to a compliance monitoring condition will arise through a source's failure to take the appropriate corrective actions within a specific time period.

Compliance Determination Requirements
There are no changes to the Compliance Determination Requirements as a result of this modification.

Compliance Monitoring Requirements
There are no changes to the Compliance Monitoring Requirements as a result of this modification.

Record Keeping
Permit Condition C.19, General Record Keeping Requirements, requires that post modification emissions records must be kept when there is a "reasonable possibility" that a project will increase emissions at the source significantly. Based on the ATPA evaluation provided above, this project will not increase emissions significantly, therefore, no new record keeping requirements are included in the permit.

Proposed Changes

Change 1. Emission Unit descriptions of EU03, EU04, and EU06, have been changed to reflect this modification.

A.2 Emission Units and Pollution Control Equipment Summary
[326 IAC 2-7-4(c)(3)][326 IAC 2-7-5(15)]

This stationary source consists of the following emission units and pollution control devices:

***

(b) Two (2) coal, natural gas, No. 1 or No. 2 fuel oil fired boilers, identified as EU-03 and EU-04, both constructed in 1959, **with economizers replaced in 2010**, with a maximum design capacity of 125 MMBtu per hour heat input each (operating at a maximum capacity of 100 MMBtu per hour heat input each when combusting coal or a combination of fuels), and with a maximum design capacity of 80 MMBtu per hour heat input each when combusting natural gas and/or fuel oil, each equipped with low NOx burners for natural gas and/or fuel oil, and each with a multiclone and a jet pulse baghouse, identified as Boiler 3 Bag and Boiler 4 Bag, for particulate control, permitted in 2008, when combusting coal and/or fuel oil, both exhausting at stack 002. In addition, the stack exhaust from boilers EU-03 and EU-04 can be treated by an activated carbon injection system for mercury control and a lime injection system for hydrogen chloride control.

***

(d) One (1) coal, natural gas, No. 1 or No. 2 fuel oil fired boiler, identified as EU-06, constructed in 1970, **with economizers replaced in 2010**, with a maximum design capacity of 190 MMBtu per hour heat input when combusting coal and/or fuel oil, and 150 MMBtu per hour heat input (two natural gas fired burners rated at 75 MMBtu per hour heat input each) when combusting natural gas, equipped with low NOx burners for natural gas and/or fuel oil, a multiclone and a jet pulse baghouse, identified as Boiler 6 Bag, for particulate control when combusting coal and/or fuel oil, permitted in 2008, and a continuous opacity monitor for monitoring opacity, exhausting to stack 003. In addition, the stack exhaust from boiler EU-06 can be treated by an activated carbon injection system for mercury control and a lime injection system for hydrogen chloride control.

***

SECTION D.2 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]:

(b) Two (2) coal, natural gas, No. 1 or No. 2 fuel oil fired boilers, identified as EU-03 and EU-04, both constructed in 1959, **with economizers replaced in 2010,** with a maximum design capacity of 125 MMBtu per hour heat input each (operating at a maximum capacity of 100 MMBtu per hour heat input each when combusting coal or a combination of fuels), and with a maximum design capacity of 80 MMBtu per hour heat input each when combusting natural gas and/or fuel oil, each equipped with low NOx burners for natural gas and/or fuel oil, and each with a multiclone and a jet pulse baghouse, identified as Boiler 3 Bag and Boiler 4 Bag including a bag leak detection system, for particulate control, permitted in 2008, when combusting coal and/or fuel oil, both exhausting at stack 002. In addition, the stack exhaust from boilers EU-03 and EU-04 can be treated by an activated carbon injection system for mercury control and a lime injection system for hydrogen chloride control.

***

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

***

SECTION D.3 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]:

(d) One (1) coal, natural gas, No. 1 or No. 2 fuel oil fired boiler, identified as EU-06, constructed in 1970, **with economizers replaced in 2010,** with a maximum design capacity of 190 MMBtu per hour heat input when combusting coal and/or fuel oil, and 150 MMBtu per hour heat input (two natural gas fired burners rated at 75 MMBtu per hour heat input each) when combusting natural gas, equipped with low NOx burners for natural gas and/or fuel oil, a multiclone and a jet pulse baghouse, identified as Boiler 6 Bag including a bag leak detection system, for particulate control when combusting coal and/or fuel oil, permitted in 2008, and a continuous opacity monitor for monitoring opacity, exhausting to stack 003. In addition, the stack exhaust from boiler EU-06 can be treated by an activated carbon injection system for mercury control and a lime injection system for hydrogen chloride control.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Change 2. 326 IAC 6-2-4 applicability has been removed from Boiler 7, pursuant to 326 IAC 6-2-1(d), 326 IAC 6-2-4 does not apply to units subject to a particulate limitation in a New Source Performance Standard, in this case 40 CFR 60, Subpart Db. All subsequent conditions have been renumbered.

~~D.1.1 Particulate Matter Limitation (PM) [326 IAC 6-2-4]~~

~~Pursuant to 326 IAC 6-2-4 (Particulate emission limitations for sources of indirect heating: emission limitations for facilities specified in 326 IAC 6-2-1(d)), the PM emissions from boiler EU-07 shall in no case exceed 0.18 pounds of particulate matter per million British thermal units heat input. This limitation is based on the following equation:~~

$$P_t = \frac{1.09}{Q^{0.26}}$$

~~where: P_t - PM limit in pounds per MMBtu~~
~~Q - total source permitted capacity in MMBtu/hr~~
~~= 1017.316 MMBtu/hr for EU-07~~

Conclusion and Recommendation

The proposed modification shall be subject to the conditions of the attached proposed Part 70 Significant Source Modification No. 105-28904-00005 and Significant Permit Modification No. 105-28915-00005. The staff recommends to the Commissioner that this Part 70 Significant Source and Significant Permit Modification be approved.

Appendix A: Actual to Projected Actual Test

Company Name: Indiana University
Address City IN Zip: 2831 East Industrial Park Drive, Brazil, Indiana 47834
Permit Number: 105-28904-00005 and 105-28915-00005
Reviewer: Jillian Bertram
Date: 2/1/2010

Indiana University
Central Heating Plant Economizer Repair
Bloomington, Indiana

Project Emission Calculations - Baseline

Actual Emissions from Existing Boiler No. 3 (tons/year)

Pollutant	2007	2008
NO_x	70.79	58.27
SO_2	471.61	442.54
PM	71.39	58.77
PM_{10}	15.16	12.48
CO	32.25	26.54
VOC	0.32	0.26

Baseline Emissions from Existing Boiler No. 3 (tons/year)

Pollutant	2007/2008
NO_x	64.53
SO_2	457.075
PM	65.08
PM_{10}	13.82
CO	29.395
VOC	0.29

Actual Emissions from Existing Boiler No. 4 (tons/year)

Pollutant	2007	2008
NO_x	87.48	67.04
SO_2	573.74	508.75
PM	45.89	35.13
PM_{10}	9.74	7.46
CO	39.85	30.6
VOC	0.4	0.31

Baseline Emissions from Existing Boiler No. 4 (tons/year)

Pollutant	2007/2008
NO_x	77.26
SO_2	541.245
PM	40.51
PM_{10}	8.6
CO	35.225
VOC	0.355

Actual Emissions from Existing Boiler No. 6 (tons/year)

Pollutant	2007	2008
NO_x	193.79	190.86
SO_2	1274.25	1352.95
PM	38.52	37.63
PM_{10}	8.18	7.94
CO	88.33	87.37
VOC	0.94	1.02

Baseline Emissions from Existing Boiler No. 6 (tons/year)

Pollutant	2007/2008
NO_x	192.32475
SO_2	1313.6
PM	38.075
PM_{10}	8.06
CO	87.85
VOC	0.98

Total Emissions from Existing Boilers No. 3, No. 4 and No. 6 (tons/year)

Pollutant	2007/2008
NO_x	334.11
SO_2	2311.92
PM	143.67
PM_{10}	30.48
CO	152.47
VOC	1.63

Appendix A: Actual to Projected Actual Test

Company Name: Indiana University
Address City IN Zip: 2831 East Industrial Park Drive, Brazil, Indiana 47834
Permit Number: 105-28904-00005 and 105-28915-00005
Reviewer: Jillian Bertram
Date: 2/1/2010

Indiana University
Central Heating Plant Economizer Repair
Bloomington, Indiana

Base-Line to Future Actual Test

Boiler 3, 4, & 6 Baseline Emissions (2007/2008)

Pollutant	Tons/yr
NO_x	334.11
SO_2	2311.92
PM	143.67
PM_{10}	30.48
CO	152.47
VOC	1.63

Projected Actual Emissions

Pollutant	Tons/yr
NO_x	334.11
SO_2	2311.92
PM	143.67
PM_{10}	30.48
CO	152.47
VOC	1.63

Total Project Baseline Actuals to Projected Actual Test

Pollutant	Tons/yr
NO_x	0.00
SO_2	0.00
PM	0.00
PM_{10}	0.00
CO	0.00
VOC	0.00

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

SENT VIA U.S. MAIL: CONFIRMED DELIVERY AND SIGNATURE REQUESTED

TO: Mike Jensen
Indiana University
1514 East 3rd St
Bloomington, IN 47401

April 30, 2010

FROM: Matt Stuckey, Branch Chief
Permits Branch
Office of Air Quality

SUBJECT: Final Decision
Title V
105-28915-00005

Enclosed is the final decision and supporting materials for the air permit application referenced above. Please note that this packet contains the original, signed, permit documents.

The final decision is being sent to you because our records indicate that you are the contact person for this application. However, if you are not the appropriate person within your company to receive this document, please forward it to the correct person.

A copy of the final decision and supporting materials has also been sent via standard mail to:
OAQ Permits Branch Interested Parties List

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178, or toll-free at 1-800-451-6027 (ext. 3-0178), and ask to speak to the permit reviewer who prepared the permit. If you think you have received this document in error, please contact Joanne Smiddie-Brush of my staff at 1-800-451-6027 (ext 3-0185), or via e-mail at jbrush@idem.IN.gov.

Final Applicant Cover letter.dot 11/30/07

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

April 30, 2010

TO: Monroe Public Library

From: Matthew Stuckey, Branch Chief
Permits Branch
Office of Air Quality

Subject: **Important Information for Display Regarding a Final Determination**

Applicant Name: Indiana University
Permit Number: 105-28915-00005

You previously received information to make available to the public during the public comment period of a draft permit. Enclosed is a copy of the final decision and supporting materials for the same project. Please place the enclosed information along with the information you previously received. To ensure that your patrons have ample opportunity to review the enclosed permit, **we ask that you retain this document for at least 60 days.**

The applicant is responsible for placing a copy of the application in your library. If the permit application is not on file, or if you have any questions concerning this public review process, please contact Joanne Smiddie-Brush, OAQ Permits Administration Section at 1-800-451-6027, extension 3-0185.

Enclosures
Final Library.dot 11/30/07

Mail Code 61-53

IDEM Staff	CDENNY 4/30/2010 Indiana University 105-28915-00005 (final)			AFFIX STAMP HERE IF USED AS CERTIFICATE OF MAILING
Name and address of Sender	▶	Indiana Department of Environmental Management Office of Air Quality – Permits Branch 100 N. Senate Indianapolis, IN 46204	Type of Mail: **CERTIFICATE OF MAILING ONLY**	

Line	Article Number	Name, Address, Street and Post Office Address	Postage	Handing Charges	Act. Value (If Registered)	Insured Value	Due Send if COD	R.R. Fee	S.D. Fee	S.H. Fee	Rest. Del. Fee Remarks
1		Mike Jensen Indiana University 1514 East 3rd St Bloomington IN 47401 (Source CAATS)									
2		Monroe Co Public Library 303 E Kirkwood Ave Bloomington IN 47408 *(Library)*									
3		Bloomington City Council 401 North Morton Bloomington IN 47404 *(Affected Party)*									
4		Monroe County Health Department 119 W 7th St Bloomington IN 47404-3989 *(Health Department)*									
5		Mr. Anthony Sullivan Barnes & Thornburg 11 South Meridian Street Indianapolis IN 46204-3534 *(Attorney)*									
6		Mr. Randy Brown Plumbers & Steam Fitters Union, Local 136 2300 St. Joe Industrial Park Dr Evansville IN 47720 *(Affected Party)*									
7		Bloomington City Council and Mayors Office 401 N. Morton St. Bloomington IN 47402 *(Local Official)*									
8		Mr. Richard Monday 545 E. Margaret Dr. Terre Haute IN 47801 *(Affected Party)*									
9		Monroe County Commissioners Monroe County Courthouse, Room 322 Bloomington IN 47404 *(Local Official)*									
10		Mr. Joe Rubino Stanley Consultants, Inc. 100 Court Avenue, Suite 300 Des Moines IA 50309 *(Affected Party)*									
11											
12											
13											
14											
15											

Total number of pieces Listed by Sender	Total number of Pieces Received at Post Office	Postmaster, Per (Name of Receiving employee)	The full declaration of value is required on all domestic and international registered mail. The maximum indemnity payable for the reconstruction of nonnegotiable documents under Express Mail document reconstructing insurance is $50,000 per piece subject to a limit of $50, 000 per occurrence. The maximum indemnity payable on Express mil merchandise insurance is $500. The maximum indemnity payable is $25,000 for registered mail, sent with optional postal insurance. See ***Domestic Mail Manual*** **R900, S913**, and **S921** for limitations of coverage on inured and COD mail. See ***International Mail Manual*** for limitations o coverage on international mail. Special handling charges apply only to Standard Mail (A) and Standard Mail (B) parcels.

FACSIMILIE OF PS Form 3877