



# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

*Mitchell E. Daniels Jr.*  
Governor

*Thomas W. Easterly*  
Commissioner

100 North Senate Avenue  
Indianapolis, Indiana 46204  
(317) 232-8603  
Toll Free (800) 451-6027  
[www.idem.IN.gov](http://www.idem.IN.gov)

TO: Interested Parties / Applicant

DATE: January 3, 2011

RE: BP Products North America, Inc. - Indianapolis Terminal / 097 - 29901 - 00076

FROM: Matthew Stuckey, Branch Chief  
Permits Branch  
Office of Air Quality

## Notice of Decision – Approval

Please be advised that on behalf of the Commissioner of the Department of Environmental Management, I have issued a decision regarding the enclosed matter. Pursuant to 326 IAC 2, this approval was effective immediately upon submittal of the application.

If you wish to challenge this decision, IC 4-21.5-3-7 requires that you file a petition for administrative review. This petition may include a request for stay of effectiveness and must be submitted to the Office of Environmental Adjudication, 100 North Senate Avenue, Government Center North, Suite N 501E, Indianapolis, IN 46204, **within eighteen (18) calendar days from the mailing of this notice**. The filing of a petition for administrative review is complete on the earliest of the following dates that apply to the filing:

- (1) the date the document is delivered to the Office of Environmental Adjudication (OEA);
- (2) the date of the postmark on the envelope containing the document, if the document is mailed to OEA by U.S. mail; or
- (3) The date on which the document is deposited with a private carrier, as shown by receipt issued by the carrier, if the document is sent to the OEA by private carrier.

The petition must include facts demonstrating that you are either the applicant, a person aggrieved or adversely affected by the decision or otherwise entitled to review by law. Please identify the permit, decision, or other order for which you seek review by permit number, name of the applicant, location, date of this notice and all of the following:

- (1) the name and address of the person making the request;
- (2) the interest of the person making the request;
- (3) identification of any persons represented by the person making the request;
- (4) the reasons, with particularity, for the request;
- (5) the issues, with particularity, proposed for considerations at any hearing; and
- (6) identification of the terms and conditions which, in the judgment of the person making the request, would be appropriate in the case in question to satisfy the requirements of the law governing documents of the type issued by the Commissioner.

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178. Callers from within Indiana may call toll-free at 1-800-451-6027, ext. 3-0178.

Enclosures  
FNPER-AM.dot12/3/07



# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

*Mitchell E. Daniels Jr.*  
Governor

*Thomas W. Easterly*  
Commissioner

100 North Senate Avenue  
Indianapolis, Indiana 46204  
(317) 232-8603  
Toll Free (800) 451-6027  
[www.idem.IN.gov](http://www.idem.IN.gov)

Mr. William Fenton  
BP Products North America, Inc.  
2500 North Tibbs Avenue  
Indianapolis, IN 46222

January 3, 2011

Re: 097-29901-00076  
First Administrative Amendment to  
F097-25559-00076

Dear Mr. Fenton:

BP Products North America Inc. - Indianapolis Terminal was issued a Federally Enforceable State Operating Permit (FESOP) Renewal No. F097-25559-00076 on March 26, 2009 for a stationary petroleum product loading terminal located at 2500 North Tibbs Avenue, Indianapolis, Indiana 46222. On November 19, 2010, the Office of Air Quality (OAQ) received an application from the source relating to the retro fitting of existing storage tank #5 with an internal floating roof, and the change from kerosene to ethanol or distillate oil as a storage material. This change in operation will be incorporated into the permit as an administrative amendment, since the potential emissions of regulated criteria pollutants and hazardous air pollutants are less than the ranges specified 326 IAC 2-8-11.1(d)(4) and 326 IAC 2-8-11.1(f)(1)(G), respectively. The proposed change does not increase the tank (or source-wide) PTE. The entire source will continue to limit VOC emissions to less than 100 tons per twelve (12) consecutive month period, single HAP emissions to less than 10 tons per twelve (12) consecutive month period, and combined HAP emissions to less than 25 tons per twelve (12) consecutive month period, rendering the requirements of 326 IAC 2-7 and 326 IAC 2-4.1 not applicable. The addition of these units will not cause the source's potential to emit to be greater than the threshold levels specified in 326 IAC 2-2 or 326 IAC 2-3.

BP Products North America Inc. - Indianapolis Terminal will also be removing the decommissioned insignificant gasoline fuel transfer and dispensing operation and the petroleum fuel dispensing facility from the source and has asked that the permit be revised to reflect their removal.

Pursuant to the provisions of 326 IAC 2-8-10, the permit is hereby administratively amended as follows with the deleted language as ~~strikeouts~~ and new language **bolded**:

...  
A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-8-3(c)(3)]

This stationary source consists of the following emission units and pollution control devices:

- ...  
(f) Storage tank # 5, equipped with a ~~fixed roof~~ **an internal floating roof as of 2010**, 1,365,000 gallon storage capacity, used to store ~~Kerosene~~ **ethanol or distillate fuel oil**, and constructed in 1941.  
...

A.3 Insignificant Activities [326 IAC 2-7-1(21)][~~326 IAC 2-8-3(c)(3)(I)~~]

This stationary source also includes the following insignificant activities:

- ...  
(b) ~~A gasoline fuel transfer and dispensing operation handling less than or equal to 1,300 gallons per day, such as filling of tanks, locomotives, automobiles, having a storage capacity less than or equal to 10,500 gallons.~~

- ~~(c)~~ — A petroleum fuel, other than gasoline, dispensing facility, having a storage capacity of less than or equal to 10,500 gallons, and dispensing less than or equal to 230,000 gallons per month.
- ~~(c)(e)~~ Filling drums, pails or other packaging containers with lubricating oils, waxes, and grease.
- ~~(d)(f)~~ Cleaners and solvents characterized as follows:  
...
- ~~(e)(g)~~ Groundwater oil recovery wells.
- ~~(f)(h)~~ Activities associated with the treatment of wastewater streams with an oil and grease content less than or equal to 1% by volume.
- ~~(g)(i)~~ Process vessels degassing and cleaning to prepare for internal repair.
- ~~(h)(j)~~ Paved and unpaved roads and parking lots with public access.
- ~~(i)(k)~~ Equipment used to collect any material that might be released during a malfunction, process upset, or spill cleanup, including catch tanks, temporary liquid separators, tanks, and fluid handling equipment.
- ~~(j)(l)~~ On-site fire and emergency response training approved by the department.
- ~~(k)(m)~~ Filter or coalescer media changeout.
- ~~(l)(n)~~ Laboratory as defined in 326 IAC 2-7-1(21)(D)
- ~~(m)(o)~~ The following facilities with VOC emissions less than 3 (three) pounds per hour or (15) fifteen pounds per day:  
...
- ~~(n)(p)~~ Degreasing operations that do not exceed 145 gallons per 12 months, except if subject to 326 IAC 20-6. [326 IAC 8-3-2] [326 IAC 8-3-5]  
...

SECTION D.2 EMISSIONS UNIT OPERATION CONDITIONS

Emission Unit Description [326 IAC 2-8-4 (10)]
...
(f) Storage tank # 5, equipped with <del>a fixed roof</del> <b>an internal floating roof as of 2010</b> , 1,365,000 gallon storage capacity, used to store <del>Kerosene ethanol or distillate fuel oil</del> , and constructed in 1941.
...
(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

...

IDEM, OAQ has decided to make additional revisions to the permit as described below in order to update the language to match the most current version of the applicable rule, to eliminate redundancy within the permit, and to provide clarification regarding the requirements of these conditions.

1. Section A.1 of the permit and the reporting forms have been revised to remove all references to the source mailing address. IDEM, OAQ will continue to maintain records of the mailing address.

2. For clarity, IDEM has changed references to the general conditions: "in accordance with Section B", in accordance with Section C", or other similar language to "Section C...contains the Permittee's obligations with regard to the records required by this condition."
3. IDEM has decided that the phrases "no later than" and "not later than" are clearer than "within" in relation to the end of a timeline. Therefore all timelines have been switched to "no later than" or "not later than" except when the underlying rule states "within."
4. IDEM has decided to clarify throughout the permit that a certification needs to meet the requirements of 326 IAC 2-8-5(a)(1). In addition, IDEM has decided to remove the last sentence dealing with the need for certification from the forms because the conditions requiring the forms already addresses this issue.
5. IDEM has decided to clarify the certification requirements in Section B - Duty to Provide Information and Section B - Certification.
6. IDEM has decided to clarify the requirements of Section B – Preventive Maintenance Plan and to add a new paragraph (b) to handle a future situation where the Permittee adds units that need preventive maintenance plans.
7. IDEM has revised the language of the Section B - Preventive Maintenance Plan, Section C - Compliance Monitoring, Section C - General Record Keeping, and Section C - General Reporting to allow the Permittee to not have to begin implementing the requirements of these conditions until ninety days after initial start up.
8. IDEM has revised Section B - Emergency Provisions to delete paragraph (h). 326 IAC 2-8-4(3)(C)(ii) allows that deviations reported under an independent requirement do not have to be included in the Quarterly Deviation and Compliance Monitoring Report.
9. IDEM has decided that having a separate condition for the reporting of deviations is unnecessary. Therefore, IDEM has removed Section B - Deviation form Permit Requirements and Conditions and added the requirements of that condition to Section C - General Reporting Requirements. Paragraph (d) of Section C - General Reporting Requirements has been removed because IDEM already states the timeline and certification needs of each report in the condition requiring the report.
10. IDEM has revised Section B - Permit Renewal paragraph (c) to state which rule establishes the authority to set a deadline for the Permittee to submit additional information.
11. IDEM has added 326 IAC 5-1-1 to the exception clause of Section C - Opacity, since 326 IAC 5-1-1 does list exceptions.
12. IDEM has revised Section C - Incineration to more closely reflect the two underlying rules.
13. IDEM has removed the first paragraph of Section C - Performance Testing as due to the fact that specific testing conditions elsewhere in the permit will specify the timeline and procedures.
14. IDEM has revised Section C - Compliance Monitoring. The reference to recordkeeping has been removed due to the fact that other conditions already address recordkeeping. The voice of the condition has been change to clearly indicate that it is the Permittee that must follow the requirements of the condition
15. IDEM has removed Section C - Monitoring Methods. The conditions that require the monitoring or testing, if required, state what methods shall be used.

16. IDEM has revised Section C - Response to Excursions or Exceedances. The introduction sentence has been added to clarify that it is only when an excursion or exceedance is detected that the requirements of this condition need to be followed. The word "excess" was added to the last sentence of paragraph (a) because the Permittee only has to minimize excess emissions. The middle of paragraph (b) has been deleted as it was duplicative of paragraph (a). The phrase "or are returning" was added to subparagraph (b)(2) as this is an acceptable response assuming the operation or emission unit does return to normal or its usual manner of operation. The phrase "within the indicator range, designated condition, or below the applicable emission limitation or standard, as applicable" was replaced with "normal or usual manner of operation" because the first phrase is just a limited list of the second phrase. The recordkeeping required by paragraph (e) was changed to require only records of the response because the previously listed items are required to be recorded elsewhere in the permit.
17. IDEM has revised Section C - Actions Related to Noncompliance Demonstrated by a Stack Test. The requirements to take response steps and minimize excess emissions have been removed because Section C - Response to Excursions or Exceedances already requires response steps related to exceedances and excess emissions minimization. The start of the timelines was switched from "the receipt of the test results" to "the date of the test." There was confusion if the "receipt" was by IDEM, the Permittee, or someone else. Since the start of the timelines has been moved up, the length of the timelines was increased. The new timelines require action within a comparable timeline; and the new timelines still ensure that the Permittee will return to compliance within a reasonable timeframe.
18. The voice of paragraph (b) of Section C - General Record Keeping Requirements has been changed to clearly indicate that it is the Permittee that must follow the requirements of the paragraph.
19. IDEM has decided to simplify the referencing in Section C - Compliance with 40 CFR 82 and 326 IAC 22-1.
20. The word "status" has been added to Section D - Record Keeping Requirements and Section D - Reporting Requirements. The Permittee has the obligation to document the compliance status. The wording has been revised to properly reflect this.
21. The phrase "of this permit" has been added to the paragraph of the Quarterly Deviation and Compliance Monitoring Report Form to match the underlying rule.
22. IDEM has decided to move the NSPS Subpart XX requirements from Sections D.1.10 and D.1.11 to Section E.1.
23. Pursuant to the Federal Register 73 FR 1933 published January 10, 2008, the requirements of 40 CFR 63, Subpart BBBB, National Emission Standards for Hazardous Air Pollutants (NESHAP) for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities are applicable to the petroleum product loading terminal because it is considered a bulk gasoline terminal that is not subject to the control requirements of 40 CFR part 63, subpart R or 40 CFR part 63, subpart CC.

The permit has been revised to include the applicable NESHAP BBBB requirements in Section E.2, and NESHAP BBBB has been included in its entirety as Attachment B to the permit.

The permit has been revised as follows with deleted language as ~~strikeouts~~ and new language **bolded**:

...

A.1 General Information [326 IAC 2-8-3(b)]

---

The Permittee owns and operates a stationary petroleum product loading terminal.

Source Address: 2500 North Tibbs Avenue, Indianapolis, Indiana 46222  
Mailing Address: 150 W. Warrenville Rd. Bldg. 502, 1225, Naperville, IL 60563  
General Source Phone Number: 317-926-5471

...

A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-8-3(c)(3)]

---

This stationary source consists of the following emission units and pollution control devices:

...

- (g) Storage tank #6, equipped with an external pontoon floating roof with a dome, 3,150,000 gallon storage capacity, used to store Subgrade/regular gasoline, and constructed in 1941.

**Under 40 CFR Part 63, Subpart BBBBBB, Storage tank #6 is an affected facility.**

- (h) Storage tank #7, equipped with an external pontoon floating roof with a dome, 3,150,000 gallon storage capacity, used to store Subgrade/ regular gasoline, and constructed in 1941.

**Under 40 CFR Part 63, Subpart BBBBBB, Storage tank #7 is an affected facility.**

- (i) Storage tank #8, equipped with an external pontoon floating roof with a dome, 3,150,000 gallon storage capacity, used to store Premium gasoline, and constructed in 1942.

**Under 40 CFR Part 63, Subpart BBBBBB, Storage tank #8 is an affected facility.**

...

A.3 Insignificant Activities [326 IAC 2-7-1(21)][326 IAC 2-8-3(c)(3)(I)]

---

This stationary source also includes the following insignificant activities:

...

- ~~(m)(e)~~ The following facilities with VOC emissions less than 3 (three) pounds per hour or (15) fifteen pounds per day which are not specified in form GSD10(a) of the application:

...

B.7 Duty to Provide Information [326 IAC 2-8-4(5)(E)]

---

- (a) The Permittee shall furnish to IDEM, OAQ, within a reasonable time, any information that IDEM, OAQ may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. ~~The submittal by the Permittee does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).~~ Upon request, the Permittee shall also furnish to IDEM, OAQ copies of records required to be kept by this permit.

...

B.8 Certification [326 IAC 2-8-3(d)][326 IAC 2-8-4(3)(C)(i)][326 IAC 2-8-5(1)]

---

- (a) ~~Where specifically designated by this permit or required by an applicable requirement, any application form, report, or compliance certification submitted shall contain certification by an "authorized individual" of truth, accuracy, and completeness. This certification shall state that,~~ **A certification required by this permit meets the requirements of 326 IAC 2-8-5(a)(1) if:**

- (1) it contains a certification by an "authorized individual", as defined by 326 IAC 2-1.1-1(1), and**

(2) **the certification states that**, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

(b) ~~One (1) certification shall be included, using~~**The Permittee may use** the attached Certification Form, **or its equivalent** with each submittal requiring certification. One (1) certification may cover multiple forms in one (1) submittal.

...

B.9 Annual Compliance Certification [326 IAC 2-8-5(a)(1)]

---

...

(c) The annual compliance certification report shall include the following:

...

The submittal by the Permittee does require ~~the a~~ certification **that meets the requirements of 326 IAC 2-8-5(a)(1)** by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

...

B.11 Preventive Maintenance Plan [326 IAC 1-6-3][326 IAC 2-8-4(9)][326 IAC 2-8-5(a)(1)]

---

~~(a) If required by specific condition(s) in Section D of this permit, the Permittee shall maintain and implement Preventive Maintenance Plans (PMPs) including the following information on each facility:~~

(a) **A Preventive Maintenance Plan meets the requirements of 326 IAC 1-6-3 if it includes, at a minimum:**

- (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;
- (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
- (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

**The Permittee shall implement the PMPs.**

(b) **If required by specific condition(s) in Section D of this permit where no PMP was previously required, the Permittee shall prepare and maintain Preventive Maintenance Plans (PMPs) no later than ninety (90) days after issuance of this permit or ninety (90) days after initial start-up, whichever is later, including the following information on each facility and its control device:**

- (1) **Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;**
- (2) **A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and**
- (3) **Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.**

**If, due to circumstances beyond the Permittee's control, the PMPs cannot be prepared and maintained within the above time frame, the Permittee may extend the date an additional ninety (90) days provided the Permittee notifies:**

**Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251**

**The PMP extension notification does not require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).**

**The Permittee shall implement the PMPs.**

- (bc) A copy of the PMPs shall be submitted to IDEM, OAQ upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. IDEM, OAQ may require the Permittee to revise its PMPs whenever lack of proper maintenance causes or is the primary contributor to an exceedance of any limitation on emissions or potential to emit. ~~The PMPs and their submittal do not require the certification a~~ **certification that meets the requirements of 326 IAC 2-8-5(a)(1)** by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (ed) To the extent the Permittee is required by 40 CFR Part 60/63 to have an Operation Maintenance, and Monitoring (OMM) Plan for a unit, such Plan is deemed to satisfy the PMP requirements of 326 IAC 1-6-3 for that unit.

**B.12 Emergency Provisions [326 IAC 2-8-12]**

---

- ...
- (b) An emergency, as defined in 326 IAC 2-7-1(12), constitutes an affirmative defense to an action brought for noncompliance with a health-based or technology-based emission limitation if the affirmative defense of an emergency is demonstrated through properly signed, contemporaneous operating logs or other relevant evidence that describe the following:
- ...
- Telephone Number: 1-800-451-6027 (ask for Office of Air Quality, Compliance ~~Section~~ **and Enforcement Branch**), or  
Telephone Number: 317-233-0178 (ask for **Office of Air Quality, Compliance ~~Section~~ and Enforcement Branch**)  
Facsimile Number: 317-233-6865
- ...
- The notification which shall be submitted by the Permittee does not require ~~the a~~ certification **that meets the requirements of 326 IAC 2-8-5(a)(1)** by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- ...
- ~~(h) The Permittee shall include all emergencies in the Quarterly Deviation and Compliance Monitoring Report.~~
- ...

**B.15 Deviations from Permit Requirements and Conditions [326 IAC 2-8-4(3)(C)(ii)] ~~Reserved~~**

---

- ~~(a) Deviations from any permit requirements (for emergencies see Section B—Emergency Provisions), the probable cause of such deviations, and any response steps or preventive measures taken shall be reported to:~~

~~Indiana Department of Environmental Management  
Compliance Data Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2254~~

~~using the attached Quarterly Deviation and Compliance Monitoring Report, or its equivalent. A deviation required to be reported pursuant to an applicable requirement that exists independent of this permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report.~~

~~The Quarterly Deviation and Compliance Monitoring Report does require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).~~

- ~~(b) — A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit.~~

B.16 Permit Modification, Reopening, Revocation and Reissuance, or Termination  
[326 IAC 2-8-4(5)(C)][326 IAC 2-8-7(a)][326 IAC 2-8-8]

---

- (a) This permit may be modified, reopened, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a Federally Enforceable State Operating Permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any condition of this permit. [326 IAC 2-8-4(5)(C)] The notification by the Permittee does require ~~the certification a~~ **certification that meets the requirements of 326 IAC 2-8-5(a)(1)** by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

...

B.17 Permit Renewal [326 IAC 2-8-3(h)]

---

- (a) The application for renewal shall be submitted using the application form or forms prescribed by IDEM, OAQ and shall include the information specified in 326 IAC 2-8-3. Such information shall be included in the application for each emission unit at this source, except those emission units included on the trivial or insignificant activities list contained in 326 IAC 2-7-1(21) and 326 IAC 2-7-1(40). The renewal application does require ~~the a~~ **certification that meets the requirements of 326 IAC 2-8-5(a)(1)** by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

...

- (c) If the Permittee submits a timely and complete application for renewal of this permit, the source's failure to have a permit is not a violation of 326 IAC 2-8 until IDEM, OAQ takes final action on the renewal application, except that this protection shall cease to apply if, subsequent to the completeness determination, the Permittee fails to submit by the deadline specified, **pursuant to 326 IAC 2-8-3(g)**, in writing by IDEM, OAQ any additional information identified as being needed to process the application.

B.18 Permit Amendment or Revision [326 IAC 2-8-10][326 IAC 2-8-11.1]

---

...

~~Any such application shall be certified~~ **does require a certification that meets the requirements of 326 IAC 2-8-5(a)(1)** by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

...

B.22 Transfer of Ownership or Operational Control [326 IAC 2-8-10]

---

...

~~The~~**Any such** application ~~which shall be submitted by the Permittee~~ does require ~~the a~~ certification **that meets the requirements of 326 IAC 2-8-5(a)(1)** by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

...

**B.23 Annual Fee Payment** [326 IAC 2-7-19][326 IAC 2-8-4(6)][326 IAC 2-8-16][326 IAC 2-1.1-7]

- (a) The Permittee shall pay annual fees to IDEM, OAQ ~~with~~**no later than** thirty (30) calendar days of receipt of a billing. Pursuant to 326 IAC 2-7-19(b), if the Permittee does not receive a bill from IDEM, OAQ the applicable fee is due April 1 of each year.

...

**C.3 Opacity** [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in **326 IAC 5-1-1 (Applicability) and 326 IAC 5-1-3** (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

...

**C.5 Incineration** [326 IAC 4-2][326 IAC 9-1-2]

The Permittee shall not operate an incinerator ~~or incinerate any waste or refuse~~ except as provided in 326 IAC 4-2 ~~and 326 IAC 9-1-2~~ **or in this permit. The Permittee shall not operate a refuse incinerator or refuse burning equipment except as provided in 326 IAC 9-1-2 or in this permit.**

...

**C.8 Performance Testing** [326 IAC 3-6]

- (a) ~~All testing shall be performed according to the provisions of 326 IAC 3-6 (Source Sampling Procedures), except as provided elsewhere in this permit, utilizing any applicable procedures and analysis methods specified in 40 CFR 51, 40 CFR 60, 40 CFR 61, 40 CFR 63, 40 CFR 75, or other procedures approved by IDEM, OAQ.~~

**A**For performance testing required by this permit, a test protocol, except as provided elsewhere in this permit, shall be submitted to:

...

no later than thirty-five (35) days prior to the intended test date. The protocol submitted by the Permittee does not require **a certification that meets the requirements of 326 IAC 2-8-5(a)(1)** by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (b) The Permittee shall notify IDEM, OAQ of the actual test date at least fourteen (14) days prior to the actual test date. The notification submitted by the Permittee does not require **a certification that meets the requirements of 326 IAC 2-8-5(a)(1)** by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

...

**C.10 Compliance Monitoring** [326 IAC 2-8-4(3)][326 IAC 2-8-5(a)(1)]

Unless otherwise specified in this permit, ~~for all monitoring and record keeping requirements not already legally required,~~ **the Permittee shall be allowed up to** ~~shall be implemented within ninety (90) days of~~ **from the date of permit issuance or of initial start-up, whichever is later, to begin such monitoring.** ~~If required by Section D, the Permittee shall be responsible for installing any necessary equipment and initiating any required monitoring related to that equipment.~~ ~~If due to circumstances beyond~~ ~~the Permittee's control,~~ **that any monitoring equipment required by this permit cannot be installed and operated** ~~with~~**no later than** ninety (90) days **after permit issuance or the date of initial startup, whichever is later,** the Permittee may extend the

compliance schedule related to the equipment for an additional ninety (90) days provided the Permittee notifies:

...

The notification which shall be submitted by the Permittee does require ~~the a~~ certification **that meets the requirements of 326 IAC 2-8-5(a)(1)** by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

...

**C.11 Monitoring Methods [326 IAC 3][40 CFR 60][40 CFR 63]Reserved**

~~Any monitoring or testing required by Section D of this permit shall be performed according to the provisions of 326 IAC 3, 40 CFR 60, Appendix A, 40 CFR 60 Appendix B, 40 CFR 63, or other approved methods as specified in this permit.~~

...

**C.14 Response to Excursions or Exceedances [326 IAC 2-8-4][326 IAC 2-8-5]**

**Upon detecting an excursion where a response step is required by the D Section or an exceedance of a limitation in this permit:**

(a) ~~Upon detecting an excursion or exceedance, the~~ **The** Permittee shall **take reasonable response steps** to restore operation of the emissions unit (including any control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing **excess** emissions.

(b) The response shall include minimizing the period of any startup, shutdown or malfunction ~~and taking any necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of an excursion or exceedance (other than those caused by excused startup or shutdown conditions).~~ **Corrective actions. The response** may include, but ~~are~~**is** not limited to, the following:

- (1) initial inspection and evaluation;
- (2) recording that operations returned **or are returning** to normal without operator action (such as through response by a computerized distribution control system); or
- (3) any necessary follow-up actions to return operation to ~~within the indicator range, designated condition, or below the applicable emission limitation or standard,~~ as applicable **normal or usual manner of operation.**

...

(e) The Permittee shall ~~record~~ maintain the following records **the reasonable response steps taken.:**

- ~~(1) monitoring data;~~
- ~~(2) monitor performance data, if applicable; and~~
- ~~(3) corrective actions taken.~~

**C.15 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-8-4][326 IAC 2-8-5]**

(a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this permit exceed the level specified in any condition of this permit, the ~~Permittee shall take appropriate response actions.~~ The Permittee shall submit a description of ~~these~~**its** response actions to IDEM, OAQ, ~~within~~ **no later than thirty (30) days of receipt of the test resultsseventy-five (75) days after the date of the test.** ~~The~~

~~Permittee shall take appropriate action to minimize excess emissions from the affected facility while the response actions are being implemented.~~

- (b) A retest to demonstrate compliance shall be performed ~~within~~ **no later than** one hundred and ~~twenty (120) days of receipt of the original test results~~ **eighty (180) days after the date of the test**. Should the Permittee demonstrate to IDEM, OAQ that retesting in one hundred ~~twenty (120)~~ **eighty (180)** days is not practicable, IDEM, OAQ may extend the retesting deadline.
- (c) IDEM, OAQ reserves the authority to take any actions allowed under law in response to noncompliant stack tests.

The response action documents submitted pursuant to this condition do require ~~the a~~ certification **that meets the requirements of 326 IAC 2-8-5(a)(1)** by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

C.16 General Record Keeping Requirements [326 IAC 2-8-4(3)][326 IAC 2-8-5]

---

- ...
- (b) Unless otherwise specified in this permit, **for** all record keeping requirements not already legally required, **the Permittee shall be allowed up to** ~~shall be implemented within~~ ninety (90) days **from the date of permit issuance or the date of initial start-up, whichever is later, to begin such record keeping.**

C.17 General Reporting Requirements [326 IAC 2-8-4(3)(C)][326 IAC 2-1.1-11]

---

- (a) The Permittee shall submit the attached Quarterly Deviation and Compliance Monitoring Report or its equivalent. Any deviation from permit requirements, the date(s) of each deviation, the cause of the deviation, and the response steps taken must be reported. **except that a deviation required to be reported pursuant to an applicable requirement that exists independent of this permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report.** This report shall be submitted ~~within~~ **not later than** thirty (30) days ~~after~~ the end of the reporting period. The Quarterly Deviation and Compliance Monitoring Report shall include ~~the a~~ certification **that meets the requirements of 326 IAC 2-8-5(a)(1)** by an "authorized individual" as defined by 326 IAC 2-1.1-1(1). **A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit.**
- (b) ~~The report required in (a) of this condition and reports required by conditions in Section D of this permit shall be submitted to~~ **address for report submittal is:**
- ...
- ~~(d) Unless otherwise specified in this permit, all reports required in Section D of this permit shall be submitted within thirty (30) days of the end of the reporting period. All reports do require the certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).~~
- (de)** Reporting periods are based on calendar years, unless otherwise specified in this permit. For the purpose of this permit "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.

C.18 ~~19~~ Compliance with 40 CFR 82 and 326 IAC 22-1

---

Pursuant to 40 CFR 82 (Protection of Stratospheric Ozone), Subpart F, except as provided for motor vehicle air conditioners in Subpart B, the Permittee shall comply with ~~the~~ **applicable** standards for recycling and emissions reduction.:

- ~~(a) Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to 40 CFR 82.156.~~

~~(b) Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to 40 CFR 82.158.~~

~~(c) Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161.~~

...

#### SECTION D.1 EMISSIONS UNIT OPERATION CONDITIONS

Emissions Unit Description[326 IAC 2-8-4(10)]:

(a) One (1) loading rack for dispensing of petroleum product, with one (1) carbon adsorber, identified as V10, for control of volatile organic compounds. Loading rack installed in 1993.

~~Under the Standards of Performance for Bulk Gasoline Terminals (40 CFR Part 60, Subpart XX), the petroleum products loading rack is an affected facility.~~

**Under 40 CFR Part 63, Subpart BBBB, the petroleum products loading rack is an affected facility.**

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

...

#### D.1.4 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

~~A Preventive Maintenance Plan, in accordance with Section B – Preventive Maintenance Plan, of this permit, is required for this facility and any control devices~~ **the loading rack and carbon adsorber vapor recovery unit. Section B – Preventive Maintenance Plan contains the Permittee’s obligation with regard to the preventive maintenance plan required by this condition.**

...

#### D.1.6 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11]

(a) To demonstrate compliance with Condition D.1.1(a), a compliance stack test shall be performed ~~within~~ **no later than** five (5) years from the date of the most recent valid compliance demonstration, at the exhaust of the carbon adsorber vapor recovery unit. This test shall be performed according to 40 CFR 60, Appendix A, Methods 25 and 25A.

...

#### D.1.8 Record Keeping Requirements

(a) To document **the compliance status** with Condition D.1.1(a), the Permittee shall maintain records at the source of the volume in gallons of each fuel ~~received~~ **dispensed** at the loading rack, including purchase orders and invoices necessary to verify the type and amount ~~used~~ **dispensed**;

(b) To document **the compliance status** with D.1.3(f), the owner or operator of a vapor balance or vapor control system subject to this section shall maintain records of all compliance testing. The records shall identify the following:

- (1) The vapor balance, vapor collection, or vapor control system.
- (2) The date of the test and, if applicable, retest.
- (3) The results of the test and, if applicable, retest.

The records shall be maintained in a legible, readily available condition for at least two (2) years after the date the testing and, if applicable, retesting were completed.

- (c) To document **the** compliance **status** with Condition D.1.3(a), the owner or operator of a gasoline transport subject to this section shall keep a legible copy of the transport's most recent valid annual modified 40 CFR 60, Appendix A, Method 27 test either in the cab of the transport or affixed to the transport trailer. The test record shall identify the following:
- (1) The gasoline transport.
  - (2) The type and date of the test and, if applicable, date of retest.
  - (3) The test methods, test data, and results certified as true, accurate, and in compliance with this rule by the person who performs the test.

This copy shall be made available immediately upon request to the department and to the owner of the loading facility for inspection and review. The department shall be allowed to make copies of the test results.

- (d) To document **the** compliance **status** with Condition D.1.7, the Permittee shall maintain records of the following operation parameters of the carbon adsorber vapor recovery unit:
- (1) bed pressure; and
  - (2) vacuum level.
- (e) **Section C - General Record Keeping Requirements of this permit contains the Permittee's obligations with regard to the records required by this condition.**

#### D.1.9 Reporting Requirements

---

A quarterly summary of the information to document compliance with Conditions D.1.1 shall be submitted ~~to the address listed in Section C - General Reporting Requirements, of this permit,~~ using the reporting forms located at the end of this permit, or their equivalent, **within no later than thirty (30) days after the end of the period being reported. Section C - General Reporting contains the Permittee's obligation with regard to the reporting required by this condition.** The report submitted by the Permittee does require ~~the a~~ certification **that meets the requirements of 326 IAC 2-8-5(a)(1)** by ~~the an~~ "authorized individual" as defined by 326 IAC 2-1.1-1(1).

#### New Source Performance Standards (NSPS) Requirements [326 IAC 2-7-5(1)]

##### ~~D.1.10 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]~~

~~Pursuant to 40 CFR 60.500, the Permittee shall comply with the provisions of 40 CFR Part 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, except when otherwise specified in 40 CFR Part 60, Subpart XX.~~

##### ~~D.1.11 New Source Performance Standards (NSPS) Standards of Performance for Bulk Gasoline Terminals [326 IAC 12][40 CFR Part 60, Subpart XX]~~

~~The Permittee which operates a bulk gasoline terminal loading rack shall comply with the following provisions of 40 CFR Part 60, Subpart XX (included as Attachment A of this permit):~~

- ~~(1) 40 CFR 60.500 (a) and (b)~~
- ~~(2) 40 CFR 60.501~~
- ~~(3) 40 CFR 60.502~~
- ~~(4) 40 CFR 60.503~~
- ~~(5) 40 CFR 60.505~~
- ~~(6) 40 CFR 60.506~~

...

SECTION D.2 EMISSIONS UNIT OPERATION CONDITIONS

Emission Unit Description [326 IAC 2-8-4 (10)]
...
(g) Storage tank #6, equipped with an external pontoon floating roof with a dome, 3,150,000 gallon storage capacity, used to store Subgrade/regular gasoline, and constructed in 1941.  <b>Under 40 CFR Part 63, Subpart BBBBBB, Storage tank #6 is an affected facility.</b>
(h) Storage tank #7, equipped with an external pontoon floating roof with a dome, 3,150,000 gallon storage capacity, used to store Subgrade/ regular gasoline, and constructed in 1941.  <b>Under 40 CFR Part 63, Subpart BBBBBB, Storage tank #7 is an affected facility.</b>
(i) Storage tank #8, equipped with an external pontoon floating roof with a dome, 3,150,000 gallon storage capacity, used to store Premium gasoline, and constructed in 1942.  <b>Under 40 CFR Part 63, Subpart BBBBBB, Storage tank #8 is an affected facility.</b>
...
(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

...

D.2.2 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

~~A Preventive Maintenance Plan, in accordance with Section B – Preventive Maintenance Plan, of this permit, is required for this facility and its control device~~ **these storage tanks and their floating roofs (as applicable). Section B – Preventive Maintenance Plan contains the Permittee’s obligation with regard to the preventive maintenance plan required by this condition.**

...

D.2.4 Record Keeping Requirements [326 IAC 8-4-3(d)]

- (a) To document ~~the~~ **compliance status** with Condition D.2.1(b), the Permittee shall maintain records of results of the quarterly inspections required in conditions D.2.3.
- (b) Pursuant to 326 IAC 8-4-3(d), the Permittee of storage tanks 1, 2, 3, 4, 5, 6, 7, 8,10 and 11 shall maintain the following records:
- (1) petroleum liquid stored,
  - (2) the period of storage, and
  - (3) the maximum true vapor pressure of that liquid during the respective storage period.
- (c) ~~All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit~~ **contains the Permittee’s obligations with regard to the records required by this condition.**

...

**SECTION E.1 FACILITY OPERATION CONDITIONS - 40 CFR 60, Subpart XX - New Source Performance Standards for Bulk Gasoline Terminals**

**Facility Description [326 IAC 2-8-4(10)]:**

**Emission Units**

- (a) One (1) loading rack for dispensing of petroleum product, with one (1) carbon adsorber, identified as V10, for control of volatile organic compounds. Loading rack installed in 1993.

Under 40 CFR Part 60, Subpart XX and 40 CFR Part 63, Subpart BBBB, the petroleum products loading rack is an affected facility.

The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

**New Source Performance Standards (NSPS) Requirements:**

**E.1.1 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]**

Pursuant to 40 CFR 60.500, the Permittee shall comply with the provisions of 40 CFR Part 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, except when otherwise specified in 40 CFR Part 60, Subpart XX.

**E.1.2 New Source Performance Standards (NSPS) Standards of Performance for Bulk Gasoline Terminals [326 IAC 12][40 CFR Part 60, Subpart XX]**

The Permittee which operates a bulk gasoline terminal loading rack shall comply with the following provisions of 40 CFR Part 60, Subpart XX (included as Attachment A of this permit):

- (1) 40 CFR 60.500 (a) and (b)
- (2) 40 CFR 60.501
- (3) 40 CFR 60.502
- (4) 40 CFR 60.503
- (5) 40 CFR 60.505
- (6) 40 CFR 60.506

**SECTION E.2 FACILITY OPERATION CONDITIONS - 40 CFR 63, Subpart BBBB - National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities**

**Facility Description [326 IAC 2-8-4(10)]:**

**Emission Units**

- (a) One (1) loading rack for dispensing of petroleum product, with one (1) carbon adsorber, identified as V10, for control of volatile organic compounds. Loading rack installed in 1993.

Under 40 CFR Part 60, Subpart XX and 40 CFR Part 63, Subpart BBBB, the petroleum products loading rack is an affected facility.

<p><b>(g)</b></p> <p><b>Storage tank #6, equipped with an external pontoon floating roof with a dome, 3,150,000 gallon storage capacity, used to store Subgrade/regular gasoline, and constructed in 1941.</b></p> <p><b>Under 40 CFR Part 63, Subpart BBBBBB, Storage tank #6 is an affected facility.</b></p> <p><b>(h)</b></p> <p><b>Storage tank #7, equipped with an external pontoon floating roof with a dome, 3,150,000 gallon storage capacity, used to store Subgrade/ regular gasoline, and constructed in 1941.</b></p> <p><b>Under 40 CFR Part 63, Subpart BBBBBB, Storage tank #7 is an affected facility.</b></p> <p><b>(i)</b></p> <p><b>Storage tank #8, equipped with an external pontoon floating roof with a dome, 3,150,000 gallon storage capacity, used to store Premium gasoline, and constructed in 1942.</b></p> <p><b>Under 40 CFR Part 63, Subpart BBBBBB, Storage tank #8 is an affected facility.</b></p> <p><b>(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)</b></p>
--

**National Emission Standards for Hazardous Air Pollutants (NESHAP) Requirements:**

**E.2.1 General Provisions Relating to National Emissions Standards for Hazardous Air Pollutants under 40 CFR Part 63 [326 IAC 20-1] [40 CFR Part 63, Subpart A]**

- (a) Pursuant to 40 CFR 63.11098, the Permittee shall comply with the provisions of 40 CFR Part 63, Subpart A – General Provisions, which are incorporated by reference as 326 IAC 20-1, for the bulk gasoline terminal as specified in Table 3 of 40 CFR Part 63, Subpart BBBBBB in accordance with the schedule in 40 CFR 63, Subpart BBBBBB.**
- (b) Pursuant to 40 CFR 63.10, the Permittee shall submit all required notifications and reports to:**

**Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251**

**E.2.2 National Emissions Standards for Hazardous Air Pollutants for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities [40 CFR Part 63, Subpart BBBBBB]**

**The Permittee shall comply with the following provisions of 40 CFR Part 63, Subpart BBBBBB (included as Attachment B) which are incorporated by reference as 326 IAC 20-1 for the bulk gasoline terminal:**

- (1) 40 CFR 63.11080**
- (2) 40 CFR 63.11081(a)(1),(b)**
- (3) 40 CFR 63.11082(a),(d)**
- (4) 40 CFR 63.11083(b),(c)**
- (5) 40 CFR 63.11087**
- (6) 40 CFR 63.11088**
- (7) 40 CFR 63.11089**
- (8) 40 CFR 63.11092(a)(2),(b),(c),(d),(e)(2),(f)**

- (9) 40 CFR 63.11093
- (10) 40 CFR 63.11094
- (11) 40 CFR 63.11095(a),(b)
- (12) 40 CFR 63.11098
- (13) 40 CFR 63.11099
- (14) 40 CFR 63.11100
- (15) Table 1
- (16) Table 2
- (17) Table 3

...

FESOP CERTIFICATION FORM:

...

Mailing Address: ~~150 W. Warrenville Rd. Bldg. 502, 1225, Naperville, IL 60563~~

...

FESOP EMERGENCY OCCURRENCE REPORT FORM:

...

Mailing Address: ~~150 W. Warrenville Rd. Bldg. 502, 1225, Naperville, IL 60563~~

...

~~A certification is not required for this report.~~

...

FESOP QUARTERLY REPORT FORM:

...

Mailing Address: ~~150 W. Warrenville Rd. Bldg. 502, 1225, Naperville, IL 60563~~

...

~~Attach a signed certification to complete this report.~~

...

FESOP QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT FORM:

...

Mailing Address: ~~150 W. Warrenville Rd. Bldg. 502, 1225, Naperville, IL 60563~~

...

This report shall be submitted quarterly based on a calendar year. Any deviation from the requirements **of this permit**, the date(s) of each deviation, the probable cause of the deviation, and the response steps taken must be reported. A deviation required to be reported pursuant to an applicable requirement that exists independent of the permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. Additional pages may be attached if necessary. If no deviations occurred, please specify in the box marked "No deviations occurred this reporting period".

...

~~Attach a signed certification to complete this report.~~

...

**Attachment B: 40 CFR 63, Subpart BBBBBB, National Emission Standard for Hazardous Air Pollutants for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities** (note: 40 CFR Part 63, Subpart BBBBBB, is now included in its entirety in the permit as Attachment B, but is not shown in its entirety as bold text in this letter)

...

All other conditions of the permit shall remain unchanged and in effect. Attached please find the

All other conditions of the permit shall remain unchanged and in effect. Attached please find the entire revised permit.

A copy of the permit is available on the Internet at: <http://www.in.gov/ai/appfiles/idem-caats/>. For additional information about air permits and how the public and interested parties can participate, refer to the IDEM's Guide for Citizen Participation and Permit Guide on the Internet at: [www.idem.in.gov](http://www.idem.in.gov)

This decision is subject to the Indiana Administrative Orders and Procedures Act - IC 4-21.5-3-5. If you have any questions on this matter, please contact Jason R. Krawczyk, of my staff, at 317-232-8427 or 1-800-451-6027, and ask for extension 2-8427.

Sincerely,



Alfred C. Dumauval, Ph. D., Section Chief  
Permits Branch  
Office of Air Quality

Attachments: Updated Permit

ACD/JRK

cc: File - Marion County  
Marion County Health Department  
U.S. EPA, Region V  
Compliance and Enforcement Branch  
Billing, Licensing and Training Section



**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT**

*We Protect Hoosiers and Our Environment.*

*Mitchell E. Daniels Jr.*  
Governor

*Thomas W. Easterly*  
Commissioner

100 North Senate Avenue  
Indianapolis, Indiana 46204  
(317) 232-8603  
Toll Free (800) 451-6027  
[www.idem.IN.gov](http://www.idem.IN.gov)

**Federally Enforceable State Operating Permit  
Renewal**

**OFFICE OF AIR QUALITY**

**BP Products North America Inc. - Indianapolis Terminal  
2500 North Tibbs Avenue  
Indianapolis, Indiana 46222**


(herein known as the Permittee) is hereby authorized to operate subject to the conditions contained herein, the source described in Section A (Source Summary) of this permit.

**The Permittee must comply with all conditions of this permit. Noncompliance with any provisions of this permit is grounds for enforcement action; permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. An emergency does constitute an affirmative defense in an enforcement action provided the Permittee complies with the applicable requirements set forth in Section B, Emergency Provisions.**

This permit is issued in accordance with 326 IAC 2 and 40 CFR Part 70 Appendix A and contains the conditions and provisions specified in 326 IAC 2-8 as required by 42 U.S.C. 7401, et. seq. (Clean Air Act as amended by the 1990 Clean Air Act Amendments), 40 CFR Part 70.6, IC 13-15 and IC 13-17.

Indiana statutes from IC 13 and rules from 326 IAC, quoted in conditions in this permit, are those applicable at the time the permit was issued. The issuance or possession of this permit shall not alone constitute a defense against an alleged violation of any law, regulation or standard, except for the requirement to obtain a FESOP under 326 IAC 2-8.

Operation Permit No.: F097-25559-00076	
Issued by: <i>Original Signed by:</i> Alfred C. Dumauval, Ph. D., Section Chief Permits Branch Office of Air Quality	Issuance Date: March 26, 2009  Expiration Date: March 26, 2019

First Administrative Amendment No.: F097-29901-00076	
Issued by:  Alfred C. Dumauval, Ph.D., Section Chief Permits Branch Office of Air Quality	Issuance Date:  January 3, 2011 Expiration Date: March 26, 2019

## TABLE OF CONTENTS

<b>A. SOURCE SUMMARY</b> .....	<b>5</b>
A.1 General Information [326 IAC 2-8-3(b)]	
A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-8-3(c)(3)]	
A.3 Insignificant Activities [326 IAC 2-7-1(21)][326 IAC 2-8-3(c)(3)(I)]	
A.4 FESOP Applicability [326 IAC 2-8-2]	
<b>B. GENERAL CONDITIONS</b> .....	<b>8</b>
B.1 Definitions [326 IAC 2-8-1]	
B.2 Permit Term [326 IAC 2-8-4(2)][326 IAC 2-1.1-9.5][IC 13-15-3-6(a)]	
B.3 Term of Conditions [326 IAC 2-1.1-9.5]	
B.4 Enforceability [326 IAC 2-8-6] [IC 13-17-12]	
B.5 Severability [326 IAC 2-8-4(4)]	
B.6 Property Rights or Exclusive Privilege [326 IAC 2-8-4(5)(D)]	
B.7 Duty to Provide Information [326 IAC 2-8-4(5)(E)]	
B.8 Certification [326 IAC 2-8-3(d)][326 IAC 2-8-4(3)(C)(i)][326 IAC 2-8-5(1)]	
B.9 Annual Compliance Certification [326 IAC 2-8-5(a)(1)]	
B.10 Compliance Order Issuance [326 IAC 2-8-5(b)]	
B.11 Preventive Maintenance Plan [326 IAC 1-6-3][326 IAC 2-8-4(9)] [326 IAC 2-8-5(a)(1)]	
B.12 Emergency Provisions [326 IAC 2-8-12]	
B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5]	
B.14 Termination of Right to Operate [326 IAC 2-8-9][326 IAC 2-8-3(h)]	
B.15 Reserved	
B.16 Permit Modification, Reopening, Revocation and Reissuance, or Termination [326 IAC 2-8-4(5)(C)][326 IAC 2-8-7(a)][326 IAC 2-8-8]	
B.17 Permit Renewal [326 IAC 2-8-3(h)]	
B.18 Permit Amendment or Revision [326 IAC 2-8-10][326 IAC 2-8-11.1]	
B.19 Operational Flexibility [326 IAC 2-8-15][326 IAC 2-8-11.1]	
B.20 Source Modification Requirement [326 IAC 2-8-11.1]	
B.21 Inspection and Entry [326 IAC 2-8-5(a)(2)][IC 13-14-2-2][IC 13-17-3-2] [IC 13-30-3-1]	
B.22 Transfer of Ownership or Operational Control [326 IAC 2-8-10]	
B.23 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-8-4(6)] [326 IAC 2-8-16] [326 IAC 2-1.1-7]	
B.24 Credible Evidence [326 IAC 2-8-4(3)][326 IAC 2-8-5][62 FR 8314] [326 IAC 1-1-6]	
<b>C. SOURCE OPERATION CONDITIONS</b> .....	<b>18</b>
<b>Emission Limitations and Standards [326 IAC 2-8-4(1)]</b>	
C.1 Particulate Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]	
C.2 Overall Source Limit [326 IAC 2-8]	
C.3 Opacity [326 IAC 5-1]	
C.4 Open Burning [326 IAC 4-1] [IC 13-17-9]	
C.5 Incineration [326 IAC 4-2] [326 IAC 9-1-2]	
C.6 Fugitive Dust Emissions [326 IAC 6-4]	
C.7 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]	
<b>Testing Requirements [326 IAC 2-8-4(3)]</b>	
C.8 Performance Testing [326 IAC 3-6]	

**Compliance Requirements [326 IAC 2-1.1-11]**

- C.9 Compliance Requirements [326 IAC 2-1.1-11]

**Compliance Monitoring Requirements [326 IAC 2-8-4][326 IAC 2-8-5(a)(1)]**

- C.10 Compliance Monitoring [326 IAC 2-8-4(3)][326 IAC 2-8-5(a)(1)]
- C.11 Reserved
- C.12 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-8-4(3)]  
[326 IAC 2-8-5(1)]

**Corrective Actions and Response Steps [326 IAC 2-8-4][326 IAC 2-8-5(a)(1)]**

- C.13 Risk Management Plan [326 IAC 2-8-4] [40 CFR 68]
- C.14 Response to Excursions or Exceedances [326 IAC 2-8-4] [326 IAC 2-8-5]
- C.15 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-8-4]  
[326 IAC 2-8-5]

**Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]**

- C.16 General Record Keeping Requirements [326 IAC 2-8-4(3)] [326 IAC 2-8-5]
- C.17 General Reporting Requirements [326 IAC 2-8-4(3)(C)] [326 IAC 2-1.1-11]

**Stratospheric Ozone Protection**

- C.18 Compliance with 40 CFR 82 and 326 IAC 22-1

**D.1. EMISSIONS UNIT OPERATION CONDITIONS..... 24**

**Emission Limitations and Standards [326 IAC 2-8-4(1)]**

- D.1.1 Volatile Organic Compounds (VOC) and Hazardous Air Pollutants (HAP) [326 IAC 2-8-4]  
[326 IAC 20] [40 CFR 63 Subpart R]
- D.1.2 Volatile Organic Compounds (VOC) [326 IAC 8-4-4]
- D.1.3 Volatile Organic Compounds (VOC) [326 IAC 8-4-9]
- D.1.4 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

**Compliance Determination Requirements**

- D.1.5 VOC and HAP
- D.1.6 Testing Requirements [326 IAC 2-8-5(a)(1)] [326 IAC 2-1.1-11]

**Compliance Monitoring Requirements [326 IAC 2-8-4][326 IAC 2-8-5(a)(1)]**

- D.1.7 Carbon Adsorber

**Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]**

- D.1.8 Record Keeping Requirements
- D.1.9 Reporting Requirements

**D.2. EMISSIONS UNIT OPERATION CONDITIONS..... 29**

**Emission Limitations and Standards [326 IAC 2-8-4(1)]**

- D.2.1 Volatile Organic Compounds (VOC) [326 IAC 8-4-3]
- D.2.2 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

**Compliance Monitoring Requirements [326 IAC 2-8-4][326 IAC 2-8-5(a)(1)]**

- D.2.3 Monitoring

**Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]**

- D.2.4 Record Keeping Requirements [326 IAC 8-4-3(d)]

**D.3. EMISSIONS UNIT OPERATION CONDITIONS..... 31**

**Emission Limitations and Standards [326 IAC 2-8-4(1)]**

- D.3.1 Volatile Organic Compounds (VOC) [326 IAC 8-3-2]
- D.3.2 Volatile Organic Compounds (VOC) [326 IAC 8-3-5]
- D.3.3 Particulate Emission Limitations for Sources of Indirect Heating (PM) [326 IAC 6-2-4]

**E.1. FACILITY OPERATION CONDITIONS ..... 33**

**New Source Performance Standards (NSPS) Requirements**

- E.1.1 General Provisions relating to NSPS [326 IAC 12-1] [40 CFR Part 60, Subpart A]
- E.1.2 New Source Performance Standards (NSPS) standards of Performance for Bulk Gasoline Terminals [326 IAC 12] [40 CFR 60, Subpart XX]

**E.2. FACILITY OPERATION CONDITIONS ..... 34**

**National Emission Standards for Hazardous Air Pollutants (NESHAP) Requirements**

- E.2.1 General Provisions relating to NESHAP [326 IAC 20-1] [40 CFR Part 63, Subpart A]
- E.2.2 National Emission Standard for Hazardous Air Pollutants for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities [40 CFR 63, Subpart BBBBBB]

Certification Form ..... 36  
Emergency Occurrence Form ..... 37  
FESOP Quarterly Report Form ..... 39  
Quarterly Deviation and Compliance Monitoring Report Form ..... 40

Attachment A: 40 CFR Part 60, Subpart XX  
Attachment B: 40 CFR Part 63, Subpart BBBBBB

## SECTION A SOURCE SUMMARY

This permit is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ). The information describing the source contained in conditions A.1 through A.3 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this permit pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

### A.1 General Information [326 IAC 2-8-3(b)]

---

The Permittee owns and operates a stationary petroleum product loading terminal.

Source Address:	2500 North Tibbs Avenue, Indianapolis, Indiana 46222
General Source Phone Number:	317-926-5471
SIC Code:	5171
County Location:	Marion
Source Location Status:	Nonattainment for PM2.5 standard Attainment for all other criteria pollutants
Source Status:	Federally Enforceable State Operating Permit Program Minor Source, under PSD and Nonattainment New Source Review Rules Minor Source, Section 112 of the Clean Air Act 1 of 28 Source Categories

### A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-8-3(c)(3)]

---

This stationary source consists of the following emission units and pollution control devices:

- (a) One (1) loading rack for dispensing of petroleum product, with one (1) carbon adsorber, identified as V10, for control of volatile organic compounds. Loading rack installed in 1993.  
  
Under 40 CFR Part 60, Subpart XX and 40 CFR Part 63, Subpart BBBB, the petroleum products loading rack is an affected facility.
- (b) Storage tank # 1, equipped with a fixed roof, 1,365,000 gallons storage capacity, used to store HS diesel, and constructed in 1941.
- (c) Storage tank #2, equipped with an external pontoon floating roof with a dome, 672,000 gallon storage capacity, used to store Slop interface, and constructed in 1940.
- (d) Storage tank #3, equipped with an external pontoon floating roof with a dome, 672,000 gallon storage capacity, used to store ethanol, and constructed in 1941.
- (e) Storage tank # 4, equipped with a fixed roof, 1,365,000 gallon storage capacity, used to store LS diesel supreme, and constructed in 1941.
- (f) Storage tank # 5, equipped with an internal floating roof as of 2010, 1,365,000 gallon storage capacity, used to store ethanol or distillate fuel oil, constructed in 1941.
- (g) Storage tank #6, equipped with an external pontoon floating roof with a dome, 3,150,000 gallon storage capacity, used to store Subgrade/regular gasoline, and constructed in 1941.

Under 40 CFR Part 63, Subpart BBBB, Storage tank #6 is an affected facility.

- (h) Storage tank #7, equipped with an external pontoon floating roof with a dome, 3,150,000 gallon storage capacity, used to store Subgrade/ regular gasoline, and constructed in 1941.

Under 40 CFR Part 63, Subpart BBBBBB, Storage tank #7 is an affected facility.

- (i) Storage tank #8, equipped with an external pontoon floating roof with a dome, 3,150,000 gallon storage capacity, used to store Premium gasoline, and constructed in 1942.

Under 40 CFR Part 63, Subpart BBBBBB, Storage tank #8 is an affected facility.

- (j) Storage tank # 10, equipped with a fixed roof, 92,400 gallon storage capacity, used to store Slop diesel, and constructed in 1941.

- (k) Storage tank # 11, equipped with a fixed roof, 3,360,000 gallon storage capacity, used to store LS diesel, and constructed in 1970.

#### A.3 Insignificant Activities [326 IAC 2-7-1(21)][326 IAC 2-8-3(c)(3)(I)]

---

This stationary source also includes the following insignificant activities:

- (a) Fuel oil-fired combustion sources with heat input equal to or less than two million (2,000,000) Btu per hour and firing fuel containing less than five-tenths (0.5) percent sulfur by weight. [326 IAC 6-2-4]
- (b) Vessels storing lubricating oils, hydraulic oils, machining oils, and machining fluid.
- (c) Filling drums, pails or other packaging containers with lubricating oils, waxes, and grease.
- (d) Cleaners and solvents characterized as follows:
  - (1) having a vapor pressure equal to or less than 2 kPa; 15 mmHg; or 0.3 psi measured at 38 degrees C (100 °F) or ;
  - (2) having a vapor pressure equal to or less than 0.7 kPa; 5 mmHg; or 0.1 psi measured at 20 degrees C (68 °F);
- (e) Groundwater oil recovery wells.
- (f) Activities associated with the treatment of wastewater streams with an oil and grease content less than or equal to 1% by volume.
- (g) Process vessels degassing and cleaning to prepare for internal repair.
- (h) Paved and unpaved roads and parking lots with public access.
- (i) Equipment used to collect any material that might be released during a malfunction, process upset, or spill cleanup, including catch tanks, temporary liquid separators, tanks, and fluid handling equipment.
- (j) On-site fire and emergency response training approved by the department.
- (k) Filter or coalescer media changeout.
- (l) Laboratory as defined in 326 IAC 2-7-1(21)(D)

(m) The following facilities with VOC emissions less than 3 (three) pounds per hour or (15) fifteen pounds per day:

- (1) Tank 12, 8,000 gallon diesel tank
- (2) Tank 13, 1,000 gallon gasoline tank
- (3) Tank 14, Oil/water separator
- (4) Tank 14a, 6000 gallon underground storage tank
- (4) Tank 15, 2,000 gallon pump-off tank
- (5) Tank 16, 1,100 gallon heater oil tank for shop
- (6) Tank 17, 8,000 gallon UST
- (7) Tank 18, 1,000 gallon furnace oil UST
- (8) Tank 19, 500 gallon oil recycling tank
- (9) Tank 20, 8,200 gallon OGA additive tank
- (10) Tank 21, 2,000 gallon VRU knock out tank
- (11) Tank 22, 1,000 gallon ground water tank
- (12) Tank 23, 1,000 gallon oil recovery tank
- (13) Tank 24, 8,000 gallon additive tank
- (14) Tank 25, 700 gallon additive tank
- (15) Tank 26, 350 gallon additive tank
- (16) Tank 27, 1,000 gallon oil recovery tank
- (17) Air Stripper
- (18) Other Miscellaneous Activities (loading, refueling, lab and maintenance)

(n) Degreasing operations that do not exceed 145 gallons per 12 months, except if subject to 326 IAC 20-6. [326 IAC 8-3-2] [326 IAC 8-3-5]

#### A.4 FESOP Applicability [326 IAC 2-8-2]

---

This stationary source, otherwise required to have a Part 70 permit as described in 326 IAC 2-7-2(a), has applied to the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ) to renew a Federally Enforceable State Operating Permit (FESOP).

## **SECTION B GENERAL CONDITIONS**

### **B.1 Definitions [326 IAC 2-8-1]**

---

Terms in this permit shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, the applicable definitions found in the statutes or regulations (IC 13-11, 326 IAC 1-2 and 326 IAC 2-7) shall prevail.

### **B.2 Permit Term [326 IAC 2-8-4(2)][326 IAC 2-1.1-9.5][IC 13-15-3-6(a)]**

- 
- (a) This permit, F097-25559-00076, is issued for a fixed term of ten (10) years from the issuance date of this permit, as determined in accordance with IC 4-21.5-3-5(f) and IC 13-15-5-3. Subsequent revisions, modifications, or amendments of this permit do not affect the expiration date of this permit.
- (b) If IDEM, OAQ, upon receiving a timely and complete renewal permit application, fails to issue or deny the permit renewal prior to the expiration date of this permit, this existing permit shall not expire and all terms and conditions shall continue in effect, until the renewal permit has been issued or denied.

### **B.3 Term of Conditions [326 IAC 2-1.1-9.5]**

---

Notwithstanding the permit term of a permit to construct, a permit to operate, or a permit modification, any condition established in a permit issued pursuant to a permitting program approved in the state implementation plan shall remain in effect until:

- (a) the condition is modified in a subsequent permit action pursuant to Title I of the Clean Air Act; or
- (b) the emission unit to which the condition pertains permanently ceases operation.

### **B.4 Enforceability [326 IAC 2-8-6] [IC 13-17-12]**

---

Unless otherwise stated, all terms and conditions in this permit, including any provisions designed to limit the source's potential to emit, are enforceable by IDEM, the United States Environmental Protection Agency (U.S. EPA) and by citizens in accordance with the Clean Air Act.

### **B.5 Severability [326 IAC 2-8-4(4)]**

---

The provisions of this permit are severable; a determination that any portion of this permit is invalid shall not affect the validity of the remainder of the permit.

### **B.6 Property Rights or Exclusive Privilege [326 IAC 2-8-4(5)(D)]**

---

This permit does not convey any property rights of any sort or any exclusive privilege.

### **B.7 Duty to Provide Information [326 IAC 2-8-4(5)(E)]**

- 
- (a) The Permittee shall furnish to IDEM, OAQ, within a reasonable time, any information that IDEM, OAQ may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. Upon request, the Permittee shall also furnish to IDEM, OAQ copies of records required to be kept by this permit.
- (b) For information furnished by the Permittee to IDEM, OAQ, the Permittee may include a claim of confidentiality in accordance with 326 IAC 17.1. When furnishing copies of requested records directly to U. S. EPA, the Permittee may assert a claim of confidentiality in accordance with 40 CFR 2, Subpart B.

B.8 Certification [326 IAC 2-8-3(d)][326 IAC 2-8-4(3)(C)(i)][326 IAC 2-8-5(1)]

- (a) A certification required by this permit meets the requirements of 326 IAC 2-8-5(a)(1) if:
- (1) it contains a certification by an "authorized individual", as defined by 326 IAC 2-1.1-1(1), and
  - (2) the certification states that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
- (b) The Permittee may use the attached Certification Form, or its equivalent with each submittal requiring certification. One (1) certification may cover multiple forms in one (1) submittal.
- (c) An "authorized individual" is defined at 326 IAC 2-1.1-1(1).

B.9 Annual Compliance Certification [326 IAC 2-8-5(a)(1)]

- (a) The Permittee shall annually submit a compliance certification report which addresses the status of the source's compliance with the terms and conditions contained in this permit, including emission limitations, standards, or work practices. All certifications shall cover the time period from January 1 to December 31 of the previous year, and shall be submitted no later than April 15 of each year to:
- Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251
- (b) The annual compliance certification report required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
- (c) The annual compliance certification report shall include the following:
- (1) The appropriate identification of each term or condition of this permit that is the basis of the certification;
  - (2) The compliance status;
  - (3) Whether compliance was continuous or intermittent;
  - (4) The methods used for determining the compliance status of the source, currently and over the reporting period consistent with 326 IAC 2-8-4(3); and
  - (5) Such other facts, as specified in Sections D of this permit, as IDEM, OAQ may require to determine the compliance status of the source.

The submittal by the Permittee does require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

B.10 Compliance Order Issuance [326 IAC 2-8-5(b)]

IDEM, OAQ may issue a compliance order to this Permittee upon discovery that this permit is in nonconformance with an applicable requirement. The order may require immediate compliance or contain a schedule for expeditious compliance with the applicable requirement.

B.11 Preventive Maintenance Plan [326 IAC 1-6-3][326 IAC 2-8-4(9)][326 IAC 2-8-5(a)(1)]

(a) A Preventive Maintenance Plan meets the requirements of 326 IAC 1-6-3 if it includes, at a minimum:

- (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;
- (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
- (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

The Permittee shall implement the PMPs.

(b) If required by specific condition(s) in Section D of this permit where no PMP was previously required, the Permittee shall prepare and maintain Preventive Maintenance Plans (PMPs) no later than ninety (90) days after issuance of this permit or ninety (90) days after initial start-up, whichever is later, including the following information on each facility and its control device:

- (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;
- (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
- (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

If, due to circumstances beyond the Permittee's control, the PMPs cannot be prepared and maintained within the above time frame, the Permittee may extend the date an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

The PMP extension notification does not require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

The Permittee shall implement the PMPs.

(c) A copy of the PMPs shall be submitted to IDEM, OAQ upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. IDEM, OAQ may require the Permittee to revise its PMPs whenever lack of proper maintenance causes or is the primary contributor to an exceedance of any limitation on emissions.

The PMPs and their submittal do not require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (d) To the extent the Permittee is required by 40 CFR Part 60/63 to have an Operation Maintenance, and Monitoring (OMM) Plan for a unit, such Plan is deemed to satisfy the PMP requirements of 326 IAC 1-6-3 for that unit.

B.12 Emergency Provisions [326 IAC 2-8-12]

- (a) An emergency, as defined in 326 IAC 2-7-1(12), is not an affirmative defense for an action brought for noncompliance with a federal or state health-based emission limitation except as provided in 326 IAC 2-8-12.

- (b) An emergency, as defined in 326 IAC 2-7-1(12), constitutes an affirmative defense to an action brought for noncompliance with a health-based or technology-based emission limitation if the affirmative defense of an emergency is demonstrated through properly signed, contemporaneous operating logs or other relevant evidence that describe the following:

- (1) An emergency occurred and the Permittee can, to the extent possible, identify the causes of the emergency;
- (2) The permitted facility was at the time being properly operated;
- (3) During the period of an emergency, the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards or other requirements in this permit;
- (4) For each emergency lasting one (1) hour or more, the Permittee notified IDEM, OAQ, within four (4) daytime business hours after the beginning of the emergency, or after the emergency was discovered or reasonably should have been discovered;

Telephone Number: 1-800-451-6027 (ask for Office of Air Quality, Compliance and Enforcement Branch), or  
Telephone Number: 317-233-0178 (ask for Office of Air Quality, Compliance and Enforcement Branch)  
Facsimile Number: 317-233-6865

- (5) For each emergency lasting one (1) hour or more, the Permittee submitted the attached Emergency Occurrence Report Form or its equivalent, either by mail or facsimile to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

within two (2) working days of the time when emission limitations were exceeded due to the emergency.

The notice fulfills the requirement of 326 IAC 2-8-4(3)(C)(ii) and must contain the following:

- (A) A description of the emergency;

- (B) Any steps taken to mitigate the emissions; and
- (C) Corrective actions taken.

The notification which shall be submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (6) The Permittee immediately took all reasonable steps to correct the emergency.
- (c) In any enforcement proceeding, the Permittee seeking to establish the occurrence of an emergency has the burden of proof.
- (d) This emergency provision supersedes 326 IAC 1-6 (Malfunctions). This permit condition is in addition to any emergency or upset provision contained in any applicable requirement.
- (e) The Permittee seeking to establish the occurrence of an emergency shall make records available upon request to ensure that failure to implement a PMP did not cause or contribute to an exceedance of any limitations on emissions. However, IDEM, OAQ may require that the Preventive Maintenance Plans required under 326 IAC 2-8-3(c)(6) be revised in response to an emergency.
- (f) Failure to notify IDEM, OAQ by telephone or facsimile of an emergency lasting more than one (1) hour in accordance with (b)(4) and (5) of this condition shall constitute a violation of 326 IAC 2-8 and any other applicable rules.
- (g) Operations may continue during an emergency only if the following conditions are met:
  - (1) If the emergency situation causes a deviation from a technology-based limit, the Permittee may continue to operate the affected emitting facilities during the emergency provided the Permittee immediately takes all reasonable steps to correct the emergency and minimize emissions.
  - (2) If an emergency situation causes a deviation from a health-based limit, the Permittee may not continue to operate the affected emissions facilities unless:
    - (A) The Permittee immediately takes all reasonable steps to correct the emergency situation and to minimize emissions; and
    - (B) Continued operation of the facilities is necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw material of substantial economic value.

Any operations shall continue no longer than the minimum time required to prevent the situations identified in (g)(2)(B) of this condition.

**B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5]**

- 
- (a) All terms and conditions of permits established prior to F097-25559-00076 and issued pursuant to permitting programs approved into the state implementation plan have been either:
    - (1) incorporated as originally stated,

- (2) revised, or
- (3) deleted.

(b) All previous registrations and permits are superseded by this permit.

**B.14 Termination of Right to Operate [326 IAC 2-8-9][326 IAC 2-8-3(h)]**

---

The Permittee's right to operate this source terminates with the expiration of this permit unless a timely and complete renewal application is submitted at least nine (9) months prior to the date of expiration of the source's existing permit, consistent with 326 IAC 2-8-3(h) and 326 IAC 2-8-9.

**B.15 Reserved**

---

**B.16 Permit Modification, Reopening, Revocation and Reissuance, or Termination  
[326 IAC 2-8-4(5)(C)][326 IAC 2-8-7(a)][326 IAC 2-8-8]**

---

- (a) This permit may be modified, reopened, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a Federally Enforceable State Operating Permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any condition of this permit. [326 IAC 2-8-4(5)(C)] The notification by the Permittee does require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (b) This permit shall be reopened and revised under any of the circumstances listed in IC 13-15-7-2 or if IDEM, OAQ determines any of the following:
  - (1) That this permit contains a material mistake.
  - (2) That inaccurate statements were made in establishing the emissions standards or other terms or conditions.
  - (3) That this permit must be revised or revoked to assure compliance with an applicable requirement. [326 IAC 2-8-8(a)]
- (c) Proceedings by IDEM, OAQ to reopen and revise this permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of this permit for which cause to reopen exists. Such reopening and revision shall be made as expeditiously as practicable. [326 IAC 2-8-8(b)]
- (d) The reopening and revision of this permit, under 326 IAC 2-8-8(a), shall not be initiated before notice of such intent is provided to the Permittee by IDEM, OAQ at least thirty (30) days in advance of the date this permit is to be reopened, except that IDEM, OAQ may provide a shorter time period in the case of an emergency. [326 IAC 2-8-8(c)]

**B.17 Permit Renewal [326 IAC 2-8-3(h)]**

---

- (a) The application for renewal shall be submitted using the application form or forms prescribed by IDEM, OAQ and shall include the information specified in 326 IAC 2-8-3. Such information shall be included in the application for each emission unit at this source, except those emission units included on the trivial or insignificant activities list contained in 326 IAC 2-7-1(21) and 326 IAC 2-7-1(40). The renewal application does require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

Request for renewal shall be submitted to:

Indiana Department of Environmental Management  
Permits Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

- (b) A timely renewal application is one that is:
- (1) Submitted at least nine (9) months prior to the date of the expiration of this permit; and
  - (2) If the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
- (c) If the Permittee submits a timely and complete application for renewal of this permit, the source's failure to have a permit is not a violation of 326 IAC 2-8 until IDEM, OAQ takes final action on the renewal application, except that this protection shall cease to apply if, subsequent to the completeness determination, the Permittee fails to submit by the deadline specified, pursuant to 326 IAC 2-8-3(g) in writing by IDEM, OAQ any additional information identified as being needed to process the application.

B.18 Permit Amendment or Revision [326 IAC 2-8-10][326 IAC 2-8-11.1]

- (a) Permit amendments and revisions are governed by the requirements of 326 IAC 2-8-10 or 326 IAC 2-8-11.1 whenever the Permittee seeks to amend or modify this permit.
- (b) Any application requesting an amendment or modification of this permit shall be submitted to:
- Indiana Department of Environmental Management  
Permits Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251
- Any such application does require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-8-10(b)(3)]

B.19 Operational Flexibility [326 IAC 2-8-15][326 IAC 2-8-11.1]

- (a) The Permittee may make any change or changes at the source that are described in 326 IAC 2-8-15(b) through (d) without a prior permit revision, if each of the following conditions is met:
- (1) The changes are not modifications under any provision of Title I of the Clean Air Act;
  - (2) Any approval required by 326 IAC 2-8-11.1 has been obtained;

(3) The changes do not result in emissions which exceed the limitations provided in this permit (whether expressed herein as a rate of emissions or in terms of total emissions);

(4) The Permittee notifies the:

Indiana Department of Environmental Management  
Permits Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V  
Air and Radiation Division, Regulation Development Branch - Indiana (AR-18J)  
77 West Jackson Boulevard  
Chicago, Illinois 60604-3590

in advance of the change by written notification at least ten (10) days in advance of the proposed change. The Permittee shall attach every such notice to the Permittee's copy of this permit; and

(5) The Permittee maintains records on-site, on a rolling five (5) year basis, which document all such changes and emission trades that are subject to 326 IAC 2-8-15(b) through (d). The Permittee shall make such records available, upon reasonable request, for public review.

Such records shall consist of all information required to be submitted to IDEM, OAQ in the notices specified in 326 IAC 2-8-15(b)(2), (c)(1), and (d).

- (b) Emission Trades [326 IAC 2-8-15(c)]  
The Permittee may trade emissions increases and decreases at the source, where the applicable SIP provides for such emission trades without requiring a permit revision, subject to the constraints of Section (a) of this condition and those in 326 IAC 2-8-15(c).
- (c) Alternative Operating Scenarios [326 IAC 2-8-15(d)]  
The Permittee may make changes at the source within the range of alternative operating scenarios that are described in the terms and conditions of this permit in accordance with 326 IAC 2-8-4(7). No prior notification of IDEM, OAQ, or U.S. EPA is required.
- (d) Backup fuel switches specifically addressed in, and limited under, Section D of this permit shall not be considered alternative operating scenarios. Therefore, the notification requirements of part (a) of this condition do not apply.

B.20 Source Modification Requirement [326 IAC 2-8-11.1]

A modification, construction, or reconstruction is governed by the requirements of 326 IAC 2.

B.21 Inspection and Entry [326 IAC 2-8-5(a)(2)][IC 13-14-2-2][IC 13-17-3-2][IC 13-30-3-1]

Upon presentation of proper identification cards, credentials, and other documents as may be required by law, and subject to the Permittee's right under all applicable laws and regulations to assert that the information collected by the agency is confidential and entitled to be treated as such, the Permittee shall allow IDEM, OAQ, U.S. EPA, or an authorized representative to perform the following:

- (a) Enter upon the Permittee's premises where a FESOP source is located, or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
- (b) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- (c) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, inspect, at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit;
- (d) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with this permit or applicable requirements; and
- (e) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, utilize any photographic, recording, testing, monitoring, or other equipment for the purpose of assuring compliance with this permit or applicable requirements.

B.22 Transfer of Ownership or Operational Control [326 IAC 2-8-10]

- (a) The Permittee must comply with the requirements of 326 IAC 2-8-10 whenever the Permittee seeks to change the ownership or operational control of the source and no other change in the permit is necessary.
- (b) Any application requesting a change in the ownership or operational control of the source shall contain a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new Permittee. The application shall be submitted to:  
  
Indiana Department of Environmental Management  
Permits Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251  
  
Any such application does require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-8-10(b)(3)]

B.23 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-8-4(6)] [326 IAC 2-8-16][326 IAC 2-1.1-7]

- (a) The Permittee shall pay annual fees to IDEM, OAQ no later than thirty (30) calendar days of receipt of a billing. Pursuant to 326 IAC 2-7-19(b), if the Permittee does not receive a bill from IDEM, OAQ the applicable fee is due April 1 of each year.
- (b) Failure to pay may result in administrative enforcement action or revocation of this permit.
- (c) The Permittee may call the following telephone numbers: 1-800-451-6027 or 317-233-4230 (ask for OAQ, Billing, Licensing, and Training Section), to determine the appropriate permit fee.

B.24 Credible Evidence [326 IAC 2-8-4(3)][326 IAC 2-8-5][62 FR 8314] [326 IAC 1-1-6]

For the purpose of submitting compliance certifications or establishing whether or not the Permittee has violated or is in violation of any condition of this permit, nothing in this permit shall preclude the use, including the exclusive use, of any credible evidence or information relevant to whether the Permittee would have been in compliance with the condition of this permit if the appropriate performance or compliance test or procedure had been performed.

## SECTION C SOURCE OPERATION CONDITIONS

Entire Source

### Emission Limitations and Standards [326 IAC 2-8-4(1)]

#### C.1 Particulate Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2(e)(2), particulate emissions from any process not exempt under 326 IAC 6-3-1(b) or (c) which has a maximum process weight rate less than 100 pounds per hour and the methods in 326 IAC 6-3-2(b) through (d) do not apply shall not exceed 0.551 pounds per hour.

#### C.2 Overall Source Limit [326 IAC 2-8]

The purpose of this permit is to limit this source's potential to emit to less than major source levels for the purpose of Section 502(a) of the Clean Air Act.

(a) Pursuant to 326 IAC 2-8:

- (1) The potential to emit any regulated pollutant, except particulate matter (PM), from the entire source shall be limited to less than one hundred (100) tons per twelve (12) consecutive month period.
- (2) The potential to emit any individual hazardous air pollutant (HAP) from the entire source shall be limited to less than ten (10) tons per twelve (12) consecutive month period; and
- (3) The potential to emit any combination of HAPs from the entire source shall be limited to less than twenty-five (25) tons per twelve (12) consecutive month period.

(b) Pursuant to 326 IAC 2-2 (PSD), potential to emit particulate matter (PM) from the entire source shall be limited to less than one hundred (100) tons per twelve (12) consecutive month period.

(c) This condition shall include all emission points at this source including those that are insignificant as defined in 326 IAC 2-7-1(21). The source shall be allowed to add insignificant activities not already listed in this permit, provided that the source's potential to emit does not exceed the above specified limits.

(d) Section D of this permit contains independently enforceable provisions to satisfy this requirement.

#### C.3 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-1 (Applicability) and 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

- (a) Opacity shall not exceed an average of thirty percent (30%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

C.4 Open Burning [326 IAC 4-1] [IC 13-17-9]

---

The Permittee shall not open burn any material except as provided in 326 IAC 4-1-3, 326 IAC 4-1-4 or 326 IAC 4-1-6. The previous sentence notwithstanding, the Permittee may open burn in accordance with an open burning approval issued by the Commissioner under 326 IAC 4-1-4.1.

C.5 Incineration [326 IAC 4-2] [326 IAC 9-1-2]

---

The Permittee shall not operate an incinerator except as provided in 326 IAC 4-2 or in this permit. The Permittee shall not operate a refuse incinerator or refuse burning equipment except as provided in 326 IAC 9-1-2 or in this permit.

C.6 Fugitive Dust Emissions [326 IAC 6-4]

---

The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions).

C.7 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

---

- (a) Notification requirements apply to each owner or operator. If the combined amount of regulated asbestos containing material (RACM) to be stripped, removed or disturbed is at least 260 linear feet on pipes or 160 square feet on other facility components, or at least thirty-five (35) cubic feet on all facility components, then the notification requirements of 326 IAC 14-10-3 are mandatory. All demolition projects require notification whether or not asbestos is present.
- (b) The Permittee shall ensure that a written notification is sent on a form provided by the Commissioner at least ten (10) working days before asbestos stripping or removal work or before demolition begins, per 326 IAC 14-10-3, and shall update such notice as necessary, including, but not limited to the following:
- (1) When the amount of affected asbestos containing material increases or decreases by at least twenty percent (20%); or
- (2) If there is a change in the following:
- (A) Asbestos removal or demolition start date;
- (B) Removal or demolition contractor; or
- (C) Waste disposal site.
- (c) The Permittee shall ensure that the notice is postmarked or delivered according to the guidelines set forth in 326 IAC 14-10-3(2).
- (d) The notice to be submitted shall include the information enumerated in 326 IAC 14-10-3(3).

All required notifications shall be submitted to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

The notice shall include a signed certification from the owner or operator that the information provided in this notification is correct and that only Indiana licensed workers and project supervisors will be used to implement the asbestos removal project. The notifications do not require a certification by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (e) **Procedures for Asbestos Emission Control**  
The Permittee shall comply with the applicable emission control procedures in 326 IAC 14-10-4 and 40 CFR 61.145(c). Per 326 IAC 14-10-1, emission control requirements are applicable for any removal or disturbance of RACM greater than three (3) linear feet on pipes or three (3) square feet on any other facility components or a total of at least 0.75 cubic feet on all facility components.
- (f) **Demolition and Renovation**  
The Permittee shall thoroughly inspect the affected facility or part of the facility where the demolition or renovation will occur for the presence of asbestos pursuant to 40 CFR 61.145(a).
- (g) **Indiana Licensed Asbestos Inspector**  
The Permittee shall comply with 326 IAC 14-10-1(a) that requires the owner or operator, prior to a renovation/demolition, to use an Indiana Licensed Asbestos Inspector to thoroughly inspect the affected portion of the facility for the presence of asbestos.

### **Testing Requirements [326 IAC 2-8-4(3)]**

#### **C.8 Performance Testing [326 IAC 3-6]**

---

- (a) For performance testing required by this permit, a test protocol, except as provided elsewhere in this permit, shall be submitted to:  
  
Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251  
  
no later than thirty-five (35) days prior to the intended test date. The protocol submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (b) The Permittee shall notify IDEM, OAQ of the actual test date at least fourteen (14) days prior to the actual test date. The notification submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (c) Pursuant to 326 IAC 3-6-4(b), all test reports must be received by IDEM, OAQ not later than forty-five (45) days after the completion of the testing. An extension may be granted by IDEM, OAQ if the Permittee submits to IDEM, OAQ a reasonable written explanation not later than five (5) days prior to the end of the initial forty-five (45) day period.

### **Compliance Requirements [326 IAC 2-1.1-11]**

#### **C.9 Compliance Requirements [326 IAC 2-1.1-11]**

---

The commissioner may require stack testing, monitoring, or reporting at any time to assure compliance with all applicable requirements by issuing an order under 326 IAC 2-1.1-11. Any

monitoring or testing shall be performed in accordance with 326 IAC 3 or other methods approved by the commissioner or the U. S. EPA.

### **Compliance Monitoring Requirements [326 IAC 2-8-4][326 IAC 2-8-5(a)(1)]**

#### **C.10 Compliance Monitoring [326 IAC 2-8-4(3)][326 IAC 2-8-5(a)(1)]**

---

Unless otherwise specified in this permit, for all monitoring requirements not already legally required, the Permittee shall be allowed up to ninety (90) days from the date of permit issuance or of initial start-up, whichever is later, to begin such monitoring. If due to circumstances beyond the Permittee's control, any monitoring equipment required by this permit cannot be installed and operated no later than ninety (90) days after permit issuance or the date of initial startup, whichever is later, the Permittee may extend the compliance schedule related to the equipment for an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

in writing, prior to the end of the initial ninety (90) day compliance schedule, with full justification of the reasons for the inability to meet this date.

The notification which shall be submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

Unless otherwise specified in the approval for the new emission unit(s), compliance monitoring for new emission units or emission units added through a permit revision shall be implemented when operation begins.

#### **C.11 Reserved**

---

#### **C.12 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-8-4(3)][326 IAC 2-8-5(1)]**

---

- (a) When required by any condition of this permit, an analog instrument used to measure a parameter related to the operation of an air pollution control device shall have a scale such that the expected maximum reading for the normal range shall be no less than twenty percent (20%) of full scale.
- (b) The Permittee may request that the IDEM, OAQ approve the use of an instrument that does not meet the above specifications provided the Permittee can demonstrate that an alternative instrument specification will adequately ensure compliance with permit conditions requiring the measurement of the parameters.

### **Corrective Actions and Response Steps [326 IAC 2-8-4][326 IAC 2-8-5(a)(1)]**

#### **C.13 Risk Management Plan [326 IAC 2-8-4] [40 CFR 68]**

---

If a regulated substance, as defined in 40 CFR 68, is present at a source in more than a threshold quantity, the Permittee must comply with the applicable requirements of 40 CFR 68.

#### **C.14 Response to Excursions or Exceedances [326 IAC 2-8-4] [326 IAC 2-8-5]**

---

Upon detecting an excursion where a response step is required by the D Section or an exceedance of a limitation in this permit:

- (a) The Permittee shall take reasonable response steps to restore operation of the emissions unit (including any control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing excess emissions.
- (b) The response shall include minimizing the period of any startup, shutdown or malfunction. The response steps include, but is not limited to, the following:
  - (1) initial inspection and evaluation;
  - (2) recording that operations returned or are returning to normal without operator action (such as through response by a computerized distribution control system);  
or
  - (3) any necessary follow-up actions to return operation to normal or usual manner of operation.
- (c) A determination of whether the Permittee has used acceptable procedures in response to an excursion or exceedance will be based on information available, which may include, but is not limited to, the following:
  - (1) monitoring results;
  - (2) review of operation and maintenance procedures and records; and/or
  - (3) inspection of the control device, associated capture system, and the process.
- (d) Failure to take reasonable response steps shall be considered a deviation from the permit.
- (e) The Permittee shall record the reasonable response steps taken.

C.15 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-8-4][326 IAC 2-8-5]

- (a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this permit exceed the level specified in any condition of this permit, the Permittee shall submit a description of its response actions to IDEM, OAQ, no later than seventy-five (75) days after the date of the test. The Permittee shall take appropriate action to minimize excess emissions from the affected facility while the response actions are being implemented.
- (b) A retest to demonstrate compliance shall be performed no later than one hundred eighty (180) days after the date of the test. Should the Permittee demonstrate to IDEM, OAQ that retesting in one hundred eighty (180) days is not practicable, IDEM, OAQ may extend the retesting deadline.
- (c) IDEM, OAQ reserves the authority to take any actions allowed under law in response to noncompliant stack tests.

The response action documents submitted pursuant to this condition do require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

## **Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]**

### **C.16 General Record Keeping Requirements [326 IAC 2-8-4(3)] [326 IAC 2-8-5]**

---

- (a) Records of all required monitoring data, reports and support information required by this permit shall be retained for a period of at least five (5) years from the date of monitoring sample, measurement, report, or application. These records shall be physically present or electronically accessible at the source location for a minimum of three (3) years. The records may be stored elsewhere for the remaining two (2) years as long as they are available upon request. If the Commissioner makes a request for records to the Permittee, the Permittee shall furnish the records to the Commissioner within a reasonable time.
- (b) Unless otherwise specified in this permit, for all record keeping requirements not already legally required, the Permittee shall be allowed up to ninety (90) days from the date of permit issuance or the date of initial start-up, whichever is later, to begin such record keeping.

### **C.17 General Reporting Requirements [326 IAC 2-8-4(3)(C)] [326 IAC 2-1.1-11]**

---

- (a) The Permittee shall submit the attached Quarterly Deviation and Compliance Monitoring Report or its equivalent. Any deviation from permit requirements, the date(s) of each deviation, the cause of the deviation, and the response steps taken must be reported except that a deviation required to be reported pursuant to an applicable requirement that exists independent of this permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. This report shall be submitted not later than thirty (30) days after the end of the reporting period. The Quarterly Deviation and Compliance Monitoring Report shall include a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1). A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit.
- (b) The address for report submittal is:  
  
Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251
- (c) Unless otherwise specified in this permit, any notice, report, or other submission required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
- (d) Reporting periods are based on calendar years, unless otherwise specified in this permit. For the purpose of this permit "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.

## **Stratospheric Ozone Protection**

### **C.18 Compliance with 40 CFR 82 and 326 IAC 22-1**

---

Pursuant to 40 CFR 82 (Protection of Stratospheric Ozone), Subpart F, except as provided for motor vehicle air conditioners in Subpart B, the Permittee shall comply with applicable standards for recycling and emissions reduction.

## SECTION D.1 EMISSIONS UNIT OPERATION CONDITIONS

### Emissions Unit Description[326 IAC 2-8-4(10)]:

- (a) One (1) loading rack for dispensing of petroleum product, with one (1) carbon adsorber, identified as V10, for control of volatile organic compounds. Loading rack installed in 1993.

Under 40 CFR Part 60, Subpart XX and 40 CFR Part 63, Subpart BBBB, the petroleum products loading rack is an affected facility.

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-8-4(1)]

#### D.1.1 Volatile Organic Compounds (VOC) and Hazardous Air Pollutants (HAP) [326 IAC 2-8-4] [40 CFR 63 Subpart R] [326 IAC 20]

- (a) The VOC emissions from the vapor recovery unit on the loading rack shall not exceed 35 milligrams per liter of gasoline loaded (0.292 lbs per 1000 gals).
- (b) The amount of gasoline and distillate oil product loaded at the loading rack are limited to less than 400,000,000 gallons per 12 consecutive month period and 270,000,000 gallons per 12 consecutive month period, respectively. Compliance with this limits source wide VOC emissions to less than one hundred tons per 12 consecutive month period.
- (c) The single HAP emissions from the vapor recovery unit on the loading rack shall not exceed 2.14 pounds per hour.
- (d) The total combined HAPs emissions from the vapor recovery unit on the loading rack shall not exceed 5.35 pounds per hour.

Compliance with these limitations will limit the VOC and HAP emissions from the loading rack such that the source-wide VOC emissions are less than 100 tons per consecutive 12 month period, and the HAP emissions are less than 10 tons for any single HAP and less than 25 tons for total combined HAP, and will make the requirements of 326 IAC 2-7 and 40 CFR 63.420 (Subpart R) not applicable.

#### D.1.2 Volatile Organic Compounds (VOC) [326 IAC 8-4-4]

Pursuant to 326 IAC 8-4-4 (Bulk gasoline terminals):

- (a) No owner or operator of a bulk gasoline terminal shall permit the loading of gasoline into any transport, excluding railroad tank cars, or barges, unless:
- (1) The bulk gasoline terminal is equipped with a vapor control system, in good working order, in operation and consisting of one of the following:
- (A) An adsorber or condensation system which processes and recovers vapors and gases from the equipment being controlled, releasing no more than 80 milligrams per liter of VOC to the atmosphere.
- (B) A vapor collection system which directs all vapors to a fuel gas system or incinerator.

- (C) An approved control system, demonstrated to have control efficiency equivalent to or greater than clause (A) above.
  - (2) Displaced vapors and gases are vented only to the vapor control system.
  - (3) A means is provided to prevent liquid drainage from the loading device when it is not in use or to accomplish complete drainage before the loading device is disconnected.
  - (4) All loading and vapor lines are equipped with fittings which make vapor-tight connections and which will be closed upon disconnection.
- (b) If employees of the owner of the bulk gasoline terminal are not present during loading, it shall be the responsibility of the owner of the transport to make certain the vapor control system is attached to the transport. The owner of the terminal shall take all reasonable steps to insure that owners of transports loading at the terminal during unsupervised times comply with this section.

#### D.1.3 Volatile Organic Compounds (VOC) [326 IAC 8-4-9]

---

Pursuant to 326 IAC 8-4-9 (Leaks from transports and vapor collection systems, records) the source will operate a vapor control system. The requirements are as follows:

- (a) No person shall allow a gasoline transport that is subject to this rule and that has a capacity of two thousand (2,000) gallons or more to be filled or emptied unless the gasoline transport completes the following:
  - (1) Annual leak detection testing before the end of the twelfth calendar month following the previous year's test, according to test procedures contained in 40 CFR 63.425 (e), as follows:
    - (A) Conduct the pressure and vacuum tests for the transport's cargo tank using a time period of five (5) minutes. The initial pressure for the pressure test shall be four hundred sixty (460) millimeters H<sub>2</sub>O (eighteen (18) inches H<sub>2</sub>O) gauge. The initial vacuum for the vacuum test shall be one hundred fifty (150) millimeters H<sub>2</sub>O (six (6) inches H<sub>2</sub>O) gauge. The maximum allowable pressure or vacuum change is twenty-five (25) millimeters H<sub>2</sub>O (one (1) inch H<sub>2</sub>O) in five (5) minutes.
    - (B) Conduct the pressure test of the cargo tank's internal vapor valve as follows:
      - (i) After completing the test under clause (A), use the procedures in 40 CFR 60, Appendix A, Method 27 to repressurize the tank to four hundred sixty (460) millimeters H<sub>2</sub>O (eighteen (18) inches H<sub>2</sub>O) gauge. Close the transport's internal vapor valve or valves, thereby isolating the vapor return line and manifold from the tank.
      - (ii) Relieve the pressure in the vapor return line to atmospheric pressure, then reseal the line. After five (5) minutes, record the gauge pressure in the vapor return line and manifold. The maximum allowable five (5) minute pressure increase is one hundred thirty (130) millimeters H<sub>2</sub>O (five (5) inches H<sub>2</sub>O).

- (2) Repairs by the gasoline transport owner or operator, if the transport does not meet the criteria of subdivision (1), and retesting to prove compliance with the criteria of subdivision (1).
- (b) The annual test data remain valid until the end of the twelfth calendar month following the test. The owner of the gasoline transport shall be responsible for compliance with subsection (b) and shall provide the owner of the loading facility with the most recent valid modified 40 CFR 60, Appendix A, Method 27 test results upon request. The owner of the loading facility shall take all reasonable steps, including reviewing the test date and tester's signature, to ensure that gasoline transports loading at its facility comply with subsection (a).
- (c) The owner or operator of a vapor balance system or vapor control system subject to this rule shall:
  - (1) design and operate the applicable system and the gasoline loading equipment in a manner that prevents:
    - (A) gauge pressure from exceeding four thousand five hundred (4,500) pascals (eighteen (18) inches of H<sub>2</sub>O) and a vacuum from exceeding one thousand five hundred (1,500) pascals (six (6) inches of H<sub>2</sub>O) in the gasoline transport;
    - (B) except for sources subject to 40 CFR 60.503(b) (NESHAP/MACT) or 40 CFR 63.425(a) (New Source Performance Standards) requirements, a reading equal to or greater than twenty-one thousand (21,000) parts per million as propane, from all points on the perimeter of a potential leak source when measured by the method referenced in 40 CFR 60, Appendix A, Method 21, or an equivalent procedure approved by the commissioner during loading or unloading operations at gasoline dispensing facilities, bulk plants, and bulk terminals; and
    - (C) avoidable visible liquid leaks during loading or unloading operations at gasoline dispensing facilities, bulk plants, and bulk terminals; and
  - (2) within fifteen (15) days, repair and retest a vapor balance, collection, or control system that exceeds the limits in subdivision (1).
- (d) The department may, at any time, monitor a gasoline transport, vapor balance, or vapor control system to confirm continuing compliance with subsection (a) or (b).
- (e) If the commissioner allows alternative test procedures in subsection (a)(1) or (c)(1)(B), such method shall be submitted to the U.S. EPA as a SIP revision.
- (f) During compliance tests conducted under 326 IAC 3-6 (stack testing), each vapor balance or control system shall be tested applying the standards described in subsection (c)(1)(B). Testers shall use 40 CFR 60, Appendix A, Method 21 to determine if there are any leaks from the hatches and the flanges of the gasoline transports. If any leak is detected, the transport cannot be used for the capacity of the compliance test of the bulk gas terminal. The threshold for leaks shall be as follows:
  - (1) Five hundred (500) parts per million methane for all bulk gas terminals subject to NESHAP/MACT (40 CFR 63, Subpart R).

- (2) Ten thousand (10,000) parts per million methane for all bulk gas terminals subject to a New Source Performance Standard.

#### D.1.4 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

---

A Preventive Maintenance Plan is required for the loading rack and carbon adsorber vapor recovery unit. Section B – Preventive Maintenance Plan contains the Permittee’s obligation with regard to the preventive maintenance plan required by this condition.

### Compliance Determination Requirements

#### D.1.5 VOC and HAP

---

In order to comply with Conditions D.1.1, and D.1.3, the carbon adsorber vapor recovery unit, or one (1) of the three (3) available backup trailer mounted vapor combustor for VOC and HAP control shall be in operation and control emissions from the loading rack at all times that the rack is in operation loading gasoline.

#### D.1.6 Testing Requirements [326 IAC 2-8-5(a)(1), (4)] [326 IAC 2-1.1-11]

---

- (a) To demonstrate compliance with Condition D.1.1(a), a compliance stack test shall be performed no later than five (5) years from the date of the most recent valid compliance demonstration, at the exhaust of the carbon adsorber vapor recovery unit. This test shall be performed according to 40 CFR 60, Appendix A, Methods 25 and 25A.
- (b) If the commissioner allows alternative test procedures, such method shall be submitted to the U.S. EPA as a SIP revision.
- (c) During compliance tests conducted under 326 IAC 3-6 (stack testing), each vapor balance or control system shall be tested applying the standards described in 40 CFR Part 60 Subpart XX. Testers shall use 40 CFR 60, Appendix A, Method 21 to determine if there are any leaks from the hatches and the flanges of the gasoline transports. If any leak is detected, the transport cannot be used for the capacity of the compliance test of the bulk gas terminal. The threshold for leaks shall be as follows:
  - (1) Five hundred (500) parts per million methane for all bulk gas terminals subject to NESHAP/MACT (40 CFR 63, Subpart R).
  - (2) Ten thousand (10,000) parts per million methane for all bulk gas terminals subject to a New Source Performance Standard.

### Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

#### D.1.7 Carbon Adsorber

---

When operating the VRU to control VOC emissions during loading at the truck loading rack, the Permittee shall monitor and continuously record the carbon bed pressure/vacuum on a strip chart indicating the regeneration cycle. The carbon bed shall be regenerated once every fifteen (15) minutes during active loading or once every five (5) tanker trucks loaded during slack periods when the VRU is in idle mode.

The Permittee shall operate and maintain an automated system to monitor the number of trucks loaded since the last regeneration cycle of the carbon bed. Whenever the VRU is in idle mode the automated system shall shut down the loading rack, if the VRU fails to go through a regeneration cycle after loading five (5) tanker trucks.

## Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]

### D.1.8 Record Keeping Requirements

---

- (a) To document the compliance status with Condition D.1.1(a), the Permittee shall maintain records at the source of the volume in gallons of each fuel dispensed at the loading rack, including purchase orders and invoices necessary to verify the type and amount dispensed;
- (b) To document the compliance status with D.1.3(f), the owner or operator of a vapor balance or vapor control system subject to this section shall maintain records of all compliance testing. The records shall identify the following:
  - (1) The vapor balance, vapor collection, or vapor control system.
  - (2) The date of the test and, if applicable, retest.
  - (3) The results of the test and, if applicable, retest.

The records shall be maintained in a legible, readily available condition for at least two (2) years after the date the testing and, if applicable, retesting were completed.

- (c) To document the compliance status with Condition D.1.3(a), the owner or operator of a gasoline transport subject to this section shall keep a legible copy of the transport's most recent valid annual modified 40 CFR 60, Appendix A, Method 27 test either in the cab of the transport or affixed to the transport trailer. The test record shall identify the following:
  - (1) The gasoline transport.
  - (2) The type and date of the test and, if applicable, date of retest.
  - (3) The test methods, test data, and results certified as true, accurate, and in compliance with this rule by the person who performs the test.

This copy shall be made available immediately upon request to the department and to the owner of the loading facility for inspection and review. The department shall be allowed to make copies of the test results.

- (d) To document the compliance status with Condition D.1.7, the Permittee shall maintain records of the following operation parameters of the carbon adsorber vapor recovery unit:
  - (1) bed pressure; and
  - (2) vacuum level.
- (e) Section C - General Record Keeping Requirements of this permit contains the Permittee's obligations with regard to the records required by this condition.

### D.1.9 Reporting Requirements

---

A quarterly summary of the information to document the compliance status with Condition D.1.1 shall be submitted using the reporting forms located at the end of this permit, or their equivalent, no later than thirty (30) days after the end of the period being reported. Section C - General Reporting contains the Permittee's obligation with regard to the reporting required by this condition. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-8-5(a)(1) by an "authorized individual" as defined by 326 IAC 2-1.1-1(1).

## SECTION D.2 EMISSIONS UNIT OPERATION CONDITIONS

### Emission Unit Description [326 IAC 2-8-4 (10)]

- (b) Storage tank # 1, equipped with a fixed roof, 1,365,000 gallons storage capacity, used to store HS diesel, and constructed in 1941.
- (c) Storage tank #2, equipped with an external pontoon floating roof with a dome, 672,000 gallon storage capacity, used to store Slop interface, and constructed in 1940.
- (d) Storage tank #3, equipped with an external pontoon floating roof with a dome, 672,000 gallon storage capacity, used to store ethanol, and constructed in 1941.
- (e) Storage tank # 4, equipped with a fixed roof, 1,365,000 gallon storage capacity, used to store LS diesel supreme, and constructed in 1941.
- (f) Storage tank # 5, equipped with an internal floating roof as of 2010, 1,365,000 gallon storage capacity, used to store ethanol or distillate fuel oil, constructed in 1941.
- (g) Storage tank #6, equipped with an external pontoon floating roof with a dome, 3,150,000 gallon storage capacity, used to store Subgrade/regular gasoline, and constructed in 1941.  
  
Under 40 CFR Part 63, Subpart BBBBBB, Storage tank #6 is an affected facility.
- (h) Storage tank #7, equipped with an external pontoon floating roof with a dome, 3,150,000 gallon storage capacity, used to store Subgrade/ regular gasoline, and constructed in 1941.  
  
Under 40 CFR Part 63, Subpart BBBBBB, Storage tank #7 is an affected facility.
- (i) Storage tank #8, equipped with an external pontoon floating roof with a dome, 3,150,000 gallon storage capacity, used to store Premium gasoline, and constructed in 1942.  
  
Under 40 CFR Part 63, Subpart BBBBBB, Storage tank #8 is an affected facility.
- (j) Storage tank # 10, equipped with a fixed roof, 92,400 gallon storage capacity, used to store diesel, and constructed in 1941.
- (k) Storage tank # 11, equipped with a fixed roof, 3,360,000 gallon storage capacity, used to store LS diesel, and constructed in 1970.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-8-4(1)]

#### D.2.1 Volatile Organic Compounds [326 IAC 8-4-3]

Pursuant to 326 IAC 8-4-3, storage tanks 1, 2, 3, 4, 5, 6, 7, 8, 10 and 11 shall meet the following requirements:

- (a) The tanks shall be retrofitted with an internal floating roof equipped with a closure seal, or seals, to close the space between the roof edge and tank wall unless the source has been retrofitted with an equally effective alternative control which has been approved.
- (b) The tanks shall be maintained such that there are no visible holes, tears, or other openings in the seal or any seal fabric or materials.

- (c) All openings, except stub drains, shall be equipped with covers, lids, or seals such that:
  - (1) the cover, lid, or seal is in the closed position at all times except when in actual use;
  - (2) automatic bleeder vents are closed at all times except when the roof is floated off or landed on the roof leg supporters; and
  - (3) rim vents, if provided, are set to open when the roof is being floated off the roof leg supports or at the manufacturer's recommended setting.

**D.2.2 Preventive Maintenance Plan [326 IAC 2-8-4(9)]**

---

A Preventive Maintenance Plan is required for these tanks and their floating roofs (as applicable). Section B – Preventive Maintenance Plan contains the Permittee's obligation with regard to the preventive maintenance plan required by this condition.

**Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]**

**D.2.3 Monitoring**

---

The Permittee shall conduct a quarterly inspection of storage tanks 1, 2, 3, 4, 5, 6, 7, 8, 10 and 11 for visible holes, tears, or other openings in the seal or any seal fabric or materials. The inspections required in this condition can be conducted through roof hatches.

**Record Keeping and Reporting Requirement [326 IAC 2-8-4(3)]**

**D.2.4 Record Keeping Requirements [326 IAC 8-4-3(d)]**

---

- (a) To document the compliance status with Condition D.2.1(b), the Permittee shall maintain records of results of the quarterly inspections required in conditions D.2.3.
- (b) Pursuant to 326 IAC 8-4-3(d), the Permittee of storage tanks 1, 2, 3, 4, 5, 6, 7, 8, 10 and 11 shall maintain the following records:
  - (1) petroleum liquid stored,
  - (2) the period of storage, and
  - (3) the maximum true vapor pressure of that liquid during the respective storage period.
- (c) Section C - General Record Keeping Requirements of this permit contains the Permittee's obligations with regard to the records required by this condition.

### SECTION D.3 EMISSION UNIT OPERATION CONDITION

Insignificant emitting activities consisting of the following:

- (a) Fuel oil-fired combustion sources with heat input equal to or less than two million (2,000,000) Btu per hour and firing fuel containing less than five-tenths (0.5) percent sulfur by weight. [326 IAC 6-2-4]
- (p) Degreasing operations that do not exceed 145 gallons per 12 months, except if subject to 326 IAC 20-6. [326 IAC 8-3-2] [326 IAC 8-3-5]

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

#### Emission Limitations and Standards [326 IAC 2-8-4(1)]

##### D.3.1 Volatile Organic Compounds (VOC) [326 IAC 8-3-2]

Pursuant to 326 IAC 8-3-2 (Cold Cleaner Operations), the owner or operator shall:

- (a) Equip the cleaner with a cover;
- (b) Equip the cleaner with a facility for draining cleaned parts;
- (c) Close the degreaser cover whenever parts are not being handled in the cleaner;
- (d) Drain cleaned parts for at least fifteen (15) seconds or until dripping ceases;
- (e) Provide a permanent, conspicuous label summarizing the operation requirements;
- (f) Store waste solvent only in covered containers and not dispose of waste solvent or transfer it to another party, in such a manner that greater than twenty percent (20%) of the waste solvent (by weight) can evaporate into the atmosphere.

##### D.3.2 Volatile Organic Compounds (VOC) [326 IAC 8-3-5]

- (a) Pursuant to 326 IAC 8-3-5(a) (Cold Cleaner Degreaser Operation and Control), the owner or operator of a cold cleaner degreaser facility existing prior to January 1, 1980 shall ensure that the following control equipment requirements are met:
  - (1) Equip the degreaser with a cover. The cover must be designed so that it can be easily operated with one (1) hand if:
    - (A) The solvent volatility is greater than two (2) kiloPascals (fifteen (15) millimeters of mercury or three-tenths (0.3) pounds per square inch) measured at thirty-eight degrees Celsius (38°C) (one hundred degrees Fahrenheit (100°F));
    - (B) The solvent is agitated; or
    - (C) The solvent is heated.
  - (2) Equip the degreaser with a facility for draining cleaned articles. If the solvent volatility is greater than four and three-tenths (4.3) kiloPascals (thirty-two (32) millimeters of mercury or six-tenths (0.6) pounds per square inch) measured at thirty-eight degrees Celsius (38°C) (one hundred degrees Fahrenheit (100°F)), then the drainage facility must be internal such that articles are enclosed under the cover while draining. The drainage facility may be external for applications where an internal type cannot fit into the cleaning system.
  - (3) Provide a permanent, conspicuous label which lists the operating requirements outlined in subsection (b).

- (4) The solvent spray, if used, must be a solid, fluid stream and shall be applied at a pressure which does not cause excessive splashing.
  - (5) Equip the degreaser with one (1) of the following control devices if the solvent volatility is greater than four and three-tenths (4.3) kiloPascals (thirty-two (32) millimeters of mercury or six-tenths (0.6) pounds per square inch) measured at thirty-eight degrees Celsius (38°C) (one hundred degrees Fahrenheit (100°F)), or if the solvent is heated to a temperature greater than forty-eight and nine-tenths degrees Celsius (48.9°C) (one hundred twenty degrees Fahrenheit (120°F)):
    - (A) A freeboard that attains a freeboard ratio of seventy-five hundredths (0.75) or greater.
    - (B) A water cover when solvent is used is insoluble in, and heavier than, water.
    - (C) Other systems of demonstrated equivalent control such as a refrigerated chiller or carbon adsorption. Such systems shall be submitted to the U.S. EPA as a SIP revision.
- (b) Pursuant to 326 IAC 8-3-5(b) (Cold Cleaner Degreaser Operation and Control), the owner or operator of a cold cleaning facility construction of which commenced after July 1, 1990, shall ensure that the following operating requirements are met:
- (1) Close the cover whenever articles are not being handled in the degreaser.
  - (2) Drain cleaned articles for at least fifteen (15) seconds or until dripping ceases.
  - (3) Store waste solvent only in covered containers and prohibit the disposal or transfer of waste solvent in any manner in which greater than twenty percent (20%) of the waste solvent by weight could evaporate.

D.3.3 Particular Emission Limitations for Sources of Indirect Heating (PM) [326 IAC 6-2-4]

Pursuant to 326 IAC 6-2-4 (Particulate Emission Limitations for Sources of Indirect Heating), the particulate emissions from four (4) oil fired boilers, with a total source maximum operating capacity of 0.913 mmBtu/hr shall be limited to 0.6 pounds per mmBtu.

**SECTION E.1 FACILITY OPERATION CONDITIONS - 40 CFR 60, Subpart XX - New Source Performance Standards for Bulk Gasoline Terminals**

**Facility Description [326 IAC 2-8-4(10)]:**

**Emission Units**

- (a) One (1) loading rack for dispensing of petroleum product, with one (1) carbon adsorber, identified as V10, for control of volatile organic compounds. Loading rack installed in 1993.

Under 40 CFR Part 60, Subpart XX and 40 CFR Part 63, Subpart BBBB, the petroleum products loading rack is an affected facility.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

**New Source Performance Standards (NSPS) Requirements:**

**E.1.1 General Provisions Relating to NSPS [326 IAC 12-1][40 CFR Part 60, Subpart A]**

Pursuant to 40 CFR 60.500, the Permittee shall comply with the provisions of 40 CFR Part 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, except when otherwise specified in 40 CFR Part 60, Subpart XX.

**E.1.2 New Source Performance Standards (NSPS) Standards of Performance for Bulk Gasoline Terminals [326 IAC 12][40 CFR Part 60, Subpart XX]**

The Permittee which operates a bulk gasoline terminal loading rack shall comply with the following provisions of 40 CFR Part 60, Subpart XX (included as Attachment A of this permit):

- (1) 40 CFR 60.500 (a) and (b)
- (2) 40 CFR 60.501
- (3) 40 CFR 60.502
- (4) 40 CFR 60.503
- (5) 40 CFR 60.505
- (6) 40 CFR 60.506

**SECTION E.2 FACILITY OPERATION CONDITIONS - 40 CFR 63, Subpart BBBBBB - National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities**

**Facility Description [326 IAC 2-8-4(10)]:**

**Emission Units**

- (a) One (1) loading rack for dispensing of petroleum product, with one (1) carbon adsorber, identified as V10, for control of volatile organic compounds. Loading rack installed in 1993.
- Under 40 CFR Part 60, Subpart XX, the petroleum products loading rack is an affected facility. Under 40 CFR Part 63, Subpart BBBBBB, the petroleum products loading rack is an affected facility.
- (g) Storage tank #6, equipped with an external pontoon floating roof with a dome, 3,150,000 gallon storage capacity, used to store Subgrade/regular gasoline, and constructed in 1941.
- Under 40 CFR Part 63, Subpart BBBBBB, Storage tank #6 is an affected facility.
- (h) Storage tank #7, equipped with an external pontoon floating roof with a dome, 3,150,000 gallon storage capacity, used to store Subgrade/ regular gasoline, and constructed in 1941.
- Under 40 CFR Part 63, Subpart BBBBBB, Storage tank #7 is an affected facility.
- (i) Storage tank #8, equipped with an external pontoon floating roof with a dome, 3,150,000 gallon storage capacity, used to store Premium gasoline, and constructed in 1942.
- Under 40 CFR Part 63, Subpart BBBBBB, Storage tank #8 is an affected facility.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

**National Emission Standards for Hazardous Air Pollutants (NESHAP) Requirements:**

**E.2.1 General Provisions Relating to National Emissions Standards for Hazardous Air Pollutants under 40 CFR Part 63 [326 IAC 20-1] [40 CFR Part 63, Subpart A]**

- (a) Pursuant to 40 CFR 63.11098, the Permittee shall comply with the provisions of 40 CFR Part 63, Subpart A – General Provisions, which are incorporated by reference as 326 IAC 20-1, for the bulk gasoline terminal as specified in Table 3 of 40 CFR Part 63, Subpart BBBBBB in accordance with the schedule in 40 CFR 63, Subpart BBBBBB.
- (b) Pursuant to 40 CFR 63.10, the Permittee shall submit all required notifications and reports to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

E.2.2 National Emissions Standards for Hazardous Air Pollutants for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities [40 CFR Part 63, Subpart BBBBBB]

---

The Permittee shall comply with the following provisions of 40 CFR Part 63, Subpart BBBBBB (included as Attachment B) which are incorporated by reference as 326 IAC 20-1 for the bulk gasoline terminal:

- (1) 40 CFR 63.11080
- (2) 40 CFR 63.11081(a)(1),(b)
- (3) 40 CFR 63.11082(a),(d)
- (4) 40 CFR 63.11083(b),(c)
- (5) 40 CFR 63.11087
- (6) 40 CFR 63.11088
- (7) 40 CFR 63.11089
- (8) 40 CFR 63.11092(a)(2),(b),(c),(d),(e)(2),(f)
- (9) 40 CFR 63.11093
- (10) 40 CFR 63.11094
- (11) 40 CFR 63.11095(a),(b)
- (12) 40 CFR 63.11098
- (13) 40 CFR 63.11099
- (14) 40 CFR 63.11100
- (15) Table 1
- (16) Table 2
- (17) Table 3

## INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT OFFICE OF AIR QUALITY

### FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP) CERTIFICATION

Source Name: BP Products North America Inc. Indianapolis Terminal  
Source Address: 2500 N. Tibbs, Indianapolis, Indiana 46222  
FESOP Permit No.: F097-25559-00076

**This certification shall be included when submitting monitoring, testing reports/results  
or other documents as required by this permit.**

Please check what document is being certified:

- Annual Compliance Certification Letter
- Test Result (specify) \_\_\_\_\_
- Report (specify) \_\_\_\_\_
- Notification (specify) \_\_\_\_\_
- Affidavit (specify) \_\_\_\_\_
- Other (specify) \_\_\_\_\_

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Signature:

Printed Name:

Title/Position:

Date:

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251  
Phone: 317-233-0178  
Fax: 317-233-6865**

**FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP)  
EMERGENCY OCCURRENCE REPORT**

Source Name: BP Products North America Inc. Indianapolis Terminal  
Source Address: 2500 N. Tibbs, Indianapolis, Indiana 46222  
FESOP Permit No.: F097-25559-00076

**This form consists of 2 pages**

**Page 1 of 2**

- |   |
|---|
| <input type="checkbox"/> This is an emergency as defined in 326 IAC 2-7-1(12) <ul style="list-style-type: none"><li>• The Permittee must notify the Office of Air Quality (OAQ), within four (4) business hours (1-800-451-6027 or 317-233-0178, ask for Compliance Section); and</li><li>• The Permittee must submit notice in writing or by facsimile within two (2) working days (Facsimile Number: 317-233-6865), and follow the other requirements of 326 IAC 2-7-16</li></ul> |
|---|

If any of the following are not applicable, mark N/A

Facility/Equipment/Operation:
Control Equipment:
Permit Condition or Operation Limitation in Permit:
Description of the Emergency:
Describe the cause of the Emergency:

If any of the following are not applicable, mark N/A

Page 2 of 2

Date/Time Emergency started:
Date/Time Emergency was corrected:
Was the facility being properly operated at the time of the emergency? Y <input type="checkbox"/> N <input type="checkbox"/> Describe:
Type of Pollutants Emitted: TSP, PM-10, SO <sub>2</sub> , VOC, NO <sub>x</sub> , CO, Pb, other:
Estimated amount of pollutant(s) emitted during emergency:
Describe the steps taken to mitigate the problem:
Describe the corrective actions/response steps taken:
Describe the measures taken to minimize emissions:
If applicable, describe the reasons why continued operation of the facilities are necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw materials of substantial economic value:

Form Completed by: \_\_\_\_\_

Title / Position: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

## INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT OFFICE OF AIR QUALITY COMPLIANCE DATA SECTION

### FESOP Quarterly Report

Source Name: BP Products North America Inc. Indianapolis Terminal  
 Source Address: 2500 N. Tibbs, Indianapolis, Indiana 46222  
 FESOP Permit No.: F097-25559-00076  
 Facility: Loading Rack  
 Parameter: Monthly Throughput to Loading Rack  
 Limit: The amount of gasoline and distillate oil product loaded at the Loading Rack are limited to less than 400,000,000 gallons per 12 consecutive month period and 270,000,000 gallons per 12 consecutive month period, respectively.

QUARTER: \_\_\_\_\_ YEAR: \_\_\_\_\_

Month	Column 1		Column 2		Column 1 + Column 2	
	This Month		Previous 11 Months		12 Month Total	
	gasoline	distillate	gasoline	distillate	gasoline	distillate
Month 1						
Month 2						
Month 3						

- No deviation occurred in this quarter.
- Deviation/s occurred in this quarter.  
 Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_  
 Title / Position: \_\_\_\_\_  
 Signature: \_\_\_\_\_  
 Date: \_\_\_\_\_  
 Phone: \_\_\_\_\_

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
 OFFICE OF AIR QUALITY  
 COMPLIANCE DATA SECTION**

**FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP)  
 QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT**

Source Name: BP Products North America Inc. Indianapolis Terminal  
 Source Address: 2500 N. Tibbs, Indianapolis, Indiana 46222  
 FESOP Permit No.: F097-25559-00076

**Months:** \_\_\_\_\_ **to** \_\_\_\_\_ **Year:** \_\_\_\_\_

<p>This report shall be submitted quarterly based on a calendar year. Any deviation from the requirements of this permit, the date(s) of each deviation, the probable cause of the deviation, and the response steps taken must be reported. A deviation required to be reported pursuant to an applicable requirement that exists independent of the permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. Additional pages may be attached if necessary. If no deviations occurred, please specify in the box marked "No deviations occurred this reporting period".</p>	
<input type="checkbox"/> NO DEVIATIONS OCCURRED THIS REPORTING PERIOD.	
<input type="checkbox"/> THE FOLLOWING DEVIATIONS OCCURRED THIS REPORTING PERIOD	
<b>Permit Requirement</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	
<b>Permit Requirement</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	

<b>Permit Requirement</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	
<b>Permit Requirement</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	
<b>Permit Requirement</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	

Form Completed by: \_\_\_\_\_

Title / Position: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

**Indiana Department of Environmental Management  
Office of Air Quality**

**Attachment A**

**Title 40: Protection of Environment**

**PART 60—STANDARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES**

**Subpart XX—Standards of Performance for Bulk Gasoline Terminals**

**Source:** 48 FR 37590, Aug. 18, 1983, unless otherwise noted.

**§ 60.500 Applicability and designation of affected facility.**

(a) The affected facility to which the provisions of this subpart apply is the total of all the loading racks at a bulk gasoline terminal which deliver liquid product into gasoline tank trucks.

(b) Each facility under paragraph (a) of this section, the construction or modification of which is commenced after December 17, 1980, is subject to the provisions of this subpart.

(c) For purposes of this subpart, any replacement of components of an existing facility, described in paragraph (a) of this section, commenced before August 18, 1983 in order to comply with any emission standard adopted by a State or political subdivision thereof will not be considered a reconstruction under the provisions of 40 CFR 60.15.

**Note:** The intent of these standards is to minimize the emissions of VOC through the application of best demonstrated technologies (BDT). The numerical emission limits in this standard are expressed in terms of total organic compounds. This emission limit reflects the performance of BDT.

**§ 60.501 Definitions.**

The terms used in this subpart are defined in the Clean Air Act, in §60.2 of this part, or in this section as follows:

*Bulk gasoline terminal* means any gasoline facility which receives gasoline by pipeline, ship or barge, and has a gasoline throughput greater than 75,700 liters per day. Gasoline throughput shall be the maximum calculated design throughput as may be limited by compliance with an enforceable condition under Federal, State or local law and discoverable by the Administrator and any other person.

*Continuous vapor processing system* means a vapor processing system that treats total organic compounds vapors collected from gasoline tank trucks on a demand basis without intermediate accumulation in a vapor holder.

*Existing vapor processing system* means a vapor processing system [capable of achieving emissions to the atmosphere no greater than 80 milligrams of total organic compounds per liter of gasoline loaded], the construction or refurbishment of which was commenced before December 17, 1980, and which was not constructed or refurbished after that date.

*Flare* means a thermal oxidation system using an open (without enclosure) flame.

*Gasoline* means any petroleum distillate or petroleum distillate/alcohol blend having a Reid vapor pressure of 27.6 kilopascals or greater which is used as a fuel for internal combustion engines.

*Gasoline tank truck* means a delivery tank truck used at bulk gasoline terminals which is loading gasoline or which has loaded gasoline on the immediately previous load.

*Intermittent vapor processing system* means a vapor processing system that employs an intermediate vapor holder to accumulate total organic compounds vapors collected from gasoline tank trucks, and treats the accumulated vapors only during automatically controlled cycles.

*Loading rack* means the loading arms, pumps, meters, shutoff valves, relief valves, and other piping and valves necessary to fill delivery tank trucks.

*Refurbishment* means, with reference to a vapor processing system, replacement of components of, or addition of components to, the system within any 2-year period such that the fixed capital cost of the new components required for such component replacement or addition exceeds 50 percent of the cost of a comparable entirely new system.

*Thermal oxidation system* means a combustion device used to mix and ignite fuel, air pollutants, and air to provide a flame to heat and oxidize hazardous air pollutants. Auxiliary fuel may be used to heat air pollutants to combustion temperatures.

*Total organic compounds* means those compounds measured according to the procedures in §60.503.

*Vapor collection system* means any equipment used for containing total organic compounds vapors displaced during the loading of gasoline tank trucks.

*Vapor processing system* means all equipment used for recovering or oxidizing total organic compounds vapors displaced from the affected facility.

*Vapor-tight gasoline tank truck* means a gasoline tank truck which has demonstrated within the 12 preceding months that its product delivery tank will sustain a pressure change of not more than 750 pascals (75 mm of water) within 5 minutes after it is pressurized to 4,500 pascals (450 mm of water). This capability is to be demonstrated using the pressure test procedure specified in Method 27.

[48 FR 37590, Aug. 18, 1983, as amended at 65 FR 61763, Oct. 17, 2000; 68 FR 70965, Dec. 19, 2003]

#### **§ 60.502 Standard for Volatile Organic Compound (VOC) emissions from bulk gasoline terminals.**

On and after the date on which §60.8(a) requires a performance test to be completed, the owner or operator of each bulk gasoline terminal containing an affected facility shall comply with the requirements of this section.

- (a) Each affected facility shall be equipped with a vapor collection system designed to collect the total organic compounds vapors displaced from tank trucks during product loading.
- (b) The emissions to the atmosphere from the vapor collection system due to the loading of liquid product into gasoline tank trucks are not to exceed 35 milligrams of total organic compounds per liter of gasoline loaded, except as noted in paragraph (c) of this section.
- (c) For each affected facility equipped with an existing vapor processing system, the emissions to the atmosphere from the vapor collection system due to the loading of liquid product into gasoline tank trucks are not to exceed 80 milligrams of total organic compounds per liter of gasoline loaded.
- (d) Each vapor collection system shall be designed to prevent any total organic compounds vapors collected at one loading rack from passing to another loading rack.
- (e) Loadings of liquid product into gasoline tank trucks shall be limited to vapor-tight gasoline tank trucks using the following procedures:
  - (1) The owner or operator shall obtain the vapor tightness documentation described in §60.505(b) for each gasoline tank truck which is to be loaded at the affected facility.

(2) The owner or operator shall require the tank identification number to be recorded as each gasoline tank truck is loaded at the affected facility.

(3)(i) The owner or operator shall cross-check each tank identification number obtained in paragraph (e)(2) of this section with the file of tank vapor tightness documentation within 2 weeks after the corresponding tank is loaded, unless either of the following conditions is maintained:

(A) If less than an average of one gasoline tank truck per month over the last 26 weeks is loaded without vapor tightness documentation then the documentation cross-check shall be performed each quarter; or

(B) If less than an average of one gasoline tank truck per month over the last 52 weeks is loaded without vapor tightness documentation then the documentation cross-check shall be performed semiannually.

(ii) If either the quarterly or semiannual cross-check provided in paragraphs (e)(3)(i) (A) through (B) of this section reveals that these conditions were not maintained, the source must return to biweekly monitoring until such time as these conditions are again met.

(4) The terminal owner or operator shall notify the owner or operator of each non-vapor-tight gasoline tank truck loaded at the affected facility within 1 week of the documentation cross-check in paragraph (e)(3) of this section.

(5) The terminal owner or operator shall take steps assuring that the nonvapor-tight gasoline tank truck will not be reloaded at the affected facility until vapor tightness documentation for that tank is obtained.

(6) Alternate procedures to those described in paragraphs (e)(1) through (5) of this section for limiting gasoline tank truck loadings may be used upon application to, and approval by, the Administrator.

(f) The owner or operator shall act to assure that loadings of gasoline tank trucks at the affected facility are made only into tanks equipped with vapor collection equipment that is compatible with the terminal's vapor collection system.

(g) The owner or operator shall act to assure that the terminal's and the tank truck's vapor collection systems are connected during each loading of a gasoline tank truck at the affected facility. Examples of actions to accomplish this include training drivers in the hookup procedures and posting visible reminder signs at the affected loading racks.

(h) The vapor collection and liquid loading equipment shall be designed and operated to prevent gauge pressure in the delivery tank from exceeding 4,500 pascals (450 mm of water) during product loading. This level is not to be exceeded when measured by the procedures specified in §60.503(d).

(i) No pressure-vacuum vent in the bulk gasoline terminal's vapor collection system shall begin to open at a system pressure less than 4,500 pascals (450 mm of water).

(j) Each calendar month, the vapor collection system, the vapor processing system, and each loading rack handling gasoline shall be inspected during the loading of gasoline tank trucks for total organic compounds liquid or vapor leaks. For purposes of this paragraph, detection methods incorporating sight, sound, or smell are acceptable. Each detection of a leak shall be recorded and the source of the leak repaired within 15 calendar days after it is detected.

[48 FR 37590, Aug. 18, 1983; 48 FR 56580, Dec. 22, 1983, as amended at 54 FR 6678, Feb. 14, 1989; 64 FR 7466, Feb. 12, 1999]

### **§ 60.503 Test methods and procedures.**

(a) In conducting the performance tests required in §60.8, the owner or operator shall use as reference methods and procedures the test methods in appendix A of this part or other methods and procedures as specified in this section, except as provided in §60.8(b). The three-run requirement of §60.8(f) does not apply to this subpart.

(b) Immediately before the performance test required to determine compliance with §60.502 (b), (c), and (h), the owner or operator shall use Method 21 to monitor for leakage of vapor all potential sources in the terminal's vapor

collection system equipment while a gasoline tank truck is being loaded. The owner or operator shall repair all leaks with readings of 10,000 ppm (as methane) or greater before conducting the performance test.

(c) The owner or operator shall determine compliance with the standards in §60.502 (b) and (c) as follows:

(1) The performance test shall be 6 hours long during which at least 300,000 liters of gasoline is loaded. If this is not possible, the test may be continued the same day until 300,000 liters of gasoline is loaded or the test may be resumed the next day with another complete 6-hour period. In the latter case, the 300,000-liter criterion need not be met. However, as much as possible, testing should be conducted during the 6-hour period in which the highest throughput normally occurs.

(2) If the vapor processing system is intermittent in operation, the performance test shall begin at a reference vapor holder level and shall end at the same reference point. The test shall include at least two startups and shutdowns of the vapor processor. If this does not occur under automatically controlled operations, the system shall be manually controlled.

(3) The emission rate (E) of total organic compounds shall be computed using the following equation:

$$E = K \sum_{i=1}^n (V_{esi} C_{ei}) / (L 10^6)$$

where:

E=emission rate of total organic compounds, mg/liter of gasoline loaded.

$V_{esi}$ =volume of air-vapor mixture exhausted at each interval "i", scm.

$C_{ei}$ =concentration of total organic compounds at each interval "i", ppm.

L=total volume of gasoline loaded, liters.

n=number of testing intervals.

i=emission testing interval of 5 minutes.

K=density of calibration gas,  $1.83 \times 10^6$  for propane and  $2.41 \times 10^6$  for butane, mg/scm.

(4) The performance test shall be conducted in intervals of 5 minutes. For each interval "i", readings from each measurement shall be recorded, and the volume exhausted ( $V_{esi}$ ) and the corresponding average total organic compounds concentration ( $C_{ei}$ ) shall be determined. The sampling system response time shall be considered in determining the average total organic compounds concentration corresponding to the volume exhausted.

(5) The following methods shall be used to determine the volume ( $V_{esi}$ ) air-vapor mixture exhausted at each interval:

(i) Method 2B shall be used for combustion vapor processing systems.

(ii) Method 2A shall be used for all other vapor processing systems.

(6) Method 25A or 25B shall be used for determining the total organic compounds concentration ( $C_{ei}$ ) at each interval. The calibration gas shall be either propane or butane. The owner or operator may exclude the methane and ethane content in the exhaust vent by any method (e.g., Method 18) approved by the Administrator.

(7) To determine the volume (L) of gasoline dispensed during the performance test period at all loading racks whose vapor emissions are controlled by the processing system being tested, terminal records or readings from gasoline dispensing meters at each loading rack shall be used.

(d) The owner or operator shall determine compliance with the standard in §60.502(h) as follows:

(1) A pressure measurement device (liquid manometer, magnehelic gauge, or equivalent instrument), capable of measuring up to 500 mm of water gauge pressure with  $\pm 2.5$  mm of water precision, shall be calibrated and installed on the terminal's vapor collection system at a pressure tap located as close as possible to the connection with the gasoline tank truck.

(2) During the performance test, the pressure shall be recorded every 5 minutes while a gasoline truck is being loaded; the highest instantaneous pressure that occurs during each loading shall also be recorded. Every loading position must be tested at least once during the performance test.

(e) The performance test requirements of paragraph (c) of this section do not apply to flares defined in §60.501 and meeting the requirements in §60.18(b) through (f). The owner or operator shall demonstrate that the flare and associated vapor collection system is in compliance with the requirements in §§60.18(b) through (f) and 60.503(a), (b), and (d).

(f) The owner or operator shall use alternative test methods and procedures in accordance with the alternative test method provisions in §60.8(b) for flares that do not meet the requirements in §60.18(b).

[54 FR 6678, Feb. 14, 1989; 54 FR 21344, Feb. 14, 1989, as amended at 68 FR 70965, Dec. 19, 2003]

#### **§ 60.504 [Reserved]**

#### **§ 60.505 Reporting and recordkeeping.**

(a) The tank truck vapor tightness documentation required under §60.502(e)(1) shall be kept on file at the terminal in a permanent form available for inspection.

(b) The documentation file for each gasoline tank truck shall be updated at least once per year to reflect current test results as determined by Method 27. This documentation shall include, as a minimum, the following information:

(1) Test title: Gasoline Delivery Tank Pressure Test—EPA Reference Method 27.

(2) Tank owner and address.

(3) Tank identification number.

(4) Testing location.

(5) Date of test.

(6) Tester name and signature.

(7) Witnessing inspector, if any: Name, signature, and affiliation.

(8) Test results: Actual pressure change in 5 minutes, mm of water (average for 2 runs).

(c) A record of each monthly leak inspection required under §60.502(j) shall be kept on file at the terminal for at least 2 years. Inspection records shall include, as a minimum, the following information:

(1) Date of inspection.

- (2) Findings (may indicate no leaks discovered; or location, nature, and severity of each leak).
- (3) Leak determination method.
- (4) Corrective action (date each leak repaired; reasons for any repair interval in excess of 15 days).
- (5) Inspector name and signature.
- (d) The terminal owner or operator shall keep documentation of all notifications required under §60.502(e)(4) on file at the terminal for at least 2 years.
- (e) As an alternative to keeping records at the terminal of each gasoline cargo tank test result as required in paragraphs (a), (c), and (d) of this section, an owner or operator may comply with the requirements in either paragraph (e)(1) or (2) of this section.
- (1) An electronic copy of each record is instantly available at the terminal.
- (i) The copy of each record in paragraph (e)(1) of this section is an exact duplicate image of the original paper record with certifying signatures.
- (ii) The permitting authority is notified in writing that each terminal using this alternative is in compliance with paragraph (e)(1) of this section.
- (2) For facilities that utilize a terminal automation system to prevent gasoline cargo tanks that do not have valid cargo tank vapor tightness documentation from loading ( e.g., via a card lock-out system), a copy of the documentation is made available ( e.g., via facsimile) for inspection by permitting authority representatives during the course of a site visit, or within a mutually agreeable time frame.
- (i) The copy of each record in paragraph (e)(2) of this section is an exact duplicate image of the original paper record with certifying signatures.
- (ii) The permitting authority is notified in writing that each terminal using this alternative is in compliance with paragraph (e)(2) of this section.
- (f) The owner or operator of an affected facility shall keep records of all replacements or additions of components performed on an existing vapor processing system for at least 3 years.

[48 FR 37590, Aug. 18, 1983; 48 FR 56580, Dec. 22, 1983, as amended at 68 FR 70965, Dec. 19, 2003]

### **§ 60.506 Reconstruction.**

For purposes of this subpart:

- (a) The cost of the following frequently replaced components of the affected facility shall not be considered in calculating either the “fixed capital cost of the new components” or the “fixed capital costs that would be required to construct a comparable entirely new facility” under §60.15: pump seals, loading arm gaskets and swivels, coupler gaskets, overfill sensor couplers and cables, flexible vapor hoses, and grounding cables and connectors.
- (b) Under §60.15, the “fixed capital cost of the new components” includes the fixed capital cost of all depreciable components (except components specified in §60.506(a)) which are or will be replaced pursuant to all continuous programs of component replacement which are commenced within any 2-year period following December 17, 1980. For purposes of this paragraph, “commenced” means that an owner or operator has undertaken a continuous program of component replacement or that an owner or operator has entered into a contractual obligation to undertake and complete, within a reasonable time, a continuous program of component replacement.

**Indiana Department of Environmental Management  
Office of Air Quality**

**Attachment B**

**Title 40: Protection of Environment**

**PART 63—NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS FOR SOURCE CATEGORIES**

**Subpart BBBBBB—National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities**

**Source:** 73 FR 1933, Jan. 10, 2008, unless otherwise noted.

**What This Subpart Covers**

**§ 63.11080 What is the purpose of this subpart?**

This subpart establishes national emission limitations and management practices for hazardous air pollutants (HAP) emitted from area source gasoline distribution bulk terminals, bulk plants, and pipeline facilities. This subpart also establishes requirements to demonstrate compliance with the emission limitations and management practices.

**§ 63.11081 Am I subject to the requirements in this subpart?**

(a) The affected source to which this subpart applies is each area source bulk gasoline terminal, pipeline breakout station, pipeline pumping station, and bulk gasoline plant identified in paragraphs (a)(1) through (4) of this section. You are subject to the requirements in this subpart if you own or operate one or more of the affected area sources identified in paragraphs (a)(1) through (4) of this section.

(1) A bulk gasoline terminal that is not subject to the control requirements of 40 CFR part 63, subpart R (§§63.422, 63.423, and 63.424) or 40 CFR part 63, subpart CC (§§63.646, 63.648, 63.649, and 63.650).

(2) A pipeline breakout station that is not subject to the control requirements of 40 CFR part 63, subpart R (§§63.423 and 63.424).

(3) A pipeline pumping station.

(4) A bulk gasoline plant.

(b) If you are an owner or operator of affected sources, as defined in (a)(1) through (4) of this section, you are not required to meet the obligation to obtain a permit under 40 CFR part 70 or 40 CFR part 71 as a result of being subject to this subpart. However, you are still subject to the requirement to apply for and obtain a permit under 40 CFR part 70 or 40 CFR part 71 if you meet one or more of the applicability criteria found in 40 CFR 70.3(a) and (b) or 40 CFR part 71.3(a) and (b).

**§ 63.11082 What parts of my affected source does this subpart cover?**

(a) The emission sources to which this subpart applies are gasoline storage tanks, gasoline loading racks, vapor collection-equipped gasoline cargo tanks, and equipment components in vapor or liquid gasoline service that meet the criteria specified in Tables 1 through 3 to this subpart.

(b) An affected source is a new affected source if you commenced construction on the affected source after November 9, 2006, and you meet the applicability criteria in §63.11081 at the time you commenced operation.

(c) An affected source is reconstructed if you meet the criteria for reconstruction as defined in §63.2.

(d) An affected source is an existing affected source if it is not new or reconstructed.

### **§ 63.11083 When do I have to comply with this subpart?**

(a) If you have a new or reconstructed affected source, you must comply with this subpart according to paragraphs (a)(1) and (2) of this section.

(1) If you start up your affected source before January 10, 2008, you must comply with the standards in this subpart no later than January 10, 2008.

(2) If you start up your affected source after January 10, 2008, you must comply with the standards in this subpart upon startup of your affected source.

(b) If you have an existing affected source, you must comply with the standards in this subpart no later than January 10, 2011.

(c) If you have an existing affected source that becomes subject to the control requirements in this subpart because of an increase in the average daily throughput, as specified in option 1 of Table 2 to this subpart, you must comply with the standards in this subpart no later than 3 years after the affected source becomes subject to the control requirements in this subpart.

### **Emission Limitations and Management Practices**

#### **§ 63.11086 What requirements must I meet if my facility is a bulk gasoline plant?**

Each owner or operator of an affected bulk gasoline plant, as defined in §63.11100, must comply with the requirements of paragraphs (a) through (i) of this section.

(a) Except as specified in paragraph (b), you must only load gasoline into storage tanks and cargo tanks at your facility by utilizing submerged filling, as defined in §63.11100, and, as specified in paragraph (a)(1) or paragraph (a)(2) of this section.

(1) Submerged fill pipes installed on or before November 9, 2006, must be no more than 12 inches from the bottom of the tank.

(2) Submerged fill pipes installed after November 9, 2006, must be no more than 6 inches from the bottom of the tank.

(b) The emission sources listed in paragraphs (b)(1) through (2) of this section are not required to comply with the control requirements in paragraph (a) of this section, but must comply only with the requirements in paragraph (d) of this section.

(1) Gasoline storage tanks with a capacity of less than 250 gallons.

(2) Gasoline storage tanks that are subject to subpart CCCCCC of this part.

(c) You must perform a monthly leak inspection of all equipment in gasoline service according to the requirements specified in §63.11089(a) through (d).

(d) You must not allow gasoline to be handled in a manner that would result in vapor releases to the atmosphere for extended periods of time. Measures to be taken include, but are not limited to, the following:

(1) Minimize gasoline spills;

(2) Clean up spills as expeditiously as practicable;

(3) Cover all open gasoline containers and all gasoline storage tank fill-pipes with a gasketed seal when not in use;

(4) Minimize gasoline sent to open waste collection systems that collect and transport gasoline to reclamation and recycling devices, such as oil/water separators.

(e) You must submit an Initial Notification that you are subject to this subpart by May 9, 2008 unless you meet the requirements in paragraph (g) of this section. The Initial Notification must contain the information specified in paragraphs (e)(1) through (4) of this section. The notification must be submitted to the applicable EPA Regional Office and the delegated State authority, as specified in §63.13.

(1) The name and address of the owner and the operator.

(2) The address (i.e., physical location) of the bulk plant.

(3) A statement that the notification is being submitted in response to this subpart and identifying the requirements in paragraphs (a), (b), (c), and (d) of this section that apply to you.

(4) A brief description of the bulk plant, including the number of storage tanks in gasoline service, the capacity of each storage tank in gasoline service, and the average monthly gasoline throughput at the affected source.

(f) You must submit a Notification of Compliance Status to the applicable EPA Regional Office and the delegated State authority, as specified in §63.13, by the compliance date specified in §63.11083 unless you meet the requirements in paragraph (g) of this section. The Notification of Compliance Status must be signed by a responsible official who must certify its accuracy and must indicate whether the source has complied with the requirements of this subpart. If your facility is in compliance with the requirements of this subpart at the time the Initial Notification required under paragraph (e) of this section is due, the Notification of Compliance Status may be submitted in lieu of the Initial Notification provided it contains the information required under paragraph (e) of this section.

(g) If, prior to January 10, 2008, you are operating in compliance with an enforceable State, local, or tribal rule or permit that requires submerged fill as specified in §63.11086(a), you are not required to submit an Initial Notification or a Notification of Compliance Status under paragraph (e) or paragraph (f) of this section.

(h) You must comply with the requirements of this subpart by the applicable dates specified in §63.11083.

(i) You must keep applicable records and submit reports as specified in §63.11094(d) and (e) and §63.11095(c).

**§ 63.11087 What requirements must I meet for gasoline storage tanks if my facility is a bulk gasoline terminal, pipeline breakout station, or pipeline pumping station?**

- (a) You must meet each emission limit and management practice in Table 1 to this subpart that applies to your gasoline storage tank.
- (b) You must comply with the requirements of this subpart by the applicable dates specified in §63.11083, except that storage vessels equipped with floating roofs and not meeting the requirements of paragraph (a) of this section must be in compliance at the first degassing and cleaning activity after January 10, 2011 or by January 10, 2018, whichever is first.
- (c) You must comply with the applicable testing and monitoring requirements specified in §63.11092(e).
- (d) You must submit the applicable notifications as required under §63.11093.
- (e) You must keep records and submit reports as specified in §§63.11094 and 63.11095.
- (f) If your gasoline storage tank is subject to, and complies with, the control requirements of 40 CFR part 60, subpart Kb of this chapter, your storage tank will be deemed in compliance with this section. You must report this determination in the Notification of Compliance Status report under §63.11093(b).

**§ 63.11088 What requirements must I meet for gasoline loading racks if my facility is a bulk gasoline terminal, pipeline breakout station, or pipeline pumping station?**

- (a) You must meet each emission limit and management practice in Table 2 to this subpart that applies to you.
- (b) As an alternative for railcar cargo tanks to the requirements specified in Table 2 to this subpart, you may comply with the requirements specified in §63.422(e).
- (c) You must comply with the requirements of this subpart by the applicable dates specified in §63.11083.
- (d) You must comply with the applicable testing and monitoring requirements specified in §63.11092.
- (e) You must submit the applicable notifications as required under §63.11093.
- (f) You must keep records and submit reports as specified in §§63.11094 and 63.11095.

**§ 63.11089 What requirements must I meet for equipment leak inspections if my facility is a bulk gasoline terminal, bulk plant, pipeline breakout station, or pipeline pumping station?**

- (a) Each owner or operator of a bulk gasoline terminal, bulk plant, pipeline breakout station, or pipeline pumping station subject to the provisions of this subpart shall perform a monthly leak inspection of all equipment in gasoline service, as defined in §63.11100. For this inspection, detection methods incorporating sight, sound, and smell are acceptable.
- (b) A log book shall be used and shall be signed by the owner or operator at the completion of each inspection. A section of the log book shall contain a list, summary description, or diagram(s) showing the location of all equipment in gasoline service at the facility.
- (c) Each detection of a liquid or vapor leak shall be recorded in the log book. When a leak is detected, an initial attempt at repair shall be made as soon as practicable, but no later than 5 calendar days after the leak is detected. Repair or replacement of leaking equipment shall be completed within 15 calendar days after detection of each leak, except as provided in paragraph (d) of this section.

(d) Delay of repair of leaking equipment will be allowed if the repair is not feasible within 15 days. The owner or operator shall provide in the semiannual report specified in §63.11095(b), the reason(s) why the repair was not feasible and the date each repair was completed.

(e) You must comply with the requirements of this subpart by the applicable dates specified in §63.11083.

(f) You must submit the applicable notifications as required under §63.11093.

(g) You must keep records and submit reports as specified in §§63.11094 and 63.11095.

## Testing and Monitoring Requirements

### § 63.11092 What testing and monitoring requirements must I meet?

(a) Each owner or operator subject to the emission standard in §63.11088 for gasoline loading racks must comply with the requirements in paragraphs (a) through (d) of this section.

(1) Conduct a performance test on the vapor processing and collection systems according to either paragraph (a)(1)(i) or paragraph (a)(1)(ii) of this section.

(i) Use the test methods and procedures in §60.503 of this chapter, except a reading of 500 parts per million shall be used to determine the level of leaks to be repaired under §60.503(b) of this chapter.

(ii) Use alternative test methods and procedures in accordance with the alternative test method requirements in §63.7(f).

(2) If you are operating your gasoline loading rack in compliance with an enforceable State, local, or tribal rule or permit that requires your loading rack to meet an emission limit of 80 milligrams (mg), or less, per liter of gasoline loaded (mg/l), you may submit a statement by a responsible official of your facility certifying the compliance status of your loading rack in lieu of the test required under paragraph (a)(1) of this section.

(3) If you have conducted performance testing on the vapor processing and collection systems within 5 years prior to January 10, 2008, and the test is for the affected facility and is representative of current or anticipated operating processes and conditions, you may submit the results of such testing in lieu of the test required under paragraph (a)(1) of this section, provided the testing was conducted using the test methods and procedures in §60.503 of this chapter. Should the Administrator deem the prior test data unacceptable, the facility is still required to meet the requirement to conduct an initial performance test within 180 days of the compliance date specified in §63.11083; thus, previous test reports should be submitted as soon as possible after January 10, 2008.

(4) The performance test requirements of §63.11092(a) do not apply to flares defined in §63.11100 and meeting the flare requirements in §63.11(b). The owner or operator shall demonstrate that the flare and associated vapor collection system is in compliance with the requirements in §63.11(b) and 40 CFR 60.503(a), (b), and (d).

(b) For each performance test conducted under paragraph (a)(1) of this section, the owner or operator shall determine a monitored operating parameter value for the vapor processing system using the procedures specified in paragraphs (b)(1) through (5) of this section.

(1) Each owner or operator of a bulk gasoline terminal subject to the provisions of this subpart shall install, calibrate, certify, operate, and maintain, according to the manufacturer's specifications, a continuous monitoring system (CMS) while gasoline vapors are displaced to the vapor processor systems specified in

paragraphs (b)(1)(i) through (iv) of this section. During the performance test, continuously record the operating parameter as specified under paragraphs (b)(1)(i) through (iv) of this section.

(i) Where a carbon adsorption system is used, the owner or operator shall monitor the operation of the system as specified in paragraphs (b)(1)(i)(A) or (B) of this section.

(A) A continuous emissions monitoring system (CEMS) capable of measuring organic compound concentration shall be installed in the exhaust air stream.

(B) As an alternative to paragraph (b)(1)(i)(A) of this section, you may choose to meet the requirements listed in paragraph (b)(1)(i)(B)( 1 ) and ( 2 ) of this section.

( 1 ) Carbon adsorption devices shall be monitored as specified in paragraphs (b)(1)(i)(B)( 1 )( i ),( ii ), and ( iii ) of this section.

( i ) Vacuum level shall be monitored using a pressure transmitter installed in the vacuum pump suction line, with the measurements displayed on a gauge that can be visually observed. Each carbon bed shall be observed during one complete regeneration cycle on each day of operation of the loading rack to determine the maximum vacuum level achieved.

( ii ) Conduct annual testing of the carbon activity for the carbon in each carbon bed. Carbon activity shall be tested in accordance with the butane working capacity test of the American Society for Testing and Materials (ASTM) Method D 5228–92 (incorporated by reference, see §63.14), or by another suitable procedure as recommended by the manufacturer.

( iii ) Conduct monthly measurements of the carbon bed outlet volatile organic compounds (VOC) concentration over the last 5 minutes of an adsorption cycle for each carbon bed, documenting the highest measured VOC concentration. Measurements shall be made using a portable analyzer, in accordance with 40 CFR part 60, Appendix A–7, EPA Method 21 for open-ended lines.

( 2 ) Develop and submit to the Administrator a monitoring and inspection plan that describes the owner or operator's approach for meeting the requirements in paragraphs (b)(1)(i)(B)( 2 )( i ) through ( v ) of this section.

( i ) The lowest maximum required vacuum level and duration needed to assure regeneration of the carbon beds shall be determined by an engineering analysis or from the manufacturer's recommendation and shall be documented in the monitoring and inspection plan.

( ii ) The owner or operator shall verify, during each day of operation of the loading rack, the proper valve sequencing, cycle time, gasoline flow, purge air flow, and operating temperatures. Verification shall be through visual observation or through an automated alarm or shutdown system that monitors and records system operation.

( iii ) The owner or operator shall perform semi-annual preventive maintenance inspections of the carbon adsorption system according to the recommendations of the manufacturer of the system.

( iv ) The monitoring plan developed under paragraph ( 2 ) of this section shall specify conditions that would be considered malfunctions of the carbon adsorption system during the inspections or automated monitoring performed under paragraphs (b)(1)(i)(B)( 2 )( i ) through ( iii ) of this section, describe specific corrective actions that will be taken to correct any malfunction, and define what the owner or operator would consider to be a timely repair for each potential malfunction.

( v ) The owner or operator shall document the maximum vacuum level observed on each carbon bed from each daily inspection and the maximum VOC concentration observed from each carbon bed on each monthly inspection as well as any system malfunction, as defined in the monitoring and inspection plan, and any activation of the automated alarm or shutdown system with a written entry into a log book or other permanent form of record. Such record shall also include a description of the corrective action taken and whether such corrective actions were taken in a timely manner, as defined in the monitoring and inspection plan, as well as an estimate of the amount of gasoline loaded during the period of the malfunction.

(ii) Where a refrigeration condenser system is used, a continuous parameter monitoring system (CPMS) capable of measuring temperature shall be installed immediately downstream from the outlet to the condenser section. Alternatively, a CEMS capable of measuring organic compound concentration may be installed in the exhaust air stream.

(iii) Where a thermal oxidation system other than a flare is used, the owner or operator shall monitor the operation of the system as specified in paragraphs (b)(1)(iii)(A) or (B) of this section.

(A) A CPMS capable of measuring temperature shall be installed in the firebox or in the ductwork immediately downstream from the firebox in a position before any substantial heat exchange occurs.

(B) As an alternative to paragraph (b)(1)(iii)(A) of this section, you may choose to meet the requirements listed in paragraphs (b)(1)(iii)(B)( 1 ) and ( 2 ) of this section.

( 1 ) The presence of a thermal oxidation system pilot flame shall be monitored using a heat-sensing device, such as an ultraviolet beam sensor or a thermocouple, installed in proximity to the pilot light to indicate the presence of a flame.

( 2 ) Develop and submit to the Administrator a monitoring and inspection plan that describes the owner or operator's approach for meeting the requirements in paragraphs (b)(1)(iii)(B)( 2 )( i ) through ( v ) of this section.

( i ) The thermal oxidation system shall be equipped to automatically prevent gasoline loading operations from beginning at any time that the pilot flame is absent.

( ii ) The owner or operator shall verify, during each day of operation of the loading rack, the proper operation of the assist-air blower, the vapor line valve, and the emergency shutdown system. Verification shall be through visual observation or through an automated alarm or shutdown system that monitors and records system operation.

( iii ) The owner or operator shall perform semi-annual preventive maintenance inspections of the thermal oxidation system according to the recommendations of the manufacturer of the system.

( iv ) The monitoring plan developed under paragraph ( 2 ) of this section shall specify conditions that would be considered malfunctions of the thermal oxidation system during the inspections or automated monitoring performed under paragraphs (b)(1)(iii)(B)( 2 )( ii ) and ( iii ) of this section, describe specific corrective actions that will be taken to correct any malfunction, and define what the owner or operator would consider to be a timely repair for each potential malfunction.

( v ) The owner or operator shall document any system malfunction, as defined in the monitoring and inspection plan, and any activation of the automated alarm or shutdown system with a written entry into a log book or other permanent form of record. Such record shall also include a description of the corrective action taken and whether such corrective actions were taken in a timely manner, as defined in the monitoring and inspection plan, as well as an estimate of the amount of gasoline loaded during the period of the malfunction.

(iv) Monitoring an alternative operating parameter or a parameter of a vapor processing system other than those listed in paragraphs (b)(1)(i) through (iii) of this section will be allowed upon demonstrating to the Administrator's satisfaction that the alternative parameter demonstrates continuous compliance with the emission standard in §63.11088(a).

(2) Where a flare meeting the requirements in §63.11(b) is used, a heat-sensing device, such as an ultraviolet beam sensor or a thermocouple, must be installed in proximity to the pilot light to indicate the presence of a flame.

(3) Determine an operating parameter value based on the parameter data monitored during the performance test, supplemented by engineering assessments and the manufacturer's recommendations.

(4) Provide for the Administrator's approval the rationale for the selected operating parameter value, monitoring frequency, and averaging time, including data and calculations used to develop the value and a description of why the value, monitoring frequency, and averaging time demonstrate continuous compliance with the emission standard in §63.11088(a).

(5) If you have chosen to comply with the performance testing alternatives provided under paragraph (a)(2) or paragraph (a)(3) of this section, the monitored operating parameter value may be determined according to the provisions in paragraph (b)(5)(i) or paragraph (b)(5)(ii) of this section.

(i) Monitor an operating parameter that has been approved by the Administrator and is specified in your facility's current enforceable operating permit. At the time that the Administrator requires a new performance test, you must determine the monitored operating parameter value according to the requirements specified in paragraph (b) of this section.

(ii) Determine an operating parameter value based on engineering assessment and the manufacturer's recommendation and submit the information specified in paragraph (b)(4) of this section for approval by the Administrator. At the time that the Administrator requires a new performance test, you must determine the monitored operating parameter value according to the requirements specified in paragraph (b) of this section.

(c) For performance tests performed after the initial test required under paragraph (a) of this section, the owner or operator shall document the reasons for any change in the operating parameter value since the previous performance test.

(d) Each owner or operator of a bulk gasoline terminal subject to the provisions of this subpart shall comply with the requirements in paragraphs (d)(1) through (4) of this section.

(1) Operate the vapor processing system in a manner not to exceed or not to go below, as appropriate, the operating parameter value for the parameters described in paragraph (b)(1) of this section.

(2) In cases where an alternative parameter pursuant to paragraph (b)(1)(iv) or paragraph (b)(5)(i) of this section is approved, each owner or operator shall operate the vapor processing system in a manner not to exceed or not to go below, as appropriate, the alternative operating parameter value.

(3) Operation of the vapor processing system in a manner exceeding or going below the operating parameter value, as appropriate, shall constitute a violation of the emission standard in §63.11088(a), except as specified in paragraph (d)(4) of this section.

(4) For the monitoring and inspection, as required under paragraphs (b)(1)(i)(B)( 2 ) and (b)(1)(iii)(B)( 2 ) of this section, malfunctions that are discovered shall not constitute a violation of the emission standard in

§63.11088(a) if corrective actions as described in the monitoring and inspection plan are followed. The owner or operator must:

(i) Initiate corrective action to determine the cause of the problem within 1 hour;

(ii) Initiate corrective action to fix the problem within 24 hours;

(iii) Complete all corrective actions needed to fix the problem as soon as practicable consistent with good air pollution control practices for minimizing emissions;

(iv) Minimize periods of start-up, shutdown, or malfunction; and

(v) Take any necessary corrective actions to restore normal operation and prevent the recurrence of the cause of the problem.

(e) Each owner or operator subject to the emission standard in §63.11087 for gasoline storage tanks shall comply with the requirements in paragraphs (e)(1) through (3) of this section.

(1) If your gasoline storage tank is equipped with an internal floating roof, you must perform inspections of the floating roof system according to the requirements of §60.113b(a) if you are complying with option 2(b) in Table 1 to this subpart, or according to the requirements of §63.1063(c)(1) if you are complying with option 2(d) in Table 1 to this subpart.

(2) If your gasoline storage tank is equipped with an external floating roof, you must perform inspections of the floating roof system according to the requirements of §60.113b(b) if you are complying with option 2(c) in Table 1 to this subpart, or according to the requirements of §63.1063(c)(2) if you are complying with option 2(d) in Table 1 to this subpart.

(3) If your gasoline storage tank is equipped with a closed vent system and control device, you must conduct a performance test and determine a monitored operating parameter value in accordance with the requirements in paragraphs (a) through (d) of this section, except that the applicable level of control specified in paragraph (a)(2) of this section shall be a 95-percent reduction in inlet total organic compounds (TOC) levels rather than 80 mg/l of gasoline loaded.

(f) The annual certification test for gasoline cargo tanks shall consist of the test methods specified in paragraphs (f)(1) or (f)(2) of this section.

(1) *EPA Method 27, Appendix A-8, 40 CFR part 60.* Conduct the test using a time period (t) for the pressure and vacuum tests of 5 minutes. The initial pressure ( $P_i$ ) for the pressure test shall be 460 millimeters (mm) of water (18 inches of water), gauge. The initial vacuum ( $V_i$ ) for the vacuum test shall be 150 mm of water (6 inches of water), gauge. The maximum allowable pressure and vacuum changes ( $\Delta p$ ,  $\Delta v$ ) for all affected gasoline cargo tanks is 3 inches of water, or less, in 5 minutes.

(2) *Railcar bubble leak test procedures.* As an alternative to the annual certification test required under paragraph (1) of this section for certification leakage testing of gasoline cargo tanks, the owner or operator may comply with paragraphs (f)(2)(i) and (ii) of this section for railcar cargo tanks, provided the railcar cargo tank meets the requirement in paragraph (f)(2)(iii) of this section.

(i) Comply with the requirements of 49 CFR 173.31(d), 49 CFR 179.7, 49 CFR 180.509, and 49 CFR 180.511 for the periodic testing of railcar cargo tanks.

(ii) The leakage pressure test procedure required under 49 CFR 180.509(j) and used to show no indication of leakage under 49 CFR 180.511(f) shall be ASTM E 515–95, BS EN 1593:1999, or another bubble leak test procedure meeting the requirements in 49 CFR 179.7, 49 CFR 180.505, and 49 CFR 180.509.

(iii) The alternative requirements in this paragraph (f)(2) may not be used for any railcar cargo tank that collects gasoline vapors from a vapor balance system and the system complies with a Federal, State, local, or tribal rule or permit. A vapor balance system is a piping and collection system designed to collect gasoline vapors displaced from a storage vessel, barge, or other container being loaded, and routes the displaced gasoline vapors into the railcar cargo tank from which liquid gasoline is being unloaded.

[73 FR 1933, Jan. 10, 2008 as amended at 73 FR 12276, Mar. 7, 2008]

## Notifications, Records, and Reports

### § 63.11093 What notifications must I submit and when?

(a) Each owner or operator of an affected source under this subpart must submit an Initial Notification as specified in §63.9(b). If your facility is in compliance with the requirements of this subpart at the time the Initial Notification is due, the Notification of Compliance Status required under paragraph (b) of this section may be submitted in lieu of the Initial Notification.

(b) Each owner or operator of an affected source under this subpart must submit a Notification of Compliance Status as specified in §63.9(h). The Notification of Compliance Status must specify which of the compliance options included in Table 1 to this subpart is used to comply with this subpart.

(c) Each owner or operator of an affected bulk gasoline terminal under this subpart must submit a Notification of Performance Test, as specified in §63.9(e), prior to initiating testing required by §63.11092(a) or §63.11092(b).

(d) Each owner or operator of any affected source under this subpart must submit additional notifications specified in §63.9, as applicable.

### § 63.11094 What are my recordkeeping requirements?

(a) Each owner or operator of a bulk gasoline terminal or pipeline breakout station whose storage vessels are subject to the provisions of this subpart shall keep records as specified in §60.115b of this chapter if you are complying with options 2(a), 2(b), or 2(c) in Table 1 to this subpart, except records shall be kept for at least 5 years. If you are complying with the requirements of option 2(d) in Table 1 to this subpart, you shall keep records as specified in §63.1065.

(b) Each owner or operator of a bulk gasoline terminal subject to the provisions of this subpart shall keep records of the test results for each gasoline cargo tank loading at the facility as specified in paragraphs (b)(1) through (3) of this section.

(1) Annual certification testing performed under §63.11092(f)(1) and periodic railcar bubble leak testing performed under §63.11092(f)(2).

(2) The documentation file shall be kept up-to-date for each gasoline cargo tank loading at the facility. The documentation for each test shall include, as a minimum, the following information:

(i) *Name of test:* Annual Certification Test—Method 27 or Periodic Railcar Bubble Leak Test Procedure.

(ii) Cargo tank owner's name and address.

(iii) Cargo tank identification number.

(iv) Test location and date.

(v) Tester name and signature.

(vi) *Witnessing inspector, if any*: Name, signature, and affiliation.

(vii) *Vapor tightness repair*: Nature of repair work and when performed in relation to vapor tightness testing.

(viii) *Test results*: Test pressure; pressure or vacuum change, mm of water; time period of test; number of leaks found with instrument; and leak definition.

(3) If you are complying with the alternative requirements in §63.11088(b), you must keep records documenting that you have verified the vapor tightness testing according to the requirements of the Administrator.

(c) As an alternative to keeping records at the terminal of each gasoline cargo tank test result as required in paragraph (b) of this section, an owner or operator may comply with the requirements in either paragraph (c)(1) or paragraph (c)(2) of this section.

(1) An electronic copy of each record is instantly available at the terminal.

(i) The copy of each record in paragraph (c)(1) of this section is an exact duplicate image of the original paper record with certifying signatures.

(ii) The Administrator is notified in writing that each terminal using this alternative is in compliance with paragraph (c)(1) of this section.

(2) For facilities that use a terminal automation system to prevent gasoline cargo tanks that do not have valid cargo tank vapor tightness documentation from loading (e.g., via a card lock-out system), a copy of the documentation is made available (e.g., via facsimile) for inspection by the Administrator's delegated representatives during the course of a site visit, or within a mutually agreeable time frame.

(i) The copy of each record in paragraph (c)(2) of this section is an exact duplicate image of the original paper record with certifying signatures.

(ii) The Administrator is notified in writing that each terminal using this alternative is in compliance with paragraph (c)(2) of this section.

(d) Each owner or operator subject to the equipment leak provisions of §63.11089 shall prepare and maintain a record describing the types, identification numbers, and locations of all equipment in gasoline service. For facilities electing to implement an instrument program under §63.11089, the record shall contain a full description of the program.

(e) Each owner or operator of an affected source subject to equipment leak inspections under §63.11089 shall record in the log book for each leak that is detected the information specified in paragraphs (e)(1) through (7) of this section.

(1) The equipment type and identification number.

(2) The nature of the leak (i.e., vapor or liquid) and the method of detection (i.e., sight, sound, or smell).

(3) The date the leak was detected and the date of each attempt to repair the leak.

(4) Repair methods applied in each attempt to repair the leak.

(5) "Repair delayed" and the reason for the delay if the leak is not repaired within 15 calendar days after discovery of the leak.

(6) The expected date of successful repair of the leak if the leak is not repaired within 15 days.

(7) The date of successful repair of the leak.

(f) Each owner or operator of a bulk gasoline terminal subject to the provisions of this subpart shall:

(1) Keep an up-to-date, readily accessible record of the continuous monitoring data required under §63.11092(b) or §63.11092(e). This record shall indicate the time intervals during which loadings of gasoline cargo tanks have occurred or, alternatively, shall record the operating parameter data only during such loadings. The date and time of day shall also be indicated at reasonable intervals on this record.

(2) Record and report simultaneously with the Notification of Compliance Status required under §63.11093(b):

(i) All data and calculations, engineering assessments, and manufacturer's recommendations used in determining the operating parameter value under §63.11092(b) or §63.11092(e); and

(ii) The following information when using a flare under provisions of §63.11(b) to comply with §63.11087(a):

(A) Flare design (i.e., steam-assisted, air-assisted, or non-assisted); and

(B) All visible emissions (VE) readings, heat content determinations, flow rate measurements, and exit velocity determinations made during the compliance determination required under §63.11092(e)(3).

(3) Keep an up-to-date, readily accessible copy of the monitoring and inspection plan required under §63.11092(b)(1)(i)(B)( 2 ) or §63.11092(b)(1)(iii)(B)( 2 ).

(4) Keep an up-to-date, readily accessible record of all system malfunctions, as specified in §63.11092(b)(1)(i)(B)( 2 )( v ) or §63.11092(b)(1)(iii)(B)( 2 )( v ).

(5) If an owner or operator requests approval to use a vapor processing system or monitor an operating parameter other than those specified in §63.11092(b), the owner or operator shall submit a description of planned reporting and recordkeeping procedures.

### **§ 63.11095 What are my reporting requirements?**

(a) Each owner or operator of a bulk terminal or a pipeline breakout station subject to the control requirements of this subpart shall include in a semiannual compliance report to the Administrator the following information, as applicable:

(1) For storage vessels, if you are complying with options 2(a), 2(b), or 2(c) in Table 1 to this subpart, the information specified in §60.115b(a), §60.115b(b), or §60.115b(c) of this chapter, depending upon the

control equipment installed, or, if you are complying with option 2(d) in Table 1 to this subpart, the information specified in §63.1066.

(2) For loading racks, each loading of a gasoline cargo tank for which vapor tightness documentation had not been previously obtained by the facility.

(3) For equipment leak inspections, the number of equipment leaks not repaired within 15 days after detection.

(b) Each owner or operator of an affected source subject to the control requirements of this subpart shall submit an excess emissions report to the Administrator at the time the semiannual compliance report is submitted. Excess emissions events under this subpart, and the information to be included in the excess emissions report, are specified in paragraphs (b)(1) through (5) of this section.

(1) Each instance of a non-vapor-tight gasoline cargo tank loading at the facility in which the owner or operator failed to take steps to assure that such cargo tank would not be reloaded at the facility before vapor tightness documentation for that cargo tank was obtained.

(2) Each reloading of a non-vapor-tight gasoline cargo tank at the facility before vapor tightness documentation for that cargo tank is obtained by the facility in accordance with §63.11094(b).

(3) Each exceedance or failure to maintain, as appropriate, the monitored operating parameter value determined under §63.11092(b). The report shall include the monitoring data for the days on which exceedances or failures to maintain have occurred, and a description and timing of the steps taken to repair or perform maintenance on the vapor collection and processing systems or the CMS.

(4) Each instance in which malfunctions discovered during the monitoring and inspections required under §63.11092(b)(1)(i)(B)( 2 ) and (b)(1)(iii)(B)( 2 ) were not resolved according to the necessary corrective actions described in the monitoring and inspection plan. The report shall include a description of the malfunction and the timing of the steps taken to correct the malfunction.

(5) For each occurrence of an equipment leak for which no repair attempt was made within 5 days or for which repair was not completed within 15 days after detection:

(i) The date on which the leak was detected;

(ii) The date of each attempt to repair the leak;

(iii) The reasons for the delay of repair; and

(iv) The date of successful repair.

(c) Each owner or operator of a bulk gasoline plant or a pipeline pumping station shall submit a semiannual excess emissions report, including the information specified in paragraphs (a)(3) and (b)(5) of this section, only for a 6-month period during which an excess emission event has occurred. If no excess emission events have occurred during the previous 6-month period, no report is required.

[73 FR 1933, Jan. 10, 2008 as amended at 73 FR 12276, Mar. 7, 2008]

#### **Other Requirements and Information**

#### **§ 63.11098 What parts of the General Provisions apply to me?**

Table 3 to this subpart shows which parts of the General Provisions apply to you.

### **§ 63.11099 Who implements and enforces this subpart?**

(a) This subpart can be implemented and enforced by the U.S. EPA or a delegated authority such as the applicable State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to a State, local, or tribal agency, then that agency, in addition to the U.S. EPA, has the authority to implement and enforce this subpart. Contact the applicable U.S. EPA Regional Office to find out if implementation and enforcement of this subpart is delegated to a State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under subpart E of this part, the authorities specified in paragraph (c) of this section are retained by the Administrator of U.S. EPA and cannot be transferred to the State, local, or tribal agency.

(c) The authorities that cannot be delegated to State, local, or tribal agencies are as specified in paragraphs (c)(1) through (4) of this section.

(1) Approval of alternatives to the requirements in §§63.11086 through 63.11088 and §63.11092. Any owner or operator requesting to use an alternative means of emission limitation for storage vessels in Table 1 to this subpart must follow either the provisions in §60.114b of this chapter if you are complying with options 2(a), 2(b), or 2(c) in Table 1 to this subpart, or the provisions in §63.1064 if you are complying with option 2(d) in Table 1 to this subpart.

(2) Approval of major alternatives to test methods under §63.7(e)(2)(ii) and (f), as defined in §63.90, and as required in this subpart.

(3) Approval of major alternatives to monitoring under §63.8(f), as defined in §63.90, and as required in this subpart.

(4) Approval of major alternatives to recordkeeping and reporting under §63.10(f), as defined in §63.90, and as required in this subpart.

### **§ 63.11100 What definitions apply to this subpart?**

As used in this subpart, all terms not defined herein shall have the meaning given them in the Clean Air Act (CAA), in subparts A, K, Ka, Kb, and XX of part 60 of this chapter, or in subparts A, R, and WW of this part. All terms defined in both subpart A of part 60 of this chapter and subparts A, R, and WW of this part shall have the meaning given in subparts A, R, and WW of this part. For purposes of this subpart, definitions in this section supersede definitions in other parts or subparts.

*Administrator* means the Administrator of the United States Environmental Protection Agency or his or her authorized representative (e.g., a State that has been delegated the authority to implement the provisions of this subpart).

*Bulk gasoline plant* means any gasoline storage and distribution facility that receives gasoline by pipeline, ship or barge, or cargo tank and has a gasoline throughput of less than 20,000 gallons per day. Gasoline throughput shall be the maximum calculated design throughput as may be limited by compliance with an enforceable condition under Federal, State, or local law and discoverable by the Administrator and any other person.

*Bulk gasoline terminal* means any gasoline storage and distribution facility that receives gasoline by pipeline, ship or barge, or cargo tank and has a gasoline throughput of 20,000 gallons per day or greater. Gasoline throughput shall be the maximum calculated design throughput as may be limited by compliance

with an enforceable condition under Federal, State, or local law and discoverable by the Administrator and any other person.

*Equipment* means each valve, pump, pressure relief device, sampling connection system, open-ended valve or line, and flange or other connector in the gasoline liquid transfer and vapor collection systems. This definition also includes the entire vapor processing system except the exhaust port(s) or stack(s).

*Flare* means a thermal oxidation system using an open (without enclosure) flame.

*Gasoline cargo tank* means a delivery tank truck or railcar which is loading gasoline or which has loaded gasoline on the immediately previous load.

*In gasoline service* means that a piece of equipment is used in a system that transfers gasoline or gasoline vapors.

*Monthly* means once per calendar month at regular intervals of no less than 28 days and no more than 35 days.

*Operating parameter value* means a value for an operating or emission parameter of the vapor processing system (e.g., temperature) which, if maintained continuously by itself or in combination with one or more other operating parameter values, determines that an owner or operator has complied with the applicable emission standard. The operating parameter value is determined using the procedures specified in §63.11092(b).

*Pipeline breakout station* means a facility along a pipeline containing storage vessels used to relieve surges or receive and store gasoline from the pipeline for re-injection and continued transportation by pipeline or to other facilities.

*Pipeline pumping station* means a facility along a pipeline containing pumps to maintain the desired pressure and flow of product through the pipeline and not containing storage vessels.

*Submerged filling* means, for the purposes of this subpart, the filling of a gasoline cargo tank or a stationary storage tank through a submerged fill pipe whose discharge is no more than the applicable distance specified in §63.11086(a) from the bottom of the tank. Bottom filling of gasoline cargo tanks or storage tanks is included in this definition.

*Vapor collection-equipped gasoline cargo tank* means a gasoline cargo tank that is outfitted with the equipment necessary to transfer vapors, displaced during the loading of gasoline into the cargo tank, to a vapor processor system.

*Vapor-tight gasoline cargo tank* means the same as the definition of the term “vapor-tight gasoline tank truck” in §60.501, except that for this subpart the term “gasoline tank truck” means “gasoline cargo tank,” as defined in this section.

**Table 1 to Subpart BBBBB of Part 63—Applicability Criteria, Emission Limits, and Management Practices for Storage Tanks**

If you own or operate	Then you must
1. A gasoline storage tank with a capacity of less than 75 cubic meters (m	Equip each gasoline storage tank with a fixed roof that is mounted to the storage tank in a stationary manner, and maintain all openings in a closed position at all times when not in use.

2. A gasoline storage tank with a capacity of greater than or equal to 75 m <sup>3</sup>	(a) Reduce emissions of total organic HAP or TOC by 95 weight-percent with a closed vent system and control device as specified in §60.112b(a)(3) of this chapter; or
	(b) Equip each internal floating roof gasoline storage tank according to the requirements in §60.112b(a)(1) of this chapter, except for the secondary seal requirements under §60.112b(a)(1)(ii)(B) and the requirements in §60.112b(a)(1)(iv) through (ix) of this chapter; and
	(c) Equip each external floating roof gasoline storage tank according to the requirements in §60.112b(a)(2) of this chapter, except that the requirements of §60.112b(a)(2)(ii) of this chapter shall only be required if such storage tank does not currently meet the requirements of §60.112b(a)(2)(i) of this chapter; or
	(d) Equip and operate each internal and external floating roof gasoline storage tank according to the applicable requirements in §63.1063(a)(1) and (b), and equip each external floating roof gasoline storage tank according to the requirements of §63.1063(a)(2) if such storage tank does not currently meet the requirements of §63.1063(a)(1).

**Table 2 to Subpart BBBBBB of Part 63—Applicability Criteria, Emission Limits, and Management Practices for Loading Racks**

<b>If you own or operate</b>	<b>Then you must</b>
1. A gasoline loading rack(s) at a bulk gasoline terminal with a gasoline throughput of 250,000 gallons per day, or greater	(a) Equip your loading rack(s) with a vapor collection system designed to collect the TOC vapors displaced from cargo tanks during product loading; and (b) Reduce emissions of TOC to less than or equal to 80 mg/l of gasoline loaded into gasoline cargo tanks at the loading rack; and
	(c) Design and operate the vapor collection system to prevent any TOC vapors collected at one loading rack from passing to another loading rack; and
	(d) Limit the loading of gasoline into gasoline cargo tanks that are vapor tight using the procedures specified in §60.502(e) through (j) of this chapter. For the purposes of this section, the term “tank truck” as used in §60.502(e) through (j) of this chapter means “cargo tank” as defined in §63.11100.
2. A gasoline loading rack(s) at a bulk gasoline terminal with a gasoline throughput of less than 250,000 gallons per day	(a) Use submerged filling with a submerged fill pipe that is no more than 6 inches from the bottom of the cargo tank. (b) Make records available within 24 hours of a request by the Administrator to document your gasoline throughput.

**Table 3 to Subpart BBBBBB of Part 63—Applicability of General Provisions**

<b>Citation</b>	<b>Subject</b>	<b>Brief description</b>	<b>Applies to subpart BBBBBB</b>
§63.1	Applicability	Initial applicability determination; applicability after standards established; permit requirements; extensions, notifications	Yes, specific requirements given in §63.11081.
§63.1(c)(2)	Title V permit	Requirements for obtaining a title V permit from the applicable permitting authority	Yes, §63.11081(b) of subpart BBBBBB

			exempts identified area sources from the obligation to obtain title V operating permits.
§63.2	Definitions	Definitions for part 63 standards	Yes, additional definitions in §63.11100.
§63.3	Units and Abbreviations	Units and abbreviations for part 63 standards	Yes.
§63.4	Prohibited Activities and Circumvention	Prohibited activities; circumvention, severability	Yes.
§63.5	Construction/Reconstruction	Applicability; applications; approvals	Yes.
§63.6(a)	Compliance with Standards/Operation & Maintenance Applicability	General Provisions apply unless compliance extension; General Provisions apply to area sources that become major	Yes.
§63.6(b)(1)–(4)	Compliance Dates for New and Reconstructed Sources	Standards apply at effective date; 3 years after effective date upon startup; 10 years after construction or reconstruction commences for CAA section 112(f)	Yes.
§63.6(b)(5)	Notification	Must notify if commenced construction or reconstruction after proposal	Yes.
§63.6(b)(6)	[Reserved]		
§63.6(b)(7)	Compliance Dates for New and Reconstructed Area Sources that Become Major	Area sources that become major must comply with major source standards immediately upon becoming major, regardless of whether required to comply when they were an area source	No.
§63.6(c)(1)–(2)	Compliance Dates for Existing Sources	Comply according to date in this subpart, which must be no later than 3 years after effective date; for CAA section 112(f) standards, comply within 90 days of effective date unless compliance extension	No, §63.11083 specifies the compliance dates.
§63.6(c)(3)–(4)	[Reserved]		
§63.6(c)(5)	Compliance Dates for Existing Area Sources that Become Major	Area sources that become major must comply with major source standards by date indicated in this subpart or by equivalent time period (e.g., 3 years)	No.
§63.6(d)	[Reserved]		
§63.6(e)(1)	Operation & Maintenance	Operate to minimize emissions at all times; correct malfunctions as soon as practicable; and operation and maintenance requirements independently enforceable; information Administrator will use to determine if operation and maintenance requirements were met	Yes.
§63.6(e)(2)	[Reserved]		
§63.6(e)(3)	Startup, Shutdown, and Malfunction (SSM) plan	Requirement for SSM plan; content of SSM plan; actions during SSM	No.
§63.6(f)(1)	Compliance Except During SSM	You must comply with emission standards at all times except during SSM	No.
§63.6(f)(2)–(3)	Methods for Determining Compliance	Compliance based on performance test, operation and maintenance plans, records, inspection	Yes.
§63.6(g)(1)–(3)	Alternative Standard	Procedures for getting an alternative standard	Yes.

§63.6(h)(1)	Compliance with Opacity/VE Standards	You must comply with opacity/VE standards at all times except during SSM	No.
§63.6(h)(2)(i)	Determining Compliance with Opacity/VE Standards	If standard does not State test method, use EPA Method 9 for opacity in appendix A of part 60 of this chapter and EPA Method 22 for VE in appendix A of part 60 of this chapter	No.
§63.6(h)(2)(ii)	[Reserved]		
§63.6(h)(2)(iii)	Using Previous Tests to Demonstrate Compliance with Opacity/VE Standards	Criteria for when previous opacity/VE testing can be used to show compliance with this subpart	No.
§63.6(h)(3)	[Reserved]		
§63.6(h)(4)	Notification of Opacity/VE Observation Date	Must notify Administrator of anticipated date of observation	No.
§63.6(h)(5)(i), (iii)–(v)	Conducting Opacity/VE Observations	Dates and schedule for conducting opacity/VE observations	No.
§63.6(h)(5)(ii)	Opacity Test Duration and Averaging Times	Must have at least 3 hours of observation with 30 6-minute averages	No.
§63.6(h)(6)	Records of Conditions During Opacity/VE Observations	Must keep records available and allow Administrator to inspect	No.
§63.6(h)(7)(i)	Report Continuous Opacity Monitoring System (COMS) Monitoring Data from Performance Test	Must submit COMS data with other performance test data	No.
§63.6(h)(7)(ii)	Using COMS Instead of EPA Method 9	Can submit COMS data instead of EPA Method 9 results even if rule requires EPA Method 9 in appendix A of part 60 of this chapter, but must notify Administrator before performance test	No.
§63.6(h)(7)(iii)	Averaging Time for COMS During Performance Test	To determine compliance, must reduce COMS data to 6-minute averages	No.
§63.6(h)(7)(iv)	COMS Requirements	Owner/operator must demonstrate that COMS performance evaluations are conducted according to §63.8(e); COMS are properly maintained and operated according to §63.8(c) and data quality as §63.8(d)	No.
§63.6(h)(7)(v)	Determining Compliance with Opacity/VE Standards	COMS is probable but not conclusive evidence of compliance with opacity standard, even if EPA Method 9 observation shows otherwise. Requirements for COMS to be probable evidence-proper maintenance, meeting Performance Specification 1 in appendix B of part 60 of this chapter, and data have not been altered	No.
§63.6(h)(8)	Determining Compliance with Opacity/VE Standards	Administrator will use all COMS, EPA Method 9 (in appendix A of part 60 of this chapter), and EPA Method 22 (in appendix A of part 60 of this chapter) results, as well as information about operation and maintenance to determine compliance	No.
§63.6(h)(9)	Adjusted Opacity Standard	Procedures for Administrator to adjust an opacity standard	No.
§63.6(i)(1)–(14)	Compliance Extension	Procedures and criteria for Administrator to grant compliance extension	Yes.
§63.6(j)	Presidential Compliance Exemption	President may exempt any source from requirement to comply with this subpart	Yes.

§63.7(a)(2)	Performance Test Dates	Dates for conducting initial performance testing; must conduct 180 days after compliance date	Yes.
§63.7(a)(3)	Section 114 Authority	Administrator may require a performance test under CAA section 114 at any time	Yes.
§63.7(b)(1)	Notification of Performance Test	Must notify Administrator 60 days before the test	Yes.
§63.7(b)(2)	Notification of Re-scheduling	If have to reschedule performance test, must notify Administrator of rescheduled date as soon as practicable and without delay	Yes.
§63.7(c)	Quality Assurance (QA)/Test Plan	Requirement to submit site-specific test plan 60 days before the test or on date Administrator agrees with; test plan approval procedures; performance audit requirements; internal and external QA procedures for testing	Yes.
§63.7(d)	Testing Facilities	Requirements for testing facilities	Yes.
§63.7(e)(1)	Conditions for Conducting Performance Tests	Performance tests must be conducted under representative conditions; cannot conduct performance tests during SSM	Yes.
§63.7(e)(2)	Conditions for Conducting Performance Tests	Must conduct according to this subpart and EPA test methods unless Administrator approves alternative	Yes.
§63.7(e)(3)	Test Run Duration	Must have three test runs of at least 1 hour each; compliance is based on arithmetic mean of three runs; conditions when data from an additional test run can be used	Yes.
§63.7(f)	Alternative Test Method	Procedures by which Administrator can grant approval to use an intermediate or major change, or alternative to a test method	Yes.
§63.7(g)	Performance Test Data Analysis	Must include raw data in performance test report; must submit performance test data 60 days after end of test with the notification of compliance status; keep data for 5 years	Yes.
§63.7(h)	Waiver of Tests	Procedures for Administrator to waive performance test	Yes.
§63.8(a)(1)	Applicability of Monitoring Requirements	Subject to all monitoring requirements in standard	Yes.
§63.8(a)(2)	Performance Specifications	Performance specifications in appendix B of 40 CFR part 60 apply	Yes.
§63.8(a)(3)	[Reserved]		
§63.8(a)(4)	Monitoring of Flares	Monitoring requirements for flares in §63.11 apply	Yes.
§63.8(b)(1)	Monitoring	Must conduct monitoring according to standard unless Administrator approves alternative	Yes.
§63.8(b)(2)–(3)	Multiple Effluents and Multiple Monitoring Systems	Specific requirements for installing monitoring systems; must install on each affected source or after combined with another affected source before it is released to the atmosphere provided the monitoring is sufficient to demonstrate compliance with the standard; if more than one monitoring system on an emission point, must report all monitoring system results, unless one monitoring system is a backup	Yes.
§63.8(c)(1)	Monitoring System Operation and Maintenance	Maintain monitoring system in a manner consistent with good air pollution control practices	Yes.
§63.8(c)(1)(i)–(iii)	Routine and Predictable SSM	Follow the SSM plan for routine repairs; keep parts for routine repairs readily available; reporting requirements for SSM when action is described in SSM plan	Yes.

§63.8(c) (2)–(8)	CMS Requirements	Must install to get representative emission or parameter measurements; must verify operational status before or at performance test	Yes.
§63.8(d)	CMS Quality Control	Requirements for CMS quality control, including calibration etc.; must keep quality control plan on record for 5 years; keep old versions for 5 years after revisions	No.
§63.8(e)	CMS Performance Evaluation	Notification, performance evaluation test plan, reports	Yes.
§63.8(f) (1)–(5)	Alternative Monitoring Method	Procedures for Administrator to approve alternative monitoring	Yes.
§63.8(f)(6)	Alternative to Relative Accuracy Test	Procedures for Administrator to approve alternative relative accuracy tests for CEMS	Yes.
§63.8(g)	Data Reduction	COMS 6-minute averages calculated over at least 36 evenly spaced data points; CEMS 1 hour averages computed over at least 4 equally spaced data points; data that cannot be used in average	Yes.
§63.9(a)	Notification Requirements	Applicability and State delegation	Yes.
§63.9(b) (1)–(2) (4)–(5)	Initial Notifications	Submit notification within 120 days after effective date; notification of intent to construct/reconstruct, notification of commencement of construction/reconstruction, notification of startup; contents of each	Yes.
§63.9(c)	Request for Compliance Extension	Can request if cannot comply by date or if installed best available control technology or lowest achievable emission rate	Yes.
§63.9(d)	Notification of Special Compliance Requirements for New Sources	For sources that commence construction between proposal and promulgation and want to comply 3 years after effective date	Yes.
§63.9(e)	Notification of Performance Test	Notify Administrator 60 days prior	Yes.
§63.9(f)	Notification of VE/Opacity Test	Notify Administrator 30 days prior	No.
§63.9(g)	Additional Notifications When Using CMS	Notification of performance evaluation; notification about use of COMS data; notification that exceeded criterion for relative accuracy alternative	Yes, however, there are no opacity standards.
§63.9(h) (1)–(6)	Notification of Compliance Status	Contents due 60 days after end of performance test or other compliance demonstration, except for opacity/VE, which are due 30 days after; when to submit to Federal vs. State authority	Yes, however, there are no opacity standards.
§63.9(i)	Adjustment of Submittal Deadlines	Procedures for Administrator to approve change when notifications must be submitted	Yes.
§63.9(j)	Change in Previous Information	Must submit within 15 days after the change	Yes.
§63.10(a)	Record-keeping/Reporting	Applies to all, unless compliance extension; when to submit Federal vs. State authority; procedures for owners of more than one source	Yes.
§63.10(b)(1)	Record-keeping/Reporting	General requirements; keep all records readily available; keep for 5 years	Yes.
§63.10(b)(2)(i) (iv)	Records Related to SSM	Occurrence of each for operations (process equipment); occurrence of each malfunction of air pollution control equipment; maintenance on air pollution control equipment; actions during SSM	Yes.

§63.10(b)(2)(vi)(xi)	CMS Records	Malfunctions, inoperative, out-of-control periods	Yes.
§63.10(b)(2)(xii)	Records	Records when under waiver	Yes.
§63.10(b)(2)(xiii)	Records	Records when using alternative to relative accuracy test	Yes.
§63.10(b)(2)(xiv)	Records	All documentation supporting initial notification and notification of compliance status	Yes.
§63.10(b)(3)	Records	Applicability determinations	Yes.
§63.10(c)	Records	Additional records for CMS	No.
§63.10(d)(1)	General Reporting Requirement	Requirement to report	Yes.
§63.10(d)(2)	Report of Performance Test Results	When to submit to Federal or State authority	Yes.
§63.10(d)(3)	Reporting Opacity or VE Observations	What to report and when	No.
§63.10(d)(4)	Progress Reports	Must submit progress reports on schedule if under compliance extension	Yes.
§63.10(d)(5)	SSM Reports	Contents and submission	Yes.
§63.10(e)(1)–(2)	Additional CMS Reports	Must report results for each CEMS on a unit; written copy of CMS performance evaluation; 2–3 copies of COMS performance evaluation	No.
§63.10(e)(3)(i)(iii)	Reports	Schedule for reporting excess emissions	Yes, note that §63.11095 specifies excess emission event for this subpart.
§63.10(e)(3)(iv)(v)	Excess Emissions Reports	Requirement to revert to quarterly submission if there is an excess emissions and parameter monitor exceedances (now defined as deviations); provision to request semiannual reporting after compliance for 1 year; submit report by 30th day following end of quarter or calendar half; if there has not been an exceedance or excess emissions (now defined as deviations), report contents in a statement that there have been no deviations; must submit report containing all of the information in §§63.8(c)(7)–(8) and 63.10(c)(5)–(13)	Yes, §63.11095 specifies excess emission events for this subpart.
§63.10(e)(3)(vi)(viii)	Excess Emissions Report and Summary Report	Requirements for reporting excess emissions for CMS; requires all of the information in §§63.8(c)(7)–(8) and 63.10(c)(5)–(13)	Yes.
§63.10(e)(4)	Reporting COMS Data	Must submit COMS data with performance test data	Yes.
§63.10(f)	Waiver for Recordkeeping/Reporting	Procedures for Administrator to waive	Yes.
§63.11(b)	Flares	Requirements for flares	Yes, the section references §63.11(b)
§63.12	Delegation	State authority to enforce standards	Yes.
§63.13	Addresses	Addresses where reports, notifications, and requests are sent	Yes.
§63.14	Incorporations by Reference	Test methods incorporated by reference	Yes.
§63.15	Availability of Information	Public and confidential information	Yes.





# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

*Mitchell E. Daniels Jr.*  
**Governor**

*Thomas W. Easterly*  
**Commissioner**

100 North Senate Avenue  
Indianapolis, Indiana 46204  
(317) 232-8603  
Toll Free (800) 451-6027  
[www.idem.IN.gov](http://www.idem.IN.gov)

## **SENT VIA U.S. MAIL: CONFIRMED DELIVERY AND SIGNATURE REQUESTED**

**TO:** William Fenton  
BP Products North America, Inc. - Indianapolis Terminal  
2500 North Tibbs Ave  
Indianapolis IN 46222

**DATE:** January 3, 2011

**FROM:** Matt Stuckey, Branch Chief  
Permits Branch  
Office of Air Quality

**SUBJECT:** Final Decision  
FESOP - Administrative Amendment  
097 - 29901 - 00076

Enclosed is the final decision and supporting materials for the air permit application referenced above. Please note that this packet contains the original, signed, permit documents.

The final decision is being sent to you because our records indicate that you are the contact person for this application. However, if you are not the appropriate person within your company to receive this document, please forward it to the correct person.

A copy of the final decision and supporting materials has also been sent via standard mail to:  
Michael Cunningham Area Mgr Midwest Terminals  
Chloe Reece Trinity Consultants  
OAQ Permits Branch Interested Parties List

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178, or toll-free at 1-800-451-6027 (ext. 3-0178), and ask to speak to the permit reviewer who prepared the permit. If you think you have received this document in error, please contact Joanne Smiddie-Brush of my staff at 1-800-451-6027 (ext 3-0185), or via e-mail at [jbrush@idem.IN.gov](mailto:jbrush@idem.IN.gov).

Final Applicant Cover letter.dot 11/30/07

# Mail Code 61-53

IDEM Staff	LPOGOST 1/3/2011 BP Products North America Inc. - Indianapolis Terminal 097 - 29901 - 00076 final)		AFFIX STAMP HERE IF USED AS CERTIFICATE OF MAILING
Name and address of Sender	 Indiana Department of Environmental Management Office of Air Quality – Permits Branch 100 N. Senate Indianapolis, IN 46204	Type of Mail:  <b>CERTIFICATE OF MAILING ONLY</b>	

Line	Article Number	Name, Address, Street and Post Office Address	Postage	Handing Charges	Act. Value (If Registered)	Insured Value	Due Send if COD	R.R. Fee	S.D. Fee	S.H. Fee	Rest. Del. Fee	Remarks
1		William Fenton BP Products North America Inc. - Indianapolis Ter 2500 North Tibbs Ave Indianapolis IN 46222 (Source CAATS) Via confirmed delivery										
2		Michael Cunningham Area Mgr Midwest Terminals BP Products North America Inc. - Indianapolis Ter 28100 Torch Pkwy, 2N Warrenville IL 60555 (RO CAATS)										
3		Marion County Health Department 3838 N, Rural St Indianapolis IN 46205-2930 (Health Department)										
4		Mrs. Sandra Lee Watson 7834 E 100 S Marion IN 46953 (Affected Party)										
5		Indianapolis City Council and Mayors Office 200 East Washington Street, Room E Indianapolis IN 46204 (Local Official)										
6		Marion County Commissioners 200 E. Washington St. City County Bldg., Suite 801 Indianapolis IN 46204 (Local Official)										
7		Chloe Reece Trinity Consultants 15660 Midwest Road, Ste. 250 Oak Brook IL 60181 (Consultant)										
8		Ms. Jodi Perras Improving Kids Environment 1111 East 54th Street, Suite 212 Indianapolis IN 46220 (Affected Party)										
9		Matt Mosier Office of Sustainability 2700 South Belmont Ave. Administration Bldg. Indianapolis IN 46221 (Local Official)										
10		Mark Zeltwanger 26545 CR 52 Nappanee IN 46550 (Affected Party)										
11												
12												
13												
14												
15												

Total number of pieces Listed by Sender	Total number of Pieces Received at Post Office	Postmaster, Per (Name of Receiving employee)	The full declaration of value is required on all domestic and international registered mail. The maximum indemnity payable for the reconstruction of nonnegotiable documents under Express Mail document reconstructing insurance is \$50,000 per piece subject to a limit of \$50, 000 per occurrence. The maximum indemnity payable on Express mil merchandise insurance is \$500. The maximum indemnity payable is \$25,000 for registered mail, sent with optional postal insurance. See <b>Domestic Mail Manual R900, S913, and S921</b> for limitations of coverage on inured and COD mail. See <b>International Mail Manual</b> for limitations o coverage on international mail. Special handling charges apply only to Standard Mail (A) and Standard Mail (B) parcels.
---	--	--	--