INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

TO: Interested Parties / Applicant

DATE: February 23, 2011

RE: Duke Energy Indiana, Inc.-Noblesville Generating Station / 057-30105-00004

FROM: Matthew Stuckey, Branch Chief
Permits Branch
Office of Air Quality

Notice of Decision – Approval

Please be advised that on behalf of the Commissioner of the Department of Environmental Management, I have issued a decision regarding the enclosed matter. Pursuant to 326 IAC 2, this approval was effective immediately upon submittal of the application.

If you wish to challenge this decision, IC 4-21.5-3-7 requires that you file a petition for administrative review. This petition may include a request for stay of effectiveness and must be submitted to the Office of Environmental Adjudication, 100 North Senate Avenue, Government Center North, Suite N 501E, Indianapolis, IN 46204, **within eighteen (18) calendar days from the mailing of this notice**. The filing of a petition for administrative review is complete on the earliest of the following dates that apply to the filing:

(1) the date the document is delivered to the Office of Environmental Adjudication (OEA);
(2) the date of the postmark on the envelope containing the document, if the document is mailed to OEA by U.S. mail; or
(3) The date on which the document is deposited with a private carrier, as shown by receipt issued by the carrier, if the document is sent to the OEA by private carrier.

The petition must include facts demonstrating that you are either the applicant, a person aggrieved or adversely affected by the decision or otherwise entitled to review by law. Please identify the permit, decision, or other order for which you seek review by permit number, name of the applicant, location, date of this notice and all of the following:

(1) the name and address of the person making the request;
(2) the interest of the person making the request;
(3) identification of any persons represented by the person making the request;
(4) the reasons, with particularity, for the request;
(5) the issues, with particularity, proposed for considerations at any hearing; and
(6) identification of the terms and conditions which, in the judgment of the person making the request, would be appropriate in the case in question to satisfy the requirements of the law governing documents of the type issued by the Commissioner.

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178. Callers from within Indiana may call toll-free at 1-800-451-6027, ext. 3-0178.

Enclosures
FNPER-AM.dot12/3/07

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

Mr. Patrick Coughlin
Duke Energy Indiana, Inc.
1000 East Main Street
Plainfield, IN 46168

February 23, 2011

Re: 057-30105-00004
First Administrative Amendment to
Part 70 Renewal No.: T 057-26751-00004

Dear Mr. Coughlin:

Duke Energy Indiana, Inc. - Noblesville Generating Station was issued a Part 70 Operating Permit Renewal on January 30, 2009, for a stationary electric generating plant. An application requesting changes to this permit was received on January 10, 2011. Pursuant to the provisions of 326 IAC 2-7-11, an administrative permit amendment to this permit is hereby approved as described below.

The source requested that the permit be updated to change the description of the Heating Boiler based on a fuel conversion that will take place in 2011. The fuel switch has been reviewed against the provisions of 326 IAC 2-7-10.5 and has been found to be exempt (see attached calculations). Conditions A.2 and A.3 of the permit are modified as follows to address this change:

A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)] [326 IAC 2-7-5(15)]

This stationary source consists of the following emission units and pollution control devices:

(a) - (b) ...

~~(c) One (1) no. 2 fuel oil--fired boiler, identified as Heating Boiler, installed in 1990, with a nominal heat input capacity of 9.923 million Btu per hour (MMBtu/hr), with no control equipment and exhausting to stack H--1.~~

A.3 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)]

This stationary source also includes the following insignificant activities which are specifically regulated, as defined in 326 IAC 2-7-1(21):

(a) - (b) ...

(c) One (1) natural gas-fired boiler, identified as Heating Boiler, installed in 1990 and converted to natural gas in 2011, with a nominal heat input capacity of 9.923 million Btu per hour (MMBtu/hr), with no control equipment and exhausting to stack H-1.

SECTION D.2 EMISSIONS UNIT OPERATION CONDITIONS

Emissions Unit Description:

~~(c) One (1) no. 2 fuel oil-fired boiler, identified as Heating Boiler, installed in 1990, with a nominal heat input capacity of 9.923 million Btu per hour (MMBtu/hr), with no control equipment and exhausting to stack H-1.~~

(c) One (1) natural gas-fired boiler, identified as Heating Boiler, installed in 1990 and converted to natural gas in 2011, with a nominal heat input capacity of 9.923 million Btu per hour (MMBtu/hr), with no control equipment and exhausting to stack H-1.

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

Additionally, IDEM has made the following administrative updates to the Operating Permit:

Change No. 1 IDEM has removed the mailing address from Condition A.1 and the reporting forms.

A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)] [326 IAC 2-7-1(22)]

The Permittee owns and operates a stationary electric generating plant.

Source Address:	21225 Riverwood Avenue, Noblesville, Indiana 46060
~~Mailing Address:~~	~~1000 East Main Street, Plainfield, IN 46168~~
General Source Phone Number:	317-838-2108
SIC Code:	4911
County Location:	Hamilton
Source Location Status:	Nonattainment for $PM_{2.5}$ standard Attainment for all other criteria pollutants
Source Status:	Part 70 Operating Permit Program Major Source, under PSD Rules Major Source, under Nonattainment NSR Minor Source, Section 112 of the Clean Air Act 1 of 28 Source Categories

Reporting Forms:

Source Name:	Duke Energy Indiana, Inc. - Noblesville Generating Station
Source Address:	21225 Riverwood Avenue, Noblesville, Indiana 46060
~~Mailing Address:~~	~~1000 East Main Street, Plainfield, IN 46168~~
Part 70 Permit No.:	T057-26751-00004

Change No. 2 Several of IDEM's Branches and sections have been renamed. Therefore, IDEM has updated the addresses and contact information listed in the permit. References to "Permit Administration and Development Section" and the "Permits Branch" have been changed to "Permit Administration and Support Section". References to "Asbestos Section", "Compliance Data Section", "Air Compliance Section", "Compliance Section", and "Compliance Branch" have been changed to "Compliance and Enforcement Branch".

Change No. 3 Condition B.2, Permit Term, is clarified as follows to reference the operating permit:

B.2 Permit Term [326 IAC 2-7-5(2)] [326 IAC 2-1.1-9.5] [326 IAC 2-7-4(a)(1)(D)] [IC 13-15-3-6(a)]

(a) ~~This permit~~**The Part 70 Operating Permit Renewal**, T057-26751-00004, is issued for a fixed term of five (5) years from the issuance date of this permit, as determined in accordance with IC 4-21.5-3-5(f) and IC 13-15-5-3. Subsequent revisions, modifications, or amendments of this permit do not affect the expiration date of this permit.

(b) ...

Change No. 4 There may be times when it is unnecessary for a responsible official to "certify" additional information requested by IDEM; therefore, paragraph (a) of Condition B.7, Duty to Provide Information, is revised as follows:

B.7 Duty to Provide Information [326 IAC 2-7-5(6)(E)]

(a) The Permittee shall furnish to IDEM, OAQ, within a reasonable time, any information that IDEM, OAQ, may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. ~~The submittal by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).~~ Upon request, the Permittee shall also furnish to IDEM, OAQ, copies of records required to be kept by this permit.

(b) ...

Change No. 5 Condition B.8, Certification, is revised as follows:

B.8 Certification [326 IAC 2-7-4(f)] [326 IAC 2-7-6(1)] [326 IAC 2-7-5(3)(C)]

(a) ~~Where specifically designated by this permit or required by an applicable requirement, any application form, report, or compliance certification submitted shall contain~~**A certification required by this permit meets the requirements of 326 IAC 2-7-6(1) if:**

(i) **it contains a** certification by ~~the~~ **a** "responsible official" ~~of truth, accuracy~~**as defined by 326 IAC 2-7-1(34)**, and ~~completeness. This~~

(ii) **the** certification ~~shall state~~**states** that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

(b) ~~One (1) certification shall be included, using~~**The Permittee may use** the attached Certification Form, or its equivalent, with each submittal requiring certification. One (1) certification may cover multiple forms in one (1) submittal.

(c) A "responsible official" is defined at 326 IAC 2-7-1(34).

Change No. 6 Condition B.10, Preventive Maintenance Plan, requirements have been clarified as follows:

B.10 Preventive Maintenance Plan [326 IAC 2-7-5(1~~),(3) and (~~13)] [326 IAC ~~2-7-6(1) and (6)]~~ ~~[326 IAC~~ 1-6-3]

(a) **A Preventive Maintenance Plan meets the requirements of 326 IAC 1-6-3 if it includes, at a minimum:**

(1) **Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;**

(2) **A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and**

(3) **Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.**

The Permittee shall implement the PMPs.

(~~a~~**b**) If required by specific condition(s) in Section D of this permit, **where no PMP was previously required,** the Permittee shall **prepare and** maintain ~~and implement~~ Preventive Maintenance Plans (PMPs) **no later than ninety (90) days after issuance of this permit or ninety (90) days after initial start-up, whichever is later,** including the following information on each facility:

(1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;

(2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and

(3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

If, due to circumstances beyond the Permittee's control, the PMPs cannot be prepared and maintained within the above time frame, the Permittee may extend the date an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

The PMP extension notification does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

The Permittee shall implement the PMPs.

(~~b~~**c**) A copy of the PMPs shall be submitted to IDEM, OAQ, upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. IDEM, OAQ, may require the Permittee to revise its PMPs whenever lack of proper maintenance causes or is the primary contributor to an exceedance of any limitation on emissions ~~or potential to emit.~~. The PMPs **and their submittal** do not require ~~the~~ **a** certification **that meets the requirements of 326 IAC 2-7-6(1)** by ~~the~~**a** "responsible official" as defined by 326 IAC 2-7-1(34).

(~~c~~**d**) To the extent the Permittee is required by 40 CFR Part 60/63 to have an Operation Maintenance, and Monitoring (OMM) Plan for a unit, such Plan is deemed to satisfy the PMP requirements of 326 IAC 1-6-3 for that unit.

Change No. 7 Condition B.11, Emergency Provisions, is updated as follows:

B.11 Emergency Provisions [326 IAC 2-7-16]

(a) ...

(b) ...

(1) - (3) ...

(4) ...

Telephone Number: 1-800-451-6027 (ask for Office of Air Quality, Compliance ~~Section~~ **and Enforcement Branch**), or
Telephone Number: 317-233-0178 (ask for **Office of Air Quality,** Compliance ~~Section~~ **and Enforcement Branch**)
Facsimile Number: 317-233-6865

(5) ...

The notification which shall be submitted by the Permittee does not require ~~the~~ **a** certification **that meets the requirements of 326 IAC 2-7-6(1)** by ~~the~~**a** "responsible official" as defined by 326 IAC 2-7-1(34).

(6) ...

(c) - (g) ...

~~(h) The Permittee shall include all emergencies in the Quarterly Deviation and Compliance Monitoring Report.~~

Change No. 8 IDEM has removed Condition B.15, Deviations from Permit Requirements and Conditions as shown below. These requirements have been moved to the General Reporting Requirements in Section C of the permit.

~~B.15 Deviations from Permit Requirements and Conditions [326 IAC 2-7-5(3)(C)(ii)]~~

~~(a) Deviations from any permit requirements (for emergencies see Section B - Emergency Provisions), the probable cause of such deviations, and any response steps or preventive measures taken shall be reported to:~~

~~Indiana Department of Environmental Management~~
~~Compliance and Enforcement Branch, Office of Air Quality~~
~~100 North Senate Avenue~~
~~MC 61-53 IGCN 1003~~
~~Indianapolis, Indiana 46204-2251~~

~~using the attached Quarterly Deviation and Compliance Monitoring Report, or its equivalent. A deviation required to be reported pursuant to an applicable requirement that exists independent of this permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report.~~

~~The Quarterly Deviation and Compliance Monitoring Report does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).~~

~~(b) A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit.~~

Change No. 9 Condition B.17 (now B.16), Permit Renewal, is clarified as follows:

B.~~17~~**16** Permit Renewal [326 IAC 2-7-3] [326 IAC 2-7-4] [326 IAC 2-7-8(e)]

(a) The application for renewal shall be submitted using the application form or forms prescribed by IDEM, OAQ, and shall include the information specified in 326 IAC 2-7-4. Such information shall be included in the application for each emission unit at this source, except those emission units included on the trivial or insignificant activities list contained in 326 IAC 2-7-1(21) and 326 IAC 2-7-1(40). The renewal application does require ~~the~~ **a** certification **that meets the requirements of 326 IAC 2-7-6(1)** by ~~the~~**a** "responsible official" as defined by 326 IAC 2-7-1(34).

...

(b) ...

(c) If the Permittee submits a timely and complete application for renewal of this permit, the source's failure to have a permit is not a violation of 326 IAC 2-7 until IDEM, OAQ, takes final action on the renewal application, except that this protection shall cease to apply if, subsequent to the completeness determination, the Permittee fails to submit by the deadline specified**, pursuant to 326 IAC 2-7-4(a)(2)(D),** in writing by IDEM, OAQ, any additional information identified as being needed to process the application.

Change No. 10 Condition B.18 (now B.17), Permit Amendment or Modification, is clarified as follows:

B.~~18~~**17** Permit Amendment or Modification [326 IAC 2-7-11] [326 IAC 2-7-12]

(a) Permit amendments and modifications are governed by the requirements of 326 IAC 2-7-11 or 326 IAC 2-7-12 whenever the Permittee seeks to amend or modify this permit.

(b) Any application requesting an amendment or modification of this permit shall be submitted to:

Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

Any such application ~~shall be certified~~**does require a certification that meets the requirements of 326 IAC 2-7-6(1)** by ~~the~~ **a** "responsible official" as defined by 326 IAC 2-7-1(34).

(c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-7-11(c)(3)]

Change No. 11 Condition B.19 (now B.18), Permit Revision Under Economic Incentives and Other Programs, is clarified as follows:

B.~~19~~**18** Permit Revision Under Economic Incentives and Other Programs [326 IAC 2-7-5(8)] [326 IAC 2-7-12(b)(2)]

(a) No Part 70 permit revision **or notice** shall be required under any approved economic incentives, marketable Part 70 permits, emissions trading, and other similar programs or processes for changes that are provided for in a Part 70 permit.

(b) ...

Change No. 12 Condition B.23 (now B.22), Transfer of Ownership or Operational Control, is clarified as follows:

B.~~23~~**22** Transfer of Ownership or Operational Control [326 IAC 2-7-11]

(a) ...

(b) ...

~~The~~ **Any such** application ~~which shall be submitted by the Permittee~~ does require ~~the~~**a** certification **that meets the requirements of 326 IAC 2-7-6(1)** by ~~the~~**a** "responsible official" as defined by 326 IAC 2-7-1(34).

(c) ...

Change No. 13 Condition C.2, Opacity, is clarified as follows:

C.2 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in **326 IAC 5-1-1 (Applicability) and** 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

(a) - (b) ...

Change No. 14 Condition C.3, Incineration, is clarified as follows:

C.3 Incineration [326 IAC 4-2] [326 IAC 9-1-2]

The Permittee shall not operate an incinerator ~~or incinerate any waste or refuse~~ except as provided in 326 IAC 4-2 ~~and~~**or in this permit. The Permittee shall not operate a refuse incinerator or refuse burning equipment except as provided in** 326 IAC 9-1-2 **or in this permit**.

Change No. 15 Condition C.7, Performance Testing, is clarified as follows:

C.7 Performance Testing [326 IAC 3-6]

(a) ~~All testing shall be performed according to the provisions of 326 IAC 3-6 (Source Sampling Procedures), except as provided elsewhere in this permit, utilizing any applicable procedures and analysis methods specified in 40 CFR 51, 40 CFR 60, 40 CFR 61, 40 CFR 63, 40 CFR 75, or other procedures approved by IDEM, OAQ.~~

~~A~~ **For performance testing required by this permit, a** test protocol, except as provided elsewhere in this permit, shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

no later than thirty-five (35) days prior to the intended test date. The protocol submitted by the Permittee does not require **a** certification **that meets the requirements of 326 IAC 2-7-6(1)** by ~~the~~**a** "responsible official" as defined by 326 IAC 2-7-1(34).

(b) The Permittee shall notify IDEM, OAQ, of the actual test date at least fourteen (14) days prior to the actual test date. The notification submitted by the Permittee does not require **a** certification **that meets the requirements of 326 IAC 2-7-6(1)** by ~~the~~**a** "responsible official" as defined by 326 IAC 2-7-1(34).

(c) ...

Change No. 16 Condition C.9, Compliance Monitoring, is clarified as follows:

C.9 Compliance Monitoring [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

Unless otherwise specified in this permit, **for** all monitoring ~~and record keeping~~ requirements not already legally required**, the Permittee** shall be ~~implemented within~~**allowed up to** ninety (90) days **from the date** of permit issuance or ~~ninety (90) days~~ of initial start-up, whichever is later~~. If required by Section D, the Permittee shall be responsible for installing any necessary equipment and initiating any required~~**, to begin such** monitoring~~ related to that equipment~~. If due to circumstances beyond ~~its~~**the Permittee's** control, ~~that equipment~~**any monitoring equipment required by this permit** cannot be installed and operated ~~within~~**no later than** ninety (90) days **after permit issuance or the date of initial startup, whichever is later**, the Permittee may extend the compliance schedule related to the equipment for an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

in writing, prior to the end of the initial ninety (90) day compliance schedule, with full justification of the reasons for the inability to meet this date.

The notification which shall be submitted by the Permittee does require ~~the~~ **a** certification **that meets the requirements of 326 IAC 2-7-6(1)** by ~~the~~**a** "responsible official" as defined by 326 IAC 2-7-1(34).

Unless otherwise specified in the approval for the new emission unit(s), compliance monitoring for new emission units or emission units added through a source modification shall be implemented when operation begins.

Change No. 17 The general requirements for Monitoring Methods (Condition C.11) were removed from the permit as follows (This provision will be included as needed in Section D of the permit.)

~~C.11 Monitoring Methods [326 IAC 3] [40 CFR 60] [40 CFR 63]~~

~~Any monitoring or testing required by Section D of this permit shall be performed according to the provisions of 326 IAC 3, 40 CFR 60, Appendix A, 40 CFR 60, Appendix B, 40 CFR 63, or other approved methods as specified in this permit.~~

Change No. 18 Condition C.13 (now C.12), Emergency Reduction Plans, is clarified as follows:

C.~~13~~**12** Emergency Reduction Plans [326 IAC 1-5-2] [326 IAC 1-5-3]

Pursuant to 326 IAC 1-5-2 (Emergency Reduction Plans; Submission):

(a) The Permittee **shall maintain the most recently** ~~prepared and~~ submitted written emergency reduction plans (ERPs) consistent with safe operating procedures~~ on February 12, 1980. The plans (ERPs) were approved on March 19, 1980~~.

(b) Upon direct notification by IDEM, OAQ that a specific air pollution episode level is in effect, the Permittee shall immediately put into effect the actions stipulated in the approved ERP for the appropriate episode level. [326 IAC 1-5-3]

Change No. 19 Condition C.15 (now C.14), Response to Excursions or Exceedances, is clarified as follows:

C.~~15~~**14** Response to Excursions or Exceedances [326 IAC 2-7-5] [326 IAC 2-7-6]

~~(a)~~ Upon detecting an excursion **where a response step is required by the D Section** or **an** exceedance~~, the~~ **of a limitation in this permit:**

(a) **The** Permittee shall **take reasonable response steps to** restore operation of the emissions unit (including any control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing **excess** emissions.

(b) The response shall include minimizing the period of any startup, shutdown or malfunction ~~and taking any necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of an excursion or exceedance (other than those caused by excused startup or shutdown conditions). Corrective actions~~**. The response** may include, but ~~are~~**is** not limited to, the following:

(1) initial inspection and evaluation;

(2) recording that operations returned **or are returning** to normal without operator action (such as through response by a computerized distribution control system); or

(3) any necessary follow-up actions to return operation to ~~within the indicator range, designated condition, or below the applicable emission limitation~~**normal** or ~~standard, as applicable~~**usual manner of operation**.

(c) - (d) ...

(e) The Permittee shall ~~maintain~~**record** the ~~following records:~~**reasonable response steps taken.**

~~(1) monitoring data;~~

~~(2) monitor performance data, if applicable; and~~

~~(3) corrective actions taken.~~

Change No. 20 Condition C.16 (now C.15), Actions Related to Noncompliance Demonstrated by a Stack Test, is clarified as follows:

C.~~16~~**15** Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5] [326 IAC 2-7-6]

(a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this permit exceed the level specified in any condition of this permit, the Permittee shall ~~take appropriate response actions. The Permittee shall~~ submit a description of ~~these~~**its** response actions to IDEM, OAQ, ~~within thirty (30~~**no later than seventy-five (75)** days ~~of receipt~~**after the date** of the test ~~results. The Permittee shall take appropriate action to minimize excess emissions from the affected facility while the response actions are being implemented~~.

(b) A retest to demonstrate compliance shall be performed ~~within~~**no later than** one hundred ~~twenty (120~~**eighty (180)** days ~~of receipt of~~**after** the ~~original~~**date of the** test ~~results~~. Should the Permittee demonstrate to IDEM, OAQ, that retesting in one hundred ~~twenty (120~~**eighty (180)** days is not practicable, IDEM, OAQ, may extend the retesting deadline.

(c) IDEM, OAQ**,** reserves the authority to take any actions allowed under law in response to noncompliant stack tests.

The response action documents submitted pursuant to this condition do require ~~the~~ **a** certification **that meets the requirements of 326 IAC 2-7-6(1)** by ~~the~~**a** "responsible official" as defined by 326 IAC 2-7-1(34).

Change No. 21 Condition C.17 (now C.16), Emission Statement, is clarified as follows:

C.~~17~~**16** Emission Statement [326 IAC 2-7-5(3)(C)(iii)] [326 IAC 2-7-5(7)] [326 IAC 2-7-19(c)] [326 IAC 2-6]

~~(a)~~ Pursuant to 326 IAC 2-6-3(a)(1), the Permittee shall submit by July 1 of each year an emission statement covering the previous calendar year. The emission statement shall contain, at a minimum, the information specified in 326 IAC 2-6-4(c) and shall meet the following requirements:

(~~1~~**a**) Indicate estimated actual emissions of all pollutants listed in 326 IAC 2-6-4(a);

(~~2~~**b**) Indicate estimated actual emissions of regulated pollutants as defined by 326 IAC 2-7-1(32) ("Regulated pollutant, which is used only for purposes of Section 19 of this rule") from the source, for purpose of fee assessment.

The statement must be submitted to:

Indiana Department of Environmental Management
Technical Support and Modeling Section, Office of Air Quality
100 North Senate Avenue
MC 61-50 IGCN 1003
Indianapolis, Indiana 46204-2251

The emission statement does require ~~the~~ **a** certification **that meets the requirements of 326 IAC 2-7-6(1)** by ~~the "~~**a** "responsible official~~"~~" as defined by 326 IAC 2-7-1(34).

~~(b) The emission statement required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.~~

Change No. 22 Condition C.18 (now C.17), General Record Keeping Requirements, is clarified as follows:

C.~~18~~**17** General Record Keeping Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [326 IAC 2-2] [326 IAC 2-3]

(a) ...

(b) Unless otherwise specified in this permit, **for** all record keeping requirements not already legally required**, the Permittee** shall be ~~implemented within~~**allowed up to** ninety (90) days **from the date** of permit issuance ~~or ninety (90) days~~ **or the date** of initial start-up, whichever is later**, to begin such record keeping**.

(c) - (d) ...

Change No. 23 Condition C.19 (now C.18), General Reporting Requirements, is clarified as follows:

C.~~19~~**18** General Reporting Requirements [326 IAC 2-7-5(3)(C)] [326 IAC 2-1.1-11] **[326 IAC 2-2] [326 IAC 2-3]**

(a) The Permittee shall submit the attached Quarterly Deviation and Compliance Monitoring Report or its equivalent. ~~-~~Any deviation from permit requirements, the date(s) of each deviation, the cause of the deviation, and the response steps taken must be reported~~.~~ **except that a deviation required to be reported pursuant to an applicable requirement that exists independent of this permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report.** This report shall be submitted ~~within~~**not later than** thirty (30) days ~~of~~ **after** the end of the reporting period.~~-~~ The Quarterly Deviation and Compliance Monitoring Report shall include ~~the~~**a** certification ~~by~~ **that meets** the **requirements of 326 IAC 2-7-6(1) by a** "responsible official" as defined by 326 IAC 2-7-1(34). **A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit.**

(b) ~~The report required in (a) of this condition and reports required by conditions in Section D of this permit shall be submitted to:~~**The address for report submittal is:**

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

(c) Unless otherwise specified in this permit, any notice, report, or other submission required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ**,** on or before the date it is due.

(d) ~~Unless otherwise specified in this permit, all reports required in Section D of this permit shall be submitted within thirty (30) days after the end of the reporting period. All reports required by this permit do require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34). Other types of documents required to be submitted by this permit that do not require the certification by the "responsible official" are specifically identified elsewhere in this permit.~~

~~(e)~~ The first report shall cover the period commencing on the date of issuance of this permit or the date of initial start-up, whichever is later, and ending on the last day of the reporting period. Reporting periods are based on calendar years, unless otherwise specified in this permit. For the purpose of this permit, "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.

(~~f~~**e**) ...

(~~g~~**f**) ...

(~~h~~**g**) ...

Change No. 24 Condition C.20 (now C.19), Compliance with 40 CFR 82 and 326 IAC 22-1, is clarified as follows:

C.~~20~~**19** Compliance with 40 CFR 82 and 326 IAC 22-1

Pursuant to 40 CFR 82 (Protection of Stratospheric Ozone), Subpart F, except as provided for motor vehicle air conditioners in Subpart B, the Permittee shall comply with ~~the~~**applicable** standards for recycling and emissions reduction~~:~~

~~(a) Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to 40 CFR 82.156.~~

~~(b) Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to 40 CFR 82.158.~~

~~(c) Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161~~.

Change No. 25 IDEM agrees to make the following changes to Section D.1 of the permit:

D.1.4 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

~~A Preventive Maintenance Plan (PMP), in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for the combustion turbines, SCR units, oxidation catalysts and mist eliminator.~~**A Preventive Maintenance Plan (PMP) is required for the combustion turbines, SCR units, oxidation catalysts and mist eliminator. Section B - Preventive Maintenance Plan contains the Permittee's obligations with regard to the preventive maintenance plan required by this condition.**

D.1.7 NO_X Monitoring System Downtime [326 IAC 2-2] [326 IAC 2-7-6] [326 IAC 2-7-5(3)]

Whenever the NO_X continuous emission monitoring system is malfunctioning or down for repairs or adjustments, the following method shall be used to provide information related to NO_X emissions:

Monitoring of the SCR operating parameters for ammonia flow rate and inlet duct temperature, shall be implemented. The parameters are as follows:

(a) The Permittee shall record the ammonia flow rate and inlet duct temperature at least four (4) times per hour until the primary CEM or a backup CEM is brought online and functioning properly. The Preventive Maintenance Plan for the SCR shall contain troubleshooting contingency and corrective actions for when the readings are outside of the normal range for any one reading during downtime of the NO_X CEMS.

(b) The instrument used for determining the ammonia flow rate and inlet duct temperature shall comply with Section C - Instrument Specifications, of this permit, shall be subject to approval by IDEM, OAQ, and shall be calibrated or replaced at least once every six (6) months or other time period specified by the manufacturer. The Permittee shall maintain records of the manufacturer specifications, if used.

Failure to take response steps ~~in accordance with Section C - Compliance Response Plan - Preparation, Implementation, Records, and Reports,~~ shall be considered a deviation from this permit. **Section C – Response to Excursions or Exceedances contains the Permittee's obligations with regard to responding to the reasonable response steps required by this condition.**

D.1.10 Record Keeping Requirements [326 IAC 3-5-2]

(a) To document compliance with CO limits in Condition D.1.1, the Permittee shall maintain records of all CO, and oxygen continuous emissions monitoring data, pursuant to 326 IAC 3-5-6, and 40 CFR 60. Records shall be complete and sufficient to establish compliance with the CO limits as required in Condition D.1.1. During CO CEMS downtime, the Permittee shall maintain records of mass emission rates determined in accordance with Condition D.1.6.

(b) ~~All records shall be maintained in accordance with~~ Section C - General Record Keeping Requirements~~, of this permit.~~ **contains the Permittee's obligations with regard to the record keeping required by this condition.**

D.1.11 Reporting Requirements

A quarterly summary of the information to document compliance with Conditions D.1.1 shall be submitted ~~to the address listed in Section C - General Reporting Requirements,~~ using the reporting forms located at the end of this permit, or their equivalent, ~~within~~**no later than** thirty (30) days ~~after~~**following** the end of the **calendar** quarter ~~being reported~~. The report submitted by the Permittee does require ~~the~~ **a** certification **that meets the requirements of 326 IAC 2-7-6(1)** by ~~the~~ **a** "responsible official" as defined by 326 IAC 2-7-1(34). **Section C - General Reporting Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.**

Change No. 26 The Nitrogen Oxide Budget Trading Program (Section F) is no longer an applicable rule; therefore, IDEM has removed these requirements from the permit. Section G is renumbered as Section F. The revisions are as follows:

~~**SECTION F Nitrogen Oxide Budget Trading Program - NO_X Budget Permit for NO_X Budget Units Under 326 IAC 10-4-1(a)**~~

~~**ORIS Code: 1007**~~

~~NO_X Budget Source [326 IAC 2-7-5(15)]~~

~~(a) Three (3) Natural Gas Fired Combined Cycle Systems [each includes a stationary combustion turbine and Heat Recovery Steam Generator (HRSG)], identified as CT-3, CT-4, and CT-5, installed in 2003, with a nominal capacity of 749.5 MMBtu per hour each based on 100% load, 55 F ambient temperature and natural gas higher heating value (833.9 MMBtu/hr at 100% load, -20 F and natural gas higher heating value), using DLN on each turbine and SCR and oxidation catalyst in each HRSG as control, and exhausting to stack 3-2, 4, and 5 respectively.~~

~~(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)~~

~~F.1 Automatic Incorporation of Definitions [326 IAC 10-4-7(e)]~~

~~This NO_X budget permit is deemed to incorporate automatically the definitions of terms under 326 IAC 10-4-2.~~

~~F.2 Standard Permit Requirements [326 IAC 10-4-4(a)]~~

~~(a) The owners and operators of the NO_X budget source and each NO_X budget unit shall operate each unit in compliance with this NO_X budget permit.~~

~~(b) The NO_X budget units subject to this NO_X budget permit are: Combined Cycle Systems CT-3, CT-4, and CT-5.~~

~~F.3 Monitoring Requirements [326 IAC 10-4-4(b)]~~

~~(a) The owners and operators and, to the extent applicable, the NO_X authorized account representative of the NO_X budget source and each NO_X budget unit at the source shall comply with the monitoring requirements of 40 CFR 75 and 326 IAC 10-4-12.~~

~~(b) The emissions measurements recorded and reported in accordance with 40 CFR 75 and 326 IAC 10-4-12 shall be used to determine compliance by each unit with the NO_X budget emissions limitation under 326 IAC 10-4-4(c) and Condition F.4, Nitrogen Oxides Requirements.~~

~~F.4 Nitrogen Oxides Requirements [326 IAC 10-4-4(c)]~~

~~(a) The owners and operators of the NO_X budget source and each NO_X budget unit at the source shall hold NO_X allowances available for compliance deductions under 326 IAC 10-4-10(j), as of the NO_X allowance transfer deadline, in each unit's compliance account and the source's overdraft account in an amount:~~

~~(1) Not less than the total NO_X emissions for the ozone control period from the unit, as determined in accordance with 40 CFR 75 and 326 IAC 10-4-12;~~

~~(2) To account for excess emissions for a prior ozone control period under 326 IAC 10-4-10(k)(5); or~~

~~(3) To account for withdrawal from the NO_X budget trading program, or a change in regulatory status of a NO_X budget opt-in unit.~~

~~(b) Each ton of NO_X emitted in excess of the NO_X budget emissions limitation shall constitute a separate violation of the Clean Air Act (CAA) and 326 IAC 10-4.~~

~~(c) NO_X allowances shall be held in, deducted from, or transferred among NO_X allowance tracking system accounts in accordance with 326 IAC 10-4-9 through 11, 326 IAC 10-4-13, and 326 IAC 10-4-14.~~

~~(d) A NO_X allowance shall not be deducted, in order to comply with the requirements under (a) above and 326 IAC 10-4-4(c)(1), for an ozone control period in a year prior to the year for which the NO_X allowance was allocated.~~

~~(e) A NO_X allowance allocated under the NO_X budget trading program is a limited authorization to emit one (1) ton of NO_X in accordance with the NO_X budget trading program. No provision of the NO_X budget trading program, the NO_X budget permit application, the NO_X budget permit, or an exemption under 326 IAC 10-4-3 and no provision of law shall be construed to limit the authority of the U.S. EPA or IDEM, OAQ to terminate or limit the authorization.~~

~~(f) A NO_X allowance allocated under the NO_X budget trading program does not constitute a property right.~~

~~(g) Upon recordation by the U.S. EPA under 326 IAC 10-4-10, 326 IAC 10-4-11, or 326 IAC 10-4-13, every allocation, transfer, or deduction of a NO_X allowance to or from each NO_X budget unit's compliance account or the overdraft account of the source where the unit is located is deemed to amend automatically, and become a part of, this NO_X budget permit of the NO_X budget unit by operation of law without any further review.~~

~~F.5 Excess Emissions Requirements [326 IAC 10-4-4(d)]~~

~~The owners and operators of each NO_X budget unit that has excess emissions in any ozone control period shall do the following:~~

~~(a) Surrender the NO_X allowances required for deduction under 326 IAC 10-4-10(k)(5).~~

~~(b) Pay any fine, penalty, or assessment or comply with any other remedy imposed under 326 IAC 10-4-10(k)(7).~~

~~F.6 Record Keeping Requirements [326 IAC 10-4-4(e)] [326 IAC 2-7-5(3)]~~

~~Unless otherwise provided, the owners and operators of the NO_X budget source and each NO_X budget unit at the source shall keep, either on site at the source or at a central location within Indiana for those owners or operators with unattended sources, each of the following documents for a period of five (5) years:~~

~~(a) The account certificate of representation for the NO_X authorized account representative for the source and each NO_X budget unit at the source and all documents that demonstrate the truth of the statements in the account certificate of representation, in accordance with 326 IAC 10-4-6(h). The certificate and documents shall be retained either on site at the source or at a central location within Indiana for those owners or operators with unattended sources beyond the five (5) year period until the documents are superseded because of the submission of a new account certificate of representation changing the NO_X authorized account representative.~~

~~(b) All emissions monitoring information, in accordance with 40 CFR 75 and 326 IAC 10-4-12, provided that to the extent that 40 CFR 75 and 326 IAC 10-4-12 provide for a three (3) year period for record keeping, the three (3) year period shall apply.~~

~~(c) Copies of all reports, compliance certifications, and other submissions and all records made or required under the NO_X budget trading program.~~

~~(d) Copies of all documents used to complete a NO_X budget permit application and any other submission under the NO_X budget trading program or to demonstrate compliance with the requirements of the NO_X budget trading program.~~

~~This period may be extended for cause, at any time prior to the end of five (5) years, in writing by IDEM, OAQ or the U.S. EPA. Records retained at a central location within Indiana shall be available immediately at the location and submitted to IDEM, OAQ or U.S. EPA within three (3) business days following receipt of a written request. Nothing in 326 IAC 10-4-4(e) shall alter the record retention requirements for a source under 40 CFR 75. Unless otherwise provided, all records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.~~

~~F.7 Reporting Requirements [326 IAC 10-4-4(e)]~~

~~(a) The NO_X authorized account representative of the NO_X budget source and each NO_X budget unit at the source shall submit the reports and compliance certifications required under the NO_X budget trading program, including those under 326 IAC 10-4-8, 326 IAC 10-4-12, or 326 IAC 10-4-13.~~

~~(b) Pursuant to 326 IAC 10-4-4(e) and 326 IAC 10-4-6(e)(1), each submission shall include the following certification statement by the NO_X authorized account representative: "I am authorized to make this submission on behalf of the owners and operators of the NO_X budget sources or NO_X budget units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the~~

~~statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."~~

~~(c) Where 326 IAC 10-4 requires a submission to IDEM, OAQ, the NO_X authorized account representative shall submit required information to:~~

~~Indiana Department of Environmental Management~~
~~Office of Air Quality~~
~~100 North Senate Avenue~~
~~MC 61-53 IGCN 1003~~
~~Indianapolis, Indiana 46204-2251~~

~~(d) Where 326 IAC 10-4 requires a submission to U.S. EPA, the NO_X authorized account representative shall submit required information to:~~

~~U.S. Environmental Protection Agency~~
~~Clean Air Markets Division~~
~~1200 Pennsylvania Avenue, NW~~
~~Mail Code 6204N~~
~~Washington, DC 20460~~

~~F.8 Liability [326 IAC 10-4-4(f)]~~

~~The owners and operators of each NO_X budget source shall be liable as follows:~~

~~(a) Any person who knowingly violates any requirement or prohibition of the NO_X budget trading program, a NO_X budget permit, or an exemption under 326 IAC 10-4-3 shall be subject to enforcement pursuant to applicable state or federal law.~~

~~(b) Any person who knowingly makes a false material statement in any record, submission, or report under the NO_X budget trading program shall be subject to criminal enforcement pursuant to the applicable state or federal law.~~

~~(c) No permit revision shall excuse any violation of the requirements of the NO_X budget trading program that occurs prior to the date that the revision takes effect.~~

~~(d) Each NO_X budget source and each NO_X budget unit shall meet the requirements of the NO_X budget trading program.~~

~~(e) Any provision of the NO_X budget trading program that applies to a NO_X budget source, including a provision applicable to the NO_X authorized account representative of a NO_X budget source, shall also apply to the owners and operators of the source and of the NO_X budget units at the source.~~

~~(f) Any provision of the NO_X budget trading program that applies to a NO_X budget unit, including a provision applicable to the NO_X authorized account representative of a NO_X budget unit, shall also apply to the owners and operators of the unit. Except with regard to the requirements applicable to units with a common stack under 40 CFR 75 and 326 IAC 10-4-12, the owners and operators and the NO_X authorized account representative of one (1) NO_X budget unit shall not be liable for any violation by any other NO_X budget unit of which they are not owners or operators or the NO_X authorized account representative and that is located at a source of which they are not owners or operators or the NO_X authorized account representative.~~

~~F.9 Effect on Other Authorities [326 IAC 10-4-4(g)]~~

~~No provision of the NO_x budget trading program, a NO_x budget permit application, a NO_x budget permit, or an exemption under 326 IAC 10-4-3 shall be construed as exempting or excluding the owners and operators and, to the extent applicable, the NO_x authorized account representative of a NO_x budget source or NO_x budget unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the CAA.~~

SECTION GF.1 New Source Performance Standards (NSPS) [40 CFR Part 60] [326 IAC 12]

Facility Description [326 IAC 2-7-5(15)]

(a) Three (3) Natural Gas Fired Combined Cycle Systems [each includes a stationary combustion turbine and Heat Recovery Steam Generator (HRSG)], identified as CT-3, CT-4, and CT-5, installed in 2003, with a nominal capacity of 749.5 MMBtu per hour each based on 100% load, 55 F ambient temperature and natural gas higher heating value (833.9 MMBtu/hr at 100% load, -20 F and natural gas higher heating value), using DLN on each turbine and SCR and oxidation catalyst in each HRSG as control, and exhausting to stack 3-2, 4, and 5 respectively.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

(1) New Source Performance Standards (NSPS) [326 IAC 12] [40 CFR Part 60]

~~G~~F.1.1 General Provisions Relating to New Source Performance Standards [326 IAC 12-1] [40 CFR Part 60, Subpart A]

~~(a) Pursuant to 40 CFR 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the stationary gas turbines except when otherwise specified in 40 CFR Part 60, Subpart GG.~~

~~(b)~~ Pursuant to 40 CFR 60.1, the Permittee shall comply with the provisions of 40 CFR Part 60 Subpart A – General Provisions, which are incorporated by reference as 326 IAC 12-1 for the stationary gas turbines except as otherwise specified in 40 CFR Part 60, Subpart GG.

~~(c) Pursuant to 40 CFR 60.7 and 60.19 the Permittee shall submit all required notifications and reports to:~~

~~Indiana Department of Environmental Management~~
~~Compliance Branch, Office of Air Quality~~
~~100 North Senate Avenue~~
~~MC 61-53, IGCN 1003~~
~~Indianapolis, Indiana 46204-2251~~

~~G~~F.1.2 Standards of Performance for Stationary Gas Turbines [40 CFR Part 60, Subpart GG] [326 IAC 12]

The Permittee shall comply with the following provisions of the Standards of Performance for Stationary Gas Turbines, included as Attachment B of this permit, which are incorporated by reference as 326 IAC 12 for the Stationary Gas Turbines:

- 40 CFR 60.330;
- 40 CFR 60.331;
- 40 CFR 60.332;
- 40 CFR 60.333;
- 40 CFR 60.334; and
- 40 CFR 60.335.

Change No. 27 The Emergency Occurrence Report has been updated as follows:

EMERGENCY OCCURRENCE REPORT

☐ This is an emergency as defined in 326 IAC 2-7-1(12)
- The Permittee must notify the Office of Air Quality (OAQ), ~~within~~ **no later than** four (**4**) **daytime** business hours (1-800-451-6027 or 317-233-0178, ask for Compliance ~~Section~~ **and Enforcement Branch**); and
- The Permittee must submit notice in writing or by facsimile ~~within~~ **no later than** two (**2**) working days (Facsimile Number: 317-233-6865), and follow the other requirements of 326 IAC 2-7-16.

~~A certification is not required for this report.~~

Change No. 28 The Quarterly Deviation and Compliance Monitoring Report has been updated as follows:

QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT

This report shall be submitted quarterly based on a calendar year. Any deviation from the requirements **of this permit**, the date(s) of each deviation, the probable cause of the deviation, and the response steps taken must be reported. A deviation required to be reported pursuant to an applicable requirement that exists independent of the permit~~,~~ shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. Additional pages may be attached if necessary. If no deviations occurred, please specify in the box marked "No deviations occurred this reporting period".

~~Attach a signed certification to complete this report.~~

All other conditions of the permit shall remain unchanged and in effect. A copy of this permit is available on the Internet at: www.in.gov/ai/appfiles/idem-caats/.

This decision is subject to the Indiana Administrative Orders and Procedures Act – IC 4-21.5-3-5. If you have any questions on this matter, please contact Kimberly Cottrell, OAQ, 100 North Senate Avenue, MC 61-53, Room 1003, Indianapolis, Indiana, 46204-2251, or call at (800) 451-6027, and ask for Kimberly Cottrell or extension (3-0870), or dial (317) 233-0870.

Sincerely,

Tripurari Sinha

Tripurari P. Sinha, Ph. D., Section Chief
Permits Branch
Office of Air Quality

Attachments:
Updated Permit, PTE Calculations

klc

cc: File – Hamilton County
Hamilton County Health Department
U.S. EPA, Region V
Compliance and Enforcement Branch
Interested Parties

Mr. Thomas Short
Duke Energy Indiana, Inc.
1000 East Main Street
Plainfield, IN 46168

Mr. Mack Sims
Duke Energy Indiana, Inc.
1000 East Main Street
Plainfield, IN 46168

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

Part 70 Operating Permit Renewal
OFFICE OF AIR QUALITY

Duke Energy Indiana Inc.-Noblesville Generating Station
21225 Riverwood Avenue
Noblesville, Indiana 46060

(herein known as the Permittee) is hereby authorized to operate subject to the conditions contained herein, the source described in Section A (Source Summary) of this permit.

The Permittee must comply with all conditions of this permit. Noncompliance with any provisions of this permit is grounds for enforcement action; permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. Noncompliance with any provision of this permit, except any provision specifically designated as not federally enforceable, constitutes a violation of the Clean Air Act. It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. An emergency does constitute an affirmative defense in an enforcement action provided the Permittee complies with the applicable requirements set forth in Section B, Emergency Provisions.

This permit is issued in accordance with 326 IAC 2 and 40 CFR Part 70 Appendix A and contains the conditions and provisions specified in 326 IAC 2-7 as required by 42 U.S.C. 7401, et. seq. (Clean Air Act as amended by the 1990 Clean Air Act Amendments), 40 CFR Part 70.6, IC 13-15 and IC 13-17.

Operation Permit No.: T057-26751-00004	
Issued by/Original Signed by: Tripurari P. Sinha, Ph. D., Section Chief Permits Branch Office of Air Quality	Issuance Date: January 30, 2009 Expiration Date: January 30, 2014

First Administrative Amendment No.: 057-30105-00004	
Issued by: Tripurari Sinha Tripurari P. Sinha, Ph. D., Section Chief Permits Branch Office of Air Quality	Issuance Date: February 23, 2011 Expiration Date: January 30, 2014

TABLE OF CONTENTS

A. SOURCE SUMMARY 5

A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)] [326 IAC 2-7-1(22)]
A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)] [326 IAC 2-7-5(15)]
A.3 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)]
A.4 Part 70 Permit Applicability [326 IAC 2-7-2]

B. GENERAL CONDITIONS 7

B.1 Definitions [326 IAC 2-7-1]
B.2 Permit Term [326 IAC 2-7-5(2)] [326 IAC 2-1.1-9.5] [326 IAC 2-7-4(a)(1)(D)] [IC 13-15-3-6(a)]
B.3 Term of Conditions [326 IAC 2-1.1-9.5]
B.4 Enforceability [326 IAC 2-7-7] [IC 13-17-12]
B.5 Severability [326 IAC 2-7-5(5)]
B.6 Property Rights or Exclusive Privilege [326 IAC 2-7-5(6)(D)]
B.7 Duty to Provide Information [326 IAC 2-7-5(6)(E)]
B.8 Certification [326 IAC 2-7-4(f)] [326 IAC 2-7-6(1)] [326 IAC 2-7-5(3)(C)]
B.9 Annual Compliance Certification [326 IAC 2-7-6(5)]
B.10 Preventive Maintenance Plan [326 IAC 2-7-5(1),(3) and (13)] [326 IAC 2-7-6(1) and (6)] [326 IAC 1-6-3]
B.11 Emergency Provisions [326 IAC 2-7-16]
B.12 Permit Shield [326 IAC 2-7-15] [326 IAC 2-7-20] [326 IAC 2-7-12]
B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5] [326 IAC 2-7-10.5]
B.14 Termination of Right to Operate [326 IAC 2-7-10] [326 IAC 2-7-4(a)]
B.15 Deviations from Permit Requirements and Conditions [326 IAC 2-7-5(3)(C)(ii)]
B.16 Permit Modification, Reopening, Revocation and Reissuance, or Termination [326 IAC 2-7-5(6)(C)] [326 IAC 2-7-8(a)] [326 IAC 2-7-9]
B.17 Permit Renewal [326 IAC 2-7-3] [326 IAC 2-7-4] [326 IAC 2-7-8(e)]
B.18 Permit Amendment or Modification [326 IAC 2-7-11] [326 IAC 2-7-12] [40 CFR 72]
B.19 Permit Revision Under Economic Incentives and Other Programs [326 IAC 2-7-5(8)] [326 IAC 2-7-12(b)(2)]
B.20 Operational Flexibility [326 IAC 2-7-20] [326 IAC 2-7-10.5]
B.21 Source Modification Requirement [326 IAC 2-7-10.5]
B.22 Inspection and Entry [326 IAC 2-7-6] [IC 13-14-2-2] [IC 13-30-3-1] [IC 13-17-3-2]
B.23 Transfer of Ownership or Operational Control [326 IAC 2-7-11]
B.24 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-7-5(7)] [326 IAC 2-1.1-7]
B.25 Credible Evidence [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [62 FR 8314] [326 IAC 1-1-6]

C. SOURCE OPERATION CONDITIONS 18

Emission Limitations and Standards [326 IAC 2-7-5(1)]
C.1 Opacity [326 IAC 5-1]
C.2 Open Burning [326 IAC 4-1] [IC 13-17-9]
C.3 Incineration [326 IAC 4-2] [326 IAC 9-1-2]
C.4 Fugitive Dust Emissions [326 IAC 6-4]
C.5 Stack Height [326 IAC 1-7]
C.6 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

Testing Requirements [326 IAC 2-7-6(1)]
C.7 Performance Testing [326 IAC 3-6]

Compliance Requirements [326 IAC 2-1.1-11]
C.8 Compliance Requirements [326 IAC 2-1.1-11]

Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]
C.9 Compliance Monitoring [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]
C.10 Maintenance of Continuous Emission Monitoring Equipment [326 IAC 2-7-5(3)(A)(iii)]
C.11 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

Corrective Actions and Response Steps [326 IAC 2-7-5] [326 IAC 2-7-6]
C.12 Emergency Reduction Plans [326 IAC 1-5-2] [326 IAC 1-5-3]
C.13 Risk Management Plan [326 IAC 2-7-5(12)] [40 CFR 68]
C.14 Response to Excursions or Exceedances [326 IAC 2-7-5] [326 IAC 2-7-6]
C.15 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5] [326 IAC 2-7-6]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
C.17 Emission Statement [326 IAC 2-7-5(3)(C)(iii)] [326 IAC 2-7-5(7)] [326 IAC 2-7-19(c)] [326 IAC 2-6]
C.18 General Record Keeping Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [326 IAC 2-2] [326 IAC 2-3]
C.19 General Reporting Requirements [326 IAC 2-7-5(3)(C)] [326 IAC 2-1.1-11] [326 IAC 2-2]

Stratospheric Ozone Protection
C.20 Compliance with 40 CFR 82 and 326 IAC 22-1

D.1. EMISSIONS UNIT OPERATION CONDITIONS 26

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.1.1 PSD Minor Limit [326 IAC 2-2]
D.1.2 Formaldehyde Limitations
D.1.3 Old Units Rendered Inoperable
D.1.4 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

Compliance Determination Requirements
D.1.5 Control Equipment Requirements

Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]
D.1.6 Continuous Emission Monitoring (CEMs) [326 IAC 3-5-2(3)]
D.1.7 NOX Monitoring System Downtime [326 IAC 2-2] [326 IAC 2-7-6] [326 IAC 2-7-5(3)]
D.1.8 CO Monitoring System Downtime [326 IAC 2-2] [326 IAC 2-7-6] [326 IAC 2-7-5(3)]
D.1.9 40 CFR Part 60, Subpart GG Custom Fuel Schedule (Stationary Gas Turbines)

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
D.1.9 Record Keeping Requirements [326 IAC 3-5-2]
D.1.10 Reporting Requirements

D.2. EMISSIONS UNIT OPERATION CONDITIONS 30

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.2.1 Particulate Matter (PM) [326 IAC 6-2-4]
D.2.2 Operation Standards [326 IAC 2-1.1-5(a)(4)] [40 CFR 261] [40 CFR 279] [329 IAC 13]

Compliance Determination Requirements
D.2.3 Cleaning Waste Characterization [326 IAC 2-1.1-5(a)(4)] [40 CFR 261]

D.3. EMISSIONS UNIT OPERATION CONDITIONS **31**

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.3.1 Volatile Organic Compounds (VOC) [326 IAC 8-3-2]
D.3.2 Volatile Organic Compounds (VOC) [326 IAC 8-3-5]

E. EMISSIONS UNIT OPERATION CONDITIONS **33**

Acid Rain Program
E.1 Acid Rain Permit [326 IAC 2-7-5(1)(C)] [326 IAC 21] [40 CFR 72 through 40 CFR 78]
E.2 Title IV Emissions Allowances [326 IAC 2-7-5(4)] [326 IAC 21]

F. New Source Performance Standards (NSPS) [40 CFR Part 60] [326 IAC 12] **34**

F.1.1 General Provisions Relating to New Source Performance Standards [326 IAC 12-1] [40 CFR Part 60, Subpart A]
F.1.2 Standards of Performance for Stationary Gas Turbines [40 CFR Part 60, Subpart GG] [326 IAC 12]

Certification **35**

Emergency Occurrence Report **36**

Quarterly Deviation and Compliance Monitoring Report **38**

Attachment A: Title IV (Acid Rain) Permit Renewal

Attachment B: Standards of Performance for Stationary Gas Turbines [40 CFR Part 60, Subpart GG] [326 IAC 12-1-1]

SECTION A SOURCE SUMMARY

This permit is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ). The information describing the source contained in conditions A.1 through A.3 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this permit pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)] [326 IAC 2-7-1(22)]

The Permittee owns and operates a stationary electric generating plant.

Source Address:	21225 Riverwood Avenue, Noblesville, Indiana 46060
General Source Phone Number:	317-838-2108
SIC Code:	4911
County Location:	Hamilton
Source Location Status:	Nonattainment for $PM_{2.5}$ standard Attainment for all other criteria pollutants
Source Status:	Part 70 Operating Permit Program Major Source, under PSD Rules Major Source, under Nonattainment NSR Minor Source, Section 112 of the Clean Air Act 1 of 28 Source Categories

A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)] [326 IAC 2-7-5(15)]

This stationary source consists of the following emission units and pollution control devices:

(a) Three (3) Natural Gas Fired Combined Cycle Systems [each includes a stationary combustion turbine and Heat Recovery Steam Generator (HRSG)], identified as CT-3, CT-4, and CT-5, installed in 2003, with a nominal capacity of 749.5 MMBtu per hour each based on 100% load, 55° F ambient temperature and natural gas higher heating value (833.9 MMBtu/hr at 100% load, -20 F and natural gas higher heating value), using DLN on each turbine and SCR and oxidation catalyst in each HRSG as control, and exhausting to stack 3-2, 4, and 5 respectively.

(b) One (1) Mechanical Draft Cooling Tower with five cells, identified as WT-1, installed in 2003, with a nominal capacity of 100,000 gallons per minute, using a high efficiency mist eliminators as control, and exhausting to stacks WT 1-A through 1-E.

A.3 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)]

This stationary source also includes the following insignificant activities which are specifically regulated, as defined in 326 IAC 2-7-1(21):

(a) Degreasing operations that do not exceed one hundred forty-five (145) gallons per twelve months, except if subject to 326 IAC 20-6. [326 IAC 8-3-2] [326 IAC 8-3-5]

(b) Distillate fuel oil system including unloading and storage in one 15,800 gallon storage tank.

(c) One (1) natural gas-fired boiler, identified as Heating Boiler, installed in 1990 and converted to natural gas in 2011, with a nominal heat input capacity of 9.923 million Btu per hour (MMBtu/hr), with no control equipment and exhausting to stack H-1.

A.4 Part 70 Permit Applicability [326 IAC 2-7-2]

This stationary source is required to have a Part 70 permit by 326 IAC 2-7-2 (Applicability) because:

(a) It is a major source, as defined in 326 IAC 2-7-1(22);

(b) It is a source in a source category designated by the United States Environmental Protection Agency (U.S. EPA) under 40 CFR 70.3 (Part 70 - Applicability).

(c) It is an affected source under Title IV (Acid Deposition Control) of the Clean Air Act, as defined in 326 IAC 2-7-1(3);

SECTION B GENERAL CONDITIONS

B.1 Definitions [326 IAC 2-7-1]

Terms in this permit shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, the applicable definitions found in the statutes or regulations (IC 13-11, 326 IAC 1-2 and 326 IAC 2-7) shall prevail.

B.2 Permit Term [326 IAC 2-7-5(2)] [326 IAC 2-1.1-9.5] [326 IAC 2-7-4(a)(1)(D)] [IC 13-15-3-6(a)]

(a) The Part 70 Operating Permit Renewal, T057-26751-00004, is issued for a fixed term of five (5) years from the issuance date of this permit, as determined in accordance with IC 4-21.5-3-5(f) and IC 13-15-5-3. Subsequent revisions, modifications, or amendments of this permit do not affect the expiration date of this permit or of permits issued pursuant to Title IV of the Clean Air Act and 326 IAC 21 (Acid Deposition Control).

(b) If IDEM, OAQ, upon receiving a timely and complete renewal permit application, fails to issue or deny the permit renewal prior to the expiration date of this permit, this existing permit shall not expire and all terms and conditions shall continue in effect, including any permit shield provided in 326 IAC 2-7-15, until the renewal permit has been issued or denied.

B.3 Term of Conditions [326 IAC 2-1.1-9.5]

Notwithstanding the permit term of a permit to construct, a permit to operate, or a permit modification, any condition established in a permit issued pursuant to a permitting program approved in the state implementation plan shall remain in effect until:

(a) the condition is modified in a subsequent permit action, or

(b) the emission unit to which the condition pertains permanently ceases operation.

B.4 Enforceability [326 IAC 2-7-7] [IC 13-17-12]

Unless otherwise stated, all terms and conditions in this permit, including any provisions designed to limit the source's potential to emit, are enforceable by IDEM, the United States Environmental Protection Agency (U.S. EPA) and by citizens in accordance with the Clean Air Act.

B.5 Severability [326 IAC 2-7-5(5)]

The provisions of this permit are severable; a determination that any portion of this permit is invalid shall not affect the validity of the remainder of the permit.

B.6 Property Rights or Exclusive Privilege [326 IAC 2-7-5(6)(D)]

This permit does not convey any property rights of any sort or any exclusive privilege.

B.7 Duty to Provide Information [326 IAC 2-7-5(6)(E)]

(a) The Permittee shall furnish to IDEM, OAQ, within a reasonable time, any information that IDEM, OAQ, may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. Upon request, the Permittee shall also furnish to IDEM, OAQ copies of records required to be kept by this permit.

(b) For information furnished by the Permittee to IDEM, OAQ, the Permittee may include a claim of confidentiality in accordance with 326 IAC 17.1. When furnishing copies of requested records directly to U.S. EPA, the Permittee may assert a claim of confidentiality in accordance with 40 CFR 2, Subpart B.

B.8 Certification [326 IAC 2-7-4(f)] [326 IAC 2-7-6(1)] [326 IAC 2-7-5(3)(C)]

(a) A certification required by this permit meets the requirements of 326 IAC 2-7-6(1) if:

(i) it contains a certification by a "responsible official" as defined by 326 IAC 2-7-1(34), and

(ii) the certification states that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

(b) The Permittee may use the attached Certification Form, or its equivalent, with each submittal requiring certification. One (1) certification may cover multiple forms in one (1) submittal.

(c) A "responsible official" is defined at 326 IAC 2-7-1(34).

B.9 Annual Compliance Certification [326 IAC 2-7-6(5)]

(a) The Permittee shall annually submit a compliance certification report which addresses the status of the source's compliance with the terms and conditions contained in this permit, including emission limitations, standards, or work practices. All certifications shall cover the time period from January 1 to December 31 of the previous year, and shall be submitted no later than July 1 of each year to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V
Air and Radiation Division, Air Enforcement Branch - Indiana (AE-17J)
77 West Jackson Boulevard
Chicago, Illinois 60604-3590

(b) The annual compliance certification report required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.

(c) The annual compliance certification report shall include the following:

(1) The appropriate identification of each term or condition of this permit that is the basis of the certification;

(2) The compliance status;

(3) Whether compliance was continuous or intermittent;

(4) The methods used for determining the compliance status of the source, currently and over the reporting period consistent with 326 IAC 2-7-5(3); and

(5) Such other facts, as specified in Sections D of this permit, as IDEM, OAQ may require to determine the compliance status of the source.

The submittal by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

B.10 Preventive Maintenance Plan [326 IAC 2-7-5(13)] [326 IAC 1-6-3]

(a) A Preventive Maintenance Plan meets the requirements of 326 IAC 1-6-3 if it includes, at a minimum:

(1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;

(2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and

(3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

The Permittee shall implement the PMPs.

(b) If required by specific condition(s) in Section D of this permit, where no PMP was previously required, the Permittee shall maintain Preventive Maintenance Plans (PMPs) no later than ninety (90) days after issuance of this permit or ninety (90) days after initial start-up, whichever is later, including the following information on each facility:

(1) Identification of the individual(s), by title or classification, responsible for inspecting, maintaining, and repairing emission control devices;

(2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and

(3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

If, due to circumstances beyond the Permittee's control, the PMPs cannot be prepared and maintained within the above time frame, the Permittee may extend the date an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

The PMP extension notification does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

The Permittee shall implement the PMPs.

(c) A copy of the PMPs shall be submitted to IDEM, OAQ, upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. IDEM, OAQ, may require the Permittee to revise its PMPs whenever lack of proper maintenance causes or is the primary contributor to an exceedance of any limitation on emissions. The PMPs and their submittal do not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

(d) To the extent the Permittee is required by 40 CFR Part 60/63 to have an Operation Maintenance, and Monitoring (OMM) Plan for a unit, such Plan is deemed to satisfy the PMP requirements of 326 IAC 1-6-3 for that unit.

B.11 Emergency Provisions [326 IAC 2-7-16]

(a) An emergency, as defined in 326 IAC 2-7-1(12), is not an affirmative defense for an action brought for noncompliance with a federal or state health-based emission limitation.

(b) An emergency, as defined in 326 IAC 2-7-1(12), constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limitation if the affirmative defense of an emergency is demonstrated through properly signed, contemporaneous operating logs or other relevant evidence that describe the following:

(1) An emergency occurred and the Permittee can, to the extent possible, identify the causes of the emergency;

(2) The permitted facility was at the time being properly operated;

(3) During the period of an emergency, the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards or other requirements in this permit;

(4) For each emergency lasting one (1) hour or more, the Permittee notified IDEM, OAQ, within four (4) daytime business hours after the beginning of the emergency, or after the emergency was discovered or reasonably should have been discovered;

Telephone Number: 1-800-451-6027 (ask for Office of Air Quality, Compliance and Enforcement Branch), or
Telephone Number: 317-233-0178 (ask for Compliance and Enforcement Branch)
Facsimile Number: 317-233-6865

(5) For each emergency lasting one (1) hour or more, the Permittee submitted the attached Emergency Occurrence Report Form or its equivalent, either by mail or facsimile to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

within two (2) working days of the time when emission limitations were exceeded due to the emergency.

The notice fulfills the requirement of 326 IAC 2-7-5(3)(C)(ii) and must contain the following:

(A) A description of the emergency;

(B) Any steps taken to mitigate the emissions; and

(C) Corrective actions taken.

The notification which shall be submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

(6) The Permittee immediately took all reasonable steps to correct the emergency.

(c) In any enforcement proceeding, the Permittee seeking to establish the occurrence of an emergency has the burden of proof.

(d) This emergency provision supersedes 326 IAC 1-6 (Malfunctions). This permit condition is in addition to any emergency or upset provision contained in any applicable requirement.

(e) The Permittee seeking to establish the occurrence of an emergency shall make records available upon request to ensure that failure to implement a PMP did not cause or contribute to an exceedance of any limitations on emissions. However, IDEM, OAQ may require that the Preventive Maintenance Plans required under 326 IAC 2-7-4(c)(9) be revised in response to an emergency.

(f) Failure to notify IDEM, OAQ by telephone or facsimile of an emergency lasting more than one (1) hour in accordance with (b)(4) and (5) of this condition shall constitute a violation of 326 IAC 2-7 and any other applicable rules.

(g) If the emergency situation causes a deviation from a technology-based limit, the Permittee may continue to operate the affected emitting facilities during the emergency provided the Permittee immediately takes all reasonable steps to correct the emergency and minimize emissions.

B.12 Permit Shield [326 IAC 2-7-15] [326 IAC 2-7-20] [326 IAC 2-7-12]

(a) Pursuant to 326 IAC 2-7-15, the Permittee has been granted a permit shield. The permit shield provides that compliance with the conditions of this permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that either the applicable requirements are included and specifically identified in this permit or the permit contains an explicit determination or concise summary of a determination that other specifically identified requirements are not applicable. The Indiana statutes from IC 13 and rules from 326 IAC, referenced in conditions in this permit, are those applicable at the time the permit was issued. The issuance or possession of this permit shall not alone constitute a defense against an alleged violation of any law, regulation or standard, except for the requirement to obtain a Part 70 permit under 326 IAC 2-7 or for applicable requirements for which a permit shield has been granted.

This permit shield does not extend to applicable requirements which are promulgated after the date of issuance of this permit unless this permit has been modified to reflect such new requirements.

(b) If, after issuance of this permit, it is determined that the permit is in nonconformance with an applicable requirement that applied to the source on the date of permit issuance, IDEM, OAQ, shall immediately take steps to reopen and revise this permit and issue a compliance order to the Permittee to ensure expeditious compliance with the applicable requirement until the permit is reissued. The permit shield shall continue in effect so long as the Permittee is in compliance with the compliance order.

(c) No permit shield shall apply to any permit term or condition that is determined after issuance of this permit to have been based on erroneous information supplied in the permit application. Erroneous information means information that the Permittee knew to

be false, or in the exercise of reasonable care should have been known to be false, at the time the information was submitted.

(d) Nothing in 326 IAC 2-7-15 or in this permit shall alter or affect the following:

(1) The provisions of Section 303 of the Clean Air Act (emergency orders), including the authority of the U.S. EPA under Section 303 of the Clean Air Act;

(2) The liability of the Permittee for any violation of applicable requirements prior to or at the time of this permit's issuance;

(3) The applicable requirements of the acid rain program, consistent with Section 408(a) of the Clean Air Act; and

(4) The ability of U.S. EPA to obtain information from the Permittee under Section 114 of the Clean Air Act.

(e) This permit shield is not applicable to any change made under 326 IAC 2-7-20(b)(2) (Sections 502(b)(10) of the Clean Air Act changes) and 326 IAC 2-7-20(c)(2) (trading based on State Implementation Plan (SIP) provisions).

(f) This permit shield is not applicable to modifications eligible for group processing until after IDEM, OAQ, has issued the modifications. [326 IAC 2-7-12(c)(7)]

(g) This permit shield is not applicable to minor Part 70 permit modifications until after IDEM, OAQ, has issued the modification. [326 IAC 2-7-12(b)(8)]

B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5] [326 IAC 2-7-10.5]

(a) All terms and conditions of permits established prior to T057-26751-00004 and issued pursuant to permitting programs approved into the state implementation plan have been either:

(1) incorporated as originally stated,

(2) revised under 326 IAC 2-7-10.5, or

(3) deleted under 326 IAC 2-7-10.5.

(b) Provided that all terms and conditions are accurately reflected in this permit, all previous registrations and permits are superseded by this Part 70 operating permit, except for permits issued pursuant to Title IV of the Clean Air Act and 326 IAC 21 (Acid Deposition Control)

B.14 Termination of Right to Operate [326 IAC 2-7-10] [326 IAC 2-7-4(a)]

The Permittee's right to operate this source terminates with the expiration of this permit unless a timely and complete renewal application is submitted at least nine (9) months prior to the date of expiration of the source’s existing permit, consistent with 326 IAC 2-7-3 and 326 IAC 2-7-4(a).

B.15 Permit Modification, Reopening, Revocation and Reissuance, or Termination [326 IAC 2-7-5(6)(C)] [326 IAC 2-7-8(a)] [326 IAC 2-7-9]

(a) This permit may be modified, reopened, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a Part 70 Operating Permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any condition of this permit.

[326 IAC 2-7-5(6)(C)] The notification by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

(b) This permit shall be reopened and revised under any of the circumstances listed in IC 13-15-7-2 or if IDEM, OAQ determines any of the following:

(1) That this permit contains a material mistake.

(2) That inaccurate statements were made in establishing the emissions standards or other terms or conditions.

(3) That this permit must be revised or revoked to assure compliance with an applicable requirement. [326 IAC 2-7-9(a)(3)]

(c) Proceedings by IDEM, OAQ to reopen and revise this permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of this permit for which cause to reopen exists. Such reopening and revision shall be made as expeditiously as practicable. [326 IAC 2-7-9(b)]

(d) The reopening and revision of this permit, under 326 IAC 2-7-9(a), shall not be initiated before notice of such intent is provided to the Permittee by IDEM, OAQ at least thirty (30) days in advance of the date this permit is to be reopened, except that IDEM, OAQ may provide a shorter time period in the case of an emergency. [326 IAC 2-7-9(c)]

B.16 Permit Renewal [326 IAC 2-7-3] [326 IAC 2-7-4] [326 IAC 2-7-8(e)]

(a) The application for renewal shall be submitted using the application form or forms prescribed by IDEM, OAQ and shall include the information specified in 326 IAC 2-7-4. Such information shall be included in the application for each emission unit at this source, except those emission units included on the trivial or insignificant activities list contained in 326 IAC 2-7-1(21) and 326 IAC 2-7-1(40). The renewal application does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

Request for renewal shall be submitted to:

Indiana Department of Environmental Management
Permits Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

(b) A timely renewal application is one that is:

(1) Submitted at least nine (9) months prior to the date of the expiration of this permit; and

(2) If the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.

(c) If the Permittee submits a timely and complete application for renewal of this permit, the source’s failure to have a permit is not a violation of 326 IAC 2-7 until IDEM, OAQ takes final action on the renewal application, except that this protection shall cease to apply if, subsequent to the completeness determination, the Permittee fails to submit by a

reasonable deadline specified, pursuant to 326 IAC 2-7-4(a)(2)(D), in writing by IDEM, OAQ any additional information identified as being needed to process the application.

B.17 Permit Amendment or Modification [326 IAC 2-7-11] [326 IAC 2-7-12] [40 CFR 72]

(a) Permit amendments and modifications are governed by the requirements of 326 IAC 2-7-11 or 326 IAC 2-7-12 whenever the Permittee seeks to amend or modify this permit.

(b) Pursuant to 326 IAC 2-7-11(b) and 326 IAC 2-7-12(a), administrative Part 70 operating permit amendments and permit modifications for purposes of the acid rain portion of a Part 70 permit shall be governed by regulations promulgated under Title IV of the Clean Air Act. [40 CFR 72]

(c) Any application requesting an amendment or modification of this permit shall be submitted to:

Indiana Department of Environmental Management
Permits Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

Any such application does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

(d) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-7-11(c)(3)]

B.18 Permit Revision Under Economic Incentives and Other Programs [326 IAC 2-7-5(8)] [326 IAC 2-7-12(b)(2)]

(a) No Part 70 permit revision or notice shall be required under any approved economic incentives, marketable Part 70 permits, emissions trading, and other similar programs or processes for changes that are provided for in a Part 70 permit.

(b) Notwithstanding 326 IAC 2-7-12(b)(1) and 326 IAC 2-7-12(c)(1), minor Part 70 permit modification procedures may be used for Part 70 modifications involving the use of economic incentives, marketable Part 70 permits, emissions trading, and other similar approaches to the extent that such minor Part 70 permit modification procedures are explicitly provided for in the applicable State Implementation Plan (SIP) or in applicable requirements promulgated or approved by the U.S. EPA.

B.19 Operational Flexibility [326 IAC 2-7-20] [326 IAC 2-7-10.5]

(a) The Permittee may make any change or changes at the source that are described in 326 IAC 2-7-20(b),(c), or (e) without a prior permit revision, if each of the following conditions is met:

(1) The changes are not modifications under any provision of Title I of the Clean Air Act;

(2) Any preconstruction approval required by 326 IAC 2-7-10.5 has been obtained;

(3) The changes do not result in emissions which exceed the limitations provided in this permit (whether expressed herein as a rate of emissions or in terms of total emissions);

(4) The Permittee notifies the:

Indiana Department of Environmental Management
Permits Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V
Air and Radiation Division, Regulation Development Branch - Indiana (AR-18J)
77 West Jackson Boulevard
Chicago, Illinois 60604-3590

in advance of the change by written notification at least ten (10) days in advance of the proposed change. The Permittee shall attach every such notice to the Permittee's copy of this permit; and

(5) The Permittee maintains records accessible on-site, on a rolling five (5) year basis, which document all such changes and emission trades that are subject to 326 IAC 2-7-20(b),(c), or (e). The Permittee shall make such records available, upon reasonable request, for public review.

Such records shall consist of all information required to be submitted to IDEM, OAQ in the notices specified in 326 IAC 2-7-20(b)(1), (c)(1), and (e)(2).

(b) The Permittee may make Section 502(b)(10) of the Clean Air Act changes (this term is defined at 326 IAC 2-7-1(36)) without a permit revision, subject to the constraint of 326 IAC 2-7-20(a). For each such Section 502(b)(10) of the Clean Air Act change, the required written notification shall include the following:

(1) A brief description of the change within the source;

(2) The date on which the change will occur;

(3) Any change in emissions; and

(4) Any permit term or condition that is no longer applicable as a result of the change.

The notification which shall be submitted is not considered an application form, report or compliance certification. Therefore, the notification by the Permittee does not require the certification by the “responsible official” as defined by 326 IAC 2-7-1(34).

(c) Emission Trades [326 IAC 2-7-20(c)]
The Permittee may trade emissions increases and decreases at the source, where the applicable SIP provides for such emission trades without requiring a permit revision, subject to the constraints of Section (a) of this condition and those in 326 IAC 2-7-20(c).

(d) Alternative Operating Scenarios [326 IAC 2-7-20(d)]
The Permittee may make changes at the source within the range of alternative operating scenarios that are described in the terms and conditions of this permit in accordance with 326 IAC 2-7-5(9). No prior notification of IDEM, OAQ, or U.S. EPA is required.

(e) Backup fuel switches specifically addressed in, and limited under, Section D of this permit shall not be considered alternative operating scenarios. Therefore, the notification requirements of part (a) of this condition do not apply.

(f) This condition does not apply to emission trades of SO_2 or NO_X under 326 IAC 21 or 326 IAC 10-4.

B.20 Source Modification Requirement [326 IAC 2-7-10.5]

(a) A modification, construction, or reconstruction is governed by the requirements of 326 IAC 2 and 326 IAC 2-7-10.5.

(b) Any modification at an existing major source is governed by the requirements of 326 IAC 2-2.

B.21 Inspection and Entry [326 IAC 2-7-6] [IC 13-14-2-2] [IC 13-30-3-1] [IC 13-17-3-2]

Upon presentation of proper identification cards, credentials, and other documents as may be required by law, and subject to the Permittee's right under all applicable laws and regulations to assert that the information collected by the agency is confidential and entitled to be treated as such, the Permittee shall allow IDEM, OAQ, U.S. EPA, or an authorized representative to perform the following:

(a) Enter upon the Permittee's premises where a Part 70 source is located, or emissions related activity is conducted, or where records are physically present or electronically accessible under the conditions of this permit;

(b) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, have access to and copy any records that must be kept under the conditions of this permit;

(c) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, inspect any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit;

(d) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, sample or monitor substances or parameters for the purpose of assuring compliance with this permit or applicable requirements; and

(e) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, utilize any photographic, recording, testing, monitoring, or other equipment for the purpose of assuring compliance with this permit or applicable requirements.

B.22 Transfer of Ownership or Operational Control [326 IAC 2-7-11]

(a) The Permittee must comply with the requirements of 326 IAC 2-7-11 whenever the Permittee seeks to change the ownership or operational control of the source and no other change in the permit is necessary.

(b) Any application requesting a change in the ownership or operational control of the source shall contain a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new Permittee. The application shall be submitted to:

Indiana Department of Environmental Management
Permits Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

Any such application does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

(c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-7-11(c)(3)]

B.23 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-7-5(7)] [326 IAC 2-1.1-7]

(a) The Permittee shall pay annual fees to IDEM, OAQ within thirty (30) calendar days of receipt of a billing. Pursuant to 326 IAC 2-7-19(b), if the Permittee does not receive a bill from IDEM, OAQ the applicable fee is due April 1 of each year.

(b) Except as provided in 326 IAC 2-7-19(e), failure to pay may result in administrative enforcement action or revocation of this permit.

(c) The Permittee may call the following telephone numbers: 1-800-451-6027 or 317-233-4230 (ask for OAQ, Billing, Licensing, and Training Section), to determine the appropriate permit fee.

B.24 Credible Evidence [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [62 FR 8314] [326 IAC 1-1-6]

For the purpose of submitting compliance certifications or establishing whether or not the Permittee has violated or is in violation of any condition of this permit, nothing in this permit shall preclude the use, including the exclusive use, of any credible evidence or information relevant to whether the Permittee would have been in compliance with the condition of this permit if the appropriate performance or compliance test or procedure had been performed.

SECTION C SOURCE OPERATION CONDITIONS

Entire Source

Emission Limitations and Standards [326 IAC 2-7-5(1)]

C.1 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-1 (Applicability) and 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

(a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.

(b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

C.2 Open Burning [326 IAC 4-1] [IC 13-17-9]

The Permittee shall not open burn any material except as provided in 326 IAC 4-1-3, 326 IAC 4-1-4 or 326 IAC 4-1-6. The previous sentence notwithstanding, the Permittee may open burn in accordance with an open burning approval issued by the Commissioner under 326 IAC 4-1-4.1.

C.3 Incineration [326 IAC 4-2] [326 IAC 9-1-2]

The Permittee shall not operate an incinerator except as provided in 326 IAC 4-2 or in this permit. The Permittee shall not operate a refuse incinerator or refuse burning equipment except as provided in 326 IAC 9-1-2 or in this permit.

C.4 Fugitive Dust Emissions [326 IAC 6-4]

The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions). 326 IAC 6-4-2(4) is not federally enforceable.

C.5 Stack Height [326 IAC 1-7]

The Permittee shall comply with the applicable provisions of 326 IAC 1-7 (Stack Height Provisions), for all exhaust stacks through which a potential (before controls) of twenty-five (25) tons per year or more of particulate matter or sulfur dioxide is emitted by using ambient air quality modeling pursuant to 326 IAC 1-7-4. The provisions of 326 IAC 1-7-1(3), 326 IAC 1-7-2, 326 IAC 1-7-3(c) and (d), 326 IAC 1-7-4, and 326 IAC 1-7-5(a), (b), and (d) are not federally enforceable.

C.6 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

The Permittee shall comply with the applicable requirements of 326 IAC 14-10, 326 IAC 18, and 40 CFR 61.140.

Testing Requirements [326 IAC 2-7-6(1)]

C.7 Performance Testing [326 IAC 3-6]

(a) For performance testing required by this permit, a test protocol, except as provided elsewhere in this permit, shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

no later than thirty-five (35) days prior to the intended test date. The protocol submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

(b) The Permittee shall notify IDEM, OAQ, of the actual test date at least fourteen (14) days prior to the actual test date. The notification submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

(c) Pursuant to 326 IAC 3-6-4(b), all test reports must be received by IDEM, OAQ not later than forty-five (45) days after the completion of the testing. An extension may be granted by IDEM, OAQ if the Permittee submits to IDEM, OAQ a reasonable written explanation not later than five (5) days prior to the end of the initial forty-five (45) day period. The test report requires certification by the responsible official.

Compliance Requirements [326 IAC 2-1.1-11]

C.8 Compliance Requirements [326 IAC 2-1.1-11]

The commissioner may require stack testing, monitoring, or reporting at any time to assure compliance with all applicable requirements by issuing an order under 326 IAC 2-1.1-11. Any monitoring or testing shall be performed in accordance with 326 IAC 3 or other methods approved by the commissioner or the U. S. EPA.

Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]

C.9 Compliance Monitoring [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

Unless otherwise specified in this permit, for all monitoring requirements not already legally required, the Permittee shall be allowed up to ninety (90) days from the date of permit issuance or of initial start-up, whichever is later, to begin such monitoring. If due to circumstances beyond the Permittee's control, any monitoring equipment required by this permit cannot be installed and no later than ninety (90) days after permit issuance or the date of initial startup, whichever is later, the Permittee may extend the compliance schedule related to the equipment for an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

in writing, prior to the end of the initial ninety (90) day compliance schedule, with full justification of the reasons for the inability to meet this date.

The notification which shall be submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

Unless otherwise specified in the approval for the new emission unit(s), compliance monitoring for new emission units or emission units added through a source modification shall be implemented when operation begins.

C.10 Maintenance of Continuous Emission Monitoring Equipment [326 IAC 2-7-5(3)(A)

(a) The Permittee shall calibrate, maintain, and operate all necessary continuous emission monitoring systems (CEMS) and related equipment as specified in Section D.

(b) All continuous emission monitoring systems shall meet all applicable performance specifications of 40 CFR 60, 40 CFR 75, or any other performance specification, and are subject to monitor system certification requirements pursuant to 326 IAC 3-5-3.

(c) In the event that a breakdown of a continuous emission monitoring system occurs, a record shall be made of the times and reasons of the breakdown and efforts made to correct the problem.

(d) Whenever a continuous emission monitor other than an opacity monitor is malfunctioning or is down for maintenance or repairs, the following shall be used as an alternative to continuous data collection:

(1) If the CEM is required for monitoring NOX or SO2 emissions pursuant to 40 CFR 75 (Title IV Acid Rain Program) or 326 IAC 10-4 (NOX Budget Trading Program), the Permittee shall comply with the relevant requirements of 40 CFR 75 Subpart D-Missing Data Substitution Procedures.

(2) If the CEM is not used to monitor NOX or SO2 emissions pursuant to 40 CFR 74 or 326 IAC 10-4, then supplemental or intermittent monitoring of the parameter shall be implemented as specified in Section D of this permit until such time as the emission monitor system is back in operation.

(e) Nothing in this permit shall excuse the Permittee from complying with the requirements to operate a continuous emission monitoring system pursuant to 326 IAC 3-5, 326 IAC 10-4, 40 CFR 60 and 40 CFR 75.

C.11 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

(a) When required by any condition of this permit, an analog instrument used to measure a parameter related to the operation of an air pollution control device shall have a scale such that the expected maximum reading for the normal range shall be no less than twenty percent (20%) of full scale.

(b) The Permittee may request that the IDEM, OAQ approve the use of an instrument that does not meet the above specifications provided the Permittee can demonstrate that an alternative instrument specification will adequately ensure compliance with permit conditions requiring the measurement of the parameters.

Corrective Actions and Response Steps [326 IAC 2-7-5] [326 IAC 2-7-6]

C.12 Emergency Reduction Plans [326 IAC 1-5-2] [326 IAC 1-5-3]

Pursuant to 326 IAC 1-5-2 (Emergency Reduction Plans; Submission):

(a) The Permittee shall maintain the most recently submitted written emergency reduction plans (ERPs) consistent with safe operating procedures.

(b) Upon direct notification by IDEM, OAQ that a specific air pollution episode level is in effect, the Permittee shall immediately put into effect the actions stipulated in the approved ERP for the appropriate episode level. [326 IAC 1-5-3]

C.13 Risk Management Plan [326 IAC 2-7-5(12)] [40 CFR 68]

If a regulated substance, as defined in 40 CFR 68, is present at a source in more than a threshold quantity, the Permittee must comply with the applicable requirements of 40 CFR 68.

C.14 Response to Excursions or Exceedances [326 IAC 2-7-5] [326 IAC 2-7-6]

Upon detecting an excursion where a response step is required by the D Section or an exceedance of a limitation in this permit:

(a) The Permittee shall take reasonable response steps to restore operation of the emissions unit (including any control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing excess emissions.

(b) The response shall include minimizing the period of any startup, shutdown or malfunction. The response may include, but is not limited to, the following:

(1) initial inspection and evaluation;

(2) recording that operations returned or are returning to normal without operator action (such as through response by a computerized distribution control system); or

(3) any necessary follow-up actions to return operation to normal or usual manner of operation.

(c) A determination of whether the Permittee has used acceptable procedures in response to an excursion or exceedance will be based on information available, which may include, but is not limited to, the following:

(1) monitoring results;

(2) review of operation and maintenance procedures and records; and/or

(3) inspection of the control device, associated capture system, and the process.

(d) Failure to take reasonable response steps shall be considered a deviation from the permit.

(e) The Permittee shall record the reasonable response steps taken.

C.15 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5] [326 IAC 2-7-6]

(a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this permit exceed the level specified in any condition of this permit, the Permittee shall submit a description of its response actions to IDEM, OAQ, no later than seventy-five (75) days after the date of the test.

(b) A retest to demonstrate compliance shall be performed no later than one hundred eighty (180) days after the date of the test. Should the Permittee demonstrate to IDEM, OAQ, that retesting in one hundred eighty (180) days is not practicable, IDEM, OAQ, may extend the retesting deadline.

(c) IDEM, OAQ, reserves the authority to take any actions allowed under law in response to noncompliant stack tests.

The response action documents submitted pursuant to this condition do require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

C.16 Emission Statement [326 IAC 2-7-5(3)(C)(iii)] [326 IAC 2-7-5(7)] [326 IAC 2-7-19(c)] [326 IAC 2-6]

Pursuant to 326 IAC 2-6-3(b)(2), starting in 2005 and every three (3) years thereafter, the Permittee shall submit by July 1 an emission statement covering the previous calendar year. The emission statement shall contain, at a minimum, the information specified in 326 IAC 2-6-4(c) and shall meet the following requirements:

(a) Indicate estimated actual emissions of all pollutants listed in 326 IAC 2-6-4(a);

(b) Indicate estimated actual emissions of regulated pollutants as defined by 326 IAC 2-7-1(32) ("Regulated pollutant, which is used only for purposes of Section 19 of this rule") from the source, for purpose of fee assessment.

The statement must be submitted to:

Indiana Department of Environmental Management
Technical Support and Modeling Section, Office of Air Quality
100 North Senate Avenue
MC 61-50 IGCN 1003
Indianapolis, Indiana 46204-2251

The emission statement does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

C.17 General Record Keeping Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [326 IAC 2-2] [326 IAC 2-3]

(a) Records of all required monitoring data, reports and support information required by this permit shall be retained for a period of at least five (5) years from the date of monitoring sample, measurement, report, or application. These records shall be physically present or electronically accessible at the source location for a minimum of three (3) years. The records may be stored elsewhere for the remaining two (2) years as long as they are available upon request. If the Commissioner makes a request for records to the Permittee, the Permittee shall furnish the records to the Commissioner within a reasonable time.

(b) Unless otherwise specified in this permit, for all record keeping requirements not already legally required, the Permittee shall be allowed up to ninety (90) days from the date of permit issuance or the date of initial start-up, whichever is later, to begin such record keeping.

(c) If there is a reasonable possibility (as defined in 40 CFR 51.165(a)(6)(vi)(A), 40 CFR 51.165(a)(6)(vi)(B), 40 CFR 51.166(r)(6)(vi)(a), and/or 40 CFR 51.166(r)(6)(vi)(b)) that a "project" (as defined in 326 IAC 2-2-1(qq) and/or 326 IAC 2-3-1(ll)) at an existing emissions unit, other than projects at a source with a Plantwide Applicability Limitation (PAL), which is not part of a "major modification" (as defined in 326 IAC 2-2-1(ee) and/or 326 IAC 2-3-1(z)) may result in significant emissions increase and the Permittee elects to utilize the "projected actual emissions" (as defined in 326 IAC 2-2-1(rr) and/or 326 IAC 2-3-1(mm)), the Permittee shall comply with following:

(1) Before beginning actual construction of the “project” (as defined in326 IAC 2-2-1(qq) and/or 326 IAC 2-3-1(ll)) at an existing emissions unit, document and maintain the following records:

(A) A description of the project.

(B) Identification of any emissions unit whose emissions of a regulated new source review pollutant could be affected by the project.

(C) A description of the applicability test used to determine that the project is not a major modification for any regulated NSR pollutant, including:

(i) Baseline actual emissions;

(ii) Projected actual emissions;

(iii) Amount of emissions excluded under section 326 IAC 2-2-1(rr)(2)(A)(iii) and/or 326 IAC 2-3-1(mm)(2)(A)(iii); and

(iv) An explanation for why the amount was excluded, and any netting calculations, if applicable.

(d) If there is a reasonable possibility (as defined in 40 CFR 51.165(a)(6)(vi)(A) and/or 40 CFR 51.166(r)(6)(vi)(a)) that a “project” (as defined in 326 IAC 2-2-1(qq) and/or 326 IAC 2-3-1(ll)) at an existing emissions unit, other than projects at a source with a Plantwide Applicability Limitation (PAL), which is not part of a “major modification” (as defined in 326 IAC 2-2-1(ee) and/or 326 IAC 2-3-1(z)) may result in significant emissions increase and the Permittee elects to utilize the “projected actual emissions” (as defined in 326 IAC 2-2-1(rr) and/or 326 IAC 2-3-1(mm)), the Permittee shall comply with following:

(1) Monitor the emissions of any regulated NSR pollutant that could increase as a result of the project and that is emitted by any existing emissions unit identified in (1)(B) above; and

(2) Calculate and maintain a record of the annual emissions, in tons per year on a calendar year basis, for a period of five (5) years following resumption of regular operations after the change, or for a period of ten (10) years following resumption of regular operations after the change if the project increases the design capacity of or the potential to emit that regulated NSR pollutant at the emissions unit.

C.18 General Reporting Requirements [326 IAC 2-7-5(3)(C)] [326 IAC 2-1.1-11] [326 IAC 2-2] [326 IAC 2-3]

(a) The Permittee shall submit the attached Quarterly Deviation and Compliance Monitoring Report or its equivalent. Any deviation from permit requirements, the date(s) of each deviation, the cause of the deviation, and the response steps taken must be reported except that a deviation required to be reported pursuant to an applicable requirement that exists independent of this permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. This report shall be submitted not later than thirty (30) days ~~of~~ after the end of the reporting period. The Quarterly Deviation and Compliance Monitoring Report shall include a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34). A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit.

(b) The address for report submittal is:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

(c) Unless otherwise specified in this permit, any notice, report, or other submission required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.

(d) Reporting periods are based on calendar years, unless otherwise specified in this permit. For the purpose of this permit "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.

(e) If the Permittee is required to comply with the recordkeeping provisions of (d) in Section C - General Record Keeping Requirements for any "project" (as defined in 326 IAC 2-2-1(qq) and/or 326 IAC 2-3-1(ll)) at an existing emissions unit, and the project meets the following criteria, then the Permittee shall submit a report to IDEM, OAQ:

(1) The annual emissions, in tons per year, from the project identified in (c)(1) in Section C- General Record Keeping Requirements exceed the baseline actual emissions, as documented and maintained under Section C- General Record Keeping Requirements (c)(1)(C)(i), by a significant amount, as defined in 326 IAC 2-2-1 (xx) and/or 326 IAC 2-3-1(qq), for that regulated NSR pollutant, and

(2) The emissions differ from the preconstruction projection as documented and maintained under Section C - General Record Keeping Requirements (c)(1)(C)(ii).

(f) The report for project at an existing emissions unit shall be submitted within sixty (60) days after the end of the year and contain the following:

(1) The name, address, and telephone number of the major stationary source.

(2) The annual emissions calculated in accordance with (d)(1) and (2) in Section C - General Record Keeping Requirements.

(3) The emissions calculated under the actual-to-projected actual test stated in 326 IAC 2-2-2(d)(3) and/or 326 IAC 2-3-2(c)(3).

(4) Any other information that the Permittee deems fit to include in this report.

Reports required in this part shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

(g) The Permittee shall make the information required to be documented and maintained in accordance with (c) in Section C- General Record Keeping Requirements available for

review upon a request for inspection by IDEM, OAQ. The general public may request this information from the IDEM, OAQ under 326 IAC 17.1.

Stratospheric Ozone Protection

C.19 Compliance with 40 CFR 82 and 326 IAC 22-1

Pursuant to 40 CFR 82 (Protection of Stratospheric Ozone), Subpart F, except as provided for motor vehicle air conditioners in Subpart B, the Permittee shall comply with the applicable standards for recycling and emissions reduction.

SECTION D.1 EMISSIONS UNIT OPERATION CONDITIONS

Emissions Unit Description:

(a) Three (3) Natural Gas Fired Combined Cycle Systems [each includes a stationary combustion turbine and Heat Recovery Steam Generator (HRSG)], identified as CT-3, CT-4, and CT-5, installed in 2003, with a nominal capacity of 749.5 MMBtu per hour each based on 100% load, 55 F ambient temperature and natural gas higher heating value (833.9 MMBtu/hr at 100% load, -20 F and natural gas higher heating value), using DLN on each turbine and SCR and oxidation catalyst in each HRSG as control, and exhausting to stack 3-2, 4, and 5 respectively.

(b) One (1) Mechanical Draft Cooling Tower with five cells, identified as WT-1, installed in 2003, with a nominal capacity of 100,000 gallons per minute, using a high efficiency mist eliminators as control, and exhausting to stacks WT 1-A through 1-E.

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.1.1 PSD Minor Limit [326 IAC 2-2]

Pursuant to SSM 057-14278-00004, the CO emissions from the combustion turbines, identified as CT-3, CT-4, and CT-5, shall not exceed 150 tons per twelve consecutive month period with compliance determined at the end of each month. Compliance with the above CO limit and the removal of the three coal-fired boiler numbers 1, 2 and 3 shall render PSD 326 IAC 2-2 not applicable.

D.1.2 Formaldehyde Limitations

Pursuant to SSM 057-14278-00004 and 326 IAC 2-1.1-5 (Air Quality Requirements), the formaldehyde emissions from each combustion turbine stack shall not exceed 0.00071 pounds of formaldehyde per MMBtu.

D.1.3 Old Units Rendered Inoperable

Pursuant to SSM 057-14278-00004 issued on October 22, 2001, the following provisions shall apply:

(a) The three coal-fired boilers # 1, 2 and 3 shall remain permanently inoperable.

(b) The coal and ash handling activities associated with the removal from service of boilers #1, 2 and 3 shall remain inoperable.

D.1.4 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

A Preventive Maintenance Plan (PMP) is required for the combustion turbines, SCR units, oxidation catalysts and mist eliminator. Section B - Preventive Maintenance Plan contains the Permittee's obligations with regard to the preventive maintenance plan required by this condition.

Compliance Determination Requirements

D.1.5 Control Equipment Requirements

In order to achieve compliance with limits specified in D.1.1 the following conditions shall apply:

Except as otherwise provided by statute or rule or in this permit, the oxidation catalyst to control CO emissions from the combustion turbine in the HRSG shall be operated at all times that the combustion units are in operation.

Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]

D.1.6 Continuous Emission Monitoring (CEMs) [326 IAC 3-5-2(3)]

The Permittee shall calibrate, certify, operate and maintain a continuous emission monitoring system for CO, for stacks designated as 3-2, 4, and 5 in accordance with 326 IAC 3-5-2 and 3-5-3.

(a) The continuous emission monitoring system (CEMS) shall measure CO emissions rates in pounds per hour and parts per million (ppmvd) corrected to 15% O_2. The use of CEMS to measure and record the CO hourly limits is sufficient to demonstrate compliance with the limitations set forth in the permit. To demonstrate compliance with the CO limit, the source shall take an average of the pounds per hour over a twenty four (24) hour averaging period. The source shall maintain records of the parts per million and the pounds per hour.

(b) The Permittee shall determine compliance with Conditions D.1.1 utilizing data from the CO, and O_2 CEMS, the fuel flow meter, and Method 19 calculations.

(c) The Permittee shall record the output of the system and shall perform the required record keeping, pursuant to 326 IAC 3-5-6, and reporting, pursuant to 326 IAC 3-5-7.

D.1.7 NO_X Monitoring System Downtime [326 IAC 2-2] [326 IAC 2-7-6] [326 IAC 2-7-5(3)]

Whenever the NO_X continuous emission monitoring system is malfunctioning or down for repairs or adjustments, the following method shall be used to provide information related to NO_X emissions:

Monitoring of the SCR operating parameters for ammonia flow rate and inlet duct temperature, shall be implemented. The parameters are as follows:

(a) The Permittee shall record the ammonia flow rate and inlet duct temperature at least four (4) times per hour until the primary CEM or a backup CEM is brought online and functioning properly. The Preventive Maintenance Plan for the SCR shall contain troubleshooting contingency and corrective actions for when the readings are outside of the normal range for any one reading during downtime of the NO_X CEMS.

(b) The instrument used for determining the ammonia flow rate and inlet duct temperature shall comply with Section C - Instrument Specifications, of this permit, shall be subject to approval by IDEM, OAQ, and shall be calibrated or replaced at least once every six (6) months or other time period specified by the manufacturer. The Permittee shall maintain records of the manufacturer specifications, if used.

Failure to take response steps shall be considered a deviation from this permit. Section C – Response to Excursions or Exceedances contains the Permittee's obligations with regard to responding to the reasonable response steps required by this condition.

D.1.8 CO Monitoring System Downtime [326 IAC 2-2] [326 IAC 2-7-6] [326 IAC 2-7-5(3)]

In instances of CO continuous emission monitoring system (CEMS) downtime, the Permittee shall use a data substitution procedure for CO that is consistent with the requirements of 40 CFR Part 75, Appendix D (Optional SO_2 Emissions Data Protocol) for fuel flow meters requirements, and 40 CFR Part 75, Appendix E (Optional NO_X Emissions Estimation Protocol) for emission rate curve establishment. CO mass emissions reported shall be based on the fuel-and-unit-specific CO emission rates ("load curve") established during the latest stack test. Record Keeping and Reporting Requirements [326 IAC 2-5.1-3(e)(2)] [326 IAC 2-6.1-5(a)(2)]

D.1.9 40 CFR Part 60, Subpart GG Custom Fuel Schedule (Stationary Gas Turbines)

(a) Pursuant to the approval letter granted by U.S. EPA on February 28, 2002, the Permittee shall use CEMS to monitor NO_X emissions. Also pursuant to the approval letter granted by U.S. EPA on February 28, 2002, the following conditions shall be met:

(1) Each turbine shall meet the emission limitation determined according to 40 CFR 60.332. The "Y" value for the applicable equation and supporting documentation should be provided by the applicant and the limitation for NO_X emissions from pipeline quality natural gas should be fixed assuming the "F" value equals zero. The emission limitation must be expressed in ppmv, dry, corrected to 15 percent oxygen.

(2) Each NO_X CEMS must meet the applicable requirements of 40 CFR Part 60, Appendix B, Performance Specification 2, and Appendix F for certifying, maintaining, operating, and assuring quality of the system.

(3) Each NO_X CEMS shall be capable of calculating NO_X emissions concentrations corrected to 15 percent oxygen and International Standards Organization (ISO) standard conditions.

(4) The owner or operator of the NO_X CEMS shall submit an excess emissions and monitoring systems performance report [40 CFR 60.13(h)] and/or a summary report form to U.S. EPA and IDEM, OAQ on a quarterly basis, if excess emissions are determined, or semi-annually, if no excess emissions are determined. The report shall be postmarked by the 30th day following the end of each reporting period. Written reports must include information required at 40 CFR 60.7(c-d). This report shall also contain the content of nitrogen in fuel oil for each reporting period when oil is fired and a clearly calculated corresponding emission limitation.

(5) Record keeping requirements shall follow the requirements specified at 40 CFR 60.7.

(6) NO_X CEMS shall be used to demonstrate compliance with the emission limitation on a continuous basis and the quarterly report shall include the NO_X mass emissions for the reported period as reported to IDEM, OAQ.

(b) Pursuant to the approval letter granted by U.S. EPA on February 28, 2002, the Permittee may use the following custom monitoring schedule for fuel sulfur content when the fuel being burned is pipeline natural gas.

(1) The Permittee shall sample fuel sulfur content once per quarter for six quarters.

(2) Measurement of sulfur content of the natural gas shall be conducted using one of the approved ASTM reference methods for the measurement of sulfur in gaseous fuels, or an approved alternative method. The reference methods are ASTM D 1072-80, ASTM D 3031-81, ASTM D 3246-81, and ASTM D 4084-82 as referenced in 40 CFR 60.335(b)(2).

(3) Sampling can be reduced to semi-annually if six quarters of quarterly sampling and analyses indicate sulfur concentrations are below the applicable standard and do not vary significantly.

(4) If any analyses indicate noncompliance with the applicable sulfur limit of 0.8 weight percent in 40 CFR 60.333(b), samples must be collected and analyzed on a weekly basis while the custom fuel monitoring schedule is re-examined by a

delegated authority. In such a case, the Permittee must notify IDEM, OAQ and U.S. EPA in accordance with 40 CFR 60.7.

(5) Reporting and record keeping requirements must be maintained in accordance with 40 CFR 60.7, 60.19, and 60.334.

(c) As per the U.S. EPA final revisions to 40 CFR 60, Subpart GG issued July 8, 2004 and IDEM, OAQ authorization of alternative monitoring requirement under 326 IAC 12-1(b):

(1) The Permittee may elect not to monitor the nitrogen content of the fuel combusted in the turbine as required by D.1.10(c), if the Permittee claims a zero allowance (i.e. F-value = 0) for the fuel bound nitrogen, regardless of whether an existing alternative procedure approved by the Commissioner for Subpart GG requires such monitoring; and

(2) The Permittee may elect not to monitor the total sulfur content of the gaseous fuel combusted in the turbine, as required by Condition D.1.10(b), if the gaseous fuel is demonstrated to meet the definition of natural gas [40 CFR 60.331(u)], regardless of whether an existing custom schedule approved by the Commissioner for Subpart GG requires such monitoring. The Permittee shall use one of the following source of information to make the required demonstration:

(A) The gas quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20.0 grains per 100 scf or less; or

(B) Representative fuel sampling data which show that the sulfur content of the gaseous fuel does not exceed 20 grains per 100 scf. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of appendix D to Part 75 is required.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.1.10 Record Keeping Requirements [326 IAC 3-5-2]

(a) To document the compliance status with CO limits in Condition D.1.1, the Permittee shall maintain records of all CO, and oxygen continuous emissions monitoring data, pursuant to 326 IAC 3-5-6, and 40 CFR 60. Records shall be complete and sufficient to establish compliance with the CO limits as required in Condition D.1.1. During CO CEMS downtime, the Permittee shall maintain records of mass emission rates determined in accordance with Condition D.1.6.

(b) Section C - General Record Keeping Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.

D.1.11 Reporting Requirements

A quarterly summary of the information to document compliance with Conditions D.1.1 shall be submitted using the reporting forms located at the end of this permit, or their equivalent, no later than thirty (30) days following the end of the calendar quarter. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a “responsible official” as defined by 326 IAC 2-7-1(34). Section C - General Reporting Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.

SECTION D.2 EMISSIONS UNIT OPERATION CONDITIONS

Emissions Unit Description:

(c) One (1) natural gas-fired boiler, identified as Heating Boiler, installed in 1990 and converted to natural gas in 2011, with a nominal heat input capacity of 9.923 million Btu per hour (MMBtu/hr), with no control equipment and exhausting to stack H-1.

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.2.1 Particulate Matter (PM) [326 IAC 6-2-4]

Pursuant to 326 IAC 6-2-4 (Particulate Matter Emissions for Sources of Indirect Heating), the PM emissions from the Heating Boiler shall not exceed 0.6 pounds per million Btu heat input (lb/MMBtu). This limitation was calculated using the following equation:

$$Pt = \frac{1.09}{Q^{0.26}}$$

Where Q = 9.923 MMBtu/hr (capacity of Heating Boiler)

SECTION D.3 EMISSIONS UNIT OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]

The following insignificant activities:

(a) Degreasing operations that do not exceed one hundred forty-five (145) gallons per twelve months, except if subject to 326 IAC 20-6. [326 IAC 8-3-2] [326 IAC 8-3-5]

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.3.1 Volatile Organic Compounds (VOC) [326 IAC 8-3-2]

Pursuant to 326 IAC 8-3-2 (Cold Cleaner Operations), the owner or operator shall:

(a) Equip the cleaner with a cover;

(b) Equip the cleaner with a facility for draining cleaned parts;

(c) Close the degreaser cover whenever parts are not being handled in the cleaner;

(d) Drain cleaned parts for at least fifteen (15) seconds or until dripping ceases;

(e) Provide a permanent, conspicuous label summarizing the operation requirements;

(f) Store waste solvent only in covered containers and not dispose of waste solvent or transfer it to another party, in such a manner that greater than twenty percent (20%) of the waste solvent (by weight) can evaporate into the atmosphere.

D.3.2 Volatile Organic Compounds (VOC) [326 IAC 8-3-5]

(a) Pursuant to 326 IAC 8-3-5(a) (Cold Cleaner Degreaser Operation and Control), the owner or operator of a cold cleaner degreaser facility shall ensure that the following control equipment requirements are met:

(1) Equip the degreaser with a cover. The cover must be designed so that it can be easily operated with one (1) hand if:

(A) The solvent volatility is greater than two (2) kiloPascals (fifteen (15) millimeters of mercury or three-tenths (0.3) pounds per square inch) measured at thirty-eight degrees Celsius (38°C) (one hundred degrees Fahrenheit (100°F));

(B) The solvent is agitated; or

(C) The solvent is heated.

(2) Equip the degreaser with a facility for draining cleaned articles. If the solvent volatility is greater than four and three-tenths (4.3) kiloPascals (thirty-two (32) millimeters of mercury or six-tenths (0.6) pounds per square inch) measured at thirty-eight degrees Celsius (38°C) (one hundred degrees Fahrenheit (100°F)), then the drainage facility must be internal such that articles are enclosed under the cover while draining. The drainage facility may be external for applications where an internal type cannot fit into the cleaning system.

(3) Provide a permanent, conspicuous label which lists the operating requirements outlined in subsection (b).

(4) The solvent spray, if used, must be a solid, fluid stream and shall be applied at a pressure which does not cause excessive splashing.

(5) Equip the degreaser with one (1) of the following control devices if the solvent volatility is greater than four and three-tenths (4.3) kiloPascals (thirty-two (32) millimeters of mercury or six-tenths (0.6) pounds per square inch) measured at thirty-eight degrees Celsius (38°C) (one hundred degrees Fahrenheit (100°F)), or if the solvent is heated to a temperature greater than forty-eight and nine-tenths degrees Celsius (48.9^{O}C) (one hundred twenty degrees Fahrenheit (120°F)):

(A) A freeboard that attains a freeboard ratio of seventy-five hundredths (0.75) or greater.

(B) A water cover when solvent is used is insoluble in, and heavier than, water.

(C) Other systems of demonstrated equivalent control such as a refrigerated chiller of carbon adsorption. Such systems shall be submitted to the U.S. EPA as a SIP revision.

(b) Pursuant to 326 IAC 8-3-5(b) (Cold Cleaner Degreaser Operation and Control), the owner or operator of a cold cleaning facility shall ensure that the following operating requirements are met:

(1) Close the cover whenever articles are not being handled in the degreaser.

(2) Drain cleaned articles for at least fifteen (15) seconds or until dripping ceases.

(3) Store waste solvent only in covered containers and prohibit the disposal or transfer of waste solvent in any manner in which greater than twenty percent (20%) of the waste solvent by weight could evaporate.

SECTION E **TITLE IV CONDITIONS**

ORIS Code: 1007

Facility Description [326 IAC 2-7-5(15)]

(a) Three (3) Natural Gas Fired Combined Cycle Systems [each includes a stationary combustion turbine and Heat Recovery Steam Generator (HRSG)], identified as CT-3, CT-4, and CT-5, installed in 2003, with a nominal capacity of 749.5 MMBtu per hour each based on 100% load, 55 F ambient temperature and natural gas higher heating value (833.9 MMBtu/hr at 100% load, -20 F and natural gas higher heating value), using DLN on each turbine and SCR and oxidation catalyst in each HRSG as control, and exhausting to stack 3-2, 4, and 5 respectively.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Acid Rain Program

E.1 Acid Rain Permit [326 IAC 2-7-5(1)(C)] [326 IAC 21] [40 CFR 72 through 40 CFR 78]

Pursuant to 326 IAC 21 (Acid Deposition Control), the Permittee shall comply with all provisions of the Acid Rain permit issued for this source, and any other applicable requirements contained in 40 CFR 72 through 40 CFR 78. The Acid Rain permit for this source is attached to this permit as Attachment A, and is incorporated by reference.

E.2 Title IV Emissions Allowances [326 IAC 2-7-5(4)] [326 IAC 21]

Emissions exceeding any allowances that the Permittee lawfully holds under the Title IV Acid Rain Program of the Clean Air Act are prohibited, subject to the following limitations:

(a) No revision of this permit shall be required for increases in emissions that are authorized by allowances acquired under the Title IV Acid Rain Program, provided that such increases do not require a permit revision under any other applicable requirement.

(b) No limit shall be placed on the number of allowances held by the Permittee. The Permittee may not use allowances as a defense to noncompliance with any other applicable requirement.

(c) Any such allowance shall be accounted for according to the procedures established in regulations promulgated under Title IV of the Clean Air Act.

SECTION F.1 New Source Performance Standards (NSPS) [40 CFR Part 60] [326 IAC 12]

Facility Description [326 IAC 2-7-5(15)]

(a) Three (3) Natural Gas Fired Combined Cycle Systems [each includes a stationary combustion turbine and Heat Recovery Steam Generator (HRSG)], identified as CT-3, CT-4, and CT-5, installed in 2003, with a nominal capacity of 749.5 MMBtu per hour each based on 100% load, 55 F ambient temperature and natural gas higher heating value (833.9 MMBtu/hr at 100% load, -20 F and natural gas higher heating value), using DLN on each turbine and SCR and oxidation catalyst in each HRSG as control, and exhausting to stack 3-2, 4, and 5 respectively.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

New Source Performance Standards (NSPS) [326 IAC 12] [40 CFR Part 60]

F.1.1 General Provisions Relating to New Source Performance Standards [326 IAC 12-1] [40 CFR Part 60, Subpart A]

Pursuant to 40 CFR 60.1, the Permittee shall comply with the provisions of 40 CFR Part 60 Subpart A – General Provisions, which are incorporated by reference as 326 IAC 12-1 for the stationary gas turbines except as otherwise specified in 40 CFR Part 60, Subpart GG.

F.1.2 Standards of Performance for Stationary Gas Turbines [40 CFR Part 60, Subpart GG] [326 IAC 12]

The Permittee shall comply with the following provisions of the Standards of Performance for Stationary Gas Turbines, included as Attachment B of this permit, which are incorporated by reference as 326 IAC 12 for the Stationary Gas Turbines:

- 40 CFR 60.330;
- 40 CFR 60.331;
- 40 CFR 60.332;
- 40 CFR 60.333;
- 40 CFR 60.334; and
- 40 CFR 60.335.

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
PART 70 OPERATING PERMIT
CERTIFICATION

Source Name: Duke Energy Indiana, Inc. - Noblesville Generating Station
Source Address: 21225 Riverwood Avenue, Noblesville, Indiana 46060
Part 70 Permit No.: T057-26751-00004

This certification shall be included when submitting monitoring, testing reports/results or other documents as required by this permit.

Please check what document is being certified:

☐ Annual Compliance Certification Letter

☐ Test Result (specify)

☐ Report (specify)

☐ Notification (specify)

☐ Affidavit (specify)

☐ Other (specify)

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
Signature:
Printed Name:
Title/Position:
Phone:
Date:

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251
Phone: (317) 233-0178
Fax: (317) 233-6865

PART 70 OPERATING PERMIT
EMERGENCY OCCURRENCE REPORT

Source Name: Duke Energy Indiana, Inc. - Noblesville Generating Station
Source Address: 21225 Riverwood Avenue, Noblesville, Indiana 46060
Part 70 Permit No.: T057-26751-00004

This form consists of 2 pages **Page 1 of 2**

☐ This is an emergency as defined in 326 IAC 2-7-1(12)

- The Permittee must notify the Office of Air Quality (OAQ), no later than four (**4**) daytime business hours (1-800-451-6027 or 317-233-0178, ask for Compliance and Enforcement Branch); and
- The Permittee must submit notice in writing or by facsimile no later than two (**2**) working days (Facsimile Number: 317-233-6865), and follow the other requirements of 326 IAC 2-7-16.

If any of the following are not applicable, mark N/A

Facility/Equipment/Operation:
Control Equipment:
Permit Condition or Operation Limitation in Permit:
Description of the Emergency:
Describe the cause of the Emergency:

If any of the following are not applicable, mark N/A **Page 2 of 2**

Date/Time Emergency started:
Date/Time Emergency was corrected:
Was the facility being properly operated at the time of the emergency? Y N
Type of Pollutants Emitted: TSP, PM-10, SO_2, VOC, NO_X, CO, Pb, other:
Estimated amount of pollutant(s) emitted during emergency:
Describe the steps taken to mitigate the problem:
Describe the corrective actions/response steps taken:
Describe the measures taken to minimize emissions:
If applicable, describe the reasons why continued operation of the facilities are necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw materials of substantial economic value:

Form Completed by:_____

Title / Position: _____

Date:_____

Phone: _____

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH
PART 70 OPERATING PERMIT
QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT

Source Name: Duke Energy Indiana, Inc. - Noblesville Generating Station
Source Address: 21225 Riverwood Avenue, Noblesville, Indiana 46060
Part 70 Permit No.: T057-26751-00004

Months: _____ to _ Year: _____

Page 1 of 2

This report shall be submitted quarterly based on a calendar year. Any deviation from the requirements of this permit, the date(s) of each deviation, the probable cause of the deviation, and the response steps taken must be reported. A deviation required to be reported pursuant to an applicable requirement that exists independent of the permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. Additional pages may be attached if necessary. If no deviations occurred, please specify in the box marked "No deviations occurred this reporting period".	
☐ NO DEVIATIONS OCCURRED THIS REPORTING PERIOD.	
☐ THE FOLLOWING DEVIATIONS OCCURRED THIS REPORTING PERIOD	
Permit Requirement (specify permit condition #)	
Date of Deviation:	**Duration of Deviation:**
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	**Duration of Deviation:**
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	

Permit Requirement (specify permit condition #)	
Date of Deviation:	**Duration of Deviation:**
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	**Duration of Deviation:**
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	**Duration of Deviation:**
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	

Form Completed by:_____

Title / Position: _____

Date:_____

Phone: _____

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

TITLE IV (ACID RAIN) PERMIT RENEWAL

OFFICE OF AIR QUALITY

Noblesville Generating Station
21225 Riverwood Avenue
Noblesville, Indiana, 46060

ORIS: 1007

The owners and operators (hereinafter collectively known as the Permittee) of the above source are issued this permit under the provisions of 326 Indiana Administrative Code (IAC) 21 with conditions listed on the attached pages.

Acid Rain Permit Second Renewal No.: AR 057-28759-00004	
Issued by/Original Signed by: Tripurari P. Sinha, Ph. D., Section Chief Permits Branch Office of Air Quality	Issuance Date: April 6, 2010 Expiration Date: April 6, 2015

Title IV Operating Conditions

Title IV Source Description:

(a) Natural Gas Fired Combined Cycle Systems, includes a stationary combustion turbine and Heat Recovery Steam Generator (HRSG)], identified as CT-3, installed in 2003, with a nominal capacity of 749.5 MMBtu per hour each based on 100% load, 55° F ambient temperature and natural gas higher heating value (833.9 MMBtu/hr at 100% load, - 20° F and natural gas higher heating value), using DLN on each turbine and SCR and oxidation catalyst in each HRSG as control, and exhausting to stack 3-2.

(b) Natural Gas Fired Combined Cycle Systems [each includes a stationary combustion turbine and Heat Recovery Steam Generator (HRSG)], identified as CT-4, installed in 2003, with a nominal capacity of 749.5 MMBtu per hour each based on 100% load, 55° F ambient temperature and natural gas higher heating value (833.9 MMBtu/hr at 100% load, - 20° F and natural gas higher heating value), using DLN on each turbine and SCR and oxidation catalyst in each HRSG as control, and exhausting to stack 4.

(c) Natural Gas Fired Combined Cycle Systems [each includes a stationary combustion turbine and Heat Recovery Steam Generator (HRSG)], identified as CT-5, installed in 2003, with a nominal capacity of 749.5 MMBtu per hour each based on 100% load, 55° F ambient temperature and natural gas higher heating value (833.9 MMBtu/hr at 100% load, - 20° F and natural gas higher heating value), using DLN on each turbine and SCR and oxidation catalyst in each HRSG as control, and exhausting to stack 5.

(The information contained in this box is descriptive information and does not constitute enforceable conditions.)

1. Statutory and Regulatory Authorities

In accordance with IC 13-17-3-4, and IC 13-17-3-11 as well as Titles IV and V of the Clean Air Act, the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ) issues this permit pursuant to 326 IAC 2 and 326 IAC 21 (incorporates by reference 40 Code of Federal Regulations (CFR) 72 through 78).

2. Standard Permit Requirements [326 IAC 21]

(a) The designated representative has submitted a complete acid rain permit application in accordance with the deadlines in 40 CFR 72.30.

(b) The Permittee shall operate CT-3, CT-4, and CT-5 in compliance with this permit.

3. Monitoring Requirements [326 IAC 21]

(a) The Permittee and, to the extent applicable, the designated representative of CT-3, CT-4, and CT-5 shall comply with the monitoring requirements as provided in 40 CFR 75.

(b) The emissions measurements recorded and reported in accordance with 40 CFR 75 shall be used to determine compliance by CT-3, CT-4, and CT-5 with the acid rain emissions limitations and emissions reduction requirements for sulfur dioxide under the Acid Rain Program.

(c) The requirements of 40 CFR 75 shall not affect the responsibility of the Permittee to monitor emissions of other pollutants or other emissions characteristics at CT-3, CT-4, and CT-5 under other applicable requirements of the Clean Air Act and other provisions of the operating permit for the source.

4. Sulfur Dioxide Requirements [326 IAC 21]

(a) The Permittee shall:

(1) Hold allowances, as of the allowance transfer deadline (as defined in 40 CFR 72.2), in the compliance subaccount of CT-3, CT-4, and CT-5, after deductions under 40 CFR 73.34(c), not less than the total annual emissions of sulfur dioxide for the previous calendar year from CT-3, CT-4, and CT-5; and,

(2) Comply with the applicable acid rain emissions limitations for sulfur dioxide.

(b) Each ton of sulfur dioxide emitted in excess of the acid rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Clean Air Act.

(c) CT-3, CT-4, and CT-5 shall be subject to the requirements under paragraph 4(a) of the sulfur dioxide requirements as follows:

(1) Starting January 1, 2000, an affected unit under 40 CFR 72.6(a)(2); or,

(2) Starting on the latter of January 1, 2000, or the deadline for monitor certification under 40 CFR 75, an affected unit under 40 CFR 72.6(a)(3).

(d) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.

(e) An allowance shall not be deducted in order to comply with the requirements under paragraph 4(a) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.

(f) CT-3, CT-4, and CT-5 were not allocated allowances by United States Environmental Protection Agency (U.S. EPA) under 40 CFR part 73.10. However, CT-3, CT-4, and CT-5 must still comply with the requirement to hold allowances to account for sulfur dioxide emissions under paragraph 4(a) and 326 IAC 21.

(g) An allowance allocated by the U.S. EPA under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the acid rain permit application, the acid rain permit, the acid rain portion of an operating permit, or the written exemption under 40 CFR 72.7 and 72.8 and 326 IAC 21, and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.

(h) An allowance allocated by U.S. EPA under the Acid Rain Program does not constitute a property right.

(i) No permit revision may be required for increases in emissions that are authorized by allowances acquired pursuant to the Acid Rain Program, provided that the increases do not require a permit revision under any other applicable requirement.
[326 IAC 2-7-5(4)(A)]

(j) No limit shall be placed on the number of allowances held by the Permittee. The Permittee may not, however, use allowances as a defense to noncompliance with any applicable requirement other than the requirements of the Acid Rain Program.
[326 IAC 2-7-5(4)(B)]

5. Nitrogen Oxides Requirements [326 IAC 21]

Pursuant to 40 CFR 76, Acid Rain Nitrogen Oxides Emission Reduction Program, CT-3, CT-4, and CT-5 are not subject to the nitrogen oxide limitations set out in 40 CFR 76.

6. Excess Emissions Requirements [40 CFR 77] [326 IAC 21]

(a) If CT-3, CT-4, or CT-5 have excess emissions of sulfur dioxide in any calendar year, the designated representative shall submit a proposed offset plan to U.S. EPA and IDEM, OAQ as required under 40 CFR 77 and 326 IAC 21.

(b) The designated representative shall submit required information to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch
Office of Air Quality
100 North Senate Avenue
MC 61-53, IGCN 1003
Indianapolis, Indiana 46204

and

U.S. Environmental Protection Agency
Clean Air Markets Division
1200 Pennsylvania Avenue, NW
Mail Code (6204N)
Washington, DC 20460

(c) If CT-3, CT-4, or CT-5 have excess emissions, as defined in 40 CFR 72.2, in any calendar year the Permittee shall:

(1) Pay to U.S. EPA without demand the penalty required, and pay to U.S. EPA upon demand the interest on that penalty, as required by 40 CFR 77 and 326 IAC 21; and,

(2) Comply with the terms of an approved sulfur dioxide offset plan, as required by 40 CFR 77 and 326 IAC 21.

7. Record Keeping and Reporting Requirements [326 IAC 21]

(a) Unless otherwise provided, the Permittee shall keep on site each of the following documents for a period of 5 years, as required by 40 CFR 72.9(f), from the date the document is created. This period may be extended for cause, at any time prior to the end of the 5 years, in writing by U.S. EPA or IDEM, OAQ:

(1) The certificate of representation for the designated representative for CT-3, CT-4, and CT-5 and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site at the source beyond such 5 year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;

(2) All emissions monitoring information collected in accordance with 40 CFR 75 shall be retained on site for 3 years;

(3) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,

(4) Copies of all documents used to complete an acid rain permit application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.

(b) The designated representative of CT-3, CT-4, and CT-5 shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 72.90 subpart I, 40 CFR 75, and 326 IAC 21. The required information is to be submitted to the appropriate authority(ies) as specified in 40 CFR 72.90 subpart I and 40 CFR 75.

8. Submissions [326 IAC 21]

(a) The designated representative of CT-3, CT-4, and CT-5 shall submit a certificate of representation, and any superseding certificate of representation, to U.S. EPA and IDEM, OAQ in accordance with 40 CFR 72 and 326 IAC 21.

(b) The designated representative shall submit required information to:

Indiana Department of Environmental Management
Permit Administration and Support Section
Office of Air Quality
100 North Senate Avenue
MC 61-53, IGCN 1003
Indianapolis, Indiana 46204

and

U.S. Environmental Protection Agency
Clean Air Markets Division
1200 Pennsylvania Avenue, NW
Mail Code (6204N)
Washington, DC 20460

(c) Each such submission under the Acid Rain Program shall be submitted, signed and certified by the designated representative for all sources on behalf of which the submission is made.

(d) In each submission under the Acid Rain Program, the designated representative shall certify, by his or her signature, the following statements which shall be included verbatim in the submission:

(1) “I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made.”; and,

(2) “I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.”

(e) The designated representative of CT-3, CT-4, and CT-5 shall notify the Permittee:

(1) By the date of submission, of any Acid Rain Program submissions by the designated representative;

(2) Within 10 business days of receipt of any written determination by U.S. EPA or IDEM, OAQ; and,

(3) Provided that the submission or determination covers CT-3, CT-4, or CT-5.

(f) The designated representative of CT-3, CT-4, and CT-5 shall provide the Permittee a copy of any submission or determination under condition 8(e) of this section, unless the Permittee expressly waives the right to receive a copy.

9. Severability [326 IAC 21]

Invalidation of the acid rain portion of an operating permit does not affect the continuing validity of the rest of the operating permit, nor shall invalidation of any other portion of the operating permit affect the continuing validity of the acid rain portion of the permit. [40 CFR 72.72(b), 326 IAC 21, and 326 IAC 2-7-5(5)]

10. Liability [326 IAC 21]

(a) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, an acid rain permit, an acid rain portion of an operation permit, or a written exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement by U.S. EPA pursuant to Section 113(c) of the Clean Air Act and shall be subject to enforcement by IDEM pursuant to 326 IAC 21 and IC 13-30-3.

(b) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to Section 113(c) of the Clean Air Act, 18 U.S.C. 1001 and IDEM pursuant to 326 IAC 21 and IC 13-30-6-2.

(c) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.

(d) CT-3, CT-4, and CT-5 shall meet the requirements of the Acid Rain Program.

(e) Any provision of the Acid Rain Program that applies to CT-3, CT-4, or CT-5, including a provision applicable to the designated representative of CT-3, CT-4, or CT-5, shall also apply to the Permittee.

(f) Any provision of the Acid Rain Program that applies to CT-3, CT-4, or CT-5, including a provision applicable to the designated representative, shall also apply to the Permittee. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans) and 40 CFR 76.11 (NOx averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR 75, including 40 CFR 75.16, 75.17, and 75.18, the Permittee and the designated representative of one affected unit shall not be liable for any violation by any other affected unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.

(g) Each violation of a provision of 40 CFR parts 72, 73, 75, 77, and 78 by CT-3, CT-4, or CT-5, or by the Permittee or designated representative shall be a separate violation of the Clean Air Act.

11. Effect on Other Authorities [326 IAC 21]

No provision of the Acid Rain Program, an acid rain permit application, an acid rain permit, an acid rain portion of an operation permit, or a written exemption under 40 CFR 72.7 or 72.8 shall be construed as:

(a) Except as expressly provided in Title IV of the Clean Air Act (42 USC 7651 to 7651(o)), exempting or excluding the Permittee and, to the extent applicable, the designated representative of CT-3, CT-4, or CT-5, from compliance with any other provision of the Clean Air Act, including the provisions of Title I of the Clean Air Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;

(b) Limiting the number of allowances a unit can hold; provided, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Clean Air Act;

(c) Requiring a change of any kind in any state law regulating electric utility rates and charges, affecting any state law regarding such state regulation, or limiting such state regulation, including any prudence review requirements under such state law;

(d) Modifying the Federal Power Act (16 USC 791(a) et seq.) or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,

(e) Interfering with or impairing any program for competitive bidding for power supply in a state in which such a program is established.

Attachment B: Standards of Performance for Stationary Gas Turbines [40 CFR Part 60, Subpart GG] [326 IAC 12-1-1]

Subpart GG—Standards of Performance for Stationary Gas Turbines

§ 60.330 Applicability and designation of affected facility.

(a) The provisions of this subpart are applicable to the following affected facilities: All stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules (10 million Btu) per hour, based on the lower heating value of the fuel fired.

(b) Any facility under paragraph (a) of this section which commences construction, modification, or reconstruction after October 3, 1977, is subject to the requirements of this part except as provided in paragraphs (e) and (j) of §60.332.

[44 FR 52798, Sept. 10, 1979, as amended at 52 FR 42434, Nov. 5, 1987; 65 FR 61759, Oct. 17, 2000]

§ 60.331 Definitions.

As used in this subpart, all terms not defined herein shall have the meaning given them in the Act and in subpart A of this part.

(a) *Stationary gas turbine* means any simple cycle gas turbine, regenerative cycle gas turbine or any gas turbine portion of a combined cycle steam/electric generating system that is not self propelled. It may, however, be mounted on a vehicle for portability.

(b) *Simple cycle gas turbine* means any stationary gas turbine which does not recover heat from the gas turbine exhaust gases to preheat the inlet combustion air to the gas turbine, or which does not recover heat from the gas turbine exhaust gases to heat water or generate steam.

(c) *Regenerative cycle gas turbine* means any stationary gas turbine which recovers heat from the gas turbine exhaust gases to preheat the inlet combustion air to the gas turbine.

(d) *Combined cycle gas turbine* means any stationary gas turbine which recovers heat from the gas turbine exhaust gases to heat water or generate steam.

(e) *Emergency gas turbine* means any stationary gas turbine which operates as a mechanical or electrical power source only when the primary power source for a facility has been rendered inoperable by an emergency situation.

(f) *Ice fog* means an atmospheric suspension of highly reflective ice crystals.

(g) *ISO standard day conditions* means 288 degrees Kelvin, 60 percent relative humidity and 101.3 kilopascals pressure.

(h) *Efficiency* means the gas turbine manufacturer's rated heat rate at peak load in terms of heat input per unit of power output based on the lower heating value of the fuel.

(i) *Peak load* means 100 percent of the manufacturer's design capacity of the gas turbine at ISO standard day conditions.

(j) *Base load* means the load level at which a gas turbine is normally operated.

(k) *Fire-fighting turbine* means any stationary gas turbine that is used solely to pump water for extinguishing fires.

(l) *Turbines employed in oil/gas production or oil/gas transportation* means any stationary gas turbine used to provide power to extract crude oil/natural gas from the earth or to move crude oil/natural gas, or products refined from these substances through pipelines.

(m) A *Metropolitan Statistical Area* or *MSA* as defined by the Department of Commerce.

(n) *Offshore platform gas turbines* means any stationary gas turbine located on a platform in an ocean.

(o) *Garrison facility* means any permanent military installation.

(p) *Gas turbine model* means a group of gas turbines having the same nominal air flow, combuster inlet pressure, combuster inlet temperature, firing temperature, turbine inlet temperature and turbine inlet pressure.

(q) *Electric utility stationary gas turbine* means any stationary gas turbine constructed for the purpose of supplying more than one-third of its potential electric output capacity to any utility power distribution system for sale.

(r) *Emergency fuel* is a fuel fired by a gas turbine only during circumstances, such as natural gas supply curtailment or breakdown of delivery system, that make it impossible to fire natural gas in the gas turbine.

(s) *Unit operating hour* means a clock hour during which any fuel is combusted in the affected unit. If the unit combusts fuel for the entire clock hour, it is considered to be a full unit operating hour. If the unit combusts fuel for only part of the clock hour, it is considered to be a partial unit operating hour.

(t) *Excess emissions* means a specified averaging period over which either:

(1) The NO_Xemissions are higher than the applicable emission limit in §60.332;

(2) The total sulfur content of the fuel being combusted in the affected facility exceeds the limit specified in §60.333; or

(3) The recorded value of a particular monitored parameter is outside the acceptable range specified in the parameter monitoring plan for the affected unit.

(u) *Natural gas* means a naturally occurring fluid mixture of hydrocarbons (*e.g.* , methane, ethane, or propane) produced in geological formations beneath the Earth's surface that maintains a gaseous state at standard atmospheric temperature and pressure under ordinary conditions. Natural gas contains 20.0 grains or less of total sulfur per 100 standard cubic feet. Equivalents of this in other units are as follows: 0.068 weight percent total sulfur, 680 parts per million by weight (ppmw) total sulfur, and 338 parts per million by volume (ppmv) at 20 degrees Celsius total sulfur. Additionally, natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 950 and 1100 British thermal units (Btu) per standard cubic foot. Natural gas does not include the following gaseous fuels: landfill gas, digester gas, refinery gas, sour gas, blast furnace gas, coal-derived gas, producer gas, coke oven gas, or any gaseous fuel produced in a process which might result in highly variable sulfur content or heating value.

(v) *Duct burner* means a device that combusts fuel and that is placed in the exhaust duct from another source, such as a stationary gas turbine, internal combustion engine, kiln, etc., to allow the firing of additional fuel to heat the exhaust gases before the exhaust gases enter a heat recovery steam generating unit.

(w) *Lean premix stationary combustion turbine* means any stationary combustion turbine where the air and fuel are thoroughly mixed to form a lean mixture for combustion in the combustor. Mixing may occur before or in the combustion chamber. A unit which is capable of operating in both lean premix and diffusion flame modes is considered a lean premix stationary combustion turbine when it is in the lean premix mode, and it is considered a diffusion flame stationary combustion turbine when it is in the diffusion flame mode.

(x) *Diffusion flame stationary combustion turbine* means any stationary combustion turbine where fuel and air are injected at the combustor and are mixed only by diffusion prior to ignition. A unit which is capable of operating in both lean premix and diffusion flame modes is considered a lean premix stationary combustion turbine when it is in the lean premix mode, and it is considered a diffusion flame stationary combustion turbine when it is in the diffusion flame mode.

(y) *Unit operating day* means a 24-hour period between 12:00 midnight and the following midnight during which any fuel is combusted at any time in the unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period.

[44 FR 52798, Sept. 10, 1979, as amended at 47 FR 3770, Jan. 27, 1982; 65 FR 61759, Oct. 17, 2000; 69 FR 41359, July 8, 2004]

§ 60.332 Standard for nitrogen oxides.

(a) On and after the date on which the performance test required by §60.8 is completed, every owner or operator subject to the provisions of this subpart as specified in paragraphs (b), (c), and (d) of this section shall comply with one of the following, except as provided in paragraphs (e), (f), (g), (h), (i), (j), (k), and (l) of this section.

(1) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine, any gases which contain nitrogen oxides in excess of:

$$STD = 0.0075\frac{(14.4)}{Y} + F$$

where:

STD = allowable ISO corrected (if required as given in §60.335(b)(1)) NO_Xemission concentration (percent by volume at 15 percent oxygen and on a dry basis),

Y = manufacturer's rated heat rate at manufacturer's rated load (kilojoules per watt hour) or, actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt hour, and

F = NO_Xemission allowance for fuel-bound nitrogen as defined in paragraph (a)(4) of this section.

(2) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine, any gases which contain nitrogen oxides in excess of:

$$STD = 0.0150\frac{(14.4)}{Y} + F$$

where:

STD = allowable ISO corrected (if required as given in §60.335(b)(1)) NO_Xemission concentration (percent by volume at 15 percent oxygen and on a dry basis),

Y = manufacturer's rated heat rate at manufacturer's rated peak load (kilojoules per watt hour), or actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt hour, and

F = NO_Xemission allowance for fuel-bound nitrogen as defined in paragraph (a)(4) of this section.

(3) The use of F in paragraphs (a)(1) and (2) of this section is optional. That is, the owner or operator may choose to apply a NO_Xallowance for fuel-bound nitrogen and determine the appropriate F-value in accordance with paragraph (a)(4) of this section or may accept an F-value of zero.

(4) If the owner or operator elects to apply a NO_Xemission allowance for fuel-bound nitrogen, F shall be defined according to the nitrogen content of the fuel during the most recent performance test required under §60.8 as follows:

Fuel-bound nitrogen (percent by weight)	**F (NO_Xpercent by volume)**
N ≤ .015	0
0.015 < N≤ 0.1	0.04 (N)
0.1 < N ≤ 0.25	0.004+0.0067(N–0.1)
N > 0.25	0.005

Where:

N = the nitrogen content of the fuel (percent by weight).

or:

Manufacturers may develop and submit to EPA custom fuel-bound nitrogen allowances for each gas turbine model they manufacture. These fuel-bound nitrogen allowances shall be substantiated with data and must be approved for use by the Administrator before the initial performance test required by §60.8. Notices of approval of custom fuel-bound nitrogen allowances will be published in theFederal Register.

(b) Electric utility stationary gas turbines with a heat input at peak load greater than 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired shall comply with the provisions of paragraph (a)(1) of this section.

(c) Stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules per hour (10 million Btu/hour) but less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired, shall comply with the provisions of paragraph (a)(2) of this section.

(d) Stationary gas turbines with a manufacturer's rated base load at ISO conditions of 30 megawatts or less except as provided in §60.332(b) shall comply with paragraph (a)(2) of this section.

(e) Stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules per hour (10 million Btu/hour) but less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired and that have commenced construction prior to October 3, 1982 are exempt from paragraph (a) of this section.

(f) Stationary gas turbines using water or steam injection for control of NO_Xemissions are exempt from paragraph (a) when ice fog is deemed a traffic hazard by the owner or operator of the gas turbine.

(g) Emergency gas turbines, military gas turbines for use in other than a garrison facility, military gas turbines installed for use as military training facilities, and fire fighting gas turbines are exempt from paragraph (a) of this section.

(h) Stationary gas turbines engaged by manufacturers in research and development of equipment for both gas turbine emission control techniques and gas turbine efficiency improvements are exempt from paragraph (a) on a case-by-case basis as determined by the Administrator.

(i) Exemptions from the requirements of paragraph (a) of this section will be granted on a case-by-case basis as determined by the Administrator in specific geographical areas where mandatory water restrictions are required by governmental agencies because of drought conditions. These exemptions will be allowed only while the mandatory water restrictions are in effect.

(j) Stationary gas turbines with a heat input at peak load greater than 107.2 gigajoules per hour that commenced construction, modification, or reconstruction between the dates of October 3, 1977, and January 27, 1982, and were required in the September 10, 1979,Federal Register(44 FR 52792) to comply with paragraph (a)(1) of this section, except electric utility stationary gas turbines, are exempt from paragraph (a) of this section.

(k) Stationary gas turbines with a heat input greater than or equal to 10.7 gigajoules per hour (10 million Btu/hour) when fired with natural gas are exempt from paragraph (a)(2) of this section when being fired with an emergency fuel.

(l) Regenerative cycle gas turbines with a heat input less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) are exempt from paragraph (a) of this section.

[44 FR 52798, Sept. 10, 1979, as amended at 47 FR 3770, Jan. 27, 1982; 65 FR 61759, Oct. 17, 2000; 69 FR 41359, July 8, 2004]

§ 60.333 Standard for sulfur dioxide.

On and after the date on which the performance test required to be conducted by §60.8 is completed, every owner or operator subject to the provision of this subpart shall comply with one or the other of the following conditions:

(a) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine any gases which contain sulfur dioxide in excess of 0.015 percent by volume at 15 percent oxygen and on a dry basis.

(b) No owner or operator subject to the provisions of this subpart shall burn in any stationary gas turbine any fuel which contains total sulfur in excess of 0.8 percent by weight (8000 ppmw).

[44 FR 52798, Sept. 10, 1979, as amended at 69 FR 41360, July 8, 2004]

§ 60.334 Monitoring of operations.

(a) Except as provided in paragraph (b) of this section, the owner or operator of any stationary gas turbine subject to the provisions of this subpart and using water or steam injection to control NO_Xemissions shall install, calibrate,

maintain and operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water or steam to fuel being fired in the turbine.

(b) The owner or operator of any stationary gas turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which uses water or steam injection to control NO_Xemissions may, as an alternative to operating the continuous monitoring system described in paragraph (a) of this section, install, certify, maintain, operate, and quality-assure a continuous emission monitoring system (CEMS) consisting of $NO_X$and O_2monitors. As an alternative, a CO_2monitor may be used to adjust the measured NO_Xconcentrations to 15 percent $O_2$by either converting the CO_2hourly averages to equivalent O_2concentrations using Equation F–14a or F–14b in appendix F to part 75 of this chapter and making the adjustments to 15 percent O_2, or by using the CO_2readings directly to make the adjustments, as described in Method 20. If the option to use a CEMS is chosen, the CEMS shall be installed, certified, maintained and operated as follows:

(1) Each CEMS must be installed and certified according to PS 2 and 3 (for diluent) of 40 CFR part 60, appendix B, except the 7-day calibration drift is based on unit operating days, not calendar days. Appendix F, Procedure 1 is not required. The relative accuracy test audit (RATA) of the $NO_X$and diluent monitors may be performed individually or on a combined basis, *i.e.* , the relative accuracy tests of the CEMS may be performed either:

(i) On a ppm basis (for NO_X) and a percent O_2basis for oxygen; or

(ii) On a ppm at 15 percent O_2basis; or

(iii) On a ppm basis (for NO_X) and a percent CO_2basis (for a CO_2monitor that uses the procedures in Method 20 to correct the NO_Xdata to 15 percent O_2).

(2) As specified in §60.13(e)(2), during each full unit operating hour, each monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required to validate the hour.

(3) For purposes of identifying excess emissions, CEMS data must be reduced to hourly averages as specified in §60.13(h).

(i) For each unit operating hour in which a valid hourly average, as described in paragraph (b)(2) of this section, is obtained for both $NO_X$and diluent, the data acquisition and handling system must calculate and record the hourly NO_Xemissions in the units of the applicable NO_Xemission standard under §60.332(a), *i.e.* , percent $NO_X$by volume, dry basis, corrected to 15 percent $O_2$and International Organization for Standardization (ISO) standard conditions (if required as given in §60.335(b)(1)). For any hour in which the hourly average O_2concentration exceeds 19.0 percent O_2, a diluent cap value of 19.0 percent O_2may be used in the emission calculations.

(ii) A worst case ISO correction factor may be calculated and applied using historical ambient data. For the purpose of this calculation, substitute the maximum humidity of ambient air (Ho), minimum ambient temperature (T_a), and minimum combustor inlet absolute pressure (P_o) into the ISO correction equation.

(iii) If the owner or operator has installed a NO_XCEMS to meet the requirements of part 75 of this chapter, and is continuing to meet the ongoing requirements of part 75 of this chapter, the CEMS may be used to meet the requirements of this section, except that the missing data substitution methodology provided for at 40 CFR part 75, subpart D, is not required for purposes of identifying excess emissions. Instead, periods of missing CEMS data are to be reported as monitor downtime in the excess emissions and monitoring performance report required in §60.7(c).

(c) For any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which does not use steam or water injection to control NO_Xemissions, the owner or operator may, but is not required to, for purposes of determining excess emissions, use a CEMS that meets the requirements of paragraph (b) of this section. Also, if the owner or operator has previously submitted and received EPA, State, or local permitting authority approval of a procedure for monitoring compliance with the applicable NO_Xemission limit under §60.332, that approved procedure may continue to be used.

(d) The owner or operator of any new turbine constructed after July 8, 2004, and which uses water or steam injection to control NO_Xemissions may elect to use either the requirements in paragraph (a) of this section for continuous water or steam to fuel ratio monitoring or may use a NO_XCEMS installed, certified, operated, maintained, and quality-assured as described in paragraph (b) of this section.

(e) The owner or operator of any new turbine that commences construction after July 8, 2004, and which does not use water or steam injection to control NO_Xemissions, may, but is not required to, elect to use a NO_XCEMS installed, certified, operated, maintained, and quality-assured as described in paragraph (b) of this section. Other acceptable monitoring approaches include periodic testing approved by EPA or the State or local permitting authority or continuous parameter monitoring as described in paragraph (f) of this section.

(f) The owner or operator of a new turbine that commences construction after July 8, 2004, which does not use water or steam injection to control NO_Xemissions may, but is not required to, perform continuous parameter monitoring as follows:

(1) For a diffusion flame turbine without add-on selective catalytic reduction controls (SCR), the owner or operator shall define at least four parameters indicative of the unit's NO_Xformation characteristics and shall monitor these parameters continuously.

(2) For any lean premix stationary combustion turbine, the owner or operator shall continuously monitor the appropriate parameters to determine whether the unit is operating in low-NO_Xmode.

(3) For any turbine that uses SCR to reduce NO_Xemissions, the owner or operator shall continuously monitor appropriate parameters to verify the proper operation of the emission controls.

(4) For affected units that are also regulated under part 75 of this chapter, if the owner or operator elects to monitor NO_Xemission rate using the methodology in appendix E to part 75 of this chapter, or the low mass emissions methodology in §75.19 of this chapter, the requirements of this paragraph (f) may be met by performing the parametric monitoring described in section 2.3 of appendix E or in §75.19(c)(1)(iv)(H) of this chapter.

(g) The steam or water to fuel ratio or other parameters that are continuously monitored as described in paragraphs (a), (d) or (f) of this section shall be monitored during the performance test required under §60.8, to establish acceptable values and ranges. The owner or operator may supplement the performance test data with engineering analyses, design specifications, manufacturer's recommendations and other relevant information to define the acceptable parametric ranges more precisely. The owner or operator shall develop and keep on-site a parameter monitoring plan which explains the procedures used to document proper operation of the NO_Xemission controls. The plan shall include the parameter(s) monitored and the acceptable range(s) of the parameter(s) as well as the basis for designating the parameter(s) and acceptable range(s). Any supplemental data such as engineering analyses, design specifications, manufacturer's recommendations and other relevant information shall be included in the monitoring plan. For affected units that are also subject to part 75 of this chapter and that use the low mass emissions methodology in §75.19 of this chapter or the NO_Xemission measurement methodology in appendix E to part 75, the owner or operator may meet the requirements of this paragraph by developing and keeping on-site (or at a central location for unmanned facilities) a quality-assurance plan, as described in §75.19 (e)(5) or in section 2.3 of appendix E and section 1.3.6 of appendix B to part 75 of this chapter.

(h) The owner or operator of any stationary gas turbine subject to the provisions of this subpart:

(1) Shall monitor the total sulfur content of the fuel being fired in the turbine, except as provided in paragraph (h)(3) of this section. The sulfur content of the fuel must be determined using total sulfur methods described in §60.335(b)(10). Alternatively, if the total sulfur content of the gaseous fuel during the most recent performance test was less than 0.4 weight percent (4000 ppmw), ASTM D4084–82, 94, D5504–01, D6228–98, or Gas Processors Association Standard 2377–86 (all of which are incorporated by reference-see §60.17), which measure the major sulfur compounds may be used; and

(2) Shall monitor the nitrogen content of the fuel combusted in the turbine, if the owner or operator claims an allowance for fuel bound nitrogen (*i.e.* , if an F-value greater than zero is being or will be used by the owner or operator to calculate STD in §60.332). The nitrogen content of the fuel shall be determined using methods described in §60.335(b)(9) or an approved alternative.

(3) Notwithstanding the provisions of paragraph (h)(1) of this section, the owner or operator may elect not to monitor the total sulfur content of the gaseous fuel combusted in the turbine, if the gaseous fuel is demonstrated to meet the definition of natural gas in §60.331(u), regardless of whether an existing custom schedule approved by the administrator for subpart GG requires such monitoring. The owner or operator shall use one of the following sources of information to make the required demonstration:

(i) The gas quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less; or

(ii) Representative fuel sampling data which show that the sulfur content of the gaseous fuel does not exceed 20 grains/100 scf. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of appendix D to part 75 of this chapter is required.

(4) For any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and for which a custom fuel monitoring schedule has previously been approved, the owner or operator may, without submitting a special petition to the Administrator, continue monitoring on this schedule.

(i) The frequency of determining the sulfur and nitrogen content of the fuel shall be as follows:

(1) *Fuel oil.* For fuel oil, use one of the total sulfur sampling options and the associated sampling frequency described in sections 2.2.3, 2.2.4.1, 2.2.4.2, and 2.2.4.3 of appendix D to part 75 of this chapter (*i.e.* , flow proportional sampling, daily sampling, sampling from the unit's storage tank after each addition of fuel to the tank, or sampling each delivery prior to combining it with fuel oil already in the intended storage tank). If an emission allowance is being claimed for fuel-bound nitrogen, the nitrogen content of the oil shall be determined and recorded once per unit operating day.

(2) *Gaseous fuel.* Any applicable nitrogen content value of the gaseous fuel shall be determined and recorded once per unit operating day. For owners and operators that elect not to demonstrate sulfur content using options in paragraph (h)(3) of this section, and for which the fuel is supplied without intermediate bulk storage, the sulfur content value of the gaseous fuel shall be determined and recorded once per unit operating day.

(3) *Custom schedules.* Notwithstanding the requirements of paragraph (i)(2) of this section, operators or fuel vendors may develop custom schedules for determination of the total sulfur content of gaseous fuels, based on the design and operation of the affected facility and the characteristics of the fuel supply. Except as provided in paragraphs (i)(3)(i) and (i)(3)(ii) of this section, custom schedules shall be substantiated with data and shall be approved by the Administrator before they can be used to comply with the standard in §60.333.

(i) The two custom sulfur monitoring schedules set forth in paragraphs (i)(3)(i)(A) through (D) and in paragraph (i)(3)(ii) of this section are acceptable, without prior Administrative approval:

(A) The owner or operator shall obtain daily total sulfur content measurements for 30 consecutive unit operating days, using the applicable methods specified in this subpart. Based on the results of the 30 daily samples, the required frequency for subsequent monitoring of the fuel's total sulfur content shall be as specified in paragraph (i)(3)(i)(B), (C), or (D) of this section, as applicable.

(B) If none of the 30 daily measurements of the fuel's total sulfur content exceeds 0.4 weight percent (4000 ppmw), subsequent sulfur content monitoring may be performed at 12 month intervals. If any of the samples taken at 12-month intervals has a total sulfur content between 0.4 and 0.8 weight percent (4000 and 8000 ppmw), follow the procedures in paragraph (i)(3)(i)(C) of this section. If any measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section.

(C) If at least one of the 30 daily measurements of the fuel's total sulfur content is between 0.4 and 0.8 weight percent (4000 and 8000 ppmw), but none exceeds 0.8 weight percent (8000 ppmw), then:

(*1*) Collect and analyze a sample every 30 days for three months. If any sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section. Otherwise, follow the procedures in paragraph (i)(3)(i)(C)(*2*) of this section.

(*2*) Begin monitoring at 6-month intervals for 12 months. If any sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section. Otherwise, follow the procedures in paragraph (i)(3)(i)(C)(*3*) of this section.

(*3*) Begin monitoring at 12-month intervals. If any sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section. Otherwise, continue to monitor at this frequency.

(D) If a sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), immediately begin daily monitoring according to paragraph (i)(3)(i)(A) of this section. Daily monitoring shall continue until 30 consecutive daily samples, each having a sulfur content no greater than 0.8 weight percent (8000 ppmw), are obtained. At that point, the applicable procedures of paragraph (i)(3)(i)(B) or (C) of this section shall be followed.

(ii) The owner or operator may use the data collected from the 720-hour sulfur sampling demonstration described in section 2.3.6 of appendix D to part 75 of this chapter to determine a custom sulfur sampling schedule, as follows:

(A) If the maximum fuel sulfur content obtained from the 720 hourly samples does not exceed 20 grains/100 scf (*i.e.* , the maximum total sulfur content of natural gas as defined in §60.331(u)), no additional monitoring of the sulfur content of the gas is required, for the purposes of this subpart.

(B) If the maximum fuel sulfur content obtained from any of the 720 hourly samples exceeds 20 grains/100 scf, but none of the sulfur content values (when converted to weight percent sulfur) exceeds 0.4 weight percent (4000 ppmw), then the minimum required sampling frequency shall be one sample at 12 month intervals.

(C) If any sample result exceeds 0.4 weight percent sulfur (4000 ppmw), but none exceeds 0.8 weight percent sulfur (8000 ppmw), follow the provisions of paragraph (i)(3)(i)(C) of this section.

(D) If the sulfur content of any of the 720 hourly samples exceeds 0.8 weight percent (8000 ppmw), follow the provisions of paragraph (i)(3)(i)(D) of this section.

(j) For each affected unit that elects to continuously monitor parameters or emissions, or to periodically determine the fuel sulfur content or fuel nitrogen content under this subpart, the owner or operator shall submit reports of excess emissions and monitor downtime, in accordance with §60.7(c). Excess emissions shall be reported for all periods of unit operation, including startup, shutdown and malfunction. For the purpose of reports required under §60.7(c), periods of excess emissions and monitor downtime that shall be reported are defined as follows:

(1) Nitrogen oxides.

(i) For turbines using water or steam to fuel ratio monitoring:

(A) An excess emission shall be any unit operating hour for which the average steam or water to fuel ratio, as measured by the continuous monitoring system, falls below the acceptable steam or water to fuel ratio needed to demonstrate compliance with §60.332, as established during the performance test required in §60.8. Any unit operating hour in which no water or steam is injected into the turbine shall also be considered an excess emission.

(B) A period of monitor downtime shall be any unit operating hour in which water or steam is injected into the turbine, but the essential parametric data needed to determine the steam or water to fuel ratio are unavailable or invalid.

(C) Each report shall include the average steam or water to fuel ratio, average fuel consumption, ambient conditions (temperature, pressure, and humidity), gas turbine load, and (if applicable) the nitrogen content of the fuel during each excess emission. You do not have to report ambient conditions if you opt to use the worst case ISO correction factor as specified in §60.334(b)(3)(ii), or if you are not using the ISO correction equation under the provisions of §60.335(b)(1).

(ii) If the owner or operator elects to take an emission allowance for fuel bound nitrogen, then excess emissions and periods of monitor downtime are as described in paragraphs (j)(1)(ii)(A) and (B) of this section.

(A) An excess emission shall be the period of time during which the fuel-bound nitrogen (N) is greater than the value measured during the performance test required in §60.8 and used to determine the allowance. The excess emission begins on the date and hour of the sample which shows that N is greater than the performance test value, and ends with the date and hour of a subsequent sample which shows a fuel nitrogen content less than or equal to the performance test value.

(B) A period of monitor downtime begins when a required sample is not taken by its due date. A period of monitor downtime also begins on the date and hour that a required sample is taken, if invalid results are obtained. The period of monitor downtime ends on the date and hour of the next valid sample.

(iii) For turbines using $NO_X$and diluent CEMS:

(A) An hour of excess emissions shall be any unit operating hour in which the 4-hour rolling average NO_Xconcentration exceeds the applicable emission limit in §60.332(a)(1) or (2). For the purposes of this subpart, a “4-hour rolling average NO_Xconcentration” is the arithmetic average of the average NO_Xconcentration measured by the CEMS for a given hour (corrected to 15 percent $O_2$and, if required under §60.335(b)(1), to ISO standard conditions) and the three unit operating hour average NO_Xconcentrations immediately preceding that unit operating hour.

(B) A period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour, for either NO_Xconcentration or diluent (or both).

(C) Each report shall include the ambient conditions (temperature, pressure, and humidity) at the time of the excess emission period and (if the owner or operator has claimed an emission allowance for fuel bound nitrogen) the nitrogen content of the fuel during the period of excess emissions. You do not have to report ambient conditions if you opt to use the worst case ISO correction factor as specified in §60.334(b)(3)(ii), or if you are not using the ISO correction equation under the provisions of §60.335(b)(1).

(iv) For owners or operators that elect, under paragraph (f) of this section, to monitor combustion parameters or parameters that document proper operation of the NO_Xemission controls:

(A) An excess emission shall be a 4-hour rolling unit operating hour average in which any monitored parameter does not achieve the target value or is outside the acceptable range defined in the parameter monitoring plan for the unit.

(B) A period of monitor downtime shall be a unit operating hour in which any of the required parametric data are either not recorded or are invalid.

(2) Sulfur dioxide. If the owner or operator is required to monitor the sulfur content of the fuel under paragraph (h) of this section:

(i) For samples of gaseous fuel and for oil samples obtained using daily sampling, flow proportional sampling, or sampling from the unit's storage tank, an excess emission occurs each unit operating hour included in the period beginning on the date and hour of any sample for which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8 weight percent and ending on the date and hour that a subsequent sample is taken that demonstrates compliance with the sulfur limit.

(ii) If the option to sample each delivery of fuel oil has been selected, the owner or operator shall immediately switch to one of the other oil sampling options (*i.e.* , daily sampling, flow proportional sampling, or sampling from the unit's storage tank) if the sulfur content of a delivery exceeds 0.8 weight percent. The owner or operator shall continue to use one of the other sampling options until all of the oil from the delivery has been combusted, and shall evaluate excess emissions according to paragraph (j)(2)(i) of this section. When all of the fuel from the delivery has been burned, the owner or operator may resume using the as-delivered sampling option.

(iii) A period of monitor downtime begins when a required sample is not taken by its due date. A period of monitor downtime also begins on the date and hour of a required sample, if invalid results are obtained. The period of monitor downtime shall include only unit operating hours, and ends on the date and hour of the next valid sample.

(3) *Ice fog.* Each period during which an exemption provided in §60.332(f) is in effect shall be reported in writing to the Administrator quarterly. For each period the ambient conditions existing during the period, the date and time the air pollution control system was deactivated, and the date and time the air pollution control system was reactivated shall be reported. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter.

(4) *Emergency fuel.* Each period during which an exemption provided in §60.332(k) is in effect shall be included in the report required in §60.7(c). For each period, the type, reasons, and duration of the firing of the emergency fuel shall be reported.

(5) All reports required under §60.7(c) shall be postmarked by the 30th day following the end of each 6-month period.

[44 FR 52798, Sept. 10, 1979, as amended at 47 FR 3770, Jan. 27, 1982; 65 FR 61759, Oct. 17, 2000; 69 FR 41360, July 8, 2004; 71 FR 9457, Feb. 24, 2006]

§ 60.335 Test methods and procedures.

(a) The owner or operator shall conduct the performance tests required in §60.8, using either

(1) EPA Method 20,

(2) ASTM D6522–00 (incorporated by reference, see §60.17), or

(3) EPA Method 7E and either EPA Method 3 or 3A in appendix A to this part, to determine $NO_X$and diluent concentration.

(4) Sampling traverse points are to be selected following Method 20 or Method 1, (non-particulate procedures) and sampled for equal time intervals. The sampling shall be performed with a traversing single-hole probe or, if feasible, with a stationary multi-hole probe that samples each of the points sequentially. Alternatively, a multi-hole probe designed and documented to sample equal volumes from each hole may be used to sample simultaneously at the required points.

(5) Notwithstanding paragraph (a)(4) of this section, the owner or operator may test at few points than are specified in Method 1 or Method 20 if the following conditions are met:

(i) You may perform a stratification test for $NO_X$and diluent pursuant to

(A) [Reserved]

(B) The procedures specified in section 6.5.6.1(a) through (e) appendix A to part 75 of this chapter.

(ii) Once the stratification sampling is completed, the owner or operator may use the following alternative sample point selection criteria for the performance test:

(A) If each of the individual traverse point NO_Xconcentrations, normalized to 15 percent O_2, is within ±10 percent of the mean normalized concentration for all traverse points, then you may use 3 points (located either 16.7, 50.0, and 83.3 percent of the way across the stack or duct, or, for circular stacks or ducts greater than 2.4 meters (7.8 feet) in diameter, at 0.4, 1.2, and 2.0 meters from the wall). The 3 points shall be located along the measurement line that exhibited the highest average normalized NO_Xconcentration during the stratification test; or

(B) If each of the individual traverse point NO_Xconcentrations, normalized to 15 percent O_2, is within ±5 percent of the mean normalized concentration for all traverse points, then you may sample at a single point, located at least 1 meter from the stack wall or at the stack centroid.

(6) Other acceptable alternative reference methods and procedures are given in paragraph (c) of this section.

(b) The owner or operator shall determine compliance with the applicable nitrogen oxides emission limitation in §60.332 and shall meet the performance test requirements of §60.8 as follows:

(1) For each run of the performance test, the mean nitrogen oxides emission concentration (NO_{Xo}) corrected to 15 percent O_2shall be corrected to ISO standard conditions using the following equation. Notwithstanding this requirement, use of the ISO correction equation is optional for: Lean premix stationary combustion turbines; units used in association with heat recovery steam generators (HRSG) equipped with duct burners; and units equipped with add-on emission control devices:

$$NO_X=(NO_{Xo})(P_r/P_o)^{0.5}\ e19\ (Ho-0.00633)(288°K/T_a)^{1.53}$$

Where:

NO_X= emission concentration of NO_Xat 15 percent $O_2$and ISO standard ambient conditions, ppm by volume, dry basis,

NO_{Xo}= mean observed NO_Xconcentration, ppm by volume, dry basis, at 15 percent O_2,

P_r= reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg,

P_o= observed combustor inlet absolute pressure at test, mm Hg,

H_o= observed humidity of ambient air, g H_2O/g air,

e = transcendental constant, 2.718, and

T_a= ambient temperature, °K.

(2) The 3-run performance test required by §60.8 must be performed within ±5 percent at 30, 50, 75, and 90-to-100 percent of peak load or at four evenly-spaced load points in the normal operating range of the gas turbine, including the minimum point in the operating range and 90-to-100 percent of peak load, or at the highest achievable load point if 90-to-100 percent of peak load cannot be physically achieved in practice. If the turbine combusts both oil and gas

as primary or backup fuels, separate performance testing is required for each fuel. Notwithstanding these requirements, performance testing is not required for any emergency fuel (as defined in §60.331).

(3) For a combined cycle turbine system with supplemental heat (duct burner), the owner or operator may elect to measure the turbine NO_Xemissions after the duct burner rather than directly after the turbine. If the owner or operator elects to use this alternative sampling location, the applicable NO_Xemission limit in §60.332 for the combustion turbine must still be met.

(4) If water or steam injection is used to control $NO_X$with no additional post-combustion NO_Xcontrol and the owner or operator chooses to monitor the steam or water to fuel ratio in accordance with §60.334(a), then that monitoring system must be operated concurrently with each EPA Method 20, ASTM D6522–00 (incorporated by reference, see §60.17), or EPA Method 7E run and shall be used to determine the fuel consumption and the steam or water to fuel ratio necessary to comply with the applicable §60.332 NO_Xemission limit.

(5) If the owner operator elects to claim an emission allowance for fuel bound nitrogen as described in §60.332, then concurrently with each reference method run, a representative sample of the fuel used shall be collected and analyzed, following the applicable procedures described in §60.335(b)(9). These data shall be used to determine the maximum fuel nitrogen content for which the established water (or steam) to fuel ratio will be valid.

(6) If the owner or operator elects to install a CEMS, the performance evaluation of the CEMS may either be conducted separately (as described in paragraph (b)(7) of this section) or as part of the initial performance test of the affected unit.

(7) If the owner or operator elects to install and certify a NO_XCEMS under §60.334(e), then the initial performance test required under §60.8 may be done in the following alternative manner:

(i) Perform a minimum of 9 reference method runs, with a minimum time per run of 21 minutes, at a single load level, between 90 and 100 percent of peak (or the highest physically achievable) load.

(ii) Use the test data both to demonstrate compliance with the applicable NO_Xemission limit under §60.332 and to provide the required reference method data for the RATA of the CEMS described under §60.334(b).

(iii) The requirement to test at three additional load levels is waived.

(8) If the owner or operator elects under §60.334(f) to monitor combustion parameters or parameters indicative of proper operation of NO_Xemission controls, the appropriate parameters shall be continuously monitored and recorded during each run of the initial performance test, to establish acceptable operating ranges, for purposes of the parameter monitoring plan for the affected unit, as specified in §60.334(g).

(9) To determine the fuel bound nitrogen content of fuel being fired (if an emission allowance is claimed for fuel bound nitrogen), the owner or operator may use equipment and procedures meeting the requirements of:

(i) For liquid fuels, ASTM D2597–94 (Reapproved 1999), D6366–99, D4629–02, D5762–02 (all of which are incorporated by reference, *see* §60.17); or

(ii) For gaseous fuels, shall use analytical methods and procedures that are accurate to within 5 percent of the instrument range and are approved by the Administrator.

(10) If the owner or operator is required under §60.334(i)(1) or (3) to periodically determine the sulfur content of the fuel combusted in the turbine, a minimum of three fuel samples shall be collected during the performance test. Analyze the samples for the total sulfur content of the fuel using:

(i) For liquid fuels, ASTM D129–00, D2622–98, D4294–02, D1266–98, D5453–00 or D1552–01 (all of which are incorporated by reference, *see* §60.17); or

(ii) For gaseous fuels, ASTM D1072–80, 90 (Reapproved 1994); D3246–81, 92, 96; D4468–85 (Reapproved 2000); or D6667–01 (all of which are incorporated by reference, see §60.17). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the prior approval of the Administrator.

(11) The fuel analyses required under paragraphs (b)(9) and (b)(10) of this section may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency.

(c) The owner or operator may use the following as alternatives to the reference methods and procedures specified in this section:

(1) Instead of using the equation in paragraph (b)(1) of this section, manufacturers may develop ambient condition correction factors to adjust the nitrogen oxides emission level measured by the performance test as provided in §60.8 to ISO standard day conditions.

Indiana Department of Environmental Management
Office of Air Quality

Appendix A – Emission Calculations
Technical Support Document (TSD)
Administrative Amendment of a Part 70 Source

Source Description and Location

Company Name:	Duke Energy Indiana Inc.-Noblesville Generating Station
Address City IN Zip:	21225 Riverwood Avenue, Noblesville, Indiana 46060
County:	Hamilton
SIC Code:	4911
Part 70 Operating Permit Renewal No.:	T057-26751-00004
Issuance Date:	January 30, 2009
Administrative Amendment No.:	057-30105-00004
Permit Reviewer:	Kimberly Cottrell
Date:	February 18, 2011

Summary of Potential to Emit

	Current Uncontrolled Potential To Emit (ton/yr)								
Process / Emission Unit	**CO**	**NO_X**	**PM**	**PM_{10}**	**$PM_{2.5}$**	**SO_2**	**VOC**	**Hexane**	**Total HAP**
Heating Boiler - fuel oil	0.22	0.87	0.09	0.09	0.09	3.09	0.01	0	2.13E-06

	New Uncontrolled Potential To Emit (ton/yr)								
Process / Emission Unit	**CO**	**NO_X**	**PM**	**PM_{10}**	**$PM_{2.5}$**	**SO_2**	**VOC**	**Hexane**	**Total HAP**
Heating Boiler - natural Gas	3.65	4.35	0.08	0.33	0.33	0.03	0.24	0.08	0.08

	Increase in Potential To Emit (ton/yr)								
Process / Emission Unit	**CO**	**NO_X**	**PM**	**PM_{10}**	**$PM_{2.5}$**	**SO_2**	**VOC**	**Single HAP**	**Combination HAPs**
Heating Boiler	3.43	3.48	0.00	0.24	0.24	(3.06)	0.22	0.08	0.08

#2 Fuel Oil Combustion <100 MMBtu/hr

Emission Unit	Heat Input Capacity	Potential Throughput	Installation Date
Heating Boiler - fuel oil	9.923 MMBtu/hr	620.90 kgal/yr	1990

S = Weight % Sulfur: 0.5

	Potential To Emit - Criteria Pollutants						
	CO	NO_X	PM	PM_{10}	$PM_{2.5}$	SO_2	VOC
Emission Factor (lb/kgal)	5.0	20.0	2.0	2.0	2.0	71.0 142 S	0.3
Uncontrolled Potential To Emit (ton/yr)	0.22	0.87	0.09	0.09	0.09	3.09	0.01

	Potential To Emit - Hazardous Air Pollutants								
	HAPs - Organics					HAPs - Metals			
	Arsenic	Beryllium	Cadmium	Chromium	Lead	Mercury	Manganese	Nickel	Selenium
Emission Factor (lb/kgal)	4.0E-06	3.0E-06	3.0E-06	3.0E-06	9.0E-06	3.0E-06	6.0E-06	3.0E-06	1.5E-05
Uncontrolled Potential To Emit (ton/yr)	1.74E-07	1.30E-07	1.30E-07	1.30E-07	3.91E-07	1.30E-07	2.61E-07	1.30E-07	6.52E-07

Methodology

1 gallon of No. 2 Fuel Oil has a heating value of 140,000 Btu
Potential Throughput (kgals/year) = Heat Input Capacity (MMBtu/hr) x 8,760 hrs/yr x 1kgal per 1000 gallon x 1 gal per 0.140 MM Btu
Emission Factors are from AP 42, Tables 1.3-1, 1.3-2, and 1.3-3 (SCC 1-03-005-01/02/03) Supplement E 9/98 (see erata file)
*PM emission factor is filterable PM only. Condensable PM emission factor is 1.3 lb/kgal.
Emission (tons/yr) = Throughput (kgals/ yr) x Emission Factor (lb/kgal)/2,000 lb/ton
No data was available in AP-42 for organic HAPs.
Potential Emissions (tons/year) = Throughput (mmBtu/hr)*Emission Factor (lb/mmBtu)*8,760 hrs/yr / 2,000 lb/ton

Natural Gas Combustion <100 MMBtu/hr

Emission Unit	Heat Input Capacity	Potential Throughput	Installation Date
Heating Boiler - natural Gas	9.923 MMBtu/hr	86.93 MMCF/yr	1990

	Potential To Emit - Criteria Pollutants						
	CO	NO_X	PM	PM_{10}	$PM_{2.5}$	SO_2	VOC
Emission Factor (lb/MMCF)	84	100	1.9	7.6	7.6	0.6	5.5
Uncontrolled Potential To Emit (ton/yr)	3.65	4.35	0.08	0.33	0.33	0.03	0.24

*PM emission factor is filterable PM only. PM_{10} emission factor is filterable and condensable PM_{10} combined.

**Emission Factors for NO_X: Uncontrolled = 100, Low NO_X Burner = 50, Low NO_X Burners/Flue gas recirculation = 32

	Potential To Emit - Hazardous Air Pollutants										
	HAPs - Organics					HAPs - Metals					
	Benzene	Dichloro-benzene	Formal-dehyde	Hexane	Toluene	Lead	Cadmium	Chromium	Manganese	Nickel	Total HAPs
Emission Factor (lb/MMCF)	2.1E-03	1.2E-03	7.5E-02	1.8	3.4E-03	5.0E-04	1.1E-03	1.4E-03	3.8E-04	2.1E-03	
Uncontrolled Potential To Emit (ton/yr)	9.1E-05	5.2E-05	3.3E-03	0.08	1.5E-04	2.2E-05	4.8E-05	6.1E-05	1.7E-05	9.1E-05	0.08

The five highest organic and metal HAPs emission factors are provided above.
Additional HAPs emission factors are available in AP-42, Chapter 1.4.

Methodology
All emission factors are based on normal firing.
MMBtu = 1,000,000 Btu
MMCF = 1,000,000 Cubic Feet of Gas
Potential Throughput (MMCF) = Heat Input Capacity (MMBtu/hr) x 8,760 hrs/yr x 1 MMCF/1,000 MMBtu
Emission Factors are from AP 42, Chapter 1.4, Tables 1.4-1, 1.4-2, 1.4-3, SCC #1-02-006-02, 1-01-006-02, 1-03-006-02, and 1-03-006-03 (SUPPLEMENT D 3/98)
Emission (tons/yr) = Throughput (MMCF/yr) x Emission Factor (lb/MMCF)/2,000 lb/ton

326 IAC 6-2 Evaluation

Boilers	Installation Date	Rating (MMBtu/hr)	Q (MMBtu/hr)	Pt (lb/MMBtu) (if Q <10)	Applicable Rule
Heating Boiler	1990	9.923	9.923	0.6	328 IAC 6-2-4

[326 IAC 6-2-4]

$$Pt = \frac{1.09}{Q^{0.26}}$$

Where: Pt = Pounds of particulate matter emitted per million Btu heat input
Q = Total source maximum operating capacity rating in million Btu

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

TO: Interested Parties / Applicant

DATE: February 23, 2011

RE: Duke Energy Indiana, Inc. – Noblesville Generating Station / 057-30105-00004

FROM: Matthew Stuckey, Branch Chief
Permits Branch
Office of Air Quality

In order to conserve paper and reduce postage costs, IDEM's Office of Air Quality is now sending many permit decisions on CDs in Adobe PDF format. The enclosed CD contains information regarding the company named above.

This permit is also available on the IDEM website at:
http://www.in.gov/ai/appfiles/idem-caats/

If you would like to request a paper copy of the permit document, please contact IDEM's central file room at:

Indiana Government Center North, Room 1201
100 North Senate Avenue, MC 50-07
Indianapolis, IN 46204
Phone: 1-800-451-6027 (ext. 4-0965)
Fax (317) 232-8659

Please Note: *If you feel you have received this information in error, or would like to be removed from the Air Permits mailing list, please contact Patricia Pear with the Air Permits Administration Section at 1-800-451-6027, ext. 3-6875 or via e-mail at PPEAR@IDEM.IN.GOV.*

Enclosures
CD Memo.dot 11/14/08

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

SENT VIA U.S. MAIL: CONFIRMED DELIVERY AND SIGNATURE REQUESTED

TO: Patrick Coughlin
Duke Energy Indiana, Inc. – Noblesville Generating Station
1000 E. Main Street
Plainfield, IN 46168

DATE: February 23, 2011

FROM: Matt Stuckey, Branch Chief
Permits Branch
Office of Air Quality

SUBJECT: Final Decision
Administrative Amendment
057-30105-00004

Enclosed is the final decision and supporting materials for the air permit application referenced above. Please note that this packet contains the original, signed, permit documents.

The final decision is being sent to you because our records indicate that you are the contact person for this application. However, if you are not the appropriate person within your company to receive this document, please forward it to the correct person.

A copy of the final decision and supporting materials has also been sent via standard mail to:
Thomas D. Short – Station Manager
Mark Sims – Duke Energy
OAQ Permits Branch Interested Parties List

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178, or toll-free at 1-800-451-6027 (ext. 3-0178), and ask to speak to the permit reviewer who prepared the permit. If you think you have received this document in error, please contact Joanne Smiddie-Brush of my staff at 1-800-451-6027 (ext 3-0185), or via e-mail at jbrush@idem.IN.gov.

Final Applicant Cover letter.dot 11/30/07

Mail Code 61-53

IDEM Staff	GHOTOPP 2/23/2011 Duke Energy Indiana, Inc. - Noblesville Generating Station 057-30105-00004 Final			AFFIX STAMP HERE IF USED AS CERTIFICATE OF MAILING
Name and address of Sender	▶	Indiana Department of Environmental Management Office of Air Quality – Permits Branch 100 N. Senate Indianapolis, IN 46204	Type of Mail: **CERTIFICATE OF MAILING ONLY**	

Line	Article Number	Name, Address, Street and Post Office Address	Postage	Handing Charges	Act. Value (If Registered)	Insured Value	Due Send if COD	R.R. Fee	S.D. Fee	S.H. Fee	Rest. Del. Fee Remarks
1		Patrick Coughlin Duke Energy Indiana, Inc. - Noblesville Generating 1000 E Main St Plainfield IN 46168 (Source CAATS) via confirmed delivery									
2		Thomas D. Short Stn Mgr of Noblesville Duke Energy Indiana, Inc. - Noblesville Generating 1000 E Main St Plainfield IN 46168 *(RO CAATS)*									
3		Mr. Wendell Hibdon Plumbers & Steam Fitters Union, Local 136 2300 St. Joe Industrial Park Dr Evansville IN 47720 *(Affected Party)*									
4		Darrell Cluesman RR 2, Box 252 A, SR 59 Jasonville IN 47438 *(Affected Party)*									
5		Stuart Douglas & Nelanie Kelly 11679 216th Street East Noblesville IN 46060 *(Affected Party)*									
6		Noblesville City Council and Mayors Office 16 S. 10th St. Noblesville IN 46060 *(Local Official)*									
7		Hayfield Partners 21593 Cumberland Rd Noblesville IN 46060 *(Affected Party)*									
8		Roy & Bonnie Kerby 4775 E 236th St Cicero IN 46034 *(Affected Party)*									
9		Edward & Patricia Prater 21911 Riverwood Ave Noblesville IN 46060 *(Affected Party)*									
10		Mr. Windford Bledsoe 22020 Riverwood Ave Noblesville IN 46060 *(Affected Party)*									
11		W.A. Teter Family Retreat Foundation, Inc 2051 Monument St Noblesville IN 46060 *(Affected Party)*									
12		Jimmy & Catherine Tittle 21008 Riverwood Ave Noblesville IN 46062 *(Affected Party)*									
13		John A. & Virginia I. Grasowski 21788 Riverwood Ave. Noblesville IN 46060 (Affected Party)									
14		Robert & Gwendolyn A. Owens 21760 Riverwood Ave. Noblesville IN 46062 *(Affected Party)*									
15		Tom & Jenny Thomas 10550 East 211th Street Noblesville IN 46060 *(Affected Party)*									

Total number of pieces Listed by Sender	Total number of Pieces Received at Post Office	Postmaster, Per (Name of Receiving employee)	The full declaration of value is required on all domestic and international registered mail. The maximum indemnity payable for the reconstruction of nonnegotiable documents under Express Mail document reconstructing insurance is $50,000 per piece subject to a limit of $50, 000 per occurrence. The maximum indemnity payable on Express mil merchandise insurance is $500. The maximum indemnity payable is $25,000 for registered mail, sent with optional postal insurance. See ***Domestic Mail Manual*** **R900, S913**, and **S921** for limitations of coverage on inured and COD mail. See ***International Mail Manual*** for limitations o coverage on international mail. Special handling charges apply only to Standard Mail (A) and Standard Mail (B) parcels.
14			

FACSIMILIE OF PS Form 3877

Mail Code 61-53

IDEM Staff	GHOTOPP 2/23/2011 Duke Energy Indiana, Inc. - Noblesville Generating Station 057-30105-00004 Final			AFFIX STAMP HERE IF USED AS CERTIFICATE OF MAILING
Name and address of Sender	▶	Indiana Department of Environmental Management Office of Air Quality – Permits Branch 100 N. Senate Indianapolis, IN 46204	Type of Mail: **CERTIFICATE OF MAILING ONLY**	

Line	Article Number	Name, Address, Street and Post Office Address	Postage	Handing Charges	Act. Value (If Registered)	Insured Value	Due Send if COD	R.R. Fee	S.D. Fee	S.H. Fee	Rest. Del. Fee Remarks
1		Timothy J. & Arlene Nethrey 20999 Riverwood Ave. Noblesville IN 46062 (Affected Party)									
2		Thomas Lee & Fennis Bledsoe Thomas 10550 E. 211th Street Noblesville IN 46060 *(Affected Party)*									
3		William Michael Muench 10521 E. 211th Street Noblesville IN 46060 *(Affected Party)*									
4		Forest Havey Wooten & Mary Imugene 10615 E. 211th Street Noblesville IN 46060 *(Affected Party)*									
5		Harold E. & Vera J. Peters 271 Miami Drive Noblesville IN 46060 *(Affected Party)*									
6		Jack A. & Elen L. Zook 21440 Riverwood Ave. Noblesville IN 46060 *(Affected Party)*									
7		Martin C & Shirley A. Castor 21450 Riverwood Ave. Noblesville IN 46060 *(Affected Party)*									
8		Gregory A. & Janet S. Estepp 42 Miami Drive Noblesville IN 46060 *(Affected Party)*									
9		Robert E. & Barbara K. Davis 45 Miami Drive Noblesville IN 46060 *(Affected Party)*									
10		R.H. & Patricia A. Gardner 52 Miami Drive Noblesville IN 46060 *(Affected Party)*									
11		Samuel J. & Maxine Beaver 333 Riverwood Drive Noblesville IN 46060 *(Affected Party)*									
12		Lisa B. Grisell One Miami Drive Noblesville IN 46060 *(Affected Party)*									
13		Charles L. & Mary Owens 59 Miami Drive Noblesville IN 46060 (Affected Party)									
14		Ms. Debbie Brown 21599 Overdorf Rd Noblesville IN 46060 *(Affected Party)*									
15		Mr. Ed Southard 10315 E 206th St Noblesville IN 46060 *(Affected Party)*									

Total number of pieces Listed by Sender	Total number of Pieces Received at Post Office	Postmaster, Per (Name of Receiving employee)	The full declaration of value is required on all domestic and international registered mail. The maximum indemnity payable for the reconstruction of nonnegotiable documents under Express Mail document reconstructing insurance is $50,000 per piece subject to a limit of $50, 000 per occurrence. The maximum indemnity payable on Express mil merchandise insurance is $500. The maximum indemnity payable is $25,000 for registered mail, sent with optional postal insurance. See ***Domestic Mail Manual*** **R900, S913**, and **S921** for limitations of coverage on inured and COD mail. See ***International Mail Manual*** for limitations o coverage on international mail. Special handling charges apply only to Standard Mail (A) and Standard Mail (B) parcels.
15			

FACSIMILIE OF PS Form 3877

Mail Code 61-53

IDEM Staff	GHOTOPP 2/23/2011 Duke Energy Indiana, Inc. - Noblesville Generating Station 057-30105-00004 Final			AFFIX STAMP HERE IF USED AS CERTIFICATE OF MAILING
Name and address of Sender	▶	Indiana Department of Environmental Management Office of Air Quality – Permits Branch 100 N. Senate Indianapolis, IN 46204	Type of Mail: **CERTIFICATE OF MAILING ONLY**	

Line	Article Number	Name, Address, Street and Post Office Address	Postage	Handing Charges	Act. Value (If Registered)	Insured Value	Due Send if COD	R.R. Fee	S.D. Fee	S.H. Fee	Rest. Del. Fee Remarks
1		Hamilton County Health Department 18030 Foundation Dr. #A Noblesville IN 46060-5405 (Health Department)									
2		Indiana State Senate Indiana State Senate 200 W. Washington St Indianapolis IN 46204-2728 *(Legislator)*									
3		Hamilton County Board of Commissioners One Hamilton County Square Noblesville IN 46064 *(Local Official)*									
4		Tim Voss 60 Miami Drive Noblesville IN 46060 *(Affected Party)*									
5		Mack Sims Duke Energy Indiana - Edwardsport 1000 E Main Street Plainfield IN 46168 *(Source ¿ addl contact)*									
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											

Total number of pieces Listed by Sender	Total number of Pieces Received at Post Office	Postmaster, Per (Name of Receiving employee)	The full declaration of value is required on all domestic and international registered mail. The maximum indemnity payable for the reconstruction of nonnegotiable documents under Express Mail document reconstructing insurance is $50,000 per piece subject to a limit of $50, 000 per occurrence. The maximum indemnity payable on Express mil merchandise insurance is $500. The maximum indemnity payable is $25,000 for registered mail, sent with optional postal insurance. See ***Domestic Mail Manual*** **R900, S913**, and **S921** for limitations of coverage on inured and COD mail. See ***International Mail Manual*** for limitations o coverage on international mail. Special handling charges apply only to Standard Mail (A) and Standard Mail (B) parcels.
5			

FACSIMILIE OF PS Form 3877