



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

TO: Interested Parties / Applicant

DATE: April 26, 2011

RE: NIPSCO – Bailly Generating Station / 127-30163-00002

FROM: Matthew Stuckey, Branch Chief
Permits Branch
Office of Air Quality

Notice of Decision: Approval – Effective Immediately

Please be advised that on behalf of the Commissioner of the Department of Environmental Management, I have issued a decision regarding the enclosed matter. Pursuant to IC 13-17-3-4 and 326 IAC 2, this permit modification is effective immediately, unless a petition for stay of effectiveness is filed and granted, and may be revoked or modified in accordance with the provisions of IC 13-15-7-1.

If you wish to challenge this decision, IC 4-21.5-3-7 and IC 13-15-7-3 require that you file a petition for administrative review. This petition may include a request for stay of effectiveness and must be submitted to the Office Environmental Adjudication, 100 North Senate Avenue, Government Center North, Suite N 501E, Indianapolis, IN 46204, **within eighteen (18) days of the mailing of this notice**. The filing of a petition for administrative review is complete on the earliest of the following dates that apply to the filing:

- (1) the date the document is delivered to the Office of Environmental Adjudication (OEA);
- (2) the date of the postmark on the envelope containing the document, if the document is mailed to OEA by U.S. mail; or
- (3) The date on which the document is deposited with a private carrier, as shown by receipt issued by the carrier, if the document is sent to the OEA by private carrier.

The petition must include facts demonstrating that you are either the applicant, a person aggrieved or adversely affected by the decision or otherwise entitled to review by law. Please identify the permit, decision, or other order for which you seek review by permit number, name of the applicant, location, date of this notice and all of the following:

- (1) the name and address of the person making the request;
- (2) the interest of the person making the request;
- (3) identification of any persons represented by the person making the request;
- (4) the reasons, with particularity, for the request;
- (5) the issues, with particularity, proposed for considerations at any hearing; and
- (6) identification of the terms and conditions which, in the judgment of the person making the request, would be appropriate in the case in question to satisfy the requirements of the law governing documents of the type issued by the Commissioner.

Pursuant to 326 IAC 2-7-18(d), any person may petition the U.S. EPA to object to the issuance of a Title V operating permit or modification within sixty (60) days of the end of the forty-five (45) day EPA review period. Such an objection must be based only on issues that were raised with reasonable specificity during the public comment period, unless the petitioner demonstrates that it was impracticable to raise such issues, or if the grounds for such objection arose after the comment period.

To petition the U.S. EPA to object to the issuance of a Title V operating permit, contact:

U.S. Environmental Protection Agency
401 M Street
Washington, D.C. 20406

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178. Callers from within Indiana may call toll-free at 1-800-451-6027, ext. 3-0178.



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels, Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

Mr. John Ross
NIPSCO - Bailly Generating Station
801 East 86th Avenue
Merrillville, IN 46410

April 26, 2011

Re: 127-30163-00002
Significant Permit Modification to
Part 70 No.: T127-6635-00002

Dear Mr. Ross:


NIPSCO - Bailly Generating Station was issued a Part 70 Operating Permit on June 27, 2006 for an electric utility generating station. A letter requesting changes to this permit was received on January 27, 2011. Pursuant to the provisions of 326 IAC 2-7-12 a significant permit modification to this permit is hereby approved as described in the attached Technical Support Document.

NIPSCO - Bailly Generating Station is installing four (4) natural gas-fired flue gas reheating duct burners, the purpose of the duct burners will be increase the temperature of the boiler exhaust gases entering the SCR system to achieve the desired SCR operating temperature during boiler startups and low load operation. The burners will be located after the boiler steam cycle and before the SCR to manage SCR operating temperature.

All other conditions of the permit shall remain unchanged and in effect. For your convenience, the entire Part 70 Operating Permit as modified will be provided at issuance.

This decision is subject to the Indiana Administrative Orders and Procedures Act – IC 4-21.5-3-5. If you have any questions on this matter, please contact Josiah Balogun, OAQ, 100 North Senate Avenue, MC 61-53, Room 1003, Indianapolis, Indiana, 46204-2251, or call at (800) 451-6027, and ask for Josiah Balogun or extension (4-5257), or dial (317) 234-5257.

Sincerely,


Tripurari P. Sinha, Ph.D., Section Chief
Permits Branch
Office of Air Quality

Attachments:
Updated Permit
Technical Support Document
PTE Calculations

JB

cc: File – Porter County
Porter County Health Department
U.S. EPA, Region V
Northwest Regional Office
Compliance and Enforcement Branch



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

**PART 70 OPERATING PERMIT
OFFICE OF AIR QUALITY**

**Northern Indiana Public Service Company (NIPSCO)
Bailly Generating Station
246 Bailly Station Road
Chesterton, Indiana 46320**

(herein known as the Permittee) is hereby authorized to operate subject to the conditions contained herein, the source described in Section A (Source Summary) of this permit.

The Permittee must comply with all conditions of this permit. Noncompliance with any provisions of this permit is grounds for enforcement action; permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. Noncompliance with any provision of this permit, except any provision specifically designated as not federally enforceable, constitutes a violation of the Clean Air Act. It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. An emergency does constitute an affirmative defense in an enforcement action provided the Permittee complies with the applicable requirements set forth in Section B, Emergency Provisions.

This permit is issued in accordance with 326 IAC 2 and 40 CFR Part 70 Appendix A and contains the conditions and provisions specified in 326 IAC 2-7 as required by 42 U.S.C. 7401, et. seq. (Clean Air Act as amended by the 1990 Clean Air Act Amendments), 40 CFR Part 70.6, IC 13-15 and IC 13-17.


Operation Permit No. T127-6635-00002	
Original issued and signed by: Paul Dubenetzky, Assistant Commissioner Office of Air Quality	Effective Date: June 27, 2006 Expiration Date: June 27, 2011
First Significant Permit Modification No. 127-23445-00002, issued May 7, 2008 Second Significant Permit Modification No. 127-26400-00002, issued on May 7, 2009.	
Significant Permit Modification No. 127-30163-00002	
Issued by:  Tripurari P. Sinha, Ph.D., Section Branch Chief Permits Branch Office of Air Quality	Issuance Date: April 26, 2011 Expiration Date: June 27, 2011

TABLE OF CONTENTS

A SOURCE SUMMARY

- A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)] [326 IAC 2-7-1(22)]
- A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)]
[326 IAC 2-7-5(15)]
- A.3 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-7-4(c)]
[326 IAC 2-7-5(15)]
- A.4 Part 70 Permit Applicability [326 IAC 2-7-2]

B GENERAL CONDITIONS

- B.1 Definitions [326 IAC 2-7-1]
- B.2 Permit Term [326 IAC 2-7-5(2)][326 IAC 2-1.1-9.5][326 IAC 2-7-4(a)(1)(D)][IC 15-13-6(a)]
- B.3 Enforceability [326 IAC 2-7-7]
- B.4 Termination of Right to Operate [326 IAC 2-7-10] [326 IAC 2-7-4(a)]
- B.5 Severability [326 IAC 2-7-5(5)]
- B.6 Property Rights or Exclusive Privilege [326 IAC 2-7-5(6)(D)]
- B.7 Duty to Provide Information [326 IAC 2-7-5(6)(E)]
- B.8 Certification [326 IAC 2-7-4(f)] [326 IAC 2-7-6(1)] [326 IAC 2-7-5(3)(C)]
- B.9 Annual Compliance Certification [326 IAC 2-7-6(5)]
- B.10 Preventive Maintenance Plan [326 IAC 2-7-5(1),(3) and (13)] [326 IAC 2-7-6(1)and(6)]
[326 IAC 1-6-3]
- B.11 Emergency Provisions [326 IAC 2-7-16]
- B.12 Permit Shield [326 IAC 2-7-15] [326 IAC 2-7-20] [326 IAC 2-7-12]
- B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5][326 IAC 2-7-10.5]
- B.14 Deviations from Permit Requirements and Conditions [326 IAC 2-7-5(3)(C)(ii)]
- B.15 Permit Modification, Reopening, Revocation and Reissuance, or Termination
[326 IAC 2-7-5(6)(C)] [326 IAC 2-7-8(a)] [326 IAC 2-7-9]
- B.16 Permit Renewal [326 IAC 2-7-3] [326 IAC 2-7-4][326 IAC 2-7-8(e)]
- B.17 Source Modification Requirements [326 IAC 1-2-42][326 IAC 2-7-10.5][326 IAC 2-2-2]
[326 IAC 2-3-2]
- B.18 Permit Amendment or Modification [326 IAC 2-7-11] [326 IAC 2-7-12] [40 CFR 72]
- B.19 Permit Revision Under Economic Incentives and Other Programs [326 IAC 2-7-5(8)]
[326 IAC 2-7-12 (b)(2)]
- B.20 Operational Flexibility [326 IAC 2-7-20] [326 IAC 2-7-10.5]
- B.21 Inspection and Entry [326 IAC 2-7-6] [IC 13-14-2-2] [IC 13-30-3-1]
- B.22 Transfer of Ownership or Operational Control [326 IAC 2-7-11]
- B.23 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-7-5(7)] [326 IAC 2-1.1-7]
- B.24 Credible Evidence [326 IAC 2-7-5(3)][326 IAC 2-7-6][62 FR 8314] [326 IAC 1-1-6]
- B.25 Term of Conditions [326 IAC 2-1.1-9.5]

C SOURCE OPERATION CONDITIONS

Emission Limitations and Standards [326 IAC 2-7-5(1)]

- C.1 Particulate Emission Limitations For Processes with Process Weight Rates
Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]
- C.2 Opacity [326 IAC 5-1]
- C.3 Open Burning [326 IAC 4-1] [IC 13-17-9]
- C.4 Incineration [326 IAC 4-2] [326 IAC 9-1-2]
- C.5 Fugitive Dust Emissions [326 IAC 6-4]
- C.6 Motor Vehicle Fugitive Dust Sources [326 IAC 6-4-4]
- C.7 Stack Height [326 IAC 1-7]
- C.8 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

Testing Requirements [326 IAC 2-7-6(1)]

- C.9 Performance Testing [326 IAC 3-6]

Compliance Requirements [326 IAC 2-1.1-11]

C.10 Compliance Requirements [326 IAC 2-1.1-11]

Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]

C.11 Compliance Monitoring [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]
C.12 Maintenance of Continuous Opacity Monitoring Equipment [326 IAC 2-7-5(3)(A)(iii)]
C.13 Monitoring Methods [326 IAC 3] [40 CFR 60] [40 CFR 63]
C.14 Other Instrument Specifications [326 IAC 2-1.1-11]
[326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

Corrective Actions and Response Steps [326 IAC 2-7-5] [326 IAC 2-7-6]

C.15 Emergency Reduction Plans [326 IAC 1-5-2] [326 IAC 1-5-3]
C.16 Risk Management Plan [326 IAC 2-7-5(12)] [40 CFR 68]
C.17 Response to Excursions or Exceedances [326 IAC 2-7-5] [326 IAC 2-7-6]
C.18 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5]
[326 IAC 2-7-6]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

C.19 Emission Statement [326 IAC 2-7-5(3)(C)(iii)] [326 IAC 2-7-5(7)] [326 IAC 2-7-19(c)]
[326 IAC 2-6]
C.20 General Record Keeping Requirements [326 IAC 2-7-5(3)][326 IAC 2-7-6][326 IAC 2-2]
[326 IAC 2-3]
C.21 General Reporting Requirements [326 IAC 2-7-5(3)(C)] [326 IAC 2-1.1-11][326 IAC 2-2]
[326 IAC 2-3]

Stratospheric Ozone Protection

C.22 Compliance with 40 CFR 82 and 326 IAC 22-1

Ambient Monitoring Requirements [326 IAC 7-3]

C.23 Ambient Monitoring [326 IAC 7-3]

D.1 FACILITY OPERATION CONDITIONS - Coal Fired Boiler Units 7 and 8

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.1.0 Prevention of Significant Deterioration (PSD) Minor Limits [326 IAC 2-2]
D.1.1 Sulfur Dioxide (SO₂) [326 IAC 7-4-14]
D.1.2 Particulate Emission Limitations for Sources of Indirect Heating [326 IAC 6-2-2]
D.1.3 Startup, Shutdown and Other Opacity Limits [326 IAC 5-1-3]

Compliance Determination Requirements

D.1.4 Testing Requirements [326 IAC 2-7-6(1),(6)] [326 IAC 2-1.1-11]
D.1.5 Operation of Electrostatic Precipitator [326 IAC 2-7-6(6)]
D.1.6 Continuous Emissions Monitoring [326 IAC 3-5] [326 IAC 7-2]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.1.7 Transformer-Rectifier (T-R) Sets [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.1.8 Opacity Readings [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.1.9 SO₂ Monitoring System Downtime [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.1.10 Record Keeping Requirements
D.1.11 Reporting Requirements

D.2 FACILITY OPERATION CONDITIONS - Natural Gas Fired Boilers

Emission Limitations and Standards [326 IAC 2-7-5(1)]

- D.2.1 PSD Minor Limit [326 IAC 2-2-1]
- D.2.2 Particulate Emission Limitations for Sources of Indirect Heating [326 IAC 6-2]
- D.2.3 Startup, Shutdown and Other Opacity Limits [326 IAC 5-1-3]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

- D.2.4 Record Keeping Requirements
- D.2.5 Reporting Requirements

D.3 FACILITY OPERATION CONDITIONS - Internal Combustion Units

Emission Limitations and Standards

- D.3.1 Porter County Sulfur Dioxide Emission Limitations [326 IAC 7-4-14]
- D.3.2 Sulfur Dioxide (SO₂) [326 IAC 7] [326 IAC 2]

Compliance Determination Requirements

- D.3.3 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 7-2] [326 IAC 7-1.1-2]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

- D.3.4 Record Keeping Requirements

D.4 FACILITY OPERATION CONDITIONS - Coal Handling

- D.4.1 New Source Performance Standard (NSPS): Coal Preparation Plants [326 IAC 12] [40 CFR 60, Subpart Y]
- D.4.2 Particulate [326 IAC 6-3-2]
- D.4.3 General Provisions Relating to NSPS [326 IAC 12-1] [40 CFR Part 60, Subpart A]

Compliance Determination Requirements

- D.4.4 NSPS Test Methods and Procedures [326 IAC 2-7-6(1), (3), (6)] [326 IAC 2-1.1-11] [40 CFR 60.8] [40 CFR 60.46]
- D.4.5 NSPS Compliance Provisions [326 IAC 12] [40 CFR 60, Subpart Y]
- D.4.6 Reporting Requirements [326 IAC 12-1] [40 CFR Part 60, Subpart A]

D.5 FACILITY OPERATION CONDITIONS - FGD System Material Handling

Emission Limitations and Standards [326 IAC 2-7-5(1)]

- D.5.1 Particulate [326 IAC 6-3-2]
- D.5.2 Material Handling Requirements [326 IAC 2]
- D.5.3 Fugitive Dust Plan [326 IAC 2]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

- D.5.4 Record Keeping Requirements

D.6 FACILITY OPERATION CONDITIONS - Fly Ash Handling

Emission Limitations and Standards [326 IAC 2-7-5(1)]

- D.6.1 Particulate [326 IAC 6-3-2]

Compliance Determination Requirements

- D.6.2 Particulate Control [326 IAC 2-7-6(6)]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- D.6.3 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.6.4 Record Keeping Requirements

D.7 FACILITY OPERATION CONDITIONS - Bottom Ash Handling

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.7.1 Fugitive Dust Emission Limitations [326 IAC 6-4-2]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.7.2 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.7.3 Record Keeping Requirements

D.8 FACILITY OPERATION CONDITIONS - Degreasing Operations

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.8.1 Organic Solvent Degreasing Operations: Cold Cleaner Operation [326 IAC 8-3-2]

D.8.2 Organic Solvent Degreasing Operations: Cold Cleaner Degreaser Operation and Control [326 8-3-5]

D.9 FACILITY OPERATION CONDITIONS - Grinding and Machining Operations

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.9.1 Particulate [326 IAC 6-3-2] [40 CFR 52 Subpart P]

Compliance Determination Requirements

D.9.2 Particulate Control [326 IAC 2-7-6(6)]

E ACID RAIN PROGRAM CONDITIONS

E.1 Acid Rain Permit [326 IAC 2-7-5(1)(C)] [326 IAC 21]

E.2 Title IV Emissions Allowances [326 IAC 2-7-5(4)]

F NITROGEN OXIDES BUDGET TRADING PROGRAM - NOX Budget Permit

F.1 Automatic Incorporation of Definitions [326 IAC 10-4-7(e)]

F.2 Standard Permit Requirements [326 IAC 10-4-4(a)]

F.3 Monitoring Requirements [326 IAC 10-4-4(b)]

F.4 Nitrogen Oxides Requirements [326 IAC 10-4-4(c)]

F.5 Excess Emissions Requirements [326 IAC 10-4-4(d)]

F.6 Record Keeping Requirements [326 IAC 10-4-4(e)] [326 IAC 2-7-5(3)]

F.7 Reporting Requirements [326 IAC 10-4-4(e)]

F.8 Liability [326 IAC 10-4-4(f)]

F.9 Effect on Other Authorities [326 IAC 10-4-4(g)]

G Clean Air Interstate Rule (CAIR) Nitrogen Oxides Annual, Sulfur Dioxide, and Nitrogen Oxides Ozone Season Trading Programs – CAIR Permit for CAIR Units Under 326 IAC 24-1-1(a), 326 IAC 24-2-1(a), and 326 IAC 24-3-1(a)

G.1 Automatic Incorporation of Definitions [326 IAC 24-1-7(e)] [326 IAC 24-2-7(e)] [326 IAC 24-3-7(e)] [40 CFR 97.123(b)] [40 CFR 97.223(b)] [40 CFR 97.323(b)]

G.2 Standard Permit Requirements [326 IAC 24-1-4(a)] [326 IAC 24-2-4(a)] [326 IAC 24-3-4(a)] [40 CFR 97.106(a)] [40 CFR 97.206(a)] [40 CFR 97.306(a)]

G.3 Monitoring, Reporting, and Record Keeping Requirements [326 IAC 24-1-4(b)] [326 IAC 24-2-4(b)] [326 IAC 24-3-4(b)] [40 CFR 97.106(b)] [40 CFR 97.206(b)] [40 CFR 97.306(b)]

- G.4.1 Nitrogen Oxides Emission Requirements [326 IAC 24-1-4(c)] [40 CFR 97.106(c)]
- G.4.2 Sulfur Dioxide Emission Requirements [326 IAC 24-2-4(c)] [40 CFR 97.206(c)]
- G.4.3 Nitrogen Oxides Ozone Season Emission Requirements [326 IAC 24-3-4(c)]
[40 CFR 97.306(c)]
- G.5 Excess Emissions Requirements [326 IAC 24-1-4(d)] [326 IAC 24-2-4(d)]
[326 IAC 24-3-4(d)] [40 CFR 97.106(d)] [40 CFR 97.206(d)] [40 CFR 97.306(d)]
- G.6 Record Keeping Requirements [326 IAC 24-1-4(e)] [326 IAC 24-2-4(e)]
[326 IAC 24-3-4(e)] [326 IAC 2-7-5(3)] [40 CFR 97.106(e)] [40 CFR 97.206(e)]
[40 CFR 97.306(e)]
- G.7 Reporting Requirements [326 IAC 24-1-4(e)] [326 IAC 24-2-4(e)] [326 IAC 24-3-4(e)]
[40 CFR 97.106(e)] [40 CFR 97.206(e)] [40 CFR 97.306(e)]
- G.8 Liability [326 IAC 24-1-4(f)] [326 IAC 24-2-4(f)] [326 IAC 24-3-4(f)] [40 CFR 97.106(f)]
[40 CFR 97.206(f)] [40 CFR 97.306(f)]
- G.9 Effect on Other Authorities [326 IAC 24-1-4(g)] [326 IAC 24-2-4(g)]
[326 IAC 24-3-4(g)] [40 CFR 97.106(g)] [40 CFR 97.206(g)] [40 CFR 97.306(g)]
- G.10 CAIR Designated Representative and Alternate CAIR Designated Representative
[326 IAC 24-1-6] [326 IAC 24-2-6] [326 IAC 24-3-6] [40 CFR 97, Subpart BB]
[40 CFR 97, Subpart BBB] [40 CFR 97, Subpart BBBB]

Certification

Emergency Occurrence Report

Auxiliary Boiler Natural Gas Usage - Quarterly Report

Quarterly Deviation and Compliance Monitoring Report

Appendix A: Road Watering Map for Fugitive Dust Control Plan

Appendix B: Acid Rain Permit

SECTION A

SOURCE SUMMARY

This permit is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ). The information describing the source contained in conditions A.1 through A.3 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this permit pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)] [326 IAC 2-7-1(22)]

The Permittee owns and operates a stationary electric utility generating station.

Source Address:	246 Bailly Station Road, Chesterton, Indiana 46304
Mailing Address:	Kelly R. Carmichael, 801 East 86 th Avenue, Merrillville, Indiana 46410
Source Telephone:	219-647-5252
SIC Code:	4911
County Location:	Porter
Source Location Status:	Nonattainment for PM2.5 and 1-hour and 8-hour ozone standards Attainment for all other criteria pollutants
Source Status:	Part 70 Permit Program Major Source, under PSD, and Emission Offset Rules Major Source, Section 112 of the Clean Air Act 1 of 28 Source Categories

A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)] [326 IAC 2-7-5(15)]

This stationary source consists of the following emission units and pollution control devices:

- (a) One (1) cyclone coal-fired boiler, identified as Unit 7, with construction completed in 1962, with a design heat input capacity of 1638 million Btu per hour, with an electrostatic precipitator (ESP) system for control of particulate matter. A wet limestone flue gas desulfurization system serves both Unit 7 and 8 for control of sulfur dioxide. Natural gas and/or No. 2 fuel oil can be fired during startup, shutdown, and malfunctions; the unit can also generate electricity while combusting natural gas only. Unit 7 has continuous emissions monitoring systems (CEMS) for nitrogen oxides (NO_x) and for sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Scrubbed emissions from Units 7 and 8 are exhausted through Stack CS001. Non-scrubbed emissions from Units 7 and 8 are exhausted through the bypass stack, Stack CS002.
- (b) One (1) cyclone coal-fired boiler, identified as Unit 8, with construction completed in 1968, with a design heat input capacity of 3374 million Btu per hour, with an electrostatic precipitator (ESP) system for control of particulate matter. A wet limestone flue gas desulfurization system serves both Unit 7 and 8 for control of sulfur dioxide. Natural gas and/or No. 2 fuel oil can be fired during startup, shutdown, and malfunctions; the unit can also generate electricity while combusting natural gas only. Unit 8 is equipped with a selective catalytic reduction (SCR) system and in 2011 was also authorized to install up to four (4) natural gas fired flue gas reheating Duct Burners each with a maximum design heat input capacity of 40 million Btu per hour. Unit 8 has continuous emissions monitoring systems (CEMS) for nitrogen oxides (NO_x) and for sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Scrubbed emissions from Units 7 and 8 are exhausted through Stack CS001. Non-scrubbed emissions from Units 7 and 8 are exhausted through the bypass stack, Stack CS002.

- (c) Two (2) natural gas-fired boilers, identified as Auxiliary Boiler 1 and Auxiliary Boiler 2, with construction completed in 1980, each with a nominal heat input capacity of 99.9 million Btu per hour, both exhausting through Stack 5.
- (d) One (1) simple-cycle, natural gas-fired combustion turbine, identified as Unit 10, with construction completed in 1968, with a design heat input capacity of 600 million Btu per hour, exhausting to Stack 10.
- (e) One (1) 825 horsepower diesel starter engine for Unit 10 combustion turbine.
- (f) A coal storage and handling system for Units 7 and 8, constructed in 1962 and 1968, with a maximum throughput of 1000 tons of coal per hour, consisting of the following equipment:
 - (1) One (1) railcar unloading station with particulate emissions controlled by enclosure and wet suppression.
 - (2) An enclosed conveyor system, with the transfer points underground or enclosed by buildings. A telescoping chute is used to drop coal to the storage pile(s).
 - (3) Coal storage pile(s), with fugitive dust emissions controlled by compaction.
- (g) Two (2) enclosed coal crushers, constructed before October 24, 1974 and reconstructed in 2003, each with a maximum throughput of 600 tons of coal per hour, exhausting through a baghouse.
- (h) Material handling and storage facilities for the flue gas desulfurization system, with installation started in 1990 and completed in 1992, including the following:
 - (1) Pneumatic conveyance of limestone to storage silos and from the silos to the scrubber, at a maximum throughput rate of 26.7 tons per hour.
 - (2) Pneumatic conveyance of hydrated lime to a storage silo and from the silo to the scrubber, at a maximum throughput rate of 4.8 tons per hour.
 - (3) Two (2) limestone storage silos, with a combined storage capacity of 2225 tons, each with a bin vent filter to recover the pneumatically conveyed material.
 - (4) One (1) hydrated lime storage silo, with a storage capacity of 115 tons, with a bin vent filter to recover the pneumatically conveyed material.
 - (5) Dewatered gypsum is transferred via an enclosed conveyor to an enclosed storage building at a maximum throughput rate of 48.8 tons per hour. Gypsum is transferred to trucks by front end loader in the building and taken offsite.
- (i) Fly ash handling, installed in 1981 or 1982, including the following:
 - (1) Vacuum conveyance of fly ash to storage silos with particulate emissions controlled by bin vent filter, with a maximum throughput rate of 10.2 tons per hour.
 - (2) Two (2) fly ash silo unloading with silo collector bag filters and silo bin vent bag filters. Each silo has wet and dry unloaders, each with a maximum throughput rate of 500 tons/hr, with particulate emissions from each controlled by the use of a telescoping chute with a vacuum system and a storage silo bin vent filter when the ash is being loaded dry, and controlled by the use of water spray mixed with the ash when the ash is being loaded wet.

- (j) Wet process bottom ash handling installed in the 1960's, with bottom ash sluiced to storage pond(s), with water cover or vegetation sufficient to prevent ash re-entrainment. Ash removed from the pond(s) is stored in piles before being taken offsite by truck.

A.3 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-7-4(c)]
[326 IAC 2-7-5(15)]

This stationary source also includes the following insignificant activities which are specifically regulated, as defined in 326 IAC 2-7-1(21):

- (a) Natural gas-fired combustion sources with heat input equal to or less than ten million (10,000,000) Btu per hour, including one (1) 2.4 million Btu per hour (MMBtu/hr) natural gas-fired main office building boiler installed after 1985, and one (1) 780,000 Btu per hour natural gas-fired boiler at the EPSC (the Electric Product Services Center building) installed in the 1990's, for building heat only. [326 IAC 6-2]
- (b) Degreasing operations that do not exceed 145 gallons per 12 months, except if subject to 326 IAC 20-6. [326 IAC 8-3-2]
- (c) Cleaners and solvents characterized as follows: [326 IAC 8-3]
 - (1) Having a vapor pressure equal to or less than 2 kPa; 15 mm Hg; or 0.3 psi measured at 38 degrees C (100°F) or;
 - (2) Having a vapor pressure equal to or less than 0.7 kPa; 5mm Hg; or 0.1 psi measured at 20°C (68°F); the use of which for all cleaners and solvents combined does not exceed 145 gallons per 12 months.
- (d) Coal bunker and coal scale exhausts and associated dust collector vents. [326 IAC 6-3]
- (e) Emergency generators as follows: One (1) FGD system emergency quench pump powered by a 500 horsepower diesel generator. [326 IAC 7] [326 IAC 2]
- (f) Other emergency equipment as follows [326 IAC 7]:
 - (1) One (1) stationary fire pump (diesel-fired).
 - (2) One (1) Unit 10 emergency generator, using diesel as fuel, with a maximum capacity less than 1,600 horsepower.
- (g) Grinding and machining operations controlled with fabric filters, scrubbers, mist collectors, wet collectors and electrostatic precipitators with a design grain loading of less than or equal to 0.03 grains per actual cubic foot and a gas flow rate less than or equal to 4000 actual cubic feet per minute, including the following: deburring; buffing; polishing; abrasive blasting; pneumatic conveying; and woodworking operations.
[326 IAC 6-3]
- (h) Other activities or categories not previously identified with potential, uncontrolled emissions equal to or less than thresholds require listing only: Pb 0.6 ton per year or 3.29 pounds per day, SO₂ 5 pounds per hour or 25 pounds per day, NO_x 5 pounds per hour or 25 pounds per day, CO 25 pounds per day, PM 5 pounds per hour or 25 pounds per day, VOC 3 pounds per hour or 15 pounds per day; including evaporation of boiler chemical cleaning liquids.

A.4 Part 70 Permit Applicability [326 IAC 2-7-2]

This stationary source is required to have a Part 70 permit by 326 IAC 2-7-2 (Applicability) because:

- (a) It is a major source, as defined in 326 IAC 2-7-1(22);
- (b) It is a source in a source category designated by the United States Environmental Protection Agency (U.S. EPA) under 40 CFR 70.3 (Part 70 - Applicability); and
- (c) It is an affected source under Title IV (Acid Deposition Control) of the Clean Air Act, as defined in 326 IAC 2-7-1(3).

SECTION B

GENERAL CONDITIONS

B.1 Definitions [326 IAC 2-7-1]

Terms in this permit shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, the applicable definitions found in the statutes or regulations (IC 13-11, 326 IAC 1-2 and 326 IAC 2-7) shall prevail.

B.2 Permit Term [326 IAC 2-7-5(2)] [326 IAC 2-1.1-9.5][326 IAC 2-7-4(a)(1)(D)][IC 15-13-6(a)]

- (a) This permit, T127-6635-00002, is issued for a fixed term of five (5) years from the effective date of this permit, as determined in accordance with IC 4-21.5-3-5(f) and IC 13-15-5-3. Subsequent revisions, modifications, or amendments of this permit do not affect the expiration date of this permit or of permits issued pursuant to Title IV of the Clean Air Act and 326 IAC 21 (Acid Deposition Control).
- (b) If IDEM, OAQ, upon receiving a timely and complete renewal permit application, fails to issue or deny the permit renewal prior to the expiration date of this permit, this existing permit shall not expire and all terms and conditions shall continue in effect, including any permit shield provided in 326 IAC 2-7-15, until the renewal permit has been issued or denied.

B.3 Enforceability [326 IAC 2-7-7]

Unless otherwise stated, all terms and conditions in this permit, including any provisions designed to limit the source's potential to emit, are enforceable by IDEM, the United States Environmental Protection Agency (U.S. EPA) and by citizens in accordance with the Clean Air Act.

B.4 Termination of Right to Operate [326 IAC 2-7-10] [326 IAC 2-7-4(a)]

The Permittee's right to operate this source terminates with the expiration of this permit unless a timely and complete renewal application is submitted at least nine (9) months prior to the date of expiration of the source's existing permit, consistent with 326 IAC 2-7-3 and 326 IAC 2-7-4(a).

B.5 Severability [326 IAC 2-7-5(5)]

The provisions of this permit are severable; a determination that any portion of this permit is invalid shall not affect the validity of the remainder of the permit.

B.6 Property Rights or Exclusive Privilege [326 IAC 2-7-5(6)(D)]

This permit does not convey any property rights of any sort, or any exclusive privilege.

B.7 Duty to Provide Information [326 IAC 2-7-5(6)(E)]

- (a) The Permittee shall furnish to IDEM, OAQ, within a reasonable time, any information that IDEM, OAQ, may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The submittal by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34). Upon request, the Permittee shall also furnish to IDEM, OAQ, copies of records required to be kept by this permit.
- (b) For information furnished by the Permittee to IDEM, OAQ, the Permittee may include a claim of confidentiality in accordance with 326 IAC 17.1. When furnishing copies of requested records directly to U. S. EPA, the Permittee may assert a claim of confidentiality in accordance with 40 CFR 2, Subpart B.

B.8 Certification [326 IAC 2-7-4(f)] [326 IAC 2-7-6(1)] [326 IAC 2-7-5(3)(C)]

- (a) Where specifically designated by this permit or required by an applicable requirement, any application form, report, or compliance certification submitted shall contain certification by a responsible official of truth, accuracy, and completeness. This certification shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

- (b) One (1) certification shall be included, using the attached Certification Form, with each submittal requiring certification. One (1) certification may cover multiple forms in one (1) submittal.
- (c) A responsible official is defined at 326 IAC 2-7-1(34).

B.9 Annual Compliance Certification [326 IAC 2-7-6(5)]

- (a) The Permittee shall annually submit a compliance certification report which addresses the status of the source's compliance with the terms and conditions contained in this permit, including emission limitations, standards, or work practices. The initial certification shall cover the time period from the effective date of the permit through December 31 of the same year. All subsequent certifications shall cover the time period from January 1 to December 31 of the previous year, and shall be submitted in letter form no later than July 1 of each year to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V
Air and Radiation Division, Air Enforcement Branch - Indiana (AE-17J)
77 West Jackson Boulevard
Chicago, Illinois 60604-3590

- (b) The annual compliance certification report required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.
- (c) The annual compliance certification report shall include the following:
 - (1) The appropriate identification of each term or condition of this permit that is the basis of the certification;
 - (2) The compliance status;
 - (3) Whether compliance was continuous or intermittent; and
 - (4) The methods used for determining the compliance status of the source, currently and over the reporting period consistent with 326 IAC 2-7-5(3).

The submittal by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

B.10 Preventive Maintenance Plan [326 IAC 2-7-5(1),(3) and (13)] [326 IAC 2-7-6(1) and (6)] [326 IAC 1-6-3]

- (a) The Permittee shall prepare and maintain Preventive Maintenance Plans (PMPs) within ninety (90) days after the effective date of this permit for the source as described in 326 IAC 1-6-3. At a minimum, the PMPs shall include:

- (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;
- (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
- (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

If, due to circumstances beyond the Permittee's control, the PMPs cannot be prepared and maintained within the above time frame, the Permittee may extend the date an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

The PMP extension notification does not require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

- (b) A copy of the PMPs shall be submitted to IDEM, OAQ, upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. IDEM, OAQ, may require the Permittee to revise its PMPs whenever lack of proper maintenance causes or is the primary contributor to an exceedance of any limitation on emissions or potential to emit. The PMPs do not require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).
- (c) To the extent the Permittee is required by 40 CFR Part 63 to have an Operation, Maintenance, and Monitoring (OMM) Plan for a unit, such Plan is deemed to satisfy the PMP requirements of 326 IAC 1-6-3 for that unit.

B.11 Emergency Provisions [326 IAC 2-7-16]

- (a) An emergency, as defined in 326 IAC 2-7-1(12), is not an affirmative defense for an action brought for noncompliance with a federal or state health-based emission limitation.
- (b) An emergency, as defined in 326 IAC 2-7-1(12), constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limitation if the affirmative defense of an emergency is demonstrated through properly signed, contemporaneous operating logs or other relevant evidence that describe the following:
 - (1) An emergency occurred and the Permittee can, to the extent possible, identify the causes of the emergency;
 - (2) The permitted facility was at the time being properly operated;
 - (3) During the period of an emergency, the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards or other requirements in this permit;
 - (4) For each emergency lasting one (1) hour or more, the Permittee notified IDEM, OAQ within four (4) daytime business hours after the beginning of the emergency, or after the emergency was discovered or reasonably should have been discovered;

Telephone Number: 1-800-451-6027 (ask for Office of Air Quality, Compliance Section), or
Telephone Number: 317-233-0178 (ask for Compliance Section)
Facsimile Number: 317-233-6865.

- (5) For each emergency lasting one (1) hour or more, the Permittee submitted the attached Emergency Occurrence Report Form or its equivalent, either by mail or facsimile to:


Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

within two (2) working days of the time when emission limitations were exceeded due to the emergency.

The notice fulfills the requirement of 326 IAC 2-7-5(3)(C)(ii) and must contain the following:

- (A) A description of the emergency;
- (B) Any steps taken to mitigate the emissions; and
- (C) Corrective actions taken.

The notification which shall be submitted by the Permittee does not require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

- (6) The Permittee immediately took all reasonable steps to correct the emergency.
- (c) In any enforcement proceeding, the Permittee seeking to establish the occurrence of an emergency has the burden of proof.
- (d) This emergency provision supersedes 326 IAC 1-6 (Malfunctions). This permit condition is in addition to any emergency or upset provision contained in any applicable requirement.
- (e)   IDEM, OAQ, may require that the Preventive Maintenance Plans required under 326 IAC 2-7-4-(c)(9) be revised in response to an emergency.
- (f) Failure to notify IDEM, OAQ, by telephone or facsimile of an emergency lasting more than one (1) hour in accordance with (b)(4) and (5) of this condition shall constitute a violation of 326 IAC 2-7 and any other applicable rules.
- (g) If the emergency situation causes a deviation from a technology-based limit, the Permittee may continue to operate the affected emitting facilities during the emergency provided the Permittee immediately takes all reasonable steps to correct the emergency and minimize emissions.

- (h) The Permittee shall include all emergencies in the Quarterly Deviation and Compliance Monitoring Report.

B.12 Permit Shield [326 IAC 2-7-15] [326 IAC 2-7-20] [326 IAC 2-7-12]

- (a) Pursuant to 326 IAC 2-7-15, the Permittee has been granted a permit shield. The permit shield provides that compliance with the conditions of this permit shall be deemed compliance with any applicable requirements as of the effective date of this permit, provided that either the applicable requirements are included and specifically identified in this permit or the permit contains an explicit determination or concise summary of a determination that other specifically identified requirements are not applicable. The Indiana statutes from IC 13 and rules from 326 IAC, referenced in conditions in this permit, are those applicable at the time the permit was issued. The issuance or possession of this permit shall not alone constitute a defense against an alleged violation of any law, regulation or standard, except for the requirement to obtain a Part 70 permit under 326 IAC 2-7 or for applicable requirements for which a permit shield has been granted.

This permit shield does not extend to applicable requirements which are promulgated after the date of issuance of this permit unless this permit has been modified to reflect such new requirements.

- (b) If, after issuance of this permit, it is determined that the permit is in nonconformance with an applicable requirement that applied to the source on the date of permit issuance, IDEM, OAQ, shall immediately take steps to reopen and revise this permit and issue a compliance order to the Permittee to ensure expeditious compliance with the applicable requirement until the permit is reissued. The permit shield shall continue in effect so long as the Permittee is in compliance with the compliance order.
- (c) No permit shield shall apply to any permit term or condition that is determined after issuance of this permit to have been based on erroneous information supplied in the permit application. Erroneous information means information that the Permittee knew to be false, or in the exercise of reasonable care should have been known to be false, at the time the information was submitted.
- (d) Nothing in 326 IAC 2-7-15 or in this permit shall alter or affect the following:
- (1) The provisions of Section 303 of the Clean Air Act (emergency orders), including the authority of the U.S. EPA under Section 303 of the Clean Air Act;
 - (2) The liability of the Permittee for any violation of applicable requirements prior to or at the time of this permit's effective date;
 - (3) The applicable requirements of the acid rain program, consistent with Section 408(a) of the Clean Air Act; and
 - (4) The ability of U.S. EPA to obtain information from the Permittee under Section 114 of the Clean Air Act.
- (e) This permit shield is not applicable to any change made under 326 IAC 2-7-20(b)(2) (Sections 502(b)(10) of the Clean Air Act changes) and 326 IAC 2-7-20(c)(2) (trading based on State Implementation Plan (SIP) provisions).
- (f) This permit shield is not applicable to modifications eligible for group processing until after IDEM, OAQ, has issued the modifications. [326 IAC 2-7-12(c)(7)]
- (g) This permit shield is not applicable to minor Part 70 permit modifications until after IDEM, OAQ, has issued the modification. [326 IAC 2-7-12(b)(8)]

B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5][326 IAC 2-7-10.5]

- (a) All terms and conditions of permits established prior to T127-6635-00002 and issued pursuant to permitting programs approved into the state implementation plan have been either
- (1) incorporated as originally stated,
 - (2) revised under 326 IAC 2-7-10.5, or
 - (3) deleted under 326 IAC 2-7-10.5.
- (b) Provided that all terms and conditions are accurately reflected in this permit, all previous registrations and permits are superseded by this part 70 operating permit, except for permits issued pursuant to Title IV of the Clean Air Act and 326 IAC 21 (Acid Deposition Control).

B.14 Deviations from Permit Requirements and Conditions [326 IAC 2-7-5(3)(C)(ii)]

- (a) Deviations from any permit requirements (for emergencies see Section B - Emergency Provisions), the probable cause of such deviations, and any response steps or preventive measures taken shall be reported to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

using the attached Quarterly Deviation and Compliance Monitoring Report, or its equivalent. A deviation required to be reported pursuant to an applicable requirement that exists independent of this permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report.

The Quarterly Deviation and Compliance Monitoring Report does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

- (b) A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit.

B.15 Permit Modification, Reopening, Revocation and Reissuance, or Termination [326 IAC 2-7-5(6)(C)] [326 IAC 2-7-8(a)] [326 IAC 2-7-9]

- (a) This permit may be modified, reopened, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a Part 70 permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any condition of this permit. [326 IAC 2-7-5(6)(C)] The notification by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).
- (b) This permit shall be reopened and revised under any of the circumstances listed in IC 13-15-7-2 or if IDEM, OAQ, determines any of the following:
- (1) That this permit contains a material mistake.
 - (2) That inaccurate statements were made in establishing the emissions standards or other terms or conditions.
 - (3) That this permit must be revised or revoked to assure compliance with an applicable requirement. [326 IAC 2-7-9(a)(3)]

- (c) Proceedings by IDEM, OAQ, to reopen and revise this permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of this permit for which cause to reopen exists. Such reopening and revision shall be made as expeditiously as practicable. [326 IAC 2-7-9(b)]
- (d) The reopening and revision of this permit, under 326 IAC 2-7-9(a), shall not be initiated before notice of such intent is provided to the Permittee by IDEM, OAQ at least thirty (30) days in advance of the date this permit is to be reopened, except that IDEM, OAQ, may provide a shorter time period in the case of an emergency. [326 IAC 2-7-9(c)]

B.16 Permit Renewal [326 IAC 2-7-3] [326 IAC 2-7-4] [326 IAC 2-7-8(e)]

- (a) The application for renewal shall be submitted using the application form or forms prescribed by IDEM, OAQ, and shall include the information specified in 326 IAC 2-7-4. Such information shall be included in the application for each emission unit at this source, except those emission units included on the trivial or insignificant activities list contained in 326 IAC 2-7-1(21) and 326 IAC 2-7-1(40). The renewal application does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

Request for renewal shall be submitted to:

Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

- (b) A timely renewal application is one that is:
 - (1) Submitted at least nine (9) months prior to the date of the expiration of this permit; and
 - (2) If the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.
- (c) If the Permittee submits a timely and complete application for renewal of this permit, the source's failure to have a permit is not a violation of 326 IAC 2-7 until IDEM, OAQ, takes final action on the renewal application, except that this protection shall cease to apply if, subsequent to the completeness determination, the Permittee fails to submit by a reasonable deadline specified in writing by IDEM, OAQ, any additional information identified as being needed to process the application.

B.17 Source Modification Requirements [326 IAC 1-2-42][326 IAC 2-7-10.5][326 IAC 2-2-2] [326 IAC 2-3-2]

- (a) The Permittee shall obtain approval as required by 326 IAC 2-7-10.5 from the IDEM, OAQ prior to making any modification to the source:
- (b) Any application requesting a source modification shall be submitted to:

Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

Any such application shall be certified by the "responsible official" as defined by 326 IAC 2-7-1(34).

(c) The Permittee shall also comply with the applicable provisions of 326 IAC 2-7-11 (Administrative Permit Amendments) or 326 IAC 2-7-12 (Permit Modification) prior to operating the approved modification.

(d) Any such application shall be certified by the "responsible official" as defined by 326 IAC 2-2-2 (326 IAC 2-3-2).

B.18 Permit Amendment or Modification [326 IAC 2-7-11] [326 IAC 2-7-12] [40 CFR 72]

(a) Permit amendments and modifications are governed by the requirements of 326 IAC 2-7-11 or 326 IAC 2-7-12 whenever the Permittee seeks to amend or modify this permit.

(b) Pursuant to 326 IAC 2-7-11(b) and 326 IAC 2-7-12(a), administrative Part 70 permit amendments and permit modifications for purposes of the acid rain portion of a Part 70 permit shall be governed by regulations promulgated under Title IV of the Clean Air Act. [40 CFR 72]

(c) Any application requesting an amendment or modification of this permit shall be submitted to:

Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

Any such application shall be certified by the "responsible official" as defined by 326 IAC 2-7-1(34).

(d) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-7-11(c)(3)]

B.19 Permit Revision Under Economic Incentives and Other Programs [326 IAC 2-7-5(8)] [326 IAC 2-7-12 (b)(2)]

(a) No Part 70 permit revision shall be required under any approved economic incentives, marketable Part 70 permits, emissions trading, and other similar programs or processes for changes that are provided for in a Part 70 permit.

(b) Notwithstanding 326 IAC 2-7-12(b)(1) and 326 IAC 2-7-12(c)(1), minor Part 70 permit modification procedures may be used for Part 70 modifications involving the use of economic incentives, marketable Part 70 permits, emissions trading, and other similar approaches to the extent that such minor Part 70 permit modification procedures are explicitly provided for in the applicable State Implementation Plan (SIP) or in applicable requirements promulgated or approved by the U.S. EPA.

B.20 Operational Flexibility [326 IAC 2-7-20] [326 IAC 2-7-10.5]

(a) The Permittee may make any change or changes at the source that are described in 326 IAC 2-7-20(b), (c), or (e), without a prior permit revision, if each of the following conditions is met:

- (1) The changes are not modifications under any provision of Title I of the Clean Air Act;
- (2) Any preconstruction approval required by 326 IAC 2-7-10.5 has been obtained;

(3) The changes do not result in emissions which exceed the limitations provided in this permit (whether expressed herein as a rate of emissions or in terms of total emissions);

(4) The Permittee notifies the:

Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V
Air and Radiation Division, Regulation Development Branch - Indiana (AR-18J)
77 West Jackson Boulevard
Chicago, Illinois 60604-3590

in advance of the change by written notification at least ten (10) days in advance of the proposed change. The Permittee shall attach every such notice to the Permittee's copy of this permit; and

(5) The Permittee maintains records on-site, on a rolling five (5) year basis, which document all such changes and emission trades that are subject to 326 IAC 2-7-20(b), (c), or (e). The Permittee shall make such records available, upon reasonable request, for public review.

Such records shall consist of all information required to be submitted to IDEM, OAQ, in the notices specified in 326 IAC 2-7-20(b)(1), (c)(1), and (e)(2).

(b) The Permittee may make Section 502(b)(10) of the Clean Air Act changes (this term is defined at 326 IAC 2-7-1(36)) without a permit revision, subject to the constraint of 326 IAC 2-7-20(a). For each such Section 502(b)(10) of the Clean Air Act change, the required written notification shall include the following:

(1) A brief description of the change within the source;

(2) The date on which the change will occur;

(3) Any change in emissions; and

(4) Any permit term or condition that is no longer applicable as a result of the change.

The notification which shall be submitted is not considered an application form, report or compliance certification. Therefore, the notification by the Permittee does not require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

(c) Emission Trades [326 IAC 2-7-20(c)]

The Permittee may trade emissions increases and decreases at the source, where the applicable SIP provides for such emission trades without requiring a permit revision, subject to the constraints of Section (a) of this condition and those in 326 IAC 2-7-20(c). The notification requirement per (a)(4) of this condition does not apply to emission trades of SO₂ or NO_x under 326 IAC 21 or 326 IAC 10-4.

- (d) Alternative Operating Scenarios [326 IAC 2-7-20(d)]
The Permittee may make changes at the source within the range of alternative operating scenarios that are described in the terms and conditions of this permit in accordance with 326 IAC 2-7-5(9). No prior notification of IDEM, OAQ, or U.S. EPA is required.
- (e) Backup fuel switches specifically addressed in, and limited under, Section D of this permit shall not be considered alternative operating scenarios. Therefore, the notification requirements of part (a) of this condition do not apply.
- (f) [REDACTED] 326 IAC 21 IAC 326 IAC 10-4.

B.21 Inspection and Entry [326 IAC 2-7-6] [IC 13-14-2-2] [IC 13-30-3-1]

Upon presentation of proper identification cards, credentials, and other documents as may be required by law, and subject to the Permittee's right under all applicable laws and regulations to assert that the information collected by the agency is confidential and entitled to be treated as such, the Permittee shall allow IDEM, OAQ, U.S. EPA, or an authorized representative to perform the following:

- (a) Enter upon the Permittee's premises where a Part 70 source is located, or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
- (b) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, have access to and copy any records that must be kept under the conditions of this permit;
- (c) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, inspect any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit;
- (d) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, sample or monitor substances or parameters for the purpose of assuring compliance with this permit or applicable requirements; and
- (e) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, utilize any photographic, recording, testing, monitoring, or other equipment for the purpose of assuring compliance with this permit or applicable requirements.

B.22 Transfer of Ownership or Operational Control [326 IAC 2-7-11]

- (a) The Permittee must comply with the requirements of 326 IAC 2-7-11 whenever the Permittee seeks to change the ownership or operational control of the source and no other change in the permit is necessary.
- (b) Any application requesting a change in the ownership or operational control of the source shall contain a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new Permittee. The application shall be submitted to:

Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

SECTION C

SOURCE OPERATION CONDITIONS

Entire Source

Emission Limitations and Standards [326 IAC 2-7-5(1)]

C.1 Particulate Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2(e)(2), particulate emissions from any process not exempt under 326 IAC 6-3-1(b) or (c) which has a maximum process weight rate less than 100 pounds per hour and the methods in 326 IAC 6-3-2(b) through (d) do not apply shall not exceed 0.551 pounds per hour.

C.2 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

- (a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

C.3 Open Burning [326 IAC 4-1] [IC 13-17-9]

The Permittee shall not open burn any material except as provided in 326 IAC 4-1-3, 326 IAC 4-1-4 or 326 IAC 4-1-6. The previous sentence notwithstanding, the Permittee may open burn in accordance with an open burning approval issued by the Commissioner under 326 IAC 4-1-4.1. 326 IAC 4-1-3 (a)(2)(A) and (B) are not federally enforceable.

C.4 Incineration [326 IAC 4-2][326 IAC 9-1-2]

The Permittee shall not operate an incinerator or incinerate any waste or refuse except as provided in 326 IAC 4-2 and 326 IAC 9-1-2. 326 IAC 9-1-2 is not federally enforceable.

C.5 Fugitive Dust Emissions [326 IAC 6-4]

The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions). 326 IAC 6-4-2(4) is not federally enforceable.

C.6 Motor Vehicle Fugitive Dust Sources [326 IAC 6-4-4]

Pursuant to 326 IAC 6-4-4, no vehicle shall be driven or moved on any public street, road, alley, highway, or other thoroughfare, unless such vehicle is so constructed as to prevent its contents from dripping, sifting, leaking, or otherwise escaping there from so as to create conditions which result in fugitive dust. This section applies only to the cargo any vehicle may be conveying and mud tracked by the vehicle.

C.7 Stack Height [326 IAC 1-7]

The Permittee shall comply with the applicable provisions of 326 IAC 1-7 (Stack Height Provisions), for all exhaust stacks through which a potential (before controls) of twenty-five (25) tons per year or more of particulate matter or sulfur dioxide is emitted. The provisions of 326 IAC 1-7-1(3), 326 IAC 1-7-2, 326 IAC 1-7-3(c) and (d), 326 IAC 1-7-4, and 326 IAC 1-7-5(a), (b), and (d) are not federally enforceable.

C.8 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

The Permittee shall comply with the applicable requirements of 326 IAC 14-10, 326 IAC 18, and 40 CFR 61.140.

Testing Requirements [326 IAC 2-7-6(1)]

C.9 Performance Testing [326 IAC 3-6]

- (a) All required testing shall be performed according to the provisions of 326 IAC 3-6 (Source Sampling Procedures), except as provided elsewhere in this permit, utilizing any applicable procedures and analysis methods specified in 40 CFR 51, 40 CFR 60, 40 CFR 61, 40 CFR 63, 40 CFR 75, or other procedures approved by IDEM, OAQ.

A test protocol, except as provided elsewhere in this permit, shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

no later than thirty-five (35) days prior to the intended test date. The protocol submitted by the Permittee does not require certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

- (b) The Permittee shall notify IDEM, OAQ of the actual test date at least fourteen (14) days prior to the actual performance test date. The notification submitted by the Permittee does not require certification by the "responsible official" as defined by 326 IAC 2-7-1(34).
- (c) Pursuant to 326 IAC 3-6-4(b), all test reports must be received by IDEM, OAQ not later than forty-five (45) days after the completion of the testing. An extension may be granted by IDEM, OAQ, if the Permittee submits to IDEM, OAQ, a reasonable written explanation not later than five (5) days prior to the end of the initial forty-five (45) day period.

Compliance Requirements [326 IAC 2-1.1-11]

C.10 Compliance Requirements [326 IAC 2-1.1-11]

The commissioner may require stack testing, monitoring, or reporting at any time to assure compliance with all applicable requirements by issuing an order under 326 IAC 2-1.1-11. Any monitoring or testing shall be performed in accordance with 326 IAC 3 or other methods approved by the commissioner or the U. S. EPA.

Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]

C.11 Compliance Monitoring [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

Unless otherwise specified in this permit, all monitoring and record keeping requirements not already legally required shall be implemented within ninety (90) days after the effective date of this permit. If required by Section D, the Permittee shall be responsible for installing any necessary equipment and initiating any required monitoring related to that equipment. If due to circumstances beyond its control, that equipment cannot be installed and operated within ninety (90) days, the Permittee may extend the compliance schedule related to the equipment for an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

in writing, prior to the end of the initial ninety (90) day compliance schedule, with full justification of the reasons for the inability to meet this date.

The notification which shall be submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

Unless otherwise specified in the approval for the new emission unit(s), compliance monitoring for new emission units or emission units added through a source modification shall be implemented when operation begins.

C.12 Maintenance of Continuous Opacity Monitoring Equipment [326 IAC 2-7-5(3)(A)(iii)]

- (a) The Permittee shall calibrate, maintain, and operate all necessary continuous opacity monitoring systems (COMS) and related equipment. For a boiler, the COMS shall be in operation at all times that the induced draft fan is in operation.
- (b) All (COMS) shall meet the performance specifications of 40 CFR 60, Appendix B, Performance Specification No. 1, and are subject to monitor system certification requirements pursuant to 326 IAC 3-5.
- (c) In the event that a breakdown of a COMS occurs, a record shall be made of the time and reason of the breakdown and efforts made to correct the problem.
- (d) Whenever a COMS is malfunctioning or is down for maintenance, or repairs for a period of twenty-four (24) hours or more and a backup COMS is not online within twenty-four (24) hours of shutdown or malfunction of the primary COMS, the Permittee shall provide a certified opacity reader, who may be an employee of the Permittee or independent contractors, to self-monitor the emissions from the emission unit stack when plume conditions allow.
 - (1) When plume conditions allow, visible emission readings shall be performed in accordance with 40 CFR 60, Appendix A, Method 9, for a minimum of five (5) consecutive six (6) minute averaging periods beginning not more than twenty-four (24) hours after the start of the malfunction or down time.
 - (2) When plume conditions allow, Method 9 opacity readings shall be repeated for a minimum of five (5) consecutive six (6) minute averaging periods at least twice per day during daylight operations, with at least four (4) hours between each set of readings, until a COMS is online.
 - (3) Method 9 readings may be discontinued once a COMS is online.
 - (4) Any opacity exceedances determined by Method 9 readings shall be reported with the Quarterly Opacity Exceedances Reports.
 - (5) When plume conditions do not allow Method 9 visible emission readings, Permittee shall keep a record of the period during which readings could not be taken and the reason why such readings could not be taken.
- (e) Nothing in this permit shall excuse the Permittee from complying with the requirements to operate a continuous opacity monitoring system pursuant to 326 IAC 3-5.

C.13 Monitoring Methods [326 IAC 3] [40 CFR 60] [40 CFR 63]

Any monitoring or testing required by Section D of this permit shall be performed according to the provisions of 326 IAC 3, 40 CFR 60 Appendix A, 40 CFR 60 Appendix B, 40 CFR 63, or other approved methods as specified in this permit.

C.14 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

- (a) All instruments used for monitoring and testing shall have a scale such that the expected maximum reading for the normal range shall be no less than twenty percent (20%) of full scale.
- (b) The Permittee may request that the IDEM, OAQ approve the use of an instrument that does not meet the above specifications provided the Permittee can demonstrate that an alternative instrument specification will adequately ensure compliance with permit conditions requiring the measurement of the parameters.

Corrective Actions and Response Steps [326 IAC 2-7-5] [326 IAC 2-7-6]

C.15 Emergency Reduction Plans [326 IAC 1-5-2] [326 IAC 1-5-3]

Pursuant to 326 IAC 1-5-2 (Emergency Reduction Plans; Submission):

- (a) The Permittee shall prepare written emergency reduction plans (ERPs) consistent with safe operating procedures.
- (b) These ERPs shall be submitted for approval to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251
- within ninety (90) days after the effective date of this permit.
- The ERP does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).
- (c) If the ERP is disapproved by IDEM, OAQ, the Permittee shall have an additional thirty (30) days to resolve the differences and submit an approvable ERP.
- (d) These ERPs shall state those actions that will be taken, when each episode level is declared, to reduce or eliminate emissions of the appropriate air pollutants.
- (e) Said ERPs shall also identify the sources of air pollutants, the approximate amount of reduction of the pollutants, and a brief description of the manner in which the reduction will be achieved.
- (f) Upon direct notification by IDEM, OAQ,, that a specific air pollution episode level is in effect, the Permittee shall immediately put into effect the actions stipulated in the approved ERP for the appropriate episode level. [326 IAC 1-5-3]

C.16 Risk Management Plan [326 IAC 2-7-5(12)] [40 CFR 68]

If a regulated substance as defined in 40 CFR 68, is present at a source in more than a threshold quantity, the Permittee must comply with the applicable requirements at 40 CFR 68.

C.17 Response to Excursions or Exceedances [326 IAC 2-7-5] [326 IAC 2-7-6]

(D) If the Permittee is notified by the Permitting Authority that the Permittee's emissions exceed the level specified in any condition of this permit, the Permittee shall take appropriate response actions. The Permittee shall submit a description of these response actions to IDEM, OAQ, within thirty (30) days of receipt of the test results. The Permittee shall take appropriate action to minimize excess emissions from the affected facility, for the pollutant for which the test was performed, while the response actions are being implemented.

(D) If the Permittee is notified by the Permitting Authority that the Permittee's emissions exceed the level specified in any condition of this permit, the Permittee shall take appropriate response actions. The Permittee shall submit a description of these response actions to IDEM, OAQ, within thirty (30) days of receipt of the test results. The Permittee shall take appropriate action to minimize excess emissions from the affected facility, for the pollutant for which the test was performed, while the response actions are being implemented.

(1) The Permittee shall take appropriate response actions;

(2) The Permittee shall submit a description of these response actions to IDEM, OAQ, within thirty (30) days of receipt of the test results; and

(3) The Permittee shall take appropriate action to minimize excess emissions from the affected facility, for the pollutant for which the test was performed, while the response actions are being implemented.

(D) If the Permittee is notified by the Permitting Authority that the Permittee's emissions exceed the level specified in any condition of this permit, the Permittee shall take appropriate response actions. The Permittee shall submit a description of these response actions to IDEM, OAQ, within thirty (30) days of receipt of the test results. The Permittee shall take appropriate action to minimize excess emissions from the affected facility, for the pollutant for which the test was performed, while the response actions are being implemented.

(1) The Permittee shall take appropriate response actions;

(2) The Permittee shall submit a description of these response actions to IDEM, OAQ, within thirty (30) days of receipt of the test results; and

(3) The Permittee shall take appropriate action to minimize excess emissions from the affected facility, for the pollutant for which the test was performed, while the response actions are being implemented.

(D) If the Permittee is notified by the Permitting Authority that the Permittee's emissions exceed the level specified in any condition of this permit, the Permittee shall take appropriate response actions. The Permittee shall submit a description of these response actions to IDEM, OAQ, within thirty (30) days of receipt of the test results. The Permittee shall take appropriate action to minimize excess emissions from the affected facility, for the pollutant for which the test was performed, while the response actions are being implemented.

(D) If the Permittee is notified by the Permitting Authority that the Permittee's emissions exceed the level specified in any condition of this permit, the Permittee shall take appropriate response actions. The Permittee shall submit a description of these response actions to IDEM, OAQ, within thirty (30) days of receipt of the test results. The Permittee shall take appropriate action to minimize excess emissions from the affected facility, for the pollutant for which the test was performed, while the response actions are being implemented.

(1) The Permittee shall take appropriate response actions;

(2) The Permittee shall submit a description of these response actions to IDEM, OAQ, within thirty (30) days of receipt of the test results; and

(3) The Permittee shall take appropriate action to minimize excess emissions from the affected facility, for the pollutant for which the test was performed, while the response actions are being implemented.

C.18 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5] [326 IAC 2-7-6]

(a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this permit exceed the level specified in any condition of this permit, the Permittee shall take appropriate response actions. The Permittee shall submit a description of these response actions to IDEM, OAQ, within thirty (30) days of receipt of the test results. The Permittee shall take appropriate action to minimize excess emissions from the affected facility, for the pollutant for which the test was performed, while the response actions are being implemented.

(b) A retest to demonstrate compliance shall be performed within one hundred twenty (120) days of receipt of the original test results. Should the Permittee demonstrate to IDEM, OAQ that retesting in one hundred twenty (120) days is not practicable, IDEM, OAQ may extend the retesting deadline.

- (c) IDEM, OAQ reserves the authority to take any actions allowed under law in response to noncompliant stack tests.

The response action documents submitted pursuant to this condition do require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

C.19 Emission Statement [326 IAC 2-7-5(3)(C)(iii)][326 IAC 2-7-5(7)][326 IAC 2-7-19(c)][326 IAC 2-6]

- (a) Pursuant to 326 IAC 2-6-3(a)(1), the Permittee shall submit by July 1 of each year an emission statement covering the previous calendar year. The emission statement shall contain, at a minimum, the information specified in 326 IAC 2-6-4(c) and shall meet the following requirements:

- (1) Indicate estimated actual emissions of all pollutants listed in 326 IAC 2-6-4(a);
- (2) Indicate estimated actual emissions of regulated pollutants as defined by 326 IAC 2-7-1(32) ("Regulated pollutant which is used only for purposes of Section 19 of this rule") from the source, for purposes of Part 70 fee assessment.

The statement must be submitted to:

Indiana Department of Environmental Management
Technical Support and Modeling Section, Office of Air Quality
100 North Senate Avenue
MC 61-50 IGCN 1003
Indianapolis, Indiana 46204-2251

The emission statement does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

- (b) The emission statement required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.

C.20 General Record Keeping Requirements [326 IAC 2-7-5(3)][326 IAC 2-7-6][326 IAC 2-2][326 IAC 2-3]

- (a) Records of all required monitoring data, reports and support information required by this permit shall be retained for a period of at least five (5) years from the date of monitoring sample, measurement, report, or application. These records shall be physically present or electronically accessible at the source location for a minimum of three (3) years. The records may be stored elsewhere for the remaining two (2) years as long as they are available upon request. If the Commissioner makes a request for records to the Permittee, the Permittee shall furnish the records to the Commissioner within a reasonable time.
- (b) Unless otherwise specified in this permit, all record keeping requirements not already legally required shall be implemented within ninety (90) days of the effective date of this permit.
- (c) If there is a reasonable possibility that a "project" (as defined in 326 IAC 2-2-1 (qq) and/or 326 IAC 2-3-1 (ll)) at an existing emissions unit, other than projects at a Clean Unit (or at a source with Plant-wide Applicability Limitation (PAL)), which is not part of a "major modification" (as defined in 326 IAC 2-2-1 (ee) and/or 326 IAC 2-3-1 (z)) may result in significant emissions increase and the Permittee elects to utilize the "projected actual emissions" (as defined in 326 IAC 2-2-1 (rr) and/or 326 IAC 2-3-1 (mm)), the Permittee shall comply with following:

- (1) Before beginning actual construction of the "project" (as defined in 326 IAC 2-2-1 (qq) and/or 326 IAC 2-3-1 (ll)) at an existing emissions unit, document and maintain the following records:
 - (A) A description of the project.
 - (B) Identification of any emissions unit whose emissions of a regulated new source review pollutant could be affected by the project.
 - (C) A description of the applicability test used to determine that the project is not a major modification for any regulated NSR pollutant, including:
 - (i) Baseline actual emissions;
 - (ii) Projected actual emissions;
 - (iii) Amount of emissions excluded under section 326 IAC 2-2-1(rr)(2)(A)(iii) and/or 326 IAC 2-3-1(mm)(2)(A)(iii); and
 - (iv) An explanation for why the amount was excluded, and any netting calculations, if applicable.
- (2) Monitor the emissions of any regulated NSR pollutant that could increase as a result of the project and that is emitted by any existing emissions unit identified in (1)(B) above; and
- (3) Calculate and maintain a record of the annual emissions, in tons per year on a calendar year basis, for a period of five (5) years following resumption of regular operations after the change, or for a period of ten (10) years following resumption of regular operations after the change if the project increases the design capacity of or the potential to emit that regulated NSR pollutant at the emissions unit.

C.21 General Reporting Requirements [326 IAC 2-7-5(3)(C)] [326 IAC 2-1.1-11][326 IAC 2-2]
[326 IAC 2-3]

- (a) The Permittee shall submit the attached Quarterly Deviation and Compliance Monitoring Report or its equivalent. Any deviation from permit requirements, the date(s) of each deviation, the cause of the deviation, and the response steps taken must be reported. This report shall be submitted within thirty (30) days of the end of the reporting period. The Quarterly Deviation and Compliance Monitoring Report shall include the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).
- (b) The report required in (a) of this condition and reports required by conditions in Section D of this permit shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251
- (c) Unless otherwise specified in this permit, any notice, report, or other submission required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.
- (d) Unless otherwise specified in this permit, all reports required in Section D of this permit shall be submitted within thirty (30) days of the end of the reporting period. All reports do require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

- (e) The first report shall cover the period commencing on the effective date of this permit and ending on the last day of the reporting period. Reporting periods are based on calendar years, unless otherwise specified in this permit. For the purpose of this permit, "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.
- (f) If the Permittee is required to comply with the recordkeeping provisions of (c) in Section C- General Record Keeping Requirements for any "project" (as defined in 326 IAC 2-2-1 (qq) and/or 326 IAC 2-3-1 (ll)) at an existing Electric Utility Steam Generating Unit, then for that project the Permittee shall:
 - (1) Submit to IDEM, OAQ a copy of the information required by (c)(1) in Section C- General Record Keeping Requirements
 - (2) Submit a report to IDEM, OAQ within sixty (60) days after the end of each year during which records are generated in accordance with (c)(2) and (3) in Section C- General Record Keeping Requirements. The report shall contain all information and data describing the annual emissions for the emissions units during the calendar year that preceded the submission of report.

Reports required in this part shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

- (g) If the Permittee is required to comply with the recordkeeping provisions of (c) in Section C - General Record Keeping Requirements for any "project" (as defined in 326 IAC 2-2-1 (qq) and/or 326 IAC 2-3-1 (ll)) at an existing emissions unit other than Electric Utility Steam Generating Unit, and the project meets the following criteria, then the Permittee shall submit a report to IDEM, OAQ:
 - (1) The annual emissions, in tons per year, from the project identified in (c)(1) in Section C- General Record Keeping Requirements exceed the baseline actual emissions, as documented and maintained under Section C- General Record Keeping Requirements (c)(1)(C)(i), by a significant amount, as defined in 326 IAC 2-2-1 (xx) and/or 326 IAC 2-3-1 (qq), for that regulated NSR pollutant, and
 - (2) The emissions differ from the preconstruction projection as documented and maintained under Section C- General Record Keeping Requirements (c)(1)(C)(ii).
- (h) The report for project at an existing emissions unit other than Electric Utility Steam Generating Unit shall be submitted within sixty (60) days after the end of the year and contain the following:
 - (1) The name, address, and telephone number of the major stationary source.
 - (2) The annual emissions calculated in accordance with (c)(2) and (3) in Section C- General Record Keeping Requirements.
 - (3) The emissions calculated under the actual-to-projected actual test stated in 326 IAC 2-2-2(d)(3) and/or 326 IAC 2-3-2(c)(3).

(4) Any other information that the Permittee deems fit to include in this report,

Reports required in this part shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

- (i) The Permittee shall make the information required to be documented and maintained in accordance with (c) in Section C- General Record Keeping Requirements available for review upon a request for inspection by IDEM, OAQ. The general public may request this information from the IDEM, OAQ under 326 IAC 17.1.

Stratospheric Ozone Protection

C.22 Compliance with 40 CFR 82 and 326 IAC 22-1

Pursuant to 40 CFR 82 (Protection of Stratospheric Ozone), Subpart F, except as provided for motor vehicle air conditioners in Subpart B, the Permittee shall comply with the standards for recycling and emissions reduction:

- (a) Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to 40 CFR 82.156.
- (b) Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to 40 CFR 82.158.
- (c) Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161.
- (d) Pursuant to 40 CFR 82, Subpart E (The Labeling of Products Using Ozone-Depleting Substances), all containers in which a Class I or Class II substance is stored or transported and all products containing a Class I substance shall be labeled as required under 40 CFR Part 82.

Ambient Monitoring Requirements [326 IAC 7-3]

C.23 Ambient Monitoring [326 IAC 7-3]

- (a) The Permittee shall operate continuous ambient sulfur dioxide air quality monitors and a meteorological data acquisition system according to a monitoring plan submitted to the commissioner for approval. The monitoring plan shall include requirements listed in 326 IAC 7-3-2(a)(1), 326 IAC 7-3-2(a)(2) and 326 IAC 7-3-2(a)(3).
- (b) The Permittee and other operators subject to the requirements of this rule, located in the same county, may submit a joint monitoring plan to satisfy the requirements of this rule. [326 IAC 7-3-2(c)]
- (c) The Permittee may petition the commissioner for an administrative waiver of all or some of the requirements of 326 IAC 7-3 if such owner or operator can demonstrate that ambient monitoring is unnecessary to determine continued maintenance of the sulfur dioxide ambient air quality standards in the vicinity of the source. [326 IAC 7-3-2(d)]

SECTION D.1 FACILITY OPERATION CONDITIONS - Coal Fired Boiler Units 7 and 8

Facility Description [326 IAC 2-7-5(15)]

- (a) One (1) cyclone coal-fired boiler, identified as Unit 7, with construction completed in 1962, with a design heat input capacity of 1638 million Btu per hour, with an electrostatic precipitator (ESP) system for control of particulate matter. A wet limestone flue gas desulfurization system serves both Unit 7 and 8 for control of sulfur dioxide. Natural gas and/or No. 2 fuel oil can be fired during startup, shutdown, and malfunctions; the unit can also generate electricity while combusting natural gas only. Unit 7 has continuous emissions monitoring systems (CEMS) for nitrogen oxides (NO_x) and for sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Scrubbed emissions from Units 7 and 8 are exhausted through Stack CS001. Non-scrubbed emissions from Units 7 and 8 are exhausted through the bypass stack, Stack CS002.
- (b) One (1) cyclone coal-fired boiler, identified as Unit 8, with construction completed in 1968, with a design heat input capacity of 3374 million Btu per hour, with an electrostatic precipitator (ESP) system for control of particulate matter. A wet limestone flue gas desulfurization system serves both Unit 7 and 8 for control of sulfur dioxide. Natural gas and/or No. 2 fuel oil can be fired during startup, shutdown, and malfunctions; the unit can also generate electricity while combusting natural gas only. Unit 8 is equipped with a selective catalytic reduction (SCR) system and in 2011 was also authorized to install up to four (4) natural gas fired flue gas reheating Duct Burners each with a maximum design heat input capacity of 40 million Btu per hour. Unit 8 has continuous emissions monitoring systems (CEMS) for nitrogen oxides (NO_x) and for sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Scrubbed emissions from Units 7 and 8 are exhausted through Stack CS001. Non-scrubbed emissions from Units 7 and 8 are exhausted through the bypass stack, Stack CS002.

Insignificant Activities [326 IAC 2-7-1(21)]:

- (h) Other activities or categories not previously identified with potential, uncontrolled emissions equal to or less than thresholds require listing only: Pb 0.6 ton per year or 3.29 pounds per day, SO₂ 5 pounds per hour or 25 pounds per day, NO_x 5 pounds per hour or 25 pounds per day, CO 25 pounds per day, PM 5 pounds per hour or 25 pounds per day, VOC 3 pounds per hour or 15 pounds per day; including evaporation of boiler chemical cleaning liquids.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.1.0 Prevention Significant Deterioration (PSD) Minor Limits [326 IAC 2-2]

Pursuant to SSM 127-30156-00002, in order to render the requirements of 326 IAC 2-2 (PSD) not applicable:

The natural gas usage for the proposed flue gas reheating duct burners at Unit 8 shall be less than 782 Million Cubic Foot (MMCF) per twelve (12) consecutive month period, with compliance determined at the end of each month, and the NO_x emissions shall not exceed 102 pounds per MMCF of natural gas.

Compliance with these limits will ensure that the potential to emit of NO_x for the proposed burners will be less than 40 tons per year and render the requirements of 326 IAC 2-2 (PSD) not applicable to this modification.

D.1.1 Sulfur Dioxide (SO₂) [326 IAC 7-4-14]

- (a) Pursuant to PC (64) 1816, issued March 15, 1990, the sulfur dioxide (SO₂) emissions from the flue gas desulfurization system stack shall be limited to 1.2 pound per million Btu's of energy input based on a thirty (30) day rolling weighted average.

- (b) Pursuant to 326 IAC 7-4-14(2)(A) (Porter County Sulfur Dioxide Emission Limitations), the SO₂ emissions from Unit 7 and Unit 8 shall not exceed 6.0 pounds per million Btu's (lbs/MMBtu) based on a thirty (30) day rolling weighted average when the FGD system is not in use.

D.1.2 Particulate Emission Limitations for Sources of Indirect Heating [326 IAC 6-2-2]

Pursuant to 326 IAC 6-2-2 (Particulate Emission Limitations for Sources of Indirect Heating: Emission limitations for facilities specified in 326 IAC 6-2-1(b)), the PM emissions from Units 7 and 8 shall not exceed 0.22 pound per million Btu heat input (lb/MMBtu). This limitation was calculated using the following equation:

$$Pt = \frac{0.87}{Q^{0.16}} \quad \text{Where } Q = \text{total source capacity (MMBtu/hr)}$$

Pursuant to 326 IAC 6-2-2(b), the emission limitations for those indirect heating facilities which were existing and in operation on or before June 8, 1972, shall be calculated using the above equation where Q shall reflect the total source capacity on June 8, 1972. For Units 7 and 8, Q = 5015.18 MMBtu/hr (1638 MMBtu/hr + 3374 MMBtu/hr + 2.4 MMBtu/hr main office building boiler + 0.78 MMBtu/hr EPSC building boiler).

D.1.3 Startup, Shutdown and Other Opacity Limits [326 IAC 5-1-3]

- (a) Pursuant to 326 IAC 5-1-3(e) (Temporary Alternative Opacity Limitations), the following applies to both Units 7 and 8:
- (1) When building a new fire in a boiler, opacity may exceed the applicable limitation established in 326 IAC 5-1-2 for a period not to exceed a cumulative total of one (1) hour (ten (10) six (6)-minute averaging periods) during the startup period, or until the flue gas temperature reaches two hundred fifty (250) degrees Fahrenheit at the inlet of the electrostatic precipitator, whichever occurs first.
 - (2) When shutting down a boiler, opacity may exceed the applicable limitation established in 326 IAC 5-1-2 for a period not to exceed a total of one (1) hour (ten (10) six (6)-minute averaging periods) during the shutdown period.
 - (3) Operation of the electrostatic precipitator is not required during these times.
- (b) When removing ashes from the fuel bed or furnace in a boiler or blowing tubes, opacity may exceed the applicable limit established in 326 IAC 5-1-2 and stated in Section C - Opacity. However, opacity levels shall not exceed sixty percent (60%) for any six (6)-minute averaging period and opacity in excess of the applicable limit shall not continue for more than one (1) six (6)-minute averaging period in any sixty (60) minute period. The averaging periods in excess of the limit set in 326 IAC 5-1-2 shall not be permitted for more than three (3) six (6)-minute averaging periods in a twelve (12) hour period. [326 IAC 5-1-3(b)]
- (c) If a facility cannot meet the opacity limitations of 326 IAC 5-1-3(b), the Permittee may submit a written request to IDEM, OAQ, for a temporary alternative opacity limitation in accordance with 326 IAC 5-1-3(d). The Permittee must demonstrate that the alternative limit is needed and justifiable.

Compliance Determination Requirements

D.1.4 Testing Requirements [326 IAC 2-7-6(1),(6)] [326 IAC 2-1.1-11]

By December 31 of the second calendar year following the most recent stack test, or within 180 days after the effective date of this permit, whichever is later, compliance with the PM limitation for Boilers 7 and 8 shall be determined by performance stack tests conducted using methods as approved by the Commissioner. This testing shall be repeated by December 31 of every second calendar year following this valid compliance demonstration. Testing shall be conducted in accordance with Section C- Performance Testing.

For the purpose of this permit, "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.

D.1.5 Operation of Electrostatic Precipitator [326 IAC 2-7-6(6)]

Except as otherwise provided by statute or rule or in this permit, the electrostatic precipitator (ESP) for a unit shall be operated at all times that coal is being combusted in that unit.

D.1.6 Continuous Emissions Monitoring [326 IAC 3-5] [326 IAC 7-2]

- (a) Pursuant to 326 IAC 3-5 (Continuous Monitoring of Emissions) and PC (64) 1816, issued March 15, 1990, continuous emission monitoring systems for Units 7 and 8 shall be calibrated, maintained, and operated for measuring opacity, SO₂ after the scrubber, NO_x, and either CO₂ or O₂ after the scrubber, which meet the performance specifications of 326 IAC 3-5-2.
- (b) Pursuant to PC (64) 1816, the opacity monitors shall be located in the individual unit ducts downstream of the ESP's but upstream of the FGD system combined flow duct for the scrubbed flue gas exhausting through Stack CS001 and in the stack for the flue gas exhausted through Stack CS002 in locations that meet the EPA CEM location guidelines. Data from these continuous opacity monitors shall not be combined but rather shall be recorded and reported separately.
- (c) Pursuant to PC (64) 1816, a separate 30-day rolling weighted average for SO₂ shall be maintained for the FGD stack and the previously existing Bailly station stack. Each day for which there is a period of more than one hour during which either stack is in use for the purpose of venting emissions from one or both of the Bailly Station units shall be included (on a weighted basis) in the 30 day rolling weighted average for that stack.
- (d) Pursuant to PC (64) 1816, the 30-day rolling weighted average SO₂ emission rates shall be determined by using the continuous emission monitor data to calculate daily SO₂ emission rates. Excess hourly average emission rates due to startup or shutdown may be excluded from the calculation of the daily average but shall be reported on a quarterly basis.
- (e) Pursuant to 326 IAC 7-2-1(g) for SO₂, continuous emission monitoring data collected and reported pursuant to 326 IAC 3-5 shall be used as the means for determining compliance with the emission limitations in 326 IAC 7. The other requirements of 326 IAC 7-2 shall not apply.
- (f) All continuous emission monitoring systems are subject to monitor system certification requirements pursuant to 326 IAC 3-5-3.
- (g) Nothing in this permit shall excuse the Permittee from complying with the requirements to operate a continuous emission monitoring system pursuant to 326 IAC 3-5, 326 IAC 10-4, or 40 CFR 75.

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.1.7 Transformer-Rectifier (T-R) Sets [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- (a) The ability of the ESP to control particulate emissions shall be monitored once per day, when the unit is in operation, by measuring and recording the number of T-R sets in service and the primary and secondary voltages and the currents of the T-R sets.
- (b) Reasonable response steps shall be taken in accordance with Section C - Response to Excursions or Exceedances whenever a combined total (considering the T-R sets at both ESPs) of more than (5) T-R sets are not in service. If Unit 7 and its T-R sets are not in operation, then reasonable response steps shall be taken in accordance with Section C - Response to Excursions or Exceedances whenever more than five (5) Unit 8 T-R sets are not in service. However, if Unit 8 and its T-R sets are not in operation, then reasonable response steps shall be taken in accordance with Section C - Response to

Excursions or Exceedances whenever more than three (3) Unit 7 T-R sets are not in service. T-R set failure resulting in a response step obligation under the preceding sentences is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances, shall be considered a deviation from this permit.

D.1.8 Opacity Readings [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- (a) In the event of emissions exceeding thirty percent (30%) average opacity for three (3) consecutive six (6) minute averaging periods during a period when the FGD system is not operating, appropriate response steps shall be taken in accordance with Section C - Response to Excursions or Exceedances such that the cause(s) of the excursion are identified and corrected and opacity levels are brought back below thirty percent (30%). Examples of expected response steps include, but are not limited to, boiler loads being reduced, adjustment of flue gas conditioning rate, and ESP T-R sets being turned to service.
- (b) Opacity readings in excess of thirty percent (30%) but not exceeding the opacity limit for the unit are not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances when opacity exceeds the level specified in (a) of this condition, shall be considered a deviation from this permit.
- (c) The Permittee may request that the IDEM, OAQ approve a different opacity trigger level than the one specified in (a) and (b) of this condition, provided the Permittee can demonstrate, through stack testing or other appropriate means, that a different opacity trigger level is appropriate for monitoring compliance with the applicable particulate matter mass emission limits.

D.1.9 SO₂ Monitoring System Downtime [326 IAC 2-7-6] [326 IAC 2-7-5(3)]

- (a) Whenever both the primary and back-up SO₂ continuous emission monitoring systems are malfunctioning or down for repairs or adjustments for twenty-four (24) hours or more, and the FGD system is in use, the Permittee shall monitor and record the feed rate to the absorber, pressure drop across the absorber, absorber pH, slurry density, percent (%) solids in slurry, and carbonate concentration in micromoles per liter, to demonstrate that the operation of the scrubber continues in a manner typical for the boiler load and sulfur content of the coal fired. Scrubber parametric monitoring readings shall be recorded at least twice per day until the primary CEMS or a backup CEMS is brought online.
- (b) Whenever both the primary and backup SO₂ continuous emission monitoring (CEM) systems are malfunctioning or down for repairs or adjustments for twenty-four (24) hour or more, and the FGD system is not in use, the following shall be used to provide information related to SO₂ emissions: either fuel sampling and fuel sample preparation and analysis shall be conducted as specified in 326 IAC 3-7-2(b) and (c), 326 IAC 3-7-2(d), and 326 IAC 3-7-2(e) or, alternatively, a portable analyzer, properly calibrated according to manufacturer specifications (such as manufacturer operating or maintenance manuals), shall be used to monitor SO₂ emissions. Pursuant to 326 IAC 3-7-3, other manual or non-ASTM automatic sampling and analysis procedures may be used upon a demonstration, submitted to the department for approval that such procedures provide sulfur dioxide emission estimates representative either of estimates based on coal sampling and analysis procedures specified in 326 IAC 3-7-2 or of continuous emissions monitoring.
- (c) Whenever the primary and backup SO₂ continuous emission monitoring systems are malfunctioning or down for repairs or adjustments for less than twenty-four (24) hours, the Permittee shall substitute an average of the quality-assured data from the hour immediately before and the hour immediately after the missing data period for each hour of missing data.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.1.10 Record Keeping Requirements

- (a) To document compliance with Section C - Opacity, Section C - Maintenance of Continuous Opacity Monitoring Equipment, and the particulate matter and opacity requirements in Conditions D.1.2, D.1.3, D.1.4, D.1.6, and D.1.7, the Permittee shall maintain records in accordance with (1) through (4) below. Records shall be complete and sufficient to establish compliance with the limits in Section C - Opacity and Conditions D.1.2 and D.1.3.
- (1) Data and results from the most recent stack test.
 - (2) All continuous opacity monitoring data, pursuant to 326 IAC 3-5-6.
 - (3) The results of all Method 9 visible emission readings taken during any periods of COMS downtime.
 - (4) All ESP parametric monitoring readings.
- (b) To document compliance with the SO₂ requirements in Conditions D.1.1(a) and (b), D.1.7, and D.1.10, the Permittee shall maintain records in accordance with (1) through (5) below. Records shall be complete and sufficient to establish compliance with the applicable SO₂ limit(s) as required in Conditions D.1.1, D.1.6, and D.1.9. The Permittee shall maintain records in accordance with (3) and (4) below during SO₂ CEM system downtime.
- (1) All SO₂ continuous emissions monitoring data, pursuant to 326 IAC 3-5-6, 326 IAC 7-2-1(g), and 40 CFR 60.45.
 - (2) All startup periods and shutdown periods.
 - (3) All scrubber parametric monitoring readings taken during any periods of CEM downtime, in accordance with Condition D.1.10(a).
 - (4) All fuel sampling and analysis data collected for or portable analyzer data for SO₂ CEMS downtime, in accordance with Condition D.1.9(b).
 - (5) Actual fuel usage during each SO₂ CEM downtime to the extent such data is required by D.1.9 to be obtained.
- (c) To document the compliance status with Condition D.1.0 - PSD Minor Limits, the Permittee shall maintain records of total natural gas usage for each month at the natural gas fired gas reheating duct burners in Unit 8.
- (d) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

D.1.11 Reporting Requirements

- (a) A quarterly report of opacity exceedances and a quarterly summary of the information to document compliance with Section C - Opacity and Conditions D.1.1(a) and (b), D.1.2, D.1.3, and D.1.6 shall be submitted to the address listed in Section C - General Reporting Requirements, of this permit, within thirty (30) days after the end of the quarter being reported. The report submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

Pursuant to Condition D.1.6(d) regarding the reporting of 30-day rolling weighted average emission rates for SO₂, the quarterly report for SO₂ shall explain whether any excess 24 hour average emission rates due to startup and shutdown were excluded from the compliance determination.

(b) Pursuant to 326 IAC 3-5-7(5), reporting of continuous monitoring system instrument downtime, except for zero (0) and span checks, which shall be reported separately, shall include the following:

- (1) Date of downtime.
- (2) Time of commencement.
- (3) Duration of each downtime.
- (4) Reasons for each downtime.
- (5) Nature of system repairs and adjustments.

The report submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

(c) A quarterly summary of the information to document the compliance status with Condition D.1.0 shall be submitted, using the reporting forms located at the end of this permit, or their equivalent, not later than thirty (30) days following the end of each calendar quarter. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34). Section C - General Reporting Requirements contains the Permittee's obligations with regard to the reporting required by this condition.

SECTION D.2 FACILITY OPERATION CONDITIONS - Natural Gas Fired Boilers

Facility Description [326 IAC 2-7-5(15)]

- (c) Two (2) natural gas-fired boilers, identified as Auxiliary Boiler 1 and Auxiliary Boiler 2, with construction completed in 1980, each with a nominal heat input capacity of 99.9 million Btu per hour, both exhausting through Stack 5.

Insignificant Activities [326 IAC 2-7-1(21)]

- (a) Natural gas-fired combustion sources with heat input equal to or less than ten million (10,000,000) Btu per hour, including one (1) 2.4 million Btu per hour (MMBtu/hr) natural gas-fired main office building boiler installed after 1985, and one (1) 780,000 Btu per hour natural gas-fired boiler at the EPSC (the Electric Product Services Center building) installed in the 1990's, for building heat only.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.2.1 PSD Minor Limit [326 IAC 2-2-1]

Pursuant to 326 IAC 2-2-1 (PSD Requirements), the following limitations and standards shall be met:

- (a) In order to make the requirements of 326 IAC 2-2-1(x) and 326 IAC 2-2-1(jj) (PSD Requirements) not applicable to Auxiliary Boilers 1 and 2, the nitrogen oxides (NO_x) emissions from both of the auxiliary boilers shall be limited to less than 40 tons per twelve (12) consecutive month period. Compliance with this limit shall be determined at the end of each month.
- (b) The input of natural gas to both auxiliary boilers shall not exceed 285 MMCF per 12 consecutive month period, with compliance determined at the end of each month.
- (c) NO_x emissions shall not exceed 280 lb/MMCF.

D.2.2 Particulate Emission Limitations for Sources of Indirect Heating [326 IAC 6-2]

- (a) Pursuant to 326 IAC 6-2-1(b) and 326 IAC 6-2-2 (Particulate Emission Limitations for Sources of Indirect Heating: Emission Limitations for Facilities Specified in 326 IAC 6-2-1(b)), the particulate matter emissions from Auxiliary Boilers 1 and 2 shall not exceed 0.22 pound per million Btu heat input (lb/MMBtu). This limitation was calculated using the following equation:

$$Pt = \frac{0.87}{Q^{0.16}} \quad \text{Where } Q = \text{total source capacity (MMBtu/hr)}$$

Pursuant to 326 IAC 6-2-2(c), the emission limitations for those indirect heating facilities which began operation after June 8, 1972, and before September 21, 1983 shall be calculated using the above equation where Q includes the capacity for the facility in question and the capacities for those facilities which were previously constructed. For Auxiliary Boilers 1 and 2, Q = 1638 MMBtu/hr + 3374 MMBtu/hr + 2.4 MMBtu/hr + 0.78

$$\text{MMBTU/hr} + (2)(99.9 \text{ MMBTU/hr}) = 5214.98 \text{ MMBTU/hr.}$$

- (b) Pursuant to 326 IAC 6-2-4 (Particulate Emission Limitations for Sources of Indirect Heating: the PM emissions from the 2.4 MMBtu/hr main office building boiler and from the 0.78 MMBTU/hr EPSC building boiler shall not exceed 0.12 pound per million Btu heat input (lb/MMBtu). This limitation was calculated using the following equation:

$$Pt = \frac{1.09}{Q^{0.26}} \quad \text{Where } Q = \text{total source capacity (MMBtu/hr)}$$

Pursuant to 326 IAC 6-2-4(a), the emission limitations for those indirect heating facilities which were existing and in operation after September 12, 1983, shall be calculated using the above equation where Q shall reflect the total source heat input capacity.

D.2.3 Startup, Shutdown and Other Opacity Limits [326 IAC 5-1-3]

- (a) Pursuant to 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), the following applies:

When building a new fire in a boiler, or shutting down a boiler, opacity may exceed the applicable limit established in 326 IAC 5-1-2 and stated in Section C - Opacity. However, opacity levels shall not exceed sixty percent (60%) for any six (6)-minute averaging period. Opacity in excess of the applicable limit established in 326 IAC 5-1-2 shall not continue for more than two (2) six (6)-minute averaging periods in any twenty-four (24) hour period. [326 IAC 5-1-3(a)]

- (b) If a facility cannot meet the opacity limitations of 326 IAC 5-1-3(a), the Permittee may submit a written request to IDEM, OAQ, for a temporary alternative opacity limitation in accordance with 326 IAC 5-1-3(d). The Permittee must demonstrate that the alternative limit is needed and justifiable.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.2.4 Record Keeping Requirements

- (a) To document compliance with Condition D.2.1, the Permittee shall maintain records of the monthly natural gas usage for Auxiliary Boilers 1 and 2, in MMCF.
- (b) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

D.2.5 Reporting Requirements

A quarterly summary of the information to document compliance with Condition D.2.1 shall be submitted to the addresses listed in Section C - General Reporting Requirements, of this permit, using the reporting forms located at the end of this permit, or their equivalent, within thirty (30) days after the end of the quarter being reported.

SECTION D.3 FACILITY CONDITIONS - Internal Combustion Units

Facility Description [326 IAC 2-7-5(15)]

- (d) One (1) simple-cycle, natural gas-fired combustion turbine, identified as Unit 10, with construction completed in 1968, with a design heat input capacity of 600 million Btu per hour, exhausting to Stack 10.
- (e) One (1) 825 horsepower diesel starter engine for Unit 10 combustion turbine.

Insignificant Activities [326 IAC 2-7-1(21)]:

- (e) Emergency generators as follows: One (1) FGD system emergency quench pump powered by a 500 horsepower diesel generator.
- (f) Other emergency equipment as follows [326 IAC 7]:
 - (1) One (1) stationary fire pump (diesel-fired).
 - (2) One (1) Unit 10 emergency generator, using diesel as fuel, with a maximum capacity less than 1,600 horsepower.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards

D.3.1 Porter County Sulfur Dioxide Emission Limitations [326 IAC 7-4-14]

Pursuant to 326 IAC 7-4-14(2)(B), the Unit 10 combustion turbine shall fire natural gas only.

D.3.2 Sulfur Dioxide (SO₂) [326 IAC 7] [326 IAC 2]

- (a) Pursuant to 326 IAC 7-1.1-2 (Sulfur Dioxide Emission Limitations), the SO₂ emissions from the diesel-fired emergency generators and the diesel starter engine for Unit 10 shall not exceed 0.5 pounds per million Btu (lbs/MMBtu).
- (b) Pursuant to PC (64) 1816, issued March 15, 1990, the oil burned in the flue gas desulfurization (FGD) system emergency diesel generator shall have a maximum sulfur content of 0.3 percent (%).

Compliance Determination Requirements

D.3.3 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3] [326 IAC 7-2] [326 IAC 7-1.1-2]

Compliance with Condition D.3.2 shall be determined utilizing one of the following options:

- (a) Pursuant to 326 IAC 7-2-1(e) and 326 IAC 3-7-4, fuel sampling and analysis data shall be collected as follows:
 - (1) The Permittee may rely upon vendor analysis of fuel delivered, if accompanied by a vendor certification [326 IAC 3-7-4(b)]; or,
 - (2) The Permittee shall perform sampling and analysis of fuel oil samples in accordance with 326 IAC 3-7-4(a).

- (A) Oil samples shall be collected from the tanker truck load prior to transferring fuel to the storage tank; or
 - (B) Oil samples shall be collected from the storage tank immediately after each addition of fuel to the tank.
- (b) Compliance may also be determined by conducting a stack test for sulfur dioxide emissions from the engines and generators, using 40 CFR 60, Appendix A, Method 6 in accordance with the procedures in 326 IAC 3-6.

A determination of noncompliance pursuant to any of the methods specified in (a) or (b) above shall not be refuted by evidence of compliance pursuant to the other method.

Record Keeping and Reporting Requirement [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.3.4 Record Keeping Requirements

- (a) To document compliance with the requirements in Conditions D.3.2 and D.3.3, the Permittee shall maintain records of all fuel sampling and analysis data, pursuant to 326 IAC 7-2. Records shall be complete and sufficient to establish compliance with the limits in Condition D.3.2.
- (b) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

SECTION D.4

FACILITY CONDITIONS - Coal Handling

Facility Description [326 IAC 2-7-5(15)]

- (f) A coal storage and handling system for Units 7 and 8, constructed in 1962 and 1968, with a maximum throughput of 1000 tons of coal per hour, consisting of the following equipment:
- (1) One (1) railcar unloading station with particulate emissions controlled by enclosure and wet suppression.
 - (2) An enclosed conveyor system, with the transfer points underground or enclosed by buildings. A telescoping chute is used to drop coal to the storage pile(s).
 - (3) Coal storage pile(s), with fugitive dust emissions controlled by compaction.
- (g) Two (2) enclosed coal crushers, constructed before October 24, 1974 and reconstructed in 2003, each with a maximum throughput of 600 tons of coal per hour, exhausting through a baghouse.

Insignificant Activities [326 IAC 2-7-1(21)]:

- (d) Coal bunker and coal scale exhausts and associated dust collector vents. [326 IAC 6-3]

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.4.1 New Source Performance Standard (NSPS): Coal Preparation Plants [326 IAC 12] [40 CFR 60, Subpart Y]

Pursuant to 326 IAC 12 and 40 CFR 60, Subpart Y (Standards of Performance for Coal Preparation Plants) the exhaust from the following coal processing and handling equipment shall not exhibit opacity greater than or equal to twenty percent (20%) [40 CFR 60.252(c)]:

- (a) the coal crushers; and
- (b) any coal conveyors, beginning after the coal storage piles, which are replaced or reconstructed or have been replaced or reconstructed after October 24, 1974.

D.4.2 Particulate [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), allowable particulate emissions for the coal handling operations shall be calculated as follows:

- (a) Particulate shall not be emitted in excess of the amount shown in the table in 326 IAC 6-3-2(e). The allowable rate of emission shall be based on the process weight rate for the process.
- (b) Interpolation of the data in the table in 326 IAC 6-3-2(e) for process weight rates up to sixty thousand (60,000) pound per hour shall be accomplished by use of the equation:

$$E = 4.10 P^{0.67}$$

where E = rate of emission in pounds per hour, and
P = process weight rate in tons per hour.

- (c) Interpolation and extrapolation of the data in the table in 326 IAC 6-3-2(e) for Process weight rates in excess of sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 55.0 P^{0.11} - 40 \quad \text{where } E = \text{rate of emission in pounds per hour; and} \\ P = \text{process weight rate in tons per hour.}$$

- (d) When the process weight rate exceeds two hundred (200) tons per hour, the allowable emission may exceed that shown in the table in 326 IAC 6-3-2(e) provided the concentration of particulate in the discharge gases to the atmosphere is less than one-tenth (0.10) pound per one thousand (1,000) pounds of gases.

D.4.3 General Provisions Relating to NSPS [326 IAC 12-1] [40 CFR Part 60, Subpart A]

The provisions of 40 CFR Part 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the coal crushers and any conveyors, beginning after the coal storage piles, which are reconstructed or have been reconstructed after October 24, 1974, except when otherwise specified in 40 CFR Part 60, Subpart Y.

Compliance Determination Requirements

D.4.4 NSPS Test Methods and Procedures [326 IAC 2-7-6(1), (3), (6)] [326 IAC 2-1.1-11] [40 CFR 60.8] [40 CFR 60.46]

Within 60 days following January 20, 2004, the date on which the coal crushers achieved the maximum production rate at which they will be operated, the owner or operator shall conduct performance tests for NSPS Subpart Y for the crushers. Performance tests shall be conducted and data reduced in accordance with the test methods and procedures contained in 40 CFR 60.8 and 40 CFR 60.254 unless the Administrator approves an alternative in accordance with 40 CFR 60.8(b). [40 CFR 60.8]

D.4.5 NSPS Compliance Provisions [326 IAC 12] [40 CFR 60, Subpart Y]

Method 9 and the procedures in 40 CFR 60.11 shall be used to determine the opacity of the coal crusher emissions. [40 CFR 60.254(b)(2)]

D.4.6 Reporting Requirements [326 IAC 12-1] [40 CFR Part 60, Subpart A]

The owner or operator shall furnish the Administrator a written report of the results of the initial performance tests for NSPS Subpart Y and any subsequent performance tests required by the Administrator under section 114 of the Clean Air Act, in accordance with 40 CFR 60.8.

SECTION D.5 FACILITY OPERATION CONDITIONS - FGD System Material Handling

Facility Description [326 IAC 2-7-5(15)]

- (h) Material handling and storage facilities for the flue gas desulfurization system, with installation started in 1990 and completed in 1992, including the following:
- (1) Pneumatic conveyance of limestone to storage silos and from the silos to the scrubber, at a maximum throughput rate of 26.7 tons per hour.
 - (2) Pneumatic conveyance of hydrated lime to a storage silo and from the silo to the scrubber, at a maximum throughput rate of 4.8 tons per hour.
 - (3) Two (2) limestone storage silos, with a combined storage capacity of 2225 tons, each with a bin vent filter to recover the pneumatically conveyed material.
 - (4) One (1) hydrated lime storage silo, with a storage capacity of 115 tons, with a bin vent filter to recover the pneumatically conveyed material.
 - (5) Dewatered gypsum is transferred via an enclosed conveyor to an enclosed storage building at a maximum throughput rate of 48.8 tons per hour. Gypsum is transferred to trucks by front end loader in the building and taken offsite.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.5.1 Particulate [326 IAC 6-3-2]

- (a) Pursuant to PC (64) 1816, issued March 15, 1990, particulate matter emissions from each of the limestone and lime bin vent filters shall be limited to 0.02 grains per dry acfm.
- (b) Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), the particulate emission rate from the limestone handling system shall not exceed 37.0 pounds per hour when operating at a process weight rate of 26.7 tons per hour, and the particulate emission rate from the hydrated lime handling system shall not exceed 11.7 pounds per hour when operating at a process weight rate of 4.8 tons per hour. These pounds per hour limitations were calculated using the following equation:

Interpolation of the data for the process weight rate up to sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 4.10 P^{0.67} \quad \text{where } E = \text{rate of emission in pounds per hour and} \\ P = \text{process weight rate in tons per hour.}$$

D.5.2 Material Handling Requirements [326 IAC 2]

- (a) Pursuant to PC (64) 1816, issued March 15, 1990, the limestone to be used in the flue gas desulfurization system shall be pulverized to the necessary size off-site and received on-site in a ready to use condition. Lime and limestone shall be delivered to the site in enclosed pneumatic trucks and unloaded pneumatically into storage silos equipped with bin vent filters.
- (b) Dewatered gypsum will be transferred via an enclosed conveyor to an enclosed storage building.

D.5.3 Fugitive Dust Plan [326 IAC 2]

Pursuant to PC (64) 1816, issued March 15, 1990, in order to control fugitive particulate emissions associated with the flue gas desulfurization (FGD) system, the following procedures will be implemented to control fugitive particulate emissions from vehicle resuspension:

- (a) A map illustrating the roadways required to be watered is attached to this permit as Appendix A. The roadways indicated on the map will be cleaned by water flushing at an applied rate of 5,000 gallons per mile on a once per week basis.
- (b) A high pressure water flushing truck will be used to wash the roadway surface.
- (c) The roadway will not be flushed under the following conditions:
 - (1) A minimum of 0.1 inch of rainfall occurred during the preceding 24-hour period. The amount of rainfall will be determined by measurements representative of onsite conditions.
 - (2) It is raining at the time of the scheduled water flushing.
 - (3) The roadway is covered with snow or ice.
 - (4) During periods of freezing temperatures. This condition will be determined by onsite temperature measurements.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.5.4 Record Keeping Requirements

- (a) To document compliance with Section C - Opacity and Condition D.5.3, the Permittee shall maintain records of the control procedures for fugitive emissions from vehicle resuspension.
- (b) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

SECTION D.6 FACILITY OPERATION CONDITIONS - Fly Ash Handling

Facility Description [326 IAC 2-7-5(15)]

- (i) Fly ash handling, installed in 1981 or 1982, including the following:
- (1) Vacuum conveyance of fly ash to storage silos with particulate emissions controlled by bin vent filter, with a maximum throughput rate of 10.2 tons per hour.
 - (2) Two (2) fly ash silo unloading with silo collector bag filters and silo bin vent bag filters. Each silo has wet and dry unloaders, each with a maximum throughput rate of 500 tons/hr, with particulate emissions from each controlled by the use of a telescoping chute with a vacuum system and a storage silo bin vent filter when the ash is being loaded dry, and controlled by the use of water spray mixed with the ash when the ash is being loaded wet.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.6.1 Particulate [326 IAC 6-3-2]

- (a) Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), the particulate emission rate from the fly ash conveying system shall not exceed 19.4 pounds per hour when operating at a process weight rate of 10.2 tons per hour. The pounds per hour limitation was calculated using the following equation:

Interpolation of the data for the process weight rate up to sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 4.10 P^{0.67} \quad \text{where } E = \text{rate of emission in pounds per hour and} \\ P = \text{process weight rate in tons per hour.}$$

- (b) Pursuant to 326 IAC 6-3-2(e)(3) (Particulate Emission Limitations for Manufacturing Processes), for the ash unloading at the maximum throughput rate of 500 tons per hour, the concentration of particulate in the discharge gases to the atmosphere shall be less than 0.10 pounds per one thousand (1,000) pounds of gases.

Compliance Determination Requirements

D.6.2 Particulate Control [326 IAC 2-7-6(6)]

Except as otherwise provided by statute or rule or in this permit, the silo collector bag filter and the storage silo bin vent filter for particulate control shall be in operation and control emissions at all times that fly ash is being transferred to the associated storage silo; and the telescoping chute with a vacuum system and bin vent filter, or the water spray, shall be in operation and control emissions at all times that the associated truck loading system is in operation.

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.6.3 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- (a) Visible emission notations of the ash silo unloading station openings shall be performed at least once per day during normal daylight operations when ash is being unloaded. A trained employee shall record whether any emissions are observed.

- (b) Visible emission notations of the fly ash conveyance, the ash silo bag filter, and the ash silo bin vent filter exhaust shall be performed at least once per day during normal daylight operations when transferring ash to the corresponding silo. A trained employee shall record whether emissions are normal or abnormal.
- (c) Visible emission notations of the nozzle of each telescoping chute shall be performed at least once per day during normal daylight operations when unloading ash through the chute. A trained employee shall record whether emissions are normal or abnormal.
- (d) If any visible emissions of ash are observed from the ash silo unloading station openings, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. Observation of visible emissions that do not violate 326 IAC 6-4 (Fugitive Dust Emissions) or an applicable opacity limit is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances, shall be considered a deviation from this permit.
- (e) If abnormal emissions are observed at the bin vent filter exhaust or from the nozzle of the telescoping chute, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. Observation of abnormal emissions that do not violate 326 IAC 6-4 (Fugitive Dust Emissions) or an applicable opacity limit is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances, shall be considered a deviation from this permit.
- (f) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation.
- (g) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- (h) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.6.4 Record Keeping Requirements

- (a) To document compliance with Condition D.6.3, the Permittee shall maintain records of the visible emission notations of the ash silo unloading station openings and the baghouse stack exhaust.
- (b) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

SECTION D.7

FACILITY CONDITIONS - Bottom Ash Handling

Facility Description [326 IAC 2-7-5(15)]

- (j) Wet process bottom ash handling installed in the 1960's, with bottom ash sluiced to storage pond(s), with water cover or vegetation sufficient to prevent ash re-entrainment. Ash removed from the pond(s) is stored in piles before being taken offsite by truck.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.7.1 Fugitive Dust Emission Limitations [326 IAC 6-4-2]

Pursuant to 326 IAC 6-4-2:

- (a) Any ash storage pond generating fugitive dust shall be in violation of this rule (326 IAC 6-4) if any of the following criteria are violated:

- (1) A source or combination of sources which cause to exist fugitive dust concentrations greater than sixty-seven percent (67%) in excess of ambient upwind concentrations as determined by the following formula:

$$P = \frac{100(R) - U}{U}$$

Where

P = Percentage increase

R = Number of particles of fugitive dust measured at downward receptor site

U = Number of particles of fugitive dust measured at upwind or background site

- (2) The fugitive dust is comprised of fifty percent (50%) or more respirable dust, then the percent increase of dust concentration in subdivision (1) of this section shall be modified as follows:

$$P_R = (1.5 \pm N) P$$

Where

N = Fraction of fugitive dust that is respirable dust;

P_R = allowable percentage increase in dust concentration above background;

and

P = no value greater than sixty-seven percent (67%).

- (3) The ground level ambient air concentrations exceed fifty (50) micrograms per cubic meter above background concentrations for a sixty (60) minute period.
- (4) If fugitive dust is visible crossing the boundary or property line of a source. This subdivision may be refuted by factual data expressed in subdivisions (1), (2) or (3) of this section. 326 IAC 6-4-2(4) is not federally enforceable.
- (b) Pursuant to 326 IAC 6-4-6(6) (Exceptions), fugitive dust from a source caused by adverse meteorological conditions will be considered an exception to this rule (326 IAC 6-4) and therefore not in violation.

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.7.2 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- (a) Any ash storage pond at the source that contains bottom ash shall be observed once per week to determine if sufficient water is present in the pond to cover or saturate ash deposited in the pond. During any period where there is not sufficient water in the pond to cover or saturate ash present in the pond visible emission notations of the ash storage pond area(s) shall be performed at least once per day during normal daylight operations. A trained employee shall record whether emissions are normal or abnormal.
- (b) If visible emissions are observed crossing the property line or boundaries of the property, right-of-way, or easement on which the source is located, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances, shall be considered a deviation from this permit.
- (c) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation.
- (d) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- (e) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.7.3 Record Keeping Requirements

- (a) To document compliance with Condition D.7.2, the Permittee shall maintain a record of pond observations and any records of visible emission notations of the ash storage pond area(s).
- (b) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

SECTION D.8 FACILITY OPERATION CONDITIONS - Degreasing Operations

Facility Description [326 IAC 2-7-5(15)]

Insignificant Activities [326 IAC 2-7-1(21)]:

- (b) Degreasing operations that do not exceed 145 gallons per 12 months, except if subject to 326 IAC 20-6.
- (c) Cleaners and solvents characterized as follows:
 - (1) Having a vapor pressure equal to or less than 2 kPa; 15 mm Hg; or 0.3 psi measured at 38 degrees C (100°F) or;
 - (2) Having a vapor pressure equal to or less than 0.7 kPa; 5mm Hg; or 0.1 psi measured at 20°C (68°F); the use of which for all cleaners and solvents combined does not exceed 145 gallons per 12 months.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.8.1 Organic Solvent Degreasing Operations: Cold Cleaner Operation [326 IAC 8-3-2]

Pursuant to 326 IAC 8-3-2 (Cold Cleaner Operations), for cold cleaning operations constructed after January 1, 1980, the Permittee shall:

- (a) Equip the cleaner with a cover;
- (b) Equip the cleaner with a facility for draining cleaned parts;
- (c) Close the degreaser cover whenever parts are not being handled in the cleaner;
- (d) Drain cleaned parts for at least fifteen (15) seconds or until dripping ceases;
- (e) Provide a permanent, conspicuous label summarizing the operation requirements;
- (f) Store waste solvent only in covered containers and not dispose of waste solvent or transfer it to another party, in such a manner that greater than twenty percent (20%) of the waste solvent (by weight) can evaporate into the atmosphere.

D.8.2 Organic Solvent Degreasing Operations: Cold Cleaner Degreaser Operation and Control [326 IAC 8-3-5]

- (a) Pursuant to 326 IAC 8-3-5(a) (Cold Cleaner Degreaser Operation and Control), for cold cleaner degreaser operations without remote solvent reservoirs, constructed after July 1, 1990, the Permittee shall ensure that the following control equipment requirements are met:
 - (1) Equip the degreaser with a cover. The cover must be designed so that it can be easily operated with one (1) hand if:
 - (A) The solvent volatility is greater than two (2) kiloPascals (fifteen (15) millimeters of mercury or three-tenths (0.3) pounds per square inch measured at thirty-eight degrees Celsius (38°C) (one hundred degrees Fahrenheit (100°F));

- (B) The solvent is agitated; or
 - (C) The solvent is heated.
- (2) Equip the degreaser with a facility for draining cleaned articles. If the solvent volatility is greater than four and three-tenths (4.3) kiloPascals (thirty-two (32) millimeters of mercury or six-tenths (0.6) pounds per square inch) measured at thirty-eight degrees Celsius (38^oC) (one hundred degrees Fahrenheit (100^oF)), then the drainage facility must be internal such that articles are enclosed under the cover while draining. The drainage facility may be external for applications where an internal type cannot fit into the cleaning system.
- (3) Provide a permanent, conspicuous label which lists the operating requirements outlined in subsection (b).
- (4) The solvent spray, if used, must be a solid, fluid stream and shall be applied at a pressure which does not cause excessive splashing.
- (5) Equip the degreaser with one (1) of the following control devices if the solvent volatility is greater than four and three-tenths (4.3) kiloPascals (thirty-two (32) millimeters of mercury or six-tenths (0.6) pounds per square inch) measured at thirty-eight degrees Celsius (38^oC) (one hundred degrees Fahrenheit (100^oF)), or if the solvent is heated to a temperature greater than forty-eight and nine-tenths degrees Celsius (48.9^oC) (one hundred twenty degrees Fahrenheit (120^oF)):
- (A) A freeboard that attains a freeboard ratio of seventy-five hundredths (0.75) or greater.
 - (B) A water cover when solvent is used is insoluble in, and heavier than, water.
 - (C) Other systems of demonstrated equivalent control such as a refrigerated chiller or carbon adsorption. Such systems shall be submitted to the U.S. EPA as a SIP revision.
- (b) Pursuant to 326 IAC 8-3-5(b) (Cold Cleaner Degreaser Operation and Control), the owner or operator of a cold cleaning facility construction of which commenced after July 1, 1990, shall ensure that the following operating requirements are met:
- (1) Close the cover whenever articles are not being handled in the degreaser.
 - (2) Drain cleaned articles for at least fifteen (15) seconds or until dripping ceases.
 - (3) Store waste solvent only in covered containers and prohibit the disposal or transfer of waste solvent in any manner in which greater than twenty percent (20%) of the waste solvent by weight could evaporate.

SECTION D.9 FACILITY CONDITIONS - Grinding and Machining Operations

Facility Description [326 IAC 2-7-5(15)]

Insignificant Activities [326 IAC 2-7-1(21)]:

- (g) Grinding and machining operations controlled with fabric filters, scrubbers, mist collectors, wet collectors and electrostatic precipitators with a design grain loading of less than or equal to 0.03 grains per actual cubic foot and a gas flow rate less than or equal to 4000 actual cubic feet per minute, including the following: deburring; buffing; polishing; abrasive blasting; pneumatic conveying; and woodworking operations.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.9.1 Particulate [326 IAC 6-3-2]

- (a) Pursuant to 326 IAC 6-3-2(e)(2) (Particulate Emission Limitations for Manufacturing Processes), particulate emissions from any process not exempt under 326 IAC 6-3-1(b) or (c) which has a maximum process weight rate less than 100 pounds per hour and the methods in 326 IAC 6-3-2(b) through (d) do not apply shall not exceed 0.551 pounds per hour.
- (b) Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), the particulate emission rate from the brazing, cutting, soldering, welding, grinding, and machining operations shall not exceed an amount determined by the following, for a process weight rate equal to or greater than 100 pounds per hour:

Interpolation of the data for the process weight rate up to sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 4.10 P^{0.67} \quad \text{where } E = \text{rate of emission in pounds per hour and} \\ P = \text{process weight rate in tons per hour.}$$

Compliance Determination Requirement

D.9.2 Particulate Control [326 IAC 2-7-6(6)]

Except as otherwise provided by statute or rule or in this permit, the fabric filters for particulate control shall be in operation and control emissions from the insignificant activities, which are included in this section and have particulate controls, at all times that the associated process is in operation.

SECTION E

TITLE IV CONDITIONS

Facility Description [326 IAC 2-7-5(15)]

- (a) One (1) cyclone coal-fired boiler, identified as Unit 7, with construction completed in 1962, with a design heat input capacity of 1638 million Btu per hour, with an electrostatic precipitator (ESP) system for control of particulate matter. A wet limestone flue gas desulfurization system serves both Unit 7 and 8 for control of sulfur dioxide. Natural gas and/or No. 2 fuel oil can be fired during startup, shutdown, and malfunctions; the unit can also generate electricity while combusting natural gas only. Unit 7 has continuous emissions monitoring systems (CEMS) for nitrogen oxides (NO_x) and for sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Scrubbed emissions from Units 7 and 8 are exhausted through Stack CS001. Non-scrubbed emissions from Units 7 and 8 are exhausted through the bypass stack, Stack CS002.
- (b) One (1) cyclone coal-fired boiler, identified as Unit 8, with construction completed in 1968, with a design heat input capacity of 3374 million Btu per hour, with an electrostatic precipitator (ESP) system for control of particulate matter. A wet limestone flue gas desulfurization system serves both Unit 7 and 8 for control of sulfur dioxide. Natural gas and/or No. 2 fuel oil can be fired during startup, shutdown, and malfunctions; the unit can also generate electricity while combusting natural gas only. Unit 8 is equipped with a selective catalytic reduction (SCR) system and in 2011 was also authorized to install up to four (4) natural gas fired flue gas reheating Duct Burners each with a maximum design heat input capacity of 40 million Btu per hour. Unit 8 has continuous emissions monitoring systems (CEMS) for nitrogen oxides (NO_x) and for sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Scrubbed emissions from Units 7 and 8 are exhausted through Stack CS001. Non-scrubbed emissions from Units 7 and 8 are exhausted through the bypass stack, Stack CS002.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Acid Rain Program

E.1 Acid Rain Permit [326 IAC 2-7-5(1)(C)] [326 IAC 21] [40 CFR 72 through 40 CFR 78]

Pursuant to 326 IAC 21 (Acid Deposition Control), the Permittee shall comply with all provisions of the Acid Rain permit issued for this source, and any other applicable requirements contained in 40 CFR 72 through 40 CFR 78. The Acid Rain permit for this source is attached to this permit as Appendix B, and is incorporated by reference.

E.2 Title IV Emissions Allowances [326 IAC 2-7-5(4)] [326 IAC 21]

Emissions exceeding any allowances that the Permittee lawfully holds under the Title IV Acid Rain Program of the Clean Air Act are prohibited, subject to the following limitations:

- (a) No revision of this permit shall be required for increases in emissions that are authorized by allowances acquired under the Title IV Acid Rain Program, provided that such increases do not require a permit revision under any other applicable requirement.
- (b) No limit shall be placed on the number of allowances held by the Permittee. The Permittee may not use allowances as a defense to noncompliance with any other applicable requirement.
- (c) Any such allowance shall be accounted for according to the procedures established in regulations promulgated under Title IV of the Clean Air Act.

SECTION F Nitrogen Oxides Budget Trading Program - NO_x Budget Permit for NO_x Budget Units Under 326 IAC 10-4-1(a)

ORIS Code: 995

NO_x Budget Source [326 IAC 2-7-5(15)]

- (a) One (1) cyclone coal-fired boiler, identified as Unit 7, with construction completed in 1962, with a design heat input capacity of 1638 million Btu per hour, with an electrostatic precipitator (ESP) system for control of particulate matter. A wet limestone flue gas desulfurization system serves both Unit 7 and 8 for control of sulfur dioxide. Natural gas and/or No. 2 fuel oil can be fired during startup, shutdown, and malfunctions; the unit can also generate electricity while combusting natural gas only. Unit 7 has continuous emissions monitoring systems (CEMS) for nitrogen oxides (NO_x) and for sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Scrubbed emissions from Units 7 and 8 are exhausted through Stack CS001. Non-scrubbed emissions from Units 7 and 8 are exhausted through the bypass stack, Stack CS002.
- (b) One (1) cyclone coal-fired boiler, identified as Unit 8, with construction completed in 1968, with a design heat input capacity of 3374 million Btu per hour, with an electrostatic precipitator (ESP) system for control of particulate matter. A wet limestone flue gas desulfurization system serves both Unit 7 and 8 for control of sulfur dioxide. Natural gas and/or No. 2 fuel oil can be fired during startup, shutdown, and malfunctions; the unit can also generate electricity while combusting natural gas only. Unit 8 is equipped with a selective catalytic reduction (SCR) system and in 2011 was also authorized to install up to four (4) natural gas fired flue gas reheating Duct Burners each with a maximum design heat input capacity of 40 million Btu per hour. Unit 8 has continuous emissions monitoring systems (CEMS) for nitrogen oxides (NO_x) and for sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Scrubbed emissions from Units 7 and 8 are exhausted through Stack CS001. Non-scrubbed emissions from Units 7 and 8 are exhausted through the bypass stack, Stack CS002.
- (d) One (1) simple-cycle, natural gas-fired combustion turbine, identified as Unit 10, with construction completed in 1968, with a design heat input capacity of 600 million Btu per hour, exhausting to Stack 10.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

F.1 Automatic Incorporation of Definitions [326 IAC 10-4-7(e)]

This NO_x budget permit is deemed to incorporate automatically the definitions of terms under 326 IAC 10-4-2.

F.2 Standard Permit Requirements [326 IAC 10-4-4(a)]

- (a) The owners and operators of the NO_x budget source and each NO_x budget unit shall operate each unit in compliance with this NO_x budget permit.
- (b) The NO_x budget units subject to this NO_x budget permit are Unit 7, Unit 8, and Unit 10.

F.3 Monitoring Requirements [326 IAC 10-4-4(b)]

- (a) The owners and operators and, to the extent applicable, the NO_x authorized account representative of the NO_x budget source and each NO_x budget unit at the source shall comply with the monitoring requirements of 40 CFR 75 and 326 IAC 10-4-12.

- (b) The emissions measurements recorded and reported in accordance with 40 CFR 75 and 326 IAC 10-4-12 shall be used to determine compliance by each unit with the NO_x budget emissions limitation under 326 IAC 10-4-4(c) and Condition F.4, Nitrogen Oxides Requirements.

F.4 Nitrogen Oxides Requirements [326 IAC 10-4-4(c)]

- (a) The owners and operators of the NO_x budget source and each NO_x budget unit at the source shall hold NO_x allowances available for compliance deductions under 326 IAC 10-4-10(j), as of the NO_x allowance transfer deadline, in each unit's compliance account and the source's overdraft account in an amount:
 - (1) Not less than the total NO_x emissions for the ozone control period from the unit, as determined in accordance with 40 CFR 75 and 326 IAC 10-4-12;
 - (2) To account for excess emissions for a prior ozone control period under 326 IAC 10-4-10(k)(5); or
 - (3) To account for withdrawal from the NO_x budget trading program, or a change in regulatory status of a NO_x budget opt-in unit.
- (b) Each ton of NO_x emitted in excess of the NO_x budget emissions limitation shall constitute a separate violation of the Clean Air Act (CAA) and 326 IAC 10-4.
- (c) Each NO_x budget unit shall be subject to the requirements under (a) above and 326 IAC 10-4-4(c)(1) starting on May 31, 2004.
- (d) NO_x allowances shall be held in, deducted from, or transferred among NO_x allowance tracking system accounts in accordance with 326 IAC 10-4-9 through 11, 326 IAC 10-4-13, and 326 IAC 10-4-14.
- (e) A NO_x allowance shall not be deducted, in order to comply with the requirements under (a) above and 326 IAC 10-4-4(c)(1), for an ozone control period in a year prior to the year for which the NO_x allowance was allocated.
- (f) A NO_x allowance allocated under the NO_x budget trading program is a limited authorization to emit one (1) ton of NO_x in accordance with the NO_x budget trading program. No provision of the NO_x budget trading program, the NO_x budget permit application, the NO_x budget permit, or an exemption under 326 IAC 10-4-3 and no provision of law shall be construed to limit the authority of the U.S. EPA or IDEM, OAQ to terminate or limit the authorization.
- (g) A NO_x allowance allocated under the NO_x budget trading program does not constitute a property right.
- (h) Upon recordation by the U.S. EPA under 326 IAC 10-4-10, 326 IAC 10-4-11, or 326 IAC 10-4-13, every allocation, transfer, or deduction of a NO_x allowance to or from each NO_x budget unit's compliance account or the overdraft account of the source where the unit is located is deemed to amend automatically, and become a part of, this NO_x budget permit of the NO_x budget unit by operation of law without any further review.

F.5 Excess Emissions Requirements [326 IAC 10-4-4(d)]

The owners and operators of each NO_x budget unit that has excess emissions in any ozone control period shall do the following:

- (a) Surrender the NO_x allowances required for deduction under 326 IAC 10-4-10(k)(5).
- (b) Pay any fine, penalty, or assessment or comply with any other remedy imposed under 326 IAC 10-4-10(k)(7).

F.6 Record Keeping Requirements [326 IAC 10-4-4(e)] [326 IAC 2-7-5(3)]

Unless otherwise provided, the owners and operators of the NO_x budget source and each NO_x budget unit at the source shall keep, either on site at the source or at a central location within Indiana for those owners or operators with unattended sources, each of the following documents for a period of five (5) years:

- (a) The account certificate of representation for the NO_x authorized account representative for the source and each NO_x budget unit at the source and all documents that demonstrate the truth of the statements in the account certificate of representation, in accordance with 326 IAC 10-4-6(h). The certificate and documents shall be retained either on site at the source or at a central location within Indiana for those owners or operators with unattended sources beyond the five (5) year period until the documents are superseded because of the submission of a new account certificate of representation changing the NO_x authorized account representative.
- (b) All emissions monitoring information, in accordance with 40 CFR 75 and 326 IAC 10-4-12, provided that to the extent that 40 CFR 75 and 326 IAC 10-4-12 provide for a three (3) year period for record keeping, the three (3) year period shall apply.
- (c) Copies of all reports, compliance certifications, and other submissions and all records made or required under the NO_x budget trading program.
- (d) Copies of all documents used to complete a NO_x budget permit application and any other submission under the NO_x budget trading program or to demonstrate compliance with the requirements of the NO_x budget trading program.

This period may be extended for cause, at any time prior to the end of five (5) years, in writing by IDEM, OAQ or the U.S. EPA. Records retained at a central location within Indiana shall be available immediately at the location and submitted to the department or U.S. EPA within three (3) business days following receipt of a written request. Nothing in 326 IAC 10-4-4(e) shall alter the record retention requirements for a source under 40 CFR 75. Unless otherwise provided, all records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

F.7 Reporting Requirements [326 IAC 10-4-4(e)]

- (a) The NO_x authorized account representative of the NO_x budget source and each NO_x budget unit at the source shall submit the reports and compliance certifications required under the NO_x budget trading program, including those under 326 IAC 10-4-8, 326 IAC 10-4-12, or 326 IAC 10-4-13.
- (b) Pursuant to 326 IAC 10-4-4(e) and 326 IAC 10-4-6(e)(1), each submission shall include the following certification statement by the NO_x authorized account representative: "I am authorized to make this submission on behalf of the owners and operators of the NO_x budget sources or NO_x budget units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."

- (c) Where 326 IAC 10-4 requires a submission to IDEM, OAQ, the NO_x authorized account representative shall submit required information to:

Indiana Department of Environmental Management
Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

- (d) Where 326 IAC 10-4 requires a submission to U.S. EPA, the NO_x authorized account representative shall submit required information to:

U.S. Environmental Protection Agency
Clean Air Markets Division
1200 Pennsylvania Avenue, NW
Mail Code 6204N
Washington, DC 20460

F.8 Liability [326 IAC 10-4-4(f)]

The owners and operators of each NO_x budget source shall be liable as follows:

- (a) Any person who knowingly violates any requirement or prohibition of the NO_x budget trading program, a NO_x budget permit, or an exemption under 326 IAC 10-4-3 shall be subject to enforcement pursuant to applicable state or federal law.
- (b) Any person who knowingly makes a false material statement in any record, submission, or report under the NO_x budget trading program shall be subject to criminal enforcement pursuant to the applicable state or federal law.
- (c) No permit revision shall excuse any violation of the requirements of the NO_x budget trading program that occurs prior to the date that the revision takes effect.
- (d) Each NO_x budget source and each NO_x budget unit shall meet the requirements of the NO_x budget trading program.
- (e) Any provision of the NO_x budget trading program that applies to a NO_x budget source, including a provision applicable to the NO_x authorized account representative of a NO_x budget source, shall also apply to the owners and operators of the source and of the NO_x budget units at the source.
- (f) Any provision of the NO_x budget trading program that applies to a NO_x budget unit, including a provision applicable to the NO_x authorized account representative of a NO_x budget unit, shall also apply to the owners and operators of the unit. Except with regard to the requirements applicable to units with a common stack under 40 CFR 75 and 326 IAC 10-4-12, the owners and operators and the NO_x authorized account representative of one (1) NO_x budget unit shall not be liable for any violation by any other NO_x budget unit of which they are not owners or operators or the NO_x authorized account representative and that is located at a source of which they are not owners or operators or the NO_x authorized account representative.

F.9 Effect on Other Authorities [326 IAC 10-4-4(g)]

No provision of the NO_x budget trading program, a NO_x budget permit application, a NO_x budget permit, or an exemption under 326 IAC 10-4-3 shall be construed as exempting or excluding the owners and operators and, to the extent applicable, the NO_x authorized account representative of a NO_x budget source or NO_x budget unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the CAA.

SECTION G Clean Air Interstate Rule (CAIR) Nitrogen Oxides Annual, Sulfur Dioxide, and Nitrogen Oxides Ozone Season Trading Programs – CAIR Permit for CAIR Units Under 326 IAC 24-1-1(a), 326 IAC 24-2-1(a), and 326 IAC 24-3-1(a)

ORIS Code: 995

CAIR Permit for CAIR Units Under 326 IAC 24-1-1(a), 326 IAC 24-2-1(a), and 326 IAC 24-3-1(a)

- (a) One (1) cyclone coal-fired boiler, identified as Unit 7, with construction completed in 1962, with a design heat input capacity of 1638 million Btu per hour, with an electrostatic precipitator (ESP) system for control of particulate matter. A wet limestone flue gas desulfurization system serves both Unit 7 and 8 for control of sulfur dioxide. Natural gas and/or No. 2 fuel oil can be fired during startup, shutdown, and malfunctions; the unit can also generate electricity while combusting natural gas only. Unit 7 has continuous emissions monitoring systems (CEMS) for nitrogen oxides (NO_x) and for sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Scrubbed emissions from Units 7 and 8 are exhausted through Stack CS001. Non-scrubbed emissions from Units 7 and 8 are exhausted through the bypass stack, Stack CS002.
- (b) One (1) cyclone coal-fired boiler, identified as Unit 8, with construction completed in 1968, with a design heat input capacity of 3374 million Btu per hour, with an electrostatic precipitator (ESP) system for control of particulate matter. A wet limestone flue gas desulfurization system serves both Unit 7 and 8 for control of sulfur dioxide. Natural gas and/or No. 2 fuel oil can be fired during startup, shutdown, and malfunctions; the unit can also generate electricity while combusting natural gas only. Unit 8 is equipped with a selective catalytic reduction (SCR) system and in 2011 was also authorized to install up to four (4) natural gas fired flue gas reheating Duct Burners each with a maximum design heat input capacity of 40 million Btu per hour. Unit 8 has continuous emissions monitoring systems (CEMS) for nitrogen oxides (NO_x) and for sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Scrubbed emissions from Units 7 and 8 are exhausted through Stack CS001. Non-scrubbed emissions from Units 7 and 8 are exhausted through the bypass stack, Stack CS002.
- (d) One (1) simple-cycle, natural gas-fired combustion turbine, identified as Unit 10, with construction completed in 1968, with a design heat input capacity of 600 million Btu per hour, exhausting to Stack 10.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

G.1 Automatic Incorporation of Definitions [326 IAC 24-1-7(e)] [326 IAC 24-2-7(e)] [326 IAC 24-3-7(e)] [40 CFR 97.123(b)] [40 CFR 97.223(b)] [40 CFR 97.323(b)]

This CAIR permit is deemed to incorporate automatically the definitions of terms under 326 IAC 24-1-2, 326 IAC 24-2-2, and 326 IAC 24-3-2.

G.2 Standard Permit Requirements [326 IAC 24-1-4(a)] [326 IAC 24-2-4(a)] [326 IAC 24-3-4(a)] [40 CFR 97.106(a)] [40 CFR 97.206(a)] [40 CFR 97.306(a)]

- (a) The owners and operators of each CAIR NO_x source, CAIR SO₂ source, and CAIR NO_x ozone season source and CAIR NO_x unit, CAIR SO₂ unit, and CAIR NO_x ozone season unit shall operate each source and unit in compliance with this CAIR permit.
- (b) The CAIR NO_x units, CAIR SO₂ units, and CAIR NO_x ozone season units subject to this CAIR permit are Unit 7, Unit 8, and Unit 10.

G.3 Monitoring, Reporting, and Record Keeping Requirements [326 IAC 24-1-4(b)] [326 IAC 24-2-4(b)] [326 IAC 24-3-4(b)] [40 CFR 97.106(b)] [40 CFR 97.206(b)] [40 CFR 97.306(b)]

- (a) The owners and operators, and the CAIR designated representative, of each CAIR NO_x source, CAIR SO₂ source, and CAIR NO_x ozone season source and CAIR NO_x unit, CAIR SO₂ unit, and CAIR NO_x ozone season unit at the source shall comply with the applicable monitoring, reporting, and record keeping requirements of 326 IAC 24-1-11, 326 IAC 24-2-10, and 326 IAC 24-3-11.
- (b) The emissions measurements recorded and reported in accordance with 326 IAC 24-1-11, 326 IAC 24-2-10, and 326 IAC 24-3-11 shall be used to determine compliance by each CAIR NO_x source, CAIR SO₂ source, and CAIR NO_x ozone season source with the CAIR NO_x emissions limitation under 326 IAC 24-1-4(c), CAIR SO₂ emissions limitation under 326 IAC 24-2-4(c), and CAIR NO_x ozone season emissions limitation under 326 IAC 24-3-4(c) and Condition G.4.1, Nitrogen Oxides Emission Requirements, Condition G.4.2, Sulfur Dioxide Emission Requirements, and Condition G.4.3, Nitrogen Oxides Ozone Season Emission Requirements.

G.4.1 Nitrogen Oxides Emission Requirements [326 IAC 24-1-4(c)] [40 CFR 97.106(c)]

- (a) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO_x source and each CAIR NO_x unit at the source shall hold, in the source's compliance account, CAIR NO_x allowances available for compliance deductions for the control period under 326 IAC 24-1-9(i) in an amount not less than the tons of total nitrogen oxides emissions for the control period from all CAIR NO_x units at the source, as determined in accordance with 326 IAC 24-1-11.
- (b) A CAIR NO_x unit shall be subject to the requirements under 326 IAC 24-1-4(c)(1) for the control period starting on the applicable date, as determined under 326 IAC 24-1-4(c)(2), and for each control period thereafter.
- (c) A CAIR NO_x allowance shall not be deducted for compliance with the requirements under 326 IAC 24-1-4(c)(1), for a control period in a calendar year before the year for which the CAIR NO_x allowance was allocated.
- (d) CAIR NO_x allowances shall be held in, deducted from, or transferred into or among CAIR NO_x allowance tracking system accounts in accordance with 326 IAC 24-1-9, 326 IAC 24-1-10, and 326 IAC 24-1-12.
- (e) A CAIR NO_x allowance is a limited authorization to emit one (1) ton of nitrogen oxides in accordance with the CAIR NO_x annual trading program. No provision of the CAIR NO_x annual trading program, the CAIR permit application, the CAIR permit, or an exemption under 326 IAC 24-1-3 and no provision of law shall be construed to limit the authority of the State of Indiana or the United States to terminate or limit the authorization.
- (f) A CAIR NO_x allowance does not constitute a property right.
- (g) Upon recordation by the U.S. EPA under 326 IAC 24-1-8, 326 IAC 24-1-9, 326 IAC 24-1-10, or 326 IAC 24-1-12, every allocation, transfer, or deduction of a CAIR NO_x allowance to or from a CAIR NO_x source's compliance account is incorporated automatically in this CAIR permit.

G.4.2 Sulfur Dioxide Emission Requirements [326 IAC 24-2-4(c)] [40 CFR 97.206(c)]

- (a) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR SO₂ source and each CAIR SO₂ unit at the source shall hold, in the source's compliance account, a tonnage equivalent of CAIR SO₂ allowances available for compliance deductions for the control period under 326 IAC 24-2-8(j) and 326 IAC 24-2-8(k) not less than the tons of total sulfur dioxide emissions for the control period from all CAIR SO₂ units at the source, as determined in accordance with 326 IAC 24-2-10.

- (b) A CAIR SO₂ unit shall be subject to the requirements under 326 IAC 24-2-4(c)(1) for the control period starting on the applicable date, as determined under 326 IAC 24-2-4(c)(2), and for each control period thereafter.
- (c) A CAIR SO₂ allowance shall not be deducted for compliance with the requirements under 326 IAC 24-2-4(c)(1), for a control period in a calendar year before the year for which the CAIR SO₂ allowance was allocated.
- (d) CAIR SO₂ allowances shall be held in, deducted from, or transferred into or among CAIR SO₂ allowance tracking system accounts in accordance with 326 IAC 24-2-8, 326 IAC 24-2-9, and 326 IAC 24-2-11.
- (e) A CAIR SO₂ allowance is a limited authorization to emit sulfur dioxide in accordance with the CAIR SO₂ trading program. No provision of the CAIR SO₂ trading program, the CAIR permit application, the CAIR permit, or an exemption under 326 IAC 24-2-3 and no provision of law shall be construed to limit the authority of the State of Indiana or the United States to terminate or limit the authorization.
- (f) A CAIR SO₂ allowance does not constitute a property right.
- (g) Upon recordation by the U.S. EPA under 326 IAC 24-2-8, 326 IAC 24-2-9, or 326 IAC 24-2-11, every allocation, transfer, or deduction of a CAIR SO₂ allowance to or from a CAIR SO₂ source's compliance account is incorporated automatically in this CAIR permit.

G.4.3 Nitrogen Oxides Ozone Season Emission Requirements [326 IAC 24-3-4(c)] [40 CFR 97.306(c)]

- (a) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO_x ozone season source and each CAIR NO_x ozone season unit at the source shall hold, in the source's compliance account, CAIR NO_x ozone season allowances available for compliance deductions for the control period under 326 IAC 24-3-9(i) in an amount not less than the tons of total nitrogen oxides emissions for the control period from all CAIR NO_x ozone season units at the source, as determined in accordance with 326 IAC 24-3-11.
- (b) A CAIR NO_x ozone season unit shall be subject to the requirements under 326 IAC 24-3-4(c)(1) for the control period starting on the applicable date, as determined under 326 IAC 24-3-4(c)(2), and for each control period thereafter.
- (c) A CAIR NO_x ozone season allowance shall not be deducted for compliance with the requirements under 326 IAC 24-3-4(c)(1), for a control period in a calendar year before the year for which the CAIR NO_x ozone season allowance was allocated.
- (d) CAIR NO_x ozone season allowances shall be held in, deducted from, or transferred into or among CAIR NO_x ozone season allowance tracking system accounts in accordance with 326 IAC 24-3-9, 326 IAC 24-3-10, and 326 IAC 24-3-12.
- (e) A CAIR NO_x ozone season allowance is a limited authorization to emit one (1) ton of nitrogen oxides in accordance with the CAIR NO_x ozone season trading program. No provision of the CAIR NO_x ozone season trading program, the CAIR permit application, the CAIR permit, or an exemption under 326 IAC 24-3-3 and no provision of law shall be construed to limit the authority of the State of Indiana or the United States to terminate or limit the authorization.
- (f) A CAIR NO_x ozone season allowance does not constitute a property right.
- (g) Upon recordation by the U.S. EPA under 326 IAC 24-3-8, 326 IAC 24-3-9, 326 IAC 24-3-10, or 326 IAC 24-3-12, every allocation, transfer, or deduction of a CAIR NO_x ozone season allowance to or from a CAIR NO_x ozone season source's compliance account is incorporated automatically in this CAIR permit.

G.5 Excess Emissions Requirements [326 IAC 24-1-4(d)] [326 IAC 24-2-4(d)] [326 IAC 24-3-4(d)]
[40 CFR 97.106(d)] [40 CFR 97.206(d)] [40 CFR 97.306(d)]

(a) The owners and operators of a CAIR NO_x source and each CAIR NO_x unit that emits nitrogen oxides during any control period in excess of the CAIR NO_x emissions limitation shall do the following:

- (1) Surrender the CAIR NO_x allowances required for deduction under 326 IAC 24-1-9(j)(4).
- (2) Pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, the Clean Air Act (CAA) or applicable state law.

Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 326 IAC 24-1-4, the Clean Air Act (CAA), and applicable state law.

(b) The owners and operators of a CAIR SO₂ source and each CAIR SO₂ unit that emits sulfur dioxide during any control period in excess of the CAIR SO₂ emissions limitation shall do the following:

- (1) Surrender the CAIR SO₂ allowances required for deduction under 326 IAC 24-2-8(k)(4).
- (2) Pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, the Clean Air Act (CAA) or applicable state law.

Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 326 IAC 24-2-4, the Clean Air Act (CAA), and applicable state law.

(c) The owners and operators of a CAIR NO_x ozone season source and each CAIR NO_x ozone season unit that emits nitrogen oxides during any control period in excess of the CAIR NO_x ozone season emissions limitation shall do the following:

- (1) Surrender the CAIR NO_x ozone season allowances required for deduction under 326 IAC 24-3-9(j)(4).
- (2) Pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, the Clean Air Act (CAA) or applicable state law.

Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 326 IAC 24-3-4, the Clean Air Act (CAA), and applicable state law.

G.6 Record Keeping Requirements [326 IAC 24-1-4(e)] [326 IAC 24-2-4(e)] [326 IAC 24-3-4(e)]
[326 IAC 2-7-5(3)] [40 CFR 97.106(e)] [40 CFR 97.206(e)] [40 CFR 97.306(e)]

Unless otherwise provided, the owners and operators of the CAIR NO_x source, CAIR SO₂ source, and CAIR NO_x ozone season source and each CAIR NO_x unit, CAIR SO₂ unit, and CAIR NO_x ozone season unit at the source shall keep on site at the source or at a central location within Indiana for those owners or operators with unattended sources, each of the following documents for a period of five (5) years from the date the document was created:

- (a) The certificate of representation under 326 IAC 24-1-6(h), 326 IAC 24-2-6(h), and 326 IAC 24-3-6(h) for the CAIR designated representative for the source and each CAIR NO_x unit, CAIR SO₂ unit, and CAIR NO_x ozone season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation. The certificate and documents shall be retained on site at the source or at a central location within Indiana for those owners or operators with unattended sources beyond such five (5) year period until such documents are superseded because of the submission of a new account certificate of representation under 326 IAC 24-1-6(h), 326 IAC 24-2-6(h), and 326 IAC 24-3-6(h) changing the CAIR designated representative.

- (b) All emissions monitoring information, in accordance with 326 IAC 24-1-11, 326 IAC 24-2-10, and 326 IAC 24-3-11, provided that to the extent that 326 IAC 24-1-11, 326 IAC 24-2-10, and 326 IAC 24-3-11 provides for a three (3) year period for record keeping, the three (3) year period shall apply.
- (c) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_x annual trading program, CAIR SO₂ trading program, and CAIR NO_x ozone season trading program.
- (d) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR NO_x annual trading program, CAIR SO₂ trading program, and CAIR NO_x ozone season trading program or to demonstrate compliance with the requirements of the CAIR NO_x annual trading program, CAIR SO₂ trading program, and CAIR NO_x ozone season trading program.

This period may be extended for cause, at any time before the end of five (5) years, in writing by IDEM, OAQ or the U.S. EPA. Unless otherwise provided, all records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

G.7 Reporting Requirements [326 IAC 24-1-4(e)] [326 IAC 24-2-4(e)] [326 IAC 24-3-4(e)]
[40 CFR 97.106(e)] [40 CFR 97.206(e)] [40 CFR 97.306(e)]

- (a) The CAIR designated representative of the CAIR NO_x source, CAIR SO₂ source, and CAIR NO_x ozone season source and each CAIR NO_x unit, CAIR SO₂ unit, and CAIR NO_x ozone season unit at the source shall submit the reports required under the CAIR NO_x annual trading program, CAIR SO₂ trading program, and CAIR NO_x ozone season trading program, including those under 326 IAC 24-1-11, 326 IAC 24-2-10, and 326 IAC 24-3-11.
- (b) Pursuant to 326 IAC 24-1-4(e), 326 IAC 24-2-4(e), and 326 IAC 24-3-4(e) and 326 IAC 24-1-6(e)(1), 326 IAC 24-2-6(e)(1), and 326 IAC 24-3-6(e)(1), each submission under the CAIR NO_x annual trading program, CAIR SO₂ trading program, and CAIR NO_x ozone season trading program shall include the following certification statement by the CAIR designated representative: "I am authorized to make this submission on behalf of the owners and operators of the source or units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."
- (c) Where 326 IAC 24-1, 326 IAC 24-2, and 326 IAC 24-3 requires a submission to IDEM, OAQ, the information shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53, IGCN 1003
Indianapolis, Indiana 46204-2251
- (d) Where 326 IAC 24-1, 326 IAC 24-2, and 326 IAC 24-3 requires a submission to U.S. EPA, the information shall be submitted to:

U.S. Environmental Protection Agency
Clean Air Markets Division
1200 Pennsylvania Avenue, NW
Mail Code 6204N
Washington, DC 20460

G.8 Liability [326 IAC 24-1-4(f)] [326 IAC 24-2-4(f)] [326 IAC 24-3-4(f)] [40 CFR 97.106(f)]
[40 CFR 97.206(f)] [40 CFR 97.306(f)]

The owners and operators of each CAIR NO_x source, CAIR SO₂ source, and CAIR NO_x ozone season source and each CAIR NO_x unit, CAIR SO₂ unit, and CAIR NO_x ozone season unit shall be liable as follows:

- (a) Each CAIR NO_x source, CAIR SO₂ source, and CAIR NO_x ozone season source and each CAIR NO_x unit, CAIR SO₂ unit, and CAIR NO_x ozone season unit shall meet the requirements of the CAIR NO_x annual trading program, CAIR SO₂ trading program, and CAIR NO_x ozone season trading program, respectively.
- (b) Any provision of the CAIR NO_x annual trading program, CAIR SO₂ trading program, and CAIR NO_x ozone season trading program that applies to a CAIR NO_x source, CAIR SO₂ source, and CAIR NO_x ozone season source or the CAIR designated representative of a CAIR NO_x source, CAIR SO₂ source, and CAIR NO_x ozone season source shall also apply to the owners and operators of such source and of the CAIR NO_x units, CAIR SO₂ units, and CAIR NO_x ozone season units at the source.
- (c) Any provision of the CAIR NO_x annual trading program, CAIR SO₂ trading program, and CAIR NO_x ozone season trading program that applies to a CAIR NO_x unit, CAIR SO₂ unit, and CAIR NO_x ozone season unit or the CAIR designated representative of a CAIR NO_x unit, CAIR SO₂ unit, and CAIR NO_x ozone season unit shall also apply to the owners and operators of such units.

G.9 Effect on Other Authorities [326 IAC 24-1-4(g)] [326 IAC 24-2-4(g)] [326 IAC 24-3-4(g)]
[40 CFR 97.106(g)] [40 CFR 97.206(g)] [40 CFR 97.306(g)]

No provision of the CAIR NO_x annual trading program, CAIR SO₂ trading program, and CAIR NO_x ozone season trading program, a CAIR permit application, a CAIR permit, or an exemption under 326 IAC 24-1-3, 326 IAC 24-2-3, and 326 IAC 24-3-3 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO_x source, CAIR SO₂ source, and CAIR NO_x ozone season source or CAIR NO_x unit, CAIR SO₂ unit, and CAIR NO_x ozone season unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act (CAA).

G.10 CAIR Designated Representative and Alternate CAIR Designated Representative [326 IAC 24-1-6]
[326 IAC 24-2-6] [326 IAC 24-3-6] [40 CFR 97, Subpart BB] [40 CFR 97, Subpart BBB] [40 CFR 97,
Subpart BBBB]

Pursuant to 326 IAC 24-1-6, 326 IAC 24-2-6, and 326 IAC 24-3-6:

- (a) Except as specified in 326 IAC 24-1-6(f)(3), 326 IAC 24-2-6(f)(3), and 326 IAC 24-3-6(f)(3), each CAIR NO_x source, CAIR SO₂ source, and CAIR NO_x ozone season source, including all CAIR NO_x units, CAIR SO₂ units, and CAIR NO_x ozone season units at the source, shall have one (1) and only one (1) CAIR designated representative, with regard to all matters under the CAIR NO_x annual trading program, CAIR SO₂ trading program, and CAIR NO_x ozone season trading program concerning the source or any CAIR NO_x unit, CAIR SO₂ unit, and CAIR NO_x ozone season unit at the source.
- (b) The provisions of 326 IAC 24-1-6(f), 326 IAC 24-2-6(f), and 326 IAC 24-3-6(f) shall apply where the owners or operators of a CAIR NO_x source, CAIR SO₂ source, and CAIR NO_x ozone season source choose to designate an alternate CAIR designated representative.

Except as specified in 326 IAC 24-1-6(f)(3), 326 IAC 24-2-6(f)(3), and 326 IAC 24-3-6(f)(3), whenever the term "CAIR designated representative" is used, the term shall be construed to include the CAIR designated representative or any alternate CAIR designated representative.

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT OFFICE OF AIR QUALITY

PART 70 OPERATING PERMIT CERTIFICATION

Source Name: Northern Indiana Public Service Company (NIPSCO) - Bailly Generating Station
Source Address: 246 Bailly Station Road, Chesterton, Indiana 46304
Mailing Address: Kelly R. Carmichael, 801 East 86th Avenue, Merrillville, Indiana 46410
Part 70 Permit No.: T127-6635-00002

**This certification shall be included when submitting monitoring, testing reports/results
or other documents as required by this permit.**

Please check what document is being certified:

- Annual Compliance Certification Letter
- Test Result (specify) _____.
- Report (specify) _____.
- Notification (specify) _____.
- Affidavit (specify) _____.
- Other (specify) _____.

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Signature:

Printed Name:

Title/Position:

Telephone:

Date:

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251
Phone: 317-233-0178
Fax: 317-233-6865**

**PART 70 OPERATING PERMIT
EMERGENCY OCCURRENCE REPORT**

Source Name: Northern Indiana Public Service Company (NIPSCO) - Bailly Generating Station
Source Address: 246 Bailly Station Road, Chesterton, Indiana 46304
Mailing Address: Kelly R. Carmichael, 801 East 86th Avenue, Merrillville, Indiana 46410
Part 70 Permit No.: T127-6635-00002

This form consists of 2 pages

Page 1 of 2

<input type="checkbox"/> This is an emergency as defined in 326 IAC 2-7-1(12) <ul style="list-style-type: none">• The Permittee must notify the Office of Air Quality (OAQ), within four (4) business hours (1-800-451-6027 or 317-233-0178, ask for Compliance Section); and• The Permittee must submit notice in writing or by facsimile within two (2) working days (Facsimile Number: 317-233-6865), and follow the other requirements of 326 IAC 2-7-16.
--

If any of the following are not applicable, mark N/A

Facility/Equipment/Operation:
Control Equipment:
Permit Condition or Operation Limitation in Permit:
Description of the Emergency:
Describe the cause of the Emergency:

If any of the following are not applicable, mark N/A

Page 2 of 2

Date/Time Emergency started:
Date/Time Emergency was corrected:
Was the facility being properly operated at the time of the emergency? Y N Describe:
Type of Pollutants Emitted: TSP, PM-10, SO ₂ , VOC, NO _x , CO, Pb, other:
Estimated amount of pollutant(s) emitted during emergency:
Describe the steps taken to mitigate the problem:
Describe the corrective actions/response steps taken:
Describe the measures taken to minimize emissions:
If applicable, describe the reasons why continued operation of the facilities are necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw materials of substantial economic value:

Form Completed by: _____.

Title / Position: _____.

Date: _____.

Telephone: _____.

A certification is not required for this report.

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT OFFICE OF AIR QUALITY COMPLIANCE AND ENFORCEMENT BRANCH

Part 70 Quarterly Report: Auxiliary Boiler Natural Gas Usage

Source Name: Northern Indiana Public Service Company (NIPSCO) - Bailly Generating Station
Source Address: 246 Bailly Station Road, Chesterton, Indiana 46304
Mailing Address: Kelly R. Carmichael, 801 East 86th Avenue, Merrillville, Indiana 46410
Part 70 Permit No.: T127-6635-00002
Facilities: Auxiliary Boilers 1 and 2
Parameter: Minor PSD Limit (NO_x)
Limit: 285 million cubic feet of natural gas used per 12 consecutive month period

YEAR: _____.

Month	Natural Gas Usage This Month (MMCF)	Natural Gas Usage Previous 11 Months (MMCF)	Total Natural Gas Usage for 12 Month Period (MMCF)	Usage Limit (MMCF)
				285
				285
				285

- No deviation occurred in this quarter.
 Deviation/s occurred in this quarter.
Deviation has been reported on: _____.

Submitted by: _____.

Title / Position: _____.

Signature: _____.

Date: _____.

Telephone: _____.

Attach a signed certification to complete this report.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH**

Part 70 Quarterly Report

Source Name: Northern Indiana Public Service Company (NIPSCO) - Bailly Generating Station
Source Address: 246 Bailly Station Road, Chesterton, Indiana 46304
Mailing Address: Kelly R. Carmichael, 801 East 86th Avenue, Merrillville, Indiana 46410
Part 70 Permit No.: T127-6635-00002
Facilities: Four (4) Duct Burners
Parameter: Natural Gas Usage
Limit: 782 million cubic feet of natural gas used per 12 consecutive month period

QUARTER :

YEAR:

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

- No deviation occurred in this quarter.
 Deviation/s occurred in this quarter.
Deviation has been reported on:

Submitted by: _____
Title / Position: _____
Signature: _____
Date: _____
Phone: _____

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH**

**PART 70 OPERATING PERMIT
QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT**

Source Name: Northern Indiana Public Service Company (NIPSCO) - Bailly Generating Station
Source Address: 246 Bailly Station Road, Chesterton, Indiana 46304
Mailing Address: Kelly R. Carmichael, 801 East 86th Avenue, Merrillville, Indiana 46410
Part 70 Permit No.: T127-6635-00002

Months: _____ to _____ Year: _____

Page 1 of 2

This report shall be submitted quarterly based on a calendar year. For the purpose of this permit, "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive. Any deviation from the requirements, the date(s) of each deviation, the probable cause of the deviation, and the response steps taken must be reported. A deviation required to be reported pursuant to an applicable requirement that exists independent of the permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. Additional pages may be attached if necessary. If no deviations occurred, please specify in the box marked "No deviations occurred this reporting period".

NO DEVIATIONS OCCURRED THIS REPORTING PERIOD.

THE FOLLOWING DEVIATIONS OCCURRED THIS REPORTING PERIOD

Permit Requirement (specify permit condition #)

Date of Deviation:

Duration of Deviation:

Number of Deviations:

Probable Cause of Deviation:

Response Steps Taken:

Permit Requirement (specify permit condition #)

Date of Deviation:

Duration of Deviation:

Number of Deviations:

Probable Cause of Deviation:

Response Steps Taken:

Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	Duration of Deviation:
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	

Form Completed By: _____.

Title/Position: _____.

Date: _____.

Telephone: _____.

Attach a signed certification to complete this report.

Indiana Department of Environmental Management Office of Air Quality

Addendum to the Technical Support Document (ATSD) for a Part 70 Significant Source and Permit Modification

Source Description and Location

Source Name:	NIPSCO – Bailly Generating Station
Source Location:	246 Bailly Station Road, Chesterton, IN 46304
County:	Porter
SIC Code:	4911
Operation Permit No.:	127-6635-00002
Operation Permit Issuance Date:	June 27, 2006
Significant Source Modification No.:	127-30156-00002
Significant Permit Modification No.:	127-30163-00002
Permit Reviewer:	Josiah Balogun

Public Notice Information

On March 3, 2011, the Office of Air Quality (OAQ) had a notice published in the Chesterton Tribune in Chesterton, Indiana, stating that NIPSCO – Bailly Generating Station had applied for a Significant Modification to their Part 70 Operating Permit issued on June 27, 2006 relating to the installation of four (4) natural gas-fired flue gas reheating duct burners. The notice also stated that OAQ proposed to issue a permit for this operation and provided information on how the public could review the proposed permit and other documentation. Finally, the notice informed interested parties that there was a period of thirty (30) days to provide comments on whether or not this permit should be issued as proposed.

Comments Received

On April 4, 2011, IDEM, OAQ received a comment from John Ross of NIPSCO – Bailly Generating Station. The comment is summarized in the subsequent pages, with IDEM's corresponding response.

No changes have been made to the TSD because the OAQ prefers that the Technical Support Document reflects the permit that was on public notice. Changes that occur after the public notice are documented in this Addendum to the Technical Support Document. This accomplishes the desired result, ensuring that these types of concerns are documented and part of the record regarding this permit decision.

The summary of the comments and IDEM, OAQ responses, including changes to the permit (language deleted is shown in ~~strikeout~~ and language added is shown in **bold**) are as follows:

Comment 1: NIPSCO - Bailly wants the wording in Condition D.1.0 of the permit to be revised, similar language is found in the Technical Support Document (TSD) on page 6 of 9 State Rule Applicability Determination and page 8 of 9 D.1.0 in TSD:

D.1.0 Prevention Significant Deterioration (PSD) Minor Limits [326 IAC 2-2]

Pursuant to SSM 127-30156-00002, in order to render the requirements of 326 IAC 2-2 (PSD) not applicable:

The natural gas usage for the proposed flue gas reheating duct burners at Unit 8, **which are designed not to exceed 102 pounds of NOx emissions per million cubic feet (MMCF) natural gas**, shall be less than 782 Million Cubic Foot (MMCF) per twelve (12) consecutive month period, with compliance determined at the end of each month ~~and the NOx emission shall not exceed 102 pounds per MMCF of natural gas.~~

Compliance with these **above** limits will ensure that the potential to emit of NOx for the proposed burners will be less than 40 tons per year and render the requirements of 326 IAC 2-2 (PSD) not applicable to this modification.

Response 1: The revision "The natural gas usage for the proposed flue gas reheating duct burners at Unit 8, **which are designed not to exceed 102 pounds of NOx emissions per million cubic feet (MMCF) natural gas**" is a statement of the design of the boiler, it is not an enforceable limit. In order for the condition to be enforceable, the limit of 102 pounds of NOx emissions per MMCF of natural gas is required. Therefore, the condition has not be revised in the permit.

**Indiana Department of Environmental Management
Office of Air Quality**

Technical Support Document (TSD) for a Part 70 Significant Source and
Permit Modification.

Source Description and Location

Source Name:	NIPSCO – Bailly Generating Station
Source Location:	246 Bailly Station Road, Chesterton, IN 46304
County:	Porter
SIC Code:	4911
Operation Permit No.:	127-6635-00002
Operation Permit Issuance Date:	June 27, 2006
Significant Source Modification No.:	127-30156-00002
Significant Permit Modification No.:	127-30163-00002
Permit Reviewer:	Josiah Balogun

Existing Approvals

The source was issued Part 70 Operating Permit No. T127-6635-00002 on June 27, 2006. The source has since received the following approvals:

- (a) Acid Rain Permit Renewal No.127-19662-00002, issued on July 14, 2006;
- (b) First Significant Permit Modification No. 127-23445-00002, issued on May 7, 2008; and
- (c) Significant Permit Modification No. 127-26400-00002, issued on May 7, 2009.

County Attainment Status

The source is located in Porter County.

Pollutant	Designation
SO ₂	Cannot be classified for the area bounded on the north by Lake Michigan; on the west by the Lake County and Porter County line; on the south by I-80 and I-90; and on the east by the LaPorte County and Porter County line. The remainder of Porter County is better than national standards.
CO	Unclassifiable or attainment effective November 15, 1990.
O ₃	Attainment effective May 11, 2010, for the 8-hour ozone standard. ¹
PM ₁₀	Unclassifiable effective November 15, 1990.
NO ₂	Cannot be classified or better than national standards.
Pb	Not designated.

¹The U. S. EPA has acknowledged in both the proposed and final rulemaking for this redesignation that the anti-backsliding provisions for the 1-hour ozone standard no longer apply as a result of the redesignation under the 8-hour ozone standard. Therefore, permits in Porter County are no longer subject to review pursuant to Emission Offset, 326 IAC 2-3. Basic nonattainment designation effective federally April 5, 2005, for PM2.5.

- (a) Ozone Standards
Volatile organic compounds (VOC) and Nitrogen Oxides (NOx) are regulated under the Clean Air Act (CAA) for the purposes of attaining and maintaining the National Ambient Air Quality Standards (NAAQS) for ozone. Therefore, VOC and NOx emissions are considered when evaluating the rule applicability relating to ozone. Porter County has been designated as attainment or unclassifiable for ozone. Therefore, VOC and NOx

emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2.

- (b) **PM2.5**
U.S. EPA, in the Federal Register Notice 70 FR 943 dated January 5, 2005, has designated Porter County as nonattainment for PM2.5. On March 7, 2005 the Indiana Attorney General's Office, on behalf of IDEM, filed a law suit with the Court of Appeals for the District of Columbia Circuit challenging U.S. EPA's designation of nonattainment areas without sufficient data. However, in order to ensure that sources are not potentially liable for a violation of the Clean Air Act, the OAQ is following the U.S. EPA's New Source Review Rule for PM2.5 promulgated on May 8th, 2008, and effective on July 15th 2008. Therefore, direct PM2.5 and SO2 emissions were reviewed pursuant to the requirements of Nonattainment New Source Review, 326 IAC 2-1.1-5. See the State Rule Applicability – Entire Source section.
- (c) **Other Criteria Pollutants**
Porter County has been classified as attainment or unclassifiable in Indiana for all criteria pollutants. Therefore, these emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2.
- (d) **Fugitive Emissions**
Since this type of operation is in one of the twenty-eight (28) listed source categories under 326 IAC 2-2 or 326 IAC 2-3, fugitive emissions are counted toward the determination of PSD and Emission Offset applicability.

Source Status

The table below summarizes the potential to emit of the entire source, prior to the proposed modification, after consideration of all enforceable limits established in the effective permits:

Pollutant	Emissions (tons/year)
PM	> 100
PM10	> 100
PM2.5	> 100
SO ₂	> 100
VOC	< 100
CO	> 100
NO _x	> 100

- (a) This existing source is a major stationary source, under PSD (326 IAC 2-2), because a regulated pollutant is emitted at a rate of 100 tons per year or more, and it is one of the twenty-eight (28) listed source categories, as specified in 326 IAC 2-2-1(gg)(1).
- (b) This existing source is a major stationary source, under nonattainment new source review rules (326 IAC 2-1.1-5) since direct PM2.5 and SO₂ is emitted at a rate of 100 tons per year or more.
- (c) These emissions are based upon Part 70 Operating Permit No 127-6635-00002, issued on June 27, 2006.

The table below summarizes the potential to emit HAPs for the entire source, prior to the proposed modification, after consideration of all enforceable limits established in the effective permits:

HAPs	Potential To Emit (tons/year)
Single HAP	> 10
Total HAPs	> 25

This existing source is a major source of HAPs, as defined in 40 CFR 63.41, because HAP emissions are greater than ten (10) tons per year for a single HAP and greater than twenty-five (25) tons per year for a combination of HAPs. Therefore, this source is a major source under Section 112 of the Clean Air Act (CAA).

Actual Emissions

The following table shows the actual emissions from the source. This information reflects the 2009 OAQ emission data.

Pollutant	Actual Emissions (tons/year)
PM10	444
PM2.5	202
SO ₂	4,903
VOC	64
CO	296
NO _x	2,460
Lead	0.48

Description of Proposed Modification

The Office of Air Quality (OAQ) has reviewed a modification application, submitted by NIPSCO - Bailly Station on January 27, 2011, relating to the installation of four (4) natural gas-fired flue gas reheating duct burners in Unit 8. The purpose of the duct burners will be increase the temperature of the boiler exhaust gases entering the SCR system to achieve the desired SCR operating temperature during boiler startups and low load operation. The burners will be located after the boiler steam cycle and before the SCR to manage SCR operating temperature. This will reduce NO_x emissions below the specified limitations in the EPA's Consent Decree No. 2:11-cv-016. The following is a list of the modified emission unit(s) and pollution control device(s):

- (a) One (1) cyclone coal-fired boiler, identified as Unit 8, with construction completed in 1968, with a design heat input capacity of 3374 million Btu per hour, with an electrostatic precipitator (ESP) system for control of particulate matter. A wet limestone flue gas desulfurization system serves both Unit 7 and 8 for control of sulfur dioxide. Natural gas and/or No. 2 fuel oil can be fired during startup, shutdown, and malfunctions; the unit can also generate electricity while combusting natural gas only. Unit 8 is equipped with a selective catalytic reduction (SCR) system and in 2011 was also authorized to install up to four (4) natural gas fired flue gas reheating Duct Burners each with a maximum design heat input capacity of 40 million Btu per hour. Unit 8 has continuous emissions monitoring systems (CEMS) for nitrogen oxides (NO_x) and for sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Scrubbed emissions from Units 7 and 8 are exhausted through Stack CS001. Non-scrubbed emissions from Units 7 and 8 are exhausted through the bypass stack, Stack CS002.

Enforcement Issues

There are no pending enforcement actions.

Emission Calculations

See Appendix A of this document for detailed emission calculations.

Permit Level Determination – Part 70

Pursuant to 326 IAC 2-1.1-1(16), Potential to Emit is defined as “the maximum capacity of a stationary source or emission unit to emit any air pollutant under its physical and operational design. Any physical or operational limitation on the capacity of a source to emit an air pollutant, including air pollution control equipment and restrictions on hours of operation or type or amount of material combusted, stored, or processed shall be treated as part of its design if the limitation is enforceable by the U. S. EPA, IDEM, or the appropriate local air pollution control agency.”

The following table is used to determine the appropriate permit level under 326 IAC 2-7-10.5. This table reflects the PTE before controls for the four natural gas fired flue gas reheating duct burners (Modification to existing unit). Control equipment is not considered federally enforceable until it has been required in a federally enforceable permit.

Pollutant	Potential To Emit (tons/year)
PM	5.22
PM10	5.22
PM2.5	4.9
SO ₂	0.41
VOC	3.73
CO	84.1
NO _x	70.08

This source modification is subject to 326 IAC 2-7-10.5(f)(4)(C), because the potential to emit of NO_x is greater than twenty-five (25) tons per year, therefore this modification will be revised as a significant source modification. Additionally, the modification will be incorporated into the Part 70 Operating Permit through a Significant permit modification issued pursuant to 326 IAC 2-7-12, because the modification involve a case by case determination of emission limitation.

Permit Level Determination – PSD

The table below summarizes the potential to emit, reflecting all limits, of the emission units. Any control equipment is considered federally enforceable only after issuance of this Part 70 permit modification, and only to the extent that the effect of the control equipment is made practically enforceable in the permit. The major modification applicability determination performed by the applicant for the project at an existing electric utility steam generating unit (EUSGU). The applicant used the actual-to-projected actual applicability test for existing EUSGU for the proposed project and submitted the applicability evaluation to IDEM as part of the permit application for this project.

Past Actual to Future Projected Analysis for Unit 8		
Emissions	VOC (Tons)	CO (tons)
Baseline Actual Emissions for Unit 8	23.61	198.91

NIPSCO - Bailly Generating Station submitted information under a claim of confidentiality that supports the determination by IDEM, OAQ that the project will not result in a significant increase in NSR regulated pollutants. IDEM, OAQ has not yet made a determination on the confidentiality claim but is holding the information as confidential pursuant to IC 5-14-3-4, IC 5-14-3-10, and 326 IAC 17.1 *et seq.*

Process/Emission Unit	Potential to Emit (tons/year)						
	PM	PM10	PM _{2.5}	SO ₂	VOC	CO	NO _x
ATPA emissions increase (Unit 8 with Four (4) Burners)	---	---	---	--	9.7	81.65	--
Four (4) Burners	2.97	2.97	2.8	0.23	--	---	39.9*
Total for Modification	2.97	2.97	2.8	0.23	9.7	81.65	39.9
Significant Level	25	15	10	40	40	100	40

Note: See detailed ATPA emissions increase calculations in the permit application submitted by the applicant to IDEM on January 27, 2011
 * Limited PTE

The Permittee completed an Actual to Potential test (pursuant to 326 IAC 2-2-2, and 326 IAC 2-1.1-5) for this modification at a major stationary source that indicates that the modification will not be major for Prevention of Significant Deterioration (PSD) (326 IAC 2-2) or Nonattainment NSR (326 IAC 2-1.1.5). IDEM, OAQ has not reviewed this information and will not be making any determination in this regard as part of this approval. The applicant will be required to keep records and report in accordance with 326 IAC 2-2-8 (Source Obligation) for Unit 8.

This modification to an existing major stationary source is not major because the emissions increases are less than the PSD significant levels. Therefore, pursuant to 326 IAC 2-2, the PSD requirements do not apply.

Federal Rule Applicability Determination

- (a) The four (4) duct burners are not subject to the requirements of the New Source Performance Standard for Small Industrial-Commercial-Institutional Steam Generating Units 40 CFR 60, Subpart Db, because the duct burners will be installed down flow from any steam generating tubes, therefore, the increased heat input will have no impact on the unit's steam generating capability. Therefore, the four (4) duct burners are not subject to the requirements of this rule.
- (b) There are no National Emission Standards for Hazardous Air Pollutants (NESHAPs) (326 IAC 14, 326 IAC 20 and 40 CFR Part 63) applicable to this proposed modification.
- (c) Pursuant to 40 CFR 64.2, Compliance Assurance Monitoring (CAM) is applicable to new or modified emission units that involve a pollutant-specific emission unit and meet the following criteria:
 - (1) has a potential to emit before controls equal to or greater than the major source threshold for the pollutant involved;
 - (2) is subject to an emission limitation or standard for that pollutant; and
 - (3) uses a control device, as defined in 40 CFR 64.1, to comply with that emission limitation or standard.

None of the units being added in this modification use a control device and the emissions are less than 100 tons per year, therefore, the requirements of 40 CFR 64.1 do not apply.

Based on this evaluation, the requirements of 40 CFR Part 64, CAM are not applicable to any of the new units as part of this modification.

State Rule Applicability Determination

326 IAC 2-2 (Prevention of Significant Deterioration (PSD))

The Permittee has taken the following limit on NO_x emissions below the significant level for this modification:

The natural gas usage for the proposed flue gas reheating duct burners at Unit 8 shall be less than 782 Million Cubic Foot (MMCF) per twelve (12) consecutive month period, with compliance determined at the end of each month, and the NO_x emissions shall not exceed 102 pounds per MMCF of natural gas.

Compliance with these limits will ensure that the potential to emit of NO_x for the proposed burners will be less than 40 tons per year and render the requirements of 326 IAC 2-2 (PSD) not applicable to this modification.

326 IAC 2-1.1-5 (Nonattainment New Source Review)

Nonattainment New Source Review applicability is discussed under the Permit Level Determination – PSD and Emission Offset section.

326 IAC 2-4.1 (Major Sources of Hazardous Air Pollutants (HAP))

The operation of four (4) duct burners will emit less than ten (10) tons per year for a single HAP and less than twenty-five (25) tons per year for a combination of HAPs. Therefore, 326 IAC 2-4.1 does not apply.

Compliance Determination and Monitoring Requirements

Permits issued under 326 IAC 2-7 are required to ensure that sources can demonstrate compliance with all applicable state and federal rules on a continuous basis. All state and federal rules contain compliance provisions; however, these provisions do not always fulfill the requirement for a continuous demonstration. When this occurs IDEM, OAQ, in conjunction with the source, must develop specific conditions to satisfy 326 IAC 2-7-5. As a result, Compliance Determination Requirements are included in the permit. The Compliance Determination Requirements in Section D of the permit are those conditions that are found directly within state and federal rules and the violation of which serves as grounds for enforcement action.

If the Compliance Determination Requirements are not sufficient to demonstrate continuous compliance, they will be supplemented with Compliance Monitoring Requirements, also in Section D of the permit. Unlike Compliance Determination Requirements, failure to meet Compliance Monitoring conditions would serve as a trigger for corrective actions and not grounds for enforcement action. However, a violation in relation to a compliance monitoring condition will arise through a source's failure to take the appropriate corrective actions within a specific time period.

Proposed Changes

The changes listed below have been made to Part 70 Operating Permit No. 127-6635-00002. Deleted language appears as ~~strikethroughs~~ and new language appears in **bold**:

- Change 1: Sections A.2, D.1, E.1, F.1 and G have been updated in the permit to include the new control device incorporated into Unit 8. A new limit has been added to Section D.1 and the Record Keeping and Reporting Requirements have been updated. Condition D.1.0 - NOV Provisions has been deleted from the permit because NIPSCO entered in to a Consent Decree with Department of Justice and the Consent Decree has replaced the condition.

A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)]
[326 IAC 2-7-5(15)]

This stationary source consists of the following emission units and pollution control devices:

- (b) One (1) cyclone coal-fired boiler, identified as Unit 8, with construction completed in 1968, with a design heat input capacity of 3374 million Btu per hour, with an electrostatic precipitator (ESP) system for control of particulate matter. A wet limestone flue gas desulfurization system serves both Unit 7 and 8 for control of sulfur dioxide. Natural gas and/or No. 2 fuel oil can be fired during startup, shutdown, and malfunctions; the unit can also generate electricity while combusting natural gas only. **Unit 8 is equipped with a selective catalytic reduction (SCR) system and in 2011 was also authorized to install up to four (4) natural gas fired flue gas reheating Duct Burners each with a maximum design heat input capacity of 40 million Btu per hour.** Construction of a selective catalytic reduction (SCR) system on Unit 8 began in 2003. Unit 8 has continuous emissions monitoring systems (CEMS) for nitrogen oxides (NO_x) and for sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Scrubbed emissions from Units 7 and 8 are exhausted through Stack CS001. Non-scrubbed emissions from Units 7 and 8 are exhausted through the bypass stack, Stack CS002.

SECTION D.1 FACILITY OPERATION CONDITIONS - Coal Fired Boiler Units 7 and 8

Facility Description [326 IAC 2-7-5(15)]

- (b) One (1) cyclone coal-fired boiler, identified as Unit 8, with construction completed in 1968, with a design heat input capacity of 3374 million Btu per hour, with an electrostatic precipitator (ESP) system for control of particulate matter. A wet limestone flue gas desulfurization system serves both Unit 7 and 8 for control of sulfur dioxide. Natural gas and/or No. 2 fuel oil can be fired during startup, shutdown, and malfunctions; the unit can also generate electricity while combusting natural gas only. **Unit 8 is equipped with a selective catalytic reduction (SCR) system and in 2011 was also authorized to install up to four (4) natural gas fired flue gas reheating Duct Burners each with a maximum design heat input capacity of 40 million Btu per hour.** Construction of a selective catalytic reduction (SCR) system on Unit 8 began in 2003. Unit 8 has continuous emissions monitoring systems (CEMS) for nitrogen oxides (NO_x) and for sulfur dioxide (SO₂) and a continuous opacity monitoring (COM) system. Scrubbed emissions from Units 7 and 8 are exhausted through Stack CS001. Non-scrubbed emissions from Units 7 and 8 are exhausted through the bypass stack, Stack CS002.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

D.1.0 NOV Provisions

U.S. EPA has issued a Notice of Violation to this Permittee for allegedly failing to obtain, and comply with, New Source Review ("NSR"), Prevention of Significant Deterioration, and/or NSR for minor source Permits authorizing construction of physical modifications to units and operation of the modified units, as required by provisions set out in the Clean Air Act and 326 IAC 2-. Therefore, the permit shield in Section B - Permit Shield does not shield the Permittee from possible enforcement actions initiated by U.S. EPA, IDEM or citizens involving Boilers Units 7 and 8. Compliance with the terms of this permit does not serve as proof of compliance for Boilers Units 7 and 8 or the matters addressed in the NOV. Following resolution of this action, IDEM will reopen this permit, if necessary, to incorporate a compliance schedule or any new applicable requirements. The standard language of Section B - Permit Shield does not shield any activity on which the permit is silent.

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.1.0 Prevention Significant Deterioration (PSD) Minor Limit [326 IAC 2-2]

Pursuant to SSM 127-30156-00002, in order to render the requirements of 326 IAC 2-2 (PSD) not applicable:

The natural gas usage for the proposed flue gas reheating duct burners at Unit 8 shall be less than 782 Million Cubic Foot (MMCF) per twelve (12) consecutive month period, with compliance determined at the end of each month, and the NOx emissions shall not exceed 102 pounds per MMCF of natural gas.

Compliance with these limits will ensure that the potential to emit of NOx for the proposed burners will be less than 40 tons per year and render the requirements of 326 IAC 2-2 (PSD) not applicable to this modification.

D.1.10 Record Keeping Requirements

- (c) To document the compliance status with Condition D.1.0 - PSD Minor Limits, the Permittee shall maintain records of total natural gas usage for each month at the natural gas fired gas reheating duct burners in Unit 8.
- (ed) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

D.1.11 Reporting Requirements

- (c) A quarterly summary of the information to document the compliance status with Condition D.1.0 shall be submitted, using the reporting forms located at the end of this permit, or their equivalent, not later than thirty (30) days following the end of each calendar quarter. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34). Section C - General Reporting Requirements contains the Permittee's obligations with regard to the reporting required by this condition.

**INDIANA DEPARTMENT OF ENVIRONMENTAL
MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH**

Part 70 Quarterly Report

Source Name: Northern Indiana Public Service Company (NIPSCO) - Bailly Generating Station
Source Address: 246 Bailly Station Road, Chesterton, Indiana 46304
Mailing Address: Kelly R. Carmichael, 801 East 86th Avenue, Merrillville, Indiana 46410
Part 70 Permit No.: T127-6635-00002
Facilities: Four (4) Duct Burners
Parameter: Natural Gas Usage
Limit: 782 million cubic feet of natural gas used per 12 consecutive month period

QUARTER :

YEAR:

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

- No deviation occurred in this quarter.
- Deviation/s occurred in this quarter.
 Deviation has been reported on:

Submitted by: _____
 Title / Position: _____
 Signature: _____
 Date: _____
 Phone: _____

Conclusion and Recommendation

The construction of this proposed modification shall be subject to the conditions of the attached proposed Part 70 Significant Source Modification No. 127-30156-00002 and Significant Permit Modification No. 127-30163-00002. The staff recommends to the Commissioner that this Part 70 Significant Source and Significant Permit Modification be approved.

Appendix A: Emissions Calculations

Emission Summary

Source Name: NPSCO - Bailly Generating Station
Source Location: 246 Bailly Station Road, Chesterton, IN 46304
Permit Number: SPM127-30163-00002
Permit Reviewer: Josiah Balogun
Date: 15-Feb-2011

Uncontrolled Potential Emissions

	PM (tons/yr)	PM₁₀ (tons/yr)	PM_{2.5} (tons/yr)	SO₂ (tons/yr)	VOC (tons/yr)	CO (tons/yr)	NOx (tons/yr)	HAPs (tons/yr)
Emission Unit								
Four (4) duct burners	5.22	5.22	4.9	0.41	3.78	84.1	70.09	0
Total Emissions	5.2	5.2	4.9	0.41	3.78	84.1	70.1	Single HAP <10 Combined HAPs < 25

Limited Potential Emissions

	PM (tons/yr)	PM₁₀ (tons/yr)	PM_{2.5} (tons/yr)	SO₂ (tons/yr)	VOC (tons/yr)	CO (tons/yr)	NOx (tons/yr)	HAPs (tons/yr)
Emission Unit								
ATPA Emission Increase (Unit 8 with four (4) burners)	0	0	0	0	9.7	81.65	0	0
Four (4) duct burners	2.97	2.97	2.8	0.23	0	0	39.9	0
Total Emissions	2.97	2.97	2.8	0.2	9.7	81.65	39.9	Single HAP <10 Combined HAPs < 25

**Appendix A: Emissions Calculations
Natural Gas Combustion Only
MM BTU/HR <100
Four (4) Duct Burners**

Company Name: NPSCO - Bailly Generating Station
Address City IN Zip: 246 Bailly Station Road, Chesterton, IN 46304
Permit Number: SPM127-30163-00002
Reviewer: Josiah Balogun
Date: 15-Feb-2011

Heat Input Capacity
MMBtu/hr

Potential Throughput
MMCF/yr

160.0

1374.4

Emission Factor in lb/MMCF	Pollutant						
	PM(F)	PM10(F+C)	PM2.5(F+C)**	SO2	NOx	VOC	CO
Potential Emission in tons/yr	7.6	7.6	7.1	0.6	102.0	5.5	122.4
	5.22	5.22	4.9	0.41	70.09	3.78	84.1

Note: Emission factors are based upon AP - 42, Chapter 1.4 July, 1998) except NOx and CO

Emission factors for NOx and CO are from vendor information.

**PM2.5 calculated as sum of PM10 emission (F) emission factor multiplied by 75% (ratio of PM2.5/PM10) and PM () i.e 1.9 X (0.75) + 5.7lb/MMcf

PM emission factor is filterable PM only. PM10 emission factor is filterable and condensable PM10 combined.

*Emission Factors for NOx: Uncontrolled = 100, Low NOx Burner = 50, Low NOx Burners/Flue gas recirculation = 32

Methodology

All emission factors are based on normal firing.

MMBtu = 1,000,000 Btu

MMCF = 1,000,000 Cubic Feet of Gas

Potential Throughput (MMCF) = Heat Input Capacity (MMBtu/hr) x 8,760 hrs/yr x 1 MMCF/1,000 MMBtu

Emission Factors are from AP 42, Chapter 1.4, Tables 1.4-1, 1.4-2, 1.4-3, SCC #1-02-006-02, 1-01-006-02, 1-03-006-02, and 1-03-006-03 (SUPPLEMENT D 3/98)

Emission (tons/yr) = Throughput (MMCF/yr) x Emission Factor (lb/MMCF)/2,000 lb/ton

**Appendix A: Emissions Calculations
Natural Gas Combustion Only
MM BTU/HR <100
Four (4) Duct Burners**

Company Name: NPSCO - Bailly Generating Station
Address City IN Zip: 246 Bailly Station Road, Chesterton, IN 46304
Permit Number: SPM127-30163-00002
Reviewer: Josiah Balogun
Date: 15-Feb-2011

Heat Input Capacity
MMBtu/hr

Potential Throughput
MMCF/yr

160.0

782.0

Emission Factor in lb/MMCF	Pollutant						
	PM(F)	PM10(F+C)	PM2.5(F+C)**	SO2	NOx	VOC	CO
Potential Emission in tons/yr	7.6	7.6	7.1	0.6	102.0	5.5	122.4
	2.97	2.97	2.8	0.23	39.88	2.15	47.9

Note: Emission factors are based upon AP - 42, Chapter 1.4 July, 1998) except NOx and CO

Emission factors for NOx and CO are from vendor information.

**PM2.5 calculated as sum of PM10 emission (F) emission factor multiplied by 75% (ratio of PM2.5/PM10) and PM () i.e 1.9 X (0.75) + 5.7lb/MMcf

PM emission factor is filterable PM only. PM10 emission factor is filterable and condensable PM10 combined.

*Emission Factors for NOx: Uncontrolled = 100, Low NOx Burner = 50, Low NOx Burners/Flue gas recirculation = 32

Methodology

All emission factors are based on normal firing.

MMBtu = 1,000,000 Btu

MMCF = 1,000,000 Cubic Feet of Gas

Potential Throughput (MMCF) = Heat Input Capacity (MMBtu/hr) x 8,760 hrs/yr x 1 MMCF/1,000 MMBtu

Emission Factors are from AP 42, Chapter 1.4, Tables 1.4-1, 1.4-2, 1.4-3, SCC #1-02-006-02, 1-01-006-02, 1-03-006-02, and 1-03-006-03 (SUPPLEMENT D 3/98)

Emission (tons/yr) = Throughput (MMCF/yr) x Emission Factor (lb/MMCF)/2,000 lb/ton



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

SENT VIA U.S. MAIL: CONFIRMED DELIVERY AND SIGNATURE REQUESTED

TO: Mr. John Ross
NIPSCO – Bailly Generating Station
801 East 86th Avenue
Merrillville, IN 46410

DATE: April 26, 2011

FROM: Matt Stuckey, Branch Chief
Permits Branch
Office of Air Quality

SUBJECT: Final Decision
Significant Permit Modification
127-30163-00002

Enclosed is the final decision and supporting materials for the air permit application referenced above. Please note that this packet contains the original, signed, permit documents.

The final decision is being sent to you because our records indicate that you are the contact person for this application. However, if you are not the appropriate person within your company to receive this document, please forward it to the correct person.

A copy of the final decision and supporting materials has also been sent via standard mail to:
Phillip Pack (Sr. VP – NIPSCO)
OAQ Permits Branch Interested Parties List

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178, or toll-free at 1-800-451-6027 (ext. 3-0178), and ask to speak to the permit reviewer who prepared the permit. If you think you have received this document in error, please contact Joanne Smiddie-Brush of my staff at 1-800-451-6027 (ext 3-0185), or via e-mail at jbrush@idem.IN.gov.

Final Applicant Cover letter.dot 11/30/07



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

April 26, 2011

TO: Hageman Memorial Public Library

From: Matthew Stuckey, Branch Chief
Permits Branch
Office of Air Quality

Subject: **Important Information for Display Regarding a Final Determination**

Applicant Name: NIPSCO – Bailly Generating Station
Permit Number: 127-30163-00002

You previously received information to make available to the public during the public comment period of a draft permit. Enclosed is a copy of the final decision and supporting materials for the same project. Please place the enclosed information along with the information you previously received. To ensure that your patrons have ample opportunity to review the enclosed permit, **we ask that you retain this document for at least 60 days.**

The applicant is responsible for placing a copy of the application in your library. If the permit application is not on file, or if you have any questions concerning this public review process, please contact Joanne Smiddie-Brush, OAQ Permits Administration Section at 1-800-451-6027, extension 3-0185.

Enclosures
Final Library.dot 11/30/07

Mail Code 61-53

IDEM Staff	MIDENNEY 4/26/2011 NIPSCO - Bailly Station 127-30163-00002 (final)		Type of Mail: CERTIFICATE OF MAILING ONLY	AFFIX STAMP HERE IF USED AS CERTIFICATE OF MAILING
Name and address of Sender		Indiana Department of Environmental Management Office of Air Quality – Permits Branch 100 N. Senate Indianapolis, IN 46204		

Line	Article Number	Name, Address, Street and Post Office Address	Postage	Handing Charges	Act. Value (If Registered)	Insured Value	Due Send if COD	R.R. Fee	S.D. Fee	S.H. Fee	Rest. Del. Fee	Remarks
1		John M. Ross NIPSCO - Bailly Station 801 E 86th Avenue Merrillville IN 46410 (Source CAATS) via confirmed delivery										
2		Phillip W. Pack Sr. VP NIPSCO - Bailly Station 801 E 86th Avenue Merrillville IN 46410 (RO CAATS)										
3		Mr. Rudolph Nichols United Steelworkers of America 1301 Texas St, Room 217 Gary IN 46402 (Affected Party)										
4		Laurence A. McHugh Barnes & Thornburg 100 North Michigan South Bend IN 46601-1632 (Affected Party)										
5		Hageman Memorial Public Library 100 Francis Porter IN 46304 (Library)										
6		Porter County Board of Commissioners 155 Indiana Ave, Ste 205 Valparaiso IN 46383 (Local Official)										
7		Porter County Health Department 155 Indiana Ave, Suite 104 Valparaiso IN 46383-5502 (Health Department)										
8		Shawn Sobocinski 3229 E. Atlanta Court Portage IN 46368 (Affected Party)										
9		Mr. Ed Dybel 2440 Schrage Avenue Whiting IN 46394 (Affected Party)										
10		Ms. Carolyn Marsh Lake Michigan Calumet Advisory Council 1804 Oliver St Whiting IN 46394-1725 (Affected Party)										
11		Mr. Dee Morse National Park Service 12795 W Alameda Pky, P.O. Box 25287 Denver CO 80225-0287 (Affected Party)										
12		Mr. Joseph Virgil 128 Kinsale Avenue Valparaiso IN 46385 (Affected Party)										
13		Mark Coleman 9 Locust Place Ogden Dunes IN 46368 (Affected Party)										
14		Mr. Chris Hernandez Pipefitters Association, Local Union 597 8762 Louisiana St., Suite G Merrillville IN 46410 (Affected Party)										
15		Eric & Sharon Haussman 57 Shore Drive Ogden Dunes IN 46368 (Affected Party)										

Total number of pieces Listed by Sender	Total number of Pieces Received at Post Office	Postmaster, Per (Name of Receiving employee)	The full declaration of value is required on all domestic and international registered mail. The maximum indemnity payable for the reconstruction of nonnegotiable documents under Express Mail document reconstructing insurance is \$50,000 per piece subject to a limit of \$50, 000 per occurrence. The maximum indemnity payable on Express mil merchandise insurance is \$500. The maximum indemnity payable is \$25,000 for registered mail, sent with optional postal insurance. See Domestic Mail Manual R900, S913, and S921 for limitations of coverage on inured and COD mail. See International Mail Manual for limitations o coverage on international mail. Special handling charges apply only to Standard Mail (A) and Standard Mail (B) parcels.
14			

Mail Code 61-53

IDEM Staff	MIDENNEY 4/26/2011 NIPSCO - Bailly Station 127-30163-00002 (final)		Type of Mail: CERTIFICATE OF MAILING ONLY	AFFIX STAMP HERE IF USED AS CERTIFICATE OF MAILING
Name and address of Sender		Indiana Department of Environmental Management Office of Air Quality – Permits Branch 100 N. Senate Indianapolis, IN 46204		

Line	Article Number	Name, Address, Street and Post Office Address	Postage	Handing Charges	Act. Value (If Registered)	Insured Value	Due Send if COD	R.R. Fee	S.D. Fee	S.H. Fee	Rest. Del. Fee	Remarks
1		Chesterton Town Council 726 Broadway Chesterton IN 46304 (Local Official)										
2		Joseph Hero 11723 S Oakridge Drive St. John IN 46373 (Affected Party)										
3		Gitte Laasby Post Tribune 1433 E. 83rd Ave Merrillville IN 46410 (Affected Party)										
4		Mark Zeltwanger 26545 CR 52 Nappanee IN 46550 (Affected Party)										
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												

Total number of pieces Listed by Sender 4	Total number of Pieces Received at Post Office	Postmaster, Per (Name of Receiving employee)	The full declaration of value is required on all domestic and international registered mail. The maximum indemnity payable for the reconstruction of nonnegotiable documents under Express Mail document reconstructing insurance is \$50,000 per piece subject to a limit of \$50, 000 per occurrence. The maximum indemnity payable on Express mil merchandise insurance is \$500. The maximum indemnity payable is \$25,000 for registered mail, sent with optional postal insurance. See Domestic Mail Manual R900, S913, and S921 for limitations of coverage on inured and COD mail. See International Mail Manual for limitations o coverage on international mail. Special handling charges apply only to Standard Mail (A) and Standard Mail (B) parcels.
---	--	--	--