INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

TO: Interested Parties / Applicant

DATE: May 1, 2012

RE: Purdue University / 157-30742-00012

FROM: Matthew Stuckey, Branch Chief
Permits Branch
Office of Air Quality

Notice of Decision: Approval – Effective Immediately

Please be advised that on behalf of the Commissioner of the Department of Environmental Management, I have issued a decision regarding the enclosed matter. Pursuant to IC 13-17-3-4 and 326 IAC 2, this permit modification is effective immediately, unless a petition for stay of effectiveness is filed and granted, and may be revoked or modified in accordance with the provisions of IC 13-15-7-1.

If you wish to challenge this decision, IC 4-21.5-3-7 and IC 13-15-7-3 require that you file a petition for administrative review. This petition may include a request for stay of effectiveness and must be submitted to the Office Environmental Adjudication, 100 North Senate Avenue, Government Center North, Suite N 501E, Indianapolis, IN 46204, **within eighteen (18) days of the mailing of this notice**. The filing of a petition for administrative review is complete on the earliest of the following dates that apply to the filing:

(1) the date the document is delivered to the Office of Environmental Adjudication (OEA);
(2) the date of the postmark on the envelope containing the document, if the document is mailed to OEA by U.S. mail; or
(3) The date on which the document is deposited with a private carrier, as shown by receipt issued by the carrier, if the document is sent to the OEA by private carrier.

The petition must include facts demonstrating that you are either the applicant, a person aggrieved or adversely affected by the decision or otherwise entitled to review by law. Please identify the permit, decision, or other order for which you seek review by permit number, name of the applicant, location, date of this notice and all of the following:

(1) the name and address of the person making the request;
(2) the interest of the person making the request;
(3) identification of any persons represented by the person making the request;
(4) the reasons, with particularity, for the request;
(5) the issues, with particularity, proposed for considerations at any hearing; and
(6) identification of the terms and conditions which, in the judgment of the person making the request, would be appropriate in the case in question to satisfy the requirements of the law governing documents of the type issued by the Commissioner.

Recycled Paper An Equal Opportunity Employer *Please Recycle*

Pursuant to 326 IAC 2-7-18(d), any person may petition the U.S. EPA to object to the issuance of a Title V operating permit or modification within sixty (60) days of the end of the forty-five (45) day EPA review period. Such an objection must be based only on issues that were raised with reasonable specificity during the public comment period, unless the petitioner demonstrates that it was impractible to raise such issues, or if the grounds for such objection arose after the comment period.

To petition the U.S. EPA to object to the issuance of a Title V operating permit, contact:

U.S. Environmental Protection Agency
401 M Street
Washington, D.C. 20406

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178. Callers from within Indiana may call toll-free at 1-800-451-6027, ext. 3-0178.

Enclosures
FNTV-PMOD.doc 3/27/08

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

Robin Mills Ridgway
Purdue University - West Lafayette
550 Stadium Mall Dr, Civil Engineering Bldg, B173
West Lafayette, IN 47907-2051

May 1, 2012

Re: 157-30742-00012
Significant Permit Modification to Part 70 Operating
Permit Renewal No.: T 157-27313-00012

Dear Ms. Ridgway:

Purdue University - West Lafayette was issued a Part 70 Operating Permit Renewal on August 27, 2010, for stationary boilers and other support facilities for the educational services operation, located at Purdue University. A letter requesting changes to this permit was received on July 26, 2011. Pursuant to the provisions of 326 IAC 2-7-12 a significant permit modification to this permit is hereby approved as described in the attached Technical Support Document.

Purdue University - West Lafayette has applied to update the permit to address removal of permit requirements that are no longer necessary since the construction activities that were previously permitted have been canceled and will not occur.

All other conditions of the permit shall remain unchanged and in effect. For your convenience, the entire Part 70 Operating Permit as modified will be provided at issuance. A copy of this permit is available on the Internet at: www.in.gov/ai/appfiles/idem-caats/.

This decision is subject to the Indiana Administrative Orders and Procedures Act – IC 4-21.5-3-5. If you have any questions on this matter, please contact Kimberly Cottrell, OAQ, 100 North Senate Avenue, MC 61-53, Room 1003, Indianapolis, Indiana, 46204-2251, or call at (800) 451-6027, and ask for Kimberly Cottrell or extension (3-0870), or dial (317) 233-0870.

Sincerely,

Tripurari Sinha

Tripurari P. Sinha, Ph. D., Section Chief
Permits Branch
Office of Air Quality

Attachments: Updated Permit & Technical Support Document

TPS/klc

cc: File – Tippecanoe County
Tippecanoe County Health Department
U.S. EPA, Region V
Compliance and Enforcement Branch

Mr. Robert E McMains
Purdue University - West Lafayette
401 S. Grant St., 1662 L. J. Freehafer Hall
West Lafayette, IN 47907-4024

David Jordan
ERM
11350 North Meridian, Suite 220
Carmel, IN 46032

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
We Protect Hoosiers and Our Environment.

Mitchell F. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

PART 70 OPERATING PERMIT RENEWAL
OFFICE OF AIR QUALITY

Purdue University
401 S. Grant Street
Freehafer Hall of Administrative Services
West Lafayette, Indiana 47907-2024

(herein known as the Permittee) is hereby authorized to operate subject to the conditions contained herein, the source described in Section A (Source Summary) of this permit.

The Permittee must comply with all conditions of this permit. Noncompliance with any provisions of this permit is grounds for enforcement action; permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. Noncompliance with any provision of this permit, except any provision specifically designated as not federally enforceable, constitutes a violation of the Clean Air Act. It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. An emergency does constitute an affirmative defense in an enforcement action provided the Permittee complies with the applicable requirements set forth in Section B, Emergency Provisions.

This permit is issued in accordance with 326 IAC 2 and 40 CFR Part 70 Appendix A and contains the conditions and provisions specified in 326 IAC 2-7 as required by 42 U.S.C. 7401, et. seq. (Clean Air Act as amended by the 1990 Clean Air Act Amendments), 40 CFR Part 70.6, IC 13-15 and IC 13-17. This permit also addresses certain new source review requirements for existing equipment and is intended to fulfill the new source review procedures, pursuant to 326 IAC 2-2 and 326 IAC 2-7-10.5, applicable to those conditions.

Operation Permit Renewal No.: T 157-27313-00012	
Issued by/ Original signed by: Tripurari P. Sinha, Ph. D., Section Chief Permits Branch Office of Air Quality	Issuance Date: August 27, 2010 Expiration Date: August 27, 2015

1st Administrative Amendment No. 157-30374-00012, issued on April 19, 2011.

Significant Permit Modification No.: 157-30742-00012	
Issued by: Tripurari P. Sinha Tripurari P. Sinha, Ph. D., Section Chief Permits Branch Office of Air Quality	Issuance Date: May 1, 2012 Expiration Date: August 27, 2015

TABLE OF CONTENTS

A SOURCE SUMMARY 9

A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)] [326 IAC 2-7-1(22)]
A.2 Part 70 Source Definition [326 IAC 2-7-1(22)]
A.3 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)] [326 IAC 2-7-5(15)]
A.4 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)] [326 2-7-4(c)] [326 IAC 2-7-5(15)]
A.5 Part 70 Permit Applicability [326 IAC 2-7-2]

B GENERAL CONDITIONS 14

B.1 Definitions [326 IAC 2-7-1]
B.2 Permit Term [326 IAC 2-7-5(2)] [326 IAC 2-1.1-9.5] [326 IAC 2-7-4(a)(1)(D)] [IC 13-15-3-6(a)]
B.3 Term of Conditions [326 IAC 2-1.1-9.5]
B.4 Enforceability [326 IAC 2-7-7]
B.5 Termination of Right to Operate [326 IAC 2-7-10] [326 IAC 2-7-4(a)]
B.6 Severability [326 IAC 2-7-5(5)]
B.7 Property Rights or Exclusive Privilege [326 IAC 2-7-5(6)(D)]
B.8 Duty to Provide Information [326 IAC 2-7-5(6)(E)]
B.9 Certification [326 IAC 2-7-4(f)] [326 IAC 2-7-6(1)] [326 IAC 2-7-5(3)(C)]
B.10 Annual Compliance Certification [326 IAC 2-7-6(5)]
B.11 Preventive Maintenance Plan [326 IAC 2-7-5(1), (3) and (13)] [326 IAC 2-7-6(1) and (6)] [326 IAC 1-6-3]
B.12 Emergency Provisions [326 IAC 2-7-16]
B.13 Permit Shield [326 IAC 2-7-15] [326 IAC 2-7-20] [326 IAC 2-7-12]
B.14 Prior Permits Superseded [326 IAC 2-1.1-9.5] [326 IAC 2-7-10.5]
B.15 Permit Modification, Reopening, Revocation and Reissuance, or Termination [326 IAC 2-7-5(6)(C)] [326 IAC 2-7-8(a)] [326 IAC 2-7-9]
B.16 Permit Renewal [326 IAC 2-7-3] [326 IAC 2-7-4] [326 IAC 2-7-8(e)]
B.17 Permit Amendment or Modification [326 IAC 2-7-11] [326 IAC 2-7-12] [40 CFR 72]
B.18 Permit Revision Under Economic Incentives and Other Programs [326 IAC 2-7-5(8)] [326 IAC 2-7-12(b)(2)]
B.19 Operational Flexibility [326 IAC 2-7-20] [326 IAC 2-7-10.5]
B.20 Source Modification Requirement [326 IAC 2-7-10.5] [326 IAC 2-2-2]
B.21 Inspection and Entry [326 IAC 2-7-6] [IC 13-14-2-2] [IC 13-30-3-1] [IC 13-17-3-2]
B.22 Transfer of Ownership or Operational Control [326 IAC 2-7-11]
B.23 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-7-5(7)] [326 IAC 2-1.1-7]
B.24 Credible Evidence [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [62 FR 8314] [326 IAC 1-1-6]

C SOURCE OPERATION CONDITIONS 25

Emission Limitations and Standards [326 IAC 2-7-5(1)]
C.1 Particulate Emission Limitations for Processes with Process Weight Rates Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]
C.2 Opacity [326 IAC 5-1]
C.3 Open Burning [326 IAC 4-1] [IC 13-17-9]
C.4 Incineration [326 IAC 4-2] [326 IAC 9-1-2]
C.5 Fugitive Dust Emissions [326 IAC 6-4]
C.6 Stack Height [326 IAC 1-7]
C.7 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

Testing Requirements [326 IAC 2-7-6(1)]
C.8 Performance Testing [326 IAC 3-6]

Compliance Requirements [326 IAC 2-1.1-11]
C.9 Compliance Requirements [326 IAC 2-1.1-11]

Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]
C.10 Compliance Monitoring [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]
C.11 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

Corrective Actions and Response Steps [326 IAC 2-7-5] [326 IAC 2-7-6]
C.12 Emergency Reduction Plans [326 IAC 1-5-2] [326 IAC 1-5-3]
C.13 Risk Management Plan [326 IAC 2-7-5(12)] [40 CFR 68]
C.14 Response to Excursions or Exceedances [326 IAC 2-7-5] [326 IAC 2-7-6]
C.15 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5] [326 IAC 2-7-6]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
C.16 Emission Statement [326 IAC 2-7-5(3)(C)(iii)] [326 IAC 2-7-5(7)] [326 IAC 2-7-19(c)] [326 IAC 2-6]
C.17 General Record Keeping Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [326 IAC 2-2] [326 IAC 2-3]
C.18 General Reporting Requirements [326 IAC 2-7-5(3)(C)] [326 IAC 2-1.1-11] [326 IAC 2-2] [326 IAC 2-3]

Stratospheric Ozone Protection
C.19 Compliance with 40 CFR 82 and 326 IAC 22-1

D.1 FACILITY OPERATION CONDITIONS - Coal-Fired Boilers 1 and 2 32

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.1.1 Nitrogen Oxides Emission Limitations [326 IAC 2-2-4]
D.1.2 Particulate Emission Limitations for Sources of Indirect Heating [326 IAC 6-2-3]
D.1.3 SO_2 PSD Emission Limit [326 IAC 2-2-4]
D.1.4 Sulfur Dioxide Emission Limitations (SO_2) [326 IAC 7-1.1-2]
D.1.5 Retirement of Existing Operations [326 IAC 2-2]
D.1.6 Temporary Alternative Opacity Limitations [326 IAC 5-1-3]
D.1.7 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

Compliance Determination Requirements
D.1.8 Testing Requirements [326 IAC 2-7-6(1),(6)] [326 IAC 2-1.1-11]
D.1.9 Particulate Control [326 IAC 2-7-6(6)]
D.1.10 Continuous Emissions Monitoring [326 IAC 3-5]
D.1.11 Continuous Opacity Monitoring [326 IAC 3-5] [40 CFR 64]
D.1.12 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3] [326 IAC 7-2-1]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.1.13 Opacity Readings [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)] [40 CFR 64]
D.1.14 Electrostatic Precipitator Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)] [40 CFR 64]
D.1.15 Baghouse Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)] [40 CFR 64]
D.1.16 Broken or Failed Bag Detection - Multi-Compartment Baghouses [40 CFR 64]
D.1.17 SO_2 Monitoring System Downtime [326 IAC 2-7-6] [326 IAC 2-7-5(3)] [326 IAC 3-7-2] [326 IAC 3-7-3]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
D.1.18 Record Keeping Requirements
D.1.19 Reporting Requirements

D.2 FACILITY OPERATION CONDITIONS - Coal-Fired Boiler 5 40

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.2.1 Boiler 5 PSD Emission Limits [326 IAC 2-2-4]
D.2.4 Sulfur Dioxide Emission Limitations [326 IAC 7-1.1-2]
D.2.3 Temporary Alternative Opacity Limitations [326 IAC 5-1-3]
D.2.4 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

Compliance Determination Requirements
D.2.5 Testing Requirements [326 IAC 2-7-6(1), (6)] [326 IAC 2-1.1-11]
D.2.6 Compliance Determination Requirements [326 IAC 2-2]
D.2.7 Continuous Emissions Monitoring [326 IAC 3-5] [40 CFR 64]
D.2.8 Continuous Opacity Monitoring [326 IAC 3-5] [40 CFR 64]
D.2.9 Particulate Control [326 IAC 2-7-6(6)] [40 CFR 64]
D.2.10 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3] [326 IAC 7-2-1]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.2.11 Opacity Readings [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)] [40 CFR 64]
D.2.12 Baghouse Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)] [40 CFR 64]
D.2.13 SO_2 Monitoring System Downtime [326 IAC 2-7-6] [326 IAC 2-7-5(3)] [326 IAC 3-7-2] [326 IAC 3-7-3]
D.2.14 NO_X Monitoring System Downtime [326 IAC 2-7-6] [326 IAC 2-7-5(3)] [326 IAC 3-7-2] [326 IAC 3-7-3]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
D.2.15 Record Keeping Requirements
D.2.16 Reporting Requirements

D.3 FACILITY OPERATION CONDITIONS - Gas and Oil-Fired Boiler 3 46

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.3.1 Temporary Alternative Opacity Limitations [326 IAC 5-1-3]
D.3.2 Sulfur Dioxide (SO_2) [326 IAC 7-1.1]
D.3.3 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

Compliance Determination Requirements
D.3.4 Continuous Emissions Monitoring [326 IAC 3-5]
D.3.5 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3] [326 IAC 7-2] [326 IAC 7-1.1-2]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
D.3.6 Record Keeping Requirements
D.3.7 Reporting Requirements

D.4 FACILITY OPERATION CONDITIONS - Gas-Fired Boiler 7 49

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.4.1 Boiler 7 PSD Minor Limits [326 IAC 2-2]

Compliance Determination Requirements
D.4.2 Testing Requirements [326 IAC 2-7-6(1), (6)] [326 IAC 2-1.1-11]
D.4.3 Compliance Determination Requirements [326 IAC 2-2]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
D.4.4 Record Keeping Requirements
D.4.5 Reporting Requirements

D.5 FACILITY OPERATION CONDITIONS - Coal Handling and Processing 51

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.5.1 PSD Minor Limit for COAL Segment 1 and COAL Segment 2 [326 IAC 2-2]
D.5.2 Particulate [326 IAC 6-3-2]
D.5.3 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

Compliance Determination Requirements
D.5.4 Particulate Control [326 IAC 2-7-6(6)]
D.5.5 Compliance Determination Requirements [326 IAC 2-2]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.5.6 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.5.7 Baghouse Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.5.8 Broken or Failed Bag Detection - Single and Multi-Compartment Baghouses [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.5.9 RotoClone Failure Detection [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
D.5.10 Record Keeping Requirements
D.5.11 Reporting Requirements

D.6 FACILITY OPERATION CONDITIONS - Ash Handling 56

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.6.1 PSD Minor Limits for Ash Segment 1 [326 IAC 2-2-1]
D.6.2 Particulate [326 IAC 6-3-2]
D.6.3 Preventative Maintenance Plan [326 IAC 2-7-5(1)(13)]

Compliance Determination Requirements
D.6.4 Particulate Control [326 IAC 2-7-10.5(d)(5)(C)]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.6.5 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.6.6 Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.6.7 Broken or Failed Bag Detection - Single Compartment Baghouses [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
D.6.8 Record Keeping Requirements

D.7 FACILITY OPERATION CONDITIONS - Limestone Handling 60

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.7.1 Particulate [326 IAC 6-3-2]
D.7.2 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

Compliance Determination Requirements
D.7.3 Particulate Control [326 IAC 2-7-6(6)]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.7.4 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.7.5 Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]
D.7.6 Broken or Failed Bag Detection - Single Compartment Baghouses [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
D.7.7 Record Keeping Requirements

D.8 FACILITY OPERATION CONDITIONS - Incinerators 63

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.8.1 Incinerators [326 IAC 4-2-2]
D.8.2 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
D.8.3 Record Keeping Requirements

D.9 FACILITY OPERATION CONDITIONS - Black Start Generator 66

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.9.1 Source Modification Limits [326 IAC 2-7-10.5(d)(5)(D)] [326 IAC 2-2-1]
D.9.2 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
D.9.3 Record Keeping Requirements
D.9.4 Reporting Requirements

D.10 FACILITY OPERATION CONDITIONS - Insignificant Boilers 68

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.10.1 Particulate Emission Limitations for Sources of Indirect Heating [326 IAC 6-2-4]

D.11 FACILITY OPERATION CONDITIONS - Pumps with Diesel Fueled Engines 69

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.11.1 Sulfur Dioxide Emission Limitations [326 IAC 7-1.1]

Compliance Determination Requirements
D.11.2 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3] [326 IAC 7-2] [326 IAC 7-1.1-2]

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]
D.11.3 Record Keeping Requirements

D.12 FACILITY OPERATION CONDITIONS - Degreasing Operations 70

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.12.1 Organic Solvent Degreasing Operations: Cold Cleaner Operation [326 IAC 8-3-2]
D.12.2 Organic Solvent Degreasing Operations: Cold Cleaner Degreaser Operation and Control [326 IAC 8-3-5]

D.13 FACILITY OPERATION CONDITIONS - Additional Insignificant Activities 72

Emission Limitations and Standards [326 IAC 2-7-5(1)]
D.13.1 Particulate [326 IAC 6-3-2]
D.13.2 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

Compliance Determination Requirements
D.13.3 Particulate Control [326 IAC 2-7-6(6)]

E.1 NEW SOURCE PERFORMANCE STANDARDS - Industrial-Commercial-Institutional Steam Generating Units 73

E.1.1 General Provisions Relating to NSPS [326 IAC 12-1] [40 CFR Part 60, Subpart A]
E.1.2 Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units [326 IAC 12] [40 CFR 60, Subpart Db]

E.2 NEW SOURCE PERFORMANCE STANDARDS - Fossil-Fuel-Fired Steam Generators for Which Construction Is Commenced After August 17, 1971 75

E.2.1 General Provisions Relating to NSPS [326 IAC 12-1] [40 CFR Part 60, Subpart A]
E.2.2 Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction is Commenced After August 17, 1971 [326 IAC 12] [40 CFR 60, Subpart D]
E.2.3 Alternative Opacity Requirement [326 IAC 12] [40 CFR 60, Subpart D]
E.2.4 Reporting Requirements

E.3 NEW SOURCE PERFORMANCE STANDARDS - Coal Preparation Plants 77

E.3.1 General Provisions Relating to NSPS [326 IAC 12-1] [40 CFR Part 60, Subpart A]
E.3.2 Standards of Performance for Coal Preparation Plants [326 IAC 12] [40 CFR 60, Subpart Y]

F Clean Air Interstate Rule (CAIR) Nitrogen Oxides Ozone Season Trading Programs – CAIR Permit for CAIR Units Under 326 IAC 24-3-1(a) 78

F.1 Automatic Incorporation of Definitions [326 IAC 24-3-7(e)] [40 CFR 97.323(b)]
F.2 Standard Permit Requirements [326 IAC 24-3-4(a)] [40 CFR 97.306(a)]
F.3 Monitoring, Reporting, and Record Keeping Requirements [326 IAC 24-3-4(b)] [40 CFR 97.306(b)]
F.4 Nitrogen Oxides Ozone Season Emission Requirements [326 IAC 24-3-4(c)] [40 CFR 97.306(c)]
F.5 Excess Emissions Requirements [326 IAC 24-3-4(d)] [40 CFR 97.306(d)]
F.6 Record Keeping Requirements [326 IAC 24-3-4(e)] [326 IAC 2-7-5(3)] [40 CFR 97.306(e)]
F.7 Reporting Requirements [326 IAC 24-3-4(e)] [40 CFR 97.306(e)]
F.8 Liability [326 IAC 24-3-4(f)] [40 CFR 97.306(f)]
F.9 Effect on Other Authorities [326 IAC 24-3-4(g)] [40 CFR 97.306(g)]
F.10 CAIR Designated Representative and Alternate CAIR Designated Representative [326 IAC 24-3-6] [40 CFR 97, Subpart BBBB]

Certification 82

Emergency Occurrence Report 83

Quarterly Reports 85

Quarterly Deviation and Compliance Monitoring Report 92

Attachment A: Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units [326 IAC 12] [40 CFR Part 60, Subpart Db]

Attachment B: Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction Is Commenced After August 17, 1971 [326 IAC 12] [40 CFR Part 60, Subpart D]

Attachment C: Standards of Performance for Coal Preparation Plants [326 IAC 12] [40 CFR Part 60, Subpart Y]

SECTION A SOURCE SUMMARY

This permit is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ). The information describing the source contained in Conditions A.1 through A.4 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this permit pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)] [326 IAC 2-7-1(22)]

The Permittee owns and operates stationary boilers and other support facilities for the educational services operation, located at Purdue University.

Source Address:	401 S. Grant St., Freehafer Hall of Administrative Services, West Lafayette, Indiana 47907-2024
General Source Phone Number:	(765) 496-6405
SIC Code:	8221
County Location:	Tippecanoe
Source Location Status:	Attainment for all criteria pollutants
Source Status:	Part 70 Operating Permit Program Major, under PSD Major Source, Section 112 of the Clean Air Act 1 of 28 Source Categories

A.2 Part 70 Source Definition [326 IAC 2-7-1(22)]

This source consists of air emission units located on the main campus in West Lafayette, Indiana, and at research farms in the vicinity of 5675 West 600 North, West Lafayette, Indiana, for the Animal Sciences Research and Education Center.

A.3 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)] [326 IAC 2-7-5(15)]

This stationary source consists of the following emission units and pollution control devices:

(a) One (1) spreader stoker coal fired boiler, identified as Boiler 1, with installation completed in 1960, with a nominal capacity of 281 MMBtu/hr, with a multi-cyclone collector and an electrostatic precipitator for particulate matter control, exhausting to stack WADE 01. Boiler 1 has two (2) auxiliary natural gas fired burners rated at 35 MMBtu/hr per burner, used for ignition and flame stabilization periods. Boiler 1 has a continuous emissions monitoring system (CEMS) for nitrogen oxides (NO_X) and a continuous opacity monitor (COM).

(b) One (1) spreader stoker coal fired boiler, identified as Boiler 2, with installation completed in 1967, with a nominal capacity of 274 MMBtu/hr, with a multi-cyclone collector and a multi-compartment baghouse for particulate matter control, exhausting to stack WADE 02. Boiler 2 has two (2) auxiliary natural gas fired burners rated at 35 MMBtu/hr per burner, used for ignition and flame stabilization periods. Boiler 2 has a continuous emissions monitoring system (CEMS) for nitrogen oxides (NO_X) and a continuous opacity monitor (COM).

(c) One (1) natural gas and distillate fuel oil fired boiler, identified as Boiler 3, with installation started in 1973 or 1974 and completed in 1974, with a nominal capacity of 286 MMBtu/hr, exhausting to stack WADE 03. Boiler 3 has a continuous emissions monitoring system (CEMS) for nitrogen oxides (NO_X).

Under the Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction is Commenced After August 17, 1971 NSPS (40 CFR 60, Subpart D), Boiler 3 is considered an affected source.

(d) One (1) circulating fluidized bed coal fired boiler, identified as Boiler 5, with installation started in 1989 and completed in 1991, with a nominal capacity of 279 MMBtu/hr, with a baghouse for particulate matter control and limestone injection for sulfur dioxide control, combusting natural gas for ignition, exhausting to stack WADE 05. Boiler 5 has continuous emissions monitoring systems (CEMS) for nitrogen oxides (NO_X) and sulfur dioxide (SO_2) and a continuous opacity monitor (COM).

Under the Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units NSPS (40 CFR 60, Subpart Db), Boiler 5 is considered an affected source.

(e) One (1) natural gas fired boiler, identified as Boiler 7, permitted in 2010, with a nominal capacity of 290 MMBtu/hr, exhausting to stack WADE 03. Boiler 7 has a continuous emissions monitoring system (CEMS) for nitrogen oxides (NO_X) for compliance with NSPS requirements.

Under the Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units NSPS (40 CFR 60, Subpart Db), Boiler 7 is considered an affected source.

(f) One (1) coal storage and handling system identified as COAL Segment 1, installed in 1960, with a nominal capacity of 110 tons/hr, including: truck unloading station with two (2) hoppers; two (2) vibratory feeders; one (1) underground belt conveyor with a magnetic separator; and one (1) bucket elevator terminating at the top of Wade Utility Plant. Coal is fed to the bunkers for Boiler 1, Boiler 2, and to the pre-crusher ahead of the indoor storage silo for Boiler 5. Emissions from the Boiler 1 and Boiler 2 bunkers are controlled by a RotoClone for each of the two (2) bunkers. The bunker for Boiler 1 exhausts to stack CB1. The bunker for Boiler 2 exhausts to CB2. COAL Segment 1 has been retained as a backup system for COAL Segment 2.

(g) One (1) coal storage and handling system identified as COAL Segment 2, installed in 1996, with a nominal capacity of 107 tons/hr, including: truck unloading and two (2) in-ground hoppers, two (2) vibratory feeders; one (1) totally enclosed tubular conveyor identified as BC-1 equipped with a magnetic separator and with emissions controlled by a baghouse exhausting to stack CV1; one (1) transfer enclosure with one (1) coal sampler, with emissions controlled by a baghouse exhausting to stack CV2; and one (1) totally enclosed tubular conveyor identified as BC-2 terminating at the top of Wade Utility Plant, with emissions from the final transfer point controlled by a baghouse exhausting to stack CV3. Coal is fed to the bunkers for Boiler 1, Boiler 2, and to the pre-crusher ahead of the indoor storage silo for Boiler 5. Emissions from the Boiler 1 and Boiler 2 bunkers are controlled by a RotoClone for each of the two (2) bunkers. The bunker for Boiler 1 exhausts to stack CB1. The bunker for Boiler 2 exhausts to CB2.

(h) One (1) outdoor coal storage pile area identified as COAL PILE 1, permitted in 1960 and 1996, with particulate matter emissions exhausting to the atmosphere.

(i) One (1) coal preparation system for Boiler 5, with installation completed in 1991, with a nominal capacity of 12.68 tons/hr, including: one (1) enclosed 125 ton/hr Redler conveyor with one (1) enclosed pre-crusher (both serving in a back-up capacity), one (1) 150 ton/hr enclosed belt conveyor and pre-crusher with installation completed in 2009. Both lines feed into; one (1) coal storage bunker, two (2) weigh belt feeders; and two (2) enclosed crushers with emission directed to a baghouse exhausting to stack CB5.

Under the Standards of Performance for Coal Preparation Plants NSPS (40 CFR 60, Subpart Y), the coal preparation system for Boiler 5 including the crushers and COAL Segment 2 are considered affected sources.

(j) One (1) pneumatic ash handling system for fly ash and bottom ash from Boiler 1 and Boiler 2, identified as ASH Segment 1, with a nominal capacity of 14 tons per hour (ton/hr), installed in approximately 1960 and modified in 2002. Ash/particulate matter collected from the primary, secondary and tertiary (baghouse) collection units are transferred to the existing ash silo. Ash accumulated in this silo is removed via a water mixer into trucks. Particulate matter that passes through the tertiary (baghouse) filter is exhausted to stack ASH1 while air from the ash silo is directed to a final filter before exhausting to stack AB1. Ash/particulate matter is transported through the system by an electric vacuum pump.

(k) One (1) pneumatic ash handling system for fly ash and bottom ash from Boiler 5, identified as ASH Segment 2, installed in 1991 and modified in 2002, exhausting to stacks ASH5A and ASH5B, with a nominal capacity of 20 tons/hr, with dust from ash transfer to the storage silo controlled by primary and secondary separator with tertiary baghouse filter, ASH5D. Ash is transferred from the silo to trucks at a nominal capacity of 300 tons/hr; dust is controlled by water mix, or by use of a telescoping spout with air displaced from the truck directed through a “filter module” with five canister filters which exhaust to the atmosphere though a vent, ASH5C.

(l) Material handling for the limestone injection system for Boiler 5, including pneumatic conveyance system, identified as LC5, from truck to bulk storage in a silo outside, identified as LS1, or to a "day bin", identified as LI5, inside the plant at an offload rate of approximately 12.5 tons per hour (ton/hr); gravity fed from day bin into Boiler 5. Particulate emissions are controlled by a baghouse, identified as LSBH1, on the silo and filter cartridges, identified as BVLI5, on the day bin.

(m) One (1) natural gas fired dual chamber animal carcass incinerator, identified as ADDL, installed in 1991, with a nominal heat input capacity of 6.5 MMBtu/hr, with an 800 lb/hr waste capacity, exhausting to stack PUADDL1.

(n) One (1) no. 2 fuel oil fired Black Start electric generator, identified as BSG, with a nominal heat input capacity of 17.7 MMBtu/hr, exhausting through stack BSG-1, with a fuel limit of 113,000 gallons per year.

(o) Two (2) portable pumps powered by 350 HP no. 2 diesel fueled engines and mounted on tri-axle trailers, operated intermittently (approximately 500 hours per year each), used for pumping lagoon material to the spray irrigation system and to transfer material from one lagoon to another.

A.4 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)] [326 2-7-4(c)] [326 IAC 2-7-5(15)]

This stationary source also includes the following insignificant activities which are specifically regulated, as defined in 326 IAC 2-7-1(21):

(a) Boilers using the following fuels:

(1) Natural gas-fired combustion sources with heat input equal to or less than ten million (10,000,000) Btu per hour, including three (3) natural gas fired Aviation Tech Building Boilers with low-NO_X combustion systems, installed in 2000, each with 2.8 MMBtu/hr heat input capacity, identified as AV Tech Boiler 1, AV Tech Boiler 2, and AV Tech Boiler 3.

(2) Propane or liquefied petroleum gas, or butane-fired combustion sources with heat input equal to or less than six million (6,000,000) Btu per hour.

(3) Fuel oil-fired combustion sources with heat input equal to or less than two million (2,000,000) Btu per hour and firing fuel containing less than five-tenths (0.5) percent sulfur by weight.

(b) Degreasing operations that do not exceed 145 gallons per 12 months, except if subject to 326 IAC 20-6. [326 IAC 8-3]

(c) Cleaners and solvents characterized as follows: [326 IAC 8-3]

(1) Having a vapor pressure equal to or less than 2 kPa; 15 mm Hg; or 0.3 psi measured at 38 degrees C (100°F) or;

(2) Having a vapor pressure equal to or less than 0.7 kPa; 5mm Hg; or 0.1 psi measured at 20°C (68°F); the use of which for all cleaners and solvents combined does not exceed 145 gallons per 12 months.

(d) The following equipment related to manufacturing activities not resulting in the emission of HAPs: brazing equipment, cutting torches, soldering equipment, welding equipment. [326 IAC 6-3]

(e) Covered conveyors for limestone conveying of less than or equal to 7,200 tons per day for sources other than mineral processing plants constructed after August 31, 1983. [326 IAC 6-3]

(f) Coal bunker and coal scale exhausts and associated dust collector vents. [326 IAC 6-3]

(g) Grinding and machining operations controlled with fabric filters, scrubbers, mist collectors, wet collectors and electrostatic precipitators with a design grain loading of less than or equal to 0.03 grains per actual cubic foot and a gas flow rate less than or equal to 4000 actual cubic feet per minute, including the following: deburring; buffing; polishing; abrasive blasting; pneumatic conveying; and woodworking operations. [326 IAC 6-3]

(h) Diesel and gasoline generators:

(1) One (1) BRK (nanotech) generator, with a nominal heat input rate of 3.4 MMBtu/hr.

(2) One (1) MJIS (biomed) generator, with a nominal heat input rate of 2.56 MMBtu/hr.

(3) Gasoline generators not exceeding one hundred ten (110) horsepower.

(4) Diesel generators not exceeding one thousand six hundred (1,600) horsepower.

(i) Other activities or categories not previously identified with potential, uncontrolled emissions equal to or less than thresholds require listing only: Pb 0.6 ton per year or 3.29 pounds per day, SO_2 5 pounds per hour (lb/hr) or 25 pounds per day, NO_X 5 pounds per hour (lb/hr) or 25 pounds per day, CO 25 pounds per day, PM 5 pounds per hour (lb/hr) or 25 pounds per day, VOC 3 pounds per hour (lb/hr) or 15 pounds per day:

(1) One (1) No. 2 fuel oil fired poultry incinerator, installed in 2007, with an afterburner and a 70 lb/hr waste capacity, located at the animal sciences farm, 5675 W 600 N, West Lafayette, Indiana; [326 IAC 4-2-1]

(2) One (1) No. 2 fuel oil fired animal carcass incinerator for swine, installed in 1991 or 1992, with an afterburner and a 100 lb/hr waste capacity, located at the animal sciences farm, 5675 W 600 N, West Lafayette, Indiana; [326 IAC 4-2-1]

(3) One (1) natural gas fired incinerator identified as RAD1, installed in 1986, with primary and secondary chambers and a 50 lb/hr waste capacity, for burning laboratory waste and non-infectious biological material contaminated with low level radioactivity, located at the By-Product Material Storage Building North (BMSN). [326 IAC 4-2-1]

(4) One (1) natural gas fired incinerator identified as RAD2, installed in 1996, with an afterburner and a 50 lb/hr waste capacity, for burning laboratory waste and non-infectious biological material contaminated with low level radioactivity, located at the By-Product Material Storage Building North (BMSN). [326 IAC 4-2-1]

A.5 Part 70 Permit Applicability [326 IAC 2-7-2]

This stationary source is required to have a Part 70 permit by 326 IAC 2-7-2 (Applicability) because:

(a) It is a major source, as defined in 326 IAC 2-7-1(22);

(b) It is a source in a source category designated by the United States Environmental Protection Agency (U.S. EPA) under 40 CFR 70.3 (Part 70 - Applicability).

SECTION B GENERAL CONDITIONS

B.1 Definitions [326 IAC 2-7-1]

Terms in this permit shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, the applicable definitions found in the statutes or regulations (IC 13-11, 326 IAC 1-2 and 326 IAC 2-7) shall prevail.

B.2 Permit Term [326 IAC 2-7-5(2)] [326 IAC 2-1.1-9.5] [326 IAC 2-7-4(a)(1)(D)] [IC 13-15-3-6(a)]

(a) The Part 70 Operating Permit Renewal, T 157-27313-00012, is issued for a fixed term of five (5) years as determined in accordance with IC 4-21.5-3-5(f) and IC 13-15-5-3. Subsequent revisions, modifications, or amendments of this permit do not affect the expiration date of this permit or of permits issued pursuant to Title IV of the Clan Air Act and 326 IAC 21 (Acid Deposition Control).

(b) If IDEM, OAQ, upon receiving a timely and complete renewal permit application, fails to issue or deny the permit renewal prior to the expiration date of this permit, this existing permit shall not expire and all terms and conditions shall continue in effect, including any permit shield provided in 326 IAC 2-7-15, until the renewal permit has been issued or denied.

B.3 Term of Conditions [326 IAC 2-1.1-9.5]

Notwithstanding the permit term of a permit to construct, a permit to operate, or a permit modification, any condition established in a permit issued pursuant to a permitting program approved in the state implementation plan shall remain in effect until:

(a) the condition is modified in a subsequent permit action pursuant to Title I of the Clean Air Act; or

(b) the emission unit to which the condition pertains permanently ceases operation.

B.4 Enforceability [326 IAC 2-7-7]

Unless otherwise stated, all terms and conditions in this permit, including any provisions designed to limit the source's potential to emit, are enforceable by IDEM, the United States Environmental Protection Agency (U.S. EPA) and by citizens in accordance with the Clean Air Act.

B.5 Termination of Right to Operate [326 IAC 2-7-10] [326 IAC 2-7-4(a)]

The Permittee's right to operate this source terminates with the expiration of this permit unless a timely and complete renewal application is submitted at least nine (9) months prior to the date of expiration of the source’s existing permit, consistent with 326 IAC 2-7-3 and 326 IAC 2-7-4(a).

B.6 Severability [326 IAC 2-7-5(5)]

The provisions of this permit are severable; a determination that any portion of this permit is invalid shall not affect the validity of the remainder of the permit.

B.7 Property Rights or Exclusive Privilege [326 IAC 2-7-5(6)(D)]

This permit does not convey any property rights of any sort or any exclusive privilege.

B.8 Duty to Provide Information [326 IAC 2-7-5(6)(E)]

(a) The Permittee shall furnish to IDEM, within a reasonable time, any information that IDEM, OAQ may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. Upon request, the Permittee shall also furnish to IDEM, OAQ copies of records required to be kept by this permit.

(b) For information furnished by the Permittee to IDEM, OAQ, the Permittee may include a claim of confidentiality in accordance with 326 IAC 17.1. When furnishing copies of requested records directly to U. S. EPA, the Permittee may assert a claim of confidentiality in accordance with 40 CFR 2, Subpart B.

B.9 Certification [326 IAC 2-7-4(f)] [326 IAC 2-7-6(1)] [326 IAC 2-7-5(3)(C)]

(a) A certification required by this permit meets the requirements of 326 IAC 2-7-6(1) if:

(i) it contains a certification by a "responsible official", as defined by 326 IAC 2-7-1 (34), and

(ii) the certification states that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

(b) The Permittee may use the attached Certification Form, or its equivalent, with each submittal requiring certification. One (1) certification may cover multiple forms in one (1) submittal.

(c) A "responsible official" is defined at 326 IAC 2-7-1(34).

B.10 Annual Compliance Certification [326 IAC 2-7-6(5)]

(a) The Permittee shall annually submit a compliance certification report which addresses the status of the source's compliance with the terms and conditions contained in this permit, including emission limitations, standards, or work practices. All certifications shall cover the time period from January 1 to December 31 of the previous year, and shall be submitted no later than July 1 of each year to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53, IGCN 1003
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V
Air and Radiation Division, Air Enforcement Branch - Indiana (AE-17J)
77 West Jackson Boulevard
Chicago, Illinois 60604-3590

(b) The annual compliance certification report required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.

(c) The annual compliance certification report shall include the following:

(1) The appropriate identification of each term or condition of this permit that is the basis of the certification;

(2) The compliance status;

(3) Whether compliance was continuous or intermittent;

(4) The methods used for determining the compliance status of the source, currently and over the reporting period consistent with 326 IAC 2-7-5(3); and

(5) Such other facts, as specified in Sections D of this permit, as IDEM, OAQ may be required to determine the compliance status of the source.

The submittal by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

B.11 Preventive Maintenance Plan [326 IAC 2-7-5(13)] [326 IAC 1-6-3]

(a) A Preventive Maintenance Plan meets the requirements of 326 IAC 1-6-3 if it includes, at a minimum:

(1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;

(2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and

(3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

The Permittee shall implement the PMPs.

(b) If required by specific condition(s) in Section D of this permit where no PMP was previously required, the Permittee shall prepare and maintain Preventive Maintenance Plans (PMPs) no later than ninety (90) days after issuance of this permit or ninety (90) days after initial start-up, whichever is later, including the following information on each facility:

(1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;

(2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and

(3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

If, due to circumstances beyond the Permittee's control, the PMPs cannot be prepared and maintained within the above time frame, the Permittee may extend the date an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

The PMP extension notification does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

The Permittee shall implement the PMPs.

(c) A copy of the PMPs shall be submitted to IDEM, OAQ upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. The PMPs and their submittal do not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

(d) To the extent the Permittee is required by 40 CFR Part 60/63 to have an Operation Maintenance, and Monitoring (OMM) Plan for a unit, such Plan is deemed to satisfy the PMP requirements of 326 IAC 1-6-3 for that unit.

B.12 Emergency Provisions [326 IAC 2-7-16]

(a) An emergency, as defined in 326 IAC 2-7-1(12), is not an affirmative defense for an action brought for noncompliance with a federal or state health-based emission limitation.

(b) An emergency, as defined in 326 IAC 2-7-1(12), constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limitation if the affirmative defense of an emergency is demonstrated through properly signed, contemporaneous operating logs or other relevant evidence that describe the following:

(1) An emergency occurred and the Permittee can, to the extent possible, identify the causes of the emergency;

(2) The permitted facility was at the time being properly operated;

(3) During the period of an emergency, the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards or other requirements in this permit;

(4) For each emergency lasting one (1) hour or more, the Permittee notified IDEM, OAQ, no later than four (4) daytime business hours after the beginning of the emergency, or after the emergency was discovered or reasonably should have been discovered;

Telephone Number: 1-800-451-6027 (ask for Office of Air Quality, Compliance and Enforcement Branch), or
Telephone Number: 317-233-0178 (ask for Compliance and Enforcement Branch)
Facsimile Number: 317-233-6865

(5) For each emergency lasting one (1) hour or more, the Permittee submitted the attached Emergency Occurrence Report Form or its equivalent, either by mail or facsimile to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53, IGCN 1003
Indianapolis, Indiana 46204-2251

no later than two (2) working days of the time when emission limitations were exceeded due to the emergency.

The notice fulfills the requirement of 326 IAC 2-7-5(3)(C)(ii) and must contain the following:

(A) A description of the emergency;

(B) Any steps taken to mitigate the emissions; and

(C) Corrective actions taken.

The notification which shall be submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

(6) The Permittee immediately took all reasonable steps to correct the emergency.

(c) In any enforcement proceeding, the Permittee seeking to establish the occurrence of an emergency has the burden of proof.

(d) This emergency provision supersedes 326 IAC 1-6 (Malfunctions). This permit condition is in addition to any emergency or upset provision contained in any applicable requirement.

(e) The Permittee seeking to establish the occurrence of an emergency shall make records available upon request to ensure that failure to implement a PMP did not cause or contribute to an exceedance of any limitations on emissions. However, IDEM, OAQ may require that the Preventive Maintenance Plans required under 326 IAC 2-7-4(c)(9) be revised in response to an emergency.

(f) Failure to notify IDEM, OAQ by telephone or facsimile of an emergency lasting more than one (1) hour in accordance with (b)(4) and (5) of this condition shall constitute a violation of 326 IAC 2-7 and any other applicable rules.

(g) If the emergency situation causes a deviation from a technology-based limit, the Permittee may continue to operate the affected emitting facilities during the emergency provided the Permittee immediately takes all reasonable steps to correct the emergency and minimize emissions.

B.13 Permit Shield [326 IAC 2-7-15] [326 IAC 2-7-20] [326 IAC 2-7-12]

(a) Pursuant to 326 IAC 2-7-15, the Permittee has been granted a permit shield. The permit shield provides that compliance with the conditions of this permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that either the applicable requirements are included and specifically identified in this permit or the permit contains an explicit determination or concise summary of a determination that other specifically identified requirements are not applicable. The Indiana statutes from IC 13 and rules from 326 IAC, referenced in conditions in this permit, are those applicable at the time the permit was issued. The issuance or possession of this permit shall not alone constitute a defense against an alleged violation of any law, regulation or standard, except for the requirement to obtain a Part 70 permit under 326 IAC 2-7 or for applicable requirements for which a permit shield has been granted.

This permit shield does not extend to applicable requirements which are promulgated after the date of issuance of this permit unless this permit has been modified to reflect such new requirements.

(b) If, after issuance of this permit, it is determined that the permit is in nonconformance with an applicable requirement that applied to the source on the date of permit issuance, IDEM, OAQ, shall immediately take steps to reopen and revise this permit and issue a compliance order to the Permittee to ensure expeditious compliance with the applicable requirement until the permit is reissued. The permit shield shall continue in effect so long as the Permittee is in compliance with the compliance order.

(c) No permit shield shall apply to any permit term or condition that is determined after issuance of this permit to have been based on erroneous information supplied in the permit application. Erroneous information means information that the Permittee knew to be false, or in the exercise of reasonable care should have been known to be false, at the time the information was submitted.

(d) Nothing in 326 IAC 2-7-15 or in this permit shall alter or affect the following:

(1) The provisions of Section 303 of the Clean Air Act (emergency orders), including the authority of the U.S. EPA under Section 303 of the Clean Air Act;

(2) The liability of the Permittee for any violation of applicable requirements prior to or at the time of this permit's issuance;

(3) The applicable requirements of the acid rain program, consistent with Section 408(a) of the Clean Air Act; and

(4) The ability of U.S. EPA to obtain information from the Permittee under Section 114 of the Clean Air Act.

(e) This permit shield is not applicable to any change made under 326 IAC 2-7-20(b)(2) (Sections 502(b)(10) of the Clean Air Act changes) and 326 IAC 2-7-20(c)(2) (trading based on State Implementation Plan (SIP) provisions).

(f) This permit shield is not applicable to modifications eligible for group processing until after IDEM, OAQ, has issued the modifications. [326 IAC 2-7-12(c)(7)]

(g) This permit shield is not applicable to minor Part 70 permit modifications until after IDEM, OAQ, has issued the modification. [326 IAC 2-7-12(b)(8)]

B.14 Prior Permits Superseded [326 IAC 2-1.1-9.5] [326 IAC 2-7-10.5]

(a) All terms and conditions of permits established prior to T157-27313-00012 and issued pursuant to permitting programs approved into the state implementation plan have been either:

(1) incorporated as originally stated,

(2) revised under 326 IAC 2-7-10.5, or

(3) deleted under 326 IAC 2-7-10.5.

(b) Provided that all terms and conditions are accurately reflected in this permit, all previous registrations and permits are superseded by this Part 70 operating permit, except for permits issued pursuant to Title IV of the Clean Air Act and 326 IAC 21 (Acid Deposition Control).

B.15 Permit Modification, Reopening, Revocation and Reissuance, or Termination [326 IAC 2-7-5(6)(C)] [326 IAC 2-7-8(a)] [326 IAC 2-7-9]

(a) This permit may be modified, reopened, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a Part 70 Operating Permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any condition of this permit.
[326 IAC 2-7-5(6)(C)] The notification by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

(b) This permit shall be reopened and revised under any of the circumstances listed in IC 13-15-7-2 or if IDEM, OAQ, determines any of the following:

(1) That this permit contains a material mistake.

(2) That inaccurate statements were made in establishing the emissions standards or other terms or conditions.

(3) That this permit must be revised or revoked to assure compliance with an applicable requirement. [326 IAC 2-7-9(a)(3)]

(c) Proceedings by IDEM, OAQ, to reopen and revise this permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of this permit for which cause to reopen exists. Such reopening and revision shall be made as expeditiously as practicable. [326 IAC 2-7-9(b)]

(d) The reopening and revision of this permit, under 326 IAC 2-7-9(a), shall not be initiated before notice of such intent is provided to the Permittee by IDEM, OAQ, at least thirty (30) days in advance of the date this permit is to be reopened, except that IDEM, OAQ, may provide a shorter time period in the case of an emergency. [326 IAC 2-7-9(c)]

B.16 Permit Renewal [326 IAC 2-7-3] [326 IAC 2-7-4] [326 IAC 2-7-8(e)]

(a) The application for renewal shall be submitted using the application form or forms prescribed by IDEM, OAQ, and shall include the information specified in 326 IAC 2-7-4. Such information shall be included in the application for each emission unit at this source, except those emission units included on the trivial or insignificant activities list contained in 326 IAC 2-7-1(21) and 326 IAC 2-7-1(40). The renewal application does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

Request for renewal shall be submitted to:

Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53, IGCN 1003
Indianapolis, Indiana 46204-2251

(b) A timely renewal application is one that is:

(1) Submitted at least nine (9) months prior to the date of the expiration of this permit; and

(2) If the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.

(c) If the Permittee submits a timely and complete application for renewal of this permit, the source's failure to have a permit is not a violation of 326 IAC 2-7 until IDEM, OAQ takes final action on the renewal application, except that this protection shall cease to apply if, subsequent to the completeness determination, the Permittee fails to submit by the deadline specified pursuant to 326 IAC 2-7-4(a)(2)(D) in writing by IDEM, OAQ any additional information identified as being needed to process the application.

B.17 Permit Amendment or Modification [326 IAC 2-7-11] [326 IAC 2-7-12] [40 CFR 72]

(a) Permit amendments and modifications are governed by the requirements of 326 IAC 2-7-11 or 326 IAC 2-7-12 whenever the Permittee seeks to amend or modify this permit.

(b) Any application requesting an amendment or modification of this permit shall be submitted to:

Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53, IGCN 1003
Indianapolis, Indiana 46204-2251

Any such application shall be certified by a "responsible official" as defined by 326 IAC 2-7-1(34).

(c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-7-11(c)(3)]

B.18 Permit Revision Under Economic Incentives and Other Programs [326 IAC 2-7-5(8)] [326 IAC 2-7-12(b)(2)]

(a) No Part 70 permit revision or notice shall be required under any approved economic incentives, marketable Part 70 permits, emissions trading, and other similar programs or processes for changes that are provided for in a Part 70 permit.

(b) Notwithstanding 326 IAC 2-7-12(b)(1) and 326 IAC 2-7-12(c)(1), minor Part 70 permit modification procedures may be used for Part 70 modifications involving the use of economic incentives, marketable Part 70 permits, emissions trading, and other similar approaches to the extent that such minor Part 70 permit modification procedures are explicitly provided for in the applicable State Implementation Plan (SIP) or in applicable requirements promulgated or approved by the U.S. EPA.

B.19 Operational Flexibility [326 IAC 2-7-20] [326 IAC 2-7-10.5]

(a) The Permittee may make any change or changes at the source that are described in 326 IAC 2-7-20(b), (c), or (e) without a prior permit revision, if each of the following conditions is met:

(1) The changes are not modifications under any provision of Title I of the Clean Air Act;

(2) Any preconstruction approval required by 326 IAC 2-7-10.5 has been obtained;

(3) The changes do not result in emissions which exceed the limitations provided in this permit (whether expressed herein as a rate of emissions or in terms of total emissions);

(4) The Permittee notifies the:

Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53, IGCN 1003
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V
Air and Radiation Division, Regulation Development Branch - Indiana (AR-18J)
77 West Jackson Boulevard
Chicago, Illinois 60604-3590

in advance of the change by written notification at least ten (10) days in advance of the proposed change. The Permittee shall attach every such notice to the Permittee's copy of this permit; and

(5) The Permittee maintains records on-site, on a rolling five (5) year basis, which document all such changes and emission trades that are subject to 326 IAC 2-7-20(b), (c), or (e). The Permittee shall make such records available, upon reasonable request, for public review.

Such records shall consist of all information required to be submitted to IDEM, OAQ in the notices specified in 326 IAC 2-7-20(b)(1), (c)(1), and (e)(2).

(b) The Permittee may make Section 502(b)(10) of the Clean Air Act changes (this term is defined at 326 IAC 2-7-1(36)) without a permit revision, subject to the constraint of 326 IAC 2-7-20(a). For each such Section 502(b)(10) of the Clean Air Act change, the required written notification shall include the following:

(1) A brief description of the change within the source;

(2) The date on which the change will occur;

(3) Any change in emissions; and

(4) Any permit term or condition that is no longer applicable as a result of the change.

The notification which shall be submitted is not considered an application form, report or compliance certification. Therefore, the notification by the Permittee does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

(c) Emission Trades [326 IAC 2-7-20(c)]
The Permittee may trade emissions increases and decreases at the source, where the applicable SIP provides for such emission trades without requiring a permit revision, subject to the constraints of Section (a) of this condition and those in 326 IAC 2-7-20(c).

(d) Alternative Operating Scenarios Part 70 Operating Permit
The Permittee may make changes at the source within the range of alternative operating scenarios that are described in the terms and conditions of this permit in accordance with 326 IAC 2-7-5(9). No prior notification of IDEM, OAQ, or U.S. EPA is required.

B.20 Source Modification Requirement [326 IAC 2-7-10.5] [326 IAC 2-2-2]

A modification, construction, or reconstruction is governed by the requirements of 326 IAC 2 and 326 IAC 2.

B.21 Inspection and Entry [326 IAC 2-7-6] [IC 13-14-2-2] [IC 13-30-3-1] [IC 13-17-3-2]

Upon presentation of proper identification cards, credentials, and other documents as may be required by law, and subject to the Permittee's right under all applicable laws and regulations to assert that the information collected by the agency is confidential and entitled to be treated as such, the Permittee shall allow IDEM, OAQ, U.S. EPA, or an authorized representative to perform the following:

(a) Enter upon the Permittee's premises where a Part 70 source is located, or emissions related activity is conducted, or where records must be kept under the conditions of this permit;

(b) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, have access to and copy any records that must be kept under the conditions of this permit;

(c) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, inspect any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit;

(d) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, sample or monitor substances or parameters for the purpose of assuring compliance with this permit or applicable requirements; and

(e) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, utilize any photographic, recording, testing, monitoring, or other equipment for the purpose of assuring compliance with this permit or applicable requirements.

B.22 Transfer of Ownership or Operational Control [326 IAC 2-7-11]

(a) The Permittee must comply with the requirements of 326 IAC 2-7-11 whenever the Permittee seeks to change the ownership or operational control of the source and no other change in the permit is necessary.

(b) Any application requesting a change in the ownership or operational control of the source shall contain a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new Permittee. The application shall be submitted to:

Indiana Department of Environmental Management
Permit Administration and Support Section, Office of Air Quality
100 North Senate Avenue
MC 61-53, IGCN 1003
Indianapolis, Indiana 46204-2251

The application which shall be submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

(c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-7-11(c)(3)]

B.23 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-7-5(7)] [326 IAC 2-1.1-7]

(a) The Permittee shall pay annual fees to IDEM, OAQ, within thirty (30) calendar days of receipt of a billing. Pursuant to 326 IAC 2-7-19(b), if the Permittee does not receive a bill from IDEM, OAQ, the applicable fee is due April 1 of each year.

(b) Except as provided in 326 IAC 2-7-19(e), failure to pay may result in administrative enforcement action or revocation of this permit.

(c) The Permittee may call the following telephone numbers: 1-800-451-6027 or 317-233-4230 (ask for OAQ, Billing, Licensing, and Training Section), to determine the appropriate permit fee.

B.24 Credible Evidence [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [62 FR 8314] [326 IAC 1-1-6]

For the purpose of submitting compliance certifications or establishing whether or not the Permittee has violated or is in violation of any condition of this permit, nothing in this permit shall preclude the use, including the exclusive use, of any credible evidence or information relevant to whether the Permittee would have been in compliance with the condition of this permit if the appropriate performance or compliance test or procedure had been performed.

SECTION C **SOURCE OPERATION CONDITIONS**

Entire Source

Emission Limitations and Standards [326 IAC 2-7-5(1)]

C.1 Particulate Emission Limitations for Processes with Process Weight Rates Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2(e)(2), particulate emissions from any manufacturing process not exempt under 326 IAC 6-3-1(b) or (c) which has a maximum process weight rate less than 100 pounds per hour (lb/hr) and the methods in 326 IAC 6-3-2(b) through (d) do not apply shall not exceed 0.551 pounds per hour (lb/hr).

C.2 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-1 (Applicability) and 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

(a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6)-minute averaging period as determined in 326 IAC 5-1-4.

(b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

C.3 Open Burning [326 IAC 4-1] [IC 13-17-9]

The Permittee shall not open burn any material except as provided in 326 IAC 4-1-3, 326 IAC 4-1-4 or 326 IAC 4-1-6. The previous sentence notwithstanding, the Permittee may open burn in accordance with an open burning approval issued by the Commissioner under 326 IAC 4-1-4.1.

C.4 Incineration [326 IAC 4-2] [326 IAC 9-1-2]

The Permittee shall not operate an incinerator except as provided in 326 IAC 4-2 or in this permit. The Permittee shall not operate a refuse incinerator or refuse burning equipment except as provided in 326 IAC 9-1-2 or in this permit.

C.5 Fugitive Dust Emissions [326 IAC 6-4]

The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions). 326 IAC 6-4-2(4) is not federally enforceable.

C.6 Stack Height [326 IAC 1-7]

The Permittee shall comply with the applicable provisions of 326 IAC 1-7 (Stack Height Provisions), for all exhaust stacks through which a potential (before controls) of twenty-five (25) tons per year or more of particulate matter or sulfur dioxide is emitted. The provisions of 326 IAC 1-7-1(3), 326 IAC 1-7-2, 326 IAC 1-7-3(c) and (d), 326 IAC 1-7-4, and 326 IAC 1-7-5(a), (b), and (d) are not federally enforceable.

C.7 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

The Permittee shall comply with the applicable requirements of 326 IAC 14-10, 326 IAC 18, and 40 CFR 61.140.

Testing Requirements [326 IAC 2-7-6(1)]

C.8 Performance Testing [326 IAC 3-6]

(a) For performance testing required by this permit, a test protocol, except as provided elsewhere in this permit, shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53, IGCN 1003
Indianapolis, Indiana 46204-2251

no later than thirty-five (35) days prior to the intended test date. The protocol submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

(b) The Permittee shall notify IDEM, OAQ of the actual test date at least fourteen (14) days prior to the actual test date. The notification submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by the “responsible official’ as defined by 326 IAC 2-7-1(34).

(c) Pursuant to 326 IAC 3-6-4(b), all test reports must be received by IDEM, OAQ not later than forty-five (45) days after the completion of the testing. An extension may be granted by IDEM, OAQ, if the Permittee submits to IDEM, OAQ, a reasonable written explanation not later than five (5) days prior to the end of the initial forty-five (45) day period.

Compliance Requirements [326 IAC 2-1.1-11]

C.9 Compliance Requirements [326 IAC 2-1.1-11]

The commissioner may require stack testing, monitoring, or reporting at any time to assure compliance with all applicable requirements by issuing an order under 326 IAC 2-1.1-11. Any monitoring or testing shall be performed in accordance with 326 IAC 3 or other methods approved by the commissioner or the U. S. EPA.

Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]

C.10 Compliance Monitoring [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

Unless otherwise specified in this permit, for all monitoring requirements not already legally required, the Permittee shall be allowed up to ninety (90) days from the date of permit issuance or of initial start-up, whichever is later, to begin such monitoring. If due to circumstances beyond the Permittee's control, any monitoring equipment required by this permit cannot be installed and operated no later than ninety (90) days after permit issuance or the date of initial startup, whichever is later, the Permittee may extend the compliance schedule related to the equipment for an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53, IGCN 1003
Indianapolis, Indiana 46204-2251

in writing, prior to the end of the initial ninety (90) day compliance schedule, with full justification of the reasons for the inability to meet this date.

The notification which shall be submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

Unless otherwise specified in the approval for the new emission unit(s), compliance monitoring for new emission units or emission units added through a source modification shall be implemented when operation begins.

C.11 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

(a) When required by any condition of this permit, an analog instrument used to measure a parameter related to the operation of an air pollution control device shall have a scale such that the expected maximum reading for the normal range shall be no less than twenty percent (20%) of full scale.

(b) The Permittee may request that the IDEM, OAQ approve the use of an instrument that does not meet the above specifications provided the Permittee can demonstrate that an alternative instrument specification will adequately ensure compliance with permit conditions requiring the measurement of the parameters.

Corrective Actions and Response Steps [326 IAC 2-7-5] [326 IAC 2-7-6]

C.12 Emergency Reduction Plans [326 IAC 1-5-2] [326 IAC 1-5-3]

Pursuant to 326 IAC 1-5-2 (Emergency Reduction Plans; Submission):

(a) The Permittee shall maintain the most recently submitted written emergency reduction plans (ERPs) consistent with safe operating procedures.

(b) Upon direct notification by IDEM, OAQ that a specific air pollution episode level is in effect, the Permittee shall immediately put into effect the actions stipulated in the approved ERP for the appropriate episode level.
[326 IAC 1-5-3]

C.13 Risk Management Plan [326 IAC 2-7-5(12)] [40 CFR 68]

If a regulated substance, as defined in 40 CFR 68, is present at a source in more than a threshold quantity, the Permittee must comply with the applicable requirements of 40 CFR 68.

C.14 Response to Excursions or Exceedances [326 IAC 2-7-5] [326 IAC 2-7-6]

Upon detecting an excursion where a response step is required by the D Section or an exceedance of a limitation in this permit:

(a) The Permittee shall take reasonable response steps to restore operation of the emissions unit (including any control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing excess emissions.

(b) The response shall include minimizing the period of any startup, shutdown or malfunction. The response may include, but is not limited to, the following:

(1) initial inspection and evaluation;

(2) recording that operations returned or are returning to normal without operator action (such as through response by a computerized distribution control system); or

(3) any necessary follow-up actions to return operation to normal or usual manner of operation.

(c) A determination of whether the Permittee has used acceptable procedures in response to an excursion or exceedance will be based on information available, which may include, but is not necessarily limited to, the following:

(1) monitoring results;

(2) review of operation and maintenance procedures and records;

(3) inspection of the control device, associated capture system, and the process.

(d) Failure to take reasonable response steps shall be considered a deviation from the permit.

(e) The Permittee shall record the reasonable response steps taken.

C.15 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5] [326 IAC 2-7-6]

(a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this permit exceed the level specified in any condition of this permit, the Permittee shall submit a description of its response actions to IDEM, OAQ, no later than seventy-five (75) days after the date of the test.

(b) A retest to demonstrate compliance shall be performed no later than one hundred eighty (180) days after the date of the test. Should the Permittee demonstrate to IDEM, OAQ that retesting in one hundred eighty (180) days is not practicable, IDEM, OAQ may extend the retesting deadline.

(c) IDEM, OAQ reserves the authority to take any actions allowed under law in response to noncompliant stack tests.

The response action documents submitted pursuant to this condition do require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

C.16 Emission Statement [326 IAC 2-7-5(3)(C)(iii)] [326 IAC 2-7-5(7)] [326 IAC 2-7-19(c)] [326 IAC 2-6]

Pursuant to 326 IAC 2-6-3(a)(1), the Permittee shall submit no later than July 1 of each year an emission statement covering the previous calendar year. The emission statement shall contain, at a minimum, the information specified in 326 IAC 2-6-4(c) and shall meet the following requirements:

(a) Indicate estimated actual emissions of all pollutants listed in 326 IAC 2-6-4(a);

(b) Indicate estimated actual emissions of regulated pollutants as defined by 326 IAC 2-7-1 (32) ("Regulated pollutant, which is used only for purposes of Section 19 of this rule") from the source, for purpose of fee assessment.

The statement must be submitted to:

Indiana Department of Environmental Management
Technical Support and Modeling Section, Office of Air Quality
100 North Senate Avenue
MC 61-50, IGCN 1003
Indianapolis, Indiana 46204-2251

The emission statement does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

C.17 General Record Keeping Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [326 IAC 2-2] [326 IAC 2-3]

(a) Records of all required monitoring data, reports and support information required by this permit shall be retained for a period of at least five (5) years from the date of monitoring sample, measurement, report, or application. These records shall be physically present or electronically accessible at the source location for a minimum of three (3) years. The records may be stored elsewhere for the remaining two (2) years as long as they are available upon request. If the Commissioner makes a request for records to the Permittee, the Permittee shall furnish the records to the Commissioner within a reasonable time.

(b) Unless otherwise specified in this permit, for all record keeping requirements not already legally required, the Permittee shall be allowed up to ninety (90) days from the date of permit issuance or the date of initial startup, whichever is later, to begin such record keeping.

(c) If there is a reasonable possibility (as defined in 40 CFR 51.165(a)(6)(vi)(A), 40 CFR 51.165(a)(6)(vi)(B), 40 CFR 51.166(r)(6)(vi)(a), and/or 40 CFR 51.166(r)(6)(vi)(b)) that a “project” (as defined in 326 IAC 2-2-1(qq) and/or 326 IAC 2-3-1(ll)) at an existing emissions unit, other than projects at a source with a Plantwide Applicability Limitation (PAL), which is not part of a “major modification” (as defined in 326 IAC 2-2-1(ee) and/or 326 IAC 2-3-1(z)) may result in significant emissions increase and the Permittee elects to utilize the “projected actual emissions” (as defined in 326 IAC 2-2-1(rr) and/or 326 IAC 2-3-1(mm)), the Permittee shall comply with following:

(1) Before beginning actual construction of the “project” (as defined in 326 IAC 2-2-1(qq) and/or 326 IAC 2-3-1(ll)) at an existing emissions unit, document and maintain the following records:

(A) A description of the project.

(B) Identification of any emissions unit whose emissions of a regulated new source review pollutant could be affected by the project.

(C) A description of the applicability test used to determine that the project is not a major modification for any regulated NSR pollutant, including:

(i) Baseline actual emissions;

(ii) Projected actual emissions;

(iii) Amount of emissions excluded under section 326 IAC 2-2-1(rr)(2)(A)(iii) and/or 326 IAC 2-3-1(mm)(2)(A)(iii); and

(iv) An explanation for why the amount was excluded, and any netting calculations, if applicable.

(d) If there is a reasonable possibility (as defined in 40 CFR 51.165(a)(6)(vi)(A) and/or 40 CFR 51.166(r)(6)(vi)(a)) that a "project" (as defined in 326 IAC 2-2-1(qq) and/or 326 IAC 2-3-1(ll)) at an existing emissions unit, other than projects at a source with a Plantwide Applicability Limitation (PAL), which is not part of a "major modification" (as defined in 326 IAC 2-2-1(ee) and/or 326 IAC 2-3-1(z)) may result in significant emissions increase and the Permittee elects to utilize the "projected actual emissions" (as defined in 326 IAC 2-2-1(rr) and/or 326 IAC 2-3-1(mm)), the Permittee shall comply with following:

(1) Monitor the emissions of any regulated NSR pollutant that could increase as a result of the project and that is emitted by any existing emissions unit identified in (1)(B) above; and

(2) Calculate and maintain a record of the annual emissions, in tons per year on a calendar year basis, for a period of five (5) years following resumption of regular operations after the change, or for a period of ten (10) years following resumption of regular operations after the change if the project increases the design capacity of or the potential to emit that regulated NSR pollutant at the emissions unit.

C.18 General Reporting Requirements [326 IAC 2-7-5(3)(C)] [326 IAC 2-1.1-11] [326 IAC 2-2] [326 IAC 2-3]

(a) The Permittee shall submit the attached Quarterly Deviation and Compliance Monitoring Report or its equivalent. Any deviation from permit requirements, the date(s) of each deviation, the cause of the deviation, and the response steps taken must be reported, except that a deviation required to be reported pursuant to an applicable requirement that exists independent of this permit shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. This report shall be submitted within thirty (30) days of the end of the reporting period. The Quarterly Deviation and Compliance Monitoring Report shall include the certification by a "responsible official" as defined by 326 IAC 2-7-1(34). A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit.

(b) The address for report submittal is:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53, IGCN 1003
Indianapolis, Indiana 46204-2251

(c) Unless otherwise specified in this permit, any notice, report, or other submission required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ, on or before the date it is due.

(d) The first report shall cover the period commencing on the date of issuance of this permit and ending on the last day of the reporting period. Reporting periods are based on calendar years, unless otherwise specified in this permit. For the purpose of this permit "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.

(e) If the Permittee is required to comply with the recordkeeping provisions of (d) in Section C – General Record Keeping Requirements for any "project" (as defined in 326 IAC 2-2-1(qq) and/or 326 IAC 2-3-1(ll) at an existing Electric Utility Steam Generating Unit, then for that project the Permittee shall:

(1) Submit to IDEM, OAQ a copy of the information required by (c)(1) in Section C – General Record Keeping Requirements

(2) Submit a report to IDEM, OAQ within sixty (60) days after the end of each year during which records are generated in accordance with (d)(1) and (2) in Section C – General Record Keeping Requirements. The report shall contain all information and data describing the annual emissions for the emissions units during the calendar year that preceded the submission of report.

Reports required in this part shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53, IGCN 1003
Indianapolis, Indiana 46204-2251

(f) The report for a project at an existing emissions unit other than Electric Utility Steam Generating Unit shall be submitted within sixty (60) days after the end of the year and contain the following:

(1) The name, address, and telephone number of the major stationary source.

(2) The annual emissions calculated in accordance with (d)(1) and (2) in Section C – General Record Keeping Requirements.

(3) The emissions calculated under the actual-to-projected actual test stated in 326 IAC 2-2-2(d)(3) and/or 326 IAC 2-3-2(c)(3.

(4) Any other information that the Permittee wishes to include in this report such as an explanation as to why the emissions differ from the preconstruction project.

Reports required in this part shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53, IGCN 1003
Indianapolis, Indiana 46204-2251

(g) The Permittee shall make the information required to be documented and maintained in accordance with (c) in Section C - General Record Keeping Requirements available for review upon a request for inspection by IDEM, OAQ. The general public may request this information from the IDEM, OAQ under 326 IAC 17.1.

Stratospheric Ozone Protection

C.19 Compliance with 40 CFR 82 and 326 IAC 22-1

Pursuant to 40 CFR 82 (Protection of Stratospheric Ozone), Subpart F, except as provided for motor vehicle air conditioners in Subpart B, the Permittee shall comply with applicable standards for recycling and emissions reduction.

SECTION D.1 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]:

(a) One (1) spreader stoker coal fired boiler, identified as Boiler 1, with installation completed in 1960, with a nominal capacity of 281 MMBtu/hr, with a multi-cyclone collector and an electrostatic precipitator for particulate matter control, exhausting to stack WADE 01. Boiler 1 has two (2) auxiliary natural gas fired burners rated at 35 MMBtu/hr per burner, used for ignition and flame stabilization periods. Boiler 1 has a continuous emissions monitoring system (CEMS) for nitrogen oxides (NO_X) and a continuous opacity monitor (COM).

(b) One (1) spreader stoker coal fired boiler, identified as Boiler 2, with installation completed in 1967, with a nominal capacity of 274 MMBtu/hr, with a multi-cyclone collector and a multi-compartment baghouse for particulate matter control, exhausting to stack WADE 02. Boiler 2 has two (2) auxiliary natural gas fired burners rated at 35 MMBtu/hr per burner, used for ignition and flame stabilization periods. Boiler 2 has a continuous emissions monitoring system (CEMS) for nitrogen oxides (NO_X) and a continuous opacity monitor (COM).

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.1.1 Nitrogen Oxides Emission Limitation [326 IAC 2-2-4]

In order to make the requirements of 326 IAC 2-2 (PSD Requirements) not applicable to the addition of natural gas fired burners to the existing Boilers 1 and 2, the following limits shall apply:

(a) The combined natural gas usage for Boiler 1 and Boiler 2 shall not exceed 395 million cubic feet (MMCF) per twelve (12) consecutive month period. Compliance with this limit shall be determined at the end of each month.

(b) NO_X emissions from the Boiler 1 and Boiler 2 natural gas fired burners shall not exceed 200 pounds per million cubic feet (lb/MMCF) of natural gas.

D.1.2 Particulate Emission Limitations for Sources of Indirect Heating [326 IAC 6-2-3]

Pursuant to 326 IAC 6-2-3 (Particulate Emission Limitations for Sources of Indirect Heating), particulate matter (PM) emissions from Boiler 1 and Boiler 2 shall not exceed 0.64 pound per million British thermal units (lb/MMBtu) of heat input, based on the following equation:

$$Pt = \frac{(C)\,(a)\,(h)}{76.5\,(Q^{0.75})\,(N^{0.25})}$$

Where: C = 50 micrograms per cubic meter (μ/m^3)
Pt = Pounds of particulate matter emitted per million British thermal units (lb/MMBtu) heat input.
Q = Total source maximum operating capacity rating in million British thermal units per hour (MMBtu/hr) heat input.
N = Number of stacks in fuel burning operation.
a = 0.67
h = Stack height in feet.

For Boiler 1 and Boiler 2, Q = 555 MMBtu/hr, N = 2, and h = 200 feet.

D.1.3 SO_2 PSD Emission Limit [326 IAC 2-2-4]

(a) Pursuant to Construction Permit PC (79) 1680, issued June 6, 1988, 326 IAC 2-2 (Prevention of Significant Deterioration), and 326 IAC 7-1.1-2, the following conditions became effective upon start-up of Boiler 5:

(1) Sulfur dioxide emissions from Boiler 1 and Boiler 2 shall be limited to 5.43 pounds per million British thermal units (lb/MMBtu) of heat input and to a total of 26.5 tons from Boiler 1 and Boiler 2 on any calendar day.

(2) The 24-hour emission limit for sulfur dioxide shall be calculated by using the sulfur content of the coal as presently reported to the OAQ in accordance with 326 IAC 3-7-2 or 3-7-3. The daily coal usage will be calculated by the use of steam production data and an evaporation factor (pounds of steam per pounds of coal). The evaporation factor shall be 8.4 pounds of steam per pound of coal. Purdue University may request a permit modification to adjust this factor if performance data warrants a review.

(b) When the daily coal usage is 420 tons or less for Boiler 1 and Boiler 2, a daily sulfur dioxide emissions level need not be provided.

(c) The stack height on the existing boilers may be increased to 65 meters without obtaining approval from the IDEM, OAQ.

(d) The Permittee may at any time submit further modeling data in an effort to demonstrate that a higher 24-hour sulfur dioxide emission level from Boiler 1 and Boiler 2 will protect the sulfur dioxide air quality standards using procedures acceptable to the OAQ. The OAQ, after appropriate review, may adjust the 24-hour sulfur dioxide limit if the air quality analysis supports an adjusted level.

D.1.4 Sulfur Dioxide Emission Limitations (SO_2) [326 IAC 7-1.1-2]

Pursuant to 326 IAC 7-1.1-2(a)(1), sulfur dioxide emissions from Boiler 1 and Boiler 2 shall not exceed six and zero-tenths (6.0) pound per million British thermal units (lb/MMBtu), using a calendar month average.

D.1.5 Retirement of Existing Operations [326 IAC 2-2]

Pursuant to 326 IAC 2-2, the Permittee shall permanently discontinue the operation of Boiler 1 within one hundred eighty (180) days of the startup date for Boiler 7. NO_X emissions from Boiler 7 shall not exceed 40 tons during this period.

D.1.6 Temporary Alternative Opacity Limitations [326 IAC 5-1-3]

(a) Pursuant to 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), the following applies:

(1) When building a new fire in a boiler, or shutting down a boiler, opacity may exceed the forty percent (40%) opacity limitation established by 326 IAC 5-1-2. However, opacity levels shall not exceed sixty percent (60%) for any six (6)-minute averaging period. Opacity in excess of the applicable limit established in 326 IAC 5-1-2 shall not continue for more than two (2) six (6)-minute averaging periods in any twenty-four (24) hour period. [326 IAC 5-1-3(a)]

Operation of the emission control devices is not required during these times unless necessary to comply with these limits.

(2) When removing ashes from the fuel bed or furnace in a boiler or blowing tubes, opacity may exceed the applicable limit established in 326 IAC 5-1-2 and stated in Section C - Opacity. However, opacity levels shall not exceed sixty percent (60%) for any six (6)-minute averaging period and opacity in excess of the applicable limit shall not continue for more than one (1) six (6)-minute averaging period in any sixty (60)-minute period. The averaging periods in excess of the limit set in 326 IAC 5-1-2 shall not be permitted for more than three (3) six (6)-minute averaging periods in a twelve (12) hour period. [326 IAC 5-1-3(b)]

(b) If a facility cannot meet the opacity limitations of 326 IAC 5-1-3(a) or (b), the Permittee may submit a written request to IDEM, OAQ, for a temporary alternative opacity limitation in accordance with 326 IAC 5-1-3(d). The Permittee must demonstrate that the alternative limit is needed and justifiable.

D.1.7 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

A Preventive Maintenance Plan (PMP) is required for Boiler 1 and Boiler 2 and their emission control devices. Section B - Preventive Maintenance Plan contains the Permittee's obligations with regard to the preventive maintenance plan required by this condition.

Compliance Determination Requirements

D.1.8 Testing Requirements [326 IAC 2-7-6(1),(6)] [326 IAC 2-1.1-11]

Compliance with the PM limitation for Boiler 1 and Boiler 2 shall be determined by performance stack tests conducted using methods as approved by the Commissioner. This testing shall be repeated by December 31 of every second calendar year following the most recent valid compliance demonstration. Testing shall be conducted in accordance with the provisions of 326 IAC 3-6 (Source Sampling Procedures). Section C - Performance Testing contains the Permittee's obligations with regard to the performance testing required by this condition.

For the purpose of this permit, “calendar year” means the twelve (12) month period from January 1 to December 31 inclusive.

D.1.9 Particulate Control [326 IAC 2-7-6(6)]

(a) Except as otherwise provided by statute or rule or in this permit, the multiclone and electrostatic precipitator (ESP) for Boiler 1 shall be in operation and control emissions at all times that the boiler, vented to that multiclone and ESP, is in operation.

(b) Except as otherwise provided by statute or rule or in this permit, the multiclone and baghouse for particulate control for Boiler 2 shall be in operation and control emissions at all times that the boiler, vented to that multiclone and baghouse, is in operation.

D.1.10 Continuous Emissions Monitoring [326 IAC 3-5] [40 CFR 64]

(a) Pursuant to 326 IAC 3-5-1(c)(2)(A) (Continuous Monitoring of Emissions), continuous emission monitoring systems (CEMS) for Boiler 1 and Boiler 2 shall be calibrated, maintained, and operated for measuring opacity, which meet all applicable performance specifications of 326 IAC 3-5-2 and 40 CFR 64. For Boiler 1 and Boiler 2, the COMS shall be in operation in accordance with 326 IAC 3-5 and 40 CFR Part 60 when fuel is being combusted in the associated boiler.

(b) All continuous emission monitoring systems are subject to monitor system certification requirements pursuant to 326 IAC 3-5-3.

(c) Nothing in this permit shall excuse the Permittee from complying with the requirements to operate a continuous emission monitoring system pursuant to 326 IAC 3-5 or 40 CFR 60.

D.1.11 Continuous Opacity Monitoring [326 IAC 3-5] [40 CFR 64]

Whenever a COMS is malfunctioning or is down for maintenance or repairs for a period of twenty-four (24) hours or more and a backup COMS is not online within twenty-four (24) hours of shutdown or malfunction of the primary COMS, the Permittee shall provide a certified opacity reader, who may be an employee of the Permittee or an independent contractor, to self-monitor the emissions from the emission unit stack.

(a) Visible emission readings shall be performed in accordance with 40 CFR 60, Appendix A, Method 9, for a minimum of five (5) consecutive six (6)-minute averaging periods beginning not more than twenty-four (24) hours after the start of the malfunction or down time.

(b) Method 9 opacity readings shall be repeated for a minimum of five (5) consecutive six (6)-minute averaging periods at least twice per day during daylight operations, with at least four (4) hours between each set of readings, until a COMS is online.

(c) Method 9 readings may be discontinued once a COMS is online.

(d) Any opacity exceedances determined by Method 9 readings shall be reported with the Quarterly Opacity Exceedances Reports.

D.1.12 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3] [326 IAC 7-2-1]

(a) Pursuant to 326 IAC 7-2-1(c), 326 IAC 3-7, and Construction Permit PC (79) 1680, the Permittee shall demonstrate that the sulfur dioxide emissions from Boiler 1 and Boiler 2 do not exceed the emission limitations specified in Conditions D.1.3 and D.1.4, using the coal sampling and analysis data as follows:

(b) Pursuant to 326 IAC 7-2-1(e) and 326 IAC 3-7, coal sampling and analysis data shall be collected as follows:

(1) Coal sampling shall be performed using the methods specified in 326 IAC 3-7-2(a), and sample preparation and analysis shall be performed as specified in 326 IAC 3-7-2(c), (d), and (e); or

(2) Pursuant to 326 IAC 3-7-2(b)(2) and 326 IAC 3-7-3, manual or other non-ASTM automatic sampling and analysis procedures may be used upon a demonstration, submitted to the department for approval, that such procedures provide sulfur dioxide emission estimates representative either of estimates based on coal sampling and analysis procedures specified in 326 IAC 3-7-2 or of continuous emissions monitoring; or

(3) The Permittee shall meet the minimum sampling requirements specified in 326 IAC 3-7-2(b)(3), and sample preparation and analysis shall be performed as specified in 326 IAC 3-7-2(c), (d), and (e).

(4) Pursuant to 326 IAC 3-7-5(a), the Permittee shall develop a standard operating procedure (SOP) to be followed for sampling, handling, analysis, quality control, quality assurance, and data reporting of the information collected pursuant to 326 IAC 3-7-2 through 326 IAC 3-7-4. In addition, any revision to the SOP shall be submitted to IDEM, OAQ.

(c) Continuous emission monitoring data collected and reported pursuant to 326 IAC 3-5 may be used as the means for determining compliance with the emission limitations in 326 IAC 7 instead of the fuel sampling and analysis required in (b). [326 IAC 7-2-1(g)]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.1.13 Opacity Readings [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)] [40 CFR 64]

(a) For Boiler 1:

(1) In the event of emissions exceeding twenty-five percent (25%) average opacity for three (3) consecutive six (6)-minute averaging periods, appropriate response steps shall be taken such that the cause(s) of the excursion are identified and corrected and opacity levels are brought back below twenty-five percent (25%). Examples of expected response steps include, but are not limited to, boiler loads being reduced, adjustment of flue gas conditioning rate, and ESP T-R sets being returned to service. Section C - Response to Excursions or Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition.

(2) Opacity readings in excess of twenty-five percent (25%) but not exceeding the opacity limit for the unit are not a deviation from this permit. Failure to take response steps shall be considered a deviation from this permit.

(b) For Boiler 2:

(1) In the event of emissions exceeding twenty percent (20)% average opacity for three (3) consecutive six (6)-minute averaging periods, appropriate response steps shall be taken such that the cause(s) of the excursion are identified and corrected and opacity levels are brought back below twenty percent (20%). Examples of expected response steps include, but are not limited to, boiler loads being reduced, and adjustment of flue gas conditioning rate, and the baghouse being returned to service. Section C - Response to Excursions or Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition.

(2) Opacity readings in excess of twenty percent (20%) but not exceeding the opacity limit for the unit are not a deviation from this permit. Failure to take response steps shall be considered a deviation from this permit.

(c) Periods of elevated opacity that are subject to a Temporary Alternative Opacity Limitation (TAOL) when building a new fire in a boiler, shutting down a boiler, removing ashes from the fuel bed or furnace in a boiler, or blowing tubes, need not be included in the averaging periods for (a) and (b) of this condition.

D.1.14 Electrostatic Precipitator Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)] [40 CFR 64]

Whenever a COMS is malfunctioning or is down for maintenance or repairs for a period of twenty-four (24) hours or more and a backup COMS is not online within twenty-four (24) hours of shutdown or malfunction of the primary COMS:

(a) The ability of the ESP to control particulate emissions from Boiler 1 shall be monitored once per day, when the unit is in operation, by measuring and recording the primary and secondary voltages and the currents of the transformer-rectifier (T-R) sets.

(b) When for any one reading, operation is outside one of the normal ranges shown below, or a range established during the latest stack test, the Permittee shall take reasonable response steps. Section C - Response to Excursions or Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition. A voltage or current reading outside the normal range is not a deviation from this permit. Failure to take response steps shall be considered a deviation from this permit.

Boiler 1:

(1)	Primary voltage:	275 - 430 V
(2)	Secondary voltage:	29 - 45 kV
(3)	T-R set secondary current:	150 - 405 mA

D.1.15 Baghouse Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)] [40 CFR 64]

Whenever a COMS is malfunctioning or is down for maintenance or repairs for a period of twenty-four (24) hours or more and a backup COMS is not online within twenty-four (24) hours of shutdown or malfunction of the primary COMS:

(a) The Permittee shall record the pressure drop across the baghouse used in conjunction with Boiler 2, at least once per day when the process is in operation when venting to the atmosphere. When for any one reading, the pressure drop across the baghouse is outside the normal range of 1.0 and 7.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps. Section C - Response to Excursions or Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition. A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps shall be considered a deviation from this permit.

(b) The instrument used for determining the pressure shall comply with Section C - Instrument Specifications, and shall be calibrated or replaced in accordance with the manufacturer's specifications. The specifications shall be available on site with the Preventive Maintenance Plan.

D.1.16 Broken or Failed Bag Detection – Multi-Compartment Baghouse [40 CFR 64]

In the event that bag failure is observed in a multi-compartment baghouse, if operations will continue for ten (10) days or more after the failure is observed before the failed units will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed units will be repaired or replaced. The notification shall also include the status of the applicable compliance monitoring parameters with respect to normal, and the results of any response actions taken up to the time of notification.

D.1.17 SO_2 Monitoring System Downtime [326 IAC 2-7-6] [326 IAC 2-7-5(3)] [326 IAC 3-7-2] [326 IAC 3-7-3]

Whenever coal sampling is not being performed and the SO_2 continuous emission monitoring system (CEMS) is being utilized to demonstrate compliance with the 24-hour emission limit for SO_2 in Condition D.1.3(a):

If the SO_2 continuous emission monitoring system (CEMS) is malfunctioning or down for repairs or adjustments, for twenty-four (24) hours or more, fuel sampling shall be conducted as specified in 326 IAC 3-7-2(b). Fuel sample preparation and analysis shall be conducted as specified in 326 IAC 3-7-2(c), 326 IAC 3-7-2(d), and 326 IAC 3-7-2(e). Pursuant to 326 IAC 3-7-3, manual or other non-ASTM automatic sampling and analysis procedures may be used upon a demonstration, submitted to the department for approval, that such procedures provide sulfur dioxide emission estimates representative either of estimates based on coal sampling and analysis procedures specified in 326 IAC 3-7-2 or of continuous emissions monitoring.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.1.18 Record Keeping Requirements

(a) To document the compliance status with Condition D.1.1, the Permittee shall maintain records including the following:

(1) Monthly records of total natural gas usage for Boiler 1 and Boiler 2.

(2) Documentation of NO_X emission rate for the Boiler 1 and Boiler 2 gas burners.

(b) To document the compliance status with Section C - Opacity and the particulate matter and opacity Conditions D.1.2, D.1.6, D.1.8, D.1.9, D.1.11, D.1.13, D.1.14, and D.1.15, the Permittee shall maintain records in accordance with (1) through (3) below. Records shall be complete and sufficient to establish compliance with the limits in Section C - Opacity and Condition D.1.6.

(1) Data and results from the most recent stack test.

(2) All continuous opacity monitoring data, pursuant to 326 IAC 3-5-6.

(3) The results of all Method 9 visible emission readings taken during any periods of COM downtime.

(c) To document the compliance status with Condition D.1.14, the Permittee shall maintain daily records of the primary and secondary voltages and the currents of the transformer-rectifier (T-R) sets for the ESP for Boiler 1 whenever a COMS is malfunctioning or is down for maintenance or repairs for a period of twenty-four (24) hours or more and a backup COMS is not online within twenty-four (24) hours of shutdown or malfunction of the primary COMS. The Permittee shall include in its daily record when a reading is not taken and the reason for the lack of a reading (e.g. the process did not operate that day).

(d) To document the compliance status with Condition D.1.15, the Permittee shall maintain daily records of the pressure drop across the baghouse for Boiler 2 whenever a COMS is malfunctioning or is down for maintenance or repairs for a period of twenty-four (24) hours or more and a backup COMS is not online within twenty-four (24) hours of shutdown or malfunction of the primary COMS. The Permittee shall include in its daily record when a reading is not taken and the reason for the lack of a reading (e.g. the process did not operate that day).

(e) To document the compliance status with SO_2 Conditions D.1.3, D.1.4, D.1.12, and D.1.17, the Permittee shall maintain records in accordance with (1) and (2) below. Records shall be complete and sufficient to establish compliance with the SO_2 limits as required in Conditions D.1.3 and D.1.4.

(1) All fuel sampling and analysis data, pursuant to 326 IAC 7-2 or all SO_2 continuous emissions monitoring data, pursuant to 326 IAC 3-5-6, 326 IAC 7-2-1(g), and 40 CFR 60.45.

(2) Daily fuel usage for each of Boiler 1 and Boiler 2.

(f) Section C - General Record Keeping Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.

D.1.19 Reporting Requirements

(a) A quarterly report of opacity exceedances shall be submitted not later than thirty (30) days following the end of each calendar quarter. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

(b) A quarterly report of the calendar month average coal sulfur content, coal heat content, and sulfur dioxide emission rate in pounds per million British thermal units (lb/MMBtu) and the total monthly coal consumption shall be submitted not later than thirty (30) days following the end of each calendar quarter. [326 IAC 7-2-1(c)(2]

The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

(c) A quarterly report of the natural gas usage for Boiler 1 and Boiler 2 shall be submitted using the reporting forms located at the end of this permit, or their equivalent, not later than thirty (30) days following the end of each calendar quarter. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

(d) Whenever coal sampling is not being performed and the SO_2 continuous emission monitoring system (CEMS) is being utilized to demonstrate compliance with the 24-hour emission limit for SO_2 in Condition D.1.3(a):

Pursuant to 326 IAC 3-5-7(5), reporting of continuous monitoring system instrument downtime, except for zero (0) and span checks, which shall be reported separately, shall include the following:

(1) date of downtime;

(2) time of commencement;

(3) duration of each downtime;

(4) reasons for each downtime; and

(5) nature of system repairs and adjustments.

The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

(e) Section C - General Reporting Requirements contains the Permittee's obligations with regard to the reporting required by this condition.

SECTION D.2 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]:

(d) One (1) circulating fluidized bed coal fired boiler, identified as Boiler 5, with installation completed in 1991, with a nominal capacity of 279 MMBtu/hr, with a baghouse for particulate matter control and limestone injection for sulfur dioxide control, combusting natural gas for ignition, exhausting to stack WADE 05. Boiler 5 has continuous emissions monitoring systems (CEMS) for nitrogen oxides (NO_X) and sulfur dioxide (SO_2) and a continuous opacity monitor (COM).

Under the Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units NSPS (40 CFR 60, Subpart Db), Boiler 5 is considered an affected source.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.2.1 Boiler 5 PSD Emission Limits [326 IAC 2-2-3] [326 IAC 6-2-1(g)]

Pursuant to Construction Permit PC (79) 1680, issued June 6, 1988, and 326 IAC 2-2 (Prevention of Significant Deterioration), the following requirements apply to Boiler 5:

(a) Sulfur dioxide emissions from Boiler 5 shall not exceed:

(1) 0.9 pounds per million British thermal units (lb/MMBtu) of heat input based on a 30-day rolling weighted average basis, and

(2) 1.1 pounds per million British thermal units (lb/MMBtu) of heat input based on a block 24-hour average basis.

(b) Particulate matter emissions from Boiler 5 shall not exceed 0.05 pounds per million Btu of heat input.

(c) Carbon monoxide emissions from Boiler 5 shall not exceed 0.27 pounds per million British thermal units (lb/MMBtu) of heat input.

(d) The rate of heat input into the boiler shall not exceed 279 million Btu's per hour.

D.2.2 Sulfur Dioxide Emission Limitations [326 IAC 7-1.1-2]

Pursuant to 326 IAC 7-1.1-2(a)(1), sulfur dioxide emissions from Boiler 5 shall not exceed six and zero-tenths (6.0) pound per million Btu (lb/MMBtu), using a calendar month average.

D.2.3 Temporary Alternative Opacity Limitations [326 IAC 5-1-3]

(a) Pursuant to 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), when building a new fire in a boiler, or shutting down a boiler, opacity may exceed the forty percent (40%) opacity limitation established by 326 IAC 5-1-2. However, opacity levels shall not exceed sixty percent (60%) for any six (6)-minute averaging period. Opacity in excess of the applicable limit established in 326 IAC 5-1-2 shall not continue for more than two (2) six (6)-minute averaging periods in any twenty-four (24) hour period. [326 IAC 5-1-3(a)]

(b) When removing ashes from the fuel bed or furnace in a boiler or blowing tubes, opacity may exceed forty percent (40%); however, opacity shall not exceed sixty percent (60%) for any six (6)-minute averaging period and opacity in excess of forty percent (40%) shall not continue for more than one (1) six (6)-minute averaging period in any sixty (60)-minute period. The averaging periods shall not be permitted for more than three (3) six (6)-minute averaging periods in a twelve (12) hour period.

(c) If a facility cannot meet the opacity limitations of 326 IAC 5-1-3(a), the Permittee may submit a written request to IDEM, OAQ, for a temporary alternative opacity limitation in accordance with 326 IAC 5-1-3(d). The Permittee must demonstrate that the alternative limit is needed and justifiable.

D.2.4 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

A Preventive Maintenance Plan (PMP) is required for Boiler 5 and its emission control device. Section B - Preventive Maintenance Plan contains the Permittee's obligations with regard to the preventive maintenance plan required by this condition.

Compliance Determination Requirements

D.2.5 Testing Requirements [326 IAC 2-7-6(1), (6)] [326 IAC 2-1.1-11]

(a) Compliance with the Boiler 5 PM limitation in Condition D.2.1(b) shall be determined by performance stack tests conducted using methods as approved by the Commissioner.

(b) Compliance with the Boiler 5 CO limitation in Condition D.2.1(c) shall be determined by performance stack tests conducted using methods as approved by the Commissioner.

(c) This testing shall be repeated by December 31 of every second calendar year following the most recent valid compliance demonstration. Testing shall be conducted in accordance with the provisions of 326 IAC 3-6 (Source Sampling Procedures). Section C - Performance Testing contains the Permittee's obligations with regard to the performance testing required by this condition.

For the purpose of this permit, “calendar year” means the twelve (12) month period from January 1 to December 31 inclusive.

D.2.6 Compliance Determination Requirements [326 IAC 2-2]

(a) Except as otherwise provided by statute, rule, or this permit, a circulating fluidized bed boiler with alkali injection shall be used as needed to maintain compliance with the sulfur dioxide emission limitations in Conditions D.2.1 and D.2.2 for Boiler 5.

(b) Compliance with the sulfur dioxide emission limits in Conditions D.2.1(a) and D.2.2 for Boiler 5 shall be determined on a 30-day rolling weighted average emission basis.

(c) Compliance with the block 24-hour average sulfur dioxide emission limitation in Condition D.2.1(a)(2) for Boiler 5 shall be determined by using the continuous sulfur dioxide emission monitoring data.

D.2.7 Continuous Emissions Monitoring [326 IAC 3-5] [40 CFR 64]

(a) Pursuant to 326 IAC 3-5 (Continuous Monitoring of Emissions), opacity, SO_2, and NO_X continuous emission monitoring systems (CEMS) for Boiler 5 shall be calibrated, maintained, and operated for measuring opacity, SO_2, and NO_X which meet the performance specifications of 326 IAC 3-5-2 and 40 CFR 60. For Boiler 5, the Continuous Opacity Monitoring System (COMS) shall be in operation in accordance with 326 IAC 3-5 and 40 CFR Part 60 when fuel is being combusted in the boiler.

(b) All continuous emission monitoring systems are subject to monitor system certification requirements pursuant to 326 IAC 3-5-3.

(c) Nothing in this permit shall excuse the Permittee from complying with the requirements to operate a continuous emission monitoring system pursuant to 326 IAC 3-5, 40 CFR 60, or 40 CFR 75.

D.2.8 Continuous Opacity Monitoring [326 IAC 3-5] [40 CFR 64]

Whenever a COMS is malfunctioning or is down for maintenance or repairs for a period of twenty-four (24) hours or more and a backup COMS is not online within twenty-four (24) hours of shutdown or malfunction of the primary COMS, the Permittee shall provide a certified opacity reader, who may be an employee of the Permittee or an independent contractor, to self-monitor the emissions from the emission unit stack.

(a) Visible emission readings shall be performed in accordance with 40 CFR 60, Appendix A, Method 9, for a minimum of five (5) consecutive six (6)-minute averaging periods beginning not more than twenty-four (24) hours after the start of the malfunction or down time.

(b) Method 9 opacity readings shall be repeated for a minimum of five (5) consecutive six (6)-minute averaging periods at least twice per day during daylight operations, with at least four (4) hours between each set of readings, until a COMS is online.

(c) Method 9 readings may be discontinued once a COMS is online.

(d) Any opacity exceedances determined by Method 9 readings shall be reported with the Quarterly Opacity Exceedances Reports.

D.2.9 Particulate Control [326 IAC 2-7-6(6)] [40 CFR 64]

(a) Except as otherwise provided by statute or rule or in this permit, the baghouse shall be operated at all times that Boiler 5 is in operation and coal is being combusted in the boiler.

(b) In the event that bag failure is observed in a multi-compartment baghouse, if operations will continue for ten (10) days or more after the failure is observed before the failed units will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed units will be repaired or replaced. The notification shall also include the status of the applicable compliance monitoring parameters with respect to normal, and the results of any response actions taken up to the time of notification.

D.2.10 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3] [326 IAC 7-2-1]

(a) Pursuant to 326 IAC 7-2-1(c), the Permittee shall demonstrate that the sulfur dioxide emissions from Boiler 5 do not exceed the equivalent of 6.0 pound per million British thermal units (lb/MMBtu) of heat input, using a calendar month average.

(b) Pursuant to 326 IAC 7-2-1(e) and 326 IAC 3-7, coal sampling and analysis data shall be collected as follows:

(1) Coal sampling shall be performed using the methods specified in 326 IAC 3-7-2(a), and sample preparation and analysis shall be performed as specified in 326 IAC 3-7-2(c), (d), and (e); or

(2) Pursuant to 326 IAC 3-7-2(b)(2) and 326 IAC 3-7-3, manual or other non-ASTM automatic sampling and analysis procedures may be used upon a demonstration, submitted to the department for approval, that such procedures provide sulfur dioxide emission estimates representative either of estimates based on coal sampling and analysis procedures specified in 326 IAC 3-7-2 or of continuous emissions monitoring; or

(3) The Permittee shall meet the minimum sampling requirements specified in 326 IAC 3-7-2(b)(3), and sample preparation and analysis shall be performed as specified in 326 IAC 3-7-2(c), (d), and (e).

(4) Pursuant to 326 IAC 3-7-5(a), the Permittee shall develop a standard operating procedure (SOP) to be followed for sampling, handling, analysis, quality control, quality assurance, and data reporting of the information collected pursuant to 326 IAC 3-7-2 through 326 IAC 3-7-4. In addition, any revision to the SOP shall be submitted to IDEM, OAQ.

(c) Continuous emission monitoring data collected and reported pursuant to 326 IAC 3-5 may be used as the means for determining compliance with the emission limitations in 326 IAC 7 instead of the fuel sampling and analysis required in (b). [326 IAC 7-2-1(g)]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.2.11 Opacity Readings [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)] [40 CFR 64]

(1) In the event of emissions exceeding twenty percent (20%) average opacity for three (3) consecutive six (6)-minute averaging periods, appropriate response steps shall be taken such that the cause(s) of the excursion are identified and corrected and opacity levels are brought back below twenty percent (20%). Examples of expected response steps include, but are not limited to, boiler loads being reduced, adjustment of flue gas conditioning rate, and the baghouse being returned to service. Section C - Response to Excursions or Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition.

(2) Opacity readings in excess of twenty percent (20%) but not exceeding the opacity limit for the unit are not a deviation from this permit. Failure to take response steps shall be considered a deviation from this permit. Section C - Response to Excursions or Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition.

D.2.12 Baghouse Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)] [40 CFR 64]

Whenever a COMS is malfunctioning or is down for maintenance or repairs for a period of twenty-four (24) hours or more and a backup COMS is not online within twenty-four (24) hours of shutdown or malfunction of the primary COMS:

(a) The Permittee shall record the pressure drop across the baghouse used in conjunction with Boiler 5, at least once per day when the process is in operation when venting to the atmosphere. When for any one reading, the pressure drop across the baghouse is outside the normal range of 1.0 and 7.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps. Section C - Response to Excursions or Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition.

(b) A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps shall be considered a deviation from this permit. The instrument used for determining the pressure shall comply with Section C - Instrument Specifications, and shall be calibrated or replaced in accordance with the manufacturer's specifications. Section C - Response to Excursions or Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition.

D.2.13 SO_2 Monitoring System Downtime [326 IAC 2-7-6] [326 IAC 2-7-5(3)] [326 IAC 3-7-2] [326 IAC 3-7-3]

Whenever the SO_2 continuous emission monitoring system for Boiler 5 is malfunctioning or down for repairs or adjustments for twenty-four (24) hours or more, the Permittee shall:

(a) Monitor and record boiler load, fuel sulfur content, and limestone injection rate, to demonstrate that the operation of the limestone injection system continues in a manner typical for the boiler load and sulfur content of the coal fired. Limestone injection parametric monitoring readings shall be recorded at least once per hour until the primary CEMS or a backup CEMS is brought online.

(b) Conduct fuel sampling as specified in 326 IAC 3-7-2(b). Fuel sample preparation and analysis shall be conducted as specified in 326 IAC 3-7-2(c), 326 IAC 3-7-2(d), and 326 IAC 3-7-2(e). Pursuant to 326 IAC 3-7-3, manual or other non-ASTM automatic sampling and analysis procedures may be used upon a demonstration, submitted to the department for approval, that such procedures provide sulfur dioxide emission estimates representative either of estimates based on coal sampling and analysis procedures specified in 326 IAC 3-7-2 or of continuous emissions monitoring.

D.2.14 NO_X Monitoring System Downtime [326 IAC 2-7-6] [326 IAC 2-7-5(3)] [326 IAC 3-7-2] [326 IAC 3-7-3]

Whenever the NO_X continuous emission monitoring system for Boiler 5 is malfunctioning or down for repairs or adjustments for twenty-four (24) hours or more, the Permittee shall operate Boiler 5 in a manner consistent with best combustion practices.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.2.15 Record Keeping Requirements

(a) To document the compliance status with Section C - Maintenance of Continuous Opacity Monitoring Equipment, and the opacity requirements in Conditions D.2.5, D.2.10, D.2.11, and D.2.14, the Permittee shall maintain records in accordance with (1) and (2) below. Records shall be complete and sufficient to establish compliance with the opacity limits in Conditions D.2.5 and D.2.14.

(1) All continuous opacity monitoring data, pursuant to 326 IAC 3-5-6.

(2) The results of all Method 9 visible emission readings taken during any periods of COM downtime.

(b) To document the compliance status with the SO_2 requirements in Conditions D.2.1, D.2.4, D.2.8, D.2.10, D.2.13, and D.2.16, the Permittee shall maintain records in accordance with (1) through (4) below. Records shall be complete and sufficient to establish compliance with the applicable SO_2 limits in Conditions D.2.1 and D.2.4. The Permittee shall maintain records in accordance with (3) and (4) below during SO_2 CEM system downtime.

(1) All SO_2 continuous emissions monitoring data, pursuant to 326 IAC 3-5-6 and 326 IAC 7-2-1(g).

(2) All startup periods and shutdown periods for Boiler 5.

(3) All boiler load, fuel sampling and analysis, and limestone injection rate data collected for SO_2 CEMS downtime, in accordance with Conditions D.2.8 and D.2.16.

(4) Actual fuel usage during each SO_2 CEM system downtime.

(c) To document the compliance status with the NO_X requirements in Condition D.2.10, the Permittee shall maintain records of all NO_X and CO_2 or O_2 continuous emissions monitoring data, pursuant to 326 IAC 3-5-6.

(d) To document the compliance status with the CO requirements in Conditions D.2.1(b) and D.2.7(a), the Permittee shall maintain data and results from the most recent stack test for Boiler 5. Records shall be complete and sufficient to establish compliance with the CO limit in Condition D.2.1(b).

(e) To document the compliance status with Condition D.2.12, the Permittee shall maintain daily records of the pressure drop across the baghouse for Boiler 5 whenever a COMS is malfunctioning or is down for maintenance or repairs for a period of twenty-four (24) hours or more and a backup COMS is not online within twenty-four (24) hours of shutdown or malfunction of the primary COMS. The Permittee shall include in its daily record when a reading is not taken and the reason for the lack of a reading (e.g. the process did not operate that day).

(f) Section C - General Record Keeping Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.

D.2.16 Reporting Requirements

(a) A quarterly report of opacity exceedances and a quarterly summary of the information to document the compliance status with Conditions D.2.1(a), D.2.4, and D.2.5, shall be submitted not later than thirty (30) days following the end of each calendar quarter. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

(b) Pursuant to Condition D.2.8(c) regarding the block 24 hour average SO_2 emission limitation for Boiler 5, the quarterly report for SO_2 shall explain whether any excess 24 hour average emission rates due to startup and shutdown were excluded from the compliance determination.

(c) Pursuant to 326 IAC 3-5-7(5), reporting of continuous monitoring system instrument downtime, except for zero (0) and span checks, which shall be reported separately, shall include the following:

(1) date of downtime;

(2) time of commencement;

(3) duration of each downtime;

(4) reasons for each downtime; and

(5) nature of system repairs and adjustments.

(d) Section C - General Reporting Requirements contains the Permittee's obligations with regard to the reporting required by this condition.

The reports submitted by the Permittee require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

SECTION D.3 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]:

(c) One (1) natural gas and distillate fuel oil fired boiler, identified as Boiler 3, with installation started in 1973 or 1974 and completed in 1974, with a nominal capacity of 286 MMBtu/hr, exhausting to stack WADE 03. Boiler 3 has a continuous emissions monitoring system (CEMS) for nitrogen oxides (NO_X).

Under the Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction is Commenced After August 17, 1971 NSPS (40 CFR 60, Subpart D), Boiler 3 is considered an affected source.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.3.1 Temporary Alternative Opacity Limitations [326 IAC 5-1-3]

(a) Pursuant to 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), when building a new fire in a boiler, or shutting down a boiler, opacity may exceed the forty percent (40%) opacity limitation established by 326 IAC 5-1-2. However, opacity levels shall not exceed sixty percent (60%) for any six (6)-minute averaging period. Opacity in excess of the applicable limit established in 326 IAC 5-1-2 shall not continue for more than two (2) six (6)-minute averaging periods in any twenty-four (24) hour period. [326 IAC 5-1-3(a)]

(b) When removing ashes from the fuel bed or furnace in a boiler or blowing tubes, opacity may exceed forty percent (40%); however, opacity shall not exceed sixty percent (60%) for any six (6)-minute averaging period and opacity in excess of forty percent (40%) shall not continue for more than one (1) six (6)-minute averaging period in any sixty (60)-minute period. The averaging periods shall not be permitted for more than three (3) six (6)-minute averaging periods in a twelve (12) hour period.

(c) If a facility cannot meet the opacity limitations of 326 IAC 5-1-3(a), the Permittee may submit a written request to IDEM, OAQ, for a temporary alternative opacity limitation in accordance with 326 IAC 5-1-3(d). The Permittee must demonstrate that the alternative limit is needed and justifiable.

D.3.2 Sulfur Dioxide (SO_2) [326 IAC 7-1.1]

Pursuant to 326 IAC 7-1.1-2(a)(3), sulfur dioxide emissions from Boiler 3 shall not exceed five-tenths (0.5) pound per million Btu (lb/MMBtu), using a calendar month average, when combusting only distillate oil or a combination of only distillate oil and natural gas.

D.3.3 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

A Preventive Maintenance Plan (PMP) is required for Boiler 3 and any emission control devices. Section B - Preventive Maintenance Plan contains the Permittee's obligations with regard to the preventive maintenance plan required by this condition.

Compliance Determination Requirements

D.3.4 Continuous Emissions Monitoring [326 IAC 3-5]

(a) Pursuant to 326 IAC 3-5 (Continuous Monitoring of Emissions), continuous emission monitoring systems for Boiler 3 shall be calibrated, maintained, and operated for measuring NO_X, which meet the performance specifications of 326 IAC 3-5-2.

(b) All continuous emission monitoring systems are subject to monitor system certification requirements pursuant to 326 IAC 3-5-3.

(c) If the Administrator approves alternative monitoring requirements in lieu of the COM requirements for Boiler 3, then IDEM, OAQ, may require additional PM stack testing and Method 9 opacity readings to demonstrate compliance with 326 IAC 5-1 and 326 IAC 6-2, pursuant to 326 IAC 3-5-1(c)(2)(A)(ii).

(d) Nothing in this permit shall excuse the Permittee from complying with the requirements to operate a continuous emission monitoring system pursuant to 326 IAC 3-5, 40 CFR 60, or 40 CFR 75.

D.3.5 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3] [326 IAC 7-2] [326 IAC 7-1.1-2]

(a) Pursuant to 326 IAC 7-2-1(c), the Permittee shall demonstrate that the sulfur dioxide emissions do not exceed the limits specified in Condition D.3.2, using a calendar month average.

(b) Pursuant to 326 IAC 7-2-1(e) and 326 IAC 3-7-4, fuel sampling and analysis data shall be collected as follows:

(1) The Permittee may rely upon vendor analysis of fuel delivered, if accompanied by a vendor certification [326 IAC 3-7-4(b)]; or,

(2) The Permittee shall perform sampling and analysis of fuel oil samples in accordance with 326 IAC 3-7-4(a).

(A) Oil samples shall be collected from the tanker truck load prior to transferring fuel to the storage tank; or

(B) Oil samples shall be collected from the storage tank immediately after each addition of fuel to the tank.

(c) Upon written notification to IDEM by a facility owner or operator, continuous emission monitoring data collected and reported pursuant to 326 IAC 3-5 may be used as the means for determining compliance with the emission limitations in 326 IAC 7. Upon such notification, the other requirements of 326 IAC 7-2 shall not apply. [326 IAC 7-2-1(g)]

Record Keeping and Reporting Requirement [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.3.6 Record Keeping Requirements

(a) To document the compliance status with the opacity requirements in Condition D.3.1, the Permittee shall maintain records in accordance with (1) and (2) below. Records and shall be complete and sufficient to establish compliance with the opacity limits in Condition D.3.1.

(1) Data and results from the most recent stack test;

(2) The opacity exceedances from COMS data or results of all daily Method 9 visible emission (VE) readings.

(b) To document the compliance status with the SO_2 requirements in Conditions D.3.2 and D.3.5, the Permittee shall maintain records in accordance with (1) and (2) below. Records and shall be complete and sufficient to establish compliance with the SO_2 limits in Condition D.3.2.

(1) All fuel sampling and analysis data, pursuant to 326 IAC 7-2.

(2) Actual fuel usage since last compliance determination period.

(c) Section C - General Record Keeping Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.

D.3.7 Reporting Requirements

Pursuant to 326 IAC 3-5-7(5), reporting of continuous monitoring system instrument downtime, except for zero (0) and span checks, which shall be reported separately, shall include the following:

(a) date of downtime;

(b) time of commencement;

(c) duration of each downtime;

(d) reasons for each downtime; and

(e) nature of system repairs and adjustments.

The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

Section C - General Reporting Requirements contains the Permittee's obligations with regard to the reporting required by this condition.

SECTION D.4 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]:

(f) One (1) natural gas fired boiler, identified as Boiler 7, permitted in 2010, with a nominal capacity of 290 MMBtu/hr, exhausting to stack WADE 03. Boiler 7 has a continuous emissions monitoring system (CEMS) for nitrogen oxides (NO_X) for compliance with NSPS requirements.

Under the Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units NSPS (40 CFR 60, Subpart Db), Boiler 7 is considered an affected source.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.4.1 Boiler 7 PSD Minor Limits [326 IAC 2-2]

(a) The natural gas usage for Boiler 7 shall not exceed 2,491 million cubic feet (MMCF) per twelve (12) consecutive month period. Compliance with this limit shall be determined at the end of each month.

(b) NO_X emissions from Boiler 7 shall not exceed 0.049 pounds per million British thermal units (lb/MMBtu) of heat input.

(c) PM emissions from Boiler 7 shall not exceed 1.9 pounds per million standard cubic feet (MMCF) of natural gas.

(d) PM_{10} emissions from Boiler 7 shall not exceed 7.6 pounds per million standard cubic feet (MMCF) of natural gas.

(e) $PM_{2.5}$ emissions from Boiler 7 shall not exceed 7.6 pounds per million standard cubic feet (MMCF) of natural gas.

(f) SO_2 emissions from Boiler 7 shall not exceed 0.6 pounds per million standard cubic feet (MMCF) of natural gas.

Compliance with these emission limits combined with the potential to emit NO_X, PM, PM_{10}, $PM_{2.5}$, and SO_2 emissions from all other emission units associated with the modification to add Boiler 7 will limit the potential to emit from this modification to less than one hundred (100) tons per year of CO, less than forty (40) tons per year of NO_X, less than twenty-five (25) tons per year of PM, less than fifteen (15) tons per year of PM_{10}, less than ten (10) tons per year of $PM_{2.5}$, and less than forty (40) tons per year of SO_2. Therefore the requirements of 326 IAC 2-2 (PSD) are not applicable to the modification to add Boiler 7.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.4.2 Record Keeping Requirements

(a) To document compliance with Condition D.4.1(a), the Permittee shall maintain monthly records of natural gas usage.

(b) Section C - General Record Keeping Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.

D.4.3 Reporting Requirements

A quarterly summary of the information to document the compliance status with Condition D.4.1(a) shall be submitted not later than thirty (30) days following the end of each calendar quarter. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34). Section C - General Reporting Requirements contains the Permittee's obligations with regard to the reporting required by this condition.

SECTION D.5 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]:

(g) One (1) coal storage and handling system identified as COAL Segment 1, installed in 1960, with a nominal capacity of 110 tons/hr, including: truck unloading station with two (2) hoppers; two (2) vibratory feeders; one (1) underground belt conveyor with a magnetic separator; and one (1) bucket elevator terminating at the top of Wade Utility Plant. Coal is fed to the bunkers for Boiler 1, Boiler 2, and to the pre-crusher ahead of the indoor storage silo for Boiler 5. Emissions from the Boiler 1 and Boiler 2 bunkers are controlled by a RotoClone for each of the two (2) bunkers. The bunker for Boiler 1 exhausts to stack CB1. The bunker for Boiler 2 exhausts to CB2. COAL Segment 1 has been retained as a backup system for COAL Segment 2.

(h) One (1) coal storage and handling system identified as COAL Segment 2, installed in 1996, with a nominal capacity of 107 tons/hr, including: truck unloading and two (2) in-ground hoppers, two (2) vibratory feeders; one (1) totally enclosed tubular conveyor identified as BC-1 equipped with a magnetic separator and with emissions controlled by a baghouse exhausting to stack CV1; one (1) transfer enclosure with one (1) coal sampler, with emissions controlled by a baghouse exhausting to stack CV2; and one (1) totally enclosed tubular conveyor identified as BC-2 terminating at the top of Wade Utility Plant, with emissions from the final transfer point controlled by a baghouse exhausting to stack CV3. Coal is fed to the bunkers for Boiler 1, Boiler 2, and to the pre-crusher ahead of the indoor storage silo for Boiler 5. Emissions from the Boiler 1 and Boiler 2 bunkers are controlled by a RotoClone for each of the two (2) bunkers. The bunker for Boiler 1 exhausts to stack CB1. The bunker for Boiler 2 exhausts to CB2.

(i) One (1) outdoor coal storage pile area identified as COAL PILE 1, permitted in 1960 and 1996, with particulate matter emissions exhausting to the atmosphere.

(j) One (1) coal preparation system for Boiler 5, with installation completed in 1991, with a nominal capacity of 12.68 tons/hr, including: one (1) enclosed 125 ton/hr Redler conveyor with one (1) enclosed pre-crusher (both serving in a back-up capacity), one (1) 150 ton/hr enclosed belt conveyor and pre-crusher with installation completed in 2009. Both lines feed into; one (1) coal storage bunker, two (2) weigh belt feeders; and two (2) enclosed crushers with emission directed to a baghouse exhausting to stack CB5.

Under the Standards of Performance for Coal Preparation Plants NSPS (40 CFR 60, Subpart Y), the coal preparation system for Boiler 5 including the crushers and COAL Segment 2 are considered affected sources.

Insignificant Activities:
Coal bunker and coal scale exhausts and associated dust collector vents.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.5.1 PSD Minor Limit [326 IAC 2-2-1]

The emissions from the coal storage and handling equipment included in COAL Segment 2 shall be limited as follows:

(1) Particulate matter (PM) emissions from CV1 shall not exceed 1.71 pounds per hour.

(2) PM_{10} emissions from CV1 shall not exceed 1.02 pounds per hour.

(3) Particulate matter (PM) emissions from CV2 shall not exceed 2.28 pounds per hour.

(4) PM_{10} emissions from CV2 shall not exceed 1.36 pounds per hour.

(5) Particulate matter (PM) emissions from CV3 shall not exceed 1.71 pounds per hour.

(6) PM_{10} emissions from CV3 shall not exceed 1.02 pounds per hour.

Compliance with the above limits shall limit PM and PM_{10} emissions less than 25 and 15 tons per year respectively, and will render the requirements of 326 IAC 2-2-1(x) and 326 IAC 2-2-1(jj) (PSD Requirements) not applicable to the coal preparation system for Boiler 5.

D.5.2 Particulate [326 IAC 6-3-2]

(a) Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), the allowable particulate emission rate from the COAL Segment 1 shall not exceed 52.23 pounds per hour (lb/hr) when operating at a process weight rate of 110 tons per hour (ton/hr), and the allowable particulate emission rate from the COAL Segment 2 shall not exceed 51.96 pounds per hour (lb/hr) when operating at a process weight rate of 107 tons per hour (ton/hr). Interpolation and extrapolation of the data for the process weight rate in excess of sixty thousand (60,000) pounds per hour (lb/hr) shall be accomplished by use of the equation:

$E = 55.0\ P^{0.11} - 40$ where E = rate of emission in pounds per hour (lb/hr); and
P = process weight rate in tons per hour (ton/hr).

(b) Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), the allowable particulate emission rate from the Boiler 5 coal preparation system shall not exceed 22.48 pounds per hour (lb/hr) when operating at a process weight rate of 12.68 tons per hour (ton/hr). Interpolation of the data for the process weight rate up to sixty thousand (60,000) pounds per hour (lb/hr) shall be accomplished by use of the equation:

$E = 4.10\ P^{0.67}$ where E = rate of emission in pounds per hour (lb/hr); and
P = process weight rate in tons per hour (ton/hr).

D.5.3 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

A Preventive Maintenance Plan (PMP) is required for these facilities and their emission control devices. Section B - Preventive Maintenance Plan contains the Permittee's obligations with regard to the preventive maintenance plan required by this condition.

Compliance Determination Requirements

D.5.4 Particulate Control [326 IAC 2-7-6(6)]

Except as otherwise provided by statute or rule or in this permit, in order to comply with Conditions D.5.1 and D.5.2, the RotoClones, cartridge filters, and baghouses for particulate control shall be in operation and control emissions at all times the associated coal processing or conveying is in operation.

Compliance Monitoring Requirements [**326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]**

D.5.5 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

(a) Visible emission notations of the coal unloading station shall be performed once per week during normal daylight operations when exhausting to the atmosphere. A trained employee shall record whether emissions are normal or abnormal.

(b) Visible emission notations of each coal transfer exhaust point shall be performed once per week during normal daylight operations when exhausting to the atmosphere. A trained employee shall record whether emissions are normal or abnormal.

(c) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.

(d) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.

(e) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.

(f) If abnormal emissions are observed, the Permittee shall take reasonable response steps. Observation of abnormal emissions that do not violate an applicable opacity limit is not a deviation from this permit. Failure to take response steps shall be considered a deviation from this permit. Section C – Response to Excursions or Exceedances contains the Permittee's obligations with regard to responding to the reasonable response steps required by this condition.

D.5.6 Baghouse Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

(a) The Permittee shall record the pressure drop across each of the baghouses used in conjunction with the coal transfer drop points at least once per week when coal is being transferred. When for any one reading, the pressure drop across baghouse CV1 or CV3 is outside the normal range of 4.0 and 10.0 inches of water or a range established during the latest stack test, or the pressure drop across baghouse CV2 is outside the normal range of 5.0 to 12.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps. A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps shall be considered a deviation from this permit. Section C - Response to Excursions or Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition.

(b) The instrument used for determining the pressure shall comply with Section C - Instrument Specifications, and shall be calibrated or replaced in accordance with the manufacturer's specifications. The specifications shall be available on site with the Preventive Maintenance Plan.

D.5.7 Broken or Failed Bag Detection - Single and Multi-Compartment Baghouses [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

(a) For a single compartment baghouse controlling emissions from a process operated continuously, a failed unit and the associated process shall be shut down immediately until the failed unit has been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).

(b) For a single compartment baghouse controlling emissions from a batch process, the feed to the process shall be shut down immediately until the failed unit has been repaired or replaced. The emissions unit shall be shut down no later than the completion of the processing of the material in the line. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).

(c) In the event that bag failure is observed in a multi-compartment baghouse, if operations will continue for ten (10) days or more after the failure is observed before the failed units will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed units will be repaired or replaced. The notification shall also include the status of the applicable compliance monitoring parameters with respect to normal, and the results of any response actions taken up to the time of notification.

Bag failure can be indicated by a significant drop in the baghouse's pressure reading with abnormal visible emissions, by an opacity violation, or by other means such as gas temperature, flow rate, air infiltration, leaks, dust traces or triboflows.

D.5.8 RotoClone Failure Detection [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

In the event that RotoClone failure has been observed:

The failed units and the associated process will be shut down immediately until the failed units have been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions). Failure to take response steps shall be considered a deviation from this permit. Section C - Response to Excursions or Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.5.9 Record Keeping Requirements

(a) To document the compliance status with Condition D.5.5, the Permittee shall maintain records of the weekly visible emission notations of the coal unloading and coal transfer exhaust points. The Permittee shall include in its weekly record when a visible emission notation is not taken and the reason for the lack of visible emission notation, (e.g., the process did not operate that week).

(b) To document the compliance status with Condition D.5.6, the Permittee shall maintain weekly records of the total static pressure drop across each baghouse. The Permittee shall include in its weekly record when a pressure drop reading is not taken and the reason for the lack of a pressure drop reading, (e.g., the process did not operate that week).

(c) Section C - General Record Keeping Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.

SECTION D.6 FACILITY CONDITIONS

Facility Description [326 IAC 2-7-5(15)]:

(k) One (1) pneumatic ash handling system for fly ash and bottom ash from Boiler 1 and Boiler 2, identified as ASH Segment 1, with a nominal capacity of 14 tons per hour (ton/hr), installed in approximately 1960 and modified in 2002. Ash/particulate matter collected from the primary, secondary and tertiary (baghouse) collection units are transferred to the existing ash silo. Ash accumulated in this silo is removed via a water mixer into trucks. Particulate matter that passes through the tertiary (baghouse) filter is exhausted to stack ASH1 while air from the ash silo is directed to a final filter before exhausting to stack AB1. Ash/particulate matter is transported through the system by an electric vacuum pump.

(l) One (1) pneumatic ash handling system for fly ash and bottom ash from Boiler 5, identified as ASH Segment 2, installed in 1991 and modified in 2002, exhausting to stacks ASH5A and ASH5B, with a nominal capacity of 20 tons/hr, with dust from ash transfer to the storage silo controlled by primary and secondary separator with tertiary baghouse filter, ASH5D. Ash is transferred from the silo to trucks at a nominal capacity of 300 tons/hr; dust is controlled by water mix, or by use of a telescoping spout with air displaced from the truck directed through a “filter module” with five canister filters which exhaust to the atmosphere though a vent, ASH5C.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.6.1 PSD Minor Limits for Ash Segment 2 [326 IAC 2-2-1]

Emissions from the Ash Segment 1 associated with Boiler 1 and Boiler 2 shall be limited as follows:

(1) Particulate matter (PM) emissions from ASH1 shall not exceed 2.85 pounds per hour.

(2) PM_{10} emissions from ASH1 shall not exceed 1.70 pounds per hour.

(3) Particulate matter (PM) emissions from AB1 shall not exceed 2.85 pounds per hour.

(4) PM_{10} emissions from AB1 shall not exceed 1.70 pounds per hour.

Compliance with the above limits shall limit PM and PM_{10} emissions less than 25 and 15 tons per year respectively, and will render the requirements of 326 IAC 2-2-1(x) and 326 IAC 2-2-1(jj) (PSD Requirements) not applicable to Ash Segment 1 associated with Boiler 1 and Boiler 2.

D.6.2 Particulate [326 IAC 6-3-2]

(a) Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), the particulate emission rate from each transfer point for the ash handling system identified as ASH Segment 1 shall not exceed 24.03 pounds per hour (lb/hr) when operating at a process weight rate of 14 tons per hour (ton/hr).

(b) Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), the allowable particulate emission rate from each transfer point for the pneumatic ash handling system identified as ASH Segment 2 shall not exceed 30.5 pounds per hour (lb/hr) when operating at a process weight rate of 20 tons per hour (ton/hr).

Interpolation of the data for the process weight rate up to sixty thousand (60,000) pounds per hour (lb/hr) shall be accomplished by use of the equation:

$E = 4.10\ P^{0.67}$ where E = rate of emission in pounds per hour (lb/hr); and
P = process weight rate in tons per hour (ton/hr).

(c) Pursuant to 326 IAC 6-3-2(e)(3) (Particulate Emission Limitations for Manufacturing Processes), for the ash unloading at the maximum throughput rate of 300 tons per hour for Ash Segment 2, the concentration of particulate in the discharge gases to the atmosphere shall be less than 0.10 pounds per one thousand (1,000) pounds of gases.

D.6.3 Preventative Maintenance Plan [326 IAC 2-7-5(1)(13)]

A Preventive Maintenance Plan (PMP) is required for the pneumatic ash handling systems identified as ASH Segment 1 and ASH Segment 2 and their emission control devices. Section B - Preventive Maintenance Plan contains the Permittee's obligations with regard to the preventive maintenance plan required by this condition.

Compliance Determination Requirements

D.6.4 Particulate Control [326 IAC 2-7-10.5(d)(5)(C)]

(a) The fresh water/mixing operation for the ash truck loading system for ASH Segment 1 shall be in operation and control the particulate emissions from the ash at all times that the ash truck loading system is in operation.

(b) The baghouse of ASH1 stack and air filter for AB1 stack for particulate control, shall be in operation and control the particulate emissions from ash system at all times that the ash storage and handling system is in operation.

(c) Except as otherwise provided by statute or rule or in this permit, in order to comply with Conditions D.6.1 and D.6.2 (Particulate) related to ASH Segment 2, the baghouse filters for particulate control shall be in operation and control emissions at all times that the associated ash handling is in operation; the telescoping spout shall be in operation and control emissions at all times that the dry ash loading system is in operation; and water shall be mixed with the ash at all times to control emissions when the wet process ash loading system.

(d) The filter module and canister filters for the ASH Segment 2 dry ash loading system, for particulate control shall be in operation and control the particulate emissions at all times that the dry ash loading system is in operation.

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.6.5 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

(a) Visible Emissions Notations:

(1) Visible emission notations of the ASH1 and AB1 exhaust stacks shall be performed once per day during normal daylight operations and when the silo is receiving ash.

(2) Visible emission notations of the ash truck loading system for ASH Segment 1 shall be performed once per day during normal daylight operations when the ash trucks are receiving ash.

(3) Visible emission notations for ASH Segment 2 of the ASH5A and ASH5B exhaust stacks shall be performed once per day during normal daylight operations when transferring ash.

(4) Visible emission notations for ASH Segment 2 of the exhaust vent, ASH5C, shall be performed once per day during normal daylight operations when transferring ash through the dry ash unloader.

A trained employee shall record whether emissions are normal or abnormal.

(b) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.

(c) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.

(d) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.

(e) If abnormal emissions are observed, the Permittee shall take reasonable response steps. Observation of abnormal emissions that do not violate an applicable opacity limit is not a deviation from this permit. Failure to take response steps shall be considered a deviation from this permit. Section C – Response to Excursions or Exceedances contains the Permittee's obligations with regard to responding to the reasonable response steps required by this condition.

D.6.6 Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

(a) The Permittee shall record the total static pressure drop across the baghouse (ASH1) and air filter (AB1) controlling emissions from the ash handling system for ASH Segment 1, at least once per day when the ash handling system is in operation. When for any one reading, the pressure drop across the baghouse is outside the normal range of 1.0 to 7.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps.

(b) The Permittee shall record the pressure drop across the ash silo baghouse for ASH Segment 2 at least once per week when the ash handling is in operation. When for any one reading, the pressure drop across the baghouse is outside the normal range of 1.0 and 7.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps.

(c) The Permittee shall record the pressure drop across the air filters controlling emissions from the ASH Segment 2 dry ash truck loading system (ASH5C), at least once per week when the dry ash truck loading system is in operation. When for any one reading, the pressure drop across the air filter is outside the normal range of 1.0 and 7.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps.

A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps shall be considered a deviation from this permit. Section C - Response to Excursions or Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition.

(d) The instrument used for determining the pressure shall comply with Section C - Instrument Specifications, and shall be calibrated or replaced in accordance with the manufacturer's specifications. The specifications shall be available on site with the Preventive Maintenance Plan.

D.6.7 Broken or Failed Bag Detection - Single Compartment Baghouses [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

(a) For a single compartment baghouse controlling emissions from a process operated continuously, a failed unit and the associated process shall be shut down immediately until the failed unit has been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).

(b) For a single compartment baghouse controlling emissions from a batch process, the feed to the process shall be shut down immediately until the failed unit has been repaired or replaced. The emissions unit shall be shut down no later than the completion of the processing of the material in the line. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).

Bag failure can be indicated by a significant drop in the baghouse's pressure reading with abnormal visible emissions, by an opacity violation, or by other means such as gas temperature, flow rate, air infiltration, leaks, dust traces or triboflows.

Record Keeping and Reporting Requirement [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.6.8 Record Keeping Requirements

(a) To document the compliance status with Condition D.6.5, the Permittee shall maintain daily records of the visible emission notations of ASH1, AB-1, the ASH5A and ASH5B exhaust stacks, and the exhaust vent ASH5C. The Permittee shall include in its daily record when a visible emission notation is not taken and the reason for the lack of visible emission notation, (e.g. the process did not operate that day).

(b) To document the compliance status with Condition D.6.6, the Permittee shall maintain daily records of the total static pressure drop across each baghouse and air filter. The Permittee shall include in its daily record when a pressure drop reading is not taken and the reason for the lack of a pressure drop reading, (e.g. the process did not operate that day).

(c) Section C - General Record Keeping Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.

SECTION D.7 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]:

(m) Material handling for the limestone injection system for Boiler 5, including pneumatic conveyance system, identified as LC5, from truck to bulk storage in a silo outside, identified as LS1, or to a "day bin", identified as LI5, inside the plant at an offload rate of approximately 12.5 tons per hour (ton/hr); gravity fed from day bin into Boiler 5. Particulate emissions are controlled by a baghouse, identified as LSBH1, on the silo and filter cartridges, identified as BVLI5, on the day bin.

Insignificant Activity:
Covered conveyors for limestone conveying of less than or equal to 7,200 tons per day for sources other than mineral processing plants constructed after August 31, 1983.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.7.1 Particulate [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), the allowable particulate emission rate from each transfer point for the limestone handling system associated with Boiler 5 shall not exceed 22.17 pounds per hour (lb/hr) when operating at a process weight rate of 12.5 tons per hour (ton/hr).

Interpolation of the data for the process weight rate up to sixty thousand (60,000) pounds per hour (lb/hr) shall be accomplished by use of the equation:

$E = 4.10\ P^{0.67}$ where E = rate of emission in pounds per hour (lb/hr); and
P = process weight rate in tons per hour (ton/hr).

D.7.2 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

A Preventive Maintenance Plan (PMP) is required for the limestone storage and handling operations and their emission control devices. Section B - Preventive Maintenance Plan contains the Permittee's obligations with regard to the preventive maintenance plan required by this condition.

Compliance Determination Requirements

D.7.3 Particulate Control [326 IAC 2-7-6(6)]

Except as otherwise provided by statute or rule or in this permit, LSBH1, and BVLI5, for particulate control shall be in operation and control emissions at all times the associated limestone transfer points are in operation.

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.7.4 Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

(a) Visible Emissions Notations:

(1) Visible emission notations of the limestone handling systems exhaust point, identified as LSBH1, shall be performed once per week during normal daylight operations and when the silo is receiving limestone. A trained employee shall record whether emissions are normal or abnormal.

(2) Visible emission notations of the Boiler 5 limestone day bin vent (BVLI5) shall be performed once per week during normal daylight operations when exhausting to the atmosphere. A trained employee shall record whether emissions are normal or abnormal.

(b) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.

(c) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.

(d) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.

(e) If abnormal emissions are observed, the Permittee shall take reasonable response steps. Observation of abnormal emissions that do not violate an applicable opacity limit is not a deviation from this permit. Failure to take response steps shall be considered a deviation from this permit. Section C – Response to Excursions or Exceedances contains the Permittee's obligations with regard to responding to the reasonable response steps required by this condition.

D.7.5 Broken or Failed Bag Detection - Single Compartment Baghouses [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

(a) For a single compartment baghouse controlling emissions from a process operated continuously, a failed unit and the associated process shall be shut down immediately until the failed unit has been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).

(b) For a single compartment baghouse controlling emissions from a batch process, the feed to the process shall be shut down immediately until the failed unit has been repaired or replaced. The emissions unit shall be shut down no later than the completion of the processing of the material in the line. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).

Bag failure can be indicated by a significant drop in the baghouse's pressure reading with abnormal visible emissions, by an opacity violation, or by other means such as gas temperature, flow rate, air infiltration, leaks, dust traces or triboflows.

Record Keeping and Reporting Requirement [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.7.6 Record Keeping Requirements

(a) To document the compliance status with Condition D.7.4, the Permittee shall maintain weekly records of the visible emission notations of LSBH–1 and BVLI5. The Permittee shall include in its weekly record when a visible emission notation is not taken and the reason for the lack of visible emission notation, (e.g. the process did not operate that week).

(b) Section C - General Record Keeping Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.

SECTION D.8 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]:

(o) One (1) natural gas fired dual chamber animal carcass incinerator, identified as ADDL, installed in 1991, with a nominal heat input capacity of 6.5 MMBtu/hr, with an 800 lb/hr waste capacity, exhausting to stack PUADDL1.

Insignificant Activities:

(1) One (1) No. 2 fuel oil fired poultry incinerator, installed in 2007, with an afterburner and a 70 lb/hr waste capacity, located at the animal sciences farm, 5675 W 600 N, West Lafayette, Indiana;

(2) One (1) No. 2 fuel oil fired animal carcass incinerator for swine, installed in 1991 or 1992, with an afterburner and a 100 lb/hr waste capacity, located at the animal sciences farm, 5675 W 600 N, West Lafayette, Indiana;

(3) One (1) natural gas fired incinerator identified as RAD1, installed in 1986, with primary and secondary chambers and a 50 lb/hr waste capacity, for burning laboratory waste and non-infectious biological material contaminated with low level radioactivity, located at the By-Product Material Storage Building North (BMSN).

(4) One (1) natural gas fired incinerator identified as RAD2, installed in 1996, with an afterburner and a 50 lb/hr waste capacity, for burning laboratory waste and non-infectious biological material contaminated with low level radioactivity, located at the By-Product Material Storage Building North (BMSN).

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.8.1 Incinerators [326 IAC 4-2-2]

(a) Pursuant to 326 IAC 4-2-2 (Incinerators), all incinerators shall comply with the following requirements:

(1) Consist of primary and secondary chambers or the equivalent.

(2) Be equipped with a primary burner unless burning only wood products.

(3) Comply with 326 IAC 5-1 and 326 IAC 2.

(4) Be maintained, operated, and burn waste in accordance with the manufacturer's specifications or an operation and maintenance plan as specified in subsection (c).

(5) Not emit particulate matter in excess of one (1) of the following:

(A) For RAD1, with a 250 lb/hr waste capacity:

Three-tenths (0.3) pound of particulate matter per one thousand (1,000) pounds of dry exhaust gas under standard conditions corrected to fifty percent (50%) excess air.

(B) For the swine incinerator with a 100 lb/hr waste capacity, the poultry incinerator with a 70 lb/hr waste capacity, and RAD2 with a 50 lb/hr waste capacity:

Five-tenths (0.5) pound of particulate matter per one thousand (1,000) pounds of dry exhaust gas under standard conditions corrected to fifty percent (50%) excess air for incinerators with solid waste capacity less than two hundred (200) pounds per hour (lb/hr).

(6) If any of the requirements of subdivisions (1) through (5) are not met, then the owner or operator shall stop charging the incinerator until adjustments are made that address the underlying cause of the deviation.

(b) An incinerator is exempt from subsection (a)(5) if subject to a more stringent particulate matter emission limit in 40 CFR 52 Subpart P*, State Implementation Plan for Indiana.

(c) An owner or operator developing an operation and maintenance plan pursuant to subsection (a)(4) must comply with the following:

(1) The operation and maintenance plan must be designed to meet the particulate matter emission limitation specified in subsection (a)(5) and include the following:

(A) Procedures for receiving, handling, and charging waste.

(B) Procedures for incinerator startup and shutdown.

(C) Procedures for responding to a malfunction.

(D) Procedures for maintaining proper combustion air supply levels.

(E) Procedures for operating the incinerator and associated air pollution control systems.

(F) Procedures for handling ash.

(G) A list of wastes that can be burned in the incinerator.

(2) Each incinerator operator shall review the plan before initial implementation of the operation and maintenance plan and annually thereafter.

(3) The operation and maintenance plan must be readily accessible to incinerator operators.

(4) The owner or operator of the incinerator shall notify the department, in writing, thirty (30) days after the operation and maintenance plan is initially developed pursuant to this section.

(d) The owner or operator of the incinerator must make the manufacturer's specifications or the operation and maintenance plan available to the department upon request.

D.8.2 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

A Preventive Maintenance Plan (PMP) is required for these facilities and any emission control devices. Section B - Preventive Maintenance Plan contains the Permittee's obligations with regard to the preventive maintenance plan required by this condition.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.8.3 Record Keeping Requirements

Section C - General Record Keeping Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.

SECTION D.9 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]:

(p) One (1) no. 2 fuel oil fired Black Start electric generator, identified as BSG, with a nominal heat input capacity of 17.7 MMBtu/hr, exhausting through stack BSG-1, with a fuel limit of 113,000 gallons per year.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.9.1 Source Modification Limits [326 IAC 2-7-10.5(d)(5)(D)] [326 IAC 2-2-1]

(a) The input of No. 2 fuel oil to the Black Start electric generator, BSG, shall be limited to less than 113,000 gallons per 12 consecutive month period, with compliance determined at the end of each month.

(b) NO_X emissions shall not exceed 3.2 lb/MMBtu.

Compliance with these emission limits will limit the potential to emit from the modification to add Black Start Generator (BSG) to less than 25 tons per year of NO_X; therefore, the requirements of 326 IAC 2-7-10.5(f), (g), and (h) (Significant Source Modifications), 326 IAC 2-2 (Prevention of Significant Deterioration) and 326 IAC 2-1.1-4 (Federal Provisions) are not applicable to modification to add the Black Start Generator (BSG).

D.9.2 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

A Preventive Maintenance Plan (PMP) is required for the Black Start electric generator, identified as BSG. Section B - Preventive Maintenance Plan contains the Permittee's obligations with regard to the preventive maintenance plan required by this condition.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.9.3 Record Keeping Requirements

(a) To document the compliance status with Condition D.9.1, the Permittee shall maintain records in accordance with (1) through (5) below.

(1) Calendar dates covered in the compliance determination period;

(2) Actual fuel oil usage since last compliance determination period and equivalent nitrogen oxides (NO_X) emissions;

(3) A certification, signed by the owner or operator, that the records of the fuel supplier certifications represent all of the fuel combusted during the period;

(4) The name of the fuel supplier; and

(5) A statement from the fuel supplier that certifies the sulfur content of the fuel oil.

(b) Section C - General Record Keeping Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.

D.9.4 Reporting Requirements

A quarterly summary of the information to document the compliance status with Condition D.9.1(a) shall be submitted using the reporting forms located at the end of this permit, or their equivalent, not later than thirty (30) days following the end of each calendar quarter. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34). Section C - General Reporting Requirements contains the Permittee's obligations with regard to the reporting required by this condition.

SECTION D.10 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]:

Insignificant Activities:
Boilers using the following fuels:

(A) Natural gas-fired combustion sources with heat input equal to or less than ten million (10,000,000) Btu per hour, including three (3) natural gas fired Aviation Tech Building Boilers with low-NO_X combustion systems, installed in 2000, each with 2.8 MMBtu/hr heat input capacity, identified as AV Tech Boiler 1, AV Tech Boiler 2, and AV Tech Boiler 3.

(B) Propane or liquefied petroleum gas, or butane-fired combustion sources with heat input equal to or less than six million (6,000,000) Btu per hour.

(C) Fuel oil-fired combustion sources with heat input equal to or less than two million (2,000,000) Btu per hour and firing fuel containing less than five-tenths (0.5) percent sulfur by weight.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.10.1 Particulate Emission Limitations for Sources of Indirect Heating [326 IAC 6-2-4]

Pursuant to 326 IAC 6-2-4 (Particulate Emission Limitations for Sources of Indirect Heating: Emission Limitations for Facilities Specified in 326 IAC 6-2-1(d)), the PM emissions from each of the boilers classified as an insignificant activity shall not exceed 0.1 pound per million British thermal units (lb/MMBtu) of heat input.

SECTION D.11 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]:

(q) Two (2) portable pumps powered by 350 HP no. 2 diesel fueled engines and mounted on tri-axle trailers, located at the Animal Sciences Research and Education Center, operated intermittently (approximately 500 hours per year each), used for pumping lagoon material to the spray irrigation system and to transfer material from one lagoon to another.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.11.1 Sulfur Dioxide Emission Limitations [326 IAC 7-1.1]

Pursuant to Minor Source Modification 157-15944-00012, issued October 21, 2002, 326 IAC 7-1.1-2, and 326 IAC 7-2-1(c), the sulfur dioxide emissions from fuel combustion facilities shall not exceed five-tenths (0.5) pound per million Btu (lb/MMBtu), using a calendar month average, for distillate oil combustion.

Compliance Determination Requirements

D.11.2 Sulfur Dioxide Emissions and Sulfur Content [326 IAC 3] [326 IAC 7-2] [326 IAC 7-1.1-2]

Pursuant to 326 IAC 7-2-1(e) and 326 IAC 3-7-4 and in order to demonstrate compliance with Condition D.11.1, fuel sampling and analysis data shall be collected as follows:

(a) The Permittee may rely upon vendor analysis of fuel delivered, if accompanied by a vendor certification [326 IAC 3-7-4(b)]; or,

(b) The Permittee shall perform sampling and analysis of fuel oil samples in accordance with 326 IAC 3-7-4(a).

(1) Oil samples shall be collected from the tanker truck load prior to transferring fuel to the storage tank; or

(2) Oil samples shall be collected from the storage tank immediately after each addition of fuel to the tank.

Record Keeping and Reporting Requirement [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.11.3 Record Keeping Requirements

(a) To document the compliance status with the requirements in Conditions D.11.1 and D.11.2, the Permittee shall maintain records of all fuel sampling and analysis data, pursuant to 326 IAC 7-2. Records and shall be complete and sufficient to establish compliance with the SO_2 limit in Condition D.11.1.

(b) Section C - General Record Keeping Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.

SECTION D.12 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]:

Insignificant Activities [326 IAC 2-7-1(21)]:

Degreasing operations that do not exceed 145 gallons per 12 months, except if subject to 326 IAC 20-6. [326 IAC 8-3]

Cleaners and solvents characterized as follows: [326 IAC 8-3]

Having a vapor pressure equal to or less than 2 kPa; 15 mm Hg; or 0.3 psi measured at 38 degrees C (100°F) or;

Having a vapor pressure equal to or less than 0.7 kPa; 5mm Hg; or 0.1 psi measured at 20□C (68°F); the use of which for all cleaners and solvents combined does not exceed 145 gallons per 12 months.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.12.1 Organic Solvent Degreasing Operations: Cold Cleaner Operation [326 IAC 8-3-2]

Pursuant to 326 IAC 8-3-2 (Cold Cleaner Operations), for cold cleaning operations constructed after January 1, 1980, the Permittee shall:

(a) Equip the cleaner with a cover;

(b) Equip the cleaner with a facility for draining cleaned parts;

(c) Close the degreaser cover whenever parts are not being handled in the cleaner;

(d) Drain cleaned parts for at least fifteen (15) seconds or until dripping ceases;

(e) Provide a permanent, conspicuous label summarizing the operation requirements;

(f) Store waste solvent only in covered containers and not dispose of waste solvent or transfer it to another party, in such a manner that greater than twenty percent (20%) of the waste solvent (by weight) can evaporate into the atmosphere.

D.12.2 Organic Solvent Degreasing Operations: Cold Cleaner Degreaser Operation and Control [326 IAC 8-3-5]

(a) Pursuant to 326 IAC 8-3-5(a) (Cold Cleaner Degreaser Operation and Control), for cold cleaner degreaser operations without remote solvent reservoirs, constructed after July 1, 1990, the Permittee shall ensure that the following control equipment requirements are met:

(1) Equip the degreaser with a cover. The cover must be designed so that it can be easily operated with one (1) hand if:

(A) The solvent volatility is greater than two (2) kiloPascals (fifteen (15) millimeters of mercury or three-tenths (0.3) pounds per square inch) measured at thirty-eight degrees Celsius (38°C) (one hundred degrees Fahrenheit (100°F));

(B) The solvent is agitated; or

(C) The solvent is heated.

(2) Equip the degreaser with a facility for draining cleaned articles. If the solvent volatility is greater than four and three-tenths (4.3) kiloPascals (thirty-two (32) millimeters of mercury or six-tenths (0.6) pounds per square inch) measured at thirty-eight degrees Celsius (38°C) (one hundred degrees Fahrenheit (100°F)), then the drainage facility must be internal such that articles are enclosed under the cover while draining. The drainage facility may be external for applications where an internal type cannot fit into the cleaning system.

(3) Provide a permanent, conspicuous label which lists the operating requirements outlined in subsection (b).

(4) The solvent spray, if used, must be a solid, fluid stream and shall be applied at a pressure which does not cause excessive splashing.

(5) Equip the degreaser with one (1) of the following control devices if the solvent volatility is greater than four and three-tenths (4.3) kiloPascals (thirty-two (32) millimeters of mercury or six-tenths (0.6) pounds per square inch) measured at thirty-eight degrees Celsius (38°C) (one hundred degrees Fahrenheit (100°F)), or if the solvent is heated to a temperature greater than forty-eight and nine-tenths degrees Celsius (48.9^{O}C) (one hundred twenty degrees Fahrenheit (120°F)):

(A) A freeboard that attains a freeboard ratio of seventy-five hundredths (0.75) or greater.

(B) A water cover when solvent is used is insoluble in, and heavier than, water.

(C) Other systems of demonstrated equivalent control such as a refrigerated chiller of carbon adsorption. Such systems shall be submitted to the U.S. EPA as a SIP revision.

(b) Pursuant to 326 IAC 8-3-5(b) (Cold Cleaner Degreaser Operation and Control), the owner or operator of a cold cleaning facility construction of which commenced after July 1, 1990, shall ensure that the following operating requirements are met:

(1) Close the cover whenever articles are not being handled in the degreaser.

(2) Drain cleaned articles for at least fifteen (15) seconds or until dripping ceases.

(3) Store waste solvent only in covered containers and prohibit the disposal or transfer of waste solvent in any manner in which greater than twenty percent (20%) of the waste solvent by weight could evaporate.

SECTION D.13 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]:

Insignificant Activities:
The following equipment related to manufacturing activities not resulting in the emission of HAPs: brazing equipment, cutting torches, soldering equipment, welding equipment.

Grinding and machining operations controlled with fabric filters, scrubbers, mist collectors, wet collectors and electrostatic precipitators with a design grain loading of less than or equal to 0.03 grains per actual cubic foot and a gas flow rate less than or equal to 4000 actual cubic feet per minute, including the following: deburring; buffing; polishing; abrasive blasting; pneumatic conveying; and woodworking operations.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.13.1 Particulate [326 IAC 6-3-2]

(a) Pursuant to 326 IAC 6-3-2(e)(2), particulate emissions from any process not exempt under 326 IAC 6-3-1(b) or (c) which has a maximum process weight rate less than 100 pounds per hour (lb/hr) and the methods in 326 IAC 6-3-2(b) through (d) do not apply shall not exceed 0.551 pounds per hour (lb/hr).

(b) Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), the particulate emission rate from the brazing, cutting, soldering, welding, grinding, and machining operations shall not exceed an amount determined by the following, for a process weight rate equal to or greater than 100 pounds per hour (lb/hr):

Interpolation of the data for the process weight rate up to sixty thousand (60,000) pounds per hour (lb/hr) shall be accomplished by use of the equation:

$E = 4.10\ P^{0.67}$ where E = rate of emission in pounds per hour (lb/hr); and
P = process weight rate in tons per hour (ton/hr).

D.13.2 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

A Preventive Maintenance Plan (PMP) is required for all brazing equipment, cutting torches, soldering equipment, welding equipment, and grinding and machining operations. Section B - Preventive Maintenance Plan contains the Permittee's obligations with regard to the preventive maintenance plan required by this condition.

Compliance Determination Requirement

D.13.3 Particulate Control [326 IAC 2-7-6(6)]

Except as otherwise provided by statute or rule or in this permit, the particulate control shall be in operation and control emissions from the grinding and machining operations at all times that the associated process is in operation.

SECTION E.1 Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units [326 IAC 12] [40 CFR 60, Subpart Db]

Emission Unit Description:

(c) One (1) circulating fluidized bed coal fired boiler, identified as Boiler 5, with installation completed in 1991, with a nominal capacity of 279 MMBtu/hr, with a baghouse for particulate matter control and limestone injection for sulfur dioxide control, combusting natural gas for ignition, exhausting to stack WADE 05. Boiler 5 has continuous emissions monitoring systems (CEMS) for nitrogen oxides (NO_X) and sulfur dioxide (SO_2) and a continuous opacity monitor (COM).

Under the Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units NSPS (40 CFR 60, Subpart Db), Boiler 5 is considered an affected source.

(d) One (1) natural gas fired boiler, identified as Boiler 7, permitted in 2010, with a nominal capacity of 290 MMBtu/hr, exhausting to stack WADE 03. Boiler 7 has a continuous emissions monitoring system (CEMS) for nitrogen oxides (NO_X) for compliance with NSPS requirements.

Under the Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units NSPS (40 CFR 60, Subpart Db), Boiler 7 is considered an affected source.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

New Source Performance Standards (NSPS) [326 IAC 12] [40 CFR 60]

E.1.1 General Provisions Relating to NSPS [326 IAC 12-1] [40 CFR Part 60, Subpart A]

The provisions of 40 CFR Part 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to Boiler 5 and Boiler 7 except when otherwise specified in 40 CFR Part 60, Subpart Db.

E.1.2 Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units [326 IAC 12] [40 CFR 60, Subpart Db]

Pursuant to 40 CFR 60, Subpart Db, the Permittee shall comply with the provisions of the Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units (included as Attachment A of this permit), which are incorporated by reference as 326 IAC 12 for Boiler 5 and Boiler 7 as specified as follows:

(a) Boiler 5 is subject to the following portions of Subpart Db.

(1) 40 CFR 60.40b(a)
(2) 40 CFR 60.41b
(3) 40 CFR 60.42b(a), (e), (g), and (i)
(4) 40 CFR 60.43b(a), (f), and (g)
(5) 40 CFR 60.44b(a), (h), and (i)
(6) 40 CFR 60.45b
(7) 40 CFR 60.46b
(8) 40 CFR 60.47b
(9) 40 CFR 60.48b
(10) 40 CFR 60.49b

(b) Boiler 7 is subject to the following portions of Subpart Db.

(1) 40 CFR 60.40b(a)
(2) 40 CFR 60.41b

(3) 40 CFR 60.42b(k)(1-2)
(4) 40 CFR 60.44b(h), (i), and (l)(1)
(5) 40 CFR 60.46b
(6) 40 CFR 60.48b
(7) 40 CFR 60.49b

SECTION E.2 Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction is Commenced After August 17, 1971 [326 IAC 12] [40 CFR 60, Subpart D]

Emission Unit Description:

(b) One (1) natural gas and distillate fuel oil fired boiler, identified as Boiler 3, with installation started in 1973 or 1974 and completed in 1974, with a nominal capacity of 286 MMBtu/hr, exhausting to stack WADE 03. Boiler 3 has a continuous emissions monitoring system (CEMS) for nitrogen oxides (NO_X).

Under the Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction is Commenced After August 17, 1971 NSPS (40 CFR 60, Subpart D), Boiler 3 is considered an affected source.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

New Source Performance Standards (NSPS) [326 IAC 12] [40 CFR 60]

E.2.1 General Provisions Relating to NSPS [326 IAC 12-1] [40 CFR Part 60, Subpart A]

The provisions of 40 CFR Part 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to Boiler 3 except when otherwise specified in 40 CFR Part 60, Subpart D.

E.2.2 Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction is Commenced After August 17, 1971 [326 IAC 12] [40 CFR 60, Subpart D]

Pursuant to 40 CFR 60, Subpart D, the Permittee shall comply with the provisions of the Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction is Commenced After August 17, 1971 (included as Attachment B of this permit), which are incorporated by reference as 326 IAC 12 for Boiler 3 as specified as follows:

(1) 40 CFR 60.40(a)(1) and (c)
(2) 40 CFR 60.41
(3) 40 CFR 60.42(a) and (c)
(4) 40 CFR 60.43(a)(1)and (b-d)
(5) 40 CFR 60.44(a)(1-2), (b), and (e)
(6) 40 CFR 60.45
(7) 40 CFR 60.46

E.2.3 Alternative Opacity Requirement [326 IAC 12] [40 CFR 60, Subpart D]

Pursuant to the U.S. EPA letter dated September 16, 2004, the Permittee may operate Boiler 3 without a continuous opacity monitoring (COM) system provided the following requirements are met:

(a) The usage of distillate fuel oil in Boiler 3 shall be limited to 500,000 U.S. gallons per twelve (12) consecutive month period, with compliance determined at the end of each month.

(b) Any change in the type of fuel oil used in Boiler 3, other than distillate fuel oil and natural gas, must be approved by IDEM, OAQ.

(c) An observer certified in accordance with EPA Method 9 shall perform 6-minute visible emissions observations at least once per day during daylight hours when distillate fuel oil is burned in Boiler 3.

(d) If the average opacity for a 6-minute set of visible emissions observations made exceeds ten (10) percent, the observer shall collect two additional 6-minute sets of visible emissions observations for a total of three data sets. If excess emissions occur during the three 6-minute sets of visible emissions observations, the observer shall collect additional 6-minute sets of visible emissions observations until excess emissions do not occur during three (3) consecutive 6-minute sets of visible emissions observations. Boiler 3 may be repaired or adjusted before the additional visible emissions observations are conducted.

E.2.4 Reporting Requirements

A quarterly summary of the information to document the compliance status with Condition E.2.3 shall be submitted not later than thirty (30) days following the end of each calendar quarter. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34). Section C - General Reporting Requirements contains the Permittee's obligations with regard to the reporting required by this condition.

SECTION E.3 Standards of Performance for Coal Preparation Plants [326 IAC 12] [40 CFR 60, Subpart Y]

Emission Unit Description:

(h) One (1) coal storage and handling system identified as COAL Segment 2, installed in 1996, with a nominal capacity of 107 tons/hr, including: truck unloading and two (2) in-ground hoppers, two (2) vibratory feeders; one (1) totally enclosed tubular conveyor identified as BC-1 equipped with a magnetic separator and with emissions controlled by a baghouse exhausting to stack CV1; one (1) transfer enclosure with one (1) coal sampler, with emissions controlled by a baghouse exhausting to stack CV2; and one (1) totally enclosed tubular conveyor identified as BC-2 terminating at the top of Wade Utility Plant, with emissions from the final transfer point controlled by a baghouse exhausting to stack CV3. Coal is fed to the bunkers for Boiler 1, Boiler 2, and to the pre-crusher ahead of the indoor storage silo for Boiler 5. Emissions from the Boiler 1 and Boiler 2 bunkers are controlled by a RotoClone for each of the two (2) bunkers. The bunker for Boiler 1 exhausts to stack CB1. The bunker for Boiler 2 exhausts to CB2.

(j) One (1) coal preparation system for Boiler 5, with installation completed in 1991, with a nominal capacity of 12.68 tons/hr, including: one (1) enclosed 125 ton/hr Redler conveyor with one (1) enclosed pre-crusher (both serving in a back-up capacity), one (1) 150 ton/hr enclosed belt conveyor and pre-crusher with installation completed in 2009. Both lines feed into one (1) coal storage bunker, two (2) weigh belt feeders; and two (2) enclosed crushers with emission directed to a baghouse exhausting to stack CB5.

Under the Standards of Performance for Coal Preparation Plants NSPS (40 CFR 60, Subpart Y), the coal preparation system for Boiler 5 including the crushers and COAL Segment 2 are considered affected sources.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

New Source Performance Standards (NSPS) [326 IAC 12] [40 CFR 60]

E.3.1 General Provisions Relating to NSPS [326 IAC 12-1] [40 CFR Part 60, Subpart A]

The provisions of 40 CFR Part 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the coal preparation system for Boiler 5 including the crushers and COAL Segment 2 except when otherwise specified in 40 CFR Part 60, Subpart Y.

E.3.2 Standards of Performance for Coal Preparation Plants [326 IAC 12] [40 CFR 60, Subpart Y]

Pursuant to 40 CFR 60, Subpart Y, the Permittee shall comply with the provisions of the Standards of Performance for Coal Preparation Plants (included as Attachment C of this permit), which are incorporated by reference as 326 IAC 12 for the coal preparation system for Boiler 5 including the crushers and COAL Segment 2 as specified as follows:

(1) 40 CFR 60.250
(2) 40 CFR 60.251
(3) 40 CFR 60.254
(4) 40 CFR 60.255
(5) 40 CFR 60.257
(6) 40 CFR 60.258

SECTION F Clean Air Interstate Rule (CAIR) Nitrogen Oxides Ozone Season Trading Programs – CAIR Permit for CAIR Units Under 326 IAC 24-3-1(a)

ORIS Code: 50240

CAIR Permit for CAIR Units Under 326 IAC 24-3-1(a)

(a) One (1) spreader stoker coal fired boiler, identified as Boiler 1, with installation completed in 1960, with a nominal capacity of 281 MMBtu/hr, with a multi-cyclone collector and an electrostatic precipitator for particulate matter control, exhausting to stack WADE 01. Boiler 1 has two (2) auxiliary natural gas fired burners rated at 35 MMBtu/hr per burner, used for ignition and flame stabilization periods. Boiler 1 has a continuous emissions monitoring system (CEMS) for nitrogen oxides (NO_X) and a continuous opacity monitor (COM).

(b) One (1) spreader stoker coal fired boiler, identified as Boiler 2, with installation completed in 1967, with a nominal capacity of 274 MMBtu/hr, with a multi-cyclone collector and a multi-compartment baghouse for particulate matter control, exhausting to stack WADE 02. Boiler 2 has two (2) auxiliary natural gas fired burners rated at 35 MMBtu/hr per burner, used for ignition and flame stabilization periods. Boiler 2 has a continuous emissions monitoring system (CEMS) for nitrogen oxides (NO_X) and a continuous opacity monitor (COM).

(c) One (1) natural gas and distillate fuel oil fired boiler, identified as Boiler 3, with installation started in 1973 or 1974 and completed in 1974, with a nominal capacity of 286 MMBtu/hr, exhausting to stack WADE 03. Boiler 3 has a continuous emissions monitoring system (CEMS) for nitrogen oxides (NO_X).

(d) One (1) circulating fluidized bed coal fired boiler, identified as Boiler 5, with installation started in 1989 and completed in 1991, with a nominal capacity of 279 MMBtu/hr, with a baghouse for particulate matter control and limestone injection for sulfur dioxide control, combusting natural gas for ignition, exhausting to stack WADE 05. Boiler 5 has continuous emissions monitoring systems (CEMS) for nitrogen oxides (NO_X) and sulfur dioxide (SO_2) and a continuous opacity monitor (COM).

(e) One (1) natural gas fired boiler, identified as Boiler 7, permitted in 2010, with a nominal capacity of 290 MMBtu/hr, exhausting to stack WADE 03. Boiler 7 has a continuous emissions monitoring system (CEMS) for nitrogen oxides (NO_X) for compliance with NSPS requirements.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

F.1 Automatic Incorporation of Definitions [326 IAC 24-3-7(e)] [40 CFR 97.323(b)]

This CAIR permit is deemed to incorporate automatically the definitions of terms under 326 IAC 24-3-2.

F.2 Standard Permit Requirements [326 IAC 24-3-4(a)] [40 CFR 97.306(a)]

(a) The owners and operators of each CAIR NO_X ozone season source and CAIR NO_X ozone season unit shall operate each source and unit in compliance with this CAIR permit.

(b) The CAIR NO_X ozone season units subject to this CAIR permit are Boiler 1, Boiler 2, Boiler 3, Boiler 5, and Boiler 7.

F.3 Monitoring, Reporting, and Record Keeping Requirements [326 IAC 24-3-4(b)] [40 CFR 97.306(b)]

(a) The owners and operators, and the CAIR designated representative, of each CAIR NO_X ozone season source and CAIR NO_X ozone season unit at the source shall comply with the applicable monitoring, reporting, and record keeping requirements of 326 IAC 24-3-11.

(b) The emissions measurements recorded and reported in accordance with 326 IAC 24-3-11 shall be used to determine compliance by each CAIR NO_X ozone season source with the CAIR NO_X ozone season emissions limitation under 326 IAC 24-3-4(c) and Condition F.4, Nitrogen Oxides Ozone Season Emission Requirements.

F.4 Nitrogen Oxides Ozone Season Emission Requirements [326 IAC 24-3-4(c)] [40 CFR 97.306(c)]

(a) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO_X ozone season source and each CAIR NO_X ozone season unit at the source shall hold, in the source's compliance account, CAIR NO_X ozone season allowances available for compliance deductions for the control period under 326 IAC 24-3-9(i) in an amount not less than the tons of total nitrogen oxides emissions for the control period from all CAIR NO_X ozone season units at the source, as determined in accordance with 326 IAC 24-3-11.

(b) A CAIR NO_X ozone season unit shall be subject to the requirements under 326 IAC 24-3-4(c)(1) for the control period starting on the applicable date, as determined under 326 IAC 24-3-4(c)(2), and for each control period thereafter.

(c) A CAIR NO_X ozone season allowance shall not be deducted for compliance with the requirements under 326 IAC 24-3-4(c)(1), for a control period in a calendar year before the year for which the CAIR NO_X ozone season allowance was allocated.

(d) CAIR NO_X ozone season allowances shall be held in, deducted from, or transferred into or among CAIR NO_X ozone season allowance tracking system accounts in accordance with 326 IAC 24-3-9, 326 IAC 24-3-10, and 326 IAC 24-3-12.

(e) A CAIR NO_X ozone season allowance is a limited authorization to emit one (1) ton of nitrogen oxides in accordance with the CAIR NO_X ozone season trading program. No provision of the CAIR NO_X ozone season trading program, the CAIR permit application, the CAIR permit, or an exemption under 326 IAC 24-3-3 and no provision of law shall be construed to limit the authority of the State of Indiana or the United States to terminate or limit the authorization.

(f) A CAIR NO_X ozone season allowance does not constitute a property right.

(g) Upon recordation by the U.S. EPA under 326 IAC 24-3-8, 326 IAC 24-3-9, 326 IAC 24-3-10, or 326 IAC 24-3-12, every allocation, transfer, or deduction of a CAIR NO_X ozone season allowance to or from a CAIR NO_X ozone season source's compliance account is incorporated automatically in this CAIR permit.

F.5 Excess Emissions Requirements [326 IAC 24-3-4(d)] [40 CFR 97.306(d)]

The owners and operators of a CAIR NO_X ozone season source and each CAIR NO_X ozone season unit that emits nitrogen oxides during any control period in excess of the CAIR NO_X ozone season emissions limitation shall do the following:

(a) Surrender the CAIR NO_X ozone season allowances required for deduction under 326 IAC 24-3-9(j)(4).

(b) Pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, the Clean Air Act (CAA) or applicable state law.

Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 326 IAC 24-3-4, the Clean Air Act (CAA), and applicable state law.

F.6 Record Keeping Requirements [326 IAC 24-3-4(e)] [326 IAC 2-7-5(3)] [40 CFR 97.306(e)]

Unless otherwise provided, the owners and operators of the CAIR NO_X ozone season source and each CAIR NO_X ozone season unit at the source shall keep on site at the source or at a central location within Indiana for those owners or operators with unattended sources, each of the following documents for a period of five (5) years from the date the document was created:

(a) The certificate of representation under 326 IAC 24-3-6(h) for the CAIR designated representative for the source and each CAIR NO_X ozone season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation. The certificate and documents shall be retained on site at the source or at a central location within Indiana for those owners or operators with unattended sources beyond such five (5) year period until such documents are superseded because of the submission of a new account certificate of representation under 326 IAC 24-3-6(h) changing the CAIR designated representative.

(b) All emissions monitoring information, in accordance with 326 IAC 24-3-11, provided that to the extent that 326 IAC 24-3-11 provides for a three (3) year period for record keeping, the three (3) year period shall apply.

(c) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_X ozone season trading program.

(d) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR NO_X ozone season trading program or to demonstrate compliance with the requirements of the CAIR NO_X ozone season trading program.

This period may be extended for cause, at any time before the end of five (5) years, in writing by IDEM, OAQ or the U.S. EPA. Section C - General Record Keeping Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.

F.7 Reporting Requirements [326 IAC 24-3-4(e)] [40 CFR 97.306(e)]

(a) The CAIR designated representative of the CAIR NO_X ozone season source and each CAIR NO_X ozone season unit at the source shall submit the reports required under the CAIR NO_X ozone season trading program, including those under 326 IAC 24-3-11.

(b) Pursuant to 326 IAC 24-3-4(e) and 326 IAC 24-3-6(e)(1), each submission under the CAIR NO_X ozone season trading program shall include the following certification statement by the CAIR designated representative: “I am authorized to make this submission on behalf of the owners and operators of the source or units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."

(c) Where 326 IAC 24-3 requires a submission to IDEM, OAQ, the information shall be submitted to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53, IGCN 1003
Indianapolis, Indiana 46204-2251

(d) Where 326 IAC 24-3 requires a submission to U.S. EPA, the information shall be submitted to:

U.S. Environmental Protection Agency
Clean Air Markets Division
1200 Pennsylvania Avenue, NW
Mail Code 6204N
Washington, DC 20460

F.8 Liability [326 IAC 24-3-4(f)] [40 CFR 97.306(f)]

The owners and operators of each CAIR NO_X ozone season source and each CAIR NO_X ozone season unit shall be liable as follows:

(a) Each CAIR NO_X ozone season source and each CAIR NO_X ozone season unit shall meet the requirements of the CAIR NO_X ozone season trading program.

(b) Any provision of the C CAIR NO_X ozone season trading program that applies to a CAIR NO_X ozone season source or the CAIR designated representative of a CAIR NO_X ozone season source shall also apply to the owners and operators of such source and of the CAIR NO_X ozone season units at the source.

(c) Any provision of the CAIR NO_X ozone season trading program that applies to a CAIR NO_X ozone season unit or the CAIR designated representative of a CAIR NO_X ozone season unit shall also apply to the owners and operators of such unit.

F.9 Effect on Other Authorities [326 IAC 24-3-4(g)] [40 CFR 97.306(g)]

No provision of the CAIR NO_X ozone season trading program, a CAIR permit application, a CAIR permit, or an exemption under 326 IAC 24-3-3 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO_X ozone season source or CAIR NO_X ozone season unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act (CAA).

F.10 CAIR Designated Representative and Alternate CAIR Designated Representative [326 IAC 24-3-6] [40 CFR 97, Subpart BBBB]

Pursuant to 326 IAC 24-3-6:

(a) Except as specified in 326 IAC 24-3-6(f)(3), each CAIR NO_X ozone season source, including all CAIR NO_X ozone season units at the source, shall have one (1) and only one (1) CAIR designated representative, with regard to all matters under the CAIR NO_X ozone season trading program concerning the source or any CAIR NO_X ozone season unit at the source.

(b) The provisions of 326 IAC 24-3-6(f) shall apply where the owners or operators of a CAIR NO_X ozone season source choose to designate an alternate CAIR designated representative.

Except as specified in 326 IAC 24-3-6(f)(3), whenever the term "CAIR designated representative" is used, the term shall be construed to include the CAIR designated representative or any alternate CAIR designated representative.

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY

PART 70 OPERATING PERMIT
CERTIFICATION

Source Name:	Purdue University
Source Address:	401 S. Grant Street, Freehafer Hall of Administrative Services,West Lafayette, Indiana, 47907-2024
Part 70 Permit Renewal No.:	T 157-27313-00012

This certification shall be included when submitting monitoring, testing reports/results or other documents as required by this permit.

Please check what document is being certified:

☐ Annual Compliance Certification Letter

☐ Test Result (specify): _____

☐ Report (specify): _____

☐ Notification (specify): _____

☐ Affidavit (specify): _____

☐ Other (specify): _____

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. Signature:
Printed Name:
Title/Position:
Phone:
Date:

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH

100 North Senate Avenue
MC 61-53, IGCN 1003
Indianapolis, Indiana 46204-2251
Phone: 317-233-0178
Fax: 317-233-6865

PART 70 OPERATING PERMIT
EMERGENCY OCCURRENCE REPORT

Source Name:	Purdue University
Source Address:	401 S. Grant Street, Freehafer Hall of Administrative Services,West Lafayette, Indiana, 47907-2024
Part 70 Permit Renewal No.:	T 157-27313-00012

This form consists of 2 pages **Page 1 of 2**

☐ This is an emergency as defined in 326 IAC 2-7-1(12)
- The Permittee must notify the Office of Air Quality (OAQ), no later than four (**4**) daytime business hours (1-800-451-6027 or 317-233-0178, ask for Compliance and Enforcement Branch); and
- The Permittee must submit notice in writing or by facsimile no later than two (**2**) days (Facsimile Number: 317-233-6865), and follow the other requirements of 326 IAC 2-7-16.

If any of the following are not applicable, mark N/A

Facility/Equipment/Operation:
Control Equipment:
Permit Condition or Operation Limitation in Permit:
Description of the Emergency
Describe the cause of the Emergency

If any of the following are not applicable, mark N/A **Page 2 of 2**

Date/Time Emergency started:
Date/Time Emergency was corrected:
Was the facility being properly operated at the time of the emergency? ☐ Y ☐ N Describe: Type of Pollutants Emitted: ☐ TSP ☐ PM-10 ☐ SO_2 ☐ VOC ☐ NO_X ☐ CO ☐ Pb ☐ other:
Estimated amount of pollutant(s) emitted during emergency:
Describe the steps taken to mitigate the problem:
Describe the corrective actions/response steps taken:
Describe the measures taken to minimize emissions:
If applicable, describe the reasons why continued operation of the facilities are necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw materials of substantial economic value:

Form Completed By: _____

Title/Position: _____

Date: _____

Phone: _____

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH

Boiler 1 and Boiler 2 Natural Gas Usage - Part 70 Quarterly Report

Source Name: Purdue University
Emission Unit Location: Purdue University, Wade Utility Plant, West Lafayette, Indiana, 47907-2024
Part 70 Permit Renewal No.: T 157-27313-00012
Facility: Boiler 1 and Boiler 2 - natural gas-fired burners
Parameter: natural gas usage
Limit: not more than 395 MMCF per 12 consecutive month period with compliance determined at the end of each month.

YEAR: _____

Month	Natural Gas Usage for This Month (MMCF)	Natural Gas Usage for Previous 11 Months (MMCF)	Natural Gas Usage for 12-Month Period (MMCF)

☐ No deviation occurred in this quarter.

☐ Deviations occurred in this quarter.
Deviation has been reported on: _____

Submitted By: _____

Title/Position: _____

Signature: _____

Date: _____

Phone: _____

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH

Fuel Oil-Fired Electric Generator (BSG) - Part 70 Quarterly Report

Source Name: Purdue University
Emission Unit Location: Purdue University, Wade Utility Plant, West Lafayette, Indiana, 47907-2024
Part 70 Permit Renewal No.: T 157-27313-00012
Facility: 17.7 MMBtu/hr electric generator, BSG
Parameter: no. 2 fuel oil usage
Limit: less than 113,000 gallons per 12 consecutive month period

YEAR: _____

Month	No. 2 Fuel Oil Usage for This Month (gallons)	No. 2 Fuel Oil Usage for Previous 11 Months (gallons)	No. 2 Fuel Oil Usage for 12-Month Period (gallons)

☐ No deviation occurred in this quarter.

☐ Deviations occurred in this quarter.
Deviation has been reported on: _____

Submitted By: _____

Title/Position: _____

Signature: _____

Date: _____

Phone: _____

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH

Boiler 3 Fuel Usage Limit - Part 70 Quarterly Report

Source Name: Purdue University
Emission Unit Location: Purdue University, Wade Utility Plant, West Lafayette, Indiana, 47907-2024
Part 70 Permit Renewal No.: T 157-27313-00012
Facility: 286 MMBtu/hr Boiler (Boiler 3)
Parameter: distillate fuel oil usage (opacity)
Limit: The usage of distillate fuel oil in Boiler 3 shall be limited to 500,000 U.S. gallons per twelve (12) consecutive month period, with compliance determined at the end of each month.

YEAR: _____

Month	Distillate Fuel Oil Usage for This Month (gallons)	Distillate Fuel Oil Usage for Previous 11 Months (gallons)	Distillate Fuel Oil Usage for 12-Month Period (gallons)

☐ No deviation occurred in this quarter.

☐ Deviations occurred in this quarter.
Deviation has been reported on: _____

Submitted By: _____

Title/Position: _____

Signature: _____

Date: _____

Phone: _____

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH

PART 70 OPERATING PERMIT
QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT

Source Name: Purdue University
Source Address: 401 S. Grant Street, Freehafer Hall of Administrative Services,West Lafayette, Indiana, 47907-2024
Part 70 Permit Renewal No.: T 157-27313-00012

Months: _____ **to** _____ **Year:** _____

Page 1 of 2

This report shall be submitted quarterly based on a calendar year. Any deviation from the requirements of this permit, the date(s) of each deviation, the probable cause of the deviation, and the response steps taken must be reported. A deviation required to be reported pursuant to an applicable requirement that exists independent of the permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. Additional pages may be attached if necessary. If no deviations occurred, please specify in the box marked “No deviations occurred this reporting period”.
☐ NO DEVIATIONS OCCURRED THIS REPORTING PERIOD.
☐ THE FOLLOWING DEVIATIONS OCCURRED THIS REPORTING PERIOD
Permit Requirement (specify permit condition #)
Date of Deviation: **Duration of Deviation:**
Number of Deviations:
Probable Cause of Deviation:
Response Steps Taken:
Permit Requirement (specify permit condition #)
Date of Deviation: **Duration of Deviation:**
Number of Deviations:
Probable Cause of Deviation:
Response Steps Taken:

Permit Requirement (specify permit condition #)	
Date of Deviation:	**Duration of Deviation:**
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	**Duration of Deviation:**
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	
Permit Requirement (specify permit condition #)	
Date of Deviation:	**Duration of Deviation:**
Number of Deviations:	
Probable Cause of Deviation:	
Response Steps Taken:	

Form Completed By: _____

Title/Position: _____

Date: _____

Phone: _____

Attachment A – Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units [326 IAC 12] [40 CFR Part 60, Subpart Db]

Source Description and Location

Source Name:	Purdue University - West Lafayette
Source Location:	401 S. Grant St., Freehafer Hall of Administrative Services, West Lafayette, IN 47907
County:	Tippecanoe
SIC Code:	8221
Operation Permit Renewal No.:	T 157-27313-00012
Permit Reviewer:	Kimberly Cottrell

NSPS [40 CFR Part 60, Subpart Db]

Subpart Db—Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units

Source: 72 FR 32742, June 13, 2007, unless otherwise noted.

§ 60.40b Applicability and delegation of authority.

(a) The affected facility to which this subpart applies is each steam generating unit that commences construction, modification, or reconstruction after June 19, 1984, and that has a heat input capacity from fuels combusted in the steam generating unit of greater than 29 megawatts (MW) (100 million British thermal units per hour (MMBtu/hr)).

(b) Any affected facility meeting the applicability requirements under paragraph (a) of this section and commencing construction, modification, or reconstruction after June 19, 1984, but on or before June 19, 1986, is subject to the following standards:

(1) Coal-fired affected facilities having a heat input capacity between 29 and 73 MW (100 and 250 MMBtu/hr), inclusive, are subject to the particulate matter (PM) and nitrogen oxides (NO_X) standards under this subpart.

(2) Coal-fired affected facilities having a heat input capacity greater than 73 MW (250 MMBtu/hr) and meeting the applicability requirements under subpart D (Standards of performance for fossil-fuel-fired steam generators; §60.40) are subject to the PM and NO_X standards under this subpart and to the sulfur dioxide (SO_2) standards under subpart D (§60.43).

(3) Oil-fired affected facilities having a heat input capacity between 29 and 73 MW (100 and 250 MMBtu/hr), inclusive, are subject to the NO_X standards under this subpart.

(4) Oil-fired affected facilities having a heat input capacity greater than 73 MW (250 MMBtu/hr) and meeting the applicability requirements under subpart D (Standards of performance for fossil-fuel-fired steam generators; §60.40) are also subject to the NO_X standards under this subpart and the PM and SO_2standards under subpart D (§60.42 and §60.43).

(c) Affected facilities that also meet the applicability requirements under subpart J (Standards of performance for petroleum refineries; §60.104) are subject to the PM and NO_X standards under this subpart and the SO_2standards under subpart J (§60.104).

(d) Affected facilities that also meet the applicability requirements under subpart E (Standards of performance for incinerators; §60.50) are subject to the NO_X and PM standards under this subpart.

(e) Steam generating units meeting the applicability requirements under subpart Da (Standards of performance for electric utility steam generating units; §60.40Da) are not subject to this subpart.

(f) Any change to an existing steam generating unit for the sole purpose of combusting gases containing total reduced sulfur (TRS) as defined under §60.281 is not considered a modification under §60.14 and the steam generating unit is not subject to this subpart.

(g) In delegating implementation and enforcement authority to a State under section 111(c) of the Clean Air Act, the following authorities shall be retained by the Administrator and not transferred to a State.

(1) Section 60.44b(f).

(2) Section 60.44b(g).

(3) Section 60.49b(a)(4).

(h) Any affected facility that meets the applicability requirements and is subject to subpart Ea, subpart Eb, or subpart AAAA of this part is not covered by this subpart.

(i)

(i) Heat recovery steam generators that are associated with combined cycle gas turbines and that meet the applicability requirements of subpart KKKK of this part are not subject to this subpart. This subpart will continue to apply to all other heat recovery steam generators that are capable of combusting more than 29 MW (100 MMBtu/hr) heat input of fossil fuel. If the heat recovery steam generator is subject to this subpart, only emissions resulting from combustion of fuels in the steam generating unit are subject to this subpart. (The gas turbine emissions are subject to subpart GG or KKKK, as applicable, of this part.)

(j) Any affected facility meeting the applicability requirements under paragraph (a) of this section and commencing construction, modification, or reconstruction after June 19, 1986 is not subject to subpart D (Standards of Performance for Fossil-Fuel-Fired Steam Generators, §60.40).

(k) Any affected facility that meets the applicability requirements and is subject to an EPA approved State or Federal section 111(d)/129 plan implementing subpart Cb or subpart BBBB of this part is not covered by this subpart.

[72 FR 32742, June 13, 2007, as amended at 74 FR 5084, Jan. 28, 2009]

§ 60.41b Definitions.

As used in this subpart, all terms not defined herein shall have the meaning given them in the Clean Air Act and in subpart A of this part.

Annual capacity factor means the ratio between the actual heat input to a steam generating unit from the fuels listed in §60.42b(a), §60.43b(a), or §60.44b(a), as applicable, during a calendar year and the potential heat input to the steam generating unit had it been operated for 8,760 hours during a calendar year at the maximum steady state design heat input capacity. In the case of steam generating units that are rented or leased, the actual heat input shall be determined based on the combined heat input from all operations of the affected facility in a calendar year.

Byproduct/waste means any liquid or gaseous substance produced at chemical manufacturing plants, petroleum refineries, or pulp and paper mills (except natural gas, distillate oil, or residual oil) and combusted in a steam generating unit for heat recovery or for disposal. Gaseous substances with carbon dioxide (CO_2) levels greater than 50 percent or carbon monoxide levels greater than 10 percent are not byproduct/waste for the purpose of this subpart.

Chemical manufacturing plants mean industrial plants that are classified by the Department of Commerce under Standard Industrial Classification (SIC) Code 28.

Coal means all solid fuels classified as anthracite, bituminous, subbituminous, or lignite by the American Society of Testing and Materials in ASTM D388 (incorporated by reference, see §60.17), coal refuse, and petroleum coke. Coal-derived synthetic fuels, including but not limited to solvent refined coal, gasified coal not meeting the definition of natural gas, coal-oil mixtures, coke oven gas, and coal-water mixtures, are also included in this definition for the purposes of this subpart.

Coal refuse means any byproduct of coal mining or coal cleaning operations with an ash content greater than 50 percent, by weight, and a heating value less than 13,900 kJ/kg (6,000 Btu/lb) on a dry basis.

Cogeneration , also known as combined heat and power, means a facility that simultaneously produces both electric (or mechanical) and useful thermal energy from the same primary energy source.

Coke oven gas means the volatile constituents generated in the gaseous exhaust during the carbonization of bituminous coal to form coke.

Combined cycle system means a system in which a separate source, such as a gas turbine, internal combustion engine, kiln, etc., provides exhaust gas to a steam generating unit.

Conventional technology means wet flue gas desulfurization (FGD) technology, dry FGD technology, atmospheric fluidized bed combustion technology, and oil hydrodesulfurization technology.

Distillate oil means fuel oils that contain 0.05 weight percent nitrogen or less and comply with the specifications for fuel oil numbers 1 and 2, as defined by the American Society of Testing and Materials in ASTM D396 (incorporated by reference, see §60.17) or diesel fuel oil numbers 1 and 2, as defined by the American Society for Testing and Materials in ASTM D975 (incorporated by reference, see §60.17).

Dry flue gas desulfurization technology means a SO_2control system that is located downstream of the steam generating unit and removes sulfur oxides from the combustion gases of the steam generating unit by contacting the combustion gases with an alkaline reagent and water, whether introduced separately or as a premixed slurry or solution and forming a dry powder material. This definition includes devices where the dry powder material is subsequently converted to another form. Alkaline slurries or solutions used in dry flue gas desulfurization technology include but are not limited to lime and sodium.

Duct burner means a device that combusts fuel and that is placed in the exhaust duct from another source, such as a stationary gas turbine, internal combustion engine, kiln, etc., to allow the firing of additional fuel to heat the exhaust gases before the exhaust gases enter a steam generating unit.

Emerging technology means any SO_2control system that is not defined as a conventional technology under this section, and for which the owner or operator of the facility has applied to the Administrator and received approval to operate as an emerging technology under §60.49b(a)(4).

Federally enforceable means all limitations and conditions that are enforceable by the Administrator, including the requirements of 40 CFR parts 60 and 61, requirements within any applicable State Implementation Plan, and any permit requirements established under 40 CFR 52.21 or under 40 CFR 51.18 and 51.24.

Fluidized bed combustion technology means combustion of fuel in a bed or series of beds (including but not limited to bubbling bed units and circulating bed units) of limestone aggregate (or other sorbent materials) in which these materials are forced upward by the flow of combustion air and the gaseous products of combustion.

Fuel pretreatment means a process that removes a portion of the sulfur in a fuel before combustion of the fuel in a steam generating unit.

Full capacity means operation of the steam generating unit at 90 percent or more of the maximum steady-state design heat input capacity.

Gaseous fuel means any fuel that is a gas at ISO conditions. This includes, but is not limited to, natural gas and gasified coal (including coke oven gas).

Gross output means the gross useful work performed by the steam generated. For units generating only electricity, the gross useful work performed is the gross electrical output from the turbine/generator set. For cogeneration units, the gross useful work performed is the gross electrical or mechanical output plus 75 percent of the useful thermal output measured relative to ISO conditions that is not used to generate additional electrical or mechanical output or to enhance the performance of the unit (*i.e.* , steam delivered to an industrial process).

Heat input means heat derived from combustion of fuel in a steam generating unit and does not include the heat derived from preheated combustion air, recirculated flue gases, or exhaust gases from other sources, such as gas turbines, internal combustion engines, kilns, etc.

Heat release rate means the steam generating unit design heat input capacity (in MW or Btu/hr) divided by the furnace volume (in cubic meters or cubic feet); the furnace volume is that volume bounded by the front furnace wall where the burner is located, the furnace side waterwall, and extending to the level just below or in front of the first row of convection pass tubes.

Heat transfer medium means any material that is used to transfer heat from one point to another point.

High heat release rate means a heat release rate greater than 730,000 J/sec-m^3 (70,000 Btu/hr-ft^3).

ISO Conditions means a temperature of 288 Kelvin, a relative humidity of 60 percent, and a pressure of 101.3 kilopascals.

Lignite means a type of coal classified as lignite A or lignite B by the American Society of Testing and Materials in ASTM D388 (incorporated by reference, see §60.17).

Low heat release rate means a heat release rate of 730,000 J/sec-m^3 (70,000 Btu/hr-ft^3) or less.

Mass-feed stoker steam generating unit means a steam generating unit where solid fuel is introduced directly into a retort or is fed directly onto a grate where it is combusted.

Maximum heat input capacity means the ability of a steam generating unit to combust a stated maximum amount of fuel on a steady state basis, as determined by the physical design and characteristics of the steam generating unit.

Municipal-type solid waste means refuse, more than 50 percent of which is waste consisting of a mixture of paper, wood, yard wastes, food wastes, plastics, leather, rubber, and other combustible materials, and noncombustible materials such as glass and rock.

Natural gas means:

(1) A naturally occurring mixture of hydrocarbon and nonhydrocarbon gases found in geologic formations beneath the earth's surface, of which the principal constituent is methane; or

(2) Liquefied petroleum gas, as defined by the American Society for Testing and Materials in ASTM D1835 (incorporated by reference, see §60.17); or

(3) A mixture of hydrocarbons that maintains a gaseous state at ISO conditions. Additionally, natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 34 and 43 megajoules (MJ) per dry standard cubic meter (910 and 1,150 Btu per dry standard cubic foot).

Noncontinental area means the State of Hawaii, the Virgin Islands, Guam, American Samoa, the Commonwealth of Puerto Rico, or the Northern Mariana Islands.

Oil means crude oil or petroleum or a liquid fuel derived from crude oil or petroleum, including distillate and residual oil.

Petroleum refinery means industrial plants as classified by the Department of Commerce under Standard Industrial Classification (SIC) Code 29.

Potential sulfur dioxide emission rate means the theoretical SO_2emissions (nanograms per joule (ng/J) or lb/MMBtu heat input) that would result from combusting fuel in an uncleaned state and without using emission control systems. For gasified coal or oil that is desulfurized prior to combustion, the *Potential sulfur dioxide emission rate* is the theoretical SO_2emissions (ng/J or lb/MMBtu heat input) that would result from combusting fuel in a cleaned state without using any post combustion emission control systems.

Process heater means a device that is primarily used to heat a material to initiate or promote a chemical reaction in which the material participates as a reactant or catalyst.

Pulp and paper mills means industrial plants that are classified by the Department of Commerce under North American Industry Classification System (NAICS) Code 322 or Standard Industrial Classification (SIC) Code 26.

Pulverized coal-fired steam generating unit means a steam generating unit in which pulverized coal is introduced into an air stream that carries the coal to the combustion chamber of the steam generating unit where it is fired in suspension. This includes both conventional pulverized coal-fired and micropulverized coal-fired steam generating units. Residual oil means crude oil, fuel oil numbers 1 and 2 that have a nitrogen content greater than 0.05 weight percent, and all fuel oil numbers 4, 5 and 6, as defined by the American Society of Testing and Materials in ASTM D396 (incorporated by reference, see §60.17).

Spreader stoker steam generating unit means a steam generating unit in which solid fuel is introduced to the combustion zone by a mechanism that throws the fuel onto a grate from above. Combustion takes place both in suspension and on the grate.

Steam generating unit means a device that combusts any fuel or byproduct/waste and produces steam or heats water or heats any heat transfer medium. This term includes any municipal-type solid waste incinerator with a heat recovery steam generating unit or any steam generating unit that combusts fuel and is part of a cogeneration system or a combined cycle system. This term does not include process heaters as they are defined in this subpart.

Steam generating unit operating day means a 24-hour period between 12:00 midnight and the following midnight during which any fuel is combusted at any time in the steam generating unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period.

Very low sulfur oil means for units constructed, reconstructed, or modified on or before February 28, 2005, oil that contains no more than 0.5 weight percent sulfur or that, when combusted without SO_2emission control, has a SO_2emission rate equal to or less than 215 ng/J (0.5 lb/MMBtu) heat input. For units constructed, reconstructed, or modified after February 28, 2005 and not located in a noncontinental area, *very low sulfur oil* means oil that contains no more than 0.30 weight percent sulfur or that, when combusted without SO_2emission control, has a SO_2emission rate equal to or less than 140 ng/J (0.32 lb/MMBtu) heat input. For units constructed, reconstructed, or modified after February 28, 2005 and located in a noncontinental area, *very low sulfur oil* means oil that contains no more than 0.5 weight percent sulfur or that, when combusted without SO_2emission control, has a SO_2emission rate equal to or less than 215 ng/J (0.50 lb/MMBtu) heat input.

Wet flue gas desulfurization technology means a SO_2control system that is located downstream of the steam generating unit and removes sulfur oxides from the combustion gases of the steam generating unit by contacting the combustion gas with an alkaline slurry or solution and forming a liquid material. This definition applies to devices where the aqueous liquid material product of this contact is subsequently converted to other forms. Alkaline reagents used in wet flue gas desulfurization technology include, but are not limited to, lime, limestone, and sodium.

Wet scrubber system means any emission control device that mixes an aqueous stream or slurry with the exhaust gases from a steam generating unit to control emissions of PM or SO_2.

Wood means wood, wood residue, bark, or any derivative fuel or residue thereof, in any form, including, but not limited to, sawdust, sanderdust, wood chips, scraps, slabs, millings, shavings, and processed pellets made from wood or other forest residues.

[72 FR 32742, June 13, 2007, as amended at 74 FR 5084, Jan. 28, 2009]

§ 60.42b Standard for sulfur dioxide (SO2).

(a) Except as provided in paragraphs (b), (c), (d), or (j) of this section, on and after the date on which the performance test is completed or required to be completed under §60.8, whichever comes first, no owner or operator of an affected facility that commenced construction, reconstruction, or modification on or before February 28, 2005, that combusts coal or oil shall cause to be discharged into the atmosphere any gases that contain SO_2in excess of 87 ng/J (0.20 lb/MMBtu) or 10 percent (0.10) of the potential SO_2emission rate (90 percent reduction) and the emission limit determined according to the following formula:

$$E_s = \frac{(K_a H_a + K_b H_b)}{(H_a + H_b)}$$

Where:

E_s= SO_2emission limit, in ng/J or lb/MMBtu heat input;

K_a= 520 ng/J (or 1.2 lb/MMBtu);

K_b= 340 ng/J (or 0.80 lb/MMBtu);

H_a= Heat input from the combustion of coal, in J (MMBtu); and

H_b= Heat input from the combustion of oil, in J (MMBtu).

For facilities complying with the percent reduction standard, only the heat input supplied to the affected facility from the combustion of coal and oil is counted in this paragraph. No credit is provided for the heat input to the affected facility from the combustion of natural gas, wood, municipal-type solid waste, or other fuels or heat derived from exhaust gases from other sources, such as gas turbines, internal combustion engines, kilns, etc.

(b) On and after the date on which the performance test is completed or required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that commenced construction, reconstruction, or modification on or before February 28, 2005, that combusts coal refuse alone in a fluidized bed combustion steam generating unit shall cause to be discharged into the atmosphere any gases that contain SO_2in excess of 87 ng/J (0.20 lb/MMBtu) or 20 percent (0.20) of the potential SO_2emission rate (80 percent reduction) and 520 ng/J (1.2 lb/MMBtu) heat input. If coal or oil is fired with coal refuse, the affected facility is subject to paragraph (a) or (d) of this section, as applicable. For facilities complying with the percent reduction standard, only the heat input supplied to the affected facility from the combustion of coal and oil is counted in this paragraph. No credit is provided for the heat input to the affected facility from the combustion of natural gas, wood, municipal-type solid waste, or other fuels or heat derived from exhaust gases from other sources, such as gas turbines, internal combustion engines, kilns, etc.

(c) On and after the date on which the performance test is completed or is required to be completed under §60.8, whichever comes first, no owner or operator of an affected facility that combusts coal or oil, either alone or in combination with any other fuel, and that uses an emerging technology for the control of SO_2emissions, shall cause to be discharged into the atmosphere any gases that contain SO_2in excess of 50 percent of the potential SO_2emission rate (50 percent reduction) and that contain SO_2in excess of the emission limit determined according to the following formula:

$$E_s = \frac{(K_c H_c + K_d H_d)}{(H_c + H_d)}$$

Where:

E_s= SO2 emission limit, in ng/J or lb/MM Btu heat input;

K_c= 260 ng/J (or 0.60 lb/MMBtu);

K_d= 170 ng/J (or 0.40 lb/MMBtu);

H_c= Heat input from the combustion of coal, in J (MMBtu); and

H_d= Heat input from the combustion of oil, in J (MMBtu).

For facilities complying with the percent reduction standard, only the heat input supplied to the affected facility from the combustion of coal and oil is counted in this paragraph. No credit is provided for the heat input to the affected facility from the combustion of natural gas, wood, municipal-type solid waste, or other fuels, or from the heat input derived from exhaust gases from other sources, such as gas turbines, internal combustion engines, kilns, etc.

(d) On and after the date on which the performance test is completed or required to be completed under §60.8, whichever comes first, no owner or operator of an affected facility that commenced construction, reconstruction, or modification on or before February 28, 2005 and listed in paragraphs (d)(1), (2), (3), or (4) of this section shall cause to be discharged into the atmosphere any gases that contain SO_2in excess of 520 ng/J (1.2 lb/MMBtu) heat input if the affected facility combusts coal, or 215 ng/J (0.5 lb/MMBtu) heat input if the affected facility combusts oil other than very low sulfur oil. Percent reduction requirements are not applicable to affected facilities under paragraphs (d)(1), (2), (3) or (4) of this section. For facilities complying with paragraphs (d)(1), (2), or (3) of this section, only the heat input supplied to the affected facility from the combustion of coal and oil is counted in this paragraph. No credit is provided for the heat input to the affected facility from the combustion of natural gas, wood, municipal-type solid waste, or other fuels or heat derived from exhaust gases from other sources, such as gas turbines, internal combustion engines, kilns, etc.

(1) Affected facilities that have an annual capacity factor for coal and oil of 30 percent (0.30) or less and are subject to a federally enforceable permit limiting the operation of the affected facility to an annual capacity factor for coal and oil of 30 percent (0.30) or less;

(2) Affected facilities located in a noncontinental area; or

(3) Affected facilities combusting coal or oil, alone or in combination with any fuel, in a duct burner as part of a combined cycle system where 30 percent (0.30) or less of the heat entering the steam generating unit is from combustion of coal and oil in the duct burner and 70 percent (0.70) or more of the heat entering the steam generating unit is from the exhaust gases entering the duct burner; or

(4) The affected facility burns coke oven gas alone or in combination with natural gas or very low sulfur distillate oil.

(e) Except as provided in paragraph (f) of this section, compliance with the emission limits, fuel oil sulfur limits, and/or percent reduction requirements under this section are determined on a 30-day rolling average basis.

(f) Except as provided in paragraph (j)(2) of this section, compliance with the emission limits or fuel oil sulfur limits under this section is determined on a 24-hour average basis for affected facilities that (1) have a federally enforceable permit limiting the annual capacity factor for oil to 10 percent or less, (2) combust only very low sulfur oil, and (3) do not combust any other fuel.

(g) Except as provided in paragraph (i) of this section and §60.45b(a), the SO_2emission limits and percent reduction requirements under this section apply at all times, including periods of startup, shutdown, and malfunction.

(h) Reductions in the potential SO_2emission rate through fuel pretreatment are not credited toward the percent reduction requirement under paragraph (c) of this section unless:

(1) Fuel pretreatment results in a 50 percent or greater reduction in potential SO_2emissions and

(2) Emissions from the pretreated fuel (without combustion or post-combustion SO_2control) are equal to or less than the emission limits specified in paragraph (c) of this section.

(i) An affected facility subject to paragraph (a), (b), or (c) of this section may combust very low sulfur oil or natural gas when the SO_2control system is not being operated because of malfunction or maintenance of the SO_2control system.

(j) Percent reduction requirements are not applicable to affected facilities combusting only very low sulfur oil. The owner or operator of an affected facility combusting very low sulfur oil shall demonstrate that the oil meets the definition of very low sulfur oil by: (1) Following the performance testing procedures as described in §60.45b(c) or §60.45b(d), and following the monitoring procedures as described in §60.47b(a) or §60.47b(b) to determine SO_2emission rate or fuel oil sulfur content; or (2) maintaining fuel records as described in §60.49b(r).

(k)(1) Except as provided in paragraphs (k)(2), (k)(3), and (k)(4) of this section, on and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that commences construction, reconstruction, or modification after February 28, 2005, and that combusts coal, oil, natural gas, a mixture of these fuels, or a mixture of these fuels with any other fuels shall cause to be discharged into the atmosphere any gases that contain SO_2in excess of 87 ng/J (0.20 lb/MMBtu) heat input or 8 percent (0.08) of the potential SO_2emission rate (92 percent reduction) and 520 ng/J (1.2 lb/MMBtu) heat input. For facilities complying with the percent reduction standard and paragraph (k)(3) of this section, only the heat input supplied to the affected facility from the combustion of coal and oil is counted in paragraph (k) of this section. No credit is provided for the heat input to the affected facility from the combustion of natural gas, wood, municipal-type solid waste, or other fuels or heat derived from exhaust gases from other sources, such as gas turbines, internal combustion engines, kilns, etc.

(2) Units firing only very low sulfur oil, gaseous fuel, a mixture of these fuels, or a mixture of these fuels with any other fuels with a potential SO_2emission rate of 140 ng/J (0.32 lb/MMBtu) heat input or less are exempt from the SO_2emissions limit in paragraph (k)(1) of this section.

(3) Units that are located in a noncontinental area and that combust coal, oil, or natural gas shall not discharge any gases that contain SO_2in excess of 520 ng/J (1.2 lb/MMBtu) heat input if the affected facility combusts coal, or 215 ng/J (0.50 lb/MMBtu) heat input if the affected facility combusts oil or natural gas.

[72 FR 32742, June 13, 2007, as amended at 74 FR 5084, Jan. 28, 2009]

§ 60.43b Standard for particulate matter (PM).

(a) On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever comes first, no owner or operator of an affected facility that commenced construction, reconstruction, or modification on or before February 28, 2005 that combusts coal or combusts mixtures of coal with other fuels, shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of the following emission limits:

(1) 22 ng/J (0.051 lb/MMBtu) heat input, (i) If the affected facility combusts only coal, or

(ii) If the affected facility combusts coal and other fuels and has an annual capacity factor for the other fuels of 10 percent (0.10) or less.

(2) 43 ng/J (0.10 lb/MMBtu) heat input if the affected facility combusts coal and other fuels and has an annual capacity factor for the other fuels greater than 10 percent (0.10) and is subject to a federally enforceable requirement limiting operation of the affected facility to an annual capacity factor greater than 10 percent (0.10) for fuels other than coal.

(3) 86 ng/J (0.20 lb/MMBtu) heat input if the affected facility combusts coal or coal and other fuels and

(i) Has an annual capacity factor for coal or coal and other fuels of 30 percent (0.30) or less,

(ii) Has a maximum heat input capacity of 73 MW (250 MMBtu/hr) or less,

(iii) Has a federally enforceable requirement limiting operation of the affected facility to an annual capacity factor of 30 percent (0.30) or less for coal or coal and other solid fuels, and

(iv) Construction of the affected facility commenced after June 19, 1984, and before November 25, 1986.

(4) An affected facility burning coke oven gas alone or in combination with other fuels not subject to a PM standard under §60.43b and not using a post-combustion technology (except a wet scrubber) for reducing PM or SO_2emissions is not subject to the PM limits under §60.43b(a).

(b) On and after the date on which the performance test is completed or required to be completed under §60.8, whichever comes first, no owner or operator of an affected facility that commenced construction, reconstruction, or modification on or before February 28, 2005, and that combusts oil (or mixtures of oil with other fuels) and uses a conventional or emerging technology to reduce SO_2emissions shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of 43 ng/J (0.10 lb/MMBtu) heat input.

(c) On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever comes first, no owner or operator of an affected facility that commenced construction, reconstruction, or modification on or before February 28, 2005, and that combusts wood, or wood with other fuels, except coal, shall cause to be discharged from that affected facility any gases that contain PM in excess of the following emission limits:

(1) 43 ng/J (0.10 lb/MMBtu) heat input if the affected facility has an annual capacity factor greater than 30 percent (0.30) for wood.

(2) 86 ng/J (0.20 lb/MMBtu) heat input if (i) The affected facility has an annual capacity factor of 30 percent (0.30) or less for wood;

(ii) Is subject to a federally enforceable requirement limiting operation of the affected facility to an annual capacity factor of 30 percent (0.30) or less for wood; and

(iii) Has a maximum heat input capacity of 73 MW (250 MMBtu/hr) or less.

(d) On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that combusts municipal-type solid waste or mixtures of municipal-type solid waste with other fuels, shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of the following emission limits:

(1) 43 ng/J (0.10 lb/MMBtu) heat input;

(i) If the affected facility combusts only municipal-type solid waste; or

(ii) If the affected facility combusts municipal-type solid waste and other fuels and has an annual capacity factor for the other fuels of 10 percent (0.10) or less.

(2) 86 ng/J (0.20 lb/MMBtu) heat input if the affected facility combusts municipal-type solid waste or municipal-type solid waste and other fuels; and

(i) Has an annual capacity factor for municipal-type solid waste and other fuels of 30 percent (0.30) or less;

(ii) Has a maximum heat input capacity of 73 MW (250 MMBtu/hr) or less;

(iii) Has a federally enforceable requirement limiting operation of the affected facility to an annual capacity factor of 30 percent (0.30) or less for municipal-type solid waste, or municipal-type solid waste and other fuels; and

(iv) Construction of the affected facility commenced after June 19, 1984, but on or before November 25, 1986.

(e) For the purposes of this section, the annual capacity factor is determined by dividing the actual heat input to the steam generating unit during the calendar year from the combustion of coal, wood, or municipal-type solid waste, and other fuels, as applicable, by the potential heat input to the steam generating unit if the steam generating unit had been operated for 8,760 hours at the maximum heat input capacity.

(f) On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that can combust coal, oil, wood, or mixtures of these fuels with any other fuels shall cause to be discharged into the atmosphere any gases that exhibit greater than 20 percent opacity (6-minute average), except for one 6-minute period per hour of not more than 27 percent opacity. Owners and operators of an affected facility that elect to install, calibrate, maintain, and operate a continuous emissions monitoring system (CEMS) for measuring PM emissions according to the requirements of this subpart and are subject to a federally enforceable PM limit of 0.030 lb/MMBtu or less are exempt from the opacity standard specified in this paragraph.

(g) The PM and opacity standards apply at all times, except during periods of startup, shutdown, or malfunction.

(h)(1) Except as provided in paragraphs (h)(2), (h)(3), (h)(4), (h)(5), and (h)(6) of this section, on and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that commenced construction, reconstruction, or modification after February 28, 2005, and that combusts coal, oil, wood, a mixture of these fuels, or a mixture of these fuels with any other fuels shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of 13 ng/J (0.030 lb/MMBtu) heat input,

(2) As an alternative to meeting the requirements of paragraph (h)(1) of this section, the owner or operator of an affected facility for which modification commenced after February 28, 2005, may elect to meet the requirements of this paragraph. On and after the date on which the initial performance test is completed or required to be completed under §60.8, no owner or operator of an affected facility that commences modification after February 28, 2005 shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of both:

(i) 22 ng/J (0.051 lb/MMBtu) heat input derived from the combustion of coal, oil, wood, a mixture of these fuels, or a mixture of these fuels with any other fuels; and

(ii) 0.2 percent of the combustion concentration (99.8 percent reduction) when combusting coal, oil, wood, a mixture of these fuels, or a mixture of these fuels with any other fuels.

(3) On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that commences modification after February 28, 2005, and that combusts over 30 percent wood (by heat input) on an annual basis and has a maximum heat input capacity of 73 MW (250 MMBtu/h) or less shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of 43 ng/J (0.10 lb/MMBtu) heat input.

(4) On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that commences modification after February 28, 2005, and that combusts over 30 percent wood (by heat input) on an annual basis and has a maximum heat input capacity greater than 73 MW (250 MMBtu/h) shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of 37 ng/J (0.085 lb/MMBtu) heat input.

(5) On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, an owner or operator of an affected facility not located in a noncontinental area that commences construction, reconstruction, or modification after February 28, 2005, and that combusts only oil that contains no more than 0.30 weight percent sulfur, coke oven gas, a mixture of these fuels, or either fuel (or a mixture of these fuels) in combination with other fuels not subject to a PM standard in §60.43b and not using a post-combustion technology (except a wet scrubber) to reduce SO_2or PM emissions is not subject to the PM limits in (h)(1) of this section.

(6) On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, an owner or operator of an affected facility located in a noncontinental area that commences construction, reconstruction, or modification after February 28, 2005, and that combusts only oil that contains no more than 0.5 weight percent sulfur, coke oven gas, a mixture of these fuels, or either fuel (or a mixture of these fuels) in combination with other fuels not subject to a PM standard in §60.43b and not using a post-combustion technology (except a wet scrubber) to reduce SO_2or PM emissions is not subject to the PM limits in (h)(1) of this section.

[72 FR 32742, June 13, 2007, as amended at 74 FR 5084, Jan. 28, 2009]

§ 60.44b Standard for nitrogen oxides (NOX).

(a) Except as provided under paragraphs (k) and (l) of this section, on and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that is subject to the provisions of this section and that combusts only coal, oil, or natural gas shall cause to be discharged into the atmosphere from that affected facility any gases that contain NO_X (expressed as NO_2) in excess of the following emission limits:

Fuel/steam generating unit type	Nitrogen oxide emission limits (expressed as NO_2) heat input	
	ng/J	lb/MMBTu
(1) Natural gas and distillate oil, except (4):		
(i) Low heat release rate	43	0.10
(ii) High heat release rate	86	0.20
(2) Residual oil:		
(i) Low heat release rate	130	0.30
(ii) High heat release rate	170	0.40
(3) Coal:		
(i) Mass-feed stoker	210	0.50
(ii) Spreader stoker and fluidized bed combustion	260	0.60
(iii) Pulverized coal	300	0.70
(iv) Lignite, except (v)	260	0.60
(v) Lignite mined in North Dakota, South Dakota, or Montana and combusted in a slag tap furnace	340	0.80
(vi) Coal-derived synthetic fuels	210	0.50
(4) Duct burner used in a combined cycle system:		
(i) Natural gas and distillate oil	86	0.20
(ii) Residual oil	170	0.40

(b) Except as provided under paragraphs (k) and (l) of this section, on and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that simultaneously combusts mixtures of coal, oil, or natural gas shall cause to be discharged into the atmosphere from that affected facility any gases that contain NO_X in excess of a limit determined by the use of the following formula:

$$E_n = \frac{(EL_{go}H_{go}) + (EL_{ro}H_{ro}) + (EL_cH_c)}{(H_{go} + H_{ro} + H_c)}$$

Where:

E_n= NO_X emission limit (expressed as NO_2), ng/J (lb/MMBtu);

EL_{go}= Appropriate emission limit from paragraph (a)(1) for combustion of natural gas or distillate oil, ng/J (lb/MMBtu);

H_{go}= Heat input from combustion of natural gas or distillate oil, J (MMBtu);

EL_{ro}= Appropriate emission limit from paragraph (a)(2) for combustion of residual oil, ng/J (lb/MMBtu);

H_{ro}= Heat input from combustion of residual oil, J (MMBtu);

EL_c= Appropriate emission limit from paragraph (a)(3) for combustion of coal, ng/J (lb/MMBtu); and

H_c= Heat input from combustion of coal, J (MMBtu).

(c) Except as provided under paragraph (l) of this section, on and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that simultaneously combusts coal or oil, or a mixture of these fuels with natural gas, and wood, municipal-type solid waste, or any other fuel shall cause to be discharged into the atmosphere any gases that contain NO_X in excess of the emission limit for the coal or oil, or mixtures of these fuels with natural gas combusted in the affected facility, as determined pursuant to paragraph (a) or (b) of this section, unless the affected facility has an annual capacity factor for coal or oil, or mixture of these fuels with natural gas of 10 percent (0.10) or less and is subject to a federally enforceable requirement that limits operation of the affected facility to an annual capacity factor of 10 percent (0.10) or less for coal, oil, or a mixture of these fuels with natural gas.

(d) On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that simultaneously combusts natural gas with wood, municipal-type solid waste, or other solid fuel, except coal, shall cause to be discharged into the atmosphere from that affected facility any gases that contain NO_X in excess of 130 ng/J (0.30 lb/MMBtu) heat input unless the affected facility has an annual capacity factor for natural gas of 10 percent (0.10) or less and is subject to a federally enforceable requirement that limits operation of the affected facility to an annual capacity factor of 10 percent (0.10) or less for natural gas.

(e) Except as provided under paragraph (l) of this section, on and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that simultaneously combusts coal, oil, or natural gas with byproduct/waste shall cause to be discharged into the atmosphere any gases that contain NO_X in excess of the emission limit determined by the following formula unless the affected facility has an annual capacity factor for coal, oil, and natural gas of 10 percent (0.10) or less and is subject to a federally enforceable requirement that limits operation of the affected facility to an annual capacity factor of 10 percent (0.10) or less:

$$E_n = \frac{(EL_{go}H_{go}) + (EL_{ro}H_{ro}) + (EL_cH_c)}{(H_{go} + H_{ro} + H_c)}$$

Where:

E_n= NO_X emission limit (expressed as NO_2), ng/J (lb/MMBtu);

EL_{go}= Appropriate emission limit from paragraph (a)(1) for combustion of natural gas or distillate oil, ng/J (lb/MMBtu);

H_{go}= Heat input from combustion of natural gas, distillate oil and gaseous byproduct/waste, J (MMBtu);

EL_{ro}= Appropriate emission limit from paragraph (a)(2) for combustion of residual oil and/or byproduct/waste, ng/J (lb/MMBtu);

H_{ro}= Heat input from combustion of residual oil, J (MMBtu);

EL_c= Appropriate emission limit from paragraph (a)(3) for combustion of coal, ng/J (lb/MMBtu); and

H_c= Heat input from combustion of coal, J (MMBtu).

(f) Any owner or operator of an affected facility that combusts byproduct/waste with either natural gas or oil may petition the Administrator within 180 days of the initial startup of the affected facility to establish a NO_X emission limit that shall apply specifically to that affected facility when the byproduct/waste is combusted. The petition shall include sufficient and appropriate data, as determined by the Administrator, such as NO_X emissions from the affected facility, waste composition (including nitrogen content), and combustion conditions to allow the Administrator to confirm that the affected facility is unable to comply with the emission limits in paragraph (e) of this section and to determine the appropriate emission limit for the affected facility.

(1) Any owner or operator of an affected facility petitioning for a facility-specific NO_X emission limit under this section shall:

(i) Demonstrate compliance with the emission limits for natural gas and distillate oil in paragraph (a)(1) of this section or for residual oil in paragraph (a)(2) or (l)(1) of this section, as appropriate, by conducting a 30-day performance test as provided in §60.46b(e). During the performance test only natural gas, distillate oil, or residual oil shall be combusted in the affected facility; and

(ii) Demonstrate that the affected facility is unable to comply with the emission limits for natural gas and distillate oil in paragraph (a)(1) of this section or for residual oil in paragraph (a)(2) or (l)(1) of this section, as appropriate, when gaseous or liquid byproduct/waste is combusted in the affected facility under the same conditions and using the same technological system of emission reduction applied when demonstrating compliance under paragraph (f)(1)(i) of this section.

(2) The NO_X emission limits for natural gas or distillate oil in paragraph (a)(1) of this section or for residual oil in paragraph (a)(2) or (l)(1) of this section, as appropriate, shall be applicable to the affected facility until and unless the petition is approved by the Administrator. If the petition is approved by the Administrator, a facility-specific NO_X emission limit will be established at the NO_X emission level achievable when the affected facility is combusting oil or natural gas and byproduct/waste in a manner that the Administrator determines to be consistent with minimizing NO_X emissions. In lieu of amending this subpart, a letter will be sent to the facility describing the facility-specific NO_X limit. The facility shall use the compliance procedures detailed in the letter and make the letter available to the public. If the Administrator determines it is appropriate, the conditions and requirements of the letter can be reviewed and changed at any point.

(g) Any owner or operator of an affected facility that combusts hazardous waste (as defined by 40 CFR part 261 or 40 CFR part 761) with natural gas or oil may petition the Administrator within 180 days of the initial startup of the affected facility for a waiver from compliance with the NO_X emission limit that applies specifically to that affected facility. The petition must include sufficient and appropriate data, as determined by the Administrator, on NO_X emissions from the affected facility, waste destruction efficiencies, waste composition (including nitrogen content), the quantity of specific wastes to be combusted and combustion conditions to allow the Administrator to determine if the affected facility is able to comply with the NO_X emission limits required by this section. The owner or operator of the affected facility shall demonstrate that when hazardous waste is combusted in the affected facility, thermal destruction efficiency requirements for hazardous waste specified in an applicable federally enforceable requirement preclude compliance with the NO_X emission limits of this section. The NO_X emission limits for natural gas or distillate oil in paragraph (a)(1) of this section or for residual oil in paragraph (a)(2) or (l)(1) of this section, as appropriate, are applicable to the affected facility until and unless the petition is approved by the Administrator. (See 40 CFR 761.70 for regulations applicable to the incineration of materials containing polychlorinated biphenyls (PCB's).) In lieu of amending this subpart, a letter will be sent to the facility describing the facility-specific NO_X limit. The facility shall use the compliance procedures detailed in the letter and make the letter available to the public. If the Administrator determines it is appropriate, the conditions and requirements of the letter can be reviewed and changed at any point.

(h) For purposes of paragraph (i) of this section, the NO_X standards under this section apply at all times including periods of startup, shutdown, or malfunction.

(i) Except as provided under paragraph (j) of this section, compliance with the emission limits under this section is determined on a 30-day rolling average basis.

(j) Compliance with the emission limits under this section is determined on a 24-hour average basis for the initial performance test and on a 3-hour average basis for subsequent performance tests for any affected facilities that:

(1) Combust, alone or in combination, only natural gas, distillate oil, or residual oil with a nitrogen content of 0.30 weight percent or less;

(2) Have a combined annual capacity factor of 10 percent or less for natural gas, distillate oil, and residual oil with a nitrogen content of 0.30 weight percent or less; and

(3) Are subject to a federally enforceable requirement limiting operation of the affected facility to the firing of natural gas, distillate oil, and/or residual oil with a nitrogen content of 0.30 weight percent or less and limiting operation of the affected facility to a combined annual capacity factor of 10 percent or less for natural gas, distillate oil, and residual oil with a nitrogen content of 0.30 weight percent or less.

(k) Affected facilities that meet the criteria described in paragraphs (j)(1), (2), and (3) of this section, and that have a heat input capacity of 73 MW (250 MMBtu/hr) or less, are not subject to the NO_X emission limits under this section.

(l) On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that commenced construction or reconstruction after July 9, 1997 shall cause to be discharged into the atmosphere from that affected facility any gases that contain NO_X (expressed as NO_2) in excess of the following limits:

(1) If the affected facility combusts coal, oil, natural gas, a mixture of these fuels, or a mixture of these fuels with any other fuels: A limit of 86 ng/J (0.20 lb/MMBtu) heat input unless the affected facility has an annual capacity factor for coal, oil, and natural gas of 10 percent (0.10) or less and is subject to a federally enforceable requirement that limits operation of the facility to an annual capacity factor of 10 percent (0.10) or less for coal, oil, and natural gas; or

(2) If the affected facility has a low heat release rate and combusts natural gas or distillate oil in excess of 30 percent of the heat input on a 30-day rolling average from the combustion of all fuels, a limit determined by use of the following formula:

$$E_n = \frac{(0.10 \times H_{gas}) + (0.20 \times H_I)}{(H_{gas} + H_I)}$$

Where:

E_n= NO_X emission limit, (lb/MMBtu);

H_{go}= 30-day heat input from combustion of natural gas or distillate oil; and

H_r= 30-day heat input from combustion of any other fuel.

(3) After February 27, 2006, units where more than 10 percent of total annual output is electrical or mechanical may comply with an optional limit of 270 ng/J (2.1 lb/MWh) gross energy output, based on a 30-day rolling average. Units complying with this output-based limit must demonstrate compliance according to the procedures of §60.48Da(i) of subpart Da of this part, and must monitor emissions according to §60.49Da(c), (k), through (n) of subpart Da of this part.

[72 FR 32742, June 13, 2007, as amended at 74 FR 5086, Jan. 28, 2009]

§ 60.45b Compliance and performance test methods and procedures for sulfur dioxide.

(a) The SO_2emission standards in §60.42b apply at all times. Facilities burning coke oven gas alone or in combination with any other gaseous fuels or distillate oil are allowed to exceed the limit 30 operating days per calendar year for SO_2control system maintenance.

(b) In conducting the performance tests required under §60.8, the owner or operator shall use the methods and procedures in appendix A (including fuel certification and sampling) of this part or the methods and procedures as specified in this section, except as provided in §60.8(b). Section 60.8(f) does not apply to this section. The 30-day notice required in §60.8(d) applies only to the initial performance test unless otherwise specified by the Administrator.

(c) The owner or operator of an affected facility shall conduct performance tests to determine compliance with the percent of potential SO_2emission rate (% P_s) and the SO_2emission rate (E_s) pursuant to §60.42b following the procedures listed below, except as provided under paragraph (d) and (k) of this section.

(1) The initial performance test shall be conducted over 30 consecutive operating days of the steam generating unit. Compliance with the SO_2standards shall be determined using a 30-day average. The first operating day included in the initial performance test shall be scheduled within 30 days after achieving the maximum production rate at which the affected facility will be operated, but not later than 180 days after initial startup of the facility.

(2) If only coal, only oil, or a mixture of coal and oil is combusted, the following procedures are used:

(i) The procedures in Method 19 of appendix A–7 of this part are used to determine the hourly SO_2emission rate (E_{ho}) and the 30-day average emission rate (E_{ao}). The hourly averages used to compute the 30-day averages are obtained from the CEMS of §60.47b(a) or (b).

(ii) The percent of potential SO_2emission rate (%P_s) emitted to the atmosphere is computed using the following formula:

$$\%P_s = 100\left(1 - \frac{\%R_g}{100}\right)\left(1 - \frac{\%R_f}{100}\right)$$

Where:

%P_s= Potential SO_2emission rate, percent;

%R_g= SO_2removal efficiency of the control device as determined by Method 19 of appendix A of this part, in percent; and

$\%R_f$= SO_2removal efficiency of fuel pretreatment as determined by Method 19 of appendix A of this part, in percent.

(3) If coal or oil is combusted with other fuels, the same procedures required in paragraph (c)(2) of this section are used, except as provided in the following:

(i) An adjusted hourly SO_2emission rate (E_{ho}^{o}) is used in Equation 19–19 of Method 19 of appendix A of this part to compute an adjusted 30-day average emission rate (E_{ao}^{o}). The Eho° is computed using the following formula:

$$E_{ho}^{o} = \frac{E_{ho} - E_{w}(1 - X_{k})}{X_{k}}$$

Where:

E_{ho}^{o} = Adjusted hourly SO_2emission rate, ng/J (lb/MMBtu);

E_{ho}= Hourly SO_2emission rate, ng/J (lb/MMBtu);

E_w= SO_2concentration in fuels other than coal and oil combusted in the affected facility, as determined by the fuel sampling and analysis procedures in Method 19 of appendix A of this part, ng/J (lb/MMBtu). The value $E_w$for each fuel lot is used for each hourly average during the time that the lot is being combusted; and

X_k= Fraction of total heat input from fuel combustion derived from coal, oil, or coal and oil, as determined by applicable procedures in Method 19 of appendix A of this part.

(ii) To compute the percent of potential SO_2emission rate ($\%P_s$), an adjusted $\%R_g$($\%R_g^{o}$) is computed from the adjusted E_{ao}^{o} from paragraph (b)(3)(i) of this section and an adjusted average SO_2inlet rate (E_{ai}^{o}) using the following formula:

$$\%R_g^{o} = 100\left(1.0 - \frac{E_{ao}^{o}}{E_{ai}^{o}}\right)$$

To compute E_{ai}^{o} , an adjusted hourly SO_2inlet rate (E_{hi}^{o}) is used. The E_{hi}^{o} is computed using the following formula:

$$E_{hi}^{o} = \frac{E_{hi} - E_{w}(1 - X_{k})}{X_{k}}$$

Where:

E_{hi}^{o} = Adjusted hourly SO_2inlet rate, ng/J (lb/MMBtu); and

E_{hi}= Hourly SO_2inlet rate, ng/J (lb/MMBtu).

(4) The owner or operator of an affected facility subject to paragraph (c)(3) of this section does not have to measure parameters $E_w$or $X_k$if the owner or operator elects to assume that X_k= 1.0. Owners or operators of affected facilities who assume X_k= 1.0 shall:

(i) Determine $\%P_s$following the procedures in paragraph (c)(2) of this section; and

(ii) Sulfur dioxide emissions (E_s) are considered to be in compliance with SO_2emission limits under §60.42b.

(5) The owner or operator of an affected facility that qualifies under the provisions of §60.42b(d) does not have to measure parameters E_w or X_k in paragraph (c)(3) of this section if the owner or operator of the affected facility elects to measure SO_2 emission rates of the coal or oil following the fuel sampling and analysis procedures in Method 19 of appendix A–7 of this part.

(d) Except as provided in paragraph (j) of this section, the owner or operator of an affected facility that combusts only very low sulfur oil, natural gas, or a mixture of these fuels, has an annual capacity factor for oil of 10 percent (0.10) or less, and is subject to a federally enforceable requirement limiting operation of the affected facility to an annual capacity factor for oil of 10 percent (0.10) or less shall:

(1) Conduct the initial performance test over 24 consecutive steam generating unit operating hours at full load;

(2) Determine compliance with the standards after the initial performance test based on the arithmetic average of the hourly emissions data during each steam generating unit operating day if a CEMS is used, or based on a daily average if Method 6B of appendix A of this part or fuel sampling and analysis procedures under Method 19 of appendix A of this part are used.

(e) The owner or operator of an affected facility subject to §60.42b(d)(1) shall demonstrate the maximum design capacity of the steam generating unit by operating the facility at maximum capacity for 24 hours. This demonstration will be made during the initial performance test and a subsequent demonstration may be requested at any other time. If the 24-hour average firing rate for the affected facility is less than the maximum design capacity provided by the manufacturer of the affected facility, the 24-hour average firing rate shall be used to determine the capacity utilization rate for the affected facility, otherwise the maximum design capacity provided by the manufacturer is used.

(f) For the initial performance test required under §60.8, compliance with the SO_2 emission limits and percent reduction requirements under §60.42b is based on the average emission rates and the average percent reduction for SO_2 for the first 30 consecutive steam generating unit operating days, except as provided under paragraph (d) of this section. The initial performance test is the only test for which at least 30 days prior notice is required unless otherwise specified by the Administrator. The initial performance test is to be scheduled so that the first steam generating unit operating day of the 30 successive steam generating unit operating days is completed within 30 days after achieving the maximum production rate at which the affected facility will be operated, but not later than 180 days after initial startup of the facility. The boiler load during the 30-day period does not have to be the maximum design load, but must be representative of future operating conditions and include at least one 24-hour period at full load.

(g) After the initial performance test required under §60.8, compliance with the SO_2 emission limits and percent reduction requirements under §60.42b is based on the average emission rates and the average percent reduction for SO_2 for 30 successive steam generating unit operating days, except as provided under paragraph (d). A separate performance test is completed at the end of each steam generating unit operating day after the initial performance test, and a new 30-day average emission rate and percent reduction for SO_2 are calculated to show compliance with the standard.

(h) Except as provided under paragraph (i) of this section, the owner or operator of an affected facility shall use all valid SO_2 emissions data in calculating $\%P_s$ and E_{ho} under paragraph (c), of this section whether or not the minimum emissions data requirements under §60.46b are achieved. All valid emissions data, including valid SO_2 emission data collected during periods of startup, shutdown and malfunction, shall be used in calculating $\%P_s$ and E_{ho} pursuant to paragraph (c) of this section.

(i) During periods of malfunction or maintenance of the SO_2 control systems when oil is combusted as provided under §60.42b(i), emission data are not used to calculate $\%P_s$ or E_s under §60.42b(a), (b) or (c), however, the emissions data are used to determine compliance with the emission limit under §60.42b(i).

(j) The owner or operator of an affected facility that only combusts very low sulfur oil, natural gas, or a mixture of these fuels with any other fuels not subject to an SO_2 standard is not subject to the compliance and performance testing requirements of this section if the owner or operator obtains fuel receipts as described in §60.49b(r).

(k) The owner or operator of an affected facility seeking to demonstrate compliance in §§60.42b(d)(4), 60.42b(j), 60.42b(k)(2), and 60.42b(k)(3) (when not burning coal) shall follow the applicable procedures in §60.49b(r).

[72 FR 32742, June 13, 2007, as amended at 74 FR 5086, Jan. 28, 2009]

§ 60.46b Compliance and performance test methods and procedures for particulate matter and nitrogen oxides.

(a) The PM emission standards and opacity limits under §60.43b apply at all times except during periods of startup, shutdown, or malfunction. The NO_X emission standards under §60.44b apply at all times.

(b) Compliance with the PM emission standards under §60.43b shall be determined through performance testing as described in paragraph (d) of this section, except as provided in paragraph (i) of this section.

(c) Compliance with the NO_X emission standards under §60.44b shall be determined through performance testing under paragraph (e) or (f), or under paragraphs (g) and (h) of this section, as applicable.

(d) To determine compliance with the PM emission limits and opacity limits under §60.43b, the owner or operator of an affected facility shall conduct an initial performance test as required under §60.8, and shall conduct subsequent performance tests as requested by the Administrator, using the following procedures and reference methods:

(1) Method 3A or 3B of appendix A–2 of this part is used for gas analysis when applying Method 5 of appendix A–3 of this part or Method 17 of appendix A–6 of this part.

(2) Method 5, 5B, or 17 of appendix A of this part shall be used to measure the concentration of PM as follows:

(i) Method 5 of appendix A of this part shall be used at affected facilities without wet flue gas desulfurization (FGD) systems; and

(ii) Method 17 of appendix A–6 of this part may be used at facilities with or without wet scrubber systems provided the stack gas temperature does not exceed a temperature of 160 °C (320 °F). The procedures of sections 8.1 and 11.1 of Method 5B of appendix A–3 of this part may be used in Method 17 of appendix A–6 of this part only if it is used after a wet FGD system. Do not use Method 17 of appendix A–6 of this part after wet FGD systems if the effluent is saturated or laden with water droplets.

(iii) Method 5B of appendix A of this part is to be used only after wet FGD systems.

(3) Method 1 of appendix A of this part is used to select the sampling site and the number of traverse sampling points. The sampling time for each run is at least 120 minutes and the minimum sampling volume is 1.7 dscm (60 dscf) except that smaller sampling times or volumes may be approved by the Administrator when necessitated by process variables or other factors.

(4) For Method 5 of appendix A of this part, the temperature of the sample gas in the probe and filter holder is monitored and is maintained at 160±14 °C (320±25 °F).

(5) For determination of PM emissions, the oxygen (O_2) or CO_2sample is obtained simultaneously with each run of Method 5, 5B, or 17 of appendix A of this part by traversing the duct at the same sampling location.

(6) For each run using Method 5, 5B, or 17 of appendix A of this part, the emission rate expressed in ng/J heat input is determined using:

(i) The O_2or CO_2measurements and PM measurements obtained under this section;

(ii) The dry basis F factor; and

(iii) The dry basis emission rate calculation procedure contained in Method 19 of appendix A of this part.

(7) Method 9 of appendix A of this part is used for determining the opacity of stack emissions.

(e) To determine compliance with the emission limits for NO_X required under §60.44b, the owner or operator of an affected facility shall conduct the performance test as required under §60.8 using the continuous system for monitoring NO_X under §60.48(b).

(1) For the initial compliance test, NO_X from the steam generating unit are monitored for 30 successive steam generating unit operating days and the 30-day average emission rate is used to determine compliance with the NO_X emission standards under §60.44b. The 30-day average emission rate is calculated as the average of all hourly emissions data recorded by the monitoring system during the 30-day test period.

(2) Following the date on which the initial performance test is completed or is required to be completed in §60.8, whichever date comes first, the owner or operator of an affected facility which combusts coal (except as specified under §60.46b(e)(4)) or which combusts residual oil having a nitrogen content greater than 0.30 weight percent shall determine compliance with the NO_X emission standards in §60.44b on a continuous basis through the use of a 30-day rolling average emission rate. A new 30-day rolling average emission rate is calculated for each steam generating unit operating day as the average of all of the hourly NO_X emission data for the preceding 30 steam generating unit operating days.

(3) Following the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, the owner or operator of an affected facility that has a heat input capacity greater than 73 MW (250 MMBtu/hr) and that combusts natural gas, distillate oil, or residual oil having a nitrogen content of 0.30 weight percent or less shall determine compliance with the NO_X standards under §60.44b on a continuous basis through the use of a 30-day rolling average emission rate. A new 30-day rolling average emission rate is calculated each steam generating unit operating day as the average of all of the hourly NO_X emission data for the preceding 30 steam generating unit operating days.

(4) Following the date on which the initial performance test is completed or required to be completed under §60.8, whichever date comes first, the owner or operator of an affected facility that has a heat input capacity of 73 MW (250 MMBtu/hr) or less and that combusts natural gas, distillate oil, gasified coal, or residual oil having a nitrogen content of 0.30 weight percent or less shall upon request determine compliance with the NO_X standards in §60.44b through the use of a 30-day performance test. During periods when performance tests are not requested, NO_X emissions data collected pursuant to §60.48b(g)(1) or §60.48b(g)(2) are used to calculate a 30-day rolling average emission rate on a daily basis and used to prepare excess emission reports, but will not be used to determine compliance with the NO_X emission standards. A new 30-day rolling average emission rate is calculated each steam generating unit operating day as the average of all of the hourly NO_X emission data for the preceding 30 steam generating unit operating days.

(5) If the owner or operator of an affected facility that combusts residual oil does not sample and analyze the residual oil for nitrogen content, as specified in §60.49b(e), the requirements of §60.48b(g)(1) apply and the provisions of §60.48b(g)(2) are inapplicable.

(f) To determine compliance with the emissions limits for NO_X required by §60.44b(a)(4) or §60.44b(l) for duct burners used in combined cycle systems, either of the procedures described in paragraph (f)(1) or (2) of this section may be used:

(1) The owner or operator of an affected facility shall conduct the performance test required under §60.8 as follows:

(i) The emissions rate (E) of NO_X shall be computed using Equation 1 in this section:

$$E = E_{ig} + \left(\frac{H_g}{H_b}\right)\left(E_{ig} - E_g\right) \qquad \text{(Eq.1)}$$

Where:

E = Emissions rate of NO_X from the duct burner, ng/J (lb/MMBtu) heat input;

E_{sg}= Combined effluent emissions rate, in ng/J (lb/MMBtu) heat input using appropriate F factor as described in Method 19 of appendix A of this part;

H_g= Heat input rate to the combustion turbine, in J/hr (MMBtu/hr);

H_b= Heat input rate to the duct burner, in J/hr (MMBtu/hr); and

E_g= Emissions rate from the combustion turbine, in ng/J (lb/MMBtu) heat input calculated using appropriate F factor as described in Method 19 of appendix A of this part.

(ii) Method 7E of appendix A of this part shall be used to determine the NO_X concentrations. Method 3A or 3B of appendix A of this part shall be used to determine O_2concentration.

(iii) The owner or operator shall identify and demonstrate to the Administrator's satisfaction suitable methods to determine the average hourly heat input rate to the combustion turbine and the average hourly heat input rate to the affected duct burner.

(iv) Compliance with the emissions limits under §60.44b(a)(4) or §60.44b(l) is determined by the three-run average (nominal 1-hour runs) for the initial and subsequent performance tests; or

(2) The owner or operator of an affected facility may elect to determine compliance on a 30-day rolling average basis by using the CEMS specified under §60.48b for measuring NO_X and $O_2$and meet the requirements of §60.48b. The sampling site shall be located at the outlet from the steam generating unit. The NO_X emissions rate at the outlet from the steam generating unit shall constitute the NO_X emissions rate from the duct burner of the combined cycle system.

(g) The owner or operator of an affected facility described in §60.44b(j) or §60.44b(k) shall demonstrate the maximum heat input capacity of the steam generating unit by operating the facility at maximum capacity for 24 hours. The owner or operator of an affected facility shall determine the maximum heat input capacity using the heat loss method or the heat input method described in sections 5 and 7.3 of the ASME *Power Test Codes* 4.1 (incorporated by reference, see §60.17). This demonstration of maximum heat input capacity shall be made during the initial performance test for affected facilities that meet the criteria of §60.44b(j). It shall be made within 60 days after achieving the maximum production rate at which the affected facility will be operated, but not later than 180 days after initial start-up of each facility, for affected facilities meeting the criteria of §60.44b(k). Subsequent demonstrations may be required by the Administrator at any other time. If this demonstration indicates that the maximum heat input capacity of the affected facility is less than that stated by the manufacturer of the affected facility, the maximum heat input capacity determined during this demonstration shall be used to determine the capacity utilization rate for the affected facility. Otherwise, the maximum heat input capacity provided by the manufacturer is used.

(h) The owner or operator of an affected facility described in §60.44b(j) that has a heat input capacity greater than 73 MW (250 MMBtu/hr) shall:

(1) Conduct an initial performance test as required under §60.8 over a minimum of 24 consecutive steam generating unit operating hours at maximum heat input capacity to demonstrate compliance with the NO_X emission standards under §60.44b using Method 7, 7A, 7E of appendix A of this part, or other approved reference methods; and

(2) Conduct subsequent performance tests once per calendar year or every 400 hours of operation (whichever comes first) to demonstrate compliance with the NO_X emission standards under §60.44b over a minimum of 3 consecutive steam generating unit operating hours at maximum heat input capacity using Method 7, 7A, 7E of appendix A of this part, or other approved reference methods.

(i) The owner or operator of an affected facility seeking to demonstrate compliance with the PM limit in paragraphs §60.43b(a)(4) or §60.43b(h)(5) shall follow the applicable procedures in §60.49b(r).

(j) In place of PM testing with Method 5 or 5B of appendix A–3 of this part, or Method 17 of appendix A–6 of this part, an owner or operator may elect to install, calibrate, maintain, and operate a CEMS for monitoring PM emissions discharged to the atmosphere and record the output of the system. The owner or operator of an affected facility who elects to continuously monitor PM emissions instead of conducting performance testing using Method 5 or 5B of appendix A–3 of this part or Method 17 of appendix A–6 of this part shall comply with the requirements specified in paragraphs (j)(1) through (j)(14) of this section.

(1) Notify the Administrator one month before starting use of the system.

(2) Notify the Administrator one month before stopping use of the system.

(3) The monitor shall be installed, evaluated, and operated in accordance with §60.13 of subpart A of this part.

(4) The initial performance evaluation shall be completed no later than 180 days after the date of initial startup of the affected facility, as specified under §60.8 of subpart A of this part or within 180 days of notification to the Administrator of use of the CEMS if the owner or operator was previously determining compliance by Method 5, 5B, or 17 of appendix A of this part performance tests, whichever is later.

(5) The owner or operator of an affected facility shall conduct an initial performance test for PM emissions as required under §60.8 of subpart A of this part. Compliance with the PM emission limit shall be determined by using the CEMS specified in paragraph (j) of this section to measure PM and calculating a 24-hour block arithmetic average emission concentration using EPA Reference Method 19 of appendix A of this part, section 4.1.

(6) Compliance with the PM emission limit shall be determined based on the 24-hour daily (block) average of the hourly arithmetic average emission concentrations using CEMS outlet data.

(7) At a minimum, valid CEMS hourly averages shall be obtained as specified in paragraphs (j)(7)(i) of this section for 75 percent of the total operating hours per 30-day rolling average.

(i) At least two data points per hour shall be used to calculate each 1-hour arithmetic average.

(ii) [Reserved]

(8) The 1-hour arithmetic averages required under paragraph (j)(7) of this section shall be expressed in ng/J or lb/MMBtu heat input and shall be used to calculate the boiler operating day daily arithmetic average emission concentrations. The 1-hour arithmetic averages shall be calculated using the data points required under §60.13(e)(2) of subpart A of this part.

(9) All valid CEMS data shall be used in calculating average emission concentrations even if the minimum CEMS data requirements of paragraph (j)(7) of this section are not met.

(10) The CEMS shall be operated according to Performance Specification 11 in appendix B of this part.

(11) During the correlation testing runs of the CEMS required by Performance Specification 11 in appendix B of this part, PM and O_2(or CO_2) data shall be collected concurrently (or within a 30-to 60-minute period) by both the continuous emission monitors and performance tests conducted using the following test methods.

(i) For PM, Method 5 or 5B of appendix A–3 of this part or Method 17 of appendix A–6 of this part shall be used; and

(ii) After July 1, 2010 or after Method 202 of appendix M of part 51 has been revised to minimize artifact measurement and notice of that change has been published in theFederal Register,whichever is later, for condensable PM emissions, Method 202 of appendix M of part 51 shall be used; and

(iii) For O_2(or CO_2), Method 3A or 3B of appendix A–2 of this part, as applicable shall be used.

(12) Quarterly accuracy determinations and daily calibration drift tests shall be performed in accordance with procedure 2 in appendix F of this part. Relative Response Audit's must be performed annually and Response Correlation Audits must be performed every 3 years.

(13) When PM emissions data are not obtained because of CEMS breakdowns, repairs, calibration checks, and zero and span adjustments, emissions data shall be obtained by using other monitoring systems as approved by the Administrator or EPA Reference Method 19 of appendix A of this part to provide, as necessary, valid emissions data for a minimum of 75 percent of total operating hours per 30-day rolling average.

(14) After July 1, 2011, within 90 days after completing a correlation testing run, the owner or operator of an affected facility shall either successfully enter the test data into EPA's WebFIRE data base located at *http://cfpub.epa.gov/oarweb/index.cfm?action=fire.main* or mail a copy to: United States Environmental Protection Agency; Energy Strategies Group; 109 TW Alexander DR; Mail Code: D243–01; RTP, NC 27711.

[72 FR 32742, June 13, 2007, as amended at 74 FR 5086, Jan. 28, 2009]

§ 60.47b Emission monitoring for sulfur dioxide.

(a) Except as provided in paragraphs (b) and (f) of this section, the owner or operator of an affected facility subject to the SO_2standards in §60.42b shall install, calibrate, maintain, and operate CEMS for measuring SO_2concentrations and either O_2or CO_2concentrations and shall record the output of the systems. For units complying with the percent reduction standard, the $SO_2$and either O_2or CO_2concentrations shall both be monitored at the inlet and outlet of the SO_2control device. If the owner or operator has installed and certified $SO_2$and O_2or CO_2CEMS according to the requirements of §75.20(c)(1) of this chapter and appendix A to part 75 of this chapter, and is continuing to meet the ongoing quality assurance requirements of §75.21 of this chapter and appendix B to part 75 of this chapter, those CEMS may be used to meet the requirements of this section, provided that:

(1) When relative accuracy testing is conducted, SO_2concentration data and CO_2(or O_2) data are collected simultaneously; and

(2) In addition to meeting the applicable $SO_2$and CO_2(or O_2) relative accuracy specifications in Figure 2 of appendix B to part 75 of this chapter, the relative accuracy (RA) standard in section 13.2 of Performance Specification 2 in appendix B to this part is met when the RA is calculated on a lb/MMBtu basis; and

(3) The reporting requirements of §60.49b are met. $SO_2$and CO_2(or O_2) data used to meet the requirements of §60.49b shall not include substitute data values derived from the missing data procedures in subpart D of part 75 of this chapter, nor shall the SO_2data have been bias adjusted according to the procedures of part 75 of this chapter.

(b) As an alternative to operating CEMS as required under paragraph (a) of this section, an owner or operator may elect to determine the average SO_2emissions and percent reduction by:

(1) Collecting coal or oil samples in an as-fired condition at the inlet to the steam generating unit and analyzing them for sulfur and heat content according to Method 19 of appendix A of this part. Method 19 of appendix A of this part provides procedures for converting these measurements into the format to be used in calculating the average SO_2input rate, or

(2) Measuring SO_2according to Method 6B of appendix A of this part at the inlet or outlet to the SO_2control system. An initial stratification test is required to verify the adequacy of the Method 6B of appendix A of this part sampling location. The stratification test shall consist of three paired runs of a suitable $SO_2$and CO_2measurement train operated at the candidate location and a second similar train operated according to the procedures in section 3.2 and the applicable procedures in section 7 of Performance Specification 2. Method 6B of appendix A of this part, Method 6A of appendix A of this part, or a combination of Methods 6 and 3 or 3B of appendix A of this part or Methods 6C and 3A of appendix A of this part are suitable measurement techniques. If Method 6B of appendix A of this part is used for the second train, sampling time and timer operation may be adjusted for the stratification test as long as an adequate sample volume is collected; however, both sampling trains are to be operated similarly. For the location to be adequate for Method 6B of appendix A of this part 24-hour tests, the mean of the absolute difference between the three paired runs must be less than 10 percent.

(3) A daily SO_2emission rate, E_D, shall be determined using the procedure described in Method 6A of appendix A of this part, section 7.6.2 (Equation 6A–8) and stated in ng/J (lb/MMBtu) heat input.

(4) The mean 30-day emission rate is calculated using the daily measured values in ng/J (lb/MMBtu) for 30 successive steam generating unit operating days using equation 19–20 of Method 19 of appendix A of this part.

(c) The owner or operator of an affected facility shall obtain emission data for at least 75 percent of the operating hours in at least 22 out of 30 successive boiler operating days. If this minimum data requirement is not met with a single monitoring system, the owner or operator of the affected facility shall supplement the emission data with data collected with other monitoring systems as approved by the Administrator or the reference methods and procedures as described in paragraph (b) of this section.

(d) The 1-hour average SO_2emission rates measured by the CEMS required by paragraph (a) of this section and required under §60.13(h) is expressed in ng/J or lb/MMBtu heat input and is used to calculate the average emission rates under §60.42(b). Each 1-hour average SO_2emission rate must be based on 30 or more minutes of steam generating unit operation. The hourly averages shall be calculated according to §60.13(h)(2). Hourly SO_2emission rates are not calculated if the affected facility is operated less than 30 minutes in a given clock hour and are not counted toward determination of a steam generating unit operating day.

(e) The procedures under §60.13 shall be followed for installation, evaluation, and operation of the CEMS.

(1) Except as provided for in paragraph (e)(4) of this section, all CEMS shall be operated in accordance with the applicable procedures under Performance Specifications 1, 2, and 3 of appendix B of this part.

(2) Except as provided for in paragraph (e)(4) of this section, quarterly accuracy determinations and daily calibration drift tests shall be performed in accordance with Procedure 1 of appendix F of this part.

(3) For affected facilities combusting coal or oil, alone or in combination with other fuels, the span value of the SO_2CEMS at the inlet to the SO_2control device is 125 percent of the maximum estimated hourly potential SO_2emissions of the fuel combusted, and the span value of the CEMS at the outlet to the SO_2control device is 50 percent of the maximum estimated hourly potential SO_2emissions of the fuel combusted. Alternatively, SO_2span values determined according to section 2.1.1 in appendix A to part 75 of this chapter may be used.

(4) As an alternative to meeting the requirements of requirements of paragraphs (e)(1) and (e)(2) of this section, the owner or operator may elect to implement the following alternative data accuracy assessment procedures:

(i) For all required $CO_2$and O_2monitors and for $SO_2$and NO_X monitors with span values greater than or equal to 100 ppm, the daily calibration error test and calibration adjustment procedures described in sections 2.1.1 and 2.1.3 of appendix B to part 75 of this chapter may be followed instead of the CD assessment procedures in Procedure 1, section 4.1 of appendix F to this part.

(ii) For all required $CO_2$and O_2monitors and for $SO_2$and NO_X monitors with span values greater than 30 ppm, quarterly linearity checks may be performed in accordance with section 2.2.1 of appendix B to part 75 of this chapter, instead of performing the cylinder gas audits (CGAs) described in Procedure 1, section 5.1.2 of appendix F to this part. If this option is selected: The frequency of the linearity checks shall be as specified in section 2.2.1 of appendix B to part 75 of this chapter; the applicable linearity specifications in section 3.2 of appendix A to part 75 of this chapter shall be met; the data validation and out-of-control criteria in section 2.2.3 of appendix B to part 75 of this chapter shall be followed instead of the excessive audit inaccuracy and out-of-control criteria in Procedure 1, section 5.2 of appendix F to this part; and the grace period provisions in section 2.2.4 of appendix B to part 75 of this chapter shall apply. For the purposes of data validation under this subpart, the cylinder gas audits described in Procedure 1, section 5.1.2 of appendix F to this part shall be performed for $SO_2$and NO_X span values less than or equal to 30 ppm; and

(iii) For SO_2, CO_2, and O_2monitoring systems and for NO_X emission rate monitoring systems, RATAs may be performed in accordance with section 2.3 of appendix B to part 75 of this chapter instead of following the procedures described in Procedure 1, section 5.1.1 of appendix F to this part. If this option is selected: The frequency of each RATA shall be as specified in section 2.3.1 of appendix B to part 75 of this chapter; the applicable relative accuracy specifications shown in Figure 2 in appendix B to part 75 of this chapter shall be met; the data validation and out-of-control criteria in section 2.3.2 of appendix B to part 75 of this chapter shall be followed instead of the excessive audit inaccuracy and out-of-control criteria in Procedure 1, section 5.2 of appendix F to this part; and the grace period provisions in section 2.3.3 of appendix B to part 75 of this chapter shall apply. For the purposes of data validation under this subpart, the relative accuracy specification in section 13.2 of Performance Specification 2 in appendix B to this part shall be met on a lb/MMBtu basis for SO_2(regardless of the SO_2emission level during the RATA), and for NO_X when the average NO_X emission rate measured by the reference method during the RATA is less than 0.100 lb/MMBtu.

(f) The owner or operator of an affected facility that combusts very low sulfur oil or is demonstrating compliance under §60.45b(k) is not subject to the emission monitoring requirements under paragraph (a) of this section if the owner or operator maintains fuel records as described in §60.49b(r).

[72 FR 32742, June 13, 2007, as amended at 74 FR 5087, Jan. 28, 2009]

§ 60.48b Emission monitoring for particulate matter and nitrogen oxides.

(a) Except as provided in paragraph (j) of this section, the owner or operator of an affected facility subject to the opacity standard under §60.43b shall install, calibrate, maintain, and operate a continuous opacity monitoring systems (COMS) for measuring the opacity of emissions discharged to the atmosphere and record the output of the system. The owner or operator of an affected facility subject to an opacity standard under §60.43b and meeting the conditions under paragraphs (j)(1), (2), (3), (4), or (5) of this section who elects not to install a COMS shall conduct a performance test using Method 9 of appendix A–4 of this part and the procedures in §60.11 to demonstrate compliance with the applicable limit in §60.43b and shall comply with either paragraphs (a)(1), (a)(2), or (a)(3) of this section. If during the initial 60 minutes of observation all 6-minute averages are less than 10 percent and all individual 15-second observations are less than or equal to 20 percent, the observation period may be reduced from 3 hours to 60 minutes.

(1) Except as provided in paragraph (a)(2) and (a)(3) of this section, the owner or operator shall conduct subsequent Method 9 of appendix A–4 of this part performance tests using the procedures in paragraph (a) of this section according to the applicable schedule in paragraphs (a)(1)(i) through (a)(1)(iv) of this section, as determined by the most recent Method 9 of appendix A–4 of this part performance test results.

(i) If no visible emissions are observed, a subsequent Method 9 of appendix A–4 of this part performance test must be completed within 12 calendar months from the date that the most recent performance test was conducted;

(ii) If visible emissions are observed but the maximum 6-minute average opacity is less than or equal to 5 percent, a subsequent Method 9 of appendix A–4 of this part performance test must be completed within 6 calendar months from the date that the most recent performance test was conducted;

(iii) If the maximum 6-minute average opacity is greater than 5 percent but less than or equal to 10 percent, a subsequent Method 9 of appendix A–4 of this part performance test must be completed within 3 calendar months from the date that the most recent performance test was conducted; or

(iv) If the maximum 6-minute average opacity is greater than 10 percent, a subsequent Method 9 of appendix A–4 of this part performance test must be completed within 30 calendar days from the date that the most recent performance test was conducted.

(2) If the maximum 6-minute opacity is less than 10 percent during the most recent Method 9 of appendix A–4 of this part performance test, the owner or operator may, as an alternative to performing subsequent Method 9 of appendix A–4 of this part performance tests, elect to perform subsequent monitoring using Method 22 of appendix A–7 of this part according to the procedures specified in paragraphs (a)(2)(i) and (ii) of this section.

(i) The owner or operator shall conduct 10 minute observations (during normal operation) each operating day the affected facility fires fuel for which an opacity standard is applicable using Method 22 of appendix A–7 of this part and demonstrate that the sum of the occurrences of any visible emissions is not in excess of 5 percent of the observation period (*i.e.* , 30 seconds per 10 minute period). If the sum of the occurrence of any visible emissions is greater than 30 seconds during the initial 10 minute observation, immediately conduct a 30 minute observation. If the sum of the occurrence of visible emissions is greater than 5 percent of the observation period (*i.e.* , 90 seconds per 30 minute period) the owner or operator shall either document and adjust the operation of the facility and demonstrate within 24 hours that the sum of the occurrence of visible emissions is equal to or less than 5 percent during a 30 minute observation (*i.e.* , 90 seconds) or conduct a new Method 9 of appendix A–4 of this part performance test using the procedures in paragraph (a) of this section within 30 calendar days according to the requirements in §60.46d(d)(7).

(ii) If no visible emissions are observed for 30 operating days during which an opacity standard is applicable, observations can be reduced to once every 7 operating days during which an opacity standard is applicable. If any visible emissions are observed, daily observations shall be resumed.

(3) If the maximum 6-minute opacity is less than 10 percent during the most recent Method 9 of appendix A–4 of this part performance test, the owner or operator may, as an alternative to performing subsequent Method 9 of appendix A–4 performance tests, elect to perform subsequent monitoring using a digital opacity compliance system according to a site-specific monitoring plan approved by the Administrator. The observations shall be similar, but not necessarily identical, to the requirements in paragraph (a)(2) of this section. For reference purposes in preparing the monitoring plan, see OAQPS “Determination of Visible Emission Opacity from Stationary Sources Using Computer-Based Photographic Analysis Systems.” This document is available from the U.S. Environmental Protection Agency (U.S. EPA); Office of Air Quality and Planning Standards; Sector Policies and Programs Division; Measurement Policy Group (D243–02), Research Triangle Park, NC 27711. This document is also available on the Technology Transfer Network (TTN) under Emission Measurement Center Preliminary Methods.

(b) Except as provided under paragraphs (g), (h), and (i) of this section, the owner or operator of an affected facility subject to a NO_X standard under §60.44b shall comply with either paragraphs (b)(1) or (b)(2) of this section.

(1) Install, calibrate, maintain, and operate CEMS for measuring NO_X and O_2(or CO_2) emissions discharged to the atmosphere, and shall record the output of the system; or

(2) If the owner or operator has installed a NO_X emission rate CEMS to meet the requirements of part 75 of this chapter and is continuing to meet the ongoing requirements of part 75 of this chapter, that CEMS may be used to meet the requirements of this section, except that the owner or operator shall also meet the requirements of §60.49b. Data reported to meet the requirements of §60.49b shall not include data substituted using the missing data procedures in subpart D of part 75 of this chapter, nor shall the data have been bias adjusted according to the procedures of part 75 of this chapter.

(c) The CEMS required under paragraph (b) of this section shall be operated and data recorded during all periods of operation of the affected facility except for CEMS breakdowns and repairs. Data is recorded during calibration checks, and zero and span adjustments.

(d) The 1-hour average NO_X emission rates measured by the continuous NO_X monitor required by paragraph (b) of this section and required under §60.13(h) shall be expressed in ng/J or lb/MMBtu heat input and shall be used to calculate the average emission rates under §60.44b. The 1-hour averages shall be calculated using the data points required under §60.13(h)(2).

(e) The procedures under §60.13 shall be followed for installation, evaluation, and operation of the continuous monitoring systems.

(1) For affected facilities combusting coal, wood or municipal-type solid waste, the span value for a COMS shall be between 60 and 80 percent.

(2) For affected facilities combusting coal, oil, or natural gas, the span value for NO_X is determined using one of the following procedures:

(i) Except as provided under paragraph (e)(2)(ii) of this section, NO_X span values shall be determined as follows:

Fuel	Span values for NO_X (ppm)
Natural gas	500.
Oil	500.
Coal	1,000.
Mixtures	500 (x + y) + 1,000z.

Where:

x = Fraction of total heat input derived from natural gas;

y = Fraction of total heat input derived from oil; and

z = Fraction of total heat input derived from coal.

(ii) As an alternative to meeting the requirements of paragraph (e)(2)(i) of this section, the owner or operator of an affected facility may elect to use the NO_X span values determined according to section 2.1.2 in appendix A to part 75 of this chapter.

(3) All span values computed under paragraph (e)(2)(i) of this section for combusting mixtures of regulated fuels are rounded to the nearest 500 ppm. Span values computed under paragraph (e)(2)(ii) of this section shall be rounded off according to section 2.1.2 in appendix A to part 75 of this chapter.

(f) When NO_X emission data are not obtained because of CEMS breakdowns, repairs, calibration checks and zero and span adjustments, emission data will be obtained by using standby monitoring systems, Method 7 of appendix A of this part, Method 7A of appendix A of this part, or other approved reference methods to provide emission data for a minimum of 75 percent of the operating hours in each steam generating unit operating day, in at least 22 out of 30 successive steam generating unit operating days.

(g) The owner or operator of an affected facility that has a heat input capacity of 73 MW (250 MMBtu/hr) or less, and that has an annual capacity factor for residual oil having a nitrogen content of 0.30 weight percent or less, natural gas, distillate oil, gasified coal, or any mixture of these fuels, greater than 10 percent (0.10) shall:

(1) Comply with the provisions of paragraphs (b), (c), (d), (e)(2), (e)(3), and (f) of this section; or

(2) Monitor steam generating unit operating conditions and predict NO_X emission rates as specified in a plan submitted pursuant to §60.49b(c).

(h) The owner or operator of a duct burner, as described in §60.41b, that is subject to the NO_X standards in §60.44b(a)(4), §60.44b(e), or §60.44b(l) is not required to install or operate a continuous emissions monitoring system to measure NO_X emissions.

(i) The owner or operator of an affected facility described in §60.44b(j) or §60.44b(k) is not required to install or operate a CEMS for measuring NO_X emissions.

(j) The owner or operator of an affected facility that meets the conditions in either paragraph (j)(1), (2), (3), (4), (5), or (6) of this section is not required to install or operate a COMS if:

(1) The affected facility uses a PM CEMS to monitor PM emissions; or

(2) The affected facility burns only liquid (excluding residual oil) or gaseous fuels with potential SO_2 emissions rates of 26 ng/J (0.060 lb/MMBtu) or less and does not use a post-combustion technology to reduce SO_2 or PM emissions. The owner or operator must maintain fuel records of the sulfur content of the fuels burned, as described under §60.49b(r); or

(3) The affected facility burns coke oven gas alone or in combination with fuels meeting the criteria in paragraph (j)(2) of this section and does not use a post-combustion technology to reduce SO_2 or PM emissions; or

(4) The affected facility does not use post-combustion technology (except a wet scrubber) for reducing PM, SO_2, or carbon monoxide (CO) emissions, burns only gaseous fuels or fuel oils that contain less than or equal to 0.30 weight percent sulfur, and is operated such that emissions of CO to the atmosphere from the affected facility are maintained at levels less than or equal to 0.15 lb/MMBtu on a steam generating unit operating day average basis. Owners and operators of affected facilities electing to comply with this paragraph must demonstrate compliance according to the procedures specified in paragraphs (j)(4)(i) through (iv) of this section; or

(i) You must monitor CO emissions using a CEMS according to the procedures specified in paragraphs (j)(4)(i)(A) through (D) of this section.

(A) The CO CEMS must be installed, certified, maintained, and operated according to the provisions in §60.58b(i)(3) of subpart Eb of this part.

(B) Each 1-hour CO emissions average is calculated using the data points generated by the CO CEMS expressed in parts per million by volume corrected to 3 percent oxygen (dry basis).

(C) At a minimum, valid 1-hour CO emissions averages must be obtained for at least 90 percent of the operating hours on a 30-day rolling average basis. The 1-hour averages are calculated using the data points required in §60.13(h)(2).

(D) Quarterly accuracy determinations and daily calibration drift tests for the CO CEMS must be performed in accordance with procedure 1 in appendix F of this part.

(ii) You must calculate the 1-hour average CO emissions levels for each steam generating unit operating day by multiplying the average hourly CO output concentration measured by the CO CEMS times the corresponding average hourly flue gas flow rate and divided by the corresponding average hourly heat input to the affected source. The 24-hour average CO emission level is determined by calculating the arithmetic average of the hourly CO emission levels computed for each steam generating unit operating day.

(iii) You must evaluate the preceding 24-hour average CO emission level each steam generating unit operating day excluding periods of affected source startup, shutdown, or malfunction. If the 24-hour average CO emission level is greater than 0.15 lb/MMBtu, you must initiate investigation of the relevant equipment and control systems within 24 hours of the first discovery of the high emission incident and, take the appropriate corrective action as soon as practicable to adjust control settings or repair equipment to reduce the 24-hour average CO emission level to 0.15 lb/MMBtu or less.

(iv) You must record the CO measurements and calculations performed according to paragraph (j)(4) of this section and any corrective actions taken. The record of corrective action taken must include the date and time during which the 24-hour average CO emission level was greater than 0.15 lb/MMBtu, and the date, time, and description of the corrective action.

(5) The affected facility uses a bag leak detection system to monitor the performance of a fabric filter (baghouse) according to the most recent requirements in section §60.48Da of this part; or

(6) The affected facility burns only gaseous fuels or fuel oils that contain less than or equal to 0.30 weight percent sulfur and operates according to a written site-specific monitoring plan approved by the permitting authority. This monitoring plan must include procedures and criteria for establishing and monitoring specific parameters for the affected facility indicative of compliance with the opacity standard.

(k) Owners or operators complying with the PM emission limit by using a PM CEMS must calibrate, maintain, operate, and record the output of the system for PM emissions discharged to the atmosphere as specified in §60.46b(j). The CEMS specified in paragraph §60.46b(j) shall be operated and data recorded during all periods of operation of the affected facility except for CEMS breakdowns and repairs. Data is recorded during calibration checks, and zero and span adjustments.

[72 FR 32742, June 13, 2007, as amended at 74 FR 5087, Jan. 28, 2009]

§ 60.49b Reporting and recordkeeping requirements.

(a) The owner or operator of each affected facility shall submit notification of the date of initial startup, as provided by §60.7. This notification shall include:

(1) The design heat input capacity of the affected facility and identification of the fuels to be combusted in the affected facility;

(2) If applicable, a copy of any federally enforceable requirement that limits the annual capacity factor for any fuel or mixture of fuels under §§60.42b(d)(1), 60.43b(a)(2), (a)(3)(iii), (c)(2)(ii), (d)(2)(iii), 60.44b(c), (d), (e), (i), (j), (k), 60.45b(d), (g), 60.46b(h), or 60.48b(i);

(3) The annual capacity factor at which the owner or operator anticipates operating the facility based on all fuels fired and based on each individual fuel fired; and

(4) Notification that an emerging technology will be used for controlling emissions of SO_2. The Administrator will examine the description of the emerging technology and will determine whether the technology qualifies as an emerging technology. In making this determination, the Administrator may require the owner or operator of the affected facility to submit additional information concerning the control device. The affected facility is subject to the provisions of §60.42b(a) unless and until this determination is made by the Administrator.

(b) The owner or operator of each affected facility subject to the SO_2, PM, and/or NO_X emission limits under §§60.42b, 60.43b, and 60.44b shall submit to the Administrator the performance test data from the initial performance test and the performance evaluation of the CEMS using the applicable performance specifications in appendix B of this part. The owner or operator of each affected facility described in §60.44b(j) or §60.44b(k) shall submit to the Administrator the maximum heat input capacity data from the demonstration of the maximum heat input capacity of the affected facility.

(c) The owner or operator of each affected facility subject to the NO_X standard in §60.44b who seeks to demonstrate compliance with those standards through the monitoring of steam generating unit operating conditions in the provisions of §60.48b(g)(2) shall submit to the Administrator for approval a plan that identifies the operating conditions to be monitored in §60.48b(g)(2) and the records to be maintained in §60.49b(g). This plan shall be submitted to the Administrator for approval within 360 days of the initial startup of the affected facility. An affected facility burning coke oven gas alone or in combination with other gaseous fuels or distillate oil shall submit this plan to the Administrator for approval within 360 days of the initial startup of the affected facility or by November 30, 2009, whichever date comes later. If the plan is approved, the owner or operator shall maintain records of predicted nitrogen oxide emission rates and the monitored operating conditions, including steam generating unit load, identified in the plan. The plan shall:

(1) Identify the specific operating conditions to be monitored and the relationship between these operating conditions and NO_X emission rates (*i.e.* , ng/J or lbs/MMBtu heat input). Steam generating unit operating conditions include, but are not limited to, the degree of staged combustion (*i.e.* , the ratio of primary air to secondary and/or tertiary air) and the level of excess air (*i.e.* , flue gas O_2level);

(2) Include the data and information that the owner or operator used to identify the relationship between NO_X emission rates and these operating conditions; and

(3) Identify how these operating conditions, including steam generating unit load, will be monitored under §60.48b(g) on an hourly basis by the owner or operator during the period of operation of the affected facility; the quality assurance procedures or practices that will be employed to ensure that the data generated by monitoring these operating conditions will be representative and accurate; and the type and format of the records of these operating conditions, including steam generating unit load, that will be maintained by the owner or operator under §60.49b(g).

(d) Except as provided in paragraph (d)(2) of this section, the owner or operator of an affected facility shall record and maintain records as specified in paragraph (d)(1) of this section.

(1) The owner or operator of an affected facility shall record and maintain records of the amounts of each fuel combusted during each day and calculate the annual capacity factor individually for coal, distillate oil, residual oil, natural gas, wood, and municipal-type solid waste for the reporting period. The annual capacity factor is determined on a 12-month rolling average basis with a new annual capacity factor calculated at the end of each calendar month.

(2) As an alternative to meeting the requirements of paragraph (d)(1) of this section, the owner or operator of an affected facility that is subject to a federally enforceable permit restricting fuel use to a single fuel such that the facility is not required to continuously monitor any emissions (excluding opacity) or parameters indicative of emissions may elect to record and maintain records of the amount of each fuel combusted during each calendar month.

(e) For an affected facility that combusts residual oil and meets the criteria under §§60.46b(e)(4), 60.44b(j), or (k), the owner or operator shall maintain records of the nitrogen content of the residual oil combusted in the affected facility and calculate the average fuel nitrogen content for the reporting period. The nitrogen content shall be determined using ASTM Method D4629 (incorporated by reference, see §60.17), or fuel suppliers. If residual oil blends are being combusted, fuel nitrogen specifications may be prorated based on the ratio of residual oils of different nitrogen content in the fuel blend.

(f) For an affected facility subject to the opacity standard in §60.43b, the owner or operator shall maintain records of opacity. In addition, an owner or operator that elects to monitor emissions according to the requirements in §60.48b(a) shall maintain records according to the requirements specified in paragraphs (f)(1) through (3) of this section, as applicable to the visible emissions monitoring method used.

(1) For each performance test conducted using Method 9 of appendix A–4 of this part, the owner or operator shall keep the records including the information specified in paragraphs (f)(1)(i) through (iii) of this section.

(i) Dates and time intervals of all opacity observation periods;

(ii) Name, affiliation, and copy of current visible emission reading certification for each visible emission observer participating in the performance test; and

(iii) Copies of all visible emission observer opacity field data sheets;

(2) For each performance test conducted using Method 22 of appendix A–4 of this part, the owner or operator shall keep the records including the information specified in paragraphs (f)(2)(i) through (iv) of this section.

(i) Dates and time intervals of all visible emissions observation periods;

(ii) Name and affiliation for each visible emission observer participating in the performance test;

(iii) Copies of all visible emission observer opacity field data sheets; and

(iv) Documentation of any adjustments made and the time the adjustments were completed to the affected facility operation by the owner or operator to demonstrate compliance with the applicable monitoring requirements.

(3) For each digital opacity compliance system, the owner or operator shall maintain records and submit reports according to the requirements specified in the site-specific monitoring plan approved by the Administrator.

(g) Except as provided under paragraph (p) of this section, the owner or operator of an affected facility subject to the NO_X standards under §60.44b shall maintain records of the following information for each steam generating unit operating day:

(1) Calendar date;

(2) The average hourly NO_X emission rates (expressed as NO_2) (ng/J or lb/MMBtu heat input) measured or predicted;

(3) The 30-day average NO_X emission rates (ng/J or lb/MMBtu heat input) calculated at the end of each steam generating unit operating day from the measured or predicted hourly nitrogen oxide emission rates for the preceding 30 steam generating unit operating days;

(4) Identification of the steam generating unit operating days when the calculated 30-day average NO_X emission rates are in excess of the NO_X emissions standards under §60.44b, with the reasons for such excess emissions as well as a description of corrective actions taken;

(5) Identification of the steam generating unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken;

(6) Identification of the times when emission data have been excluded from the calculation of average emission rates and the reasons for excluding data;

(7) Identification of “F” factor used for calculations, method of determination, and type of fuel combusted;

(8) Identification of the times when the pollutant concentration exceeded full span of the CEMS;

(9) Description of any modifications to the CEMS that could affect the ability of the CEMS to comply with Performance Specification 2 or 3; and

(10) Results of daily CEMS drift tests and quarterly accuracy assessments as required under appendix F, Procedure 1 of this part.

(h) The owner or operator of any affected facility in any category listed in paragraphs (h)(1) or (2) of this section is required to submit excess emission reports for any excess emissions that occurred during the reporting period.

(1) Any affected facility subject to the opacity standards in §60.43b(f) or to the operating parameter monitoring requirements in §60.13(i)(1).

(2) Any affected facility that is subject to the NO_X standard of §60.44b, and that:

(i) Combusts natural gas, distillate oil, gasified coal, or residual oil with a nitrogen content of 0.3 weight percent or less; or

(ii) Has a heat input capacity of 73 MW (250 MMBtu/hr) or less and is required to monitor NO_X emissions on a continuous basis under §60.48b(g)(1) or steam generating unit operating conditions under §60.48b(g)(2).

(3) For the purpose of §60.43b, excess emissions are defined as all 6-minute periods during which the average opacity exceeds the opacity standards under §60.43b(f).

(4) For purposes of §60.48b(g)(1), excess emissions are defined as any calculated 30-day rolling average NO_X emission rate, as determined under §60.46b(e), that exceeds the applicable emission limits in §60.44b.

(i) The owner or operator of any affected facility subject to the continuous monitoring requirements for NO_X under §60.48(b) shall submit reports containing the information recorded under paragraph (g) of this section.

(j) The owner or operator of any affected facility subject to the SO_2standards under §60.42b shall submit reports.

(k) For each affected facility subject to the compliance and performance testing requirements of §60.45b and the reporting requirement in paragraph (j) of this section, the following information shall be reported to the Administrator:

(1) Calendar dates covered in the reporting period;

(2) Each 30-day average SO_2emission rate (ng/J or lb/MMBtu heat input) measured during the reporting period, ending with the last 30-day period; reasons for noncompliance with the emission standards; and a description of corrective actions taken; For an exceedance due to maintenance of the SO_2control system covered in paragraph 60.45b(a), the report shall identify the days on which the maintenance was performed and a description of the maintenance;

(3) Each 30-day average percent reduction in SO_2emissions calculated during the reporting period, ending with the last 30-day period; reasons for noncompliance with the emission standards; and a description of corrective actions taken;

(4) Identification of the steam generating unit operating days that coal or oil was combusted and for which SO_2or diluent (O_2or CO_2) data have not been obtained by an approved method for at least 75 percent of the operating hours in the steam generating unit operating day; justification for not obtaining sufficient data; and description of corrective action taken;

(5) Identification of the times when emissions data have been excluded from the calculation of average emission rates; justification for excluding data; and description of corrective action taken if data have been excluded for periods other than those during which coal or oil were not combusted in the steam generating unit;

(6) Identification of “F” factor used for calculations, method of determination, and type of fuel combusted;

(7) Identification of times when hourly averages have been obtained based on manual sampling methods;

(8) Identification of the times when the pollutant concentration exceeded full span of the CEMS;

(9) Description of any modifications to the CEMS that could affect the ability of the CEMS to comply with Performance Specification 2 or 3;

(10) Results of daily CEMS drift tests and quarterly accuracy assessments as required under appendix F, Procedure 1 of this part; and

(11) The annual capacity factor of each fired as provided under paragraph (d) of this section.

(l) For each affected facility subject to the compliance and performance testing requirements of §60.45b(d) and the reporting requirements of paragraph (j) of this section, the following information shall be reported to the Administrator:

(1) Calendar dates when the facility was in operation during the reporting period;

(2) The 24-hour average SO_2emission rate measured for each steam generating unit operating day during the reporting period that coal or oil was combusted, ending in the last 24-hour period in the quarter; reasons for noncompliance with the emission standards; and a description of corrective actions taken;

(3) Identification of the steam generating unit operating days that coal or oil was combusted for which $S0_2$or diluent (O_2or CO_2) data have not been obtained by an approved method for at least 75 percent of the operating hours; justification for not obtaining sufficient data; and description of corrective action taken;

(4) Identification of the times when emissions data have been excluded from the calculation of average emission rates; justification for excluding data; and description of corrective action taken if data have been excluded for periods other than those during which coal or oil were not combusted in the steam generating unit;

(5) Identification of “F” factor used for calculations, method of determination, and type of fuel combusted;

(6) Identification of times when hourly averages have been obtained based on manual sampling methods;

(7) Identification of the times when the pollutant concentration exceeded full span of the CEMS;

(8) Description of any modifications to the CEMS that could affect the ability of the CEMS to comply with Performance Specification 2 or 3; and

(9) Results of daily CEMS drift tests and quarterly accuracy assessments as required under Procedure 1 of appendix F 1 of this part. If the owner or operator elects to implement the alternative data assessment procedures described in §§60.47b(e)(4)(i) through (e)(4)(iii), each data assessment report shall include a summary of the results of all of the RATAs, linearity checks, CGAs, and calibration error or drift assessments required by §§60.47b(e)(4)(i) through (e)(4)(iii).

(m) For each affected facility subject to the SO_2standards in §60.42(b) for which the minimum amount of data required in §60.47b(c) were not obtained during the reporting period, the following information is reported to the Administrator in addition to that required under paragraph (k) of this section:

(1) The number of hourly averages available for outlet emission rates and inlet emission rates;

(2) The standard deviation of hourly averages for outlet emission rates and inlet emission rates, as determined in Method 19 of appendix A of this part, section 7;

(3) The lower confidence limit for the mean outlet emission rate and the upper confidence limit for the mean inlet emission rate, as calculated in Method 19 of appendix A of this part, section 7; and

(4) The ratio of the lower confidence limit for the mean outlet emission rate and the allowable emission rate, as determined in Method 19 of appendix A of this part, section 7.

(n) If a percent removal efficiency by fuel pretreatment (*i.e.* , $\%R_f$) is used to determine the overall percent reduction (*i.e.* , $\%R_o$) under §60.45b, the owner or operator of the affected facility shall submit a signed statement with the report.

(1) Indicating what removal efficiency by fuel pretreatment (*i.e.* , $\%R_f$) was credited during the reporting period;

(2) Listing the quantity, heat content, and date each pre-treated fuel shipment was received during the reporting period, the name and location of the fuel pretreatment facility; and the total quantity and total heat content of all fuels received at the affected facility during the reporting period;

(3) Documenting the transport of the fuel from the fuel pretreatment facility to the steam generating unit; and

(4) Including a signed statement from the owner or operator of the fuel pretreatment facility certifying that the percent removal efficiency achieved by fuel pretreatment was determined in accordance with the provisions of Method 19 of appendix A of this part and listing the heat content and sulfur content of each fuel before and after fuel pretreatment.

(o) All records required under this section shall be maintained by the owner or operator of the affected facility for a period of 2 years following the date of such record.

(p) The owner or operator of an affected facility described in §60.44b(j) or (k) shall maintain records of the following information for each steam generating unit operating day:

(1) Calendar date;

(2) The number of hours of operation; and

(3) A record of the hourly steam load.

(q) The owner or operator of an affected facility described in §60.44b(j) or §60.44b(k) shall submit to the Administrator a report containing:

(1) The annual capacity factor over the previous 12 months;

(2) The average fuel nitrogen content during the reporting period, if residual oil was fired; and

(3) If the affected facility meets the criteria described in §60.44b(j), the results of any NO_X emission tests required during the reporting period, the hours of operation during the reporting period, and the hours of operation since the last NO_X emission test.

(r) The owner or operator of an affected facility who elects to use the fuel based compliance alternatives in §60.42b or §60.43b shall either:

(1) The owner or operator of an affected facility who elects to demonstrate that the affected facility combusts only very low sulfur oil, natural gas, wood, a mixture of these fuels, or any of these fuels (or a mixture of these fuels) in combination with other fuels that are known to contain an insignificant amount of sulfur in §60.42b(j) or §60.42b(k) shall obtain and maintain at the affected facility fuel receipts from the fuel supplier that certify that the oil meets the definition of distillate oil and gaseous fuel meets the definition of natural gas as defined in §60.41b and the applicable sulfur limit. For the purposes of this section, the distillate oil need not meet the fuel nitrogen content specification in the definition of distillate oil. Reports shall be submitted to the Administrator certifying that only very low sulfur oil meeting this definition, natural gas, wood, and/or other fuels that are known to contain insignificant amounts of sulfur were combusted in the affected facility during the reporting period; or

(2) The owner or operator of an affected facility who elects to demonstrate compliance based on fuel analysis in §60.42b or §60.43b shall develop and submit a site-specific fuel analysis plan to the Administrator for review and approval no later than 60 days before the date you intend to demonstrate compliance. Each fuel analysis plan shall include a minimum initial requirement of weekly testing and each analysis report shall contain, at a minimum, the following information:

(i) The potential sulfur emissions rate of the representative fuel mixture in ng/J heat input;

(ii) The method used to determine the potential sulfur emissions rate of each constituent of the mixture. For distillate oil and natural gas a fuel receipt or tariff sheet is acceptable;

(iii) The ratio of different fuels in the mixture; and

(iv) The owner or operator can petition the Administrator to approve monthly or quarterly sampling in place of weekly sampling.

(s) Facility specific NO_X standard for Cytec Industries Fortier Plant's C.AOG incinerator located in Westwego, Louisiana:

(1) *Definitions* .

Oxidation zone is defined as the portion of the C.AOG incinerator that extends from the inlet of the oxidizing zone combustion air to the outlet gas stack.

Reducing zone is defined as the portion of the C.AOG incinerator that extends from the burner section to the inlet of the oxidizing zone combustion air.

Total inlet air is defined as the total amount of air introduced into the C.AOG incinerator for combustion of natural gas and chemical by-product waste and is equal to the sum of the air flow into the reducing zone and the air flow into the oxidation zone.

(2) *Standard for nitrogen oxides* . (i) When fossil fuel alone is combusted, the NO_X emission limit for fossil fuel in §60.44b(a) applies.

(ii) When natural gas and chemical by-product waste are simultaneously combusted, the NO_X emission limit is 289 ng/J (0.67 lb/MMBtu) and a maximum of 81 percent of the total inlet air provided for combustion shall be provided to the reducing zone of the C.AOG incinerator.

(3) *Emission monitoring* . (i) The percent of total inlet air provided to the reducing zone shall be determined at least every 15 minutes by measuring the air flow of all the air entering the reducing zone and the air flow of all the air entering the oxidation zone, and compliance with the percentage of total inlet air that is provided to the reducing zone shall be determined on a 3-hour average basis.

(ii) The NO_X emission limit shall be determined by the compliance and performance test methods and procedures for NO_X in §60.46b(i).

(iii) The monitoring of the NO_X emission limit shall be performed in accordance with §60.48b.

(4) *Reporting and recordkeeping requirements* . (i) The owner or operator of the C.AOG incinerator shall submit a report on any excursions from the limits required by paragraph (a)(2) of this section to the Administrator with the quarterly report required by paragraph (i) of this section.

(ii) The owner or operator of the C.AOG incinerator shall keep records of the monitoring required by paragraph (a)(3) of this section for a period of 2 years following the date of such record.

(iii) The owner of operator of the C.AOG incinerator shall perform all the applicable reporting and recordkeeping requirements of this section.

(t) Facility-specific NO_X standard for Rohm and Haas Kentucky Incorporated's Boiler No. 100 located in Louisville, Kentucky:

(1) *Definitions* .

Air ratio control damper is defined as the part of the low NO_X burner that is adjusted to control the split of total combustion air delivered to the reducing and oxidation portions of the combustion flame.

Flue gas recirculation line is defined as the part of Boiler No. 100 that recirculates a portion of the boiler flue gas back into the combustion air.

(2) *Standard for nitrogen oxides* . (i) When fossil fuel alone is combusted, the NO_X emission limit for fossil fuel in §60.44b(a) applies.

(ii) When fossil fuel and chemical by-product waste are simultaneously combusted, the NO_X emission limit is 473 ng/J (1.1 lb/MMBtu), and the air ratio control damper tee handle shall be at a minimum of 5 inches (12.7 centimeters) out of the boiler, and the flue gas recirculation line shall be operated at a minimum of 10 percent open as indicated by its valve opening position indicator.

(3) *Emission monitoring for nitrogen oxides* . (i) The air ratio control damper tee handle setting and the flue gas recirculation line valve opening position indicator setting shall be recorded during each 8-hour operating shift.

(ii) The NO_X emission limit shall be determined by the compliance and performance test methods and procedures for NO_X in §60.46b.

(iii) The monitoring of the NO_X emission limit shall be performed in accordance with §60.48b.

(4) *Reporting and recordkeeping requirements* . (i) The owner or operator of Boiler No. 100 shall submit a report on any excursions from the limits required by paragraph (b)(2) of this section to the Administrator with the quarterly report required by §60.49b(i).

(ii) The owner or operator of Boiler No. 100 shall keep records of the monitoring required by paragraph (b)(3) of this section for a period of 2 years following the date of such record.

(iii) The owner of operator of Boiler No. 100 shall perform all the applicable reporting and recordkeeping requirements of §60.49b.

(u) *Site-specific standard for Merck & Co., Inc.'s Stonewall Plant in Elkton, Virginia* . (1) This paragraph (u) applies only to the pharmaceutical manufacturing facility, commonly referred to as the Stonewall Plant, located at Route 340 South, in Elkton, Virginia ("site") and only to the natural gas-fired boilers installed as part of the powerhouse conversion required pursuant to 40 CFR 52.2454(g). The requirements of this paragraph shall apply, and the requirements of §§60.40b through 60.49b(t) shall not apply, to the natural gas-fired boilers installed pursuant to 40 CFR 52.2454(g).

(i) The site shall equip the natural gas-fired boilers with low NO_X technology.

(ii) The site shall install, calibrate, maintain, and operate a continuous monitoring and recording system for measuring NO_X emissions discharged to the atmosphere and opacity using a continuous emissions monitoring system or a predictive emissions monitoring system.

(iii) Within 180 days of the completion of the powerhouse conversion, as required by 40 CFR 52.2454, the site shall perform a performance test to quantify criteria pollutant emissions.

(2) [Reserved]

(v) The owner or operator of an affected facility may submit electronic quarterly reports for $SO_2$and/or NO_X and/or opacity in lieu of submitting the written reports required under paragraphs (h), (i), (j), (k) or (l) of this section. The format of each quarterly electronic report shall be coordinated with the permitting authority. The electronic report(s) shall be submitted no later than 30 days after the end of the calendar quarter and shall be accompanied by a certification statement from the owner or operator, indicating whether compliance with the applicable emission standards and minimum data requirements of this subpart was achieved during the reporting period. Before submitting reports in the electronic format, the owner or operator shall coordinate with the permitting authority to obtain their agreement to submit reports in this alternative format.

(w) The reporting period for the reports required under this subpart is each 6 month period. All reports shall be submitted to the Administrator and shall be postmarked by the 30th day following the end of the reporting period.

(x) Facility-specific NO_X standard for Weyerhaeuser Company's No. 2 Power Boiler located in New Bern, North Carolina:

(1) *Standard for nitrogen oxides* . (i) When fossil fuel alone is combusted, the NO_X emission limit for fossil fuel in §60.44b(a) applies.

(ii) When fossil fuel and chemical by-product waste are simultaneously combusted, the NO_X emission limit is 215 ng/J (0.5 lb/MMBtu).

(2) *Emission monitoring for nitrogen oxides* . (i) The NO_X emissions shall be determined by the compliance and performance test methods and procedures for NO_X in §60.46b.

(ii) The monitoring of the NO_X emissions shall be performed in accordance with §60.48b.

(3) *Reporting and recordkeeping requirements* . (i) The owner or operator of the No. 2 Power Boiler shall submit a report on any excursions from the limits required by paragraph (x)(2) of this section to the Administrator with the quarterly report required by §60.49b(i).

(ii) The owner or operator of the No. 2 Power Boiler shall keep records of the monitoring required by paragraph (x)(3) of this section for a period of 2 years following the date of such record.

(iii) The owner or operator of the No. 2 Power Boiler shall perform all the applicable reporting and recordkeeping requirements of §60.49b.

(y) Facility-specific NO_X standard for INEOS USA's AOGI located in Lima, Ohio:

(1) *Standard for* NO_X . (i) When fossil fuel alone is combusted, the NO_X emission limit for fossil fuel in §60.44b(a) applies.

(ii) When fossil fuel and chemical byproduct/waste are simultaneously combusted, the NO_X emission limit is 645 ng/J (1.5 lb/MMBtu).

(2) *Emission monitoring for* NO_X . (i) The NO_X emissions shall be determined by the compliance and performance test methods and procedures for NO_X in §60.46b.

(ii) The monitoring of the NO_X emissions shall be performed in accordance with §60.48b.

(3) *Reporting and recordkeeping requirements* . (i) The owner or operator of the AOGI shall submit a report on any excursions from the limits required by paragraph (y)(2) of this section to the Administrator with the quarterly report required by paragraph (i) of this section.

(ii) The owner or operator of the AOGI shall keep records of the monitoring required by paragraph (y)(3) of this section for a period of 2 years following the date of such record.

(iii) The owner or operator of the AOGI shall perform all the applicable reporting and recordkeeping requirements of this section.

Attachment B – Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction Is Commenced After August 17, 1971 [326 IAC 12] [40 CFR Part 60, Subpart D]

Source Description and Location

Source Name:	Purdue University - West Lafayette
Source Location:	401 S. Grant St., Freehafer Hall of Administrative Services, West Lafayette, IN 47907
County:	Tippecanoe
SIC Code:	8221
Operation Permit Renewal No.:	T 157-27313-00012
Permit Reviewer:	Kimberly Cottrell

NSPS [40 CFR Part 60, Subpart D]

Subpart D—Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction Is Commenced After August 17, 1971

Source: 72 FR 32717, June 13, 2007, unless otherwise noted.

§ 60.40 Applicability and designation of affected facility.

(a) The affected facilities to which the provisions of this subpart apply are:

(1) Each fossil-fuel-fired steam generating unit of more than 73 megawatts (MW) heat input rate (250 million British thermal units per hour (MMBtu/hr)).

(2) Each fossil-fuel and wood-residue-fired steam generating unit capable of firing fossil fuel at a heat input rate of more than 73 MW (250 MMBtu/hr).

(b) Any change to an existing fossil-fuel-fired steam generating unit to accommodate the use of combustible materials, other than fossil fuels as defined in this subpart, shall not bring that unit under the applicability of this subpart.

(c) Except as provided in paragraph (d) of this section, any facility under paragraph (a) of this section that commenced construction or modification after August 17, 1971, is subject to the requirements of this subpart.

(d) The requirements of §§60.44 (a)(4), (a)(5), (b) and (d), and 60.45(f)(4)(vi) are applicable to lignite-fired steam generating units that commenced construction or modification after December 22, 1976.

(e) Any facility covered under subpart Da is not covered under this subpart.

§ 60.41 Definitions.

As used in this subpart, all terms not defined herein shall have the meaning given them in the Act, and in subpart A of this part.

Boiler operating day means a 24-hour period between 12 midnight and the following midnight during which any fuel is combusted at any time in the steam-generating unit. It is not necessary for fuel to be combusted the entire 24-hour period.

Coal means all solid fuels classified as anthracite, bituminous, subbituminous, or lignite by ASTM D388 (incorporated by reference, see §60.17).

Coal refuse means waste-products of coal mining, cleaning, and coal preparation operations (e.g. culm, gob, etc.) containing coal, matrix material, clay, and other organic and inorganic material.

Fossil fuel means natural gas, petroleum, coal, and any form of solid, liquid, or gaseous fuel derived from such materials for the purpose of creating useful heat.

Fossil fuel and wood residue-fired steam generating unit means a furnace or boiler used in the process of burning fossil fuel and wood residue for the purpose of producing steam by heat transfer.

Fossil-fuel-fired steam generating unit means a furnace or boiler used in the process of burning fossil fuel for the purpose of producing steam by heat transfer.

Wood residue means bark, sawdust, slabs, chips, shavings, mill trim, and other wood products derived from wood processing and forest management operations.

§ 60.42 Standard for particulate matter (PM).

(a) On and after the date on which the performance test required to be conducted by §60.8 is completed, no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any affected facility any gases that:

(1) Contain PM in excess of 43 nanograms per joule (ng/J) heat input (0.10 lb/MMBtu) derived from fossil fuel or fossil fuel and wood residue.

(2) Exhibit greater than 20 percent opacity except for one six-minute period per hour of not more than 27 percent opacity.

(b)(1) On or after December 28, 1979, no owner or operator shall cause to be discharged into the atmosphere from the Southwestern Public Service Company's Harrington Station #1, in Amarillo, TX, any gases which exhibit greater than 35 percent opacity, except that a maximum or 42 percent opacity shall be permitted for not more than 6 minutes in any hour.

(2) Interstate Power Company shall not cause to be discharged into the atmosphere from its Lansing Station Unit No. 4 in Lansing, IA, any gases which exhibit greater than 32 percent opacity, except that a maximum of 39 percent opacity shall be permitted for not more than six minutes in any hour.

(c) As an alternate to meeting the requirements of paragraph (a) of this section, an owner or operator that elects to install, calibrate, maintain, and operate a continuous emissions monitoring systems (CEMS) for measuring PM emissions can petition the Administrator (in writing) to comply with §60.42Da(a) of subpart Da of this part. If the Administrator grants the petition, the source will from then on (unless the unit is modified or reconstructed in the future) have to comply with the requirements in §60.43Da(a) of subpart Da of this part.

[60 FR 65415, Dec. 19, 1995, as amended at 74 FR 5077, Jan. 28, 2009]

§ 60.43 Standard for sulfur dioxide (SO_2).

(a) Except as provided under paragraph (d) of this section, on and after the date on which the performance test required to be conducted by §60.8 is completed, no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any affected facility any gases that contain SO_2in excess of:

(1) 340 ng/J heat input (0.80 lb/MMBtu) derived from liquid fossil fuel or liquid fossil fuel and wood residue.

(2) 520 ng/J heat input (1.2 lb/MMBtu) derived from solid fossil fuel or solid fossil fuel and wood residue, except as provided in paragraph (e) of this section.

(b) Except as provided under paragraph (d) of this section, when different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) shall be determined by proration using the following formula:

$$PS_{SO_2} = \frac{y\,(340) + z\,(520)}{(y + z)}$$

Where:

$PS_{SO}2$= Prorated standard for $S_{O2}$when burning different fuels simultaneously, in ng/J heat input derived from all fossil fuels or from all fossil fuels and wood residue fired;

y = Percentage of total heat input derived from liquid fossil fuel; and

z = Percentage of total heat input derived from solid fossil fuel.

(c) Compliance shall be based on the total heat input from all fossil fuels burned, including gaseous fuels.

(d) As an alternate to meeting the requirements of paragraphs (a) and (b) of this section, an owner or operator can petition the Administrator (in writing) to comply with §60.43Da(i)(3) of subpart Da of this part or comply with §60.42b(k)(4) of subpart Db of this part, as applicable to the affected source. If the Administrator grants the petition, the source will from then on (unless the unit is modified or reconstructed in the future) have to comply with the requirements in §60.43Da(i)(3) of subpart Da of this part or §60.42b(k)(4) of subpart Db of this part, as applicable to the affected source.

(e) Units 1 and 2 (as defined in appendix G of this part) at the Newton Power Station owned or operated by the Central Illinois Public Service Company will be in compliance with paragraph (a)(2) of this section if Unit 1 and Unit 2 individually comply with paragraph (a)(2) of this section or if the combined emission rate from Units 1 and 2 does not exceed 470 ng/J (1.1 lb/MMBtu) combined heat input to Units 1 and 2.

[60 FR 65415, Dec. 19, 1995, as amended at 74 FR 5077, Jan. 28, 2009]

§ 60.44 Standard for nitrogen oxides (NOX).

(a) Except as provided under paragraph (e) of this section, on and after the date on which the performance test required to be conducted by §60.8 is completed, no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any affected facility any gases that contain NO_X, expressed as NO_2in excess of:

(1) 86 ng/J heat input (0.20 lb/MMBtu) derived from gaseous fossil fuel.

(2) 129 ng/J heat input (0.30 lb/MMBtu) derived from liquid fossil fuel, liquid fossil fuel and wood residue, or gaseous fossil fuel and wood residue.

(3) 300 ng/J heat input (0.70 lb/MMBtu) derived from solid fossil fuel or solid fossil fuel and wood residue (except lignite or a solid fossil fuel containing 25 percent, by weight, or more of coal refuse).

(4) 260 ng/J heat input (0.60 lb MMBtu) derived from lignite or lignite and wood residue (except as provided under paragraph (a)(5) of this section).

(5) 340 ng/J heat input (0.80 lb MMBtu) derived from lignite which is mined in North Dakota, South Dakota, or Montana and which is burned in a cyclone-fired unit.

(b) Except as provided under paragraphs (c), (d), and (e) of this section, when different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) is determined by proration using the following formula:

$$PS_{NO_x} = \frac{w\,(260) + x\,(86) + y\,(130) + z\,(300)}{(w + x + y + z)}$$

Where:

PS_{NOX}= Prorated standard for $NO_X$when burning different fuels simultaneously, in ng/J heat input derived from all fossil fuels fired or from all fossil fuels and wood residue fired;

w = Percentage of total heat input derived from lignite;

x = Percentage of total heat input derived from gaseous fossil fuel;

y = Percentage of total heat input derived from liquid fossil fuel; and

z = Percentage of total heat input derived from solid fossil fuel (except lignite).

(c) When a fossil fuel containing at least 25 percent, by weight, of coal refuse is burned in combination with gaseous, liquid, or other solid fossil fuel or wood residue, the standard for NO_Xdoes not apply.

(d) Except as provided under paragraph (e) of this section, cyclone-fired units which burn fuels containing at least 25 percent of lignite that is mined in North Dakota, South Dakota, or Montana remain subject to paragraph (a)(5) of this section regardless of the types of fuel combusted in combination with that lignite.

(e) As an alternate to meeting the requirements of paragraphs (a), (b), and (d) of this section, an owner or operator can petition the Administrator (in writing) to comply with §60.44Da(e)(3) of subpart Da of this part. If the Administrator grants the petition, the source will from then on (unless the unit is modified or reconstructed in the future) have to comply with the requirements in §60.44Da(e)(3) of subpart Da of this part.

§ 60.45 Emissions and fuel monitoring.

(a) Each owner or operator shall install, calibrate, maintain, and operate continuous opacity monitoring system (COMS) for measuring opacity and a CEMS for measuring SO2emissions, NOXemissions, and either oxygen (O2) or carbon dioxide (CO2) except as provided in paragraph (b) of this section.

(b) Certain of the CEMS requirements under paragraph (a) of this section do not apply to owners or operators under the following conditions:

(1) For a fossil-fuel-fired steam generator that burns only gaseous or liquid fossil fuel (excluding residual oil) with potential SO2emissions rates of 26 ng/J (0.060 lb/MMBtu) or less and that does not use post-combustion technology to reduce emissions of SO2or PM, CEMS for measuring the opacity of emissions and SO2 emissions are not required if the owner or operator monitors SO2emissions by fuel sampling and analysis or fuel receipts.

(2) For a fossil-fuel-fired steam generator that does not use a flue gas desulfurization device, a CEMS for measuring SO_2emissions is not required if the owner or operator monitors SO_2emissions by fuel sampling and analysis.

(3) Notwithstanding §60.13(b), installation of a CEMS for NO_Xmay be delayed until after the initial performance tests under §60.8 have been conducted. If the owner or operator demonstrates during the performance test that emissions of $NO_X$are less than 70 percent of the applicable standards in §60.44, a CEMS for measuring NO_Xemissions is not required. If the initial performance test results show that NO_Xemissions are greater than 70 percent of the applicable standard, the owner or operator shall install a CEMS for NO_Xwithin one year after the date of the initial performance tests under §60.8 and comply with all other applicable monitoring requirements under this part.

(4) If an owner or operator does not install any CEMS for sulfur oxides and NO_X, as provided under paragraphs (b)(1) and (b)(3) or paragraphs (b)(2) and (b)(3) of this section a CEMS for measuring either O_2or $CO_2$is not required.

(5) An owner or operator may petition the Administrator (in writing) to install a PM CEMS as an alternative to the CEMS for monitoring opacity emissions.

(6) A CEMS for measuring the opacity of emissions is not required for a fossil fuel-fired steam generator that does not use post-combustion technology (except a wet scrubber) for reducing PM, SO_2, or carbon monoxide (CO) emissions, burns only gaseous fuels or fuel oils that contain less than or equal to 0.30 weight percent sulfur, and is operated such that emissions of CO to the atmosphere from the affected source are maintained at levels less than or equal to 0.15 lb/MMBtu on a boiler operating day average basis. Owners and operators of affected sources electing to comply with this paragraph must demonstrate compliance according to the procedures specified in paragraphs (b)(6)(i) through (iv) of this section.

(i) You must monitor CO emissions using a CEMS according to the procedures specified in paragraphs (b)(6)(i)(A) through (D) of this section.

(A) The CO CEMS must be installed, certified, maintained, and operated according to the provisions in §60.58b(i)(3) of subpart Eb of this part.

(B) Each 1-hour CO emissions average is calculated using the data points generated by the CO CEMS expressed in parts per million by volume corrected to 3 percent oxygen (dry basis).

(C) At a minimum, valid 1-hour CO emissions averages must be obtained for at least 90 percent of the operating hours on a 30-day rolling average basis. The 1-hour averages are calculated using the data points required in §60.13(h)(2).

(D) Quarterly accuracy determinations and daily calibration drift tests for the CO CEMS must be performed in accordance with procedure 1 in appendix F of this part.

(ii) You must calculate the 1-hour average CO emissions levels for each boiler operating day by multiplying the average hourly CO output concentration measured by the CO CEMS times the corresponding average hourly flue gas flow rate and divided by the corresponding average hourly heat input to the affected source. The 24-hour average CO emission level is determined by calculating the arithmetic average of the hourly CO emission levels computed for each boiler operating day.

(iii) You must evaluate the preceding 24-hour average CO emission level each boiler operating day excluding periods of affected source startup, shutdown, or malfunction. If the 24-hour average CO emission level is greater than 0.15 lb/MMBtu, you must initiate investigation of the relevant equipment and control systems within 24 hours of the first discovery of the high emission incident and, take the appropriate corrective action as soon as practicable to adjust control settings or repair equipment to reduce the 24-hour average CO emission level to 0.15 lb/MMBtu or less.

(iv) You must record the CO measurements and calculations performed according to paragraph (b)(6) of this section and any corrective actions taken. The record of corrective action taken must include the date and time during which the 24-hour average CO emission level was greater than 0.15 lb/MMBtu, and the date, time, and description of the corrective action.

(7) The owner or operator of an affected facility subject to an opacity standard under §60.42 and that elects to not install a COMS because the affected facility burns only fuels as specified under paragraph (b)(1) of this section, monitors PM emissions as specified under paragraph (b)(5) of this section, or monitors CO emissions as specified under paragraph (b)(6) of this section shall conduct a performance test using Method 9 of appendix A–4 of this part and the procedures in §60.11 to demonstrate compliance with the applicable limit in §60.42 and shall comply with either paragraphs (b)(7)(i), (b)(7)(ii), or (b)(7)(iii) of this section. If during the initial 60 minutes of observation all 6-minute averages are less than 10 percent and all individual 15-second observations are less than or equal to 20 percent, the observation period may be reduced from 3 hours to 60 minutes.

(i) Except as provided in paragraph (b)(7)(ii) or (b)(7)(iii) of this section, the owner or operator shall conduct subsequent Method 9 of appendix A–4 of this part performance tests using the procedures in paragraph (b)(7) of this section according to the applicable schedule in paragraphs (b)(7)(i)(A) through (b)(7)(i)(D) of this section, as determined by the most recent Method 9 of appendix A–4 of this part performance test results.

(A) If no visible emissions are observed, a subsequent Method 9 of appendix A–4 of this part performance test must be completed within 12 calendar months from the date that the most recent performance test was conducted;

(B) If visible emissions are observed but the maximum 6-minute average opacity is less than or equal to 5 percent, a subsequent Method 9 of appendix A–4 of this part performance test must be completed within 6 calendar months from the date that the most recent performance test was conducted;

(C) If the maximum 6-minute average opacity is greater than 5 percent but less than or equal to 10 percent, a subsequent Method 9 of appendix A–4 of this part performance test must be completed within 3 calendar months from the date that the most recent performance test was conducted; or

(D) If the maximum 6-minute average opacity is greater than 10 percent, a subsequent Method 9 of appendix A–4 of this part performance test must be completed within 30 calendar days from the date that the most recent performance test was conducted.

(ii) If the maximum 6-minute opacity is less than 10 percent during the most recent Method 9 of appendix A–4 of this part performance test, the owner or operator may, as an alternative to performing subsequent Method 9 of appendix A–4 of this part performance test, elect to perform subsequent monitoring using Method 22 of appendix A–7 of this part according to the procedures specified in paragraphs (b)(7)(ii)(A) and (B) of this section.

(A) The owner or operator shall conduct 10 minute observations (during normal operation) each operating day the affected facility fires fuel for which an opacity standard is applicable using Method 22 of appendix A–7 of this part and demonstrate that the sum of the occurrences of any visible emissions is not in excess of 5 percent of the observation period (*i.e.* , 30 seconds per 10 minute period). If the sum of the occurrence of any visible emissions is greater than 30 seconds during the initial 10 minute observation, immediately conduct a 30 minute observation. If the sum of the occurrence of visible emissions is greater than 5 percent of the observation period (*i.e.* , 90 seconds per 30 minute period) the owner or operator shall either document and adjust the operation of the facility and demonstrate within 24 hours that the sum of the occurrence of visible emissions is equal to or less than 5 percent during a 30 minute observation (*i.e.* , 90 seconds) or conduct a new Method 9 of appendix A–4 of this part performance test using the procedures in paragraph (b)(7) of this section within 30 calendar days according to the requirements in §60.46(b)(3).

(B) If no visible emissions are observed for 30 operating days during which an opacity standard is applicable, observations can be reduced to once every 7 operating days during which an opacity standard is applicable. If any visible emissions are observed, daily observations shall be resumed.

(iii) If the maximum 6-minute opacity is less than 10 percent during the most recent Method 9 of appendix A–4 of this part performance test, the owner or operator may, as an alternative to performing subsequent Method 9 of appendix A–4 performance tests, elect to perform subsequent monitoring using a digital opacity compliance system according to a site-specific monitoring plan approved by the Administrator. The observations shall be similar, but not necessarily identical, to the requirements in paragraph (b)(7)(ii) of this section. For reference purposes in preparing the monitoring plan, see OAQPS “Determination of Visible Emission Opacity from Stationary Sources Using Computer-Based Photographic Analysis Systems.” This document is available from the U.S. Environmental Protection Agency (U.S. EPA); Office of Air Quality and Planning Standards; Sector Policies and Programs Division; Measurement Policy Group (D243–02), Research Triangle Park, NC 27711. This document is also available on the Technology Transfer Network (TTN) under Emission Measurement Center Preliminary Methods.

(c) For performance evaluations under §60.13(c) and calibration checks under §60.13(d), the following procedures shall be used:

(1) Methods 6, 7, and 3B of appendix A of this part, as applicable, shall be used for the performance evaluations of $SO_2$and NO_Xcontinuous monitoring systems. Acceptable alternative methods for Methods 6, 7, and 3B of appendix A of this part are given in §60.46(d).

(2) Sulfur dioxide or nitric oxide, as applicable, shall be used for preparing calibration gas mixtures under Performance Specification 2 of appendix B to this part.

(3) For affected facilities burning fossil fuel(s), the span value for a continuous monitoring system measuring the opacity of emissions shall be 80, 90, or 100 percent. For a continuous monitoring system measuring sulfur oxides or $NO_X$the span value shall be determined using one of the following procedures:

(i) Except as provided under paragraph (c)(3)(ii) of this section, $SO_2$and NO_Xspan values shall be determined as follows:

Fossil fuel	In parts per million	
	Span value for SO_2	Span value for NO_X
Gas	([1])	500.
Liquid	1,000	500.
Solid	1,500	1,000.
Combinations	1,000y + 1,500z	500 (x + y) + 1,000z.

[1]Not applicable.

Where:

x = Fraction of total heat input derived from gaseous fossil fuel;

y = Fraction of total heat input derived from liquid fossil fuel; and

z = Fraction of total heat input derived from solid fossil fuel.

(ii) As an alternative to meeting the requirements of paragraph (c)(3)(i) of this section, the owner or operator of an affected facility may elect to use the $SO_2$and NO_Xspan values determined according to sections 2.1.1 and 2.1.2 in appendix A to part 75 of this chapter.

(4) All span values computed under paragraph (c)(3)(i) of this section for burning combinations of fossil fuels shall be rounded to the nearest 500 ppm. Span values that are computed under paragraph (c)(3)(ii) of this section shall be rounded off according to the applicable procedures in section 2 of appendix A to part 75 of this chapter.

(5) For a fossil-fuel-fired steam generator that simultaneously burns fossil fuel and nonfossil fuel, the span value of all CEMS shall be subject to the Administrator's approval.

(d) [Reserved]

(e) For any CEMS installed under paragraph (a) of this section, the following conversion procedures shall be used to convert the continuous monitoring data into units of the applicable standards (ng/J, lb/MMBtu):

(1) When a CEMS for measuring $O_2$is selected, the measurement of the pollutant concentration and O_2concentration shall each be on a consistent basis (wet or dry). Alternative procedures approved by the Administrator shall be used when measurements are on a wet basis. When measurements are on a dry basis, the following conversion procedure shall be used:

$$E = CF\left(\frac{20.9}{(20.9 - \%O_2)}\right)$$

Where E, C, F, and $\%O_2$ are determined under paragraph (f) of this section.

(2) When a CEMS for measuring CO_2 is selected, the measurement of the pollutant concentration and CO_2 concentration shall each be on a consistent basis (wet or dry) and the following conversion procedure shall be used:

$$E = CF_c\left(\frac{100}{\%CO_2}\right)$$

Where E, C, F_c and $\%CO_2$ are determined under paragraph (f) of this section.

(f) The values used in the equations under paragraphs (e)(1) and (2) of this section are derived as follows:

(1) E = pollutant emissions, ng/J (lb/MMBtu).

(2) C = pollutant concentration, ng/dscm (lb/dscf), determined by multiplying the average concentration (ppm) for each one-hour period by 4.15×10^4 M ng/dscm per ppm (2.59×10^{-9}M lb/dscf per ppm) where M = pollutant molecular weight, g/g-mole (lb/lb-mole). M = 64.07 for SO_2 and 46.01 for NO_X.

(3) $\%O_2$, $\%CO_2$ = O_2 or CO_2 volume (expressed as percent), determined with equipment specified under paragraph (a) of this section.

(4) F, F_c = a factor representing a ratio of the volume of dry flue gases generated to the calorific value of the fuel combusted (F), and a factor representing a ratio of the volume of CO_2 generated to the calorific value of the fuel combusted (F_c), respectively. Values of F and F_c are given as follows:

(i) For anthracite coal as classified according to ASTM D388 (incorporated by reference, see §60.17), F = $2{,}723 \times 10^{-17}$dscm/J (10,140 dscf/MMBtu) and F_c = 0.532×10^{-17}scm CO_2/J (1,980 scf CO_2/MMBtu).

(ii) For subbituminous and bituminous coal as classified according to ASTM D388 (incorporated by reference, see §60.17), F = 2.637×10^{-7}dscm/J (9,820 dscf/MMBtu) and F_c = 0.486×10^{-7}scm CO_2/J (1,810 scf CO_2/MMBtu).

(iii) For liquid fossil fuels including crude, residual, and distillate oils, F = 2.476×10^{-7}dscm/J (9,220 dscf/MMBtu) and F_c = 0.384×10^{-7}scm CO_2/J (1,430 scf CO_2/MMBtu).

(iv) For gaseous fossil fuels, F = 2.347×10^{-7}dscm/J (8,740 dscf/MMBtu). For natural gas, propane, and butane fuels, F_c = 0.279×10^{-7}scm CO_2/J (1,040 scf CO_2/MMBtu) for natural gas, 0.322×10^{-7}scm CO_2/J (1,200 scf CO_2/MMBtu) for propane, and 0.338×10^{-7}scm CO_2/J (1,260 scf CO_2/MMBtu) for butane.

(v) For bark F = 2.589×10^{-7}dscm/J (9,640 dscf/MMBtu) and F_c = 0.500×10^{-7}scm CO_2/J (1,840 scf CO_2/MMBtu). For wood residue other than bark F = 2.492×10^{-7}dscm/J (9,280 dscf/MMBtu) and F_c = 0.494×10^{-7}scm CO_2/J (1,860 scf CO_2/MMBtu).

(vi) For lignite coal as classified according to ASTM D388 (incorporated by reference, see §60.17), F = 2.659×10^{-7}dscm/J (9,900 dscf/MMBtu) and F_c = 0.516×10^{-7}scm CO_2/J (1,920 scf CO_2/MMBtu).

(5) The owner or operator may use the following equation to determine an F factor (dscm/J or dscf/MMBtu) on a dry basis (if it is desired to calculate F on a wet basis, consult the Administrator) or Fc factor (scm CO_2/J, or scf CO_2/MMBtu) on either basis in lieu of the F or F_c factors specified in paragraph (f)(4) of this section:

$$F = 10^{-6} \frac{[227.2\ (\%H) + 95.5\ (\%C) + 35.6\ (\%S) + 8.7\ (\%N) - 28.7\ (\%O)]}{GCV}$$

$$F_c = \frac{2.0 \times 10^{-5} (\%C)}{GCV\ (SI\ units)}$$

$$F = 10^{-6} \frac{[3.64\ (\%H) + 1.53\ (\%C) + 0.57\ (\%S) + 0.14\ (\%N) - 0.46\ (\%O)]}{GCV\ (English\ units)}$$

$$F_c = \frac{20.0\ (\%C)}{GCV\ (SI\ units)}$$

$$F_c = \frac{321 \times 10^{3}\ (\%C)}{GCV\ (English\ units)}$$

(i) %H, %C, %S, %N, and %O are content by weight of hydrogen, carbon, sulfur, nitrogen, and O_2(expressed as percent), respectively, as determined on the same basis as GCV by ultimate analysis of the fuel fired, using ASTM D3178 or D3176 (solid fuels), or computed from results using ASTM D1137, D1945, or D1946 (gaseous fuels) as applicable. (These five methods are incorporated by reference, see §60.17.)

(ii) GVC is the gross calorific value (kJ/kg, Btu/lb) of the fuel combusted determined by the ASTM test methods D2015 or D5865 for solid fuels and D1826 for gaseous fuels as applicable. (These three methods are incorporated by reference, see §60.17.)

(iii) For affected facilities which fire both fossil fuels and nonfossil fuels, the F or Fc value shall be subject to the Administrator's approval.

(6) For affected facilities firing combinations of fossil fuels or fossil fuels and wood residue, the F or Fc factors determined by paragraphs (f)(4) or (f)(5) of this section shall be prorated in accordance with the applicable formula as follows:

$$F = \sum_{i=1}^{n} X_i F_i \quad \text{or} \quad F_c = \sum_{i=1}^{n} X_i (F_c)_i$$

Where:

X_i= Fraction of total heat input derived from each type of fuel (e.g. natural gas, bituminous coal, wood residue, etc.);

$F_i$or $(F_c)_i$= Applicable F or $F_c$factor for each fuel type determined in accordance with paragraphs (f)(4) and (f)(5) of this section; and

n = Number of fuels being burned in combination.

(g) Excess emission and monitoring system performance reports shall be submitted to the Administrator semiannually for each six-month period in the calendar year. All semiannual reports shall be postmarked by the 30th day following the end of each six-month period. Each excess emission and MSP report shall include the information required in §60.7(c). Periods of excess emissions and monitoring systems (MS) downtime that shall be reported are defined as follows:

(1) *Opacity* . Excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 20 percent opacity, except that one six-minute average per hour of up to 27 percent opacity need not be reported.

(i) For sources subject to the opacity standard of §60.42(b)(1), excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 35 percent opacity, except that one six-minute average per hour of up to 42 percent opacity need not be reported.

(ii) For sources subject to the opacity standard of §60.42(b)(2), excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 32 percent opacity, except that one six-minute average per hour of up to 39 percent opacity need not be reported.

(2) *Sulfur dioxide.* Excess emissions for affected facilities are defined as:

(i) For affected facilities electing not to comply with §60.43(d), any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) of SO_2as measured by a CEMS exceed the applicable standard in §60.43; or

(ii) For affected facilities electing to comply with §60.43(d), any 30 operating day period during which the average emissions (arithmetic average of all one-hour periods during the 30 operating days) of SO_2as measured by a CEMS exceed the applicable standard in §60.43. Facilities complying with the 30-day SO_2standard shall use the most current associated SO_2compliance and monitoring requirements in §§60.48Da and 60.49Da of subpart Da of this part or §§60.45b and 60.47b of subpart Db of this part, as applicable.

(3) *Nitrogen oxides.* Excess emissions for affected facilities using a CEMS for measuring $NO_X$are defined as:

(i) For affected facilities electing not to comply with §60.44(e), any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) exceed the applicable standards in §60.44; or

(ii) For affected facilities electing to comply with §60.44(e), any 30 operating day period during which the average emissions (arithmetic average of all one-hour periods during the 30 operating days) of NO_Xas measured by a CEMS exceed the applicable standard in §60.44. Facilities complying with the 30-day NO_Xstandard shall use the most current associated NO_Xcompliance and monitoring requirements in §§60.48Da and 60.49Da of subpart Da of this part.

(4) *Particulate matter.* Excess emissions for affected facilities using a CEMS for measuring PM are defined as any boiler operating day period during which the average emissions (arithmetic average of all operating one-hour periods) exceed the applicable standards in §60.42. Affected facilities using PM CEMS must follow the most current applicable compliance and monitoring provisions in §§60.48Da and 60.49Da of subpart Da of this part.

(h) The owner or operator of an affected facility subject to the opacity limits in §60.42 that elects to monitor emissions according to the requirements in §60.45(b)(7) shall maintain records according to the requirements specified in paragraphs (h)(1) through (3) of this section, as applicable to the visible emissions monitoring method used.

(1) For each performance test conducted using Method 9 of appendix A–4 of this part, the owner or operator shall keep the records including the information specified in paragraphs (h)(1)(i) through (iii) of this section.

(i) Dates and time intervals of all opacity observation periods;

(ii) Name, affiliation, and copy of current visible emission reading certification for each visible emission observer participating in the performance test; and

(iii) Copies of all visible emission observer opacity field data sheets;

(2) For each performance test conducted using Method 22 of appendix A–4 of this part, the owner or operator shall keep the records including the information specified in paragraphs (h)(2)(i) through (iv) of this section.

(i) Dates and time intervals of all visible emissions observation periods;

(ii) Name and affiliation for each visible emission observer participating in the performance test;

(iii) Copies of all visible emission observer opacity field data sheets; and

(iv) Documentation of any adjustments made and the time the adjustments were completed to the affected facility operation by the owner or operator to demonstrate compliance with the applicable monitoring requirements.

(3) For each digital opacity compliance system, the owner or operator shall maintain records and submit reports according to the requirements specified in the site-specific monitoring plan approved by the Administrator.

[60 FR 65415, Dec. 19, 1995, as amended at 74 FR 5077, Jan. 28, 2009]

§ 60.46 Test methods and procedures.

(a) In conducting the performance tests required in §60.8, and subsequent performance tests as requested by the EPA Administrator, the owner or operator shall use as reference methods and procedures the test methods in appendix A of this part or other methods and procedures as specified in this section, except as provided in §60.8(b). Acceptable alternative methods and procedures are given in paragraph (d) of this section.

(b) The owner or operator shall determine compliance with the PM, SO_2, and NO_Xstandards in §§60.42, 60.43, and 60.44 as follows:

(1) The emission rate (E) of PM, SO_2, or NO_Xshall be computed for each run using the following equation:

$$E = CF_d\left(\frac{20.9}{(20.9 - \%O_2)}\right)$$

Where:

E = Emission rate of pollutant, ng/J (1b/million Btu);

C = Concentration of pollutant, ng/dscm (1b/dscf);

$\%O_2$= O_2concentration, percent dry basis; and

F_d= Factor as determined from Method 19 of appendix A of this part.

(2) Method 5 of appendix A of this part shall be used to determine the PM concentration (C) at affected facilities without wet flue-gas-desulfurization (FGD) systems and Method 5B of appendix A of this part shall be used to determine the PM concentration (C) after FGD systems.

(i) The sampling time and sample volume for each run shall be at least 60 minutes and 0.85 dscm (30 dscf). The probe and filter holder heating systems in the sampling train shall be set to provide an average gas temperature of 160±14 °C (320±25 °F).

(ii) The emission rate correction factor, integrated or grab sampling and analysis procedure of Method 3B of appendix A of this part shall be used to determine the O_2concentration ($\%O_2$). The O_2sample shall be obtained simultaneously with, and at the same traverse points as, the particulate sample. If the grab sampling procedure is used, the O_2concentration for the run shall be the arithmetic mean of the sample O_2concentrations at all traverse points.

(iii) If the particulate run has more than 12 traverse points, the O_2traverse points may be reduced to 12 provided that Method 1 of appendix A of this part is used to locate the 12 O_2traverse points.

(3) Method 9 of appendix A of this part and the procedures in §60.11 shall be used to determine opacity.

(4) Method 6 of appendix A of this part shall be used to determine the SO_2concentration.

(i) The sampling site shall be the same as that selected for the particulate sample. The sampling location in the duct shall be at the centroid of the cross section or at a point no closer to the walls than 1 m (3.28 ft). The sampling time and sample volume for each sample run shall be at least 20 minutes and 0.020 dscm (0.71 dscf). Two samples shall be taken during a 1-hour period, with each sample taken within a 30-minute interval.

(ii) The emission rate correction factor, integrated sampling and analysis procedure of Method 3B of appendix A of this part shall be used to determine the O_2concentration (%O_2). The O_2sample shall be taken simultaneously with, and at the same point as, the SO_2sample. The SO_2emission rate shall be computed for each pair of $SO_2$and O_2samples. The SO_2emission rate (E) for each run shall be the arithmetic mean of the results of the two pairs of samples.

(5) Method 7 of appendix A of this part shall be used to determine the NO_Xconcentration.

(i) The sampling site and location shall be the same as for the SO_2sample. Each run shall consist of four grab samples, with each sample taken at about 15-minute intervals.

(ii) For each NO_Xsample, the emission rate correction factor, grab sampling and analysis procedure of Method 3B of appendix A of this part shall be used to determine the O_2concentration (%O_2). The sample shall be taken simultaneously with, and at the same point as, the NO_Xsample.

(iii) The NO_Xemission rate shall be computed for each pair of $NO_X$and O_2samples. The NO_Xemission rate (E) for each run shall be the arithmetic mean of the results of the four pairs of samples.

(c) When combinations of fossil fuels or fossil fuel and wood residue are fired, the owner or operator (in order to compute the prorated standard as shown in §§60.43(b) and 60.44(b)) shall determine the percentage (w, x, y, or z) of the total heat input derived from each type of fuel as follows:

(1) The heat input rate of each fuel shall be determined by multiplying the gross calorific value of each fuel fired by the rate of each fuel burned.

(2) ASTM Methods D2015, or D5865 (solid fuels), D240 (liquid fuels), or D1826 (gaseous fuels) (all of these methods are incorporated by reference, see §60.17) shall be used to determine the gross calorific values of the fuels. The method used to determine the calorific value of wood residue must be approved by the Administrator.

(3) Suitable methods shall be used to determine the rate of each fuel burned during each test period, and a material balance over the steam generating system shall be used to confirm the rate.

(d) The owner or operator may use the following as alternatives to the reference methods and procedures in this section or in other sections as specified:

(1) The emission rate (E) of PM, $SO_2$and NO_Xmay be determined by using the Fc factor, provided that the following procedure is used:

(i) The emission rate (E) shall be computed using the following equation:

$$E = CF_c \left(\frac{100}{\%CO_2} \right)$$

Where:

E = Emission rate of pollutant, ng/J (lb/MMBtu);

C = Concentration of pollutant, ng/dscm (lb/dscf);

$\%CO_2$= CO_2concentration, percent dry basis; and

F_c= Factor as determined in appropriate sections of Method 19 of appendix A of this part.

(ii) If and only if the average Fc factor in Method 19 of appendix A of this part is used to calculate E and either E is from 0.97 to 1.00 of the emission standard or the relative accuracy of a continuous emission monitoring system is from 17 to 20 percent, then three runs of Method 3B of appendix A of this part shall be used to determine the $O_2$and CO_2concentration according to the procedures in paragraph (b)(2)(ii), (4)(ii), or (5)(ii) of this section. Then if F_o(average of three runs), as calculated from the equation in Method 3B of appendix A of this part, is more than ±3 percent than the average $F_o$value, as determined from the average values of $F_d$and $F_c$in Method 19 of appendix A of this part, *i.e.* , F_{oa}= 0.209 (F_{da}/F_{ca}), then the following procedure shall be followed:

(A) When $F_o$is less than 0.97 F_{oa}, then E shall be increased by that proportion under 0.97 F_{oa}, *e.g.* , if $F_o$is 0.95 F_{oa}, E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the emission standard.

(B) When $F_o$is less than 0.97 $F_{oa}$and when the average difference (d) between the continuous monitor minus the reference methods is negative, then E shall be increased by that proportion under 0.97 F_{oa}, *e.g.* , if $F_o$is 0.95 F_{oa}, E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(C) When $F_o$is greater than 1.03 $F_{oa}$and when the average difference d is positive, then E shall be decreased by that proportion over 1.03 F_{oa}, *e.g.* , if $F_o$is 1.05 F_{oa}, E shall be decreased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(2) For Method 5 or 5B of appendix A–3 of this part, Method 17 of appendix A–6 of this part may be used at facilities with or without wet FGD systems if the stack gas temperature at the sampling location does not exceed an average temperature of 160 °C (320 °F). The procedures of sections 8.1 and 11.1 of Method 5B of appendix A–3 of this part may be used with Method 17 of appendix A–6 of this part only if it is used after wet FGD systems. Method 17 of appendix A–6 of this part shall not be used after wet FGD systems if the effluent gas is saturated or laden with water droplets.

(3) Particulate matter and SO_2may be determined simultaneously with the Method 5 of appendix A of this part train provided that the following changes are made:

(i) The filter and impinger apparatus in sections 2.1.5 and 2.1.6 of Method 8 of appendix A of this part is used in place of the condenser (section 2.1.7) of Method 5 of appendix A of this part.

(ii) All applicable procedures in Method 8 of appendix A of this part for the determination of SO_2(including moisture) are used:

(4) For Method 6 of appendix A of this part, Method 6C of appendix A of this part may be used. Method 6A of appendix A of this part may also be used whenever Methods 6 and 3B of appendix A of this part data are specified to determine the SO_2emission rate, under the conditions in paragraph (d)(1) of this section.

(5) For Method 7 of appendix A of this part, Method 7A, 7C, 7D, or 7E of appendix A of this part may be used. If Method 7C, 7D, or 7E of appendix A of this part is used, the sampling time for each run shall be at least 1 hour and the integrated sampling approach shall be used to determine the O_2concentration ($\%O_2$) for the emission rate correction factor.

(6) For Method 3 of appendix A of this part, Method 3A or 3B of appendix A of this part may be used.

(7) For Method 3B of appendix A of this part, Method 3A of appendix A of this part may be used.

[60 FR 65415, Dec. 19, 1995, as amended at 74 FR 5078, Jan. 28, 2009]

Attachment C – Standards of Performance for Coal Preparation Plants [326 IAC 12] [40 CFR Part 60, Subpart Y]

Source Description and Location

Source Name:	Purdue University - West Lafayette
Source Location:	401 S. Grant St., Freehafer Hall of Administrative Services, West Lafayette, IN 47907
County:	Tippecanoe
SIC Code:	8221
Operation Permit Renewal No.:	T 157-27313-00012
Permit Reviewer:	Kimberly Cottrell

NSPS [40 CFR Part 60, Subpart Y]

Subpart Y—Standards of Performance for Coal Preparation Plants

§ 60.250 Applicability and designation of affected facility.

(a) The provisions of this subpart are applicable to any of the following affected facilities in coal preparation plants which process more than 181 Mg (200 tons) per day: Thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems, and coal transfer and loading systems.

(b) Any facility under paragraph (a) of this section that commences construction or modification after October 24, 1974, is subject to the requirements of this subpart.

[42 FR 37938, July 25, 1977; 42 FR 44812, Sept. 7, 1977, as amended at 65 FR 61757, Oct. 17, 2000]

§ 60.251 Definitions.

As used in this subpart, all terms not defined herein have the meaning given them in the Act and in subpart A of this part.

(a) *Coal preparation plant* means any facility (excluding underground mining operations) which prepares coal by one or more of the following processes: breaking, crushing, screening, wet or dry cleaning, and thermal drying.

(b) *Bituminous coal* means solid fossil fuel classified as bituminous coal by ASTM Designation D388–77, 90, 91, 95, or 98a (incorporated by reference—see §60.17).

(c) *Coal* means all solid fossil fuels classified as anthracite, bituminous, subbituminous, or lignite by ASTM Designation D388–77, 90, 91, 95, or 98a (incorporated by reference—see §60.17).

(d) *Cyclonic flow* means a spiraling movement of exhaust gases within a duct or stack.

(e) *Thermal dryer* means any facility in which the moisture content of bituminous coal is reduced by contact with a heated gas stream which is exhausted to the atmosphere.

(f) *Pneumatic coal-cleaning equipment* means any facility which classifies bituminous coal by size or separates bituminous coal from refuse by application of air stream(s).

(g) *Coal processing and conveying equipment* means any machinery used to reduce the size of coal or to separate coal from refuse, and the equipment used to convey coal to or remove coal and refuse from the machinery. This includes, but is not limited to, breakers, crushers, screens, and conveyor belts.

(h) *Coal storage system* means any facility used to store coal except for open storage piles.

(i) *Transfer and loading system* means any facility used to transfer and load coal for shipment.

[41 FR 2234, Jan. 15, 1976, as amended at 48 FR 3738, Jan. 27, 1983; 65 FR 61757, Oct. 17, 2000]

§ 60.252 Standards for particulate matter.

(a) On and after the date on which the performance test required to be conducted by §60.8 is completed, an owner or operator subject to the provisions of this subpart shall not cause to be discharged into the atmosphere from any thermal dryer gases which:

(1) Contain particulate matter in excess of 0.070 g/dscm (0.031 gr/dscf).

(2) Exhibit 20 percent opacity or greater.

(b) On and after the date on which the performance test required to be conducted by §60.8 is completed, an owner or operator subject to the provisions of this subpart shall not cause to be discharged into the atmosphere from any pneumatic coal cleaning equipment, gases which:

(1) Contain particulate matter in excess of 0.040 g/dscm (0.017 gr/dscf).

(2) Exhibit 10 percent opacity or greater.

(c) On and after the date on which the performance test required to be conducted by §60.8 is completed, an owner or operator subject to the provisions of this subpart shall not cause to be discharged into the atmosphere from any coal processing and conveying equipment, coal storage system, or coal transfer and loading system processing coal, gases which exhibit 20 percent opacity or greater.

[41 FR 2234, Jan. 15, 1976, as amended at 65 FR 61757, Oct. 17, 2000]

§ 60.253 Monitoring of operations.

(a) The owner or operator of any thermal dryer shall install, calibrate, maintain, and continuously operate monitoring devices as follows:

(1) A monitoring device for the measurement of the temperature of the gas stream at the exit of the thermal dryer on a continuous basis. The monitoring device is to be certified by the manufacturer to be accurate within ±1.7 °C (±3 °F).

(2) For affected facilities that use venturi scrubber emission control equipment:

(i) A monitoring device for the continuous measurement of the pressure loss through the venturi constriction of the control equipment. The monitoring device is to be certified by the manufacturer to be accurate within ±1 inch water gauge.

(ii) A monitoring device for the continuous measurement of the water supply pressure to the control equipment. The monitoring device is to be certified by the manufacturer to be accurate within ±5 percent of design water supply pressure. The pressure sensor or tap must be located close to the water discharge point. The Administrator may be consulted for approval of alternative locations.

(b) All monitoring devices under paragraph (a) of this section are to be recalibrated annually in accordance with procedures under §60.13(b).

[41 FR 2234, Jan. 15, 1976, as amended at 54 FR 6671, Feb. 14, 1989; 65 FR 61757, Oct. 17, 2000]

§ 60.254 Test methods and procedures.

(a) In conducting the performance tests required in §60.8, the owner or operator shall use as reference methods and procedures the test methods in appendix A of this part or other methods and procedures as specified in this section, except as provided in §60.8(b).

(b) The owner or operator shall determine compliance with the particular matter standards in §60.252 as follows:

(1) Method 5 shall be used to determine the particulate matter concentration. The sampling time and sample volume for each run shall be at least 60 minutes and 0.85 dscm (30 dscf). Sampling shall begin no less than 30 minutes after startup and shall terminate before shutdown procedures begin.

(2) Method 9 and the procedures in §60.11 shall be used to determine opacity.

[54 FR 6671, Feb. 14, 1989]

Indiana Department of Environmental Management
Office of Air Quality

Technical Support Document (TSD)
for a Part 70 Significant Permit Modification

Source Description and Location

Source Name:	Purdue University - West Lafayette
Source Location:	401 S. Grant St., Freehafer Hall of Administrative Services, West Lafayette, IN 47907-2024
County:	Tippecanoe
SIC Code:	8221
Operation Permit Renewal No.:	T 157-27313-00012
Issuance Date of Renewal:	August 27, 2010
Significant Permit Modification No.:	SPM 157-30742-00012
Permit Reviewer:	Kimberly Cottrell

Part 70 Source Definition

This source consists of air emission units located on the main campus in West Lafayette, Indiana, and at research farms in the vicinity of 5675 West 600 North, West Lafayette, Indiana, for the Animal Sciences Research and Education Center.

Existing Approvals

Purdue University was issued Part 70 Operating Permit Renewal No. T 157-27313-00012 on August 27, 2010. Since the issuance of the Part 70 Operating Permit Renewal, the source has constructed or has been operating under the following approvals:

Administrative Amendment No. 157-30374-00012, issued on April 19, 2011.

County Attainment Status

The source is located in Tippecanoe County.

Table 1: County Attainment Status

Pollutant	Designation
SO_2	Better than national standards.
CO	Unclassifiable or attainment effective November 15, 1990.
O_3	Unclassifiable or attainment effective June 15, 2004, for the 8-hour ozone standard.[1]
PM_{10}	Unclassifiable effective November 15, 1990.
$PM_{2.5}$	Unclassifiable or attainment effective April 5, 2005.
NO_2	Cannot be classified or better than national standards.
Pb	Not designated.

[1]Unclassifiable or attainment effective October 18, 2000, for the 1-hour ozone standard which was revoked effective June 15, 2005.

(a) Volatile organic compounds (VOC) and Nitrogen Oxides (NO_X) are regulated under the Clean Air Act (CAA) for the purposes of attaining and maintaining the National Ambient Air Quality Standards (NAAQS) for ozone. Therefore, VOC emissions and NO_X emissions are considered when evaluating the rule applicability relating to ozone. Tippecanoe County has been designated as attainment or unclassifiable for ozone. Therefore, VOC emissions and NO_X emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2. See the State Rule Applicability – Entire Source section.

(b) $PM_{2.5}$
Tippecanoe County has been classified as attainment for $PM_{2.5}$. On May 8, 2008 U.S. EPA promulgated the requirements for Prevention of Significant Deterioration (PSD) for $PM_{2.5}$ emissions, and the effective date of these rules was July 15th, 2008. Indiana has three years from the publication of these rules to revise its PSD rules, 326 IAC 2-2, to include those requirements. The May 8, 2008 rule revisions require IDEM to regulate PM_{10} emissions as a surrogate for $PM_{2.5}$ emissions until 326 IAC 2-2 is revised.

(c) Tippecanoe County has been classified as attainment or unclassifiable for CO,PM_{10}, NO_2, SO_2, and Lead. Therefore, these emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2.

(d) Since this source is classified as a fossil fuel fired steam electric plant rated at more than 250 MMBtu/hr heat input, it is considered one of the twenty-eight (28) listed source categories, as specified in 326 IAC 2-2-1(gg)(1).

Fugitive Emissions

Since this type of operation is in one of the twenty-eight (28) listed source categories under 326 IAC 2-2 or 326 IAC 2-3, fugitive emissions are counted toward the determination of PSD and Emission Offset applicability.

Source Status

The table below summarizes the potential to emit of the entire source, prior to the proposed modification, after consideration of all enforceable limits established in the effective permits:

Table 2: Source Status PTE

Pollutant	**Emissions** (ton/yr)
CO	**>100**
NO_X	**>100**
PM	**>100**
PM_{10}	**>100**
SO_2	**>100**
VOC	<100
GHGs as CO_2e*	**>100,000**

Table 2: Source Status PTE	
Pollutant	**Emissions** (ton/yr)
HF	**>10**
HCl	**>10**
Arsenic	<10
Beryllium	<10
Cadmium	<10
Chromium	<10
Formaldehyde	<10
Glycol Ethers	<10
Lead	<10
Manganese	<10
MEK	<10
Methanol	<10
Nickel	<10
Toluene	<10
TOTAL HAP	**>25**

(a) This existing source is a major stationary source, under PSD (326 IAC 2-2), because a regulated pollutant is emitted at a rate of 100 tons per year or more, the emissions of GHGs are greater than one hundred thousand (100,000) tons of CO_2 equivalent emissions (CO_2e) per year, and it is one of the twenty-eight (28) listed source categories, as specified in 326 IAC 2-2-1(gg)(1).

(b) This existing source is not a major stationary source under Emission Offset (326 IAC 2-3) because no nonattainment regulated pollutant is emitted at a rate of 100 tons per year or more.

(c) This existing source is a major source of HAPs, as defined in 40 CFR 63.41, because HAP emissions are greater than ten (10) tons per year for a single HAP and greater than twenty-five (25) tons per year for a combination of HAPs. Therefore, this source is a major source under Section 112 of the Clean Air Act (CAA).

(d) These emissions are based upon Part 70 Operating Permit Renewal No. T 157-27313-00012, issued on August 27, 2010.

Description of Proposed Modification

The Office of Air Quality (OAQ) has reviewed a modification application, submitted by Purdue University - West Lafayette on July 26, 2011, relating to updating the permit to address removal of permit requirements that are no longer necessary since the construction activities that were previously permitted have been canceled and will not occur.

Enforcement Issues

There are no pending enforcement actions related to this modification.

Stack Summary

There are no new stacks proposed as part of this modification.

Emission Calculations

There is no new equipment included in this modification, and there is no increase in potential to emit as a result of this modification.

Permit Level Determination – Part 70

Pursuant to 326 IAC 2-1.1-1(16), Potential to Emit is defined as "the maximum capacity of a stationary source or emission unit to emit any air pollutant under its physical and operational design. Any physical or operational limitation on the capacity of a source to emit an air pollutant, including air pollution control equipment and restrictions on hours of operation or type or amount of material combusted, stored, or processed shall be treated as part of its design if the limitation is enforceable by the U. S. EPA, IDEM, or the appropriate local air pollution control agency."

There is no increase in the potential to emit of any regulated pollutants associated with this modification. This modification is not subject to the source modification requirements under 326 IAC -7-10.5. This modification will be incorporated into the Part 70 Operating Permit through a significant permit modification issued pursuant to 326 IAC 2-7-12(d), because the modification involves changes to case-by-case emission limitations and standards and requires significant changes in existing monitoring, record keeping, and reporting requirements.

Permit Level Determination for the Modification – PSD

Since there is no increase in potential to emit as a result of this modification, there is no change to the PSD applicability for this source.

Federal Rule Applicability Determination - Entire Source

There are no changes to federal rule applicability included in the permit for this modification.

State Rule Applicability - Entire Source

There are no changes to state rule applicability included in the permit for this modification. Several emission limitations, testing, monitoring, recordkeeping, and reporting requirements have been updated as noted below in the Proposed Changes section of this Technical Support Document. These are Title I changes.

Compliance Determination and Monitoring Requirements - Boiler 6 & Boiler 7

Permits issued under 326 IAC 2-7 are required to ensure that sources can demonstrate compliance with all applicable state and federal rules on a continuous basis. All state and federal rules contain compliance provisions; however, these provisions do not always fulfill the requirement for a continuous demonstration. When this occurs, IDEM, OAQ, in conjunction with the source, must develop specific conditions to satisfy 326 IAC 2-7-5. As a result, Compliance Determination Requirements are included in the permit. The Compliance Determination Requirements in Section D of the permit are those conditions that are found directly within state and federal rules and the violation of which serves as grounds for enforcement action.

If the Compliance Determination Requirements are not sufficient to demonstrate continuous compliance, they will be supplemented with Compliance Monitoring Requirements, also in Section D of the permit. Unlike Compliance Determination Requirements, failure to meet Compliance Monitoring conditions would serve as a trigger for corrective actions and not grounds for enforcement action. However, a violation in relation to a compliance monitoring condition will arise through a source's failure to take the appropriate corrective actions within a specific time period.

Compliance Determination Requirements
There are no new compliance determination requirements included in the permit for this modification.

Compliance Monitoring Requirements
There are no new compliance monitoring requirements included in the permit for this modification.

Proposed Changes

The changes listed below have been made to Part 70 Operating Permit Renewal No. T 157-27313-00012. Deleted language appears as ~~strikethroughs~~ and new language appears in **bold**. The following changes to emission limits, testing, monitoring, record keeping, and reporting are Title I changes:

Change No. 1 IDEM has rearranged the placement of condition language with regard to the observation of bag failure. The changes to Conditions D.1.9 and D.1.16 are as follows:

D.1.9 Particulate Control [326 IAC 2-7-6(6)] ~~[40 CFR 64]~~

(a) Except as otherwise provided by statute or rule or in this permit, the multiclone and electrostatic precipitator (ESP) for Boiler 1 shall be in operation and control emissions at all times that the boiler, vented to that multiclone and ESP, is in operation.

(b) Except as otherwise provided by statute or rule or in this permit, the multiclone and baghouse for particulate control for Boiler 2 shall be in operation and control emissions at all times that the boiler, vented to that multiclone and baghouse, is in operation.

~~(c) In the event that bag failure is observed in a multi-compartment baghouse, if operations will continue for ten (10) days or more after the failure is observed before the failed units will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed units will be repaired or replaced. The notification shall also include the status of the applicable compliance monitoring parameters with respect to normal, and the results of any response actions taken up to the time of notification.~~

D.1.16 Broken or Failed Bag Detection **– Multi-Compartment Baghouse [40 CFR 64]**

In the event that bag failure is observed in a multi-compartment baghouse, if operations will continue for ten (10) days or more after the failure is observed before the failed units will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed units will be repaired or replaced. The notification shall also include the status of the applicable compliance monitoring parameters with respect to normal, and the results of any response actions taken up to the time of notification.

Change No. 2 The original particulate matter limitation for Boiler 5 (from T157-7340-00012) has been reinstated in the permit along with the testing requirement that is needed to demonstrate compliance with this limit. The changes to Conditions D.2.1 and D.2.7 (now D.2.5) are as follows:

D.2.1 Boiler 5 PSD Emission Limits [326 IAC 2-2-~~4~~**3**] **[326 IAC 6-2-1(g)]**

Pursuant to Construction Permit PC (79) 1680, issued June 6, 1988, and 326 IAC 2-2 (Prevention of Significant Deterioration), the following requirements apply to Boiler 5:

(a) Sulfur dioxide emissions from Boiler 5 shall not exceed:

(1) 0.9 pounds per million British thermal units (lb/MMBtu) of heat input based on a 30-day rolling weighted average basis, and

(2) 1.1 pounds per million British thermal units (lb/MMBtu) of heat input based on a block 24-hour average basis.

(b) Particulate matter emissions from Boiler 5 shall not exceed 0.05 pounds per million Btu of heat input.

(**c**~~b~~) Carbon monoxide emissions from Boiler 5 shall not exceed 0.27 pounds per million British thermal units (lb/MMBtu) of heat input.

(d) The rate of heat input into the boiler shall not exceed 279 million Btu's per hour.

~~D.2.7~~ **D.2.5** Testing Requirements [326 IAC 2-7-6(1), (6)] [326 IAC 2-1.1-11]

(a) **Compliance with the Boiler 5 PM limitation in Condition D.2.1(b) hall be determined by performance stack tests conducted using methods as approved by the Commissioner.**

(b) Compliance with the Boiler 5 CO limitation in Condition D.2.1(~~b~~**c**) shall be determined by performance stack tests conducted using methods as approved by the Commissioner.

(~~b~~**c**) This testing shall be repeated by December 31 of every second calendar year following the most recent valid compliance demonstration. Testing shall be conducted in accordance with the provisions of 326 IAC 3-6 (Source Sampling Procedures). Section C - Performance Testing contains the Permittee's obligations with regard to the performance testing required by this condition.

For the purpose of this permit, "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.

Change No. 3 IDEM has removed the "reserved" conditions D.2.2, D.2.3, D.2.9(b), D.2.10, and D.2.18, and renumbered the remaining conditions.

~~D.2.2 RESERVED~~

~~D.2.3 RESERVED~~

~~D.2.9~~ **D.2.7** Continuous Emissions Monitoring [326 IAC 3-5] [40 CFR 64]

(a) Pursuant to 326 IAC 3-5 (Continuous Monitoring of Emissions), opacity, SO_2, and NO_X continuous emission monitoring systems (CEMS) for Boiler 5 shall be calibrated, maintained, and operated for measuring opacity, SO_2, and NO_X which meet the performance specifications of 326 IAC 3-5-2 and 40 CFR 60. For Boiler 5, the Continuous Opacity Monitoring System (COMS) shall be in operation in accordance with 326 IAC 3-5 and 40 CFR Part 60 when fuel is being combusted in the boiler.

(b) ~~RESERVED~~

~~(c)~~ All continuous emission monitoring systems are subject to monitor system certification requirements pursuant to 326 IAC 3-5-3.

~~(d)~~ **(c)** Nothing in this permit shall excuse the Permittee from complying with the requirements to operate a continuous emission monitoring system pursuant to 326 IAC 3-5, 40 CFR 60, or 40 CFR 75.

~~D.2.10 RESERVED~~

~~D.2.18 RESERVED~~

Change No. 4 IDEM has updated the requirements for Opacity Readings in Condition D.2.14 (now D.2.11) and the Baghouse Parametric Monitoring in Condition D.2.15 (now D.2.12) as follows:

~~D.2.14~~ **D.2.11** Opacity Readings [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)] [40 CFR 64]

~~For Boiler 5:~~

(1) In the event of emissions exceeding twenty percent (20%) average opacity for three (3) consecutive six (6)-minute averaging periods, appropriate response steps shall be taken such that the cause(s) of the excursion are identified and corrected and opacity levels are brought back below twenty percent (20%). Examples of expected response steps include, but are not limited to, boiler loads being reduced, adjustment of flue gas conditioning rate, and the baghouse being returned to service. **Section C - Response to Excursions or Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition.**

(2) Opacity readings in excess of twenty percent (20%) but not exceeding the opacity limit for the unit are not a deviation from this permit. Failure to take response steps shall be considered a deviation from this permit**. Section C - Response to Excursions or Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition.**

~~D.2.15~~ **D.2.12** Baghouse Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)] [40 CFR 64]

Whenever a COMS is malfunctioning or is down for maintenance or repairs for a period of twenty-four (24) hours or more and a backup COMS is not online within twenty-four (24) hours of shutdown or malfunction of the primary COMS:

(a) The Permittee shall record the pressure drop across the baghouse used in conjunction with Boiler 5, at least once per day when the process is in operation when venting to the atmosphere. When for any one reading, the pressure drop across the baghouse is outside the normal range of 1.0 and 7.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps. **Section C - Response to Excursions or Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition.**

(b) A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps shall be considered a deviation from this permit. The instrument used for determining the pressure shall comply with Section C - Instrument Specifications, and shall be calibrated or replaced in accordance with the manufacturer's specifications. **Section C - Response to Excursions or Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition.**

Change No. 5 The "reserved" paragraphs from the Record Keeping Requirements in Condition D.2.19 (now D.2.15) have been removed, and the requirements were clarified to say "to document **the** compliance **status** with..." as follows:

~~D.2.19~~ **D.2.15** Record Keeping Requirements

(a) To document **the** compliance **status** with Section C - Maintenance of Continuous Opacity Monitoring Equipment, and the opacity requirements in Conditions D.2.5, D.2.10, D.2.11, and D.2.14, the Permittee shall maintain records in accordance with (1) and (2) below. Records shall be complete and sufficient to establish compliance with the opacity limits in Conditions D.2.5 and D.2.14.

(1) All continuous opacity monitoring data, pursuant to 326 IAC 3-5-6.

(2) The results of all Method 9 visible emission readings taken during any periods of COM downtime.

(b) To document **the** compliance **status** with the SO_2 requirements in Conditions D.2.1, D.2.4, D.2.8, D.2.10, D.2.13, and D.2.16, the Permittee shall maintain records in accordance with (1) through (4) below. Records shall be complete and sufficient to establish compliance with the applicable SO_2 limits in Conditions D.2.1 and D.2.4. The Permittee shall maintain records in accordance with (3) and (4) below during SO_2 CEM system downtime.

(1) All SO_2 continuous emissions monitoring data, pursuant to 326 IAC 3-5-6 and 326 IAC 7-2-1(g).

(2) All startup periods and shutdown periods for Boiler 5.

(3) All boiler load, fuel sampling and analysis, and limestone injection rate data collected for SO_2 CEMS downtime, in accordance with Conditions D.2.8 and D.2.16.

(4) Actual fuel usage during each SO_2 CEM system downtime.

(c) To document **the** compliance **status** with the NO_X requirements in Condition D.2.10, the Permittee shall maintain records of all NO_X and CO_2 or O_2 continuous emissions monitoring data, pursuant to 326 IAC 3-5-6.

(d) To document **the** compliance **status** with the CO requirements in Conditions D.2.1(b) and D.2.7(a), the Permittee shall maintain data and results from the most recent stack test for Boiler 5. Records shall be complete and sufficient to establish compliance with the CO limit in Condition D.2.1(b).

(e) ~~RESERVED~~

~~(f) RESERVED~~

~~(g) RESERVED~~

~~(h)~~ To document **the** compliance **status** with Condition D.2.15, the Permittee shall maintain daily records of the pressure drop across the baghouse for Boiler 5 whenever a COMS is malfunctioning or is down for maintenance or repairs for a period of twenty-four (24) hours or more and a backup COMS is not online within twenty-four (24) hours of shutdown or malfunction of the primary COMS. The Permittee shall include in its daily record when a reading is not taken and the reason for the lack of a reading (e.g. the process did not operate that day).

(~~i~~**f**) Section C - General Record Keeping Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.

Change No. 6 The requirements for Boiler 7 in Section D.4 have been revised to remove the natural gas usage limit and update the CO emissions limit to a lb/MMBtu emission rate. Since the emission limits for this unit are equivalent to the standard emission factors for a natural gas fired boiler, the remaining requirements for testing, record keeping, and reporting, are no longer necessary and have been removed. The changes are as follows:

SECTION D.4 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]:

(f) One (1) natural gas fired boiler, identified as Boiler 7, permitted in 2010, with a nominal capacity of 290 MMBtu/hr, exhausting to stack WADE 03. Boiler 7 has a continuous emissions monitoring system (CEMS) for nitrogen oxides (NO_X) **for compliance with NSPS requirements**.

Under the Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units NSPS (40 CFR 60, Subpart Db), Boiler 7 is considered an affected source.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.4.1 Boiler 7 PSD Minor Limits [326 IAC 2-2]

(a) The natural gas usage for Boiler 7 shall not exceed 2,491 million cubic feet (MMCF) per twelve (12) consecutive month period. Compliance with this limit shall be determined at the end of each month.

~~(b) CO emissions from Boiler 7 shall not exceed 257.13 tons per twelve (12) consecutive month period with compliance determined at the end of each month.~~

(~~c~~**b**) NO_X emissions from Boiler 7 shall not exceed 0.049 pounds per million British thermal units (lb/MMBtu) of heat input.

(~~d~~**c**) PM emissions from Boiler 7 shall not exceed ~~0.0019~~**1.9** pounds per million **standard cubic feet (MMCF) of natural gas**~~British thermal units (lb/MMBtu) of heat input~~.

(~~e~~**d**) PM_{10} emissions from Boiler 7 shall not exceed ~~**0.0075**~~**7.6** pounds per million **standard cubic feet (MMCF) of natural gas**~~British thermal units (lb/MMBtu) of heat input~~.

(~~f~~**e**) $PM_{2.5}$ emissions from Boiler 7 shall not exceed ~~**0.0075**~~**7.6** pounds per million **standard cubic feet (MMCF) of natural gas**~~British thermal units (lb/MMBtu) of heat input~~.

(~~g~~**f**) SO_2 emissions from Boiler 7 shall not exceed ~~**0.0006**~~**0.6** pounds per million ~~British thermal units (lb/MMBtu) of heat input~~**standard cubic feet (MMCF) of natural gas**.

Compliance with these emission limits combined with the potential to emit ~~CO,~~ NO_X, PM, PM_{10}, $PM_{2.5}$, and SO_2 emissions from ~~all other emission units associated with the modification to add~~ Boiler 7 will limit the potential to emit from this modification to ~~less than one hundred (100) tons per year of CO,~~ less than forty (40) tons per year of NO_X, less than twenty-five (25) tons per year of PM, less than fifteen (15) tons per year of PM_{10}, less than ten (10) tons per year of $PM_{2.5}$, and less than forty (40) tons per year of SO_2. Therefore the requirements of 326 IAC 2-2 (PSD) are not applicable to the modification to add Boiler 7.

~~**Compliance Determination Requirements**~~

~~D.4.2 Testing Requirements [326 IAC 2-7-6(1), (6)] [326 IAC 2-1.1-11]~~

~~Compliance with the CO limitation in Condition D.4.1(b) shall be determined by a performance stack test for Boiler 7 conducted using methods as approved by the Commissioner. This testing shall be repeated by December 31 of every second calendar year following the most recent valid compliance demonstration. Testing shall be conducted in accordance with the provisions of 326 IAC 3-6 (Source Sampling Procedures). Section C - Performance Testing contains the Permittee's obligations with regard to the performance testing required by this condition. For the purpose of this permit, "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.~~

~~D.4.3 Compliance Determination Requirements [326 IAC 2-2]~~

~~The following equation shall be used for demonstrating compliance with the CO limit for Boiler 7 in D.4.1(b):~~

$$\cancel{E = \frac{[U \times HV \times EF_{CO\text{-}B7}]}{2000\ lb/ton}}$$

~~Where:~~

~~E = Total CO Emissions, tons/month~~
~~U = Natural Gas Usage, MMCF natural gas/month for Boiler 7~~
~~HV = Fuel Heating Value, Btu/CF natural gas;~~
~~$EF_{CO\text{-}B7}$ = 0.0379 lb/MMBtu or other value as determined during the last valid compliance demonstration~~

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

~~D.4.4~~ **D.4.3** Record Keeping Requirements

~~(a) To document compliance with the CO requirements in Conditions D.4.1(b), D.4.2, and D.4.3, the Permittee shall maintain records in accordance with (1) through (3) below. Records shall be complete and sufficient to establish compliance with the CO limit in Condition D.4.1(b).~~

~~(1) Data and results from the most recent stack test.~~

~~(2) Monthly natural gas usage.~~

~~(3) Natural gas heating value (HV).~~

(a) To document compliance with Condition D.4.1(a), the Permittee shall maintain monthly records of natural gas usage.

(b) Section C - General Record Keeping Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.

~~D.4.5~~ **D.4.3** Reporting Requirements

A quarterly summary of the information to document the compliance status with ~~Conditions~~ **Condition** D.4.1(a) ~~and D.4.1(b)~~ shall be submitted not later than thirty (30) days following the end of each calendar quarter. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34). Section C - General Reporting Requirements contains the Permittee's obligations with regard to the reporting required by this condition.

~~Boiler 7 CO Emissions - Part 70 Quarterly Report~~

~~Facility: Boiler 7~~
~~Parameter: CO Emissions~~
~~Limit: not more than 257.13 tons per 12 consecutive month period with compliance determined at the end of each month.~~

~~Boiler 7 Natural Gas Usage - Part 70 Quarterly Report~~

~~Facility: Boiler 7~~
~~Parameter: natural gas usage~~
~~Limit: not more than 2,491 MMCF per 12 consecutive month period with compliance determined at the end of each month.~~

Change No. 7 The original limitation for COAL Segment 2 (from T157-7340-00012) has been reinstated in the permit along with a new limitation for the coal preparation plant. The changes to Condition D.5.1 are as follows:

~~D.5.1 PSD Minor Limits for COAL Segment 1 and COAL Segment 2 [326 IAC 2-2]~~

~~(a) Total PM emissions from the coal storage and handling systems identified as COAL Segment 1 and COAL Segment 2 shall not exceed 8.0 tons of PM per twelve (12) consecutive month period, with compliance determined at the end of each month.~~

~~(b) PM_{10} emissions from the coal storage and handling systems identified as COAL Segment 1 and COAL Segment 2 shall not exceed 8.0 tons of PM_{10} per twelve (12) consecutive month period, with compliance determined at the end of each month.~~

~~(c) $PM_{2.5}$ emissions from the coal storage and handling systems identified as COAL Segment 1 and COAL Segment 2 shall not exceed 1.5 tons of $PM_{2.5}$ per twelve (12) consecutive month period, with compliance determined at the end of each month.~~

~~Compliance with these emission limits combined with the potential to emit PM, PM_{10}, and $PM_{2.5}$ emissions from all other emission units associated with this modification to add Boiler 7, will limit the potential to emit from this modification to less than twenty-five (25) tons per year of PM, less than fifteen (15) tons per year of PM_{10}, and less than ten (10) tons per year of $PM_{2.5}$. Therefore the requirements of 326 IAC 2-2 (PSD) are not applicable to the modification to add Boiler 7.~~

~~Compliance with these emission limits combined with the potential to emit PM and PM_{10} emissions from all other emission units associated with the 1996 modification to add COAL Segment 2, will limit the potential to emit from the 1996 modification to less than twenty-five (25) tons per year of PM and less than fifteen (15) tons per year of PM_{10}. Therefore the requirements of 326 IAC 2-2 (PSD) are not applicable to the 1996 modification to add COAL Segment 2.~~

D.5.1 PSD Minor Limit [326 IAC 2-2-1]

The emissions from the coal storage and handling equipment included in COAL Segment 2 shall be limited as follows:

(1) Particulate matter (PM) emissions from CV1 shall not exceed 1.71 pounds per hour.

(2) PM_{10} emissions from CV1 shall not exceed 1.02 pounds per hour.

(3) Particulate matter (PM) emissions from CV2 shall not exceed 2.28 pounds per hour.

(4) PM_{10} emissions from CV2 shall not exceed 1.36 pounds per hour.

(5) Particulate matter (PM) emissions from CV3 shall not exceed 1.71 pounds per hour.

(6) PM_{10} emissions from CV3 shall not exceed 1.02 pounds per hour.

Compliance with the above limits shall limit PM and PM_{10} emissions less than 25 and 15 tons per year respectively, and will render the requirements of 326 IAC 2-2-1(x) and 326 IAC 2-2-1(jj) (PSD Requirements) not applicable to the coal preparation system for Boiler 5.

~~D.5.5 Compliance Determination Requirements [326 IAC 2-2]~~

~~The following equation shall be used for demonstrating compliance with the PM, PM_{10}, and $PM_{2.5}$ limits for COAL Segment 1 and COAL Segment 2 in D.5.1:~~

$$\cancel{E = \sum U \times EF\left(\frac{(100 - CE)}{100}\right) \times \left(\frac{1_ton}{2000_lb}\right)}$$

~~Where:~~

~~E = Pollutant Emissions, tons/month~~
~~U = Coal Handled, tons coal/month~~
~~EF = Uncontrolled pollutant emission rate, lb/ton coal~~
~~CE = Control device efficiency, %~~
~~(for baghouses, CE = 99%; for rotoclones / multiclones, CE = 50%)~~
~~EF_{PM} = 0.862 lb/ton coal~~
~~EF_{PM10} = 0.408 lb/ton coal~~
~~$EF_{PM2.5}$ = 0.062 lb/ton coal~~

~~D.5.11 Reporting Requirements~~

~~A quarterly summary of the information to document the compliance status with Condition D.5.1 shall be submitted not later than thirty (30) days following the end of each calendar quarter. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34). Section C - General Reporting Requirements contains the Permittee's obligations with regard to the reporting required by this condition.~~

~~Coal Handling PM Emissions - Part 70 Quarterly Report~~

~~Facility: Coal Handling Operations~~
~~Parameter: PM Emissions~~
~~Limit: not more than 8.0 tons per 12 consecutive month period with compliance determined at the end of each month.~~

~~Coal Handling PM_{10} Emissions - Part 70 Quarterly Report~~

~~Facility: Coal Handling Operations~~
~~Parameter: PM_{10} Emissions~~
~~Limit: not more than 8.0 tons per 12 consecutive month period with compliance determined at the end of each month.~~

~~Coal Handling $PM_{2.5}$ Emissions - Part 70 Quarterly Report~~

~~Facility: Coal Handling Operations~~
~~Parameter: $PM_{2.5}$ Emissions~~
~~Limit: not more than 1.5 tons per 12 consecutive month period with compliance determined at the end of each month.~~

Change No. 8 IDEM has rearranged the placement of condition language with regard to the observation of bag failure. The changes to Conditions D.5.4 and D.5.8 are as follows:

D.5.4 Particulate Control [326 IAC 2-7-6(6)]

~~(a)~~ Except as otherwise provided by statute or rule or in this permit, in order to comply with Conditions D.5.1 and D.5.2, the RotoClones, cartridge filters, and baghouses for particulate control shall be in operation and control emissions at all times the associated coal processing or conveying is in operation.

~~(b) In the event that bag failure is observed in a multi-compartment baghouse, if operations will continue for ten (10) days or more after the failure is observed before the failed units will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed units will be repaired or replaced. The notification shall also include the status of the applicable compliance monitoring parameters with respect to normal, and the results of any response actions taken up to the time of notification.~~

~~D.5.8~~ **D.5.7** Broken or Failed Bag Detection [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

(a) For a single compartment baghouse controlling emissions from a process operated continuously, a failed unit and the associated process shall be shut down immediately until the failed unit has been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).

(b) For a single compartment baghouse controlling emissions from a batch process, the feed to the process shall be shut down immediately until the failed unit has been repaired or replaced. The emissions unit shall be shut down no later than the completion of the processing of the material in the line. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).

(c) In the event that bag failure is observed in a multi-compartment baghouse, if operations will continue for ten (10) days or more after the failure is observed before the failed units will be repaired or replaced, the Permittee shall promptly notify the IDEM, OAQ of the expected date the failed units will be repaired or replaced. The notification shall also include the status of the applicable compliance monitoring parameters with respect to normal, and the results of any response actions taken up to the time of notification.

Bag failure can be indicated by a significant drop in the baghouse's pressure reading with abnormal visible emissions, by an opacity violation, or by other means such as gas temperature, flow rate, air infiltration, leaks, dust traces or triboflows.

Change No. 9 IDEM has updated the requirements for Baghouse Parametric Monitoring in Condition D.5.7 and the RotoClone Failure Detection in Condition D.5.9 as follows:

~~D.5.7~~ **D.5.6** Baghouse Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

(a) The Permittee shall record the pressure drop across each of the baghouses used in conjunction with the coal transfer drop points at least once per week when coal is being transferred. When for any one reading, the pressure drop across baghouse CV1 or CV3 is outside the normal range of 4.0 and 10.0 inches of water or a range established during the latest stack test, or the pressure drop across baghouse CV2 is outside the normal range of 5.0 to 12.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps ~~in accordance with Section C - Response to Excursions or Exceedances~~. A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps ~~in accordance with Section C - Response to Excursions or Exceedances~~ shall be considered a deviation from this permit. **Section C - Response to Excursions or Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition.**

(b) The instrument used for determining the pressure shall comply with Section C - Instrument Specifications, and shall be calibrated or replaced in accordance with the manufacturer's specifications. The specifications shall be available on site with the Preventive Maintenance Plan.

~~D.5.9~~ **D.5.8** RotoClone Failure Detection [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

In the event that RotoClone failure has been observed:

The failed units and the associated process will be shut down immediately until the failed units have been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions). Failure to take response steps ~~in accordance with Section C - Response to Excursions or Exceedances~~ shall be considered a deviation from this permit. **Section C - Response to Excursions or Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition.**

Change No. 10 The Record Keeping Requirements in Condition D.5.10 were clarified to say "to document **the** compliance **status** with..." as follows:

~~D.5.10~~ **D.5.9** Record Keeping Requirements

(a) ~~To document compliance with the PM, PM_{10}, and $PM_{2.5}$ requirements in Conditions D.5.1 and D.5.5, the Permittee shall maintain monthly records of the amount of coal handled. Records shall be complete and sufficient to establish compliance with the PM, PM_{10}, and $PM_{2.5}$ limits in Condition D.5.1.~~

~~(b)~~ To document **the** compliance **status** with Condition ~~D.5.6~~ **D.5.5**, the Permittee shall maintain records of the weekly visible emission notations of the coal unloading and coal transfer exhaust points. The Permittee shall include in its weekly record when a visible emission notation is not taken and the reason for the lack of visible emission notation, (i.e., the process did not operate that week).

(~~c~~**b**) To document **the** compliance **status** with Condition ~~D.5.7~~ **D.5.6,** the Permittee shall maintain weekly records of the total static pressure drop across each baghouse. The Permittee shall include in its weekly record when a pressure drop reading is not taken and the reason for the lack of a pressure drop reading, (i.e., the process did not operate that week).

(~~d~~**c**) Section C - General Record Keeping Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.

Change No. 11 The original limitation for Ash Segment 1 associated with Boiler 1 and Boiler 2 (from T157-7340-00012) has been reinstated in the permit (with updates). Purdue will not be changing Ash Segment 2; therefore, the requirements that were added for addressing emissions from the modification to Ash Segment 2 are no longer needed. The remainder of Section D.6 has been updated to reflect this change. The changes to Section D.6 are as follows:

D.6.1 PSD Minor Limits for Ash Segment 2 [326 IAC 2-2-1]

~~Emissions from the ash handling equipment included in Ash Segment 1 associated with Boiler 1 and Boiler 2 shall be limited at all times the unit is handling ash as follows:~~

~~(a) Particulate matter (PM) emissions shall not exceed 5.71 pounds per hour (lb/hr).~~

~~(b) PM_{10} emissions shall not exceed 3.42 pounds per hour (lb/hr).~~

~~Compliance with these emission limits will limit the potential to emit from the modification to add the ash handling system identified as Ash Segment 1 to less than twenty five (25) tons per year of PM and fifteen (15) tons per year of PM_{10}. Therefore the requirements of 326 IAC 2-2 (PSD) are not applicable to the modification to add the ash handling system identified as Ash Segment 1.~~

Emissions from the Ash Segment 1 associated with Boiler 1 and Boiler 2 shall be limited as follows:

(1) Particulate matter (PM) emissions from ASH1 shall not exceed 2.85 pounds per hour.

(2) PM_{10} emissions from ASH1 shall not exceed 1.70 pounds per hour.

(3) Particulate matter (PM) emissions from AB1 shall not exceed 2.85 pounds per hour.

(4) PM_{10} emissions from AB1 shall not exceed 1.70 pounds per hour.

Compliance with the above limits shall limit PM and PM_{10} emissions less than 25 and 15 tons per year respectively, and will render the requirements of 326 IAC 2-2-1(x) and 326 IAC 2-2-1(jj) (PSD Requirements) not applicable to Ash Segment 1 associated with Boiler 1 and Boiler 2.

~~D.6.2 PSD Minor Limits for Ash Segment 2 [326 IAC 2-2]~~

~~(a) Total PM emissions from the ash handling equipment included in Ash Segment 2 associated with Boiler 5 shall be limited at all times the unit is handling ash to not exceed 6.0 tons of PM per twelve (12) consecutive month period, with compliance determined at the end of each month.~~

~~(b) PM_{10} emissions from the ash handling equipment included in Ash Segment 2 associated with Boiler 5 shall be limited at all times the unit is handling ash to not exceed 3.0 tons of PM_{10} per twelve (12) consecutive month period, with compliance determined at the end of each month.~~

~~(c) $PM_{2.5}$ emissions from the ash handling equipment included in Ash Segment 2 associated with Boiler 5 shall be limited at all times the unit is handling ash to not exceed 3.0 tons of $PM_{2.5}$ per twelve (12) consecutive month period, with compliance determined at the end of each month.~~

~~Compliance with these emission limits combined with the potential to emit PM, PM_{10}, and $PM_{2.5}$ emissions from all other emission units associated with this modification to add Boiler 7, will limit the potential to emit from this modification to less than twenty-five (25) tons per year of PM, less than fifteen (15) tons per year of PM_{10}, and less than ten (10) tons per year of $PM_{2.5}$. Therefore the requirements of 326 IAC 2-2 (PSD) are not applicable to the modification to add Boiler 7.~~

~~D.6.5~~ **D.6.4** Particulate Control [326 IAC 2-7-10.5(d)(5)(C)]

(a) The fresh water/mixing operation for the ash truck loading system for ASH Segment 1 shall be in operation and control the particulate emissions from the ash at all times that the ash truck loading system is in operation.

(b) The baghouse of ASH1 stack and air filter for AB1 stack for particulate control, shall be in operation and control the particulate emissions from ash system at all times that the ash storage and handling system is in operation.

(c) Except as otherwise provided by statute or rule or in this permit, in order to comply with Condition**s D.1 and** D.6.2 (Particulate) related to ASH Segment 2, the baghouse filters for particulate control shall be in operation and control emissions at all times that the associated ash handling is in operation; the telescoping spout shall be in operation and control emissions at all times that the dry ash loading system is in operation; and water shall be mixed with the ash at all times to control emissions when the wet process ash loading system.

(d) The filter module and canister filters for the ASH Segment 2 dry ash loading system, for particulate control shall be in operation and control the particulate emissions at all times that the dry ash loading system is in operation.

~~D.6.6 Compliance Determination Requirements [326 IAC 2-2]~~

~~The following equation shall be used for demonstrating compliance with the PM, PM_{10}, and $PM_{2.5}$ limits for ASH Segment 2 in D.6.2:~~

$$\cancel{E} = \sum U \times EF\left(\frac{(100 - CE)}{100}\right) \times \left(\frac{1_ton}{2000_lb}\right)$$

~~Where:~~

~~E = Pollutant Emissions, tons/month~~
~~U = Ash Handled, tons ash/month~~
~~EF = Uncontrolled pollutant emission rate, lb/ton ash~~

~~CE = Control device efficiency, %~~
~~(for baghouses, CE = 99%; for bin vents, CE = 99%)~~
~~EF_{PM} = 3.14 lb/ton ash~~
~~EF_{PM10} = 1.10 lb/ton ash~~
~~$EF_{PM2.5}$ = 1.10 lb/ton ash~~

Change No. 12 IDEM has clarified that the Particulate Emission Limitations for Manufacturing Processes in Condition D.6.3 (now D.6.2) apply to each transfer point in the ash handling processes. The changes are as follows:

~~D.6.3~~ **D.6.2** Particulate [326 IAC 6-3-2]

(a) Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), the particulate emission rate from **each transfer point for** the ash handling system identified as ASH Segment 1 shall not exceed 24.03 pounds per hour (lb/hr) when operating at a process weight rate of 14 tons per hour (ton/hr).

(b) Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), the allowable particulate emission rate **from each transfer point for** the pneumatic ash handling system identified as ASH Segment 2 shall not exceed 30.5 pounds per hour (lb/hr) when operating at a process weight rate of 20 tons per hour (ton/hr).

Interpolation of the data for the process weight rate up to sixty thousand (60,000) pounds per hour (lb/hr) shall be accomplished by use of the equation:

$E = 4.10\ P^{0.67}$ where E = rate of emission in pounds per hour (lb/hr); and
P = process weight rate in tons per hour (ton/hr).

(c) Pursuant to 326 IAC 6-3-2(e)(3) (Particulate Emission Limitations for Manufacturing Processes), for the ash unloading at the maximum throughput rate of 300 tons per hour for Ash Segment 2, the concentration of particulate in the discharge gases to the atmosphere shall be less than 0.10 pounds per one thousand (1,000) pounds of gases.

Change No. 13 IDEM has updated the requirements for Parametric Monitoring in Condition D.6.9 (now D.6.7) as follows:

~~D.6.9~~ **D.6.7** Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

(a) The Permittee shall record the total static pressure drop across the baghouse (ASH1) and air filter (AB1) controlling emissions from the ash handling system for ASH Segment 1, at least once per day when the ash handling system is in operation. When for any one reading, the pressure drop across the baghouse is outside the normal range of 1.0 to 7.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps ~~in accordance with Section C - Response to Excursions or Exceedances~~.

(b) The Permittee shall record the pressure drop across the ash silo baghouse for ASH Segment 2 at least once per week when the ash handling is in operation. When for any one reading, the pressure drop across the baghouse is outside the normal range of 1.0 and 7.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps ~~in accordance with Section C - to Excursions or Exceedances~~.

(c) The Permittee shall record the pressure drop across the air filters controlling emissions from the ASH Segment 2 dry ash truck loading system (ASH5C), at least once per week when the dry ash truck loading system is in operation. When for any one reading, the pressure drop across the air filter is outside the normal range of 1.0 and 7.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps ~~in accordance with Section C - to Excursions or Exceedances~~.

A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps ~~in accordance with Section C - Response to Excursions or Exceedances,~~ shall be considered a deviation from this permit. Section C - Response to Excursions or Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition.

(d) The instrument used for determining the pressure shall comply with Section C - Instrument Specifications, and shall be calibrated or replaced in accordance with the manufacturer's specifications. The specifications shall be available on site with the Preventive Maintenance Plan.

Change No. 14 The title of the condition for Broken or Failed Bag Detection - Condition D.6.9 (now D.6.7) was updated as follows for clarification:

~~D.6.9~~ **D.6.7** Broken or Failed Bag Detection **- Single Compartment Baghouses** [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

Change No. 15 The Record Keeping Requirements in Condition D.6.10 (now D.6.8) were clarified to say "to document **the** compliance **status** with..." as follows:

~~D.6.10~~ **D.6.8** Record Keeping Requirements

(a) ~~To document the compliance status with the PM, PM_{10}, and $PM_{2.5}$ requirements in Conditions D.6.2, and D.6.6, the Permittee shall maintain monthly records of the amount of ash handled. Records shall be complete and sufficient to establish compliance with the PM, PM_{10}, and $PM_{2.5}$ limits in Condition D.6.2.~~

~~(b)~~ To document **the** compliance **status** with Condition ~~D.6.7~~ **D.6.5**, the Permittee shall maintain daily records of the visible emission notations of ASH1, AB-1, the ASH5A and ASH5B exhaust stacks, and the exhaust vent ASH5C. The Permittee shall include in its daily record when a visible emission notation is not taken and the reason for the lack of visible emission notation, (e.g. the process did not operate that day).

(~~c~~**b**) To document **the** compliance **status** with Condition ~~D.6.8~~ **D.6.6**, the Permittee shall maintain daily records of the total static pressure drop across each baghouse and air filter. The Permittee shall include in its daily record when a pressure drop reading is not taken and the reason for the lack of a pressure drop reading, (e.g. the process did not operate that day).

(~~d~~**c**) Section C - General Record Keeping Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.

~~D.6.11 Reporting Requirements~~

~~A quarterly summary of the information to document the compliance status with Condition D.6.2, shall be submitted not later than thirty (30) days following the end of each calendar quarter. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34). Section C - General Reporting Requirements contains the Permittee's obligations with regard to the reporting required by this condition.~~

~~Ash Handling PM Emissions - Part 70 Quarterly Report~~

~~Facility: Ash Segment 2~~
~~Parameter: PM Emissions~~
~~Limit: not more than 6.0 tons per 12 consecutive month period with compliance determined at the end of each month.~~

~~Ash Handling PM_{10} Emissions - Part 70 Quarterly Report~~

~~Facility: Ash Segment 2~~
~~Parameter: PM_{10} Emissions~~
~~Limit: not more than 3.0 tons per 12 consecutive month period with compliance determined at the end of each month.~~

~~Ash Handling $PM_{2.5}$ Emissions - Part 70 Quarterly Report~~

~~Facility: Ash Segment 2~~
~~Parameter: $PM_{2.5}$ Emissions~~
~~Limit: not more than 3.0 tons per 12 consecutive month period with compliance determined at the end of each month.~~

Change No. 16 Purdue will not be changing the limestone handling operations; therefore, the requirements that were added for addressing emissions from the modification to the limestone handling operation are no longer needed. The remainder of Section D.7 has been updated to reflect this change. The changes are as follows:

~~D.7.1 PSD Minor Limits for Limestone Storage and Handling Operations [326 IAC 2-2]~~

~~(a) Total PM emissions from the limestone storage and handling equipment, LSBH1, and BVLI5, shall be limited at all times the unit is handling limestone to not exceed 6.0 tons of PM per twelve (12) consecutive month period, with compliance determined at the end of each month.~~

~~(b) PM_{10} emissions from the limestone storage and handling equipment, LSBH1, and BVLI5, shall be limited at all times the unit is handling limestone to not exceed 6.0 tons of PM_{10} per twelve (12) consecutive month period, with compliance determined at the end of each month.~~

~~(c) $PM_{2.5}$ emissions from the limestone storage and handling equipment, LSBH1, and BVLI5, shall be limited at all times the unit is handling limestone to not exceed 2.0 tons of $PM_{2.5}$ per twelve (12) consecutive month period, with compliance determined at the end of each month.~~

~~Compliance with these emission limits combined with the potential to emit PM, PM_{10}, and $PM_{2.5}$ emissions from all other emission units associated with this modification to add Boiler 7, will limit the potential to emit from this modification to less than twenty-five (25) tons per year of PM, less than fifteen (15) tons per year of PM_{10}, and less than ten (10) tons per year of $PM_{2.5}$. Therefore the requirements of 326 IAC 2-2 (PSD) are not applicable to the modification to add Boiler 7.~~

~~D.7.5 Compliance Determination Requirements [326 IAC 2-2]~~

~~The following equation shall be used for demonstrating compliance with the PM, PM_{10}, and $PM_{2.5}$ limits for the limestone storage and handling equipment in D.7.1:~~

$$\cancel{E = \sum U \times EF\left(\frac{(100 - CE)}{100}\right) \times \left(\frac{1_ton}{2000_lb}\right)}$$

~~Where:~~

~~E = Pollutant Emissions, tons/month~~
~~U = Limestone Handled, tons limestone /month~~
~~EF = Uncontrolled pollutant emission rate, lb/ton limestone~~
~~CE = Control device efficiency, %~~
~~(for baghouses, CE = 99%; for bin vents, CE = 99%)~~
~~EF_{PM} = 2.2 lb/ton limestone~~
~~EF_{PM10} = 2.2 lb/ton limestone~~
~~$EF_{PM2.5}$ = 2.2 lb/ton limestone~~

Change No. 17 IDEM has clarified that the Particulate Emission Limitations for Manufacturing Processes in Condition D.7.2 (now D.7.1) apply to each transfer point in the limestone handling process. The changes are as follows:

D.7.1 Particulate [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), the allowable particulate emission rate from **each transfer point for** the limestone handling system associated with Boiler 5 shall not exceed 22.17 pounds per hour (lb/hr) when operating at a process weight rate of 12.5 tons per hour (ton/hr).

Interpolation of the data for the process weight rate up to sixty thousand (60,000) pounds per hour (lb/hr) shall be accomplished by use of the equation:

$E = 4.10\ P^{0.67}$ where E = rate of emission in pounds per hour (lb/hr); and
P = process weight rate in tons per hour (ton/hr).

Change No. 18 IDEM has replaced the requirements for Parametric Monitoring in original Condition D.7.7 with requiremetns for weekly visible emission notations [now D.7.4(a)(2)] as follows:

~~D.7.6~~**D.7.4** Visible Emissions Notations [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

(a) **Visible Emissions Notations:**

(1) Visible emission notations of the limestone handling systems exhaust point, identified as LSBH1, shall be performed once per week during normal daylight operations and when the silo is receiving limestone. A trained employee shall record whether emissions are normal or abnormal.

(2) Visible emission notations of the Boiler 5 limestone day bin vent (BVLI5) shall be performed once per week during normal daylight operations when exhausting to the atmosphere. A trained employee shall record whether emissions are normal or abnormal.

(b) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.

(c) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.

(d) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.

(e) If abnormal emissions are observed, the Permittee shall take reasonable response steps ~~in accordance with Section C - Response to Excursions or Exceedances~~. **Observation of abnormal emissions that do not violate an applicable opacity limit is not a deviation from this permit.** Failure to take response steps ~~in accordance with Section C - Response to Excursions or Exceedances~~ shall be considered a deviation from this permit. **Section C – Response to Excursions or Exceedances contains the Permittee's obligations with regard to responding to the reasonable response steps required by this condition.**

~~D.7.7 Parametric Monitoring [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]~~

~~(a) The Permittee shall record the pressure drop across the baghouse, identified as LSBH1, at least once per week when limestone is being transferred into the silo. When for any one reading, the pressure drop across the baghouse is outside the normal range of 1.0 and 7.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances, shall be considered a deviation from this permit.~~

~~(b) The Permittee shall record the pressure drop across the bin vent filters, identified as BVLI5, at least once per week when limestone is being transferred into the day bins. When for any one reading, the pressure drop across the bin vent filters is outside the normal range of 1.0 and 7.0 inches of water or a range established during the latest stack test, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. A pressure reading that is outside the above mentioned range is not a deviation from this permit. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances, shall be considered a deviation from this permit.~~

~~(c) The instrument used for determining the pressure shall comply with Section C - Instrument Specifications, and shall be calibrated or replaced in accordance with the manufacturer's specifications. The specifications shall be available on site with the Preventive Maintenance Plan.~~

Change No. 19 The title of the condition for Broken or Failed Bag Detection - Condition D.7.8 (now D.7.6) was updated as follows for clarification:

~~D.7.8~~ **D.7.5** Broken or Failed Bag Detection **- Single Compartment Baghouses** [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

~~D.7.9~~ **D.7.6** Record Keeping Requirements

(a) ~~To document the compliance status with the PM, PM_{10}, and $PM_{2.5}$ requirements in Conditions D.7.1, and D.7.5, the Permittee shall maintain monthly records of the amount of limestone handled. Records shall be complete and sufficient to establish compliance with the PM, PM_{10}, and $PM_{2.5}$ limits in Condition D.7.1.~~

~~(b)~~ To document the compliance status with Condition ~~D.7.6~~ **D.7.4**, the Permittee shall maintain weekly records of the visible emission notations of LSBH–1 **and BVLI5**. The Permittee shall include in its weekly record when a visible emission notation is not taken and the reason for the lack of visible emission notation, (e.g. the process did not operate that week).

~~(c) To document the compliance status with Condition D.7.7, the Permittee shall maintain weekly records of the total static pressure drop across LSBH-1 and BVLI-5. The Permittee shall include in its weekly record when a pressure drop reading is not taken and the reason for the lack of a pressure drop reading, (e.g. the process did not operate that week).~~

(~~d~~**b**) Section C - General Record Keeping Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.

~~D.7.10 Reporting Requirements~~

~~A quarterly summary of the information to document the compliance status with Condition D.7.1 shall be submitted not later than thirty (30) days following the end of each calendar quarter. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34). Section C - General Reporting Requirements contains the Permittee's obligations with regard to the reporting required by this condition.~~

~~Limestone Storage and Handling PM Emissions~~
~~Part 70 Quarterly Report~~

~~Facility: Limestone Storage and Handling (LSBH1, BVLI5, and BVLI6)~~
~~Parameter: PM Emissions~~
~~Limit: not more than 6.0 tons per 12 consecutive month period with compliance determined at the end of each month.~~

~~Limestone Storage and Handling PM_{10} Emissions~~
~~Part 70 Quarterly Report~~

~~Facility: Limestone Storage and Handling (LSBH1, BVLI5, and BVLI6)~~
~~Parameter: PM_{10} Emissions~~
~~Limit: not more than 6.0 tons per 12 consecutive month period with compliance determined at the end of each month.~~

~~Limestone Storage and Handling $PM_{2.5}$ Emissions~~
~~Part 70 Quarterly Report~~

~~Facility: Limestone Storage and Handling (LSBH1, BVLI5, and BVLI6)~~
~~Parameter: $PM_{2.5}$ Emissions~~
~~Limit: not more than 2.0 tons per 12 consecutive month period with compliance determined at the end of each month.~~

Change No. 20 The Record Keeping Requirements in Conditions D.9.3 and D.11.3 were clarified to say "to document **the** compliance **status** with..." as follows:

D.9.3 Record Keeping Requirements

(a) To document **the** compliance **status** with Condition D.9.1, the Permittee shall maintain records in accordance with (1) through (5) below.

(1) Calendar dates covered in the compliance determination period;

(2) Actual fuel oil usage since last compliance determination period and equivalent nitrogen oxides (NO_X) emissions;

(3) A certification, signed by the owner or operator, that the records of the fuel supplier certifications represent all of the fuel combusted during the period;

(4) The name of the fuel supplier; and

(5) A statement from the fuel supplier that certifies the sulfur content of the fuel oil.

(b) Section C - General Record Keeping Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.

D.11.3 Record Keeping Requirements

(a) To document **the** compliance **status** with the requirements in Conditions D.11.1 and D.11.2, the Permittee shall maintain records of all fuel sampling and analysis data, pursuant to 326 IAC 7-2. Records and shall be complete and sufficient to establish compliance with the SO_2 limit in Condition D.11.1.

(b) Section C - General Record Keeping Requirements contains the Permittee's obligations with regard to the record keeping required by this condition.

Change No. 21 The Preventive Maintenance Plan Requirements were added as Condition D.13.2 as follows:

D.13.2 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

A Preventive Maintenance Plan (PMP) is required for all brazing equipment, cutting torches, soldering equipment, welding equipment, and grinding and machining operations. Section B - Preventive Maintenance Plan contains the Permittee's obligations with regard to the preventive maintenance plan required by this condition.

Conclusion and Recommendation

The operation of this proposed modification shall be subject to the conditions of the attached proposed Part 70 Significant Permit Modification No.: 157-30742-00012.

(1) Based on the facts, conditions and evaluations made, OAQ recommends to the IDEM Commissioner that the Significant Permit Modification No.: 157-30742-00012 be approved.

(2) A copy of the preliminary findings is also available on the Internet at: www.in.gov/idem/permits/air/pending.html.

(3) For additional information about air permits and how the public and interested parties can participate, refer to the IDEM's Guide for Citizen Participation and Permit Guide on the Internet at: www.in.gov/idem/permits/guide/.

IDEM Contact

Questions regarding this proposed permit can be directed to:

Kimberly Cottrell
Indiana Department Environmental Management
Office of Air Quality
100 North Senate Avenue
MC 61-53, Room 1003
Indianapolis, Indiana 46204-2251
Toll free (within Indiana): 1-800-451-6027 extension 3-0870
Or dial directly: (317) 233-0870
kcottrel@idem.in.gov

Please refer to Significant Permit Modification No.: 157-30742-00012 in all correspondence.

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

SENT VIA U.S. MAIL: CONFIRMED DELIVERY AND SIGNATURE REQUESTED

TO: Robin Mills Ridgway
Purdue University HMMT
201 Ahlers Drive
West Lafayette, IN 47906

DATE: May 1, 2012

FROM: Matt Stuckey, Branch Chief
Permits Branch
Office of Air Quality

SUBJECT: Final Decision
Title V
157-30742-00012

Enclosed is the final decision and supporting materials for the air permit application referenced above. Please note that this packet contains the original, signed, permit documents.

The final decision is being sent to you because our records indicate that you are the contact person for this application. However, if you are not the appropriate person within your company to receive this document, please forward it to the correct person.

A copy of the final decision and supporting materials has also been sent via standard mail to:
Robert E McMains, Responsible Official
David Jordan, Consultant, ERM
OAQ Permits Branch Interested Parties List

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178, or toll-free at 1-800-451-6027 (ext. 3-0178), and ask to speak to the permit reviewer who prepared the permit. If you think you have received this document in error, please contact Joanne Smiddie-Brush of my staff at 1-800-451-6027 (ext 3-0185), or via e-mail at jbrush@idem.IN.gov.

Final Applicant Cover letter.dot 11/30/07

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

Mitchell E. Daniels Jr.
Governor

Thomas W. Easterly
Commissioner

100 North Senate Avenue
Indianapolis, Indiana 46204
(317) 232-8603
Toll Free (800) 451-6027
www.idem.IN.gov

TO: West Lafayette Public Library

From: Matthew Stuckey, Branch Chief
Permits Branch
Office of Air Quality

Subject: **Important Information for Display Regarding a Final Determination**

Applicant Name: Purdue University
Permit Number: 157-30742-00012

You previously received information to make available to the public during the public comment period of a draft permit. Enclosed is a copy of the final decision and supporting materials for the same project. Please place the enclosed information along with the information you previously received. To ensure that your patrons have ample opportunity to review the enclosed permit, **we ask that you retain this document for at least 60 days.**

The applicant is responsible for placing a copy of the application in your library. If the permit application is not on file, or if you have any questions concerning this public review process, please contact Joanne Smiddie-Brush, OAQ Permits Administration Section at 1-800-451-6027, extension 3-0185.

Enclosures
Final Library.dot 11/30/07

Mail Code 61-53

IDEM Staff	DPABST 5/1/2012 Purdue University 157-30742-00012 (Final)			AFFIX STAMP HERE IF USED AS CERTIFICATE OF MAILING
Name and address of Sender	▶	Indiana Department of Environmental Management Office of Air Quality – Permits Branch 100 N. Senate Indianapolis, IN 46204	Type of Mail: **CERTIFICATE OF MAILING ONLY**	

Line	Article Number	Name, Address, Street and Post Office Address	Postage	Handing Charges	Act. Value (If Registered)	Insured Value	Due Send if COD	R.R. Fee	S.D. Fee	S.H. Fee	Rest. Del. Fee Remarks
1		Robin Mills Ridgway Purdue University HMMT, 201 Ahlers Dr West Lafayette IN 47906-5991 (Source CAATS) (CONFIRM DELIVERY)									
2		Robert E McMains VP - Physical Facilities Purdue University 401 S Grant St, 1662 Freehafer West Lafayette IN 47907-4024 *(RO CAATS)*									
3		Tippecanoe County Commissioners 20 N 3rd St, County Office Building Lafayette IN 47901 *(Local Official)*									
4		Tippecanoe County Health Department 20 N. 3rd St Lafayette IN 47901-1211 *(Health Department)*									
5		Lafayette City Council and Mayors Office 20 North 6th Street Lafayette IN 47901-1411 *(Local Official)*									
6		Ms. Dorothy Whicker 2700 Bonny Lane Lafayette IN 47904 *(Affected Party)*									
7		Ms. Geneva Werner 3212 Longlois Drive Lafayette IN 47904-1718 *(Affected Party)*									
8		Mrs. Phyllis Owens 3600 Cypress Lane Lafayette IN 47905 *(Affected Party)*									
9		Mr. Jerry White 1901 King Eider Ct West Lafayette IN 47906 *(Affected Party)*									
10		West Lafayette Public Library 208 W Columbus St West Lafayette IN 47906-3096 *(Library)*									
11		Ms. Rose Filley 5839 Lookout Drive West Lafayette IN 47906 *(Affected Party)*									
12		Mr. William Cramer 128 Seminole Drive West Lafayette IN 47906 *(Affected Party)*									
13		Mr. Robert Kelley 2555 S 30th Street Lafayette IN 44909 (Affected Party)									
14		David Jordan Environmental Resources Management (ERM) 11350 North Meridian, Suite 320 Carmel IN 46032 *(Consultant)*									
15		West Lafayette City Council and Mayors Office 609 W. Navajo West Lafayette IN 47906 *(Local Official)*									

Total number of pieces Listed by Sender	Total number of Pieces Received at Post Office	Postmaster, Per (Name of Receiving employee)	The full declaration of value is required on all domestic and international registered mail. The maximum indemnity payable for the reconstruction of nonnegotiable documents under Express Mail document reconstructing insurance is $50,000 per piece subject to a limit of $50, 000 per occurrence. The maximum indemnity payable on Express mil merchandise insurance is $500. The maximum indemnity payable is $25,000 for registered mail, sent with optional postal insurance. See ***Domestic Mail Manual*** **R900, S913**, and **S921** for limitations of coverage on inured and COD mail. See ***International Mail Manual*** for limitations o coverage on international mail. Special handling charges apply only to Standard Mail (A) and Standard Mail (B) parcels.

FACSIMILIE OF PS Form 3877

Mail Code 61-53

IDEM Staff	DPABST 5/1/2012 Purdue University 157-30742-00012 (Final)			AFFIX STAMP HERE IF USED AS CERTIFICATE OF MAILING
Name and address of Sender	▶	Indiana Department of Environmental Management Office of Air Quality – Permits Branch 100 N. Senate Indianapolis, IN 46204	Type of Mail: **CERTIFICATE OF MAILING ONLY**	

Line	Article Number	Name, Address, Street and Post Office Address	Postage	Handing Charges	Act. Value (If Registered)	Insured Value	Due Send if COD	R.R. Fee	S.D. Fee	S.H. Fee	Rest. Del. Fee Remarks
1		James Program Assistant Sierra Club Environmental Law Program 85 Second St 2nd Floor San Francisco CA 94105 (Affected Party)									
2											
3											
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											

Total number of pieces Listed by Sender	Total number of Pieces Received at Post Office	Postmaster, Per (Name of Receiving employee)	The full declaration of value is required on all domestic and international registered mail. The maximum indemnity payable for the reconstruction of nonnegotiable documents under Express Mail document reconstructing insurance is $50,000 per piece subject to a limit of $50, 000 per occurrence. The maximum indemnity payable on Express mil merchandise insurance is $500. The maximum indemnity payable is $25,000 for registered mail, sent with optional postal insurance. See ***Domestic Mail Manual*** **R900, S913**, and **S921** for limitations of coverage on inured and COD mail. See ***International Mail Manual*** for limitations o coverage on international mail. Special handling charges apply only to Standard Mail (A) and Standard Mail (B) parcels.

FACSIMILIE OF PS Form 3877