



# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

*Mitchell E. Daniels Jr.*  
Governor

*Thomas W. Easterly*  
Commissioner

100 North Senate Avenue  
Indianapolis, Indiana 46204  
(317) 232-8603  
Toll Free (800) 451-6027  
[www.idem.IN.gov](http://www.idem.IN.gov)

TO: Interested Parties / Applicant

DATE: July 19, 2012

RE: Indiana Municipal Power Agency – Anderson Station / 095 - 30940 - 00051

FROM: Matthew Stuckey, Branch Chief  
Permits Branch  
Office of Air Quality

## Notice of Decision: Approval – Effective Immediately

Please be advised that on behalf of the Commissioner of the Department of Environmental Management, I have issued a decision regarding the enclosed matter. Pursuant to IC 13-15-5-3, this permit is effective immediately, unless a petition for stay of effectiveness is filed and granted, and may be revoked or modified in accordance with the provisions of IC 13-15-7-1.

If you wish to challenge this decision, IC 4-21.5-3-7 and IC 13-15-6-1(b) or IC 13-15-6-1(a) require that you file a petition for administrative review. This petition may include a request for stay of effectiveness and must be submitted to the Office of Environmental Adjudication, 100 North Senate Avenue, Government Center North, Suite N 501E, Indianapolis, IN 46204.

For an **initial Title V Operating Permit**, a petition for administrative review must be submitted to the Office of Environmental Adjudication within **thirty (30)** days from the receipt of this notice provided under IC 13-15-5-3, pursuant to IC 13-15-6-1(b).

For a **Title V Operating Permit renewal**, a petition for administrative review must be submitted to the Office of Environmental Adjudication within **fifteen (15)** days from the receipt of this notice provided under IC 13-15-5-3, pursuant to IC 13-15-6-1(a).

The filing of a petition for administrative review is complete on the earliest of the following dates that apply to the filing:

- (1) the date the document is delivered to the Office of Environmental Adjudication (OEA);
- (2) the date of the postmark on the envelope containing the document, if the document is mailed to OEA by U.S. mail; or
- (3) The date on which the document is deposited with a private carrier, as shown by receipt issued by the carrier, if the document is sent to the OEA by private carrier.

The petition must include facts demonstrating that you are either the applicant, a person aggrieved or adversely affected by the decision or otherwise entitled to review by law. Please identify the permit, decision, or other order for which you seek review by permit number, name of the applicant, location, date of this notice and all of the following:

- (1) the name and address of the person making the request;
- (2) the interest of the person making the request;
- (3) identification of any persons represented by the person making the request;
- (4) the reasons, with particularity, for the request;
- (5) the issues, with particularity, proposed for considerations at any hearing; and
- (6) identification of the terms and conditions which, in the judgment of the person making the request, would be appropriate in the case in question to satisfy the requirements of the law governing documents of the type issued by the Commissioner.

Pursuant to 326 IAC 2-7-18(d), any person may petition the U.S. EPA to object to the issuance of an initial Title V operating permit, permit renewal, or modification within sixty (60) days of the end of the forty-five (45) day EPA review period. Such an objection must be based only on issues that were raised with reasonable specificity during the public comment period, unless the petitioner demonstrates that it was impracticable to raise such issues, or if the grounds for such objection arose after the comment period.

To petition the U.S. EPA to object to the issuance of a Title V operating permit, contact:

U.S. Environmental Protection Agency  
401 M Street  
Washington, D.C. 20406

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178. Callers from within Indiana may call toll-free at 1-800-451-6027, ext. 3-0178.



**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT**

*We Protect Hoosiers and Our Environment.*

*Mitchell E. Daniels Jr.*  
Governor

*Thomas W. Easterly*  
Commissioner

100 North Senate Avenue  
Indianapolis, Indiana 46204  
(317) 232-8603  
Toll Free (800) 451-6027  
[www.idem.IN.gov](http://www.idem.IN.gov)

**Part 70 Operating Permit Renewal  
OFFICE OF AIR QUALITY**

**Indiana Municipal Power Agency – Anderson Station  
6035 Park Road  
Anderson, Indiana 46011**

(herein known as the Permittee) is hereby authorized to operate subject to the conditions contained herein, the source described in Section A (Source Summary) of this permit.

**The Permittee must comply with all conditions of this permit. Noncompliance with any provisions of this permit is grounds for enforcement action; permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. Noncompliance with any provision of this permit, except any provision specifically designated as not federally enforceable, constitutes a violation of the Clean Air Act. It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. An emergency does constitute an affirmative defense in an enforcement action provided the Permittee complies with the applicable requirements set forth in Section B, Emergency Provisions.**

This permit is issued in accordance with 326 IAC 2 and 40 CFR Part 70 Appendix A and contains the conditions and provisions specified in 326 IAC 2-7 as required by 42 U.S.C. 7401, et. seq. (Clean Air Act as amended by the 1990 Clean Air Act Amendments), 40 CFR Part 70.6, IC 13-15 and IC 13-17.

Operation Permit No.: T 095-30940-00051	
Issued by:	Issuance Date: July 19, 2012
 Tripurari P. Sinha, Ph. D., Section Chief Permits Branch Office of Air Quality	Expiration Date: July 19, 2017

## TABLE OF CONTENTS

### A. SOURCE SUMMARY

- A.1 General Information [326 IAC 2-7-4(c)][326 IAC 2-7-5(14)][326 IAC 2-7-1(22)]
- A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)]  
[326 IAC 2-7-5(14)]
- A.3 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)][326 IAC 2-7-4(c)]  
[326 IAC 2-7-5(14)]
- A.4 Part 70 Permit Applicability [326 IAC 2-7-2]

### B. GENERAL CONDITIONS

- B.1 Definitions [326 IAC 2-7-1]
- B.2 Permit Term [326 IAC 2-7-5(2)][326 IAC 2-1.1-9.5][326 IAC 2-7-4(a)(1)(D)]  
[IC 13-15-3-6(a)]
- B.3 Term of Conditions [326 IAC 2-1.1-9.5]
- B.4 Enforceability [326 IAC 2-7-7] [IC 13-17-12]
- B.5 Severability [326 IAC 2-7-5(5)]
- B.6 Property Rights or Exclusive Privilege [326 IAC 2-7-5(6)(D)]
- B.7 Duty to Provide Information [326 IAC 2-7-5(6)(E)]
- B.8 Certification [326 IAC 2-7-4(f)][326 IAC 2-7-6(1)][326 IAC 2-7-5(3)(C)]
- B.9 Annual Compliance Certification [326 IAC 2-7-6(5)]
- B.10 Preventive Maintenance Plan [326 IAC 2-7-5(12)][326 IAC 1-6-3]
- B.11 Emergency Provisions [326 IAC 2-7-16]
- B.12 Permit Shield [326 IAC 2-7-15][326 IAC 2-7-20][326 IAC 2-7-12]
- B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5][326 IAC 2-7-10.5]
- B.14 Termination of Right to Operate [326 IAC 2-7-10][326 IAC 2-7-4(a)]
- B.15 Permit Modification, Reopening, Revocation and Reissuance, or Termination  
[326 IAC 2-7-5(6)(C)][326 IAC 2-7-8(a)][326 IAC 2-7-9]
- B.16 Permit Renewal [326 IAC 2-7-3][326 IAC 2-7-4][326 IAC 2-7-8(e)]
- B.17 Permit Amendment or Modification [326 IAC 2-7-11][326 IAC 2-7-12] [40 CFR 72]
- B.18 Permit Revision Under Economic Incentives and Other Programs [326 IAC 2-7-5(8)]  
[326 IAC 2-7-12(b)(2)]
- B.19 Operational Flexibility [326 IAC 2-7-20][326 IAC 2-7-10.5]
- B.20 Source Modification Requirement [326 IAC 2-7-10.5]
- B.21 Inspection and Entry [326 IAC 2-7-6][IC 13-14-2-2][IC 13-30-3-1][IC 13-17-3-2]
- B.22 Transfer of Ownership or Operational Control [326 IAC 2-7-11]
- B.23 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-7-5(7)][326 IAC 2-1.1-7]
- B.24 Advanced Source Modification Approval [326 IAC 2-7-5(15)] [326 IAC 2-7-10.5]
- B.25 Credible Evidence [326 IAC 2-7-5(3)][326 IAC 2-7-6][62 FR 8314] [326 IAC 1-1-6]

### C. SOURCE OPERATION CONDITIONS

#### Emission Limitations and Standards [326 IAC 2-7-5(1)]

- C.1 Particulate Emission Limitations For Processes with Process Weight Rates  
Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]
- C.2 Opacity [326 IAC 5-1]
- C.3 Open Burning [326 IAC 4-1] [IC 13-17-9]
- C.4 Incineration [326 IAC 4-2] [326 IAC 9-1-2]
- C.5 Fugitive Dust Emissions [326 IAC 6-4]
- C.6 Stack Height [326 IAC 1-7]
- C.7 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

#### Testing Requirements [326 IAC 2-7-6(1)]

- C.8 Performance Testing [326 IAC 3-6]

**Compliance Requirements [326 IAC 2-1.1-11]**

- C.9 Compliance Requirements [326 IAC 2-1.1-11]

**Compliance Monitoring Requirements [326 IAC 2-7-5(1)][326 IAC 2-7-6(1)]**

- C.10 Compliance Monitoring [326 IAC 2-7-5(3)][326 IAC 2-7-6(1)]
- C.11 Monitoring Methods [326 IAC 3][40 CFR 60][40 CFR 63]

**Corrective Actions and Response Steps [326 IAC 2-7-5][326 IAC 2-7-6]**

- C.12 Emergency Reduction Plans [326 IAC 1-5-2] [326 IAC 1-5-3]
- C.13 Risk Management Plan [326 IAC 2-7-5(12)] [40 CFR 68]
- C.14 Response to Excursions or Exceedances [326 IAC 2-7-5] [326 IAC 2-7-6]
- C.15 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5] [326 IAC 2-7-6]

**Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

- C.16 Emission Statement [326 IAC 2-7-5(3)(C)(iii)][326 IAC 2-7-5(7)][326 IAC 2-7-19(c)] [326 IAC 2-6]
- C.17 General Record Keeping Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-6]
- C.18 General Reporting Requirements [326 IAC 2-7-5(3)(C)] [326 IAC 2-1.1-11]

**Stratospheric Ozone Protection**

- C.19 Compliance with 40 CFR 82 and 326 IAC 22-1

**D.1. FACILITY OPERATION CONDITIONS**

**Emission Limitations and Standards [326 IAC 2-7-5(1)]**

- D.1.1 Prevention of Significant Deterioration (PSD) Minor Limit [326 IAC 2-2]
- D.1.2 SO<sub>2</sub> Limitations [326 IAC 7-2]
- D.1.3 Streamlined Requirements [326 IAC 2-7-24]

**Compliance Determination Requirements**

- D.1.4 Nitrogen Oxide Control
- D.1.5 Testing Requirements [326 IAC 2-7-6(1),(6)] [326 IAC 2-1.1-11]

**Compliance Monitoring Requirements [326 IAC 2-7-5(1)][326 IAC 2-7-6(1)]**

- D.1.6 Visible Emissions Notations

**Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

- D.1.7 Record Keeping Requirements
- D.1.8 Reporting Requirements

**D.2 FACILITY OPERATION CONDITIONS - Engines**

- D.2.1 Prevention of Significant Deterioration (PSD) Minor Limit [326 IAC 2-2]

**Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

- D.2.2 Record Keeping Requirements
- D.2.3 Reporting Requirements

**E.1 FACILITY OPERATION CONDITIONS**

**Emission Limitations and Standards [326 IAC 2-7-5(1)]**

- E.1.1 General Provisions Relating to New Source Performance Standards (NSPS) [326 IAC 12-1] [40 CFR 60, Subpart A] [326 IAC 12]

- E.1.2 Standards of Performance for Stationary Gas Turbines (NSPS) [326 IAC 12]  
[40 CFR 60, Subpart GG]

## **E.2 FACILITY OPERATION CONDITIONS**

### **Emission Limitations and Standards [326 IAC 2-7-5(1)]**

- E.2.1 General Provisions Relating to NESHAP ZZZZ [326 IAC 20-1] [40 CFR 63, Subpart A]
- E.2.2 National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines [40 CFR 63, Subpart ZZZZ] [326 IAC 20-82]

## **F.1 FACILITY OPERATION CONDITIONS**

### **Acid Rain Program**

- F.1.1 Acid Rain Permit [326 IAC 2-7-5(1)(C)] [326 IAC 21] [40 CFR 72 through 40 CFR 78]
- F.1.2 Title IV Emissions Allowances [326 IAC 2-7-5(4)] [326 IAC 21]

## **G Clean Air Interstate Rule (CAIR) Nitrogen Oxides Annual, Sulfur Dioxide, and Nitrogen Oxides Ozone Season Trading Programs – CAIR Permit for CAIR Units Under 326 IAC 24-1-1(a), 326 IAC 24-2-1(a), and 326 IAC 24-3-1(a)**

**ORIS Code: 7335**

- G.1 Automatic Incorporation of Definitions [326 IAC 24-1-7(e)] [326 IAC 24-2-7(e)] [326 IAC 24-3-7(e)] [40 CFR 97.123(b)] [40 CFR 97.223(b)] [40 CFR 97.323(b)]
- G.2 Standard Permit Requirements [326 IAC 24-1-4(a)] [326 IAC 24-2-4(a)] [326 IAC 24-3-4(a)] [40 CFR 97.106(a)] [40 CFR 97.206(a)] [40 CFR 97.306(a)]
- G.3 Monitoring, Reporting, and Record Keeping Requirements [326 IAC 24-1-4(b)] [326 IAC 24-2-4(b)] [326 IAC 24-3-4(b)] [40 CFR 97.106(b)] [40 CFR 97.206(b)] [40 CFR 97.306(b)]
- G.4.1 Nitrogen Oxides Emission Requirements [326 IAC 24-1-4(c)] [40 CFR 97.106(c)]
- G.4.2 Sulfur Dioxide Emission Requirements [326 IAC 24-2-4(c)] [40 CFR 97.206(c)]
- G.4.3 Nitrogen Oxides Ozone Season Emission Requirements [326 IAC 24-3-4(c)] [40 CFR 97.306(c)]
- G.5 Excess Emissions Requirements [326 IAC 24-1-4(d)] [326 IAC 24-2-4(d)] [326 IAC 24-3-4(d)] [40 CFR 97.106(d)] [40 CFR 97.206(d)] [40 CFR 97.306(d)]
- G.6 Record Keeping Requirements [326 IAC 24-1-4(e)] [326 IAC 24-2-4(e)] [326 IAC 24-3-4(e)] [326 IAC 2-7-5(3)] [40 CFR 97.106(e)] [40 CFR 97.206(e)] [40 CFR 97.306(e)]
- G.7 Reporting Requirements [326 IAC 24-1-4(e)] [326 IAC 24-2-4(e)] [326 IAC 24-3-4(e)] [40 CFR 97.106(e)] [40 CFR 97.206(e)] [40 CFR 97.306(e)]
- G.8 Liability [326 IAC 24-1-4(f)] [326 IAC 24-2-4(f)] [326 IAC 24-3-4(f)] [40 CFR 97.106(f)] [40 CFR 97.206(f)] [40 CFR 97.306(f)]
- G.9 Effect on Other Authorities [326 IAC 24-1-4(g)] [326 IAC 24-2-4(g)] [326 IAC 24-3-4(g)] [40 CFR 97.106(g)] [40 CFR 97.206(g)] [40 CFR 97.306(g)]
- G.10 CAIR Designated Representative and Alternate CAIR Designated Representative [326 IAC 24-1-6] [326 IAC 24-2-6] [326 IAC 24-3-6] [40 CFR 97, Subpart BB] [40 CFR 97, Subpart BBB] [40 CFR 97, Subpart BBBB]

### **Certification**

### **Emergency Occurrence Report**

### **Quarterly Report**

### **Quarterly Deviation and Compliance Monitoring Report**

Attachment A:40 CFR 63, Subpart ZZZZ  
Attachment B:40 CFR 60, Subpart GG  
Attachment C: Title IV-Acid Rain

## SECTION A SOURCE SUMMARY

This permit is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ). The information describing the source contained in conditions A.1 through A.3 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this permit pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

### A.1 General Information [326 IAC 2-7-4(c)][326 IAC 2-7-5(14)][326 IAC 2-7-1(22)]

---

The Permittee owns and operates a stationary Station relating to the operation of a gas turbine electric generating plant.

Source Address:	6035 Park Road, Anderson, Indiana 46011
General Source Phone Number:	(317) 428-6710
SIC Code:	4911
County Location:	Madison
Source Location Status:	Attainment for all criteria pollutants
Source Status:	Part 70 Operating Permit Program Minor Source, under PSD Greenhouse Gas (GHG) potential to emit (PTE) is equal to or more than one hundred thousand (100,000) tons of CO2 equivalent emissions (CO2e) per year Minor Source, Section 112 of the Clean Air Act Not 1 of 28 Source Categories

### A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)][326 IAC 2-7-5(14)]

---

This stationary source consists of the following emission units and pollution control devices:

- (a) Two (2) 38.7 MW natural gas-fired simple cycle gas turbines, identified as T1 and T2, constructed in 1990, using No. 2 fuel oil as the back-up fuel, controlled by a water injection system, each with a maximum heat input capacity of 431 MMBtu/hr while combusting natural gas and a maximum heat input capacity of 425 MMBtu/hr while combusting No. 2 fuel oil (at ISO conditions), and exhausting to stacks 3 and 4, respectively. Under 40 CFR Part 60, Subpart GG, turbines T1 and T2 are considered stationary gas turbines.
- (b) One (1) 84 MW natural gas-fired simple cycle gas turbine, identified as T3, constructed in 2002, using No. 2 fuel oil as the back-up fuel, with a maximum heat input capacity of 858 MMBtu/hr while combusting natural gas and a maximum heat input capacity of 850 MMBtu/hr while combusting No. 2 fuel oil (at ISO conditions), and exhausting to stack 7. This unit is a lean premix combustion turbine. Under 40 CFR Part 60, Subpart GG, turbine T3 is considered a stationary gas turbine.
- (c) Two (2) diesel-fired black start stationary RICE, identified as D7 and D8, constructed in 1990, each with a maximum power output of 630 horsepower and a maximum heat input of 2 MMBtu/hr, exhausting to stacks 5 and 6, respectively.

### A.3 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)][326 IAC 2-7-4(c)][326 IAC 2-7-5(14)]

---

This stationary source does not include any insignificant activities, which are specifically regulated, as defined in 326 IAC 2-7-1(21)

A.4 Part 70 Permit Applicability [326 IAC 2-7-2]

---

This stationary source is required to have a Part 70 permit by 326 IAC 2-7-2 (Applicability) because:

- (a) It is a major source, as defined in 326 IAC 2-7-1(22);
- (b) It is a source in a source category designated by the United States Environmental Protection Agency (U.S. EPA) under 40 CFR 70.3 (Part 70 - Applicability).
- (c) It is an affected source under Title IV (Acid Deposition Control) of the Clean Air Act, as defined in 326 IAC 2-7-1(3);

## SECTION B GENERAL CONDITIONS

### B.1 Definitions [326 IAC 2-7-1]

---

Terms in this permit shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, the applicable definitions found in the statutes or regulations (IC 13-11, 326 IAC 1-2 and 326 IAC 2-7) shall prevail.

### B.2 Permit Term [326 IAC 2-7-5(2)][326 IAC 2-1.1-9.5][326 IAC 2-7-4(a)(1)(D)][IC 13-15-3-6(a)]

---

- (a) This permit, T 095-30940-00051, is issued for a fixed term of five (5) years from the issuance date of this permit, as determined in accordance with IC 4-21.5-3-5(f) and IC 13-15-5-3. Subsequent revisions, modifications, or amendments of this permit do not affect the expiration date of this permit or of permits issued pursuant to Title IV of the Clean Air Act and 326 IAC 21 (Acid Deposition Control).
- (b) If IDEM, OAQ, upon receiving a timely and complete renewal permit application, fails to issue or deny the permit renewal prior to the expiration date of this permit, this existing permit shall not expire and all terms and conditions shall continue in effect, including any permit shield provided in 326 IAC 2-7-15, until the renewal permit has been issued or denied.

### B.3 Term of Conditions [326 IAC 2-1.1-9.5]

---

Notwithstanding the permit term of a permit to construct, a permit to operate, or a permit modification, any condition established in a permit issued pursuant to a permitting program approved in the state implementation plan shall remain in effect until:

- (a) the condition is modified in a subsequent permit action pursuant to Title I of the Clean Air Act; or
- (b) the emission unit to which the condition pertains permanently ceases operation.

### B.4 Enforceability [326 IAC 2-7-7] [IC 13-17-12]

---

Unless otherwise stated, all terms and conditions in this permit, including any provisions designed to limit the source's potential to emit, are enforceable by IDEM, the United States Environmental Protection Agency (U.S. EPA) and by citizens in accordance with the Clean Air Act.

### B.5 Severability [326 IAC 2-7-5(5)]

---

The provisions of this permit are severable; a determination that any portion of this permit is invalid shall not affect the validity of the remainder of the permit.

### B.6 Property Rights or Exclusive Privilege [326 IAC 2-7-5(6)(D)]

---

This permit does not convey any property rights of any sort or any exclusive privilege.

### B.7 Duty to Provide Information [326 IAC 2-7-5(6)(E)]

---

- (a) The Permittee shall furnish to IDEM, OAQ, within a reasonable time, any information that IDEM, OAQ may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. Upon request, the Permittee shall also furnish to IDEM, OAQ copies of records required to be kept by this permit.
- (b) For information furnished by the Permittee to IDEM, OAQ, the Permittee may include a claim of confidentiality in accordance with 326 IAC 17.1. When furnishing copies of requested records directly to U. S. EPA, the Permittee may assert a claim of confidentiality in accordance with 40 CFR 2, Subpart B.

B.8 Certification [326 IAC 2-7-4(f)][326 IAC 2-7-6(1)][326 IAC 2-7-5(3)(C)]

- (a) A certification required by this permit meets the requirements of 326 IAC 2-7-6(1) if:
- (1) it contains a certification by a "responsible official" as defined by 326 IAC 2-7-1(34), and
  - (2) the certification states that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
- (b) The Permittee may use the attached Certification Form, or its equivalent with each submittal requiring certification. One (1) certification may cover multiple forms in one (1) submittal.
- (c) A "responsible official" is defined at 326 IAC 2-7-1(34).

B.9 Annual Compliance Certification [326 IAC 2-7-6(5)]

- (a) The Permittee shall annually submit a compliance certification report which addresses the status of the source's compliance with the terms and conditions contained in this permit, including emission limitations, standards, or work practices. All certifications shall cover the time period from January 1 to December 31 of the previous year, and shall be submitted no later than July 1 of each year to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V  
Air and Radiation Division, Air Enforcement Branch - Indiana (AE-17J)  
77 West Jackson Boulevard  
Chicago, Illinois 60604-3590

- (b) The annual compliance certification report required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
- (c) The annual compliance certification report shall include the following:
- (1) The appropriate identification of each term or condition of this permit that is the basis of the certification;
  - (2) The compliance status;
  - (3) Whether compliance was continuous or intermittent;
  - (4) The methods used for determining the compliance status of the source, currently and over the reporting period consistent with 326 IAC 2-7-5(3); and

- (5) Such other facts, as specified in Sections D of this permit, as IDEM, OAQ may require to determine the compliance status of the source.

The submittal by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

B.10 Preventive Maintenance Plan [326 IAC 2-7-5(12)][326 IAC 1-6-3]

- (a) A Preventive Maintenance Plan meets the requirements of 326 IAC 1-6-3 if it includes, at a minimum:

- (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;
- (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
- (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

The Permittee shall implement the PMPs.

- (b) If required by specific condition(s) in Section D of this permit where no PMP was previously required, the Permittee shall prepare and maintain Preventive Maintenance Plans (PMPs) no later than ninety (90) days after issuance of this permit or ninety (90) days after initial start-up, whichever is later, including the following information on each facility:

- (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;
- (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
- (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

If, due to circumstances beyond the Permittee's control, the PMPs cannot be prepared and maintained within the above time frame, the Permittee may extend the date an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

The PMP extension notification does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

The Permittee shall implement the PMPs.

- (c) A copy of the PMPs shall be submitted to IDEM, OAQ upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. IDEM, OAQ may require the Permittee to revise its PMPs whenever lack of proper maintenance

causes or is the primary contributor to an exceedance of any limitation on emissions. The PMPs and their submittal do not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

- (d) To the extent the Permittee is required by 40 CFR Part 60/63 to have an Operation Maintenance, and Monitoring (OMM) Plan for a unit, such Plan is deemed to satisfy the PMP requirements of 326 IAC 1-6-3 for that unit.

#### B.11 Emergency Provisions [326 IAC 2-7-16]

---

- (a) An emergency, as defined in 326 IAC 2-7-1(12), is not an affirmative defense for an action brought for noncompliance with a federal or state health-based emission limitation.
- (b) An emergency, as defined in 326 IAC 2-7-1(12), constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limitation if the affirmative defense of an emergency is demonstrated through properly signed, contemporaneous operating logs or other relevant evidence that describe the following:
  - (1) An emergency occurred and the Permittee can, to the extent possible, identify the causes of the emergency;
  - (2) The permitted facility was at the time being properly operated;
  - (3) During the period of an emergency, the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards or other requirements in this permit;
  - (4) For each emergency lasting one (1) hour or more, the Permittee notified IDEM, OAQ, within four (4) daytime business hours after the beginning of the emergency, or after the emergency was discovered or reasonably should have been discovered;

Telephone Number: 1-800-451-6027 (ask for Office of Air Quality, Compliance and Enforcement Branch), or  
Telephone Number: 317-233-0178 (ask for Office of Air Quality, Compliance and Enforcement Branch)  
Facsimile Number: 317-233-6865

- (5) For each emergency lasting one (1) hour or more, the Permittee submitted the attached Emergency Occurrence Report Form or its equivalent, either by mail or facsimile to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

within two (2) working days of the time when emission limitations were exceeded due to the emergency.

The notice fulfills the requirement of 326 IAC 2-7-5(3)(C)(ii) and must contain the following:

- (A) A description of the emergency;

- (B) Any steps taken to mitigate the emissions; and
- (C) Corrective actions taken.

The notification which shall be submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

- (6) The Permittee immediately took all reasonable steps to correct the emergency.
- (c) In any enforcement proceeding, the Permittee seeking to establish the occurrence of an emergency has the burden of proof.
- (d) This emergency provision supersedes 326 IAC 1-6 (Malfunctions). This permit condition is in addition to any emergency or upset provision contained in any applicable requirement.
- (e) The Permittee seeking to establish the occurrence of an emergency shall make records available upon request to ensure that failure to implement a PMP did not cause or contribute to an exceedance of any limitations on emissions. However, IDEM, OAQ may require that the Preventive Maintenance Plans required under 326 IAC 2-7-4(c)(8) be revised in response to an emergency.
- (f) Failure to notify IDEM, OAQ by telephone or facsimile of an emergency lasting more than one (1) hour in accordance with (b)(4) and (5) of this condition shall constitute a violation of 326 IAC 2-7 and any other applicable rules.
- (g) If the emergency situation causes a deviation from a technology-based limit, the Permittee may continue to operate the affected emitting facilities during the emergency provided the Permittee immediately takes all reasonable steps to correct the emergency and minimize emissions.

B.12 Permit Shield [326 IAC 2-7-15][326 IAC 2-7-20][326 IAC 2-7-12]

- (a) Pursuant to 326 IAC 2-7-15, the Permittee has been granted a permit shield. The permit shield provides that compliance with the conditions of this permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that either the applicable requirements are included and specifically identified in this permit or the permit contains an explicit determination or concise summary of a determination that other specifically identified requirements are not applicable. The Indiana statutes from IC 13 and rules from 326 IAC, referenced in conditions in this permit, are those applicable at the time the permit was issued. The issuance or possession of this permit shall not alone constitute a defense against an alleged violation of any law, regulation or standard, except for the requirement to obtain a Part 70 permit under 326 IAC 2-7 or for applicable requirements for which a permit shield has been granted.

This permit shield does not extend to applicable requirements which are promulgated after the date of issuance of this permit unless this permit has been modified to reflect such new requirements.

- (b) If, after issuance of this permit, it is determined that the permit is in nonconformance with an applicable requirement that applied to the source on the date of permit issuance, IDEM, OAQ, shall immediately take steps to reopen and revise this permit and issue a compliance order to the Permittee to ensure expeditious compliance with the applicable

requirement until the permit is reissued. The permit shield shall continue in effect so long as the Permittee is in compliance with the compliance order.

- (c) No permit shield shall apply to any permit term or condition that is determined after issuance of this permit to have been based on erroneous information supplied in the permit application. Erroneous information means information that the Permittee knew to be false, or in the exercise of reasonable care should have been known to be false, at the time the information was submitted.
- (d) Nothing in 326 IAC 2-7-15 or in this permit shall alter or affect the following:
  - (1) The provisions of Section 303 of the Clean Air Act (emergency orders), including the authority of the U.S. EPA under Section 303 of the Clean Air Act;
  - (2) The liability of the Permittee for any violation of applicable requirements prior to or at the time of this permit's issuance;
  - (3) The applicable requirements of the acid rain program, consistent with Section 408(a) of the Clean Air Act; and
  - (4) The ability of U.S. EPA to obtain information from the Permittee under Section 114 of the Clean Air Act.
- (e) This permit shield is not applicable to any change made under 326 IAC 2-7-20(b)(2) (Sections 502(b)(10) of the Clean Air Act changes) and 326 IAC 2-7-20(c)(2) (trading based on State Implementation Plan (SIP) provisions).
- (f) This permit shield is not applicable to modifications eligible for group processing until after IDEM, OAQ, has issued the modifications. [326 IAC 2-7-12(c)(7)]
- (g) This permit shield is not applicable to minor Part 70 permit modifications until after IDEM, OAQ, has issued the modification. [326 IAC 2-7-12(b)(8)]

B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5][326 IAC 2-7-10.5]

- (a) All terms and conditions of permits established prior to T 095-30940-00051 and issued pursuant to permitting programs approved into the state implementation plan have been either:
  - (1) incorporated as originally stated,
  - (2) revised under 326 IAC 2-7-10.5, or
  - (3) deleted under 326 IAC 2-7-10.5.
- (b) Provided that all terms and conditions are accurately reflected in this permit, all previous registrations and permits are superseded by this Part 70 operating permit, except for permits issued pursuant to Title IV of the Clean Air Act and 326 IAC 21 (Acid Deposition Control)

B.14 Termination of Right to Operate [326 IAC 2-7-10][326 IAC 2-7-4(a)]

The Permittee's right to operate this source terminates with the expiration of this permit unless a timely and complete renewal application is submitted at least nine (9) months prior to the date of expiration of the source's existing permit, consistent with 326 IAC 2-7-3 and 326 IAC 2-7-4(a).

B.15 Permit Modification, Reopening, Revocation and Reissuance, or Termination  
[326 IAC 2-7-5(6)(C)][326 IAC 2-7-8(a)][326 IAC 2-7-9]

---

- (a) This permit may be modified, reopened, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a Part 70 Operating Permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any condition of this permit. [326 IAC 2-7-5(6)(C)] The notification by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).
- (b) This permit shall be reopened and revised under any of the circumstances listed in IC 13-15-7-2 or if IDEM, OAQ determines any of the following:
- (1) That this permit contains a material mistake.
  - (2) That inaccurate statements were made in establishing the emissions standards or other terms or conditions.
  - (3) That this permit must be revised or revoked to assure compliance with an applicable requirement. [326 IAC 2-7-9(a)(3)]
- (c) Proceedings by IDEM, OAQ to reopen and revise this permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of this permit for which cause to reopen exists. Such reopening and revision shall be made as expeditiously as practicable. [326 IAC 2-7-9(b)]
- (d) The reopening and revision of this permit, under 326 IAC 2-7-9(a), shall not be initiated before notice of such intent is provided to the Permittee by IDEM, OAQ at least thirty (30) days in advance of the date this permit is to be reopened, except that IDEM, OAQ may provide a shorter time period in the case of an emergency. [326 IAC 2-7-9(c)]

B.16 Permit Renewal [326 IAC 2-7-3][326 IAC 2-7-4][326 IAC 2-7-8(e)]

---

- (a) The application for renewal shall be submitted using the application form or forms prescribed by IDEM, OAQ and shall include the information specified in 326 IAC 2-7-4. Such information shall be included in the application for each emission unit at this source, except those emission units included on the trivial or insignificant activities list contained in 326 IAC 2-7-1(21) and 326 IAC 2-7-1(40). The renewal application does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

Request for renewal shall be submitted to:

Indiana Department of Environmental Management  
Permit Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

- (b) A timely renewal application is one that is:
- (1) Submitted at least nine (9) months prior to the date of the expiration of this permit; and

- (2) If the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
- (c) If the Permittee submits a timely and complete application for renewal of this permit, the source's failure to have a permit is not a violation of 326 IAC 2-7 until IDEM, OAQ takes final action on the renewal application, except that this protection shall cease to apply if, subsequent to the completeness determination, the Permittee fails to submit by the deadline specified, pursuant to 326 IAC 2-7-4(a)(2)(D), in writing by IDEM, OAQ any additional information identified as being needed to process the application.

**B.17 Permit Amendment or Modification [326 IAC 2-7-11][326 IAC 2-7-12] [40 CFR 72]**

---

- (a) Permit amendments and modifications are governed by the requirements of 326 IAC 2-7-11 or 326 IAC 2-7-12 whenever the Permittee seeks to amend or modify this permit.
- (b) Pursuant to 326 IAC 2-7-11(b) and 326 IAC 2-7-12(a), administrative Part 70 operating permit amendments and permit modifications for purposes of the acid rain portion of a Part 70 permit shall be governed by regulations promulgated under Title IV of the Clean Air Act. [40 CFR 72]
- (c) Any application requesting an amendment or modification of this permit shall be submitted to:  
  
Indiana Department of Environmental Management  
Permit Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251  
  
Any such application does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).
- (d) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-7-11(c)(3)]

**B.18 Permit Revision Under Economic Incentives and Other Programs [326 IAC 2-7-5(8)][326 IAC 2-7-12(b)(2)]**

---

- (a) No Part 70 permit revision or notice shall be required under any approved economic incentives, marketable Part 70 permits, emissions trading, and other similar programs or processes for changes that are provided for in a Part 70 permit.
- (b) Notwithstanding 326 IAC 2-7-12(b)(1) and 326 IAC 2-7-12(c)(1), minor Part 70 permit modification procedures may be used for Part 70 modifications involving the use of economic incentives, marketable Part 70 permits, emissions trading, and other similar approaches to the extent that such minor Part 70 permit modification procedures are explicitly provided for in the applicable State Implementation Plan (SIP) or in applicable requirements promulgated or approved by the U.S. EPA.

**B.19 Operational Flexibility [326 IAC 2-7-20][326 IAC 2-7-10.5]**

---

- (a) The Permittee may make any change or changes at the source that are described in 326 IAC 2-7-20(b) or (c) without a prior permit revision, if each of the following conditions is met:

- (1) The changes are not modifications under any provision of Title I of the Clean Air Act;
- (2) Any preconstruction approval required by 326 IAC 2-7-10.5 has been obtained;
- (3) The changes do not result in emissions which exceed the limitations provided in this permit (whether expressed herein as a rate of emissions or in terms of total emissions);
- (4) The Permittee notifies the:

Indiana Department of Environmental Management  
Permit Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V  
Air and Radiation Division, Regulation Development Branch - Indiana (AR-18J)  
77 West Jackson Boulevard  
Chicago, Illinois 60604-3590

in advance of the change by written notification at least ten (10) days in advance of the proposed change. The Permittee shall attach every such notice to the Permittee's copy of this permit; and

- (5) The Permittee maintains records on-site, on a rolling five (5) year basis, which document all such changes and emission trades that are subject to 326 IAC 2-7-20(b)(1) and (c)(1). The Permittee shall make such records available, upon reasonable request, for public review.

Such records shall consist of all information required to be submitted to IDEM, OAQ in the notices specified in 326 IAC 2-7-20(b)(1) and (c)(1).

- (b) The Permittee may make Section 502(b)(10) of the Clean Air Act changes (this term is defined at 326 IAC 2-7-1(36)) without a permit revision, subject to the constraint of 326 IAC 2-7-20(a). For each such Section 502(b)(10) of the Clean Air Act change, the required written notification shall include the following:

- (1) A brief description of the change within the source;
- (2) The date on which the change will occur;
- (3) Any change in emissions; and
- (4) Any permit term or condition that is no longer applicable as a result of the change.

The notification which shall be submitted is not considered an application form, report or compliance certification. Therefore, the notification by the Permittee does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

- (c) Emission Trades [326 IAC 2-7-20(c)]  
The Permittee may trade emissions increases and decreases at the source, where the applicable SIP provides for such emission trades without requiring a permit revision, subject to the constraints of Section (a) of this condition and those in 326 IAC 2-7-20(c).
- (d) Alternative Operating Scenarios [326 IAC 2-7-20(d)]  
The Permittee may make changes at the source within the range of alternative operating scenarios that are described in the terms and conditions of this permit in accordance with 326 IAC 2-7-5(9). No prior notification of IDEM, OAQ, or U.S. EPA is required.
- (e) Backup fuel switches specifically addressed in, and limited under, Section D of this permit shall not be considered alternative operating scenarios. Therefore, the notification requirements of part (a) of this condition do not apply.
- (f) This condition does not apply to emission trades of SO<sub>2</sub> or NO<sub>x</sub> under 326 IAC 21 or 326 IAC 10-4.

**B.20 Source Modification Requirement [326 IAC 2-7-10.5]**

---

A modification, construction, or reconstruction is governed by the requirements of 326 IAC 2.

**B.21 Inspection and Entry [326 IAC 2-7-6][IC 13-14-2-2][IC 13-30-3-1][IC 13-17-3-2]**

---

Upon presentation of proper identification cards, credentials, and other documents as may be required by law, and subject to the Permittee's right under all applicable laws and regulations to assert that the information collected by the agency is confidential and entitled to be treated as such, the Permittee shall allow IDEM, OAQ, U.S. EPA, or an authorized representative to perform the following:

- (a) Enter upon the Permittee's premises where a Part 70 source is located, or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
- (b) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, have access to and copy any records that must be kept under the conditions of this permit;
- (c) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, inspect any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit;
- (d) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, sample or monitor substances or parameters for the purpose of assuring compliance with this permit or applicable requirements; and
- (e) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, utilize any photographic, recording, testing, monitoring, or other equipment for the purpose of assuring compliance with this permit or applicable requirements.

**B.22 Transfer of Ownership or Operational Control [326 IAC 2-7-11]**

---

- (a) The Permittee must comply with the requirements of 326 IAC 2-7-11 whenever the Permittee seeks to change the ownership or operational control of the source and no other change in the permit is necessary.
- (b) Any application requesting a change in the ownership or operational control of the source shall contain a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new Permittee. The application shall be submitted to:

Indiana Department of Environmental Management  
Permit Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

Any such application does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-7-11(c)(3)]

**B.23 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-7-5(7)][326 IAC 2-1.1-7]**

---

- (a) The Permittee shall pay annual fees to IDEM, OAQ within thirty (30) calendar days of receipt of a billing. Pursuant to 326 IAC 2-7-19(b), if the Permittee does not receive a bill from IDEM, OAQ the applicable fee is due April 1 of each year.
- (b) Except as provided in 326 IAC 2-7-19(e), failure to pay may result in administrative enforcement action or revocation of this permit.
- (c) The Permittee may call the following telephone numbers: 1-800-451-6027 or 317-233-4230 (ask for OAQ, Billing, Licensing, and Training Section), to determine the appropriate permit fee.

**B.24 Advanced Source Modification Approval [326 IAC 2-7-5(15)] [326 IAC 2-7-10.5]**

---

- (a) The requirements to obtain a source modification approval under 326 IAC 2-7-10.5 or a permit modification under 326 IAC 2-7-12 are satisfied by this permit for the proposed emission units, control equipment or insignificant activities in Sections A.2 and A.3.
- (b) Pursuant to 326 IAC 2-1.1-9 any permit authorizing construction may be revoked if construction of the emission unit has not commenced within eighteen (18) months from the date of issuance of the permit, or if during the construction, work is suspended for a continuous period of one (1) year or more.

**B.25 Credible Evidence [326 IAC 2-7-5(3)][326 IAC 2-7-6][62 FR 8314] [326 IAC 1-1-6]**

---

For the purpose of submitting compliance certifications or establishing whether or not the Permittee has violated or is in violation of any condition of this permit, nothing in this permit shall preclude the use, including the exclusive use, of any credible evidence or information relevant to whether the Permittee would have been in compliance with the condition of this permit if the appropriate performance or compliance test or procedure had been performed.

## SECTION C SOURCE OPERATION CONDITIONS

Entire Source

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

C.1 Particulate Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2(e)(2), particulate emissions from any process not exempt under 326 IAC 6-3-1(b) or (c) which has a maximum process weight rate less than 100 pounds per hour and the methods in 326 IAC 6-3-2(b) through (d) do not apply shall not exceed 0.551 pounds per hour.

C.2 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-1 (Applicability) and 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

- (a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

C.3 Open Burning [326 IAC 4-1] [IC 13-17-9]

The Permittee shall not open burn any material except as provided in 326 IAC 4-1-3, 326 IAC 4-1-4 or 326 IAC 4-1-6. The previous sentence notwithstanding, the Permittee may open burn in accordance with an open burning approval issued by the Commissioner under 326 IAC 4-1-4.1.

C.4 Incineration [326 IAC 4-2] [326 IAC 9-1-2]

The Permittee shall not operate an incinerator except as provided in 326 IAC 4-2 or in this permit. The Permittee shall not operate a refuse incinerator or refuse burning equipment except as provided in 326 IAC 9-1-2 or in this permit.

C.5 Fugitive Dust Emissions [326 IAC 6-4]

The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions). 326 IAC 6-4-2(4) is not federally enforceable.

C.6 Stack Height [326 IAC 1-7]

The Permittee shall comply with the applicable provisions of 326 IAC 1-7 (Stack Height Provisions), for all exhaust stacks through which a potential (before controls) of twenty-five (25) tons per year or more of particulate matter or sulfur dioxide is emitted. The provisions of 326 IAC 1-7-1(3), 326 IAC 1-7-2, 326 IAC 1-7-3(c) and (d), 326 IAC 1-7-4, and 326 IAC 1-7-5(a), (b), and (d) are not federally enforceable.

C.7 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

- (a) Notification requirements apply to each owner or operator. If the combined amount of regulated asbestos containing material (RACM) to be stripped, removed or disturbed is at least 260 linear feet on pipes or 160 square feet on other facility components, or at least

thirty-five (35) cubic feet on all facility components, then the notification requirements of 326 IAC 14-10-3 are mandatory. All demolition projects require notification whether or not asbestos is present.

- (b) The Permittee shall ensure that a written notification is sent on a form provided by the Commissioner at least ten (10) working days before asbestos stripping or removal work or before demolition begins, per 326 IAC 14-10-3, and shall update such notice as necessary, including, but not limited to the following:
  - (1) When the amount of affected asbestos containing material increases or decreases by at least twenty percent (20%); or
  - (2) If there is a change in the following:
    - (A) Asbestos removal or demolition start date;
    - (B) Removal or demolition contractor; or
    - (C) Waste disposal site.
- (c) The Permittee shall ensure that the notice is postmarked or delivered according to the guidelines set forth in 326 IAC 14-10-3(2).
- (d) The notice to be submitted shall include the information enumerated in 326 IAC 14-10-3(3).

All required notifications shall be submitted to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

The notice shall include a signed certification from the owner or operator that the information provided in this notification is correct and that only Indiana licensed workers and project supervisors will be used to implement the asbestos removal project. The notifications do not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

- (e) **Procedures for Asbestos Emission Control**  
The Permittee shall comply with the applicable emission control procedures in 326 IAC 14-10-4 and 40 CFR 61.145(c). Per 326 IAC 14-10-1, emission control requirements are applicable for any removal or disturbance of RACM greater than three (3) linear feet on pipes or three (3) square feet on any other facility components or a total of at least 0.75 cubic feet on all facility components.
- (f) **Demolition and Renovation**  
The Permittee shall thoroughly inspect the affected facility or part of the facility where the demolition or renovation will occur for the presence of asbestos pursuant to 40 CFR 61.145(a).
- (g) **Indiana Licensed Asbestos Inspector**  
The Permittee shall comply with 326 IAC 14-10-1(a) that requires the owner or operator, prior to a renovation/demolition, to use an Indiana Licensed Asbestos Inspector to

thoroughly inspect the affected portion of the facility for the presence of asbestos. The requirement to use an Indiana Licensed Asbestos inspector is not federally enforceable.

### **Testing Requirements [326 IAC 2-7-6(1)]**

#### **C.8 Performance Testing [326 IAC 3-6]**

---

- (a) For performance testing required by this permit, a test protocol, except as provided elsewhere in this permit, shall be submitted to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

no later than thirty-five (35) days prior to the intended test date. The protocol submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

- (b) The Permittee shall notify IDEM, OAQ of the actual test date at least fourteen (14) days prior to the actual test date. The notification submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).
- (c) Pursuant to 326 IAC 3-6-4(b), all test reports must be received by IDEM, OAQ not later than forty-five (45) days after the completion of the testing. An extension may be granted by IDEM, OAQ if the Permittee submits to IDEM, OAQ a reasonable written explanation not later than five (5) days prior to the end of the initial forty-five (45) day period.

### **Compliance Requirements [326 IAC 2-1.1-11]**

#### **C.9 Compliance Requirements [326 IAC 2-1.1-11]**

---

The commissioner may require stack testing, monitoring, or reporting at any time to assure compliance with all applicable requirements by issuing an order under 326 IAC 2-1.1-11. Any monitoring or testing shall be performed in accordance with 326 IAC 3 or other methods approved by the commissioner or the U. S. EPA.

### **Compliance Monitoring Requirements [326 IAC 2-7-5(1)][326 IAC 2-7-6(1)]**

#### **C.10 Compliance Monitoring [326 IAC 2-7-5(3)][326 IAC 2-7-6(1)]**

---

Unless otherwise specified in this permit, for all monitoring requirements not already legally required, the Permittee shall be allowed up to ninety (90) days from the date of permit issuance or of initial start-up, whichever is later, to begin such monitoring. If due to circumstances beyond the Permittee's control, any monitoring equipment required by this permit cannot be installed and operated no later than ninety (90) days after permit issuance or the date of initial startup, whichever is later, the Permittee may extend the compliance schedule related to the equipment for an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

in writing, prior to the end of the initial ninety (90) day compliance schedule, with full justification of the reasons for the inability to meet this date.

The notification which shall be submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

Unless otherwise specified in the approval for the new emission unit(s), compliance monitoring for new emission units or emission units added through a source modification shall be implemented when operation begins.

**C.11 Monitoring Methods [326 IAC 3] [40 CFR 60] [40 CFR 63]**

---

Any monitoring or testing required by Section D of this permit shall be performed according to the provisions of 326 IAC 3, 40 CFR 60, Appendix A, 40 CFR 60 Appendix B, 40 CFR 63, or other approved methods as specified in this permit.

**Corrective Actions and Response Steps [326 IAC 2-7-5][326 IAC 2-7-6]**

**C.12 Emergency Reduction Plans [326 IAC 1-5-2] [326 IAC 1-5-3]**

---

Pursuant to 326 IAC 1-5-2 (Emergency Reduction Plans; Submission):

- (a) The Permittee shall maintain the most recently submitted written emergency reduction plans (ERPs) consistent with safe operating procedures.
- (b) Upon direct notification by IDEM, OAQ that a specific air pollution episode level is in effect, the Permittee shall immediately put into effect the actions stipulated in the approved ERP for the appropriate episode level. [326 IAC 1-5-3]

**C.13 Risk Management Plan [326 IAC 2-7-5(12)] [40 CFR 68]**

---

If a regulated substance, as defined in 40 CFR 68, is present at a source in more than a threshold quantity, the Permittee must comply with the applicable requirements of 40 CFR 68.

**C.14 Response to Excursions or Exceedances [326 IAC 2-7-5] [326 IAC 2-7-6]**

---

Upon detecting an excursion where a response step is required by the D Section or an exceedance of a limitation in this permit:

- (a) The Permittee shall take reasonable response steps to restore operation of the emissions unit (including any control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing excess emissions.
- (b) The response shall include minimizing the period of any startup, shutdown or malfunction. The response may include, but is not limited to, the following:
  - (1) initial inspection and evaluation;
  - (2) recording that operations returned or are returning to normal without operator action (such as through response by a computerized distribution control system);  
or
  - (3) any necessary follow-up actions to return operation to normal or usual manner of operation.
- (c) A determination of whether the Permittee has used acceptable procedures in response to an excursion or exceedance will be based on information available, which may include, but is not limited to, the following:
  - (1) monitoring results;

- (2) review of operation and maintenance procedures and records; and/or
- (3) inspection of the control device, associated capture system, and the process.
- (d) Failure to take reasonable response steps shall be considered a deviation from the permit.
- (e) The Permittee shall record the reasonable response steps taken.

**C.15 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5][326 IAC 2-7-6]**

- (a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this permit exceed the level specified in any condition of this permit, the Permittee shall submit a description of its response actions to IDEM, OAQ, no later than seventy-five (75) days after the date of the test.
- (b) A retest to demonstrate compliance shall be performed no later than one hundred eighty (180) days after the date of the test. Should the Permittee demonstrate to IDEM, OAQ that retesting in one hundred eighty (180) days is not practicable, IDEM, OAQ may extend the retesting deadline
- (c) IDEM, OAQ reserves the authority to take any actions allowed under law in response to noncompliant stack tests.

The response action documents submitted pursuant to this condition do require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

**Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

**C.16 Emission Statement [326 IAC 2-7-5(3)(C)(iii)][326 IAC 2-7-5(7)][326 IAC 2-7-19(c)][326 IAC 2-6]**

Pursuant to 326 IAC 2-6-3(b)(2), starting in 2005 and every three (3) years thereafter, the Permittee shall submit by July 1 an emission statement covering the previous calendar year. The emission statement shall contain, at a minimum, the information specified in 326 IAC 2-6-4(c) and shall meet the following requirements:

- (1) Indicate estimated actual emissions of all pollutants listed in 326 IAC 2-6-4(a);
- (2) Indicate estimated actual emissions of regulated pollutants as defined by 326 IAC 2-7-1(32) ("Regulated pollutant, which is used only for purposes of Section 19 of this rule") from the source, for purpose of fee assessment.

The statement must be submitted to:

Indiana Department of Environmental Management  
Technical Support and Modeling Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-50 IGCN 1003  
Indianapolis, Indiana 46204-2251

The emission statement does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

**C.17 General Record Keeping Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-6]**

---

- (a) Records of all required monitoring data, reports and support information required by this permit shall be retained for a period of at least five (5) years from the date of monitoring sample, measurement, report, or application. Support information includes the following:
- (AA) All calibration and maintenance records.
  - (BB) All original strip chart recordings for continuous monitoring instrumentation.
  - (CC) Copies of all reports required by the Part 70 permit.
- Records of required monitoring information include the following:
- (AA) The date, place, as defined in this permit, and time of sampling or measurements.
  - (BB) The dates analyses were performed.
  - (CC) The company or entity that performed the analyses.
  - (DD) The analytical techniques or methods used.
  - (EE) The results of such analyses.
  - (FF) The operating conditions as existing at the time of sampling or measurement.

These records shall be physically present or electronically accessible at the source location for a minimum of three (3) years. The records may be stored elsewhere for the remaining two (2) years as long as they are available upon request. If the Commissioner makes a request for records to the Permittee, the Permittee shall furnish the records to the Commissioner within a reasonable time.

- (b) Unless otherwise specified in this permit, for all record keeping requirements not already legally required, the Permittee shall be allowed up to ninety (90) days from the date of permit issuance or the date of initial start-up, whichever is later, to begin such record keeping.

**C.18 General Reporting Requirements [326 IAC 2-7-5(3)(C)] [326 IAC 2-1.1-11]**

---

- (a) The Permittee shall submit the attached Quarterly Deviation and Compliance Monitoring Report or its equivalent. Proper notice submittal under Section B –Emergency Provisions satisfies the reporting requirements of this paragraph. Any deviation from permit requirements, the date(s) of each deviation, the cause of the deviation, and the response steps taken must be reported except that a deviation required to be reported pursuant to an applicable requirement that exists independent of this permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. This report shall be submitted not later than thirty (30) days after the end of the reporting period. The Quarterly Deviation and Compliance Monitoring Report shall include a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34). A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit.

- (b) The address for report submittal is:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

- (c) Unless otherwise specified in this permit, any notice, report, or other submission required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or

before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.

- (d) Reporting periods are based on calendar years, unless otherwise specified in this permit. For the purpose of this permit “calendar year” means the twelve (12) month period from January 1 to December 31 inclusive.

### **Stratospheric Ozone Protection**

#### **C.19 Compliance with 40 CFR 82 and 326 IAC 22-1**

---

Pursuant to 40 CFR 82 (Protection of Stratospheric Ozone), Subpart F, except as provided for motor vehicle air conditioners in Subpart B, the Permittee shall comply with applicable standards for recycling and emissions reduction.

## SECTION D.1 FACILITY OPERATION CONDITIONS

### Emissions Unit Description:

- (a) Two (2) 38.7 MW natural gas-fired simple cycle gas turbines, identified as T1 and T2, constructed in 1990, using No. 2 fuel oil as the back-up fuel, controlled by a water injection system, each with a maximum heat input capacity of 431 MMBtu/hr while combusting natural gas and a maximum heat input capacity of 425 MMBtu/hr while combusting No. 2 fuel oil (at ISO conditions), and exhausting to stacks 3 and 4, respectively. Under 40 CFR Part 60, Subpart GG, turbines T1 and T2 are considered stationary gas turbines.
- (b) One (1) 84 MW natural gas-fired simple cycle gas turbine, identified as T3, constructed in 2002, using No. 2 fuel oil as the back-up fuel, with a maximum heat input capacity of 858 MMBtu/hr while combusting natural gas and a maximum heat input capacity of 850 MMBtu/hr while combusting No. 2 fuel oil (at ISO conditions), and exhausting to stack 7. This unit is a lean premix combustion turbine. Under 40 CFR Part 60, Subpart GG, turbine T3 is considered a stationary gas turbine.

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

#### D.1.1 Prevention of Significant Deterioration (PSD) Minor Limit [326 IAC 2-2]

In order to render the requirements of 326 IAC 2-2 (PSD) not applicable and as requested by the Permittee, the Permittee shall comply with the following:

- (a) Emissions from turbines T1 and T2 shall be controlled by Water Injection systems and Emissions from turbines T3 shall be controlled by Lean-Premix systems when operating on natural gas and by Water Injection system when operating on No.2 fuel oil.

The total equivalent natural gas used in turbines T1, T2 and T3 shall be limited to 7900 million standard cubic feet (MMSCF) per twelve (12) consecutive month period with compliance determined at the end of each month.

- (1) For every one (1) MMSCF consumed by turbine T3, the natural gas equivalent limit shall be reduced by one (1) MMSCF.
  - (2) For every one (1) MMSCF consumed by turbine T1 or T2 during normal operation, the natural gas equivalent limit shall be reduced by 2.47 MMSCF.
  - (3) For every one (1) thousand gallons of fuel oil (kgal) consumed by turbine T3, the natural gas equivalent limit shall be reduced by 0.392 MMSCF.
  - (4) For every one (1) thousand gallons of fuel oil (kgal) consumed by turbine T1 or T2 during normal operation, the natural gas equivalent limit shall be reduced by 0.537 MMSCF.
- (b) During normal operation, the NO<sub>x</sub> and CO emissions from each of the turbines T1, T2, and T3 shall not exceed the emission limits listed in the table below:

Emission Limits for T1 and T2 (Normal Operation)		
Type of Fuel	NOx Emission Limit	CO Emission Limit
Natural Gas	153 lbs/MMCF	153 lbs/MMCF
No. 2 Fuel Oil	33.4 lbs/kgal	33.4 lbs/kgal
Emission Limits for T3 (Normal Operation)		
Natural Gas	62.2 lbs/MMCF	62.22 lbs/MMCF
No. 2 Fuel Oil	24.4 lbs/kgal	24.4 lbs/kgal

- (c) When operating in "full-speed, no load" mode, the NOx and CO emissions from each of the turbines (T1, T2, and T3) shall not exceed the emission limits listed in the table below:

Emission Limits for T1 ,T2, and T3 -NO LOAD		
Natural Gas	490 lbs/MMCF	490 lbs/MMCF
No. 2 Fuel Oil	183 lbs/kgal	183 lbs/kgal

- (d) When operating in "full-speed, no load" mode for T1,T2 and T3, the use of one (1) MMSCF of natural gas is equivalent to the use of 7.9 MMSCF of equivalent natural gas and the use of 1,000 gallon of No. 2 fuel oil is equivalent to the use of 2.94 MMSCF of equivalent natural gas.
- (e) The Permittee shall perform NOx and CO stack tests for a turbine if its operating hours in "full-speed, no load" mode exceed twenty (20) hours per twelve (12) consecutive month period with compliance determined at the end of each month.
- (f) The sulfur content of the No. 2 fuel oil combusted in turbine T1, T2, or T3 shall not exceed 0.17% by weight.

Compliance with the above limits, Condition D.2.1 and combined with the NOx and CO emissions from other emission units, the potential to emit of NOx and CO from the entire source are each limited to less than 250 tons per year, and renders the requirements of 326 IAC 2-2 (PSD) are not applicable to this source.

**D.1.2 SO<sub>2</sub> Limitations [326 IAC 7-2]**

- (a) The potential to emit SO<sub>2</sub> emissions from each of the turbines, T1, T2, T3 is greater than 25 tons/year or 10 pounds/hour when operating on No. 2 fuel oil. Therefore, the requirements of 326 IAC 7-1.1 are applicable. pursuant to 326 IAC 7-1.1-2, the SO<sub>2</sub> emissions from each of these turbines shall not exceed five-tenth (0.5) pounds per millionBritish thermal units when operating on No. 2 fuel oil

There are no specific SO<sub>2</sub> emission limitations in 326 IAC 7-1.1-2 for units combusting natural gas only.

**D.1.3 Streamlined Requirements [326 IAC 2-7-24]**

The Permittee shall comply with the following for the turbines T1 and T2:

- (a) NOx emissions from each of turbines shall be limited to the following:
- (1) Less than 42 ppmv at 15% oxygen while combusting natural gas.
  - (2) Less than 65 ppmv at 15% oxygen while combusting No. 2 fuel oil.
- (b) The sulfur content of any fuel used shall be limited to less than 0.17% sulfur by weight.

- (c) Visible emissions shall not exceed 20% opacity.

Compliance with the requirements above ensures compliance with the SO<sub>2</sub> emission limits in 326 IAC 7-1.1-2 and the NO<sub>x</sub> emission limits in 40 CFR 60, Subpart GG for turbines T1 and T2.

### Compliance Determination Requirements

#### D.1.4 Nitrogen Oxide Control

---

In order to ensure compliance with Conditions D.1.3(a), the water injection system for NO<sub>x</sub> control shall be in operation and control emissions from turbine T1 and T2 when these units are in operation.

#### D.1.5 Testing Requirements [326 IAC 2-7-6(1),(6)] [326 IAC 2-1.1-11]

---

- (a) In order to demonstrate the compliance status with Condition D.1.1( b ), the Permittee shall perform CO and NO<sub>x</sub> testing for turbine T1, T2 and T3 (for both natural gas and No. 2 fuel oil combustion scenarios during normal operation) utilizing methods approved by the Commissioner at least once every five (5) years from the date of the most recent valid compliance demonstration. Testing shall be conducted in accordance with the provisions of 326 IAC 3-6 (Source Sampling Procedures). Section C – Performance Testing contains the Permittee's obligation with regard to the performance testing required by this condition.
- (b) In order to demonstrate the compliance status with Condition D.1.1(e), the Permittee shall perform NO<sub>x</sub> and CO testing for a turbine within ninety (90) days after the last day of the month when the "full-speed, no load" mode operating hours for each turbine exceed 20 hours per twelve (12) consecutive month period, utilizing methods as approved by the Commissioner. Testing shall be conducted in accordance with the provisions of 326 IAC 3-6 (Source Sampling Procedures). Section C – Performance Testing contains the Permittee's obligation with regard to the performance testing required by this condition.

### Compliance Monitoring Requirements [326 IAC 2-7-5(1)][326 IAC 2-7-6(1)]

#### D.1.6 Visible Emissions Notations

---

- (a) Visible emission notations of the turbine stack exhausts (Stacks 3, 4 and 7) shall be performed once per day during normal daylight operations when combusting No. 2 fuel oil. A trained employee shall record whether emissions are normal or abnormal.
- (b) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.
- (c) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- (d) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.
- (e) If abnormal emissions are observed, the Permittee shall take reasonable response steps in accordance with Section C - Response to Excursions or Exceedances. Failure to take response steps in accordance with Section C - Response to Excursions or Exceedances shall be considered a deviation from this permit.

## **Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

### **D.1.7 Record Keeping Requirements**

---

- (a) In order to document the compliance status with Condition D. 1.1(a), the Permittee shall maintain records of the following:
  - (1) The total equivalent natural gas usage for each month in turbines T1, T2 and T3.
  - (2) The total equivalent natural gas usage for each compliance period in turbines T1, T2 and T3.
- (b) In order to document the compliance status with Conditions D.1.1 (e), the Permittee shall maintain the records of operating hours for the "full-speed, no load" mode for each turbine T1, T2, and T3.
- (c) To document compliance with Conditions D.1.1 (f), D.1.2, and D.1.3 (b), the Permittee shall maintain the records of sulfur content of the No. 2 fuel oil combusted in the turbines.
- (d) In order to document the compliance status with Condition D.1.6, the Permittee shall maintain records of daily visible emission notations of the turbine stack exhausts when combusting No. 2 fuel oil. The Permittee shall include in its daily record when a visible emission notation is not taken and the reason for the lack of visible emission notation (e.g. the process did not operate that day).
- (d) Section C – General Record Keeping Requirements contains the Permittee’s obligation with regard to the records required by this condition.

### **D.1.8 Reporting Requirements**

---

A quarterly summary of the information to document the compliance status with Conditions D. 1.1(a) and D.1.1(e) shall be submitted to the address listed in Section C – General Reporting Requirements, of this permit, not later than thirty (30) days after the end of the quarter being reported. Section C – General Reporting contains the Permittee’s obligation with regard to the reporting required by this condition. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a “responsible official,” as defined by 326 IAC 2-7-1(34).

## SECTION D.2 FACILITY OPERATION CONDITIONS - Engines

### Emissions Unit Description:

- (a) Two (2) diesel-fired start-up engines, identified as D7 and D8, constructed in 1990, each with a maximum power output of 630 horsepower and a maximum heat input of 2 MMBtu/hr, and exhausting to stacks 5 and 6, respectively. [40 CFR 63, Subpart ZZZZ]

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

#### D.2.1 Prevention of Significant Deterioration (PSD) Minor Limit [326 IAC 2-2]

In order to render the requirements of 326 IAC 2-2 (PSD) not applicable, the Permittee shall comply with the following:

- (a) The total amount of No. 2 fuel oil used in the diesel engines, D7 and D8, shall not exceed 2200 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (b) The NO<sub>x</sub> and CO emissions from each of the diesel fired engines (D7 and D8) shall not exceed the following:

Type of Fuel	NO <sub>x</sub> Emission Limit (lbs/gal)	CO Emission Limit (lbs/gal)
Diesel	0.448	0.119

Compliance with the above limits, Condition D.1.1 and combined with the NO<sub>x</sub> and CO emissions from other emission units, the potential to emit of NO<sub>x</sub> and CO from the entire source are each limited to less than 250 tons per year, and renders the requirements of 326 IAC 2-2 (PSD) are not applicable to this source.

### Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

#### D.2.2 Record Keeping Requirements

- (a) In order to document the compliance status with Condition D.2.1(a), the Permittee shall maintain monthly records of total diesel usage for diesel engines, identified as D7 and D8.
- (b) Section C – General Record Keeping Requirements contains the Permittee's obligation with regard to the records required by this condition.

#### D.2.3 Reporting Requirements

A quarterly summary of the information to document the compliance status with Condition D.2.1(a) shall be submitted to the address listed in Section C – General Reporting Requirements, of this permit, not later than thirty (30) days after the end of the quarter being reported. Section C – General Reporting contains the Permittee's obligation with regard to the reporting required by this condition. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official," as defined by 326 IAC 2-7-1(34).

## SECTION E.1 FACILITY OPERATION CONDITIONS

### Emissions Unit Description:

- (a) Two (2) 38.7 MW natural gas-fired simple cycle gas turbines, identified as T1 and T2, constructed in 1990, using No. 2 fuel oil as the back-up fuel, controlled by a water injection system, each with a maximum heat input capacity of 431 MMBtu/hr while combusting natural gas and a maximum heat input capacity of 425 MMBtu/hr while combusting No. 2 fuel oil (at ISO conditions), and exhausting to stacks 3 and 4, respectively. Under 40 CFR Part 60, Subpart GG, turbines T1 and T2 are considered stationary gas turbines.
- (b) One (1) 84 MW natural gas-fired simple cycle gas turbine, identified as T3, constructed in 2002, using No. 2 fuel oil as the back-up fuel, with a maximum heat input capacity of 858 MMBtu/hr while combusting natural gas and a maximum heat input capacity of 850 MMBtu/hr while combusting No. 2 fuel oil (at ISO conditions), and exhausting to stack 7. This unit is a lean premix combustion turbine. Under 40 CFR Part 60, Subpart GG, turbine T3 is considered a stationary gas turbine.

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

#### E.1.1 General Provisions Relating to New Source Performance Standards (NSPS) [326 IAC 12-1] [40 CFR 60, Subpart A] [326 IAC 12]

The provisions of 40 CFR 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the natural gas-fired simple cycle gas turbines, identified as T1, T2, and T3, except when otherwise specified in 40 CFR 60, Subpart GG.

#### E.1.2 Standards of Performance for Stationary Gas Turbines (NSPS) [40 CFR 60, Subpart GG][326 IAC 12]

Pursuant to 40 CFR 60 Subpart GG, the Permittee shall comply with the provisions of 40 CFR 60 Subpart GG, included as Attachment B which are incorporated as 326 IAC 12-1 for the natural gas-fired simple cycle gas turbines, identified as T1, T2, and T3 as specified as follows:

- 1) 40 CFR 60.330;
- 2) 40 CFR 60.331;
- 3) 40 CFR 60.332(a)(1), (b);
- 4) 40 CFR 60.333;
- 5) 40 CFR 60.334(a), (g), (h)(1), (h)(3), (i)(1), (j)(1)(i), (j)(2), (j)(5);
- 6) 40 CFR 60.334(a), (g), (h)(1), (h)(3), (i)(1), (j)(1)(i)(A to C), (j)(2), (j)(5); and
- 7) 40 CFR 60.335(a), (b)(1 to 4), (b)(8), (b)(10 to 11).

#### E.1.3 Custom Monitoring Schedule (NSPS) [326 IAC 12] [40 CFR 60, Subpart GG]

Pursuant to the custom monitoring schedule approved by U.S. EPA on April 5, 2001, the Permittee variances to 40 CFR 60, Subpart GG apply:

- (a) Natural gas sulfur content monitoring shall be conducted on a semi annual basis;

- (b) The installation of NO<sub>x</sub> and O<sub>2</sub> monitors on T1, T2, and T3 are not required; and
- (c) Sampling of the No.2 fuel oil for nitrogen and sulfur content shall be conducted on a semi annual basis or after each addition of fuel oil is complete.

## SECTION E.2 FACILITY OPERATION CONDITIONS

### Emissions Unit Description:

- (a) Two (2) diesel-fired black start stationary RICE, identified as D7 and D8, constructed in 1990, each with a maximum power output of 630 horsepower and a maximum heat input of 2 MMBtu/hr, and exhausting to stacks 5 and 6, respectively. [40 CFR 63, Subpart ZZZZ]

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

#### E.2.1 General Provisions Relating to NESHAP ZZZZ [326 IAC 20-1] [40 CFR 63, Subpart A]

The provisions of 40 CFR 63, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 20-1, apply to the diesel-fired startup engines, identified as D7 and D8, except when otherwise specified in 40 CFR 63, Subpart ZZZZ.

#### E.2.2 National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines [40 CFR 63, Subpart ZZZZ] [326 IAC 20-82]

Pursuant to 40 CFR 63, Subpart ZZZZ, the Permittee shall comply with the provisions of National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines, which are incorporated as 326 IAC 20-82, for the diesel-fired startup engines, identified as as D7 and D8 as follows:

- 1) 40 CFR 63.6585
- 2) 40 CFR 63.6590(a)(1)(iii)
- 3) 40 CFR 63.6595(a) and (c)
- 4) 40 CFR 63.6603
- 5) 40 CFR 63.6605
- 6) 40 CFR 63.6612
- 7) 40 CFR 63.6625(e)(3), (h) and (i)
- 8) 40 CFR 63.6645(a)(5)
- 9) 40 CFR 63.6655(e)(2)
- 10) 40 CFR 63.6660
- 11) 40 CFR 63.6665
- 12) 40 CFR 63.6670
- 13) 40 CFR 63.6675

## SECTION F.1 FACILITY OPERATION CONDITIONS

### Emissions Unit Description:

- (a) Two (2) 38.7 MW natural gas-fired simple cycle gas turbines, identified as T1 and T2, constructed in 1990, using No. 2 fuel oil as the back-up fuel, controlled by a water injection system, each with a maximum heat input capacity of 431 MMBtu/hr while combusting natural gas and a maximum heat input capacity of 425 MMBtu/hr while combusting No. 2 fuel oil (at ISO conditions), and exhausting to stacks 3 and 4, respectively. Under 40 CFR Part 60, Subpart GG, turbines T1 and T2 are considered stationary gas turbines.
- (b) One (1) 84 MW natural gas-fired simple cycle gas turbine, identified as T3, constructed in 2002, using No. 2 fuel oil as the back-up fuel, with a maximum heat input capacity of 858 MMBtu/hr while combusting natural gas and a maximum heat input capacity of 850 MMBtu/hr while combusting No. 2 fuel oil (at ISO conditions), and exhausting to stack 7. This unit is a lean premix combustion turbine. Under 40 CFR Part 60, Subpart GG, turbine T3 is considered a stationary gas turbine.

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

### Acid Rain Program

#### F.1.1 Acid Rain Permit [326 IAC 2-7-5(1)(C)] [326 IAC 21] [40 CFR 72 through 40 CFR 78]

Pursuant to 326 IAC 21 (Acid Deposition Control), the Permittee shall comply with all provisions of the Acid Rain permit issued for this source, and any other applicable requirements contained in 40 CFR 72 through 40 CFR 78. The Acid Rain permit for this source is attached to this permit as Appendix A, and is incorporated by reference.

#### F.1.2 Title IV Emissions Allowances [326 IAC 2-7-5(4)] [326 IAC 21]

Emissions exceeding any allowances that the Permittee lawfully holds under the Title IV Acid Rain Program of the Clean Air Act are prohibited, subject to the following limitations:

- (a) No revision of this permit shall be required for increases in emissions that are authorized by allowances acquired under the Title IV Acid Rain Program, provided that such increases do not require a permit revision under any other applicable requirement.
- (b) No limit shall be placed on the number of allowances held by the Permittee. The Permittee may not use allowances as a defense to noncompliance with any other applicable requirement.
- (c) Any such allowance shall be accounted for according to the procedures established in regulations promulgated under Title IV of the Clean Air Act.

**SECTION G Clean Air Interstate Rule (CAIR) Nitrogen Oxides Annual, Sulfur Dioxide, and Nitrogen Oxides Ozone Season Trading Programs – CAIR Permit for CAIR Units Under 326 IAC 24-1-1(a), 326 IAC 24-2-1(a), and 326 IAC 24-3-1(a)**

**ORIS Code: 7336**

**Emissions Unit Description:**

- (a) Two (2) 38.7 MW natural gas-fired simple cycle gas turbines, identified as T1 and T2, constructed in 1990, using No. 2 fuel oil as the back-up fuel, controlled by a water injection system, each with a maximum heat input capacity of 431 MMBtu/hr while combusting natural gas and a maximum heat input capacity of 425 MMBtu/hr while combusting No. 2 fuel oil (at ISO conditions), and exhausting to stacks 3 and 4, respectively. Under 40 CFR Part 60, Subpart GG, turbines T1 and T2 are considered stationary gas turbines.
- (b) One (1) 84 MW natural gas-fired simple cycle gas turbine, identified as T3, constructed in 2002, using No. 2 fuel oil as the back-up fuel, with a maximum heat input capacity of 858 MMBtu/hr while combusting natural gas and a maximum heat input capacity of 850 MMBtu/hr while combusting No. 2 fuel oil (at ISO conditions), and exhausting to stack 7. This unit is a lean premix combustion turbine. Under 40 CFR Part 60, Subpart GG, turbine T3 is considered a stationary gas turbine.

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

**G.1 Automatic Incorporation of Definitions [326 IAC 24-1-7(e)] [326 IAC 24-2-7(e)] [326 IAC 24-3-7(e)] [40 CFR 97.123(b)] [40 CFR 97.223(b)] [40 CFR 97.323(b)]**

This CAIR permit is deemed to incorporate automatically the definitions of terms under 326 IAC 24-1-2, 326 IAC 24-2-2, and 326 IAC 24-3-2.

**G.2 Standard Permit Requirements [326 IAC 24-1-4(a)] [326 IAC 24-2-4(a)] [326 IAC 24-3-4(a)] [40 CFR 97.106(a)] [40 CFR 97.206(a)] [40 CFR 97.306(a)]**

- (a) The owners and operators of each CAIR NO<sub>x</sub> source, CAIR SO<sub>2</sub> source, and CAIR NO<sub>x</sub> ozone season source and CAIR NO<sub>x</sub> units, CAIR SO<sub>2</sub> units, and CAIR NO<sub>x</sub> ozone season units shall operate each source and unit in compliance with this CAIR permit.
- (b) The CAIR NO<sub>x</sub> units, CAIR SO<sub>2</sub> units, and CAIR NO<sub>x</sub> ozone season units subject to this CAIR permit are T1(ACT1), T2(ACT2), T3(ACT3).

**G.3 Monitoring, Reporting, and Record Keeping Requirements [326 IAC 24-1-4(b)] [326 IAC 24-2-4(b)] [326 IAC 24-3-4(b)] [40 CFR 97.106(b)] [40 CFR 97.206(b)] [40 CFR 97.306(b)]**

- (a) The owners and operators, and the CAIR designated representative, of each CAIR NO<sub>x</sub> source, CAIR SO<sub>2</sub> source, and CAIR NO<sub>x</sub> ozone season source and CAIR NO<sub>x</sub> unit, CAIR SO<sub>2</sub> unit, and CAIR NO<sub>x</sub> ozone season unit at the source shall comply with the applicable monitoring, reporting, and record keeping requirements of 326 IAC 24-1-11, 326 IAC 24-2-10, and 326 IAC 24-3-11.
- (b) The emissions measurements recorded and reported in accordance with 326 IAC 24-1-11, 326 IAC 24-2-10, and 326 IAC 24-3-11 shall be used to determine compliance by each CAIR NO<sub>x</sub> source, CAIR SO<sub>2</sub> source, and CAIR NO<sub>x</sub> ozone season

source with the CAIR NO<sub>x</sub> emissions limitation under 326 IAC 24-1-4(c), CAIR SO<sub>2</sub> emissions limitation under 326 IAC 24-2-4(c), and CAIR NO<sub>x</sub> ozone season emissions limitation under 326 IAC 24-3-4(c) and Condition G.4.1, Nitrogen Oxides Emission Requirements, Condition G.4.2, Sulfur Dioxide Emission Requirements, and Condition G.4.3, Nitrogen Oxides Ozone Season Emission Requirements.

G.4.1 Nitrogen Oxides Emission Requirements [326 IAC 24-1-4(c)] [40 CFR 97.106(c)]

- (a) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall hold, in the source's compliance account, CAIR NO<sub>x</sub> allowances available for compliance deductions for the control period under 326 IAC 24-1-9(i) in an amount not less than the tons of total nitrogen oxides emissions for the control period from all CAIR NO<sub>x</sub> units at the source, as determined in accordance with 326 IAC 24-1-11.
- (b) A CAIR NO<sub>x</sub> unit shall be subject to the requirements under 326 IAC 24-1-4(c)(1) for the control period starting on the applicable date, as determined under 326 IAC 24-1-4(c)(2), and for each control period thereafter.
- (c) A CAIR NO<sub>x</sub> allowance shall not be deducted for compliance with the requirements under 326 IAC 24-1-4(c)(1), for a control period in a calendar year before the year for which the CAIR NO<sub>x</sub> allowance was allocated.
- (d) CAIR NO<sub>x</sub> allowances shall be held in, deducted from, or transferred into or among CAIR NO<sub>x</sub> allowance tracking system accounts in accordance with 326 IAC 24-1-9, 326 IAC 24-1-10, and 326 IAC 24-1-12.
- (e) A CAIR NO<sub>x</sub> allowance is a limited authorization to emit one (1) ton of nitrogen oxides in accordance with the CAIR NO<sub>x</sub> annual trading program. No provision of the CAIR NO<sub>x</sub> annual trading program, the CAIR permit application, the CAIR permit, or an exemption under 326 IAC 24-1-3 and no provision of law shall be construed to limit the authority of the State of Indiana or the United States to terminate or limit the authorization.
- (f) A CAIR NO<sub>x</sub> allowance does not constitute a property right.
- (g) Upon recordation by the U.S. EPA under 326 IAC 24-1-8, 326 IAC 24-1-9, 326 IAC 24-1-10, or 326 IAC 24-1-12, every allocation, transfer, or deduction of a CAIR NO<sub>x</sub> allowance to or from a CAIR NO<sub>x</sub> source's compliance account is incorporated automatically in this CAIR permit.

G.4.2 Sulfur Dioxide Emission Requirements [326 IAC 24-2-4(c)] [40 CFR 97.206(c)]

- (a) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall hold, in the source's compliance account, a tonnage equivalent of CAIR SO<sub>2</sub> allowances available for compliance deductions for the control period under 326 IAC 24-2-8(j) and 326 IAC 24-2-8(k) not less than the tons of total sulfur dioxide emissions for the control period from all CAIR SO<sub>2</sub> units at the source, as determined in accordance with 326 IAC 24-2-10.
- (b) A CAIR SO<sub>2</sub> unit shall be subject to the requirements under 326 IAC 24-2-4(c)(1) for the control period starting on the applicable date, as determined under 326 IAC 24-2-4(c)(2), and for each control period thereafter.
- (c) A CAIR SO<sub>2</sub> allowance shall not be deducted for compliance with the requirements under 326 IAC 24-2-4(c)(1), for a control period in a calendar year before the year for which the CAIR SO<sub>2</sub> allowance was allocated.

- (d) CAIR SO<sub>2</sub> allowances shall be held in, deducted from, or transferred into or among CAIR SO<sub>2</sub> allowance tracking system accounts in accordance with 326 IAC 24-2-8, 326 IAC 24-2-9, and 326 IAC 24-2-11.
- (e) A CAIR SO<sub>2</sub> allowance is a limited authorization to emit sulfur dioxide in accordance with the CAIR SO<sub>2</sub> trading program. No provision of the CAIR SO<sub>2</sub> trading program, the CAIR permit application, the CAIR permit, or an exemption under 326 IAC 24-2-3 and no provision of law shall be construed to limit the authority of the State of Indiana or the United States to terminate or limit the authorization.
- (f) A CAIR SO<sub>2</sub> allowance does not constitute a property right.
- (g) Upon recordation by the U.S. EPA under 326 IAC 24-2-8, 326 IAC 24-2-9, or 326 IAC 24-2-11, every allocation, transfer, or deduction of a CAIR SO<sub>2</sub> allowance to or from a CAIR SO<sub>2</sub> source's compliance account is incorporated automatically in this CAIR permit.

G.4.3 Nitrogen Oxides Ozone Season Emission Requirements [326 IAC 24-3-4(c)] [40 CFR 97.306(c)]

- (a) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO<sub>x</sub> ozone season source and each CAIR NO<sub>x</sub> ozone season unit at the source shall hold, in the source's compliance account, CAIR NO<sub>x</sub> ozone season allowances available for compliance deductions for the control period under 326 IAC 24-3-9(i) in an amount not less than the tons of total nitrogen oxides emissions for the control period from all CAIR NO<sub>x</sub> ozone season units at the source, as determined in accordance with 326 IAC 24-3-11.
- (b) A CAIR NO<sub>x</sub> ozone season unit shall be subject to the requirements under 326 IAC 24-3-4(c)(1) for the control period starting on the applicable date, as determined under 326 IAC 24-3-4(c)(2), and for each control period thereafter.
- (c) A CAIR NO<sub>x</sub> ozone season allowance shall not be deducted for compliance with the requirements under 326 IAC 24-3-4(c)(1), for a control period in a calendar year before the year for which the CAIR NO<sub>x</sub> ozone season allowance was allocated.
- (d) CAIR NO<sub>x</sub> ozone season allowances shall be held in, deducted from, or transferred into or among CAIR NO<sub>x</sub> ozone season allowance tracking system accounts in accordance with 326 IAC 24-3-9, 326 IAC 24-3-10, and 326 IAC 24-3-12.
- (e) A CAIR NO<sub>x</sub> ozone season allowance is a limited authorization to emit one (1) ton of nitrogen oxides in accordance with the CAIR NO<sub>x</sub> ozone season trading program. No provision of the CAIR NO<sub>x</sub> ozone season trading program, the CAIR permit application, the CAIR permit, or an exemption under 326 IAC 24-3-3 and no provision of law shall be construed to limit the authority of the State of Indiana or the United States to terminate or limit the authorization.
- (f) A CAIR NO<sub>x</sub> ozone season allowance does not constitute a property right.
- (g) Upon recordation by the U.S. EPA under 326 IAC 24-3-8, 326 IAC 24-3-9, 326 IAC 24-3-10, or 326 IAC 24-3-12, every allocation, transfer, or deduction of a CAIR NO<sub>x</sub> ozone season allowance to or from a CAIR NO<sub>x</sub> ozone season source's compliance account is incorporated automatically in this CAIR permit.

G.5 Excess Emissions Requirements [326 IAC 24-1-4(d)] [326 IAC 24-2-4(d)] [326 IAC 24-3-4(d)]  
[40 CFR 97.106(d)] [40 CFR 97.206(d)] [40 CFR 97.306(d)]

---

(a) The owners and operators of a CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit that emits nitrogen oxides during any control period in excess of the CAIR NO<sub>x</sub> emissions limitation shall do the following:

- (1) Surrender the CAIR NO<sub>x</sub> allowances required for deduction under 326 IAC 24-1-9(j)(4).
- (2) Pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, the Clean Air Act (CAA) or applicable state law.

Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 326 IAC 24-1-4, the Clean Air Act (CAA), and applicable state law.

(b) The owners and operators of a CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit that emits sulfur dioxide during any control period in excess of the CAIR SO<sub>2</sub> emissions limitation shall do the following:

- (1) Surrender the CAIR SO<sub>2</sub> allowances required for deduction under 326 IAC 24-2-8(k)(4).
- (2) Pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, the Clean Air Act (CAA) or applicable state law.

Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 326 IAC 24-2-4, the Clean Air Act (CAA), and applicable state law.

(c) The owners and operators of a CAIR NO<sub>x</sub> ozone season source and each CAIR NO<sub>x</sub> ozone season unit that emits nitrogen oxides during any control period in excess of the CAIR NO<sub>x</sub> ozone season emissions limitation shall do the following:

- (1) Surrender the CAIR NO<sub>x</sub> ozone season allowances required for deduction under 326 IAC 24-3-9(j)(4).
- (2) Pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, the Clean Air Act (CAA) or applicable state law.

Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 326 IAC 24-3-4, the Clean Air Act (CAA), and applicable state law.

G.6 Record Keeping Requirements [326 IAC 24-1-4(e)] [326 IAC 24-2-4(e)] [326 IAC 24-3-4(e)]  
[326 IAC 2-7-5(3)] [40 CFR 97.106(e)] [40 CFR 97.206(e)] [40 CFR 97.306(e)]

---

Unless otherwise provided, the owners and operators of the CAIR NO<sub>x</sub> source, CAIR SO<sub>2</sub> source, and CAIR NO<sub>x</sub> ozone season source and each CAIR NO<sub>x</sub> unit, CAIR SO<sub>2</sub> unit, and CAIR NO<sub>x</sub> ozone season unit at the source shall keep on site at the source or at a central location within Indiana for those owners or operators with unattended sources, each of the following documents for a period of five (5) years from the date the document was created:

(a) The certificate of representation under 326 IAC 24-1-6(h), 326 IAC 24-2-6(h), and 326 IAC 24-3-6(h) for the CAIR designated representative for the source and each CAIR NO<sub>x</sub> unit, CAIR SO<sub>2</sub> unit, and CAIR NO<sub>x</sub> ozone season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation. The certificate and documents shall be retained on site at the source or at a central location within Indiana for those owners or operators with unattended sources

beyond such five (5) year period until such documents are superseded because of the submission of a new account certificate of representation under 326 IAC 24-1-6(h), 326 IAC 24-2-6(h), and 326 IAC 24-3-6(h) changing the CAIR designated representative.

- (b) All emissions monitoring information, in accordance with 326 IAC 24-1-11, 326 IAC 24-2-10, and 326 IAC 24-3-11, provided that to the extent that 326 IAC 24-1-11, 326 IAC 24-2-10, and 326 IAC 24-3-11 provides for a three (3) year period for record keeping, the three (3) year period shall apply.
- (c) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO<sub>x</sub> annual trading program, CAIR SO<sub>2</sub> trading program, and CAIR NO<sub>x</sub> ozone season trading program.
- (d) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR NO<sub>x</sub> annual trading program, CAIR SO<sub>2</sub> trading program, and CAIR NO<sub>x</sub> ozone season trading program or to demonstrate compliance with the requirements of the CAIR NO<sub>x</sub> annual trading program, CAIR SO<sub>2</sub> trading program, and CAIR NO<sub>x</sub> ozone season trading program.

This period may be extended for cause, at any time before the end of five (5) years, in writing by IDEM, OAQ or the U.S. EPA. Unless otherwise provided, all records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

G.7 Reporting Requirements [326 IAC 24-1-4(e)] [326 IAC 24-2-4(e)] [326 IAC 24-3-4(e)]  
[40 CFR 97.106(e)] [40 CFR 97.206(e)] [40 CFR 97.306(e)]

---

- (a) The CAIR designated representative of the CAIR NO<sub>x</sub> source, CAIR SO<sub>2</sub> source, and CAIR NO<sub>x</sub> ozone season source and each CAIR NO<sub>x</sub> unit, CAIR SO<sub>2</sub> unit, and CAIR NO<sub>x</sub> ozone season unit at the source shall submit the reports required under the CAIR NO<sub>x</sub> annual trading program, CAIR SO<sub>2</sub> trading program, and CAIR NO<sub>x</sub> ozone season trading program, including those under 326 IAC 24-1-11, 326 IAC 24-2-10, and 326 IAC 24-3-11.
- (b) Pursuant to 326 IAC 24-1-4(e), 326 IAC 24-2-4(e), and 326 IAC 24-3-4(e) and 326 IAC 24-1-6(e)(1), 326 IAC 24-2-6(e)(1), and 326 IAC 24-3-6(e)(1), each submission under the CAIR NO<sub>x</sub> annual trading program, CAIR SO<sub>2</sub> trading program, and CAIR NO<sub>x</sub> ozone season trading program shall include the following certification statement by the CAIR designated representative: "I am authorized to make this submission on behalf of the owners and operators of the source or units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."
- (c) Where 326 IAC 24-1, 326 IAC 24-2, and 326 IAC 24-3 requires a submission to IDEM, OAQ, the information shall be submitted to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53, IGCN 1003  
Indianapolis, Indiana 46204-2251

- (d) Where 326 IAC 24-1, 326 IAC 24-2, and 326 IAC 24-3 requires a submission to U.S. EPA, the information shall be submitted to:

U.S. Environmental Protection Agency  
Clean Air Markets Division  
1200 Pennsylvania Avenue, NW  
Mail Code 6204N  
Washington, DC 20460

G.8 Liability [326 IAC 24-1-4(f)] [326 IAC 24-2-4(f)] [326 IAC 24-3-4(f)] [40 CFR 97.106(f)]  
[40 CFR 97.206(f)] [40 CFR 97.306(f)]

---

The owners and operators of each CAIR NO<sub>x</sub> source, CAIR SO<sub>2</sub> source, and CAIR NO<sub>x</sub> ozone season source and each CAIR NO<sub>x</sub> unit, CAIR SO<sub>2</sub> unit, and CAIR NO<sub>x</sub> ozone season unit shall be liable as follows:

- (a) Each CAIR NO<sub>x</sub> source, CAIR SO<sub>2</sub> source, and CAIR NO<sub>x</sub> ozone season source and each CAIR NO<sub>x</sub> unit, CAIR SO<sub>2</sub> unit, and CAIR NO<sub>x</sub> ozone season unit shall meet the requirements of the CAIR NO<sub>x</sub> annual trading program, CAIR SO<sub>2</sub> trading program, and CAIR NO<sub>x</sub> ozone season trading program, respectively.
- (b) Any provision of the CAIR NO<sub>x</sub> annual trading program, CAIR SO<sub>2</sub> trading program, and CAIR NO<sub>x</sub> ozone season trading program that applies to a CAIR NO<sub>x</sub> source, CAIR SO<sub>2</sub> source, and CAIR NO<sub>x</sub> ozone season source or the CAIR designated representative of a CAIR NO<sub>x</sub> source, CAIR SO<sub>2</sub> source, and CAIR NO<sub>x</sub> ozone season source shall also apply to the owners and operators of such source and of the CAIR NO<sub>x</sub> units, CAIR SO<sub>2</sub> units, and CAIR NO<sub>x</sub> ozone season units at the source.
- (c) Any provision of the CAIR NO<sub>x</sub> annual trading program, CAIR SO<sub>2</sub> trading program, and CAIR NO<sub>x</sub> ozone season trading program that applies to a CAIR NO<sub>x</sub> unit, CAIR SO<sub>2</sub> unit, and CAIR NO<sub>x</sub> ozone season unit or the CAIR designated representative of a CAIR NO<sub>x</sub> unit, CAIR SO<sub>2</sub> unit, and CAIR NO<sub>x</sub> ozone season unit shall also apply to the owners and operators of such units.

G.9 Effect on Other Authorities [326 IAC 24-1-4(g)] [326 IAC 24-2-4(g)] [326 IAC 24-3-4(g)]  
[40 CFR 97.106(g)] [40 CFR 97.206(g)] [40 CFR 97.306(g)]

---

No provision of the CAIR NO<sub>x</sub> annual trading program, CAIR SO<sub>2</sub> trading program, and CAIR NO<sub>x</sub> ozone season trading program, a CAIR permit application, a CAIR permit, or an exemption under 326 IAC 24-1-3, 326 IAC 24-2-3, and 326 IAC 24-3-3 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO<sub>x</sub> source, CAIR SO<sub>2</sub> source, and CAIR NO<sub>x</sub> ozone season source or CAIR NO<sub>x</sub> unit, CAIR SO<sub>2</sub> unit, and CAIR NO<sub>x</sub> ozone season unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act (CAA).

G.10 CAIR Designated Representative and Alternate CAIR Designated Representative  
[326 IAC 24-1-6] [326 IAC 24-2-6] [326 IAC 24-3-6] [40 CFR 97, Subpart BB] [40 CFR 97,  
Subpart BBB] [40 CFR 97, Subpart BBBB]

---

Pursuant to 326 IAC 24-1-6, 326 IAC 24-2-6, and 326 IAC 24-3-6:

- (a) Except as specified in 326 IAC 24-1-6(f)(3), 326 IAC 24-2-6(f)(3), and 326 IAC 24-3-6(f)(3), each CAIR NO<sub>x</sub> source, CAIR SO<sub>2</sub> source, and CAIR NO<sub>x</sub> ozone season source, including all CAIR NO<sub>x</sub> units, CAIR SO<sub>2</sub> units, and CAIR NO<sub>x</sub> ozone season units at the source, shall have one (1) and only one (1) CAIR designated representative, with regard to all matters under the CAIR NO<sub>x</sub> annual trading program,

CAIR SO<sub>2</sub> trading program, and CAIR NO<sub>x</sub> ozone season trading program concerning the source or any CAIR NO<sub>x</sub> unit, CAIR SO<sub>2</sub> unit, and CAIR NO<sub>x</sub> ozone season unit at the

- (b) The provisions of 326 IAC 24-1-6(f), 326 IAC 24-2-6(f), and 326 IAC 24-3-6(f) shall apply where the owners or operators of a CAIR NO<sub>x</sub> source, CAIR SO<sub>2</sub> source, and CAIR NO<sub>x</sub> ozone season source choose to designate an alternate CAIR designated representative.

Except as specified in 326 IAC 24-1-6(f)(3), 326 IAC 24-2-6(f)(3), and 326 IAC 24-3-6(f)(3), whenever the term "CAIR designated representative" is used, the term shall be construed to include the CAIR designated representative or any alternate CAIR designated representative.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH  
PART 70 OPERATING PERMIT  
CERTIFICATION**

Source Name: Indiana Municipal Power Agency – Anderson Station  
Source Address: 6035 Park Road, Anderson, Indiana 46011  
Part 70 Permit No.: T 095-30940-00051

**This certification shall be included when submitting monitoring, testing reports/results or other documents as required by this permit.**

Please check what document is being certified:

- Annual Compliance Certification Letter
- Test Result (specify)
- Report (specify)
- Notification (specify)
- Affidavit (specify)
- Other (specify)

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Signature:

Printed Name:

Title/Position:

Phone:

Date:

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT**  
**OFFICE OF AIR QUALITY**  
**COMPLIANCE AND ENFORCEMENT BRANCH**  
**100 North Senate Avenue**  
**MC 61-53 IGCN 1003**  
**Indianapolis, Indiana 46204-2251**  
**Phone: (317) 233-0178**  
**Fax: (317) 233-6865**

**PART 70 OPERATING PERMIT**  
**EMERGENCY OCCURRENCE REPORT**

Source Name: Indiana Municipal Power Agency – Anderson Station  
Source Address: 6035 Park Road, Anderson, Indiana 46011  
Part 70 Permit No.: T 095-30940-00051

**This form consists of 2 pages**

**Page 1 of 2**

- This is an emergency as defined in 326 IAC 2-7-1(12), for each emergency lasting one (1) hour or more:
- The Permittee must notify the Office of Air Quality (OAQ), within four (4) business hours (1-800-451-6027 or 317-233-0178, ask for Compliance Section); and
  - The Permittee must submit notice in writing or by facsimile within two (2) working days (Facsimile Number: 317-233-6865), and follow the other requirements of 326 IAC 2-7-16.

If any of the following are not applicable, mark N/A

Facility/Equipment/Operation:
Control Equipment:
Permit Condition or Operation Limitation in Permit:
Description of the Emergency:
Describe the cause of the Emergency:

If any of the following are not applicable, mark N/A

Page 2 of 2

Date/Time Emergency started:
Date/Time Emergency was corrected:
Was the facility being properly operated at the time of the emergency?    Y    N
Type of Pollutants Emitted: TSP, PM-10, SO <sub>2</sub> , VOC, NO <sub>x</sub> , CO, Pb, other:
Estimated amount of pollutant(s) emitted during emergency:
Describe the steps taken to mitigate the problem:
Describe the corrective actions/response steps taken:
Describe the measures taken to minimize emissions:
If applicable, describe the reasons why continued operation of the facilities are necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw materials of substantial economic value:

Form Completed by: \_\_\_\_\_

Title / Position: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
 OFFICE OF AIR QUALITY  
 COMPLIANCE AND ENFORCEMENT BRANCH**

**Part 70 Quarterly Report**

Source Name: Indiana Municipal Power Agency – Anderson Station  
 Source Address: 6035 Park Road, Anderson, Indiana 46011  
 Part 70 Permit No.: T 095-30940-00051  
 Facility: Turbine T1, T2, and T3  
 Parameter: Total Equivalent Natural Gas Usage  
 Limit: Turbines T1, T2 and T3 shall be limited to 7900 million standard cubic feet (MMSCF) per twelve (12) consecutive month period with compliance determined at the end of each month.

**Natural Gas equivalent conversion factors:**

- (1) For every one (1) MMSCF consumed by turbine T3, the natural gas equivalent limit shall be reduced by one (1) MMSCF.
- (2) For every one (1) MMSCF consumed by turbine T1 or T2 during normal operation, the natural gas equivalent limit shall be reduced by 2.47 MMSCF.
- (3) For every one (1) thousand gallons of fuel oil (kgal) consumed by turbine T3, the natural gas equivalent limit shall be reduced by 0.392 MMSCF.
- (4) For every one (1) thousand gallons of fuel oil (kgal) consumed by turbine T1 or T2 during normal operation, the natural gas equivalent limit shall be reduced by 0.537 MMSCF.
- (5) When operating in "full-speed, no load" mode for T1, T2 and T3, the use of one (1) MMSCF of natural gas is equivalent to the use of 7.9 MMSCF of equivalent natural gas and the use of 1,000 gallon of No. 2 fuel oil is equivalent to the use of 2.94 MMSCF of equivalent natural gas.

QUARTER :

YEAR:

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

No deviation occurred in this quarter.

- Deviation/s occurred in this quarter.  
    Deviation has been reported on:

Submitted by: \_\_\_\_\_  
Title / Position: \_\_\_\_\_  
Signature: \_\_\_\_\_  
Date: \_\_\_\_\_  
Phone: \_\_\_\_\_

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
 OFFICE OF AIR QUALITY  
 COMPLIANCE AND ENFORCEMENT BRANCH**

**Part 70 Quarterly Report**

Source Name: Indiana Municipal Power Agency – Anderson Station  
 Source Address: 6035 Park Road, Anderson, Indiana 46011  
 Part 70 Permit No.: T 095-30940-00051  
 Facility: Turbine T1  
 Parameter: The operating hours for "full-speed, no-load" mode  
 Limit: Less than twenty (20) hours per twelve (12) consecutive month period with compliance determined at the end of each month.

QUARTER :

YEAR:

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

No deviation occurred in this quarter.

Deviation/s occurred in this quarter.

Deviation has been reported on:

Submitted by: \_\_\_\_\_

Title / Position: \_\_\_\_\_

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH

**Part 70 Quarterly Report**

Source Name: Indiana Municipal Power Agency – Anderson Station  
Source Address: 6035 Park Road, Anderson, Indiana 46011  
Part 70 Permit No.: T 095-30940-00051  
Facility: Turbine T2  
Parameter: The operating hours for "full-speed, no-load" mode  
Limit: Less than twenty (20) hours per twelve (12) consecutive month period with compliance determined at the end of each month.

QUARTER :

YEAR:

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

No deviation occurred in this quarter.

Deviation/s occurred in this quarter.  
Deviation has been reported on:

Submitted by: \_\_\_\_\_  
Title / Position: \_\_\_\_\_  
Signature: \_\_\_\_\_  
Date: \_\_\_\_\_  
Phone: \_\_\_\_\_

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH

**Part 70 Quarterly Report**

Source Name: Indiana Municipal Power Agency – Anderson Station  
Source Address: 6035 Park Road, Anderson, Indiana 46011  
Part 70 Permit No.: T 095-30940-00051  
Facility: Turbine T3  
Parameter: The operating hours for "full-speed, no-load" mode  
Limit: Less than twenty (20) hours per twelve (12) consecutive month period with compliance determined at the end of each month.

QUARTER :

YEAR:

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

No deviation occurred in this quarter.

Deviation/s occurred in this quarter.  
Deviation has been reported on:

Submitted by: \_\_\_\_\_  
Title / Position: \_\_\_\_\_  
Signature: \_\_\_\_\_  
Date: \_\_\_\_\_  
Phone: \_\_\_\_\_

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH

**Part 70 Quarterly Report**  
**Diesel Usage D7 and D8**

Source Name: Indiana Municipal Power Agency – Anderson Station  
Source Address: 6035 Park Road, Anderson, Indiana 46011  
Part 70 Permit No.: T 095-30940-00051  
Facility: Diesel Engines D7 and D8  
Parameter: Total Diesel Usage  
Limit: Less than 2,200 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.

QUARTER : \_\_\_\_\_ YEAR: \_\_\_\_\_

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

- No deviation occurred in this quarter.
- Deviation/s occurred in this quarter.  
Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_

Title / Position: \_\_\_\_\_

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
 OFFICE OF AIR QUALITY  
 COMPLIANCE AND ENFORCEMENT BRANCH  
 PART 70 OPERATING PERMIT  
 QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT**

Source Name: Indiana Municipal Power Agency – Anderson Station  
 Source Address: 6035 Park Road, Anderson, Indiana 46011  
 Part 70 Permit No.: T 095-30940-00051

**Months:** \_\_\_\_\_ **to** \_\_\_\_\_ **Year:** \_\_\_\_\_

<p>This report shall be submitted quarterly based on a calendar year. Proper notice submittal under Section B –Emergency Provisions satisfies the reporting requirements of paragraph (a) of Section C- General Reporting. Any deviation from the requirements of this permit, the date(s) of each deviation, the probable cause of the deviation, and the response steps taken must be reported. A deviation required to be reported pursuant to an applicable requirement that exists independent of the permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. Additional pages may be attached if necessary. If no deviations occurred, please specify in the box marked "No deviations occurred this reporting period".</p>	
<input type="checkbox"/> NO DEVIATIONS OCCURRED THIS REPORTING PERIOD.	
<input type="checkbox"/> THE FOLLOWING DEVIATIONS OCCURRED THIS REPORTING PERIOD	
<b>Permit Requirement</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	
<b>Permit Requirement</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	

<b>Permit Requirement</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	
<b>Permit Requirement</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	
<b>Permit Requirement</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	

Form Completed by: \_\_\_\_\_

Title / Position: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

**Indiana Department of Environmental Management  
Office of Air Quality**

**Attachment A**

**Subpart ZZZZ — National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines**

**Source Description and Location**

<b>Source Name:</b>	<b>Indiana Municipal Power Agency – Anderson Station</b>
<b>Source Location:</b>	<b>6035 Park Road, Anderson, Indiana 46011</b>
<b>County:</b>	<b>Madison</b>
<b>SIC Code:</b>	<b>4911</b>
<b>Permit Renewal No.:</b>	<b>T 095-30940-00051</b>
<b>Permit Reviewer:</b>	<b>Anh Nguyen</b>

**Complete Text of 40 CFR 63, Subpart ZZZZ**

**Subpart ZZZZ — National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines**

**Source:** 69 FR 33506, June 15, 2004, unless otherwise noted.

**What This Subpart Covers**

**§ 63.6580 What is the purpose of subpart ZZZZ?**

Subpart ZZZZ establishes national emission limitations and operating limitations for hazardous air pollutants (HAP) emitted from stationary reciprocating internal combustion engines (RICE) located at major and area sources of HAP emissions. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emission limitations and operating limitations.  
[73 FR 3603, Jan. 18, 2008]

**§ 63.6585 Am I subject to this subpart?**

You are subject to this subpart if you own or operate a stationary RICE at a major or area source of HAP emissions, except if the stationary RICE is being tested at a stationary RICE test cell/stand.

(a) A stationary RICE is any internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work and which is not mobile. Stationary RICE differ from mobile RICE in that a stationary RICE is not a non-road engine as defined at 40 CFR 1068.30, and is not used to propel a motor vehicle or a vehicle used solely for competition.

(b) A major source of HAP emissions is a plant site that emits or has the potential to emit any single HAP at a rate of 10 tons (9.07 megagrams) or more per year or any combination of HAP at a rate of 25 tons (22.68 megagrams) or more per year, except that for oil and gas production facilities, a major source of HAP emissions is determined for each surface site.

(c) An area source of HAP emissions is a source that is not a major source.

(d) If you are an owner or operator of an area source subject to this subpart, your status as an entity subject to a standard or other requirements under this subpart does not subject you to the obligation to obtain a permit under 40 CFR part 70 or 71, provided you are not required to obtain a permit under 40 CFR 70.3(a) or 40 CFR 71.3(a) for a reason other than your status as an area source under this subpart. Notwithstanding the previous sentence, you must continue to comply with the provisions of this subpart as applicable.

(e) If you are an owner or operator of a stationary RICE used for national security purposes, you may be eligible to request an exemption from the requirements of this subpart as described in 40 CFR part 1068, subpart C.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3603, Jan. 18, 2008]

### **§ 63.6590 What parts of my plant does this subpart cover?**

This subpart applies to each affected source.

(a) Affected source. An affected source is any existing, new, or reconstructed stationary RICE located at a major or area source of HAP emissions, excluding stationary RICE being tested at a stationary RICE test cell/stand.

(1) Existing stationary RICE.

(i) For stationary RICE with a site rating of more than 500 brake horsepower (HP) located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before December 19, 2002.

(ii) For stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.

(iii) For stationary RICE located at an area source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.

(iv) A change in ownership of an existing stationary RICE does not make that stationary RICE a new or reconstructed stationary RICE.

(2) New stationary RICE. (i) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions is new if you commenced construction of the stationary RICE on or after December 19, 2002.

(ii) A stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.

(iii) A stationary RICE located at an area source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.

(3) Reconstructed stationary RICE. (i) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions is reconstructed if you meet the definition of reconstruction in §63.2 and reconstruction is commenced on or after December 19, 2002.

(ii) A stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions is reconstructed if you meet the definition of reconstruction in §63.2 and reconstruction is commenced on or after June 12, 2006.

(iii) A stationary RICE located at an area source of HAP emissions is reconstructed if you meet the definition of reconstruction in §63.2 and reconstruction is commenced on or after June 12, 2006.

(b) Stationary RICE subject to limited requirements. (1) An affected source which meets either of the criteria in paragraphs (b)(1)(i) through (ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of §63.6645(f).

(i) The stationary RICE is a new or reconstructed emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.

(ii) The stationary RICE is a new or reconstructed limited use stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.

(2) A new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis must meet the initial notification requirements of §63.6645(f) and the requirements of §§63.6625(c), 63.6650(g), and 63.6655(c). These stationary RICE do not have to meet the emission limitations and operating limitations of this subpart.

(3) The following stationary RICE do not have to meet the requirements of this subpart and of subpart A of this part, including initial notification requirements:

(i) Existing spark ignition 2 stroke lean burn (2SLB) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;

(ii) Existing spark ignition 4 stroke lean burn (4SLB) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;

- (iii) Existing emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;
  - (iv) Existing limited use stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;
  - (v) Existing stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis;
  - (vi) Existing residential emergency stationary RICE located at an area source of HAP emissions;
  - (vii) Existing commercial emergency stationary RICE located at an area source of HAP emissions; or
  - (viii) Existing institutional emergency stationary RICE located at an area source of HAP emissions.
- (c) Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines. No further requirements apply for such engines under this part.
- (1) A new or reconstructed stationary RICE located at an area source;
  - (2) A new or reconstructed 2SLB stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;
  - (3) A new or reconstructed 4SLB stationary RICE with a site rating of less than 250 brake HP located at a major source of HAP emissions;
  - (4) A new or reconstructed spark ignition 4 stroke rich burn (4SRB) stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;
  - (5) A new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis;
  - (6) A new or reconstructed emergency or limited use stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;
  - (7) A new or reconstructed compression ignition (CI) stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions.
- [69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008; 75 FR 9674, Mar. 3, 2010; 75 FR 37733, June 30, 2010; 75 FR 51588, Aug. 20, 2010]

#### **§ 63.6595 When do I have to comply with this subpart?**

- (a) Affected sources. (1) If you have an existing stationary RICE, excluding existing non-emergency CI stationary RICE, with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the applicable emission limitations and operating limitations no later than June 15, 2007. If you have an existing non-emergency CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, an existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or an existing stationary CI RICE located at an area source of HAP emissions, you must comply with the applicable emission limitations and operating limitations no later than May 3, 2013. If you have an existing stationary SI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or an existing stationary SI RICE located at an area source of HAP emissions, you must comply with the applicable emission limitations and operating limitations no later than October 19, 2013.
- (2) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions before August 16, 2004, you must comply with the applicable emission limitations and operating limitations in this subpart no later than August 16, 2004.
- (3) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions after August 16, 2004, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.
- (4) If you start up your new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions before January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart no later than January 18, 2008.

(5) If you start up your new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions after January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(6) If you start up your new or reconstructed stationary RICE located at an area source of HAP emissions before January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart no later than January 18, 2008.

(7) If you start up your new or reconstructed stationary RICE located at an area source of HAP emissions after January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(b) Area sources that become major sources. If you have an area source that increases its emissions or its potential to emit such that it becomes a major source of HAP, the compliance dates in paragraphs (b)(1) and (2) of this section apply to you.

(1) Any stationary RICE for which construction or reconstruction is commenced after the date when your area source becomes a major source of HAP must be in compliance with this subpart upon startup of your affected source.

(2) Any stationary RICE for which construction or reconstruction is commenced before your area source becomes a major source of HAP must be in compliance with the provisions of this subpart that are applicable to RICE located at major sources within 3 years after your area source becomes a major source of HAP.

(c) If you own or operate an affected source, you must meet the applicable notification requirements in §63.6645 and in 40 CFR part 63, subpart A.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008; 75 FR 9675, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010]

## **Emission and Operating Limitations**

### **§ 63.6600 What emission limitations and operating limitations must I meet if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?**

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in §63.6620 and Table 4 to this subpart.

(a) If you own or operate an existing, new, or reconstructed spark ignition 4SRB stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 1a to this subpart and the operating limitations in Table 1b to this subpart which apply to you.

(b) If you own or operate a new or reconstructed 2SLB stationary RICE with a site rating of more than 500 brake HP located at major source of HAP emissions, a new or reconstructed 4SLB stationary RICE with a site rating of more than 500 brake HP located at major source of HAP emissions, or a new or reconstructed CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 2a to this subpart and the operating limitations in Table 2b to this subpart which apply to you.

(c) If you own or operate any of the following stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the emission limitations in Tables 1a, 2a, 2c, and 2d to this subpart or operating limitations in Tables 1b and 2b to this subpart: an existing 2SLB stationary RICE; an existing 4SLB stationary RICE; a stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis; an emergency stationary RICE; or a limited use stationary RICE.

(d) If you own or operate an existing non-emergency stationary CI RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 2c to this subpart and the operating limitations in Table 2b to this subpart which apply to you.

[73 FR 3605, Jan. 18, 2008, as amended at 75 FR 9675, Mar. 3, 2010]

**§ 63.6601 What emission limitations must I meet if I own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 brake HP and less than or equal to 500 brake HP located at a major source of HAP emissions?**

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in §63.6620 and Table 4 to this subpart. If you own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at major source of HAP emissions manufactured on or after January 1, 2008, you must comply with the emission limitations in Table 2a to this subpart and the operating limitations in Table 2b to this subpart which apply to you. [73 FR 3605, Jan. 18, 2008, as amended at 75 FR 9675, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010]

**§ 63.6602 What emission limitations must I meet if I own or operate an existing stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions?**

If you own or operate an existing stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 2c to this subpart which apply to you. Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in §63.6620 and Table 4 to this subpart. [75 FR 51589, Aug. 20, 2010]

**§ 63.6603 What emission limitations and operating limitations must I meet if I own or operate an existing stationary RICE located at an area source of HAP emissions?**

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in §63.6620 and Table 4 to this subpart.

(a) If you own or operate an existing stationary RICE located at an area source of HAP emissions, you must comply with the requirements in Table 2d to this subpart and the operating limitations in Table 1b and Table 2b to this subpart that apply to you.

(b) If you own or operate an existing stationary non-emergency CI RICE greater than 300 HP located at area sources in areas of Alaska not accessible by the Federal Aid Highway System (FAHS) you do not have to meet the numerical CO emission limitations specified in Table 2d to this subpart. Existing stationary non-emergency CI RICE greater than 300 HP located at area sources in areas of Alaska not accessible by the FAHS must meet the management practices that are shown for stationary non-emergency CI RICE less than or equal to 300 HP in Table 2d to this subpart.

[75 FR 9675, Mar. 3, 2010, as amended at 75 FR 51589, Aug. 20, 2010; 76 FR 12866, Mar. 9, 2011]

**§ 63.6604 What fuel requirements must I meet if I own or operate an existing stationary CI RICE?**

If you own or operate an existing non-emergency, non-black start CI stationary RICE with a site rating of more than 300 brake HP with a displacement of less than 30 liters per cylinder that uses diesel fuel, you must use diesel fuel that meets the requirements in 40 CFR 80.510(b) for nonroad diesel fuel. Existing non-emergency CI stationary RICE located in Guam, American Samoa, the Commonwealth of the Northern Mariana Islands, or at area sources in areas of Alaska not accessible by the FAHS are exempt from the requirements of this section.

[75 FR 51589, Aug. 20, 2010]

**General Compliance Requirements**

**§ 63.6605 What are my general requirements for complying with this subpart?**

(a) You must be in compliance with the emission limitations and operating limitations in this subpart that apply to you at all times.

(b) At all times you must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.

[75 FR 9675, Mar. 3, 2010]

### Testing and Initial Compliance Requirements

#### **§ 63.6610 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?**

If you own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions you are subject to the requirements of this section.

(a) You must conduct the initial performance test or other initial compliance demonstrations in Table 4 to this subpart that apply to you within 180 days after the compliance date that is specified for your stationary RICE in §63.6595 and according to the provisions in §63.7(a)(2).

(b) If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004 and own or operate stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must demonstrate initial compliance with either the proposed emission limitations or the promulgated emission limitations no later than February 10, 2005 or no later than 180 days after startup of the source, whichever is later, according to §63.7(a)(2)(ix).

(c) If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004 and own or operate stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, and you chose to comply with the proposed emission limitations when demonstrating initial compliance, you must conduct a second performance test to demonstrate compliance with the promulgated emission limitations by December 13, 2007 or after startup of the source, whichever is later, according to §63.7(a)(2)(ix).

(d) An owner or operator is not required to conduct an initial performance test on units for which a performance test has been previously conducted, but the test must meet all of the conditions described in paragraphs (d)(1) through (5) of this section.

(1) The test must have been conducted using the same methods specified in this subpart, and these methods must have been followed correctly.

(2) The test must not be older than 2 years.

(3) The test must be reviewed and accepted by the Administrator.

(4) Either no process or equipment changes must have been made since the test was performed, or the owner or operator must be able to demonstrate that the results of the performance test, with or without adjustments, reliably demonstrate compliance despite process or equipment changes.

(5) The test must be conducted at any load condition within plus or minus 10 percent of 100 percent load.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3605, Jan. 18, 2008]

#### **§ 63.6611 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a new or reconstructed 4SLB SI stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions?**

If you own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions, you must conduct an initial performance test within 240 days after the compliance date that is specified for your stationary RICE in §63.6595 and according to the provisions specified in Table 4 to this subpart, as appropriate.

[73 FR 3605, Jan. 18, 2008, as amended at 75 FR 51589, Aug. 20, 2010]

**§ 63.6612 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate an existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing stationary RICE located at an area source of HAP emissions?**

If you own or operate an existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing stationary RICE located at an area source of HAP emissions you are subject to the requirements of this section.

(a) You must conduct any initial performance test or other initial compliance demonstration according to Tables 4 and 5 to this subpart that apply to you within 180 days after the compliance date that is specified for your stationary RICE in §63.6595 and according to the provisions in §63.7(a)(2).

(b) An owner or operator is not required to conduct an initial performance test on a unit for which a performance test has been previously conducted, but the test must meet all of the conditions described in paragraphs (b)(1) through (4) of this section.

(1) The test must have been conducted using the same methods specified in this subpart, and these methods must have been followed correctly.

(2) The test must not be older than 2 years.

(3) The test must be reviewed and accepted by the Administrator.

(4) Either no process or equipment changes must have been made since the test was performed, or the owner or operator must be able to demonstrate that the results of the performance test, with or without adjustments, reliably demonstrate compliance despite process or equipment changes.

[75 FR 9676, Mar. 3, 2010, as amended at 75 FR 51589, Aug. 20, 2010]

**§ 63.6615 When must I conduct subsequent performance tests?**

If you must comply with the emission limitations and operating limitations, you must conduct subsequent performance tests as specified in Table 3 of this subpart.

**§ 63.6620 What performance tests and other procedures must I use?**

(a) You must conduct each performance test in Tables 3 and 4 of this subpart that applies to you.

(b) Each performance test must be conducted according to the requirements that this subpart specifies in Table 4 to this subpart. If you own or operate a non-operational stationary RICE that is subject to performance testing, you do not need to start up the engine solely to conduct the performance test. Owners and operators of a non-operational engine can conduct the performance test when the engine is started up again.

(c) [Reserved]

(d) You must conduct three separate test runs for each performance test required in this section, as specified in §63.7(e)(3). Each test run must last at least 1 hour.

(e)(1) You must use Equation 1 of this section to determine compliance with the percent reduction requirement:

$$\frac{C_i - C_o}{C_i} \times 100 = R \quad (\text{Eq. 1})$$

Where:

$C_i$  = concentration of CO or formaldehyde at the control device inlet,

$C_o$  = concentration of CO or formaldehyde at the control device outlet, and

R = percent reduction of CO or formaldehyde emissions.

(2) You must normalize the carbon monoxide (CO) or formaldehyde concentrations at the inlet and outlet of the control device to a dry basis and to 15 percent oxygen, or an equivalent percent carbon dioxide (CO<sub>2</sub>). If pollutant concentrations are to be corrected to 15 percent oxygen and CO<sub>2</sub> concentration is measured in lieu of oxygen concentration measurement, a CO<sub>2</sub> correction factor is needed. Calculate the CO<sub>2</sub> correction factor as described in paragraphs (e)(2)(i) through (iii) of this section.

(i) Calculate the fuel-specific  $F_o$  value for the fuel burned during the test using values obtained from Method 19, section 5.2, and the following equation:

$$F_o = \frac{0.209 F_d}{F_c} \quad (\text{Eq. 2})$$

Where:

$F_o$  = Fuel factor based on the ratio of oxygen volume to the ultimate  $\text{CO}_2$  volume produced by the fuel at zero percent excess air.

0.209 = Fraction of air that is oxygen, percent/100.

$F_d$  = Ratio of the volume of dry effluent gas to the gross calorific value of the fuel from Method 19,  $\text{dscf}/10^6 \text{ Btu}$ .

$F_c$  = Ratio of the volume of  $\text{CO}_2$  produced to the gross calorific value of the fuel from Method 19,  $\text{dscf}/10^6 \text{ Btu}$ .

(ii) Calculate the  $\text{CO}_2$  correction factor for correcting measurement data to 15 percent oxygen, as follows:

$$X_{\text{CO}_2} = \frac{5.9}{F_o} \quad (\text{Eq. 3})$$

Where:

$X_{\text{CO}_2}$  =  $\text{CO}_2$  correction factor, percent.

5.9 = 20.9 percent  $\text{O}_2$  - 15 percent  $\text{O}_2$ , the defined  $\text{O}_2$  correction value, percent.

(iii) Calculate the  $\text{NO}_x$  and  $\text{SO}_2$  gas concentrations adjusted to 15 percent  $\text{O}_2$  using  $\text{CO}_2$  as follows:

$$C_{\text{adj}} = C_d \frac{X_{\text{CO}_2}}{\% \text{CO}_2} \quad (\text{Eq. 4})$$

Where:

$\% \text{CO}_2$  = Measured  $\text{CO}_2$  concentration measured, dry basis, percent.

(f) If you comply with the emission limitation to reduce CO and you are not using an oxidation catalyst, if you comply with the emission limitation to reduce formaldehyde and you are not using NSCR, or if you comply with the emission limitation to limit the concentration of formaldehyde in the stationary RICE exhaust and you are not using an oxidation catalyst or NSCR, you must petition the Administrator for operating limitations to be established during the initial performance test and continuously monitored thereafter; or for approval of no operating limitations. You must not conduct the initial performance test until after the petition has been approved by the Administrator.

(g) If you petition the Administrator for approval of operating limitations, your petition must include the information described in paragraphs (g)(1) through (5) of this section.

(1) Identification of the specific parameters you propose to use as operating limitations;

(2) A discussion of the relationship between these parameters and HAP emissions, identifying how HAP emissions change with changes in these parameters, and how limitations on these parameters will serve to limit HAP emissions;

(3) A discussion of how you will establish the upper and/or lower values for these parameters which will establish the limits on these parameters in the operating limitations;

(4) A discussion identifying the methods you will use to measure and the instruments you will use to monitor these parameters, as well as the relative accuracy and precision of these methods and instruments; and

(5) A discussion identifying the frequency and methods for recalibrating the instruments you will use for monitoring these parameters.

(h) If you petition the Administrator for approval of no operating limitations, your petition must include the information described in paragraphs (h)(1) through (7) of this section.

(1) Identification of the parameters associated with operation of the stationary RICE and any emission control device which could change intentionally ( e.g., operator adjustment, automatic controller adjustment, etc.) or unintentionally ( e.g., wear and tear, error, etc.) on a routine basis or over time;

(2) A discussion of the relationship, if any, between changes in the parameters and changes in HAP emissions;

(3) For the parameters which could change in such a way as to increase HAP emissions, a discussion of whether establishing limitations on the parameters would serve to limit HAP emissions;

(4) For the parameters which could change in such a way as to increase HAP emissions, a discussion of how you could establish upper and/or lower values for the parameters which would establish limits on the parameters in operating limitations;

- (5) For the parameters, a discussion identifying the methods you could use to measure them and the instruments you could use to monitor them, as well as the relative accuracy and precision of the methods and instruments;
- (6) For the parameters, a discussion identifying the frequency and methods for recalibrating the instruments you could use to monitor them; and
- (7) A discussion of why, from your point of view, it is infeasible or unreasonable to adopt the parameters as operating limitations.
  - (i) The engine percent load during a performance test must be determined by documenting the calculations, assumptions, and measurement devices used to measure or estimate the percent load in a specific application. A written report of the average percent load determination must be included in the notification of compliance status. The following information must be included in the written report: the engine model number, the engine manufacturer, the year of purchase, the manufacturer's site-rated brake horsepower, the ambient temperature, pressure, and humidity during the performance test, and all assumptions that were made to estimate or calculate percent load during the performance test must be clearly explained. If measurement devices such as flow meters, kilowatt meters, beta analyzers, stain gauges, etc. are used, the model number of the measurement device, and an estimate of its accurate in percentage of true value must be provided.  
[69 FR 33506, June 15, 2004, as amended at 75 FR 9676, Mar. 3, 2010]

**§ 63.6625 What are my monitoring, installation, collection, operation, and maintenance requirements?**

- (a) If you elect to install a CEMS as specified in Table 5 of this subpart, you must install, operate, and maintain a CEMS to monitor CO and either oxygen or CO<sub>2</sub> at both the inlet and the outlet of the control device according to the requirements in paragraphs (a)(1) through (4) of this section.
  - (1) Each CEMS must be installed, operated, and maintained according to the applicable performance specifications of 40 CFR part 60, appendix B.
  - (2) You must conduct an initial performance evaluation and an annual relative accuracy test audit (RATA) of each CEMS according to the requirements in §63.8 and according to the applicable performance specifications of 40 CFR part 60, appendix B as well as daily and periodic data quality checks in accordance with 40 CFR part 60, appendix F, procedure 1.
  - (3) As specified in §63.8(c)(4)(ii), each CEMS must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period. You must have at least two data points, with each representing a different 15-minute period, to have a valid hour of data.
  - (4) The CEMS data must be reduced as specified in §63.8(g)(2) and recorded in parts per million or parts per billion (as appropriate for the applicable limitation) at 15 percent oxygen or the equivalent CO<sub>2</sub> concentration.
- (b) If you are required to install a continuous parameter monitoring system (CPMS) as specified in Table 5 of this subpart, you must install, operate, and maintain each CPMS according to the requirements in paragraphs (b)(1) through (5) of this section. For an affected source that is complying with the emission limitations and operating limitations on March 9, 2011, the requirements in paragraph (b) of this section are applicable September 6, 2011.
  - (1) You must prepare a site-specific monitoring plan that addresses the monitoring system design, data collection, and the quality assurance and quality control elements outlined in paragraphs (b)(1)(i) through (v) of this section and in §63.8(d). As specified in §63.8(f)(4), you may request approval of monitoring system quality assurance and quality control procedures alternative to those specified in paragraphs (b)(1) through (5) of this section in your site-specific monitoring plan.
    - (i) The performance criteria and design specifications for the monitoring system equipment, including the sample interface, detector signal analyzer, and data acquisition and calculations;
    - (ii) Sampling interface ( e.g., thermocouple) location such that the monitoring system will provide representative measurements;
    - (iii) Equipment performance evaluations, system accuracy audits, or other audit procedures;
    - (iv) Ongoing operation and maintenance procedures in accordance with provisions in §63.8(c)(1) and (c)(3); and
    - (v) Ongoing reporting and recordkeeping procedures in accordance with provisions in §63.10(c), (e)(1), and (e)(2)(i).

(2) You must install, operate, and maintain each CPMS in continuous operation according to the procedures in your site-specific monitoring plan.

(3) The CPMS must collect data at least once every 15 minutes (see also §63.6635).

(4) For a CPMS for measuring temperature range, the temperature sensor must have a minimum tolerance of 2.8 degrees Celsius (5 degrees Fahrenheit) or 1 percent of the measurement range, whichever is larger.

(5) You must conduct the CPMS equipment performance evaluation, system accuracy audits, or other audit procedures specified in your site-specific monitoring plan at least annually.

(6) You must conduct a performance evaluation of each CPMS in accordance with your site-specific monitoring plan.

(c) If you are operating a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must monitor and record your fuel usage daily with separate fuel meters to measure the volumetric flow rate of each fuel. In addition, you must operate your stationary RICE in a manner which reasonably minimizes HAP emissions.

(d) If you are operating a new or reconstructed emergency 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions, you must install a non-resettable hour meter prior to the startup of the engine.

(e) If you own or operate any of the following stationary RICE, you must operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission-related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions:

(1) An existing stationary RICE with a site rating of less than 100 HP located at a major source of HAP emissions;

(2) An existing emergency or black start stationary RICE with a site rating of less than or equal to 500 HP located at a major source of HAP emissions;

(3) An existing emergency or black start stationary RICE located at an area source of HAP emissions;

(4) An existing non-emergency, non-black start stationary CI RICE with a site rating less than or equal to 300 HP located at an area source of HAP emissions;

(5) An existing non-emergency, non-black start 2SLB stationary RICE located at an area source of HAP emissions;

(6) An existing non-emergency, non-black start landfill or digester gas stationary RICE located at an area source of HAP emissions;

(7) An existing non-emergency, non-black start 4SLB stationary RICE with a site rating less than or equal to 500 HP located at an area source of HAP emissions;

(8) An existing non-emergency, non-black start 4SRB stationary RICE with a site rating less than or equal to 500 HP located at an area source of HAP emissions;

(9) An existing, non-emergency, non-black start 4SLB stationary RICE with a site rating greater than 500 HP located at an area source of HAP emissions that is operated 24 hours or less per calendar year; and

(10) An existing, non-emergency, non-black start 4SRB stationary RICE with a site rating greater than 500 HP located at an area source of HAP emissions that is operated 24 hours or less per calendar year.

(f) If you own or operate an existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing emergency stationary RICE located at an area source of HAP emissions, you must install a non-resettable hour meter if one is not already installed.

(g) If you own or operate an existing non-emergency, non-black start CI engine greater than or equal to 300 HP that is not equipped with a closed crankcase ventilation system, you must comply with either paragraph (g)(1) or paragraph (g)(2) of this section. Owners and operators must follow the manufacturer's specified maintenance requirements for operating and maintaining the open or closed crankcase ventilation systems and replacing the crankcase filters, or can request the Administrator to approve different maintenance requirements that are as protective as manufacturer requirements. Existing CI engines located at area sources in areas of Alaska not accessible by the FAHS do not have to meet the requirements of paragraph (g) of this section.

(1) Install a closed crankcase ventilation system that prevents crankcase emissions from being emitted to the atmosphere, or

(2) Install an open crankcase filtration emission control system that reduces emissions from the crankcase by filtering the exhaust stream to remove oil mist, particulates, and metals.

(h) If you operate a new, reconstructed, or existing stationary engine, you must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup in Tables 1a, 2a, 2c, and 2d to this subpart apply.

(i) If you own or operate a stationary CI engine that is subject to the work, operation or management practices in items 1 or 2 of Table 2c to this subpart or in items 1 or 4 of Table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.

(j) If you own or operate a stationary SI engine that is subject to the work, operation or management practices in items 6, 7, or 8 of Table 2c to this subpart or in items 5, 6, 7, 9, or 11 of Table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Acid Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Acid Number increases by more than 3.0 milligrams of potassium hydroxide (KOH) per gram from Total Acid Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3606, Jan. 18, 2008; 75 FR 9676, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010; 76 FR 12866, Mar. 9, 2011]

**§ 63.6630 How do I demonstrate initial compliance with the emission limitations and operating limitations?**

(a) You must demonstrate initial compliance with each emission and operating limitation that applies to you according to Table 5 of this subpart.

(b) During the initial performance test, you must establish each operating limitation in Tables 1b and 2b of this subpart that applies to you.

(c) You must submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in §63.6645.

## Continuous Compliance Requirements

### § 63.6635 How do I monitor and collect data to demonstrate continuous compliance?

(a) If you must comply with emission and operating limitations, you must monitor and collect data according to this section.

(b) Except for monitor malfunctions, associated repairs, required performance evaluations, and required quality assurance or control activities, you must monitor continuously at all times that the stationary RICE is operating. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions.

(c) You may not use data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities in data averages and calculations used to report emission or operating levels. You must, however, use all the valid data collected during all other periods.

[69 FR 33506, June 15, 2004, as amended at 76 FR 12867, Mar. 9, 2011]

### § 63.6640 How do I demonstrate continuous compliance with the emission limitations and operating limitations?

(a) You must demonstrate continuous compliance with each emission limitation and operating limitation in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply to you according to methods specified in Table 6 to this subpart.

(b) You must report each instance in which you did not meet each emission limitation or operating limitation in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply to you. These instances are deviations from the emission and operating limitations in this subpart. These deviations must be reported according to the requirements in §63.6650. If you change your catalyst, you must reestablish the values of the operating parameters measured during the initial performance test. When you reestablish the values of your operating parameters, you must also conduct a performance test to demonstrate that you are meeting the required emission limitation applicable to your stationary RICE.

(c) [Reserved]

(d) For new, reconstructed, and rebuilt stationary RICE, deviations from the emission or operating limitations that occur during the first 200 hours of operation from engine startup (engine burn-in period) are not violations. Rebuilt stationary RICE means a stationary RICE that has been rebuilt as that term is defined in 40 CFR 94.11(a).

(e) You must also report each instance in which you did not meet the requirements in Table 8 to this subpart that apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing emergency stationary RICE, an existing limited use stationary RICE, or an existing stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart, except for the initial notification requirements: a new or reconstructed stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new or reconstructed emergency stationary RICE, or a new or reconstructed limited use stationary RICE.

(f) Requirements for emergency stationary RICE. (1) If you own or operate an existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, a new or reconstructed emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions that was installed on or after June 12, 2006, or an existing emergency stationary RICE located at an area source of HAP emissions, you must operate the emergency stationary RICE according to the requirements in paragraphs (f)(1)(i) through (iii) of this section. Any operation other than emergency operation, maintenance and testing, and operation in non-emergency

situations for 50 hours per year, as described in paragraphs (f)(1)(i) through (iii) of this section, is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1)(i) through (iii) of this section, the engine will not be considered an emergency engine under this subpart and will need to meet all requirements for non-emergency engines.

(i) There is no time limit on the use of emergency stationary RICE in emergency situations.

(ii) You may operate your emergency stationary RICE for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by Federal, State or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of such units is limited to 100 hours per year. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency RICE beyond 100 hours per year.

(iii) You may operate your emergency stationary RICE up to 50 hours per year in non-emergency situations, but those 50 hours are counted towards the 100 hours per year provided for maintenance and testing. The 50 hours per year for non-emergency situations cannot be used for peak shaving or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity; except that owners and operators may operate the emergency engine for a maximum of 15 hours per year as part of a demand response program if the regional transmission organization or equivalent balancing authority and transmission operator has determined there are emergency conditions that could lead to a potential electrical blackout, such as unusually low frequency, equipment overload, capacity or energy deficiency, or unacceptable voltage level. The engine may not be operated for more than 30 minutes prior to the time when the emergency condition is expected to occur, and the engine operation must be terminated immediately after the facility is notified that the emergency condition is no longer imminent. The 15 hours per year of demand response operation are counted as part of the 50 hours of operation per year provided for non-emergency situations. The supply of emergency power to another entity or entities pursuant to financial arrangement is not limited by this paragraph (f)(1)(iii), as long as the power provided by the financial arrangement is limited to emergency power.

(2) If you own or operate an emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions that was installed prior to June 12, 2006, you must operate the engine according to the conditions described in paragraphs (f)(2)(i) through (iii) of this section. If you do not operate the engine according to the requirements in paragraphs (f)(2)(i) through (iii) of this section, the engine will not be considered an emergency engine under this subpart and will need to meet all requirements for non-emergency engines.

(i) There is no time limit on the use of emergency stationary RICE in emergency situations.

(ii) You may operate your emergency stationary RICE for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by the manufacturer, the vendor, or the insurance company associated with the engine. Required testing of such units should be minimized, but there is no time limit on the use of emergency stationary RICE in emergency situations and for routine testing and maintenance.

(iii) You may operate your emergency stationary RICE for an additional 50 hours per year in non-emergency situations. The 50 hours per year for non-emergency situations cannot be used for peak shaving or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

[69 FR 33506, June 15, 2004, as amended at 71 FR 20467, Apr. 20, 2006; 73 FR 3606, Jan. 18, 2008; 75 FR 9676, Mar. 3, 2010; 75 FR 51591, Aug. 20, 2010]

## **Notifications, Reports, and Records**

### **§ 63.6645 What notifications must I submit and when?**

(a) You must submit all of the notifications in §§63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), 63.9(b) through (e), and (g) and (h) that apply to you by the dates specified if you own or operate any of the following:

(1) An existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions.

(2) An existing stationary RICE located at an area source of HAP emissions.

(3) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.

(4) A new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 HP located at a major source of HAP emissions.

(5) This requirement does not apply if you own or operate an existing stationary RICE less than 100 HP, an existing stationary emergency RICE, or an existing stationary RICE that is not subject to any numerical emission standards.

(b) As specified in §63.9(b)(2), if you start up your stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions before the effective date of this subpart, you must submit an Initial Notification not later than December 13, 2004.

(c) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions on or after August 16, 2004, you must submit an Initial Notification not later than 120 days after you become subject to this subpart.

(d) As specified in §63.9(b)(2), if you start up your stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions before the effective date of this subpart and you are required to submit an initial notification, you must submit an Initial Notification not later than July 16, 2008.

(e) If you start up your new or reconstructed stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions on or after March 18, 2008 and you are required to submit an initial notification, you must submit an Initial Notification not later than 120 days after you become subject to this subpart.

(f) If you are required to submit an Initial Notification but are otherwise not affected by the requirements of this subpart, in accordance with §63.6590(b), your notification should include the information in §63.9(b)(2)(i) through (v), and a statement that your stationary RICE has no additional requirements and explain the basis of the exclusion (for example, that it operates exclusively as an emergency stationary RICE if it has a site rating of more than 500 brake HP located at a major source of HAP emissions).

(g) If you are required to conduct a performance test, you must submit a Notification of Intent to conduct a performance test at least 60 days before the performance test is scheduled to begin as required in §63.7(b)(1).

(h) If you are required to conduct a performance test or other initial compliance demonstration as specified in Tables 4 and 5 to this subpart, you must submit a Notification of Compliance Status according to §63.9(h)(2)(ii).

(1) For each initial compliance demonstration required in Table 5 to this subpart that does not include a performance test, you must submit the Notification of Compliance Status before the close of business on the 30th day following the completion of the initial compliance demonstration.

(2) For each initial compliance demonstration required in Table 5 to this subpart that includes a performance test conducted according to the requirements in Table 3 to this subpart, you must submit the Notification of Compliance Status, including the performance test results, before the close of business on the 60th day following the completion of the performance test according to §63.10(d)(2).

[73 FR 3606, Jan. 18, 2008, as amended at 75 FR 9677, Mar. 3, 2010; 75 FR 51591, Aug. 20, 2010]

### **§ 63.6650 What reports must I submit and when?**

(a) You must submit each report in Table 7 of this subpart that applies to you.

(b) Unless the Administrator has approved a different schedule for submission of reports under §63.10(a), you must submit each report by the date in Table 7 of this subpart and according to the requirements in paragraphs (b)(1) through (b)(9) of this section.

(1) For semiannual Compliance reports, the first Compliance report must cover the period beginning on the compliance date that is specified for your affected source in §63.6595 and ending on June 30 or December 31, whichever date is the first date following the end of the first calendar half after the compliance date that is specified for your source in §63.6595.

(2) For semiannual Compliance reports, the first Compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date follows the end of the first calendar half after the compliance date that is specified for your affected source in §63.6595.

(3) For semiannual Compliance reports, each subsequent Compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through

December 31.

(4) For semiannual Compliance reports, each subsequent Compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date is the first date following the end of the semiannual reporting period.

(5) For each stationary RICE that is subject to permitting regulations pursuant to 40 CFR part 70 or 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6 (a)(3)(iii)(A), you may submit the first and subsequent Compliance reports according to the dates the permitting authority has established instead of according to the dates in paragraphs (b)(1) through (b)(4) of this section.

(6) For annual Compliance reports, the first Compliance report must cover the period beginning on the compliance date that is specified for your affected source in §63.6595 and ending on December 31.

(7) For annual Compliance reports, the first Compliance report must be postmarked or delivered no later than January 31 following the end of the first calendar year after the compliance date that is specified for your affected source in §63.6595.

(8) For annual Compliance reports, each subsequent Compliance report must cover the annual reporting period from January 1 through December 31.

(9) For annual Compliance reports, each subsequent Compliance report must be postmarked or delivered no later than January 31.

(c) The Compliance report must contain the information in paragraphs (c)(1) through (6) of this section.

(1) Company name and address.

(2) Statement by a responsible official, with that official's name, title, and signature, certifying the accuracy of the content of the report.

(3) Date of report and beginning and ending dates of the reporting period.

(4) If you had a malfunction during the reporting period, the compliance report must include the number, duration, and a brief description for each type of malfunction which occurred during the reporting period and which caused or may have caused any applicable emission limitation to be exceeded. The report must also include a description of actions taken by an owner or operator during a malfunction of an affected source to minimize emissions in accordance with §63.6605(b), including actions taken to correct a malfunction.

(5) If there are no deviations from any emission or operating limitations that apply to you, a statement that there were no deviations from the emission or operating limitations during the reporting period.

(6) If there were no periods during which the continuous monitoring system (CMS), including CEMS and CPMS, was out-of-control, as specified in §63.8(c)(7), a statement that there were no periods during which the CMS was out-of-control during the reporting period.

(d) For each deviation from an emission or operating limitation that occurs for a stationary RICE where you are not using a CMS to comply with the emission or operating limitations in this subpart, the Compliance report must contain the information in paragraphs (c)(1) through (4) of this section and the information in paragraphs (d)(1) and (2) of this section.

(1) The total operating time of the stationary RICE at which the deviation occurred during the reporting period.

(2) Information on the number, duration, and cause of deviations (including unknown cause, if applicable), as applicable, and the corrective action taken.

(e) For each deviation from an emission or operating limitation occurring for a stationary RICE where you are using a CMS to comply with the emission and operating limitations in this subpart, you must include information in paragraphs (c)(1) through (4) and (e)(1) through (12) of this section.

(1) The date and time that each malfunction started and stopped.

(2) The date, time, and duration that each CMS was inoperative, except for zero (low-level) and high-level checks.

(3) The date, time, and duration that each CMS was out-of-control, including the information in §63.8(c)(8).

(4) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of malfunction or during another period.

(5) A summary of the total duration of the deviation during the reporting period, and the total duration as a percent of the total source operating time during that reporting period.

(6) A breakdown of the total duration of the deviations during the reporting period into those that are due to control equipment problems, process problems, other known causes, and other unknown causes.

(7) A summary of the total duration of CMS downtime during the reporting period, and the total duration of

CMS downtime as a percent of the total operating time of the stationary RICE at which the CMS downtime occurred during that reporting period.

(8) An identification of each parameter and pollutant (CO or formaldehyde) that was monitored at the stationary RICE.

(9) A brief description of the stationary RICE.

(10) A brief description of the CMS.

(11) The date of the latest CMS certification or audit.

(12) A description of any changes in CMS, processes, or controls since the last reporting period.

(f) Each affected source that has obtained a title V operating permit pursuant to 40 CFR part 70 or 71 must report all deviations as defined in this subpart in the semiannual monitoring report required by 40 CFR 70.6

(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If an affected source submits a Compliance report pursuant to Table 7 of this subpart along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the Compliance report includes all required information concerning deviations from any emission or operating limitation in this subpart, submission of the Compliance report shall be deemed to satisfy any obligation to report the same deviations in the semiannual monitoring report. However, submission of a Compliance report shall not otherwise affect any obligation the affected source may have to report deviations from permit requirements to the permit authority.

(g) If you are operating as a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must submit an annual report according to Table 7 of this subpart by the date specified unless the Administrator has approved a different schedule, according to the information described in paragraphs (b)(1) through (b)(5) of this section. You must report the data specified in (g)(1) through (g)(3) of this section.

(1) Fuel flow rate of each fuel and the heating values that were used in your calculations. You must also demonstrate that the percentage of heat input provided by landfill gas or digester gas is equivalent to 10 percent or more of the total fuel consumption on an annual basis.

(2) The operating limits provided in your federally enforceable permit, and any deviations from these limits.

(3) Any problems or errors suspected with the meters.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9677, Mar. 3, 2010]

### **§ 63.6655 What records must I keep?**

(a) If you must comply with the emission and operating limitations, you must keep the records described in paragraphs (a)(1) through (a)(5), (b)(1) through (b)(3) and (c) of this section.

(1) A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted, according to the requirement in §63.10(b)(2)(xiv).

(2) Records of the occurrence and duration of each malfunction of operation ( i.e., process equipment) or the air pollution control and monitoring equipment.

(3) Records of performance tests and performance evaluations as required in §63.10(b)(2)(viii).

(4) Records of all required maintenance performed on the air pollution control and monitoring equipment.

(5) Records of actions taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation.

(b) For each CEMS or CPMS, you must keep the records listed in paragraphs (b)(1) through (3) of this section.

(1) Records described in §63.10(b)(2)(vi) through (xi).

(2) Previous ( i.e., superseded) versions of the performance evaluation plan as required in §63.8(d)(3).

(3) Requests for alternatives to the relative accuracy test for CEMS or CPMS as required in §63.8(f)(6)(i), if applicable.

(c) If you are operating a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must keep the records of your daily fuel usage monitors.

(d) You must keep the records required in Table 6 of this subpart to show continuous compliance with each emission or operating limitation that applies to you.

(e) You must keep records of the maintenance conducted on the stationary RICE in order to demonstrate

that you operated and maintained the stationary RICE and after-treatment control device (if any) according to your own maintenance plan if you own or operate any of the following stationary RICE;

(1) An existing stationary RICE with a site rating of less than 100 brake HP located at a major source of HAP emissions.

(2) An existing stationary emergency RICE.

(3) An existing stationary RICE located at an area source of HAP emissions subject to management practices as shown in Table 2d to this subpart.

(f) If you own or operate any of the stationary RICE in paragraphs (f)(1) or (2) of this section, you must keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. The owner or operator must document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for non-emergency operation. If the engines are used for demand response operation, the owner or operator must keep records of the notification of the emergency situation, and the time the engine was operated as part of demand response.

(1) An existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions that does not meet the standards applicable to non-emergency engines.

(2) An existing emergency stationary RICE located at an area source of HAP emissions that does not meet the standards applicable to non-emergency engines.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9678, Mar. 3, 2010; 75 FR 51592, Aug. 20, 2010]

#### **§ 63.6660 In what form and how long must I keep my records?**

(a) Your records must be in a form suitable and readily available for expeditious review according to §63.10(b)(1).

(b) As specified in §63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record readily accessible in hard copy or electronic form for at least 5 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to §63.10(b)(1).

[69 FR 33506, June 15, 2004, as amended at 75 FR 9678, Mar. 3, 2010]

#### **Other Requirements and Information**

#### **§ 63.6665 What parts of the General Provisions apply to me?**

Table 8 to this subpart shows which parts of the General Provisions in §§63.1 through 63.15 apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with any of the requirements of the General Provisions specified in Table 8: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing stationary RICE that combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, an existing emergency stationary RICE, or an existing limited use stationary RICE. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in the General Provisions specified in Table 8 except for the initial notification requirements: A new stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new emergency stationary RICE, or a new limited use stationary RICE.

[75 FR 9678, Mar. 3, 2010]

#### **§ 63.6670 Who implements and enforces this subpart?**

(a) This subpart is implemented and enforced by the U.S. EPA, or a delegated authority such as your

State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency (as well as the U.S. EPA) has the authority to implement and enforce this subpart. You should contact your U.S. EPA Regional Office to find out whether this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under 40 CFR part 63, subpart E, the authorities contained in paragraph (c) of this section are retained by the Administrator of the U.S. EPA and are not transferred to the State, local, or tribal agency.

(c) The authorities that will not be delegated to State, local, or tribal agencies are:

- (1) Approval of alternatives to the non-opacity emission limitations and operating limitations in §63.6600 under §63.6(g).
- (2) Approval of major alternatives to test methods under §63.7(e)(2)(ii) and (f) and as defined in §63.90.
- (3) Approval of major alternatives to monitoring under §63.8(f) and as defined in §63.90.
- (4) Approval of major alternatives to recordkeeping and reporting under §63.10(f) and as defined in §63.90.
- (5) Approval of a performance test which was conducted prior to the effective date of the rule, as specified in §63.6610(b).

### **§ 63.6675 What definitions apply to this subpart?**

Terms used in this subpart are defined in the Clean Air Act (CAA); in 40 CFR 63.2, the General Provisions of this part; and in this section as follows:

Area source means any stationary source of HAP that is not a major source as defined in part 63.

Associated equipment as used in this subpart and as referred to in section 112(n)(4) of the CAA, means equipment associated with an oil or natural gas exploration or production well, and includes all equipment from the well bore to the point of custody transfer, except glycol dehydration units, storage vessels with potential for flash emissions, combustion turbines, and stationary RICE.

Black start engine means an engine whose only purpose is to start up a combustion turbine.

CAA means the Clean Air Act (42 U.S.C. 7401 et seq., as amended by Public Law 101-549, 104 Stat. 2399).

Commercial emergency stationary RICE means an emergency stationary RICE used in commercial establishments such as office buildings, hotels, stores, telecommunications facilities, restaurants, financial institutions such as banks, doctor's offices, and sports and performing arts facilities.

Compression ignition means relating to a type of stationary internal combustion engine that is not a spark ignition engine.

Custody transfer means the transfer of hydrocarbon liquids or natural gas: After processing and/or treatment in the producing operations, or from storage vessels or automatic transfer facilities or other such equipment, including product loading racks, to pipelines or any other forms of transportation. For the purposes of this subpart, the point at which such liquids or natural gas enters a natural gas processing plant is a point of custody transfer.

Deviation means any instance in which an affected source subject to this subpart, or an owner or operator of such a source:

- (1) Fails to meet any requirement or obligation established by this subpart, including but not limited to any emission limitation or operating limitation;
- (2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this subpart and that is included in the operating permit for any affected source required to obtain such a permit; or
- (3) Fails to meet any emission limitation or operating limitation in this subpart during malfunction, regardless or whether or not such failure is permitted by this subpart.
- (4) Fails to satisfy the general duty to minimize emissions established by §63.6(e)(1)(i).

Diesel engine means any stationary RICE in which a high boiling point liquid fuel injected into the combustion chamber ignites when the air charge has been compressed to a temperature sufficiently high for auto-ignition. This process is also known as compression ignition.

Diesel fuel means any liquid obtained from the distillation of petroleum with a boiling point of approximately 150 to 360 degrees Celsius. One commonly used form is fuel oil number 2. Diesel fuel also includes any non-distillate fuel with comparable physical and chemical properties ( e.g. biodiesel) that is suitable for use in compression ignition engines.

Digester gas means any gaseous by-product of wastewater treatment typically formed through the anaerobic decomposition of organic waste materials and composed principally of methane and CO<sub>2</sub>.

Dual-fuel engine means any stationary RICE in which a liquid fuel (typically diesel fuel) is used for compression ignition and gaseous fuel (typically natural gas) is used as the primary fuel.

Emergency stationary RICE means any stationary internal combustion engine whose operation is limited to emergency situations and required testing and maintenance. Examples include stationary RICE used to produce power for critical networks or equipment (including power supplied to portions of a facility) when electric power from the local utility (or the normal power source, if the facility runs on its own power production) is interrupted, or stationary RICE used to pump water in the case of fire or flood, etc. Stationary RICE used for peak shaving are not considered emergency stationary RICE. Stationary RICE used to supply power to an electric grid or that supply non-emergency power as part of a financial arrangement with another entity are not considered to be emergency engines, except as permitted under §63.6640(f). All emergency stationary RICE must comply with the requirements specified in §63.6640(f) in order to be considered emergency stationary RICE. If the engine does not comply with the requirements specified in §63.6640(f), then it is not considered to be an emergency stationary RICE under this subpart.

Engine startup means the time from initial start until applied load and engine and associated equipment reaches steady state or normal operation. For stationary engine with catalytic controls, engine startup means the time from initial start until applied load and engine and associated equipment, including the catalyst, reaches steady state or normal operation.

Four-stroke engine means any type of engine which completes the power cycle in two crankshaft revolutions, with intake and compression strokes in the first revolution and power and exhaust strokes in the second revolution.

Gaseous fuel means a material used for combustion which is in the gaseous state at standard atmospheric temperature and pressure conditions.

Gasoline means any fuel sold in any State for use in motor vehicles and motor vehicle engines, or nonroad or stationary engines, and commonly or commercially known or sold as gasoline.

Glycol dehydration unit means a device in which a liquid glycol (including, but not limited to, ethylene glycol, diethylene glycol, or triethylene glycol) absorbent directly contacts a natural gas stream and absorbs water in a contact tower or absorption column (absorber). The glycol contacts and absorbs water vapor and other gas stream constituents from the natural gas and becomes "rich" glycol. This glycol is then regenerated in the glycol dehydration unit reboiler. The "lean" glycol is then recycled.

Hazardous air pollutants (HAP) means any air pollutants listed in or pursuant to section 112(b) of the CAA.

Institutional emergency stationary RICE means an emergency stationary RICE used in institutional establishments such as medical centers, nursing homes, research centers, institutions of higher education, correctional facilities, elementary and secondary schools, libraries, religious establishments, police stations, and fire stations.

ISO standard day conditions means 288 degrees Kelvin (15 degrees Celsius), 60 percent relative humidity and 101.3 kilopascals pressure.

Landfill gas means a gaseous by-product of the land application of municipal refuse typically formed through the anaerobic decomposition of waste materials and composed principally of methane and CO<sub>2</sub>.

Lean burn engine means any two-stroke or four-stroke spark ignited engine that does not meet the definition of a rich burn engine.

Limited use stationary RICE means any stationary RICE that operates less than 100 hours per year.

Liquefied petroleum gas means any liquefied hydrocarbon gas obtained as a by-product in petroleum refining of natural gas production.

Liquid fuel means any fuel in liquid form at standard temperature and pressure, including but not limited to diesel, residual/crude oil, kerosene/naphtha (jet fuel), and gasoline.

Major Source, as used in this subpart, shall have the same meaning as in §63.2, except that:

- (1) Emissions from any oil or gas exploration or production well (with its associated equipment (as defined in this section)) and emissions from any pipeline compressor station or pump station shall not be aggregated with emissions from other similar units, to determine whether such emission points or stations are major sources, even when emission points are in a contiguous area or under common control;
- (2) For oil and gas production facilities, emissions from processes, operations, or equipment that are not part of the same oil and gas production facility, as defined in §63.1271 of subpart HHH of this part, shall not be aggregated;
- (3) For production field facilities, only HAP emissions from glycol dehydration units, storage vessel with the potential for flash emissions, combustion turbines and reciprocating internal combustion engines shall be aggregated for a major source determination; and
- (4) Emissions from processes, operations, and equipment that are not part of the same natural gas transmission and storage facility, as defined in §63.1271 of subpart HHH of this part, shall not be aggregated.

Malfunction means any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner which causes, or has the potential to cause, the emission limitations in an applicable standard to be exceeded. Failures that are caused in part by poor maintenance or careless operation are not malfunctions.

Natural gas means a naturally occurring mixture of hydrocarbon and non-hydrocarbon gases found in geologic formations beneath the Earth's surface, of which the principal constituent is methane. Natural gas may be field or pipeline quality.

Non-selective catalytic reduction (NSCR) means an add-on catalytic nitrogen oxides (NO<sub>x</sub>) control device for rich burn engines that, in a two-step reaction, promotes the conversion of excess oxygen, NO<sub>x</sub>, CO, and volatile organic compounds (VOC) into CO<sub>2</sub>, nitrogen, and water.

Oil and gas production facility as used in this subpart means any grouping of equipment where hydrocarbon liquids are processed, upgraded ( i.e., remove impurities or other constituents to meet contract specifications), or stored prior to the point of custody transfer; or where natural gas is processed, upgraded, or stored prior to entering the natural gas transmission and storage source category. For purposes of a major source determination, facility (including a building, structure, or installation) means oil and natural gas production and processing equipment that is located within the boundaries of an individual surface site as defined in this section. Equipment that is part of a facility will typically be located within close proximity to other equipment located at the same facility. Pieces of production equipment or groupings of equipment located on different oil and gas leases, mineral fee tracts, lease tracts, subsurface or surface unit areas, surface fee tracts, surface lease tracts, or separate surface sites, whether or not connected by a road, waterway, power line or pipeline, shall not be considered part of the same facility. Examples of facilities in the oil and natural gas production source category include, but are not limited to, well sites, satellite tank batteries, central tank batteries, a compressor station that transports natural gas to a natural gas processing plant, and natural gas processing plants.

Oxidation catalyst means an add-on catalytic control device that controls CO and VOC by oxidation.

Peaking unit or engine means any standby engine intended for use during periods of high demand that are not emergencies.

Percent load means the fractional power of an engine compared to its maximum manufacturer's design capacity at engine site conditions. Percent load may range between 0 percent to above 100 percent.

Potential to emit means the maximum capacity of a stationary source to emit a pollutant under its physical and operational design. Any physical or operational limitation on the capacity of the stationary source to emit a pollutant, including air pollution control equipment and restrictions on hours of operation or on the type or amount of material combusted, stored, or processed, shall be treated as part of its design if the limitation or the effect it would have on emissions is federally enforceable. For oil and natural gas production facilities subject to subpart HH of this part, the potential to emit provisions in §63.760(a) may be used. For natural gas transmission and storage facilities subject to subpart HHH of this part, the maximum annual facility gas throughput for storage facilities may be determined according to §63.1270(a)(1) and the maximum annual throughput for transmission facilities may be determined according to §63.1270(a)(2).

Production field facility means those oil and gas production facilities located prior to the point of custody transfer.

Production well means any hole drilled in the earth from which crude oil, condensate, or field natural gas is extracted.

Propane means a colorless gas derived from petroleum and natural gas, with the molecular structure  $C_3H_8$ .

Residential emergency stationary RICE means an emergency stationary RICE used in residential establishments such as homes or apartment buildings.

Responsible official means responsible official as defined in 40 CFR 70.2.

Rich burn engine means any four-stroke spark ignited engine where the manufacturer's recommended operating air/fuel ratio divided by the stoichiometric air/fuel ratio at full load conditions is less than or equal to 1.1. Engines originally manufactured as rich burn engines, but modified prior to December 19, 2002 with passive emission control technology for  $NO_x$  (such as pre-combustion chambers) will be considered lean burn engines. Also, existing engines where there are no manufacturer's recommendations regarding air/fuel ratio will be considered a rich burn engine if the excess oxygen content of the exhaust at full load conditions is less than or equal to 2 percent.

Site-rated HP means the maximum manufacturer's design capacity at engine site conditions.

Spark ignition means relating to either: A gasoline-fueled engine; or any other type of engine with a spark plug (or other sparking device) and with operating characteristics significantly similar to the theoretical Otto combustion cycle. Spark ignition engines usually use a throttle to regulate intake air flow to control power during normal operation. Dual-fuel engines in which a liquid fuel (typically diesel fuel) is used for CI and gaseous fuel (typically natural gas) is used as the primary fuel at an annual average ratio of less than 2 parts diesel fuel to 100 parts total fuel on an energy equivalent basis are spark ignition engines.

Stationary reciprocating internal combustion engine (RICE) means any reciprocating internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work and which is not mobile. Stationary RICE differ from mobile RICE in that a stationary RICE is not a non-road engine as defined at 40 CFR 1068.30, and is not used to propel a motor vehicle or a vehicle used solely for competition.

Stationary RICE test cell/stand means an engine test cell/stand, as defined in subpart P of this part, that tests stationary RICE.

Stoichiometric means the theoretical air-to-fuel ratio required for complete combustion.

Storage vessel with the potential for flash emissions means any storage vessel that contains a hydrocarbon liquid with a stock tank gas-to-oil ratio equal to or greater than 0.31 cubic meters per liter and an American Petroleum Institute gravity equal to or greater than 40 degrees and an actual annual average hydrocarbon liquid throughput equal to or greater than 79,500 liters per day. Flash emissions occur when dissolved hydrocarbons in the fluid evolve from solution when the fluid pressure is reduced.

Subpart means 40 CFR part 63, subpart ZZZZ.

Surface site means any combination of one or more graded pad sites, gravel pad sites, foundations, platforms, or the immediate physical location upon which equipment is physically affixed.

Two-stroke engine means a type of engine which completes the power cycle in single crankshaft revolution by combining the intake and compression operations into one stroke and the power and exhaust operations into a second stroke. This system requires auxiliary scavenging and inherently runs lean of stoichiometric. [69 FR 33506, June 15, 2004, as amended at 71 FR 20467, Apr. 20, 2006; 73 FR 3607, Jan. 18, 2008; 75 FR 9679, Mar. 3, 2010; 75 FR 51592, Aug. 20, 2010; 76 FR 12867, Mar. 9, 2011]

**Table 1a to Subpart ZZZZ of Part 63—Emission Limitations for Existing, New, and Reconstructed Spark Ignition, 4SRB Stationary RICE >500 HP Located at a Major Source of HAP Emissions**

As stated in §§63.6600 and 63.6640, you must comply with the following emission limitations at 100 percent load plus or minus 10 percent for existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions:

For each . . .	You must meet the following emission limitation, except during periods of startup . . .	During periods of startup you must . . .
1. 4SRB stationary RICE	a. Reduce formaldehyde emissions by 76 percent or more. If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004, you may reduce formaldehyde emissions by 75 percent or more until June 15, 2007 or	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. <sup>1</sup>
	b. Limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O <sub>2</sub>	

<sup>1</sup>Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

[75 FR 9679, Mar. 3, 2010, as amended at 75 FR 51592, Aug. 20, 2010]

**Table 1b to Subpart ZZZZ of Part 63—Operating Limitations for Existing, New, and Reconstructed Spark Ignition 4SRB Stationary RICE >500 HP Located at a Major Source of HAP Emissions and Existing Spark Ignition 4SRB Stationary RICE >500 HP Located at an Area Source of HAP Emissions**

As stated in §§63.6600, 63.6603, 63.6630 and 63.6640, you must comply with the following operating limitations for existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions and existing 4SRB stationary RICE >500 HP located at an area source of HAP emissions that operate more than 24 hours per calendar year:

For each . . .	You must meet the following operating limitation . . .
1. 4SRB stationary RICE complying with the requirement to reduce formaldehyde emissions by 76 percent or more (or by 75 percent or more, if applicable) and using NSCR; or 4SRB stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O <sub>2</sub> and using NSCR; or 4SRB stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 2.7 ppmvd or less at 15 percent O <sub>2</sub> and using NSCR.	a. Maintain your catalyst so that the pressure drop across the catalyst does not change by more than 2 inches of water at 100 percent load plus or minus 10 percent from the pressure drop across the catalyst measured during the initial performance test; and b. Maintain the temperature of your stationary RICE exhaust so that the catalyst inlet temperature is greater than or equal to 750 °F and less than or equal to 1250 °F.
2. 4SRB stationary RICE complying with the requirement to reduce formaldehyde emissions by 76 percent or more (or by 75 percent or more, if applicable) and not using NSCR; or 4SRB stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O <sub>2</sub> and not	Comply with any operating limitations approved by the Administrator.

For each . . .	You must meet the following operating limitation . . .
using NSCR; or 4SRB stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 2.7 ppmvd or less at 15 percent O <sub>2</sub> and not using NSCR.	

[76 FR 12867, Mar. 9, 2011]

**Table 2a to Subpart ZZZZ of Part 63—Emission Limitations for New and Reconstructed 2SLB and Compression Ignition Stationary RICE >500 HP and New and Reconstructed 4SLB Stationary RICE ≥250 HP Located at a Major Source of HAP Emissions**

As stated in §§63.6600 and 63.6640, you must comply with the following emission limitations for new and reconstructed lean burn and new and reconstructed compression ignition stationary RICE at 100 percent load plus or minus 10 percent:

For each . . .	You must meet the following emission limitation, except during periods of startup . . .	During periods of startup you must . . .
1. 2SLB stationary RICE	a. Reduce CO emissions by 58 percent or more; or b. Limit concentration of formaldehyde in the stationary RICE exhaust to 12 ppmvd or less at 15 percent O <sub>2</sub> . If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004, you may limit concentration of formaldehyde to 17 ppmvd or less at 15 percent O <sub>2</sub> until June 15, 2007	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. <sup>1</sup>
2. 4SLB stationary RICE	a. Reduce CO emissions by 93 percent or more; or	
	b. Limit concentration of formaldehyde in the stationary RICE exhaust to 14 ppmvd or less at 15 percent O <sub>2</sub>	
3. CI stationary RICE	a. Reduce CO emissions by 70 percent or more; or	
	b. Limit concentration of formaldehyde in the stationary RICE exhaust to 580 ppbvd or less at 15 percent O <sub>2</sub>	

<sup>1</sup>Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

[75 FR 9680, Mar. 3, 2010]

**Table 2b to Subpart ZZZZ of Part 63— Operating Limitations for New and Reconstructed 2SLB and Compression Ignition Stationary RICE >500 HP Located at a Major Source of HAP Emissions, New and Reconstructed 4SLB Stationary RICE ≥250 HP Located at a Major Source of HAP Emissions, Existing Compression Ignition Stationary RICE >500 HP, and Existing 4SLB Stationary RICE >500 HP Located at an Area Source of HAP Emissions**

As stated in §§63.6600, 63.6601, 63.6603, 63.6630, and 63.6640, you must comply with the following operating limitations for new and reconstructed 2SLB and compression ignition stationary RICE located at a major source of HAP emissions; new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions; existing compression ignition stationary RICE >500 HP; and existing 4SLB stationary RICE >500 HP located at an area source of HAP emissions that operate more than 24 hours per calendar year:

For each . . .	You must meet the following operating limitation . . .
1. 2SLB and 4SLB stationary RICE and CI stationary RICE complying with the requirement to reduce CO emissions and using an oxidation catalyst; or 2SLB and 4SLB stationary RICE and CI stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust and using an oxidation catalyst; or 4SLB stationary RICE and CI stationary RICE complying with the requirement to limit the concentration of CO in the stationary RICE exhaust and using an oxidation catalyst	a. maintain your catalyst so that the pressure drop across the catalyst does not change by more than 2 inches of water at 100 percent load plus or minus 10 percent from the pressure drop across the catalyst that was measured during the initial performance test; and b. maintain the temperature of your stationary RICE exhaust so that the catalyst inlet temperature is greater than or equal to 450 °F and less than or equal to 1350 °F. <sup>1</sup>
2. 2SLB and 4SLB stationary RICE and CI stationary RICE complying with the requirement to reduce CO emissions and not using an oxidation catalyst; or 2SLB and 4SLB stationary RICE and CI stationary RICE complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust and not using an oxidation catalyst; or 4SLB stationary RICE and CI stationary RICE complying with the requirement to limit the concentration of CO in the stationary RICE exhaust and not using an oxidation catalyst	Comply with any operating limitations approved by the Administrator.

<sup>1</sup>Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.8(g) for a different temperature range.

[75 FR 51593, Aug. 20, 2010, as amended at 76 FR 12867, Mar. 9, 2011]

**Table 2c to Subpart ZZZZ of Part 63—Requirements for Existing Compression Ignition Stationary RICE Located at a Major Source of HAP Emissions and Existing Spark Ignition Stationary RICE ≤500 HP Located at a Major Source of HAP Emissions**

As stated in §§63.6600, 63.6602, and 63.6640, you must comply with the following requirements for existing compression ignition stationary RICE located at a major source of HAP emissions and existing spark ignition stationary RICE ≤500 HP located at a major source of HAP emissions:

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
1. Emergency stationary CI RICE and black start stationary CI RICE. <sup>1</sup>	a. Change oil and filter every 500 hours of operation or annually, whichever comes first; <sup>2</sup> b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. <sup>3</sup>
2. Non-Emergency, non-black start stationary CI RICE <100 HP	a. Change oil and filter every 1,000 hours of operation or annually, whichever comes first; <sup>2</sup>	
	b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first;	
	c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>	
3. Non-Emergency, non-black start CI stationary RICE 100≤HP≤300 HP	Limit concentration of CO in the stationary RICE exhaust to 230 ppmvd or less at 15 percent O <sub>2</sub>	
4. Non-Emergency, non-black start CI stationary RICE 300<HP≤500	a. Limit concentration of CO in the stationary RICE exhaust to 49 ppmvd or less at 15 percent O <sub>2</sub> ; or	
	b. Reduce CO emissions by 70 percent or more.	
5. Non-Emergency, non-black start stationary CI RICE >500 HP	a. Limit concentration of CO in the stationary RICE exhaust to 23 ppmvd or less at 15 percent O <sub>2</sub> ; or	

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
	b. Reduce CO emissions by 70 percent or more.	
6. Emergency stationary SI RICE and black start stationary SI RICE. <sup>1</sup>	a. Change oil and filter every 500 hours of operation or annually, whichever comes first; <sup>2</sup>	
	b. Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first;	
	c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>	
7. Non-Emergency, non-black start stationary SI RICE <100 HP that are not 2SLB stationary RICE	a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first; <sup>2</sup>	
	b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first;	
	c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>	
8. Non-Emergency, non-black start 2SLB stationary SI RICE <100 HP	a. Change oil and filter every 4,320 hours of operation or annually, whichever comes first; <sup>2</sup>	
	b. Inspect spark plugs every 4,320 hours of operation or annually, whichever comes first;	
	c. Inspect all hoses and belts every 4,320 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>	
9. Non-emergency, non-black start 2SLB stationary RICE 100≤HP≤500	Limit concentration of CO in the stationary RICE exhaust to 225 ppmvd or less at 15 percent O <sub>2</sub>	

<b>For each . . .</b>	<b>You must meet the following requirement, except during periods of startup . . .</b>	<b>During periods of startup you must . . .</b>
10. Non-emergency, non-black start 4SLB stationary RICE 100≤HP≤500	Limit concentration of CO in the stationary RICE exhaust to 47 ppmvd or less at 15 percent O <sub>2</sub>	
11. Non-emergency, non-black start 4SRB stationary RICE 100≤HP≤500	Limit concentration of formaldehyde in the stationary RICE exhaust to 10.3 ppmvd or less at 15 percent O <sub>2</sub>	
12. Non-emergency, non-black start landfill or digester gas-fired stationary RICE 100≤HP≤500	Limit concentration of CO in the stationary RICE exhaust to 177 ppmvd or less at 15 percent O <sub>2</sub>	

<sup>1</sup>If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the work practice requirements on the schedule required in Table 2c of this subpart, or if performing the work practice on the required schedule would otherwise pose an unacceptable risk under Federal, State, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under Federal, State, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, State, or local law has abated. Sources must report any failure to perform the work practice on the schedule required and the Federal, State or local law under which the risk was deemed unacceptable.

<sup>2</sup>Sources have the option to utilize an oil analysis program as described in §63.6625(i) in order to extend the specified oil change requirement in Table 2c of this subpart.

<sup>3</sup>Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

[75 FR 51593, Aug. 20, 2010]

**Table 2d to Subpart ZZZZ of Part 63— Requirements for Existing Stationary RICE Located at Area Sources of HAP Emissions**

As stated in §§63.6603 and 63.6640, you must comply with the following requirements for existing stationary RICE located at area sources of HAP emissions:

<b>For each . . .</b>	<b>You must meet the following requirement, except during periods of startup . . .</b>	<b>During periods of startup you must . . .</b>
1. Non-Emergency, non-black start CI stationary RICE ≤300 HP	a. Change oil and filter every 1,000 hours of operation or annually, whichever comes first; <sup>1</sup>	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply.
	b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first;	
	c. Inspect all hoses and	

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
	belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	
2. Non-Emergency, non-black start CI stationary RICE 300<HP≤500	a. Limit concentration of CO in the stationary RICE exhaust to 49 ppmvd at 15 percent O <sub>2</sub> ; or	
	b. Reduce CO emissions by 70 percent or more.	
3. Non-Emergency, non-black start CI stationary RICE >500 HP	a. Limit concentration of CO in the stationary RICE exhaust to 23 ppmvd at 15 percent O <sub>2</sub> ; or	
	b. Reduce CO emissions by 70 percent or more.	
4. Emergency stationary CI RICE and black start stationary CI RICE. <sup>2</sup>	a. Change oil and filter every 500 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; and	
	c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	
5. Emergency stationary SI RICE; black start stationary SI RICE; non-emergency, non-black start 4SLB stationary RICE >500 HP that operate 24 hours or less per calendar year; non-emergency, non-black start 4SRB stationary RICE >500 HP that operate 24 hours or less per calendar year. <sup>2</sup>	a. Change oil and filter every 500 hours of operation or annually, whichever comes first; <sup>1</sup> b. Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first; and c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	
6. Non-emergency, non-black start 2SLB stationary RICE	a. Change oil and filter every 4,320 hours of	

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
	operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect spark plugs every 4,320 hours of operation or annually, whichever comes first; and	
	c. Inspect all hoses and belts every 4,320 hours of operation or annually, whichever comes first, and replace as necessary.	
7. Non-emergency, non-black start 4SLB stationary RICE ≤500 HP	a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first; and	
	c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary.	
8. Non-emergency, non-black start 4SLB stationary RICE >500 HP	a. Limit concentration of CO in the stationary RICE exhaust to 47 ppmvd at 15 percent O <sub>2</sub> ; or	
	b. Reduce CO emissions by 93 percent or more.	
9. Non-emergency, non-black start 4SRB stationary RICE ≤500 HP	a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first; and	
	c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary.	

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
10. Non-emergency, non-black start 4SRB stationary RICE >500 HP	a. Limit concentration of formaldehyde in the stationary RICE exhaust to 2.7 ppmvd at 15 percent O <sub>2</sub> ; or	
	b. Reduce formaldehyde emissions by 76 percent or more.	
11. Non-emergency, non-black start landfill or digester gas-fired stationary RICE	a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first; and	
	c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary.	

<sup>1</sup>Sources have the option to utilize an oil analysis program as described in §63.6625(i) in order to extend the specified oil change requirement in Table 2d of this subpart.

<sup>2</sup>If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in Table 2d of this subpart, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under Federal, State, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under Federal, State, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, State, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the Federal, State or local law under which the risk was deemed unacceptable.

[75 FR 51595, Aug. 20, 2010]

**Table 3 to Subpart ZZZZ of Part 63—Subsequent Performance Tests**

As stated in §§63.6615 and 63.6620, you must comply with the following subsequent performance test requirements:

For each . . .	Complying with the requirement to . . .	You must . . .
1. New or reconstructed 2SLB stationary RICE with a brake horsepower >500 located at major sources; new or reconstructed 4SLB stationary RICE with a brake horsepower ≥250 located at major sources; and new or reconstructed CI stationary RICE with a brake horsepower >500 located at major sources	Reduce CO emissions and not using a CEMS	Conduct subsequent performance tests semiannually. <sup>1</sup>
2. 4SRB stationary RICE with a brake horsepower ≥5,000 located at major sources	Reduce formaldehyde emissions	Conduct subsequent performance tests semiannually. <sup>1</sup>
3. Stationary RICE with a brake horsepower >500 located at major sources and new or reconstructed 4SLB stationary RICE with a brake horsepower 250≤HP≤500 located at major sources	Limit the concentration of formaldehyde in the stationary RICE exhaust	Conduct subsequent performance tests semiannually. <sup>1</sup>
4. Existing non-emergency, non-black start CI stationary RICE with a brake horsepower >500 that are not limited use stationary RICE; existing non-emergency, non-black start 4SLB and 4SRB stationary RICE located at an area source of HAP emissions with a brake horsepower >500 that are operated more than 24 hours per calendar year that are not limited use stationary RICE	Limit or reduce CO or formaldehyde emissions	Conduct subsequent performance tests every 8,760 hrs. or 3 years, whichever comes first.
5. Existing non-emergency, non-black start CI stationary RICE with a brake horsepower >500 that are limited use stationary RICE; existing non-emergency, non-black start 4SLB and 4SRB stationary RICE located at an area source of HAP emissions with a brake horsepower >500 that are operated more than 24 hours per calendar year and are limited use stationary RICE	Limit or reduce CO or formaldehyde emissions	Conduct subsequent performance tests every 8,760 hrs. or 5 years, whichever comes first.

<sup>1</sup>After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.  
[75 FR 51596, Aug. 20, 2010]

**Table 4 to Subpart ZZZZ of Part 63—Requirements for Performance Tests**

As stated in §§63.6610, 63.6611, 63.6612, 63.6620, and 63.6640, you must comply with the following requirements for performance tests for stationary RICE:

For each . . .	Complying with the requirement to . . .	You must . . .	Using . . .	According to the following requirements . . .
1. 2SLB, 4SLB, and CI stationary RICE	a. Reduce CO emissions	i. Measure the O <sub>2</sub> at the inlet and outlet of the control device; and	(1) Portable CO and O <sub>2</sub> analyzer	(a) Using ASTM D6522–00 (2005) <sup>a</sup> (incorporated by reference, see §63.14). Measurements to determine O <sub>2</sub> must be made at the same time as the measurements for CO concentration.
		ii. Measure the CO at the inlet and the outlet of the control device	(1) Portable CO and O <sub>2</sub> analyzer	(a) Using ASTM D6522–00 (2005) <sup>ab</sup> (incorporated by reference, see §63.14) or Method 10 of 40 CFR appendix A. The CO concentration must be at 15 percent O <sub>2</sub> , dry basis.
2. 4SRB stationary RICE	a. Reduce formaldehyde emissions	i. Select the sampling port location and the number of traverse points; and	(1) Method 1 or 1A of 40 CFR part 60, appendix A §63.7(d)(1)(i)	(a) Sampling sites must be located at the inlet and outlet of the control device.
		ii. Measure O <sub>2</sub> at the inlet and outlet of the control device; and	(1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A, or ASTM Method D6522–00m (2005)	(a) Measurements to determine O <sub>2</sub> concentration must be made at the same time as the measurements for formaldehyde concentration.
		iii. Measure moisture content at the inlet and outlet of the control device; and	(1) Method 4 of 40 CFR part 60, appendix A, or Test Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348–03	(a) Measurements to determine moisture content must be made at the same time and location as the measurements for formaldehyde concentration.
		iv. Measure formaldehyde at the inlet and the outlet of the control device	(1) Method 320 or 323 of 40 CFR part 63, appendix A; or ASTM D6348–03, <sup>c</sup> provided in ASTM D6348–03 Annex A5 (Analyte Spiking Technique), the percent R must be greater than or equal to 70 and less than or equal to 130	(a) Formaldehyde concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs.
3. Stationary RICE	a. Limit the concentration of formaldehyde or	i. Select the sampling port location and the	(1) Method 1 or 1A of 40 CFR part 60, appendix A §63.7(d)(1)(i)	(a) If using a control device, the sampling site must be located at the outlet of the

For each . . .	Complying with the requirement to . . .	You must . . .	Using . . .	According to the following requirements . . .
	CO in the stationary RICE exhaust	number of traverse points; and		control device.
		ii. Determine the O <sub>2</sub> concentration of the stationary RICE exhaust at the sampling port location; and	(1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A, or ASTM Method D6522-00 (2005)	(a) Measurements to determine O <sub>2</sub> concentration must be made at the same time and location as the measurements for formaldehyde concentration.
		iii. Measure moisture content of the stationary RICE exhaust at the sampling port location; and	(1) Method 4 of 40 CFR part 60, appendix A, or Test Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348-03	(a) Measurements to determine moisture content must be made at the same time and location as the measurements for formaldehyde concentration.
		iv. Measure formaldehyde at the exhaust of the stationary RICE; or	(1) Method 320 or 323 of 40 CFR part 63, appendix A; or ASTM D6348-03, <sup>c</sup> provided in ASTM D6348-03 Annex A5 (Analyte Spiking Technique), the percent R must be greater than or equal to 70 and less than or equal to 130	(a) Formaldehyde concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs.
		v. Measure CO at the exhaust of the stationary RICE	(1) Method 10 of 40 CFR part 60, appendix A, ASTM Method D6522-00 (2005), <sup>a</sup> Method 320 of 40 CFR part 63, appendix A, or ASTM D6348-03	(a) CO Concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour longer runs.

<sup>a</sup>You may also use Methods 3A and 10 as options to ASTM-D6522-00 (2005). You may obtain a copy of ASTM-D6522-00 (2005) from at least one of the following addresses: American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, or University Microfilms International, 300 North Zeeb Road, Ann Arbor, MI 48106. ASTM-D6522-00 (2005) may be used to test both CI and SI stationary RICE.

<sup>b</sup>You may also use Method 320 of 40 CFR part 63, appendix A, or ASTM D6348-03.

<sup>c</sup>You may obtain a copy of ASTM-D6348-03 from at least one of the following addresses: American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, or University Microfilms International, 300 North Zeeb Road, Ann Arbor, MI 48106.

[75 FR 51597, Aug. 20, 2010]

**Table 5 to Subpart ZZZZ of Part 63—Initial Compliance With Emission Limitations and Operating Limitations**

As stated in §§63.6612, 63.6625 and 63.6630, you must initially comply with the emission and operating limitations as required by the following:

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if. . .
<p>1. New or reconstructed non-emergency 2SLB stationary RICE &gt;500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, non-emergency stationary CI RICE &gt;500 HP located at a major source of HAP, existing non-emergency stationary CI RICE &gt;500 HP located at an area source of HAP, and existing non-emergency 4SLB stationary RICE &gt;500 HP located at an area source of HAP that are operated more than 24 hours per calendar year</p>	<p>a. Reduce CO emissions and using oxidation catalyst, and using a CPMS</p>	<p>i. The average reduction of emissions of CO determined from the initial performance test achieves the required CO percent reduction; and ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in §63.6625(b); and iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.</p>
<p>2. Non-emergency stationary CI RICE &gt;500 HP located at a major source of HAP, existing non-emergency stationary CI RICE &gt;500 HP located at an area source of HAP, and existing non-emergency 4SLB stationary RICE &gt;500 HP located at an area source of HAP that are operated more than 24 hours per calendar year</p>	<p>a. Limit the concentration of CO, using oxidation catalyst, and using a CPMS</p>	<p>i. The average CO concentration determined from the initial performance test is less than or equal to the CO emission limitation; and ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in §63.6625(b); and iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.</p>
<p>3. New or reconstructed non-emergency 2SLB stationary RICE &gt;500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, non-emergency stationary CI RICE &gt;500 HP located at a major source of HAP, existing non-emergency stationary CI RICE &gt;500 HP located at an area source of HAP, and existing non-emergency 4SLB stationary RICE &gt;500 HP located at an area source of HAP that are operated more than 24 hours per calendar year</p>	<p>a. Reduce CO emissions and not using oxidation catalyst</p>	<p>i. The average reduction of emissions of CO determined from the initial performance test achieves the required CO percent reduction; and ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in §63.6625(b); and iii. You have recorded the approved operating parameters (if any) during the initial performance test.</p>
<p>4. Non-emergency stationary CI RICE &gt;500 HP located at a major source of HAP, existing non-emergency stationary CI RICE &gt;500 HP located at an area source of HAP, and existing non-emergency 4SLB stationary RICE &gt;500 HP located at an area source of HAP that are operated more than 24 hours per calendar year</p>	<p>a. Limit the concentration of CO, and not using oxidation catalyst</p>	<p>i. The average CO concentration determined from the initial performance test is less than or equal to the CO emission limitation; and ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the</p>

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if. . .
		requirements in §63.6625(b); and iii. You have recorded the approved operating parameters (if any) during the initial performance test.
5. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, non-emergency stationary CI RICE >500 HP located at a major source of HAP, existing non-emergency stationary CI RICE >500 HP located at an area source of HAP, and existing non-emergency 4SLB stationary RICE >500 HP located at an area source of HAP that are operated more than 24 hours per calendar year	a. Reduce CO emissions, and using a CEMS	i. You have installed a CEMS to continuously monitor CO and either O <sub>2</sub> or CO <sub>2</sub> at both the inlet and outlet of the oxidation catalyst according to the requirements in §63.6625(a); and ii. You have conducted a performance evaluation of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B; and iii. The average reduction of CO calculated using §63.6620 equals or exceeds the required percent reduction. The initial test comprises the first 4-hour period after successful validation of the CEMS. Compliance is based on the average percent reduction achieved during the 4-hour period.
6. Non-emergency stationary CI RICE >500 HP located at a major source of HAP, existing non-emergency stationary CI RICE >500 HP located at an area source of HAP, and existing non-emergency 4SLB stationary RICE >500 HP located at an area source of HAP that are operated more than 24 hours per calendar year	a. Limit the concentration of CO, and using a CEMS	i. You have installed a CEMS to continuously monitor CO and either O <sub>2</sub> or CO <sub>2</sub> at the outlet of the oxidation catalyst according to the requirements in §63.6625(a); and ii. You have conducted a performance evaluation of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B; and
		iii. The average concentration of CO calculated using §63.6620 is less than or equal to the CO emission limitation. The initial test comprises the first 4-hour period after successful validation of the CEMS. Compliance is based on the average concentration measured during the 4-hour period.
7. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP, and existing non-emergency 4SRB stationary RICE >500 HP located at an area source of HAP that are operated more than 24 hours per calendar year	a. Reduce formaldehyde emissions and using NSCR	i. The average reduction of emissions of formaldehyde determined from the initial performance test is equal to or greater than the required formaldehyde percent reduction; and ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in §63.6625(b); and
		iii. You have recorded the catalyst

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if. . .
		pressure drop and catalyst inlet temperature during the initial performance test.
8. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP, and existing non-emergency 4SRB stationary RICE >500 HP located at an area source of HAP that are operated more than 24 hours per calendar year	a. Reduce formaldehyde emissions and not using NSCR	i. The average reduction of emissions of formaldehyde determined from the initial performance test is equal to or greater than the required formaldehyde percent reduction; and ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in §63.6625(b); and
		iii. You have recorded the approved operating parameters (if any) during the initial performance test.
9. Existing non-emergency 4SRB stationary RICE >500 HP located at an area source of HAP that are operated more than 24 hours per calendar year	a. Limit the concentration of formaldehyde and not using NSCR	i. The average formaldehyde concentration determined from the initial performance test is less than or equal to the formaldehyde emission limitation; and
		ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in §63.6625(b); and
		iii. You have recorded the approved operating parameters (if any) during the initial performance test.
10. New or reconstructed non-emergency stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE 250≤HP≤500 located at a major source of HAP, and existing non-emergency 4SRB stationary RICE >500 HP	a. Limit the concentration of formaldehyde in the stationary RICE exhaust and using oxidation catalyst or NSCR	i. The average formaldehyde concentration, corrected to 15 percent O <sub>2</sub> , dry basis, from the three test runs is less than or equal to the formaldehyde emission limitation; and ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in §63.6625(b); and
		iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.
11. New or reconstructed non-emergency stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE 250≤HP≤500 located at a major source of	a. Limit the concentration of formaldehyde in the stationary RICE exhaust and not using	i. The average formaldehyde concentration, corrected to 15 percent O <sub>2</sub> , dry basis, from the three test runs is less than or equal to the formaldehyde emission limitation; and

<b>For each . . .</b>	<b>Complying with the requirement to . . .</b>	<b>You have demonstrated initial compliance if . . .</b>
HAP, and existing non-emergency 4SRB stationary RICE >500 HP	oxidation catalyst or NSCR	ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in §63.6625(b); and
		iii. You have recorded the approved operating parameters (if any) during the initial performance test.
12. Existing non-emergency stationary RICE $100 \leq \text{HP} \leq 500$ located at a major source of HAP, and existing non-emergency stationary CI RICE $300 < \text{HP} \leq 500$ located at an area source of HAP	a. Reduce CO or formaldehyde emissions	i. The average reduction of emissions of CO or formaldehyde, as applicable determined from the initial performance test is equal to or greater than the required CO or formaldehyde, as applicable, percent reduction.
13. Existing non-emergency stationary RICE $100 \leq \text{HP} \leq 500$ located at a major source of HAP, and existing non-emergency stationary CI RICE $300 < \text{HP} \leq 500$ located at an area source of HAP	a. Limit the concentration of formaldehyde or CO in the stationary RICE exhaust	i. The average formaldehyde or CO concentration, as applicable, corrected to 15 percent O <sub>2</sub> , dry basis, from the three test runs is less than or equal to the formaldehyde or CO emission limitation, as applicable.

[76 FR 12867, Mar. 9, 2011]

**Table 6 to Subpart ZZZZ of Part 63—Continuous Compliance With Emission Limitations, Operating Limitations, Work Practices, and Management Practices**

As stated in §63.6640, you must continuously comply with the emissions and operating limitations and work or management practices as required by the following:

<b>For each . . .</b>	<b>Complying with the requirement to . . .</b>	<b>You must demonstrate continuous compliance by . . .</b>
1. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE $\geq 250$ HP located at a major source of HAP, and new or reconstructed non-emergency CI stationary RICE >500 HP located at a major source of HAP	a. Reduce CO emissions and using an oxidation catalyst, and using a CPMS	i. Conducting semiannual performance tests for CO to demonstrate that the required CO percent reduction is achieved; <sup>a</sup> and ii. Collecting the catalyst inlet temperature data according to §63.6625(b); and iii. Reducing these data to 4-hour rolling averages; and iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and
		v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
2. New or reconstructed non-emergency	a. Reduce CO emissions	i. Conducting semiannual performance

<b>For each . . .</b>	<b>Complying with the requirement to . . .</b>	<b>You must demonstrate continuous compliance by . . .</b>
2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, and new or reconstructed non-emergency CI stationary RICE >500 HP located at a major source of HAP	and not using an oxidation catalyst, and using a CPMS	tests for CO to demonstrate that the required CO percent reduction is achieved; <sup>a</sup> and ii. Collecting the approved operating parameter (if any) data according to §63.6625(b); and iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.
3. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, new or reconstructed non-emergency stationary CI RICE >500 HP located at a major source of HAP, existing non-emergency stationary CI RICE >500 HP, existing non-emergency 4SLB stationary RICE >500 HP located at an area source of HAP that are operated more than 24 hours per calendar year	a. Reduce CO emissions or limit the concentration of CO in the stationary RICE exhaust, and using a CEMS	i. Collecting the monitoring data according to §63.6625(a), reducing the measurements to 1-hour averages, calculating the percent reduction or concentration of CO emissions according to §63.6620; and ii. Demonstrating that the catalyst achieves the required percent reduction of CO emissions over the 4-hour averaging period, or that the emission remain at or below the CO concentration limit; and iii. Conducting an annual RATA of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B, as well as daily and periodic data quality checks in accordance with 40 CFR part 60, appendix F, procedure 1.
4. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP	a. Reduce formaldehyde emissions and using NSCR	i. Collecting the catalyst inlet temperature data according to §63.6625(b); and
		ii. Reducing these data to 4-hour rolling averages; and
		iii. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and
		iv. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
5. Non-emergency 4SRB stationary RICE >500 HP located at a major source	a. Reduce formaldehyde emissions and not using	i. Collecting the approved operating parameter (if any) data according to

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
of HAP	NSCR	§63.6625(b); and ii. Reducing these data to 4-hour rolling averages; and
		iii. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.
6. Non-emergency 4SRB stationary RICE with a brake HP $\geq 5,000$ located at a major source of HAP	a. Reduce formaldehyde emissions	Conducting semiannual performance tests for formaldehyde to demonstrate that the required formaldehyde percent reduction is achieved. <sup>a</sup>
7. New or reconstructed non-emergency stationary RICE $>500$ HP located at a major source of HAP and new or reconstructed non-emergency 4SLB stationary RICE $250 \leq \text{HP} \leq 500$ located at a major source of HAP	a. Limit the concentration of formaldehyde in the stationary RICE exhaust and using oxidation catalyst or NSCR	i. Conducting semiannual performance tests for formaldehyde to demonstrate that your emissions remain at or below the formaldehyde concentration limit; <sup>a</sup> and ii. Collecting the catalyst inlet temperature data according to §63.6625(b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and
		v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
8. New or reconstructed non-emergency stationary RICE $>500$ HP located at a major source of HAP and new or reconstructed non-emergency 4SLB stationary RICE $250 \leq \text{HP} \leq 500$ located at a major source of HAP	a. Limit the concentration of formaldehyde in the stationary RICE exhaust and not using oxidation catalyst or NSCR	i. Conducting semiannual performance tests for formaldehyde to demonstrate that your emissions remain at or below the formaldehyde concentration limit; <sup>a</sup> and ii. Collecting the approved operating parameter (if any) data according to §63.6625(b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
		test.
<p>9. Existing emergency and black start stationary RICE ≤500 HP located at a major source of HAP, existing non-emergency stationary RICE &lt;100 HP located at a major source of HAP, existing emergency and black start stationary RICE located at an area source of HAP, existing non-emergency stationary CI RICE ≤300 HP located at an area source of HAP, existing non-emergency 2SLB stationary RICE located at an area source of HAP, existing non-emergency landfill or digester gas stationary SI RICE located at an area source of HAP, existing non-emergency 4SLB and 4SRB stationary RICE ≤500 HP located at an area source of HAP, existing non-emergency 4SLB and 4SRB stationary RICE &gt;500 HP located at an area source of HAP that operate 24 hours or less per calendar year</p>	<p>a. Work or Management practices</p>	<p>i. Operating and maintaining the stationary RICE according to the manufacturer's emission-related operation and maintenance instructions; or ii. Develop and follow your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.</p>
<p>10. Existing stationary CI RICE &gt;500 HP that are not limited use stationary RICE, and existing 4SLB and 4SRB stationary RICE &gt;500 HP located at an area source of HAP that operate more than 24 hours per calendar year and are not limited use stationary RICE</p>	<p>a. Reduce CO or formaldehyde emissions, or limit the concentration of formaldehyde or CO in the stationary RICE exhaust, and using oxidation catalyst or NSCR</p>	<p>i. Conducting performance tests every 8,760 hours or 3 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and</p>
		<p>ii. Collecting the catalyst inlet temperature data according to §63.6625(b); and</p>
		<p>iii. Reducing these data to 4-hour rolling averages; and</p>
		<p>iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and</p>
		<p>v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.</p>
<p>11. Existing stationary CI RICE &gt;500 HP</p>	<p>a. Reduce CO or</p>	<p>i. Conducting performance tests every</p>

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
that are not limited use stationary RICE, and existing 4SLB and 4SRB stationary RICE >500 HP located at an area source of HAP that operate more than 24 hours per calendar year and are not limited use stationary RICE	formaldehyde emissions, or limit the concentration of formaldehyde or CO in the stationary RICE exhaust, and not using oxidation catalyst or NSCR	8,760 hours or 3 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and
		ii. Collecting the approved operating parameter (if any) data according to §63.6625(b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.
12. Existing limited use CI stationary RICE >500 HP and existing limited use 4SLB and 4SRB stationary RICE >500 HP located at an area source of HAP that operate more than 24 hours per calendar year	a. Reduce CO or formaldehyde emissions or limit the concentration of formaldehyde or CO in the stationary RICE exhaust, and using an oxidation catalyst or NSCR	i. Conducting performance tests every 8,760 hours or 5 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and
		ii. Collecting the catalyst inlet temperature data according to §63.6625(b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and
		v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
13. Existing limited use CI stationary RICE >500 HP and existing limited use 4SLB and 4SRB stationary RICE >500 HP located at an area source of HAP	a. Reduce CO or formaldehyde emissions or limit the concentration of formaldehyde or CO in	i. Conducting performance tests every 8,760 hours or 5 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
that operate more than 24 hours per calendar year	the stationary RICE exhaust, and not using an oxidation catalyst or NSCR	required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and
		ii. Collecting the approved operating parameter (if any) data according to §63.6625(b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.

<sup>a</sup>After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests. [76 FR 12870, Mar. 9, 2011]

**Table 7 to Subpart ZZZZ of Part 63—Requirements for Reports**

As stated in §63.6650, you must comply with the following requirements for reports:

For each ...	You must submit a ...	The report must contain ...	You must submit the report ...
1. Existing non-emergency, non-black start stationary RICE 100≤HP≤500 located at a major source of HAP; existing non-emergency, non-black start stationary CI RICE >500 HP located at a major source of HAP; existing non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP; existing non-emergency, non-black start stationary CI RICE >300 HP located at an area source of HAP; existing non-emergency, non-black start 4SLB and 4SRB stationary RICE >500 HP located at an area source of HAP and operated more than 24 hours per calendar year; new or reconstructed non-emergency stationary RICE >500 HP located at a major source of HAP; and new or reconstructed non-emergency 4SLB stationary	Compliance report	a. If there are no deviations from any emission limitations or operating limitations that apply to you, a statement that there were no deviations from the emission limitations or operating limitations during the reporting period. If there were no periods during which the CMS, including CEMS and CPMS, was out-of-control, as specified in §63.8(c)(7), a statement that there were not periods during which the CMS was out-of-control during the reporting period; or b. If you had a deviation from any emission limitation or operating limitation during the reporting period, the information in §63.6650(d). If there were periods during which the CMS, including CEMS and CPMS, was out-of-control, as specified in §63.8(c)(7), the information in §63.6650(e); or	i. Semiannually according to the requirements in §63.6650(b)(1)–(5) for engines that are not limited use stationary RICE subject to numerical emission limitations; and ii. Annually according to the requirements in §63.6650(b)(6)–(9) for engines that are limited use stationary RICE subject to numerical emission limitations. i. Semiannually according to the requirements in §63.6650(b). i. Semiannually according to the requirements in §63.6650(b).

RICE 250≤HP≤500 located at a major source of HAP		c. If you had a malfunction during the reporting period, the information in §63.6650(c)(4)	
2. New or reconstructed non-emergency stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis	Report	a. The fuel flow rate of each fuel and the heating values that were used in your calculations, and you must demonstrate that the percentage of heat input provided by landfill gas or digester gas, is equivalent to 10 percent or more of the gross heat input on an annual basis; and	i. Annually, according to the requirements in §63.6650.
		b. The operating limits provided in your federally enforceable permit, and any deviations from these limits; and i. See item 2.a.i.	
		c. Any problems or errors suspected with the meters. i. See item 2.a.i.	

[75 FR 51603, Aug. 20, 2010]

**Table 8 to Subpart ZZZZ of Part 63—Applicability of General Provisions to Subpart ZZZZ.**

As stated in §63.6665, you must comply with the following applicable general provisions.

General provisions citation	Subject of citation	Applies to subpart	Explanation
§63.1	General applicability of the General Provisions	Yes.	
§63.2	Definitions	Yes	Additional terms defined in §63.6675.
§63.3	Units and abbreviations	Yes.	
§63.4	Prohibited activities and circumvention	Yes.	
§63.5	Construction and reconstruction	Yes.	
§63.6(a)	Applicability	Yes.	
§63.6(b)(1)–(4)	Compliance dates for new and reconstructed sources	Yes.	
§63.6(b)(5)	Notification	Yes.	
§63.6(b)(6)	[Reserved]		
§63.6(b)(7)	Compliance dates for new and reconstructed area sources that become major sources	Yes.	

<b>General provisions citation</b>	<b>Subject of citation</b>	<b>Applies to subpart</b>	<b>Explanation</b>
§63.6(c)(1)–(2)	Compliance dates for existing sources	Yes.	
§63.6(c)(3)–(4)	[Reserved]		
§63.6(c)(5)	Compliance dates for existing area sources that become major sources	Yes.	
§63.6(d)	[Reserved]		
§63.6(e)	Operation and maintenance	No.	
§63.6(f)(1)	Applicability of standards	No.	
§63.6(f)(2)	Methods for determining compliance	Yes.	
§63.6(f)(3)	Finding of compliance	Yes.	
§63.6(g)(1)–(3)	Use of alternate standard	Yes.	
§63.6(h)	Opacity and visible emission standards	No	Subpart ZZZZ does not contain opacity or visible emission standards.
§63.6(i)	Compliance extension procedures and criteria	Yes.	
§63.6(j)	Presidential compliance exemption	Yes.	
§63.7(a)(1)–(2)	Performance test dates	Yes	Subpart ZZZZ contains performance test dates at §§63.6610, 63.6611, and 63.6612.
§63.7(a)(3)	CAA section 114 authority	Yes.	
§63.7(b)(1)	Notification of performance test	Yes	Except that §63.7(b)(1) only applies as specified in §63.6645.
§63.7(b)(2)	Notification of rescheduling	Yes	Except that §63.7(b)(2) only applies as specified in §63.6645.
§63.7(c)	Quality assurance/test plan	Yes	Except that §63.7(c) only applies as specified in §63.6645.
§63.7(d)	Testing facilities	Yes.	
§63.7(e)(1)	Conditions for conducting performance tests	No.	Subpart ZZZZ specifies conditions for conducting performance tests at §63.6620.
§63.7(e)(2)	Conduct of performance tests and reduction of data	Yes	Subpart ZZZZ specifies test methods at §63.6620.
§63.7(e)(3)	Test run duration	Yes.	
§63.7(e)(4)	Administrator may require other	Yes.	

General provisions citation	Subject of citation	Applies to subpart	Explanation
	testing under section 114 of the CAA		
§63.7(f)	Alternative test method provisions	Yes.	
§63.7(g)	Performance test data analysis, recordkeeping, and reporting	Yes.	
§63.7(h)	Waiver of tests	Yes.	
§63.8(a)(1)	Applicability of monitoring requirements	Yes	Subpart ZZZZ contains specific requirements for monitoring at §63.6625.
§63.8(a)(2)	Performance specifications	Yes.	
§63.8(a)(3)	[Reserved]		
§63.8(a)(4)	Monitoring for control devices	No.	
§63.8(b)(1)	Monitoring	Yes.	
§63.8(b)(2)–(3)	Multiple effluents and multiple monitoring systems	Yes.	
§63.8(c)(1)	Monitoring system operation and maintenance	Yes.	
§63.8(c)(1)(i)	Routine and predictable SSM	Yes.	
§63.8(c)(1)(ii)	SSM not in Startup Shutdown Malfunction Plan	Yes.	
§63.8(c)(1)(iii)	Compliance with operation and maintenance requirements	Yes.	
§63.8(c)(2)–(3)	Monitoring system installation	Yes.	
§63.8(c)(4)	Continuous monitoring system (CMS) requirements	Yes	Except that subpart ZZZZ does not require Continuous Opacity Monitoring System (COMS).
§63.8(c)(5)	COMS minimum procedures	No	Subpart ZZZZ does not require COMS.
§63.8(c)(6)–(8)	CMS requirements	Yes	Except that subpart ZZZZ does not require COMS.
§63.8(d)	CMS quality control	Yes.	
§63.8(e)	CMS performance evaluation	Yes	Except for §63.8(e)(5)(ii), which applies to COMS.
		Except that §63.8(e) only applies as specified in §63.6645.	

<b>General provisions citation</b>	<b>Subject of citation</b>	<b>Applies to subpart</b>	<b>Explanation</b>
§63.8(f)(1)–(5)	Alternative monitoring method	Yes	Except that §63.8(f)(4) only applies as specified in §63.6645.
§63.8(f)(6)	Alternative to relative accuracy test	Yes	Except that §63.8(f)(6) only applies as specified in §63.6645.
§63.8(g)	Data reduction	Yes	Except that provisions for COMS are not applicable. Averaging periods for demonstrating compliance are specified at §§63.6635 and 63.6640.
§63.9(a)	Applicability and State delegation of notification requirements	Yes.	
§63.9(b)(1)–(5)	Initial notifications	Yes	Except that §63.9(b)(3) is reserved.
		Except that §63.9(b) only applies as specified in §63.6645.	
§63.9(c)	Request for compliance extension	Yes	Except that §63.9(c) only applies as specified in §63.6645.
§63.9(d)	Notification of special compliance requirements for new sources	Yes	Except that §63.9(d) only applies as specified in §63.6645.
§63.9(e)	Notification of performance test	Yes	Except that §63.9(e) only applies as specified in §63.6645.
§63.9(f)	Notification of visible emission (VE)/opacity test	No	Subpart ZZZZ does not contain opacity or VE standards.
§63.9(g)(1)	Notification of performance evaluation	Yes	Except that §63.9(g) only applies as specified in §63.6645.
§63.9(g)(2)	Notification of use of COMS data	No	Subpart ZZZZ does not contain opacity or VE standards.
§63.9(g)(3)	Notification that criterion for alternative to RATA is exceeded	Yes	If alternative is in use.
		Except that §63.9(g) only applies as specified in §63.6645.	
§63.9(h)(1)–(6)	Notification of compliance status	Yes	Except that notifications for sources using a CEMS are due 30 days after completion of performance evaluations. §63.9(h)(4) is reserved.

<b>General provisions citation</b>	<b>Subject of citation</b>	<b>Applies to subpart</b>	<b>Explanation</b>
			Except that §63.9(h) only applies as specified in §63.6645.
§63.9(i)	Adjustment of submittal deadlines	Yes.	
§63.9(j)	Change in previous information	Yes.	
§63.10(a)	Administrative provisions for recordkeeping/reporting	Yes.	
§63.10(b)(1)	Record retention	Yes.	
§63.10(b)(2)(i)–(v)	Records related to SSM	No.	
§63.10(b)(2)(vi)–(xi)	Records	Yes.	
§63.10(b)(2)(xii)	Record when under waiver	Yes.	
§63.10(b)(2)(xiii)	Records when using alternative to RATA	Yes	For CO standard if using RATA alternative.
§63.10(b)(2)(xiv)	Records of supporting documentation	Yes.	
§63.10(b)(3)	Records of applicability determination	Yes.	
§63.10(c)	Additional records for sources using CEMS	Yes	Except that §63.10(c)(2)–(4) and (9) are reserved.
§63.10(d)(1)	General reporting requirements	Yes.	
§63.10(d)(2)	Report of performance test results	Yes.	
§63.10(d)(3)	Reporting opacity or VE observations	No	Subpart ZZZZ does not contain opacity or VE standards.
§63.10(d)(4)	Progress reports	Yes.	
§63.10(d)(5)	Startup, shutdown, and malfunction reports	No.	
§63.10(e)(1) and (2)(i)	Additional CMS Reports	Yes.	
§63.10(e)(2)(ii)	COMS-related report	No	Subpart ZZZZ does not require COMS.
§63.10(e)(3)	Excess emission and parameter exceedances reports	Yes.	Except that §63.10(e)(3)(i) (C) is reserved.
§63.10(e)(4)	Reporting COMS data	No	Subpart ZZZZ does not require COMS.
§63.10(f)	Waiver for recordkeeping/reporting	Yes.	

<b>General provisions citation</b>	<b>Subject of citation</b>	<b>Applies to subpart</b>	<b>Explanation</b>
§63.11	Flares	No.	
§63.12	State authority and delegations	Yes.	
§63.13	Addresses	Yes.	
§63.14	Incorporation by reference	Yes.	
§63.15	Availability of information	Yes.	

[75 FR 9688, Mar. 3, 2010]

**Indiana Department of Environmental Management  
Office of Air Quality**

**Attachment B**

**Subpart GG — Standards of Performance for Stationary Gas Turbines**

**Source Description and Location**

<b>Source Name:</b>	<b>Indiana Municipal Power Agency – Anderson Station</b>
<b>Source Location:</b>	<b>6035 Park Road, Anderson, Indiana 46011</b>
<b>County:</b>	<b>Madison</b>
<b>SIC Code:</b>	<b>4911</b>
<b>Permit Renewal No.:</b>	<b>T 095-30940-00051</b>
<b>Permit Reviewer:</b>	<b>Anh Nguyen</b>

**Complete Text of 40 CFR 60, Subpart GG**

**Subpart GG — Standards of Performance for Stationary Gas Turbines**

**§ 60.330 Applicability and designation of affected facility.**

(a) The provisions of this subpart are applicable to the following affected facilities: All stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules (10 million Btu) per hour, based on the lower heating value of the fuel fired.

(b) Any facility under paragraph (a) of this section which commences construction, modification, or reconstruction after October 3, 1977, is subject to the requirements of this part except as provided in paragraphs (e) and (j) of §60.332.

[44 FR 52798, Sept. 10, 1979, as amended at 52 FR 42434, Nov. 5, 1987; 65 FR 61759, Oct. 17, 2000]

**§ 60.331 Definitions.**

As used in this subpart, all terms not defined herein shall have the meaning given them in the Act and in subpart A of this part.

(a) *Stationary gas turbine* means any simple cycle gas turbine, regenerative cycle gas turbine or any gas turbine portion of a combined cycle steam/electric generating system that is not self propelled. It may, however, be mounted on a vehicle for portability.

(b) *Simple cycle gas turbine* means any stationary gas turbine which does not recover heat from the gas turbine exhaust gases to preheat the inlet combustion air to the gas turbine, or which does not recover heat from the gas turbine exhaust gases to heat water or generate steam.

(c) *Regenerative cycle gas turbine* means any stationary gas turbine which recovers heat from the gas turbine exhaust gases to preheat the inlet combustion air to the gas turbine.

(d) *Combined cycle gas turbine* means any stationary gas turbine which recovers heat from the gas turbine exhaust gases to heat water or generate steam.

(e) *Emergency gas turbine* means any stationary gas turbine which operates as a mechanical or electrical power source only when the primary power source for a facility has been rendered inoperable by an emergency situation.

(f) *Ice fog* means an atmospheric suspension of highly reflective ice crystals.

(g) *ISO standard day conditions* means 288 degrees Kelvin, 60 percent relative humidity and 101.3 kilopascals pressure.

(h) *Efficiency* means the gas turbine manufacturer's rated heat rate at peak load in terms of heat input per unit of power output based on the lower heating value of the fuel.

- (i) *Peak load* means 100 percent of the manufacturer's design capacity of the gas turbine at ISO standard day conditions.
- (j) *Base load* means the load level at which a gas turbine is normally operated.
- (k) *Fire-fighting turbine* means any stationary gas turbine that is used solely to pump water for extinguishing fires.
- (l) *Turbines employed in oil/gas production or oil/gas transportation* means any stationary gas turbine used to provide power to extract crude oil/natural gas from the earth or to move crude oil/natural gas, or products refined from these substances through pipelines.
- (m) A *Metropolitan Statistical Area* or *MSA* as defined by the Department of Commerce.
- (n) *Offshore platform gas turbines* means any stationary gas turbine located on a platform in an ocean.
- (o) *Garrison facility* means any permanent military installation.
- (p) *Gas turbine model* means a group of gas turbines having the same nominal air flow, combustor inlet pressure, combustor inlet temperature, firing temperature, turbine inlet temperature and turbine inlet pressure.
- (q) *Electric utility stationary gas turbine* means any stationary gas turbine constructed for the purpose of supplying more than one-third of its potential electric output capacity to any utility power distribution system for sale.
- (r) *Emergency fuel* is a fuel fired by a gas turbine only during circumstances, such as natural gas supply curtailment or breakdown of delivery system, that make it impossible to fire natural gas in the gas turbine.
- (s) *Unit operating hour* means a clock hour during which any fuel is combusted in the affected unit. If the unit combusts fuel for the entire clock hour, it is considered to be a full unit operating hour. If the unit combusts fuel for only part of the clock hour, it is considered to be a partial unit operating hour.
- (t) *Excess emissions* means a specified averaging period over which either:
- (1) The NO<sub>x</sub> emissions are higher than the applicable emission limit in §60.332;
  - (2) The total sulfur content of the fuel being combusted in the affected facility exceeds the limit specified in §60.333; or
  - (3) The recorded value of a particular monitored parameter is outside the acceptable range specified in the parameter monitoring plan for the affected unit.
- (u) *Natural gas* means a naturally occurring fluid mixture of hydrocarbons ( e.g. , methane, ethane, or propane) produced in geological formations beneath the Earth's surface that maintains a gaseous state at standard atmospheric temperature and pressure under ordinary conditions. Natural gas contains 20.0 grains or less of total sulfur per 100 standard cubic feet. Equivalents of this in other units are as follows: 0.068 weight percent total sulfur, 680 parts per million by weight (ppmw) total sulfur, and 338 parts per million by volume (ppmv) at 20 degrees Celsius total sulfur. Additionally, natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 950 and 1100 British thermal units (Btu) per standard cubic foot. Natural gas does not include the following gaseous fuels: landfill gas, digester gas, refinery gas, sour gas, blast furnace gas, coal-derived gas, producer gas, coke oven gas, or any gaseous fuel produced in a process which might result in highly variable sulfur content or heating value.
- (v) *Duct burner* means a device that combusts fuel and that is placed in the exhaust duct from another source, such as a stationary gas turbine, internal combustion engine, kiln, etc., to allow the firing of additional fuel to heat the exhaust gases before the exhaust gases enter a heat recovery steam generating unit.
- (w) *Lean premix stationary combustion turbine* means any stationary combustion turbine where the air and fuel are thoroughly mixed to form a lean mixture for combustion in the combustor. Mixing may occur before or in the combustion chamber. A unit which is capable of operating in both lean premix and diffusion flame modes is considered a lean premix stationary combustion turbine when it is in the lean premix mode, and it is considered a diffusion flame stationary combustion turbine when it is in the diffusion flame mode.
- (x) *Diffusion flame stationary combustion turbine* means any stationary combustion turbine where fuel and air are injected at the combustor and are mixed only by diffusion prior to ignition. A unit which is capable of operating in both lean premix and diffusion flame modes is considered a lean premix stationary combustion turbine when it is in the lean premix mode, and it is considered a diffusion flame stationary combustion turbine when it is in the diffusion flame mode.

(y) *Unit operating day* means a 24-hour period between 12:00 midnight and the following midnight during which any fuel is combusted at any time in the unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period.

[44 FR 52798, Sept. 10, 1979, as amended at 47 FR 3770, Jan. 27, 1982; 65 FR 61759, Oct. 17, 2000; 69 FR 41359, July 8, 2004]

**§ 60.332 Standard for nitrogen oxides.**

(a) On and after the date on which the performance test required by §60.8 is completed, every owner or operator subject to the provisions of this subpart as specified in paragraphs (b), (c), and (d) of this section shall comply with one of the following, except as provided in paragraphs (e), (f), (g), (h), (i), (j), (k), and (l) of this section.

(1) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine, any gases which contain nitrogen oxides in excess of:

$$STD = 0.0075 \frac{(14.4)}{Y} + F$$

where:

STD = allowable ISO corrected (if required as given in §60.335(b)(1)) NO<sub>x</sub> emission concentration (percent by volume at 15 percent oxygen and on a dry basis),

Y = manufacturer's rated heat rate at manufacturer's rated load (kilojoules per watt hour) or, actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility.

The value of Y shall not exceed 14.4 kilojoules per watt hour, and

F = NO<sub>x</sub> emission allowance for fuel-bound nitrogen as defined in paragraph (a)(4) of this section.

(2) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine, any gases which contain nitrogen oxides in excess of:

$$STD = 0.0150 \frac{(14.4)}{Y} + F$$

where:

STD = allowable ISO corrected (if required as given in §60.335(b)(1)) NO<sub>x</sub> emission concentration (percent by volume at 15 percent oxygen and on a dry basis),

Y = manufacturer's rated heat rate at manufacturer's rated peak load (kilojoules per watt hour), or actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility.

The value of Y shall not exceed 14.4 kilojoules per watt hour, and

F = NO<sub>x</sub> emission allowance for fuel-bound nitrogen as defined in paragraph (a)(4) of this section.

(3) The use of F in paragraphs (a)(1) and (2) of this section is optional. That is, the owner or operator may choose to apply a NO<sub>x</sub> allowance for fuel-bound nitrogen and determine the appropriate F-value in accordance with paragraph (a)(4) of this section or may accept an F-value of zero.

(4) If the owner or operator elects to apply a NO<sub>x</sub> emission allowance for fuel-bound nitrogen, F shall be defined according to the nitrogen content of the fuel during the most recent performance test required under §60.8 as follows:

Fuel-bound nitrogen (percent by weight)	F (NO <sub>x</sub> percent by volume)
N ≤ .015	0
0.015 < N ≤ 0.1	0.04 (N)
0.1 < N ≤ 0.25	0.004+0.0067(N-0.1)
N > 0.25	0.005

Where:

N = the nitrogen content of the fuel (percent by weight).

or:

Manufacturers may develop and submit to EPA custom fuel-bound nitrogen allowances for each gas turbine model they manufacture. These fuel-bound nitrogen allowances shall be substantiated with data and must be approved for use by the Administrator before the initial performance test required by §60.8. Notices of approval of custom fuel-bound nitrogen allowances will be published in the Federal Register.

(b) Electric utility stationary gas turbines with a heat input at peak load greater than 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired shall comply with the provisions of paragraph (a)(1) of this section.

(c) Stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules per hour (10 million Btu/hour) but less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired, shall comply with the provisions of paragraph (a)(2) of this section.

(d) Stationary gas turbines with a manufacturer's rated base load at ISO conditions of 30 megawatts or less except as provided in §60.332(b) shall comply with paragraph (a)(2) of this section.

(e) Stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules per hour (10 million Btu/hour) but less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired and that have commenced construction prior to October 3, 1982 are exempt from paragraph (a) of this section.

(f) Stationary gas turbines using water or steam injection for control of NO<sub>x</sub> emissions are exempt from paragraph (a) when ice fog is deemed a traffic hazard by the owner or operator of the gas turbine.

(g) Emergency gas turbines, military gas turbines for use in other than a garrison facility, military gas turbines installed for use as military training facilities, and fire fighting gas turbines are exempt from paragraph (a) of this section.

(h) Stationary gas turbines engaged by manufacturers in research and development of equipment for both gas turbine emission control techniques and gas turbine efficiency improvements are exempt from paragraph (a) on a case-by-case basis as determined by the Administrator.

(i) Exemptions from the requirements of paragraph (a) of this section will be granted on a case-by-case basis as determined by the Administrator in specific geographical areas where mandatory water restrictions are required by governmental agencies because of drought conditions. These exemptions will be allowed only while the mandatory water restrictions are in effect.

(j) Stationary gas turbines with a heat input at peak load greater than 107.2 gigajoules per hour that commenced construction, modification, or reconstruction between the dates of October 3, 1977, and January 27, 1982, and were required in the September 10, 1979, Federal Register (44 FR 52792) to comply with paragraph (a)(1) of this section, except electric utility stationary gas turbines, are exempt from paragraph (a) of this section.

(k) Stationary gas turbines with a heat input greater than or equal to 10.7 gigajoules per hour (10 million Btu/hour) when fired with natural gas are exempt from paragraph (a)(2) of this section when being fired with an emergency fuel.

(l) Regenerative cycle gas turbines with a heat input less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) are exempt from paragraph (a) of this section.

[44 FR 52798, Sept. 10, 1979, as amended at 47 FR 3770, Jan. 27, 1982; 65 FR 61759, Oct. 17, 2000; 69 FR 41359, July 8, 2004]

### **§ 60.333 Standard for sulfur dioxide.**

On and after the date on which the performance test required to be conducted by §60.8 is completed, every owner or operator subject to the provision of this subpart shall comply with one or the other of the following conditions:

(a) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine any gases which contain sulfur dioxide in excess of 0.015 percent by volume at 15 percent oxygen and on a dry basis.

(b) No owner or operator subject to the provisions of this subpart shall burn in any stationary gas turbine any fuel which contains total sulfur in excess of 0.8 percent by weight (8000 ppmw).

[44 FR 52798, Sept. 10, 1979, as amended at 69 FR 41360, July 8, 2004]

### § 60.334 Monitoring of operations.

(a) Except as provided in paragraph (b) of this section, the owner or operator of any stationary gas turbine subject to the provisions of this subpart and using water or steam injection to control NO<sub>x</sub> emissions shall install, calibrate, maintain and operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water or steam to fuel being fired in the turbine.

(b) The owner or operator of any stationary gas turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which uses water or steam injection to control NO<sub>x</sub> emissions may, as an alternative to operating the continuous monitoring system described in paragraph (a) of this section, install, certify, maintain, operate, and quality-assure a continuous emission monitoring system (CEMS) consisting of NO<sub>x</sub> and O<sub>2</sub> monitors. As an alternative, a CO<sub>2</sub> monitor may be used to adjust the measured NO<sub>x</sub> concentrations to 15 percent O<sub>2</sub> by either converting the CO<sub>2</sub> hourly averages to equivalent O<sub>2</sub> concentrations using Equation F-14a or F-14b in appendix F to part 75 of this chapter and making the adjustments to 15 percent O<sub>2</sub>, or by using the CO<sub>2</sub> readings directly to make the adjustments, as described in Method 20. If the option to use a CEMS is chosen, the CEMS shall be installed, certified, maintained and operated as follows:

(1) Each CEMS must be installed and certified according to PS 2 and 3 (for diluent) of 40 CFR part 60, appendix B, except the 7-day calibration drift is based on unit operating days, not calendar days. Appendix F, Procedure 1 is not required. The relative accuracy test audit (RATA) of the NO<sub>x</sub> and diluent monitors may be performed individually or on a combined basis, *i.e.*, the relative accuracy tests of the CEMS may be performed either:

(i) On a ppm basis (for NO<sub>x</sub>) and a percent O<sub>2</sub> basis for oxygen; or

(ii) On a ppm at 15 percent O<sub>2</sub> basis; or

(iii) On a ppm basis (for NO<sub>x</sub>) and a percent CO<sub>2</sub> basis (for a CO<sub>2</sub> monitor that uses the procedures in Method 20 to correct the NO<sub>x</sub> data to 15 percent O<sub>2</sub>).

(2) As specified in §60.13(e)(2), during each full unit operating hour, each monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required to validate the hour.

(3) For purposes of identifying excess emissions, CEMS data must be reduced to hourly averages as specified in §60.13(h).

(i) For each unit operating hour in which a valid hourly average, as described in paragraph (b)(2) of this section, is obtained for both NO<sub>x</sub> and diluent, the data acquisition and handling system must calculate and record the hourly NO<sub>x</sub> emissions in the units of the applicable NO<sub>x</sub> emission standard under §60.332(a), *i.e.*, percent NO<sub>x</sub> by volume, dry basis, corrected to 15 percent O<sub>2</sub> and International Organization for Standardization (ISO) standard conditions (if required as given in §60.335(b)(1)). For any hour in which the hourly average O<sub>2</sub> concentration exceeds 19.0 percent O<sub>2</sub>, a diluent cap value of 19.0 percent O<sub>2</sub> may be used in the emission calculations.

(ii) A worst case ISO correction factor may be calculated and applied using historical ambient data. For the purpose of this calculation, substitute the maximum humidity of ambient air (H<sub>o</sub>), minimum ambient temperature (T<sub>a</sub>), and minimum combustor inlet absolute pressure (P<sub>o</sub>) into the ISO correction equation.

(iii) If the owner or operator has installed a NO<sub>x</sub> CEMS to meet the requirements of part 75 of this chapter, and is continuing to meet the ongoing requirements of part 75 of this chapter, the CEMS may be used to meet the requirements of this section, except that the missing data substitution methodology provided for at 40 CFR part 75, subpart D, is not required for purposes of identifying excess emissions. Instead, periods of missing CEMS data are to be reported as monitor downtime in the excess emissions and monitoring performance report required in §60.7(c).

(c) For any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which does not use steam or water injection to control NO<sub>x</sub> emissions, the owner or operator may, but is not required to, for purposes of determining excess emissions, use a CEMS that meets the requirements of paragraph (b) of this section. Also, if the owner or operator has previously

submitted and received EPA, State, or local permitting authority approval of a procedure for monitoring compliance with the applicable NO<sub>x</sub> emission limit under §60.332, that approved procedure may continue to be used.

(d) The owner or operator of any new turbine constructed after July 8, 2004, and which uses water or steam injection to control NO<sub>x</sub> emissions may elect to use either the requirements in paragraph (a) of this section for continuous water or steam to fuel ratio monitoring or may use a NO<sub>x</sub>CEMS installed, certified, operated, maintained, and quality-assured as described in paragraph (b) of this section.

(e) The owner or operator of any new turbine that commences construction after July 8, 2004, and which does not use water or steam injection to control NO<sub>x</sub> emissions, may, but is not required to, elect to use a NO<sub>x</sub>CEMS installed, certified, operated, maintained, and quality-assured as described in paragraph (b) of this section. Other acceptable monitoring approaches include periodic testing approved by EPA or the State or local permitting authority or continuous parameter monitoring as described in paragraph (f) of this section.

(f) The owner or operator of a new turbine that commences construction after July 8, 2004, which does not use water or steam injection to control NO<sub>x</sub> emissions may, but is not required to, perform continuous parameter monitoring as follows:

(1) For a diffusion flame turbine without add-on selective catalytic reduction controls (SCR), the owner or operator shall define at least four parameters indicative of the unit's NO<sub>x</sub> formation characteristics and shall monitor these parameters continuously.

(2) For any lean premix stationary combustion turbine, the owner or operator shall continuously monitor the appropriate parameters to determine whether the unit is operating in low-NO<sub>x</sub> mode.

(3) For any turbine that uses SCR to reduce NO<sub>x</sub> emissions, the owner or operator shall continuously monitor appropriate parameters to verify the proper operation of the emission controls.

(4) For affected units that are also regulated under part 75 of this chapter, if the owner or operator elects to monitor NO<sub>x</sub> emission rate using the methodology in appendix E to part 75 of this chapter, or the low mass emissions methodology in §75.19 of this chapter, the requirements of this paragraph (f) may be met by performing the parametric monitoring described in section 2.3 of appendix E or in §75.19(c)(1)(iv)(H) of this chapter.

(g) The steam or water to fuel ratio or other parameters that are continuously monitored as described in paragraphs (a), (d) or (f) of this section shall be monitored during the performance test required under §60.8, to establish acceptable values and ranges. The owner or operator may supplement the performance test data with engineering analyses, design specifications, manufacturer's recommendations and other relevant information to define the acceptable parametric ranges more precisely. The owner or operator shall develop and keep on-site a parameter monitoring plan which explains the procedures used to document proper operation of the NO<sub>x</sub> emission controls. The plan shall include the parameter(s) monitored and the acceptable range(s) of the parameter(s) as well as the basis for designating the parameter(s) and acceptable range(s). Any supplemental data such as engineering analyses, design specifications, manufacturer's recommendations and other relevant information shall be included in the monitoring plan. For affected units that are also subject to part 75 of this chapter and that use the low mass emissions methodology in §75.19 of this chapter or the NO<sub>x</sub> emission measurement methodology in appendix E to part 75, the owner or operator may meet the requirements of this paragraph by developing and keeping on-site (or at a central location for unmanned facilities) a quality-assurance plan, as described in §75.19 (e)(5) or in section 2.3 of appendix E and section 1.3.6 of appendix B to part 75 of this chapter.

(h) The owner or operator of any stationary gas turbine subject to the provisions of this subpart:

(1) Shall monitor the total sulfur content of the fuel being fired in the turbine, except as provided in paragraph (h)(3) of this section. The sulfur content of the fuel must be determined using total sulfur methods described in §60.335(b)(10). Alternatively, if the total sulfur content of the gaseous fuel during the most recent performance test was less than 0.4 weight percent (4000 ppmw), ASTM D4084–82, 94, D5504–01, D6228–98, or Gas Processors Association Standard 2377–86 (all of which are incorporated by reference-see §60.17), which measure the major sulfur compounds may be used; and

(2) Shall monitor the nitrogen content of the fuel combusted in the turbine, if the owner or operator claims an allowance for fuel bound nitrogen ( *i.e.* , if an F-value greater than zero is being or will be used by the owner or operator to calculate STD in §60.332). The nitrogen content of the fuel shall be determined using methods described in §60.335(b)(9) or an approved alternative.

(3) Notwithstanding the provisions of paragraph (h)(1) of this section, the owner or operator may elect not to monitor the total sulfur content of the gaseous fuel combusted in the turbine, if the gaseous fuel is demonstrated to meet the definition of natural gas in §60.331(u), regardless of whether an existing custom schedule approved by the administrator for subpart GG requires such monitoring. The owner or operator shall use one of the following sources of information to make the required demonstration:

(i) The gas quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less; or

(ii) Representative fuel sampling data which show that the sulfur content of the gaseous fuel does not exceed 20 grains/100 scf. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of appendix D to part 75 of this chapter is required.

(4) For any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and for which a custom fuel monitoring schedule has previously been approved, the owner or operator may, without submitting a special petition to the Administrator, continue monitoring on this schedule.

(i) The frequency of determining the sulfur and nitrogen content of the fuel shall be as follows:

(1) *Fuel oil.* For fuel oil, use one of the total sulfur sampling options and the associated sampling frequency described in sections 2.2.3, 2.2.4.1, 2.2.4.2, and 2.2.4.3 of appendix D to part 75 of this chapter ( *i.e.* , flow proportional sampling, daily sampling, sampling from the unit's storage tank after each addition of fuel to the tank, or sampling each delivery prior to combining it with fuel oil already in the intended storage tank). If an emission allowance is being claimed for fuel-bound nitrogen, the nitrogen content of the oil shall be determined and recorded once per unit operating day.

(2) *Gaseous fuel.* Any applicable nitrogen content value of the gaseous fuel shall be determined and recorded once per unit operating day. For owners and operators that elect not to demonstrate sulfur content using options in paragraph (h)(3) of this section, and for which the fuel is supplied without intermediate bulk storage, the sulfur content value of the gaseous fuel shall be determined and recorded once per unit operating day.

(3) *Custom schedules.* Notwithstanding the requirements of paragraph (i)(2) of this section, operators or fuel vendors may develop custom schedules for determination of the total sulfur content of gaseous fuels, based on the design and operation of the affected facility and the characteristics of the fuel supply. Except as provided in paragraphs (i)(3)(i) and (i)(3)(ii) of this section, custom schedules shall be substantiated with data and shall be approved by the Administrator before they can be used to comply with the standard in §60.333.

(i) The two custom sulfur monitoring schedules set forth in paragraphs (i)(3)(i)(A) through (D) and in paragraph (i)(3)(ii) of this section are acceptable, without prior Administrative approval:

(A) The owner or operator shall obtain daily total sulfur content measurements for 30 consecutive unit operating days, using the applicable methods specified in this subpart. Based on the results of the 30 daily samples, the required frequency for subsequent monitoring of the fuel's total sulfur content shall be as specified in paragraph (i)(3)(i)(B), (C), or (D) of this section, as applicable.

(B) If none of the 30 daily measurements of the fuel's total sulfur content exceeds 0.4 weight percent (4000 ppmw), subsequent sulfur content monitoring may be performed at 12 month intervals. If any of the samples taken at 12-month intervals has a total sulfur content between 0.4 and 0.8 weight percent (4000 and 8000 ppmw), follow the procedures in paragraph (i)(3)(i)(C) of this section. If any measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section.

(C) If at least one of the 30 daily measurements of the fuel's total sulfur content is between 0.4 and 0.8 weight percent (4000 and 8000 ppmw), but none exceeds 0.8 weight percent (8000 ppmw), then:

( 1 ) Collect and analyze a sample every 30 days for three months. If any sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section. Otherwise, follow the procedures in paragraph (i)(3)(i)(C)( 2 ) of this section.

( 2 ) Begin monitoring at 6-month intervals for 12 months. If any sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section. Otherwise, follow the procedures in paragraph (i)(3)(i)(C)( 3 ) of this section.

( 3 ) Begin monitoring at 12-month intervals. If any sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section. Otherwise, continue to monitor at this frequency.

(D) If a sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), immediately begin daily monitoring according to paragraph (i)(3)(i)(A) of this section. Daily monitoring shall continue until 30 consecutive daily samples, each having a sulfur content no greater than 0.8 weight percent (8000 ppmw), are obtained. At that point, the applicable procedures of paragraph (i)(3)(i)(B) or (C) of this section shall be followed.

(ii) The owner or operator may use the data collected from the 720-hour sulfur sampling demonstration described in section 2.3.6 of appendix D to part 75 of this chapter to determine a custom sulfur sampling schedule, as follows:

(A) If the maximum fuel sulfur content obtained from the 720 hourly samples does not exceed 20 grains/100 scf ( *i.e.* , the maximum total sulfur content of natural gas as defined in §60.331(u)), no additional monitoring of the sulfur content of the gas is required, for the purposes of this subpart.

(B) If the maximum fuel sulfur content obtained from any of the 720 hourly samples exceeds 20 grains/100 scf, but none of the sulfur content values (when converted to weight percent sulfur) exceeds 0.4 weight percent (4000 ppmw), then the minimum required sampling frequency shall be one sample at 12 month intervals.

(C) If any sample result exceeds 0.4 weight percent sulfur (4000 ppmw), but none exceeds 0.8 weight percent sulfur (8000 ppmw), follow the provisions of paragraph (i)(3)(i)(C) of this section.

(D) If the sulfur content of any of the 720 hourly samples exceeds 0.8 weight percent (8000 ppmw), follow the provisions of paragraph (i)(3)(i)(D) of this section.

(j) For each affected unit that elects to continuously monitor parameters or emissions, or to periodically determine the fuel sulfur content or fuel nitrogen content under this subpart, the owner or operator shall submit reports of excess emissions and monitor downtime, in accordance with §60.7(c). Excess emissions shall be reported for all periods of unit operation, including startup, shutdown and malfunction. For the purpose of reports required under §60.7(c), periods of excess emissions and monitor downtime that shall be reported are defined as follows:

(1) Nitrogen oxides.

(i) For turbines using water or steam to fuel ratio monitoring:

(A) An excess emission shall be any unit operating hour for which the average steam or water to fuel ratio, as measured by the continuous monitoring system, falls below the acceptable steam or water to fuel ratio needed to demonstrate compliance with §60.332, as established during the performance test required in §60.8. Any unit operating hour in which no water or steam is injected into the turbine shall also be considered an excess emission.

(B) A period of monitor downtime shall be any unit operating hour in which water or steam is injected into the turbine, but the essential parametric data needed to determine the steam or water to fuel ratio are unavailable or invalid.

(C) Each report shall include the average steam or water to fuel ratio, average fuel consumption, ambient conditions (temperature, pressure, and humidity), gas turbine load, and (if applicable) the nitrogen content of the fuel during each excess emission. You do not have to report ambient conditions if you opt to use the worst case ISO correction factor as specified in §60.334(b)(3)(ii), or if you are not using the ISO correction equation under the provisions of §60.335(b)(1).

(ii) If the owner or operator elects to take an emission allowance for fuel bound nitrogen, then excess emissions and periods of monitor downtime are as described in paragraphs (j)(1)(ii)(A) and (B) of this section.

(A) An excess emission shall be the period of time during which the fuel-bound nitrogen (N) is greater than the value measured during the performance test required in §60.8 and used to determine the allowance. The excess emission begins on the date and hour of the sample which shows that N is greater than the performance test value, and ends with the date and hour of a subsequent sample which shows a fuel nitrogen content less than or equal to the performance test value.

(B) A period of monitor downtime begins when a required sample is not taken by its due date. A period of monitor downtime also begins on the date and hour that a required sample is taken, if invalid results are obtained. The period of monitor downtime ends on the date and hour of the next valid sample.

(iii) For turbines using NO<sub>x</sub> and diluent CEMS:

(A) An hour of excess emissions shall be any unit operating hour in which the 4-hour rolling average NO<sub>x</sub> concentration exceeds the applicable emission limit in §60.332(a)(1) or (2). For the purposes of this subpart, a "4-hour rolling average NO<sub>x</sub> concentration" is the arithmetic average of the average NO<sub>x</sub>

concentration measured by the CEMS for a given hour (corrected to 15 percent O<sub>2</sub> and, if required under §60.335(b)(1), to ISO standard conditions) and the three unit operating hour average NO<sub>x</sub> concentrations immediately preceding that unit operating hour.

(B) A period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour, for either NO<sub>x</sub> concentration or diluent (or both).

(C) Each report shall include the ambient conditions (temperature, pressure, and humidity) at the time of the excess emission period and (if the owner or operator has claimed an emission allowance for fuel bound nitrogen) the nitrogen content of the fuel during the period of excess emissions. You do not have to report ambient conditions if you opt to use the worst case ISO correction factor as specified in §60.334(b)(3)(ii), or if you are not using the ISO correction equation under the provisions of §60.335(b)(1).

(iv) For owners or operators that elect, under paragraph (f) of this section, to monitor combustion parameters or parameters that document proper operation of the NO<sub>x</sub> emission controls:

(A) An excess emission shall be a 4-hour rolling unit operating hour average in which any monitored parameter does not achieve the target value or is outside the acceptable range defined in the parameter monitoring plan for the unit.

(B) A period of monitor downtime shall be a unit operating hour in which any of the required parametric data are either not recorded or are invalid.

(2) Sulfur dioxide. If the owner or operator is required to monitor the sulfur content of the fuel under paragraph (h) of this section:

(i) For samples of gaseous fuel and for oil samples obtained using daily sampling, flow proportional sampling, or sampling from the unit's storage tank, an excess emission occurs each unit operating hour included in the period beginning on the date and hour of any sample for which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8 weight percent and ending on the date and hour that a subsequent sample is taken that demonstrates compliance with the sulfur limit.

(ii) If the option to sample each delivery of fuel oil has been selected, the owner or operator shall immediately switch to one of the other oil sampling options ( *i.e.* , daily sampling, flow proportional sampling, or sampling from the unit's storage tank) if the sulfur content of a delivery exceeds 0.8 weight percent. The owner or operator shall continue to use one of the other sampling options until all of the oil from the delivery has been combusted, and shall evaluate excess emissions according to paragraph (j)(2)(i) of this section. When all of the fuel from the delivery has been burned, the owner or operator may resume using the as-delivered sampling option.

(iii) A period of monitor downtime begins when a required sample is not taken by its due date. A period of monitor downtime also begins on the date and hour of a required sample, if invalid results are obtained. The period of monitor downtime shall include only unit operating hours, and ends on the date and hour of the next valid sample.

(3) *Ice fog*. Each period during which an exemption provided in §60.332(f) is in effect shall be reported in writing to the Administrator quarterly. For each period the ambient conditions existing during the period, the date and time the air pollution control system was deactivated, and the date and time the air pollution control system was reactivated shall be reported. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter.

(4) *Emergency fuel*. Each period during which an exemption provided in §60.332(k) is in effect shall be included in the report required in §60.7(c). For each period, the type, reasons, and duration of the firing of the emergency fuel shall be reported.

(5) All reports required under §60.7(c) shall be postmarked by the 30th day following the end of each 6-month period.

[44 FR 52798, Sept. 10, 1979, as amended at 47 FR 3770, Jan. 27, 1982; 65 FR 61759, Oct. 17, 2000; 69 FR 41360, July 8, 2004; 71 FR 9457, Feb. 24, 2006]

### **§ 60.335 Test methods and procedures.**

(a) The owner or operator shall conduct the performance tests required in §60.8, using either

(1) EPA Method 20,

(2) ASTM D6522-00 (incorporated by reference, see §60.17), or

(3) EPA Method 7E and either EPA Method 3 or 3A in appendix A to this part, to determine NO<sub>x</sub> and diluent concentration.

(4) Sampling traverse points are to be selected following Method 20 or Method 1, (non-particulate procedures) and sampled for equal time intervals. The sampling shall be performed with a traversing single-hole probe or, if feasible, with a stationary multi-hole probe that samples each of the points sequentially. Alternatively, a multi-hole probe designed and documented to sample equal volumes from each hole may be used to sample simultaneously at the required points.

(5) Notwithstanding paragraph (a)(4) of this section, the owner or operator may test at few points than are specified in Method 1 or Method 20 if the following conditions are met:

(i) You may perform a stratification test for  $\text{NO}_x$  and diluent pursuant to

(A) [Reserved]

(B) The procedures specified in section 6.5.6.1(a) through (e) appendix A to part 75 of this chapter.

(ii) Once the stratification sampling is completed, the owner or operator may use the following alternative sample point selection criteria for the performance test:

(A) If each of the individual traverse point  $\text{NO}_x$  concentrations, normalized to 15 percent  $\text{O}_2$ , is within  $\pm 10$  percent of the mean normalized concentration for all traverse points, then you may use 3 points (located either 16.7, 50.0, and 83.3 percent of the way across the stack or duct, or, for circular stacks or ducts greater than 2.4 meters (7.8 feet) in diameter, at 0.4, 1.2, and 2.0 meters from the wall). The 3 points shall be located along the measurement line that exhibited the highest average normalized  $\text{NO}_x$  concentration during the stratification test; or

(B) If each of the individual traverse point  $\text{NO}_x$  concentrations, normalized to 15 percent  $\text{O}_2$ , is within  $\pm 5$  percent of the mean normalized concentration for all traverse points, then you may sample at a single point, located at least 1 meter from the stack wall or at the stack centroid.

(6) Other acceptable alternative reference methods and procedures are given in paragraph (c) of this section.

(b) The owner or operator shall determine compliance with the applicable nitrogen oxides emission limitation in §60.332 and shall meet the performance test requirements of §60.8 as follows:

(1) For each run of the performance test, the mean nitrogen oxides emission concentration ( $\text{NO}_{x0}$ ) corrected to 15 percent  $\text{O}_2$  shall be corrected to ISO standard conditions using the following equation. Notwithstanding this requirement, use of the ISO correction equation is optional for: Lean premix stationary combustion turbines; units used in association with heat recovery steam generators (HRSG) equipped with duct burners; and units equipped with add-on emission control devices:

$$\text{NO}_x = (\text{NO}_{x0}) (P_r/P_o)^{0.5} e^{19} (\text{Ho} - 0.00633) (288^\circ\text{K}/T_a)^{1.53}$$

Where:

$\text{NO}_x$  = emission concentration of  $\text{NO}_x$  at 15 percent  $\text{O}_2$  and ISO standard ambient conditions, ppm by volume, dry basis,

$\text{NO}_{x0}$  = mean observed  $\text{NO}_x$  concentration, ppm by volume, dry basis, at 15 percent  $\text{O}_2$ ,

$P_r$  = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg,

$P_o$  = observed combustor inlet absolute pressure at test, mm Hg,

$\text{H}_o$  = observed humidity of ambient air, g  $\text{H}_2\text{O}/\text{g}$  air,

$e$  = transcendental constant, 2.718, and

$T_a$  = ambient temperature, °K.

(2) The 3-run performance test required by §60.8 must be performed within  $\pm 5$  percent at 30, 50, 75, and 90-to-100 percent of peak load or at four evenly-spaced load points in the normal operating range of the gas turbine, including the minimum point in the operating range and 90-to-100 percent of peak load, or at the highest achievable load point if 90-to-100 percent of peak load cannot be physically achieved in practice. If the turbine combusts both oil and gas as primary or backup fuels, separate performance testing is required for each fuel. Notwithstanding these requirements, performance testing is not required for any emergency fuel (as defined in §60.331).

(3) For a combined cycle turbine system with supplemental heat (duct burner), the owner or operator may elect to measure the turbine  $\text{NO}_x$  emissions after the duct burner rather than directly after the turbine. If the owner or operator elects to use this alternative sampling location, the applicable  $\text{NO}_x$  emission limit in §60.332 for the combustion turbine must still be met.

(4) If water or steam injection is used to control  $\text{NO}_x$  with no additional post-combustion  $\text{NO}_x$  control and the owner or operator chooses to monitor the steam or water to fuel ratio in accordance with §60.334(a), then that monitoring system must be operated concurrently with each EPA Method 20, ASTM D6522-00

(incorporated by reference, see §60.17), or EPA Method 7E run and shall be used to determine the fuel consumption and the steam or water to fuel ratio necessary to comply with the applicable §60.332 NO<sub>x</sub> emission limit.

(5) If the owner or operator elects to claim an emission allowance for fuel bound nitrogen as described in §60.332, then concurrently with each reference method run, a representative sample of the fuel used shall be collected and analyzed, following the applicable procedures described in §60.335(b)(9). These data shall be used to determine the maximum fuel nitrogen content for which the established water (or steam) to fuel ratio will be valid.

(6) If the owner or operator elects to install a CEMS, the performance evaluation of the CEMS may either be conducted separately (as described in paragraph (b)(7) of this section) or as part of the initial performance test of the affected unit.

(7) If the owner or operator elects to install and certify a NO<sub>x</sub>CEMS under §60.334(e), then the initial performance test required under §60.8 may be done in the following alternative manner:

(i) Perform a minimum of 9 reference method runs, with a minimum time per run of 21 minutes, at a single load level, between 90 and 100 percent of peak (or the highest physically achievable) load.

(ii) Use the test data both to demonstrate compliance with the applicable NO<sub>x</sub> emission limit under §60.332 and to provide the required reference method data for the RATA of the CEMS described under §60.334(b).

(iii) The requirement to test at three additional load levels is waived.

(8) If the owner or operator elects under §60.334(f) to monitor combustion parameters or parameters indicative of proper operation of NO<sub>x</sub> emission controls, the appropriate parameters shall be continuously monitored and recorded during each run of the initial performance test, to establish acceptable operating ranges, for purposes of the parameter monitoring plan for the affected unit, as specified in §60.334(g).

(9) To determine the fuel bound nitrogen content of fuel being fired (if an emission allowance is claimed for fuel bound nitrogen), the owner or operator may use equipment and procedures meeting the requirements of:

(i) For liquid fuels, ASTM D2597-94 (Reapproved 1999), D6366-99, D4629-02, D5762-02 (all of which are incorporated by reference, see §60.17); or

(ii) For gaseous fuels, shall use analytical methods and procedures that are accurate to within 5 percent of the instrument range and are approved by the Administrator.

(10) If the owner or operator is required under §60.334(i)(1) or (3) to periodically determine the sulfur content of the fuel combusted in the turbine, a minimum of three fuel samples shall be collected during the performance test. Analyze the samples for the total sulfur content of the fuel using:

(i) For liquid fuels, ASTM D129-00, D2622-98, D4294-02, D1266-98, D5453-00 or D1552-01 (all of which are incorporated by reference, see §60.17); or

(ii) For gaseous fuels, ASTM D1072-80, 90 (Reapproved 1994); D3246-81, 92, 96; D4468-85 (Reapproved 2000); or D6667-01 (all of which are incorporated by reference, see §60.17). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the prior approval of the Administrator.

(11) The fuel analyses required under paragraphs (b)(9) and (b)(10) of this section may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency.

(c) The owner or operator may use the following as alternatives to the reference methods and procedures specified in this section:

(1) Instead of using the equation in paragraph (b)(1) of this section, manufacturers may develop ambient condition correction factors to adjust the nitrogen oxides emission level measured by the performance test as provided in §60.8 to ISO standard day conditions.

[69 FR 41363, July 8, 2004, as amended at 71 FR 9458, Feb. 24, 2006]



# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

*Mitchell E. Daniels Jr.*  
**Governor**

*Thomas W. Easterly*  
**Commissioner**

100 North Senate Avenue  
Indianapolis, Indiana 46204  
(317) 232-8603  
Toll Free (800) 451-6027  
[www.idem.IN.gov](http://www.idem.IN.gov)

## Attachment C

### **TITLE IV (ACID RAIN) PERMIT RENEWAL OFFICE OF AIR QUALITY**

**Anderson Combustion Turbine Facility  
6035 Park Road  
Anderson, Indiana, 46011  
ORIS: 7336**

The owners and operators (hereinafter collectively known as the Permittee) of the above source are issued this permit under the provisions of 326 Indiana Administrative Code (IAC) 21 with conditions listed on the attached pages.

Operation Permit No.: AR 095-28886-00051	
Issued by:  Tripurari P. Sinha, Ph. D., Section Chief Permits Branch Office of Air Quality	Issuance Date: March 29, 2010  Expiration Date: March 29, 2015

### Title IV Operating Conditions

Title IV Source Description:

- (a) Two (2) 38.7 megawatt (net) simple cycle gas turbines using natural gas as the primary fuel with No. 2 fuel oil used as a backup identified as ACT1 and ACT2 (known as T1 and T2 in Title V permit), and using a water injection system as control, with each turbine exhausting to stacks, identified as S/V 3 and S/V 4, respectively.
- (b) One (1) 84 megawatt simple cycle gas turbine, using natural gas as the primary fuel and No. 2 fuel oil as backup fuel, identified as ACT3 (known as T3 in the Title V permit) using water injection for NOx control when fuel oil is used, and exhausting to stack S/V 7. When using natural gas, ACT3 has a maximum heat input capacity of 858 MMBtu/hr. When using No. 2 fuel oil, ACT3 has a maximum heat input capacity of 850 MMBtu/hr.

(The information contained in this box is descriptive information and does not constitute enforceable conditions.)

1. Statutory and Regulatory Authorities

In accordance with IC 13-17-3-4 and IC 13-17-3-11, as well as Titles IV and V of the Clean Air Act, the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ) issues this permit pursuant to 326 IAC 2 and 326 IAC 21 (incorporates by reference 40 Code of Federal Regulations (CFR) 72 through 78).

2. Standard Permit Requirements [326 IAC 21]

- (a) The designated representative has submitted a complete acid rain permit application in accordance with 40 CFR 72.30.
- (b) The Permittee shall operate ACT1, ACT2 and ACT3 in compliance with this permit.

3. Monitoring Requirements [326 IAC 21]

- (a) The Permittee and, to the extent applicable, the designated representative of ACT1, ACT2 and ACT3 shall comply with the monitoring requirements as provided in 40 CFR 75.
- (b) The emissions measurements recorded and reported in accordance with 40 CFR 75 shall be used to determine compliance by ACT1, ACT2 and ACT3 with the acid rain emissions limitations and emissions reduction requirements for sulfur dioxide under the Acid Rain Program.
- (c) The requirements of 40 CFR 75 shall not affect the responsibility of the Permittee to monitor emissions of other pollutants or other emissions characteristics at ACT1, ACT2 and ACT3 under other applicable requirements of the Clean Air Act and other provisions of the operating permit for the source.

4. Sulfur Dioxide Requirements [326 IAC 21]

- (a) The Permittee shall:
  - (1) Hold allowances, as of the allowance transfer deadline (as defined in 40 CFR 72.2), in the compliance subaccount of ACT1, ACT2 and ACT3, after deductions under 40 CFR 73.34(c), not less than the total annual emissions of sulfur dioxide for the previous calendar year from ACT1, ACT2 and ACT3; and,
  - (2) Comply with the applicable acid rain emissions limitations for sulfur dioxide.
- (b) Each ton of sulfur dioxide emitted in excess of the acid rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Clean Air Act.
- (c) ACT1, ACT2 and ACT3 shall be subject to the requirements under paragraph 4(a) of the sulfur dioxide requirements as follows:

- (1) Starting January 1, 2000, an affected unit under 40 CFR 72.6(a)(2); or,
  - (2) Starting on the latter of January 1, 2000, or the deadline for monitor certification under 40 CFR 75, an affected unit under 40 CFR 72.6(a)(3).
- 
- (d) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
  - (e) An allowance shall not be deducted in order to comply with the requirements under paragraph 4(a) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
  - (f) ACT1, ACT2 and ACT3 were not allocated allowances by United States Environmental Protection Agency (U.S. EPA) under 40 CFR 73.10. However, ACT1, ACT2 and ACT3 must still comply with the requirement to hold allowances to account for sulfur dioxide emissions under paragraph 4(a) and 326 IAC 21.
  - (g) An allowance allocated by the U.S. EPA under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the acid rain permit application, the acid rain permit, the acid rain portion of an operating permit, or the written exemption under 40 CFR 72.7 and 72.8 and 326 IAC 21, and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
  - (h) An allowance allocated by U.S. EPA under the Acid Rain Program does not constitute a property right.
  - (i) No permit revision may be required for increases in emissions that are authorized by allowances acquired pursuant to the Acid Rain Program, provided that the increases do not require a permit revision under any other applicable requirement. [326 IAC 2-7-5(4)(A)]
  - (j) No limit shall be placed on the number of allowances held by the Permittee. The Permittee may not, however, use allowances as a defense to noncompliance with any applicable requirement other than the requirements of the Acid Rain Program. [326 IAC 2-7-5(4)(B)]

5. Nitrogen Oxides Requirements [326 IAC 21]

- (a) Pursuant to 40 CFR 76, Acid Rain Nitrogen Oxides Emission Reduction Program, the natural gas fired simple cycle ACT1, ACT2 and ACT3 are not subject to the nitrogen oxide limitations set out in 40 CFR 76.
- (b) Pursuant to 40 CFR 76, Acid Rain Nitrogen Oxides Emission Reduction Program, the oil fired ACT1, ACT2 and ACT3 are not subject to the nitrogen oxide limitations set out in 40 CFR 76.

6. Excess Emissions Requirements [40 CFR 77] [326 IAC 21]

- (a) If ACT1, ACT2 or ACT3 has excess emissions of sulfur dioxide in any calendar year, the designated representative shall submit a proposed offset plan to U.S. EPA and IDEM, OAQ as required under 40 CFR 77 and 326 IAC 21.
- (b) The designated representative shall submit required information to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, IN 46204-2251

and

U.S. Environmental Protection Agency  
Clean Air Markets Division  
1200 Pennsylvania Avenue, NW  
Mail Code (6204N)  
Washington, DC 20460

- (c) If ACT1, ACT2 and ACT3 has excess emissions, as defined in 40 CFR 72.2, in any calendar year, the Permittee shall:
- (1) Pay to U.S. EPA without demand the penalty required, and pay to U.S. EPA upon demand the interest on that penalty, as required by 40 CFR 77 and 326 IAC 21; and,
  - (2) Comply with the terms of an approved sulfur dioxide offset plan, as required by 40 CFR 77 and 326 IAC 21.

7. Record Keeping and Reporting Requirements [326 IAC 21]

- (a) Unless otherwise provided, the Permittee shall keep on site each of the following documents for a period of 5 years, as required by 40 CFR 72.9(f), from the date the document is created. This period may be extended for cause, at any time prior to the end of the 5 years, in writing by U.S. EPA or IDEM, OAQ:
- (1) The certificate of representation for the designated representative of ACT1, ACT2 and ACT3 and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site at the source beyond such 5 year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
  - (2) All emissions monitoring information collected in accordance with 40 CFR 75 shall be retained on site for 3 years;
  - (3) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,
  - (4) Copies of all documents used to complete an acid rain permit application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.
- (b) The designated representative of ACT1, ACT2 and ACT3 shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 72.90 subpart I, 40 CFR 75, and 326 IAC 21. The required information is to be submitted to the appropriate authority(ies) as specified in 40 CFR 72.90 subpart I and 40 CFR 75.

8. Submissions [326 IAC 21]

- (a) The designated representative of ACT1, ACT2 and ACT3 shall submit a certificate of representation, and any superseding certificate of representation, to U.S. EPA and IDEM, OAQ in accordance with 40 CFR 72 and 326 IAC 21.
- (b) The designated representative shall submit required information to:

Indiana Department of Environmental Management  
Permit Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, IN 46204-2251

and

U.S. Environmental Protection Agency  
Clean Air Markets Division  
1200 Pennsylvania Avenue, NW  
Mail Code (6204N)  
Washington, DC 20460

- (c) Each such submission under the Acid Rain Program shall be submitted, signed and certified by the designated representative for all sources on behalf of which the submission is made.
- (d) In each submission under the Acid Rain Program, the designated representative shall certify, by his or her signature, the following statements which shall be included verbatim in the submission:
  - (1) "I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made."; and,
  - (2) "I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."
- (e) The designated representative of ACT1, ACT2 and ACT3 shall notify the Permittee:
  - (1) By the date of submission, of any Acid Rain Program submissions by the designated representative;
  - (2) Within 10 business days of receipt of any written determination by U.S. EPA or IDEM, OAQ; and,
  - (3) Provided that the submission or determination covers ACT1, ACT2 and ACT3.
- (f) The designated representative of ACT1, ACT2 and ACT3 shall provide the Permittee a copy of any submission or determination under paragraph 8(e) of this section, unless the Permittee expressly waives the right to receive a copy.

9. Severability [326 IAC 21]

Invalidation of the acid rain portion of an operating permit does not affect the continuing validity of the rest of the operating permit, nor shall invalidation of any other portion of the operating permit affect the continuing validity of the acid rain portion of the permit. [40 CFR 72.72(b), 326 IAC 21, and 326 IAC 2-7-5(5)]

10. Liability [326 IAC 21]

- (a) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, an acid rain permit, an acid rain portion of an operation permit, or a written exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement by U.S. EPA pursuant to Section 113(c) of the Clean Air Act and shall be subject to enforcement by IDEM pursuant to 326 IAC 21 and IC 13-30-3.
- (b) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to Section 113(c) of the Clean Air Act, 18 U.S.C. 1001 and IDEM pursuant to 326 IAC 21 and IC 13-30-6-2.
- (c) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.

- (d) ACT1, ACT2 and ACT3 shall meet the requirements of the Acid Rain Program.
- (e) Any provision of the Acid Rain Program that applies to ACT1, ACT2 and ACT3, including a provision applicable to the designated representative of ACT1, ACT2 and ACT3, shall also apply to the Permittee.
- (f) Any provision of the Acid Rain Program that applies to ACT1, ACT2 and ACT3, including a provision applicable to the designated representative, shall also apply to the Permittee. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans) and 40 CFR 76.11 (NOx averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR 75, including 40 CFR 75.16, 75.17, and 75.18, the Permittee and the designated representative of one affected unit, shall not be liable for any violation by any other affected unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.
- (g) Each violation of a provision of 40 CFR parts 72, 73, 75, 76, 77, and 78 by ACT1, ACT2 and ACT3, or by the Permittee or designated representative, shall be a separate violation of the Clean Air Act.

11. Effect on Other Authorities [326 IAC 21]

No provision of the Acid Rain Program, an acid rain permit application, an acid rain permit, an acid rain portion of an operation permit, or a written exemption under 40 CFR 72.7 or 72.8 shall be construed as:

- (a) Except as expressly provided in Title IV of the Clean Air Act (42 USC 7651 to 7651(o)), exempting or excluding the Permittee and, to the extent applicable, the designated representative of ACT1, ACT2 and ACT3, from compliance with any other provision of the Clean Air Act, including the provisions of Title I of the Clean Air Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;
- (b) Limiting the number of allowances a unit can hold; provided, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Clean Air Act;
- (c) Requiring a change of any kind in any state law regulating electric utility rates and charges, affecting any state law regarding such state regulation, or limiting such state regulation, including any prudence review requirements under such state law;
- (d) Modifying the Federal Power Act (16 USC 791(a) et seq.) or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
- (e) Interfering with or impairing any program for competitive bidding for power supply in a state in which such a program is established.

**Indiana Department of Environmental Management  
Office of Air Quality**

**Addendum to the Technical Support Document (ATSD)  
for a Part 70 Operating Permit Renewal**

**Source Description and Location**

<b>Source Name:</b>	<b>Indiana Municipal Power Agency – Anderson Station</b>
<b>Source Location:</b>	<b>6035 Park Road, Anderson, Indiana 46011</b>
<b>County:</b>	<b>Madison</b>
<b>SIC Code:</b>	<b>4911</b>
<b>Permit Renewal No.:</b>	<b>T 095-30940-00051</b>
<b>Permit Reviewer:</b>	<b>Anh Nguyen</b>

The Office of Air Quality (OAQ) has reviewed Part 70 Operating Permit for a Renewal permit application, submitted by Indiana Municipal Power Agency – Anderson Station on September 20, 2011, relating to the operation of a stationary carbon dioxide processing plant.

**Public Notice Information**

On May 27, 2012, the Office of Air Quality (OAQ) had a notice published in the Herald Bulletin in Madison County stating that Indiana Municipal Power Agency – Anderson Station has applied for a Renewal Permit of their Part 70 Operating Permit issued on July 25, 2007. The notice also stated that the OAQ proposed to issue a Part 70 Operating Permit Renewal for this operation and provided information on how the public could review the proposed permit and other documentation. Finally, the notice informed interested parties that there was a period of thirty (30) days to provide comments on whether or not this permit should be issued as proposed.

On June 11, 2012, Scott Berry of IMPA submitted comments on the proposed Title V Operating Permit. The comments are summarized in the subsequent pages, with IDEM's corresponding responses.

No changes have been made to the TSD because the OAQ prefers that the Technical Support Document reflects the permit that was on public notice. Changes that occur after the public notice are documented in this Addendum to the Technical Support Document. This accomplishes the desired result, ensuring that these types of concerns are documented and part of the record regarding this permit decision.

**Comments and IDEM's Responses**

IDEM has summarized and consolidated comments received during the public notice period. Comments dealing with a similar issue were grouped and IDEM provided a response on the issue in question. Appendix A to the ATSD contains revised emission calculations for this source as a result of the comments received by IDEM. The Technical Support Document (TSD) is used by IDEM, OAQ for historical purposes and will not be updated, but the Permit will have the updated changes. Public comments and IDEM's responses follow below:

**Source Comment #1**

Section D.1.2 SO<sub>2</sub> Limitations - Subsection (a) IMPA requests that "No. 2fuel oil" and also in the lastline of this paragraph " No.2 " needs a space added between the period and the number 2.

**IDEM RESPONSE: IDEM agrees to the changes and this condition has been revised accordingly.**

D.1.2 SO<sub>2</sub> Limitations [326 IAC 7-2]

---

- (a) The potential to emit SO<sub>2</sub> emissions from each of the turbines, T1, T2, T3 is greater than 25 tons/year or 10 pounds/hour when operating on ~~No. 2 fuel oil~~ **No. 2 fuel oil**. Therefore, the requirements of 326 IAC 7-1.1 are applicable. pursuant to 326 IAC 7-1.1-2, the SO<sub>2</sub> emissions from each of these turbines shall not exceed five-tenth (0.5) pounds per million British thermal units when operating on ~~No. 2~~ **No. 2** fuel oil

**Source Comment #2:**

Section D.1.4 Nitrogen Oxide Control - In order to ensure compliance with Conditions D.1.3 (a) which is applicable only to T1 and T2. T1 and T2 only uses water injection system for NO<sub>x</sub> control when operating on either gas or No. 2 fuel oil. T3 uses Lean Mix system for NO<sub>x</sub> control when operating, but the limits in D.1.3(a) do not apply to T3. The paragraph should read:  
In order to ensure compliance with Conditions D.1.3 (a), the water injection system for NO<sub>x</sub> control shall be in operation and control emissions from turbine T1 and T2 when these units are in operation.

**IDEM RESPONSE: IDEM agrees to the changes and this condition has been revised accordingly.**

**Compliance Determination Requirements**

D.1.4 Nitrogen Oxide Control

---

In order to ensure compliance with Conditions D.1.3 (a), the water injection system, ~~and the Lean Mix system~~ for NO<sub>x</sub> control shall be in operation and control emissions from turbine T1 and T2 when these units are in operation.

**Source Comment #3**

D.1.7 Record Keeping Requirements

Section (b) Condition D.1.1 (g) is incorrect and should be Conditions D.1.1 (e)

Section (c) Condition D.1.1 (h) is incorrect and should be Conditions D.1.1 (f)

Section (d) Condition D.1.5 is incorrect and should be Conditions D.1.6

**IDEM RESPONSE: IDEM agrees to the changes and this condition has been revised accordingly.**

**Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

D.1.7 Record Keeping Requirements

---

- (a) ...
- (b) In order to document the compliance status with Conditions D.1.1 ~~(g)~~ **(e)** Permittee shall maintain the records of operating hours for the "full-speed, no load" mode for each turbine T1, T2, and T3.
- (c) To document compliance with Conditions D.1.1 ~~(h)~~ **(f)**, D.1.2, and D.1.3 (b), the Permittee shall maintain the records of sulfur content of the No. 2 fuel oil combusted in the turbines.

- (d) In order to document the compliance status with Condition ~~D.1.5~~ **D.1.6**, the Permittee shall maintain records of daily visible emission notations of the turbine stack exhausts when combusting No. 2 fuel oil. The Permittee shall include in its daily record when a visible emission notation is not taken and the reason for the lack of visible emission notation (e.g. the process did not operate that day).

#### Source Comment #4

D.1.8 Reporting Requirements - D.1.1 (b) is no longer referencing the fuel use of T3 individually (T3 has been added to D.1.1 (a)). In addition, the reference of D.1.1 (g) needs to be changed to D.1.1 (e) due to the last change in the draft version of the air permit

**IDEM RESPONSE: IDEM agrees to the changes and this condition has been revised accordingly.**

#### D.1.8 Reporting Requirements

---

A quarterly summary of the information to document the compliance status with Conditions D.1.1(a), ~~D.1.1 (b)~~ and D.1.1 **(e)** ~~(g)~~ shall be submitted to the address listed in Section C – General Reporting Requirements, of this permit, not later than thirty (30) days after the end of the quarter being reported. Section C – General Reporting contains the Permittee's obligation with regard to the reporting required by this condition. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official," as defined by 326 IAC 2-7-1(34).

#### Source Comment #5

Section D.2.2 Record Keeping Requirements; subsection (a), Section E.2.1 General Provisions Relating to NESHAP ZZZZ, and Section E.2.2 General Provisions Relating to NESHAP ZZZZ referencing "Unit 7 and Unit 8" should be changed to D7 and D8 to be consistent with the units' name.

**IDEM RESPONSE: IDEM agrees to the changes and this condition has been revised accordingly.**

#### Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

#### D.2.2 Record Keeping Requirements

---

- (a) In order to document the compliance status with Condition D.2.1(a), the Permittee shall maintain monthly records of total diesel usage for diesel engines, identified as ~~Unit 7 and Unit 8~~ **D7 and D8**.

#### E.2.1 General Provisions Relating to NESHAP ZZZZ [326 IAC 20-1] [40 CFR 63, Subpart A]

---

The provisions of 40 CFR 63, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 20-1, apply to the diesel-fired startup engines, identified as ~~Unit 7 and Unit 8~~ **D7 and D8** except when otherwise specified in 40 CFR 63, Subpart ZZZZ.

#### E.2.2 National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines [40 CFR 63, Subpart ZZZZ] [326 IAC 20-82]

---

Pursuant to 40 CFR 63, Subpart ZZZZ, the Permittee shall comply with the provisions of National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines, which are incorporated as 326 IAC 20-82, for the diesel-fired startup engines, identified as ~~Unit 7 and Unit 8~~ **D7 and D8** as follows:

### Source Comment #6

Section E. 1.1 and E.1.2 General Provisions Relating to New Source Performance Standards (NSPS) and Standards of Performance for Stationary Gas Turbines (NSPS) - referencing "Unit 1 and Unit 2" are not correct. Gas turbines at IMPA Anderson Station are identified as T1, T2, and T3.

**IDEM RESPONSE: IDEM agrees to the changes and this condition has been revised accordingly.**

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

E.1.1 General Provisions Relating to New Source Performance Standards (NSPS) [326 IAC 12-1] [40 CFR 60, Subpart A] [326 IAC 12]

---

The provisions of 40 CFR 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the natural gas-fired simple cycle gas turbines, identified as T1, T2, and T3 ~~Unit 1 and Unit 2~~ **T1, T2, and T3**, except when otherwise specified in 40 CFR 60, Subpart GG.

E.1.2 Standards of Performance for Stationary Gas Turbines (NSPS) [40 CFR 60, Subpart GG][326 IAC 12]

---

Pursuant to 40 CFR 60 Subpart GG, the Permittee shall comply with the provisions of 40 CFR 60 Subpart GG, included as Attachment B which are incorporated as 326 IAC 12-1 for the natural gas-fired simple cycle gas turbines, identified as ~~Unit 1 and Unit 2~~ **T1, T2, and T3** as specified as follows:

### Source Comment #7

Section E.1.3 Customer Monitoring Schedule – The word "Customer" should be changed "Custom". In subsection (b) a space should be added between the word "NOxand O2" to "NOx and O2", the spelling of "monitprs" needs to be corrected to- "monitors" and corrects "Unit 1 and Unit 2 " to "**T1, T2, and T3**" **as stated in the box above.**

In subsection (c) the spelling of "~~fter~~" needs to be corrected to "after".

**IDEM RESPONSE: IDEM agrees to the changes and this condition has been revised accordingly.**

E.1.3 ~~Customer~~ **Custom** Monitoring Schedule (NSPS) [326 IAC 12] [40 CFR 60, Subpart GG]

---

Pursuant to the custom monitoring schedule approved by U.S. EPA on April 5, 2001, the Permittee variances to 40 CFR 60, Subpart GG apply:

- (a) Natural gas sulfur content monitoring shall be conducted on a semi annual basis;
- (b) The installation of NOx and O2 ~~monitors~~ **monitors** on ~~Unit 1 and Unit 2~~ **T1, T2, and T3** are not required; and
- (c) Sampling of the No.2 fuel oil for nitrogen and sulfur content shall be conducted on a semi annual basis or ~~after fter~~ **after** each addition of fuel oil is complete.

### Source Comment #8

Section G.2 Standard Permit Requirements, in subsection (b), IMPA requests that the quotation marks be removed around the following: "T1(ACT1), T2(ACT2), T3(ACT3)." to "T1(ACT1), T2(ACT2), T3(ACT3)."

**IDEM RESPONSE: IDEM agrees to the changes and this condition has been revised accordingly.**

G.2 Standard Permit Requirements [326 IAC 24-1-4(a)] [326 IAC 24-2-4(a)] [326 IAC 24-3-4(a)]  
[40 CFR 97.106(a)] [40 CFR 97.206(a)] [40 CFR 97.306(a)]

- 
- (a) The owners and operators of each CAIR NO<sub>x</sub> source, CAIR SO<sub>2</sub> source, and CAIR NO<sub>x</sub> ozone season source and CAIR NO<sub>x</sub> units, CAIR SO<sub>2</sub> units, and CAIR NO<sub>x</sub> ozone season units shall operate each source and unit in compliance with this CAIR permit.
- (b) The CAIR NO<sub>x</sub> units, CAIR SO<sub>2</sub> units, and CAIR NO<sub>x</sub> ozone season units subject to this CAIR permit are "T1(ACT1), T2(ACT2), T3(ACT3)" **T1(ACT1), T2(ACT2), T3(ACT3)** .

**Source Comment #11**

Reporting form on page 44 of 50, the section (a) and (b) are confusing and not inclusive of all the needed conversion factors. Therefore, IMPA- Anderson Station would like to update listing of natural gas equivalent conversion factors that is similar to the formatting used in the current permit (T095-22506-00051, page 52 of 58). IMPA understands that there maybe different numbers in some of the conversion factors but using this form will make the conversion factors clear and complete.

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH

**Part 70 Quarterly Report**

...

- (a) The use of 1,000 gallon of No. 2 fuel oil is equivalent to the use of 0.22 MMSCF of equivalent natural gas. When operating in "full-speed, no load" mode for T1 & T2 controlled by Water Injection systems , the use of one (1) MMSCF of natural gas is equivalent to the use of 3.20 MMSCF of equivalent natural gas and the use of 1,000 gallon of No. 2 fuel oil is equivalent to the use of 1.20 MMSCF of equivalent natural gas.
- (b) The use of 1,000 gallon of No. 2 fuel oil is equivalent to the use of 0.39 MMSCF of equivalent natural gas. When operating in "full-speed, no load" mode for T3 controlled by Lean-Premix systems , the use of one (1) MMSCF of natural gas is equivalent to the use of 7.9 MMSCF of equivalent natural gas and the use of 1,000 gallon of No. 2 fuel oil is equivalent to the use of 2.94 MMSCF of equivalent natural gas.

**IDEM RESPONSE: IDEM agrees to the changes and this condition has been revised accordingly.**

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH

**Part 70 Quarterly Report**

...

- ~~(a) The use of 1,000 gallon of No. 2 fuel oil is equivalent to the use of 0.22 MMSCF of equivalent natural gas. When operating in "full-speed, no load" mode for T1 & T2 controlled by Water Injection systems, the use of one (1) MMSCF of natural gas is equivalent to the use of 3.20 MMSCF of equivalent natural gas and the use of 1,000 gallon of No. 2 fuel oil is equivalent to the use of 1.20 MMSCF of equivalent natural gas.~~
- ~~(b) The use of 1,000 gallon of No. 2 fuel oil is equivalent to the use of 0.39 MMSCF of equivalent natural gas. When operating in "full-speed, no load" mode for T3 controlled by Lean-Premix systems, the use of one (1) MMSCF of natural gas is equivalent to the use of 7.9 MMSCF of equivalent natural gas and the use of 1,000 gallon of No. 2 fuel oil is equivalent to the use of 2.94 MMSCF of equivalent natural gas.~~

**Natural Gas equivalent conversion factors:**

- (1) For every one (1) MMSCF consumed by turbine T3, the natural gas equivalent limit shall be reduced by one (1) MMSCF.**
- (2) For every one (1) MMSCF consumed by turbine T1 or T2 during normal operation, the natural gas equivalent limit shall be reduced by 2.47 MMSCF.**
- (3) For every one (1) thousand gallons of fuel oil (kgal) consumed by turbine T3, the natural gas equivalent limit shall be reduced by 0.392 MMSCF.**
- (4) For every one (1) thousand gallons of fuel oil (kgal) consumed by turbine T1 or T2 during normal operation, the natural gas equivalent limit shall be reduced by 0.537 MMSCF.**
- (5) When operating in "full-speed, no load" mode for T1, T2 and T3, the use of one (1) MMSCF of natural gas is equivalent to the use of 7.9 MMSCF of equivalent natural gas and the use of 1,000 gallon of No. 2 fuel oil is equivalent to the use of 2.94 MMSCF of equivalent natural gas.**

...

<b>IDEM Contact</b>
---------------------

Questions regarding this proposed permit can be directed to:

Anh Nguyen  
Indiana Department Environmental Management  
Office of Air Quality  
100 North Senate Avenue  
MC 61-53, Room 1003  
Indianapolis, Indiana 46204-2251  
Toll free (within Indiana): 1-800-451-6027 extension (3-5334)  
Or dial directly: (317) 233-5334  
[pnguyen@idem.in.gov](mailto:pnguyen@idem.in.gov)

Please reference permit number T 095-30940-00051 in all correspondence.



**Indiana Department of Environmental Management**  
Office of Air Quality

Technical Support Document (TSD) for a Part 70 Operating Permit Renewal

**Source Background and Description**

<b>Source Name:</b>	<b>Indiana Municipal Power Agency – Anderson Station</b>
<b>Source Location:</b>	<b>6035 Park Road, Anderson, Indiana 46011</b>
<b>County:</b>	<b>Madison</b>
<b>SIC Code:</b>	<b>4911</b>
<b>Permit Renewal No.:</b>	<b>T 095-30940-00051</b>
<b>Permit Reviewer:</b>	<b>Anh Nguyen</b>

The Office of Air Quality (OAQ) has reviewed the operating permit renewal application from Indiana Municipal Power Agency – Anderson Station relating to the operation of a gas turbine electric generating plant. On September 19, 2011, Indiana Municipal Power Agency – Anderson Station submitted an application to the OAQ requesting to renew its operating permit. Indiana Municipal Power Agency – Anderson Station was issued its first Part 70 Operating Permit Renewal T095-22506-00051 on July 25, 2007. This source is an ESP source.

**Permitted Emission Units and Pollution Control Equipment**

The source consists of the following permitted emission units:

- (a) Two (2) 38.7 MW natural gas-fired simple cycle gas turbines, identified as T1 and T2, constructed in 1990, using No. 2 fuel oil as the back-up fuel, controlled by a water injection system, each with a maximum heat input capacity of 431 MMBtu/hr while combusting natural gas and a maximum heat input capacity of 425 MMBtu/hr while combusting No. 2 fuel oil (at ISO conditions), and exhausting to stacks 3 and 4, respectively. Under 40 CFR Part 60, Subpart GG, turbines T1 and T2 are considered stationary gas turbines.
- (b) One (1) 84 MW natural gas-fired simple cycle gas turbine, identified as T3, constructed in 2002, using No. 2 fuel oil as the back-up fuel, with a maximum heat input capacity of 858 MMBtu/hr while combusting natural gas and a maximum heat input capacity of 850 MMBtu/hr while combusting No. 2 fuel oil (at ISO conditions), and exhausting to stack 7. This unit is a lean premix combustion turbine. Under 40 CFR Part 60, Subpart GG, turbine T3 is considered a stationary gas turbine.
- (c) Two (2) diesel-fired black start stationary Rice, identified as D7 and D8, constructed in 1990, each with a maximum power output of 630 horsepower and a maximum heat input of 2 MMBtu/hr, exhausting to stacks 5 and 6, respectively. [40 CFR 63, Subpart ZZZZ]

**Emission Units and Pollution Control Equipment Constructed and/or Operated without a Permit**

There are no unpermitted emission units operating at this source during this review process.

### **Emission Units and Pollution Control Equipment Removed From the Source**

There are no new emission units or pollution control equipment included in this Part 70 operating permit renewal.

### **Insignificant Activities**

The source also consists of the following insignificant activities, as defined in 326 IAC 2-7-1(21):

- (a) Natural gas-fired combustion sources with heat input equal to or less than ten million (10,000,000) Btu per hour, including one the following:
  - (1) One (1) natural gas-fired heater, constructed in 2002, with a maximum heat input capacity of 2 MMBtu/hr.
  - (2) One (1) natural gas-fired heater, with a maximum heat input capacity of 0.003 MMBtu/hr.
- (b) Combustion source flame safety purging on startup.
- (c) Storage tanks with capacity less than or equal to 1,000 gallons and annual throughputs less than 12,000 gallons, including two (2) diesel storage tanks, each with a maximum capacity of 350 gallons.
- (d) Closed loop heating and cooling systems.
- (e) Activities associated with the treatment of wastewater streams with an oil and grease content less than or equal to 1% by volume.
- (f) Heat exchanger cleaning and repair.
- (g) Purging of gas lines and vessels that is related to routine maintenance and repair of buildings, structures, or vehicles at the source where air emissions from those activities would not be associated with any production process.
- (h) Equipment used to collect any material that might be released during a malfunction, process upset, or spill cleanup, including catch tanks, temporary liquid separators, tanks, and fluid handling equipment.
- (i) Blowdown for any of the following: sight glass; boiler; compressors; pumps; and cooling tower.
- (j) Filter or coalescer media changeout.
- (k) Emission units, not regulated by a NESHAP, with PM<sub>10</sub>, NO<sub>x</sub>, and SO<sub>2</sub> emissions less than five (5) pounds per hour or twenty-five (25) pounds per day, CO emissions less than twenty-five (25) pounds per day, VOC emissions less than three (3) pounds per hour or fifteen (15) pounds per day, lead emissions less than six-tenths (0.6) tons per year or three and twenty-nine hundredths (3.29) pounds per day, and emitting greater than one (1) pound per day but less than five (5) pounds per day or one (1) ton per year of a single HAP, or emitting greater than one (1) pound per day but less than twelve and five tenths (12.5) pounds per day or two and five tenths (2.5) tons per year of any combination of HAPs, including two (2) No. 2 fuel oil storage tanks, identified as FT10 and FT11, constructed in 1990, each with a maximum storage capacity of 300,000 gallons.

**Existing Approvals**

Since the issuance of the Part 70 Operating Permit T095-22506-00051 on July 25, 2007, the source has constructed or has been operating under the following additional approvals:

- (a) Administrative Amendment No. 095-27589-00051 issued on March 12, 2009; and
- (b) Significant Permit Modification No. 095-26304-00051 issued on March 05, 2009

All terms and conditions of previous permits issued pursuant to permitting programs approved into the State Implementation Plan have been either incorporated as originally stated, revised, or deleted by this permit. All previous registrations and permits are superseded by this permit.

**Enforcement Issue**

There are no enforcement actions pending.

**Emission Calculations**

See Appendix A of this document for detailed emission calculations.

**County Attainment Status**

The source is located in **Madison** County.

Pollutant	Designation
SO <sub>2</sub>	Cannot be classified.
CO	Unclassifiable or attainment effective November 15, 1990.
O <sub>3</sub>	Unclassifiable or attainment effective June 15, 2004, for the 8-hour ozone standard. <sup>1</sup>
PM <sub>10</sub>	Unclassifiable effective November 15, 1990.
NO <sub>2</sub>	Cannot be classified or better than national standards.
Pb	Not designated.

<sup>1</sup>Unclassifiable or attainment effective October 18, 2000, for the 1-hour ozone standard which was revoked effective June 15, 2005.  
 Basic nonattainment designation effective federally April 5, 2005, for the Madison Twp for PM<sub>2.5</sub>. The remainder of Jefferson County is unclassifiable or attainment effective April 5, 2005, for PM<sub>2.5</sub>.

- (a) Ozone Standards

Volatile organic compounds (VOC) and Nitrogen Oxides (NO<sub>x</sub>) are regulated under the Clean Air Act (CAA) for the purposes of attaining and maintaining the National Ambient Air Quality Standards (NAAQS) for ozone. Therefore, VOC and NO<sub>x</sub> emissions are considered when evaluating the rule applicability relating to ozone. Madison County has been designated as attainment or unclassifiable for ozone. Therefore, VOC and NO<sub>x</sub> emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2.

- (b) PM<sub>2.5</sub>

Madison County has been classified as attainment for PM<sub>2.5</sub>. On May 8, 2008, U.S. EPA promulgated the requirements for Prevention of Significant Deterioration (PSD) for PM<sub>2.5</sub> emissions. These rules became effective on July 15, 2008. On May 4, 2011 the air pollution control board issued an emergency rule establishing the direct PM<sub>2.5</sub> significant level at ten (10) tons per year. This rule became effective, June 28, 2011.. Therefore,

direct PM<sub>2.5</sub> and SO<sub>2</sub> emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2. See the State Rule Applicability – Entire Source section.

- (c) Other Criteria Pollutants  
 Madison County has been classified as attainment or unclassifiable in Indiana for all other criteria pollutants. Therefore, these emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2.

**Fugitive Emissions**

Since this type of operation is not one of the twenty-eight (28) listed source categories under 326 IAC 2-2, 326 IAC 2-3, or 326 IAC 2-7, and there is no applicable New Source Performance Standard that was in effect on August 7, 1980, fugitive emissions are not counted toward the determination of PSD, Emission Offset, and Part 70 Permit applicability.

**Unrestricted Potential Emissions**

This table reflects the unrestricted potential emissions of the source.

Unrestricted Potential Emissions	
Pollutant	Tons/year
PM	90.4
PM <sub>10</sub>	90.4
PM <sub>2.5</sub>	90.4
SO <sub>2</sub>	3804.5
VOC	15.82
CO	617.76
NO <sub>x</sub>	6629.6
GHGs as CO <sub>2</sub> e	1,161,527
Single HAP	5.35
Total HAP	7.35

Appendix A of this TSD reflects the unrestricted potential emissions of the source.

- (a) The potential to emit (as defined in 326 IAC 2-7-1(29)) of SO<sub>2</sub>, CO, and NO<sub>x</sub> are equal to or greater than 100 tons per year. Therefore, the source is subject to the provisions of 326 IAC 2-7 and will be issued a Part 70 Operating Permit Renewal.
- (b) The potential to emit (as defined in 326 IAC 2-7-1(29)) of GHGs is equal to or greater than one hundred thousand (100,000) tons of CO<sub>2</sub> equivalent emissions (CO<sub>2</sub>e) per year. Therefore, the source is subject to the provisions of 326 IAC 2-7.
- (c) The potential to emit (as defined in 326 IAC 2-7-1(29)) of any single HAP is less than or ten (10) tons per year and/or the potential to emit (as defined in 326 IAC 2-7-1(29)) of a combination of HAPs is less than twenty-five (25) tons per year. Therefore, the source is is an area source under Section 112 of the Clean Air Act (CAA).

**Part 70 Permit Conditions**

This source is subject to the requirements of 326 IAC 2-7, because the source met the following:

- (a) Emission limitations and standards, including those operational requirements and limitations that assure compliance with all applicable requirements at the time of issuance of Part 70 permits.
- (b) Monitoring and related record keeping requirements which assume that all reasonable information is provided to evaluate continuous compliance with the applicable requirements.

**Potential to Emit After Issuance**

The table below summarizes the potential to emit, reflecting all limits, of the emission units. Any new control equipment is considered federally enforceable only after issuance of this Part 70 permit renewal, and only to the extent that the effect of the control equipment is made practically enforceable in the permit.

Process/ Emission Unit	Potential To Emit of the Entire Source After Issuance of Renewal (tons/year)									
	PM	PM <sub>10</sub> *	PM <sub>2.5</sub> **	SO <sub>2</sub>	NO <sub>x</sub>	VOC	CO	GHGs	Total HAPs	Worst Single HAP
Turbines (T1, T2, T3)	26.7	26.7	26.7	240	246	8.46	246	476,887	3.93	2.86
Engines (D7 and D8)	0.02	0.02	0.02	0.08	0.49	0.01	0.13	73.06	Negl.	Negl.
Natural Gas Heaters	0.02	0.07	0.07	0.01	0.88	0.05	0.74	1053	.02	Negl.
Storage Tanks	Negl.	Negl.	Negl.	Negl.	Negl.	1.00	Negl.	Negl.	Negl.	Negl.
<b>Total PTE of Entire Source</b>	<b>26.7</b>	<b>26.7</b>	<b>26.7</b>	<b>241</b>	<b>248</b>	<b>9.52</b>	<b>247</b>	<b>478,012</b>	<b>3.95</b>	<b>2.86</b>
Title V Major Source Thresholds	NA	100	100	100	100	100	100	100,000 CO <sub>2</sub> e	<25	<10
PSD Major Source Thresholds	250	250	250	250	250	250	250	100,000 CO <sub>2</sub> e	NA	NA
negl. = negligible *Under the Part 70 Permit program (40 CFR 70), particulate matter with an aerodynamic diameter less than or equal to a nominal 10 micrometers (PM10), not particulate matter (PM), is considered as a "regulated air pollutant". **PM <sub>2.5</sub> listed is direct PM <sub>2.5</sub> .										

- (a) This existing source is not a major stationary source, under PSD (326 IAC 2-2), because no regulated pollutant is emitted at a rate of 250 tons per year or more, it is not one of the twenty-eight (28) listed source categories, as specified in 326 IAC 2-2-1(gg)(1), and the source has not undertaken a physical change or change in the method of operation on or after July 1, 2011 that resulted in an emissions increase of seventy-five thousand (75,000) tpy CO<sub>2</sub>e or more.

### Federal Rule Applicability

- (a) Pursuant to 40 CFR 64.2, Compliance Assurance Monitoring (CAM) is applicable to each existing pollutant-specific emission unit that meets the following criteria:
- (1) has a potential to emit before controls equal to or greater than the major source threshold for the pollutant involved;
  - (2) is subject to an emission limitation or standard for that pollutant; and
  - (3) uses a control device, as defined in 40 CFR 64.1, to comply with that emission limitation or standard.

These Gas Turbines T1, T2 and T3 have the potential to emit of NO<sub>x</sub> and CO in excess of the major source of threshold of 100 TPY. These units are subject to an emission limit or other standard for NO<sub>x</sub> and CO and these units use a control device for NO<sub>x</sub> to comply with the emission limit or standard. However, pursuant to 40 CFR 64.2(b)(1), any facility subject to the requirements of Sections 404 through 407(b) or 410 of the Acid Rain Program are exempt from the requirements of 40 CFR 64. Since turbines T1, T2, and T3 are subject to requirements of the Acid Rain Program, these units are exempt from the requirements of 40 CFR 64 (Continuous Assurance Monitoring).

### NSPS

- (b) The NO<sub>x</sub> emissions from turbines T1 and T2 are controlled by water injection systems. Turbine T3 is a lean premix combustion turbine. The three (3) combustion turbines (T1, T2, and T3), which use No. 2 fuel oil as a back-up fuel are subject to the Standards of Performance for Stationary Gas Turbines (40 CFR 60.330-60.335, Subpart GG), which is incorporated by reference as 326 IAC 12. These three (3) turbines are subject to the requirements of this rule because they have heat input capacities greater than 10 MMBtu/hr and were constructed after October 3, 1977.

Turbines T1, T2, and T3, are subject to the following portions of Subpart GG:

1. 40 CFR 60.330
2. 40 CFR 60.331
3. 40 CFR 60.332(a)(1) and (b)
4. 40 CFR 60.333(a), (b)
5. 40 CFR 60.334(a), (g), (h)(1), (h)(3), (i)(1), (j)(1)(i), (j)(2), (j)(5)
6. 40 CFR 60.335(a), (b)(1), (b)(2), (b)(4), (b)(8), (b)(10), (b)(11), and (c)(1)

The provisions of 40 CFR 60 Subpart A – General Provisions, which are incorporated as 326 IAC 12-1, apply to the turbines described in this section, except when otherwise specified in 40 CFR 60, Subpart GG.

- (c) The three (3) combustion turbines (T1, T2, and T3) are not subject to the Standards of Performance for Stationary Combustion Turbines (40 CFR 60.4305, Subpart KKKK), because the turbines do not have emissions from any associated heat recovery steam generators (HRSG) or duct burners, and because the turbines were constructed prior to the applicability date of February 18, 2005. Therefore 40 CFR 60.4305, Subpart KKKK does not apply to the turbines.
- (d) The diesel-fired emergency engines, identified as D7 and D8, are not subject to the Standards of Performance for Stationary Compression Ignition Internal Combustion

Engines (40 CFR 60.4200, Subpart IIII), because the engines were manufactured prior to the applicability date of July 11, 2005 and have not been reconstructed

- (e) No. 2 fuel oil storage tanks FT10 and FT11 were constructed in 1990 and each has a maximum capacity greater than 75 cubic meters (19,813 gallons). However, the liquids stored in these tanks have a maximum true vapor pressure of less than 3.5 kPa. Therefore, tanks FT10 and FT11 are exempt from the requirements of the Standards of Performance for Volatile Organic Liquid Storage Vessels for Which Construction, Reconstruction, or Modification Commenced After July 23, 1984 (40 CFR 60.110b - 117b, Subpart Kb), pursuant to 40 CFR 60.110b(b).

## NESHAP

- (f) The Two (2) diesel-fired black start stationary Rice, identified as D7 and D8 are not subject to the National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines (40 CFR 63, Subpart YYYY) because the engines are minor source for HAPs.
- (g) The requirements of the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE) (40 CFR 63, Subpart ZZZZ), (326 IAC 20-82) with a compliance date of May 3, 2013 are included in this permit for the Two (2) diesel-fired black start stationary Rice, identified as D7 and D8 at this source because the units are existing black start stationary RICE, manufactured before June 12, 2006 and have a site rating of greater than 500 brake horsepower (HP) and are located at an area source of HAP emissions.

Diesel-fired black start stationary Rice start-up engines, D7 and D8 are subject to the following portions of Subpart ZZZZ:

- (1) 40 CFR 63.6580
- (2) 40 CFR 63.6585
- (3) 40 CFR 63.6590(a)(1)(iii)
- (4) 40 CFR 63.6595(a)(1), (b), and (c)
- (5) 40 CFR 63.6603
- (6) 40 CFR 63.6604 (for >300 HP)
- (7) 40 CFR 63.6605
- (8) 40 CFR 63.6612
- (9) 40 CFR 63.6615
- (10) 40 CFR 63.6620
- (11) 40 CFR 63.6625(e)(3), (h) and (i)
- (12) 40 CFR 63.6645(a)(5), (g) and (h)
- (13) 40 CFR 63.6655 (e)(2)
- (14) 40 CFR 63.6660
- (15) 40 CFR 63.6665
- (16) 40 CFR 63.6670
- (17) 40 CFR 63.6675

The provisions of 40 CFR 63 Subpart A – General Provisions, which are incorporated as 326 IAC 20-1-1, apply to the facilities described in this section except when otherwise specified in 40 CFR 63 Subpart ZZZZ.

## Clean Air Interstate Rule (CAIR)

- (h) This source is subject to the requirements of 40 CFR Part 72 through 40 CFR Part 80 (Acid Rain Program). The requirements of this program are detailed in the Acid Rain

Permit Renewal #095-28886-00051, issued on March 29, 2010, included as Appendix A to the permit.

- (h) 326 IAC 24-1 (Clean Air Interstate Rule (CAIR) Nitrogen Oxides (NO<sub>x</sub>) Annual Trading Program): This rule establishes an annual NO<sub>x</sub> emissions budget and an annual NO<sub>x</sub> trading program for any stationary fossil fuel-fired boiler or stationary fossil-fuel-fired combustion turbine, serving since the later of November 15, 1990 or the start-up of the unit's combustion chamber, a generator with a nameplate capacity of more than twenty-five (25) megawatt electrical producing electricity for sale. Therefore, this rule is applicable to the combustion turbines, identified as T1, T2 and T3.
- (i) 326 IAC 24-2 (Clean Air Interstate Rule (CAIR) Sulfur Dioxide (SO<sub>2</sub>) Trading Program): This rule establishes an SO<sub>2</sub> emissions budget and an SO<sub>2</sub> trading program for any stationary fossil-fuel-fired boiler or stationary fossil-fuel-fired combustion turbine, serving since the later of November 15, 1990 or the start-up of the unit's combustion chamber, a generator with a nameplate capacity of more than twenty-five (25) megawatt electrical producing electricity for sale. Therefore, this rule is applicable to the combustion turbines, identified as T1, T2 and T3.
- (j) 326 IAC 24-3 (Clean Air Interstate Rule (CAIR) NO<sub>x</sub> Ozone Season Trading Program): This rule establishes a NO<sub>x</sub> ozone season emissions budget and a NO<sub>x</sub> trading program for fossil-fuel-fired generating units and large affected units. This rule applies to any stationary, fossil-fuel-fired boiler or stationary, fossil-fuel-fired combustion turbine serving at any time, since the later of November 15, 1990 or the start-up of the unit's combustion chamber, a generator with a nameplate capacity of more than twenty-five (25) megawatt electrical producing electricity for sale or any large affected unit. Therefore, this rule is applicable to the combustion turbines, identified as T1, T2 and T3.

Cross-State Air Pollution Rule (CSAPR)

- (k) On July 6, 2011, the U.S. EPA finalized a rule that helps states reduce air pollution and attain clean air standards. This rule, known as the Cross-State Air Pollution Rule (CSAPR), requires states to significantly improve air quality by reducing power plant emissions that contribute to ozone and fine particle pollution. In December 2008, a court decision kept the requirements of CAIR in place temporarily but directed EPA to issue a new rule (the Cross-State Air Pollution Rule) to implement Clean Air Act requirements concerning the transport of air pollution across state boundaries. On December 30, 2011, the United State Court of Appeals for the District of Columbia Circuit issued a ruling to stay the CSAPR pending judicial review (USCA Case #11-1302, Document #1350421). Pending judicial review, the requirements of CSAPR apply to the combustion turbines but are not included in this permit.

<b>State Rule Applicability - Entire Source</b>
---

326 IAC 2-2 (Prevention of Significant Deterioration (PSD) Requirements)

This electric utility generating plant was constructed in 1990 and modified in 2002. This source is not in 1 of the 28 source categories and the potential to emit CO, NO<sub>x</sub>, and SO<sub>2</sub> from the entire source are greater than 250 tons/yr before control.

In order to render the requirements of 326 IAC 2-2 (PSD) not applicable for the criteria pollutants, the Permittee shall comply with the following:

Combustion turbines

- (a) Emissions from turbines T1 and T2 shall be controlled by Water Injection systems and Emissions from turbines T3 shall be controlled by Lean-Premix systems when operating on natural gas and by Water Injection system when operating on No.2 fuel.

The total equivalent natural gas used in turbines T1, T2 and T3 shall be limited to less than 7900 million standard cubic feet (MMSCF) per twelve (12) consecutive month period with compliance determined at the end of each month.

- (1) For every one (1) MMSCF consumed by turbine T3, the natural gas equivalent limit shall be reduced by one (1) MMSCF.
  - (2) For every one (1) MMSCF consumed by turbine T1 or T2 during normal operation, the natural gas equivalent limit shall be reduced by 2.47 MMSCF.
  - (3) For every one (1) thousand gallons of fuel oil (kgal) consumed by turbine T3, the natural gas equivalent limit shall be reduced by 0.392 MMSCF.
  - (4) For every one (1) thousand gallons of fuel oil (kgal) consumed by turbine T1 or T2 during normal operation, the natural gas equivalent limit shall be reduced by 0.537 MMSCF.
- (b) During normal operation, the NOx and CO emissions from each of the turbines T1, T2, and T3 shall not exceed the emission limits listed in the table below:

Emission Limits for T1 and T2 (Normal Operation)		
Type of Fuel	NOx Emission Limit	CO Emission Limit
Natural Gas	153 lbs/MMCF	153 lbs/MMCF
No. 2 Fuel Oil	33.4 lbs/kgal	33.4 lbs/kgal
Emission Limits for T3 (Normal Operation)		
Natural Gas	62.2 lbs/MMCF	62.22 lbs/MMCF
No. 2 Fuel Oil	24.4 lbs/kgal	24.4 lbs/kgal

- (c) When operating in "full-speed, no load" mode, the NOx and CO emissions from each of the turbines (T1, T2, and T3) shall not exceed the emission limits listed in the table below:

Emission Limits for T1 ,T2, and T3 -NO LOAD		
Type of Fuel	NOx Emission Limit	CO Emission Limit
Natural Gas	490 lbs/MMCF	490 lbs/MMCF
No. 2 Fuel Oil	183 lbs/kgal	183 lbs/kgal

- (d) When operating in "full-speed, no load" mode for T1, T2 and T3, the use of one (1) MMSCF of natural gas is equivalent to the use of 7.9 MMSCF of equivalent natural gas and the use of 1,000 gallon of No. 2 fuel oil is equivalent to the use of 2.94 MMSCF of equivalent natural gas.
- (e) The Permittee shall perform NOx and CO stack tests for a turbine if its operating hours in "full-speed, no load" mode exceed twenty (20) hours per twelve (12) consecutive month period with compliance determined at the end of each month.
- (f) The sulfur content of the No. 2 fuel oil combusted in turbine T1, T2, or T3 shall not exceed 0.17% by weight.

**Reciprocating Internal Combustion Engines**

In order to render the requirements of 326 IAC 2-2 (PSD) not applicable, the Permittee shall comply with the following:

- (a) The total amount of No. 2 fuel oil used in the diesel engines (D7 and D8) shall not exceed 2200 gallons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (b) The NOx and CO emissions from each of the diesel fired engines (D7 and D8) shall not exceed the following:

Type of Fuel	NOx Emission Limit (lbs/gal)	CO Emission Limit (lbs/gal)
Diesel	0.448	0.119

Compliance with the above limits, Condition D.1.1 and combined with the NOx and CO emissions from other emission units, the potential to emit of NOx and CO from the entire source are each limited to less than 250 tons per year, and renders the requirements of 326 IAC 2-2 (PSD) are not applicable to this source.

**326 IAC 2-6 (Emission Reporting)**

This source, not located in Lake, Porter, or LaPorte County, is subject to 326 IAC 2-6 (Emission Reporting); because, it is required to have an operating permit pursuant to 326 IAC 2-7 (Part 70). The potential to emit, as defined in 326 IAC 2-7-1(29), of VOC and PM10 is less than 250 tons per year; and the potential to emit of CO, NOx, and SO2 is less than 2,500 tons per year; and the potential to emit of CO, NOx, and SO2 is less than 2,500 tons per year. Therefore, pursuant to 326 IAC 2-6-3(b)(2), triennial reporting is required. An emission statement shall be submitted in accordance with the compliance schedule in 326 IAC 2-6-3 by July 1, 2014, and every three (3) years thereafter. The emission statement shall contain, at a minimum, the information specified in 326 IAC 2-6-4.

**326 IAC 5-1 (Opacity Limitations)**

This source is subject to the opacity limitations specified in 326 IAC 5-1-2(1)

<b>State Rule Applicability – Individual Facilities</b>
---

**326 IAC 8-1-6 (New facilities; general reduction requirements)**

This rule applies to new facilities as of January 1, 1980, that have potential emissions of twenty-five (25) tons per year or more of VOC, are located anywhere in the state, and are not otherwise regulated under Article 8, 326 IAC 20-48 or 326 IAC 20-56. The turbines, T1, T2, and T3 and the diesel engines, D7 & D8, have potential emissions less than 25 TPY. Therefore, this rule does not apply to the turbines or diesel engines.

**326 IAC 2-4.1 (Major Sources of Hazardous Air Pollutants)**

The operation of the turbine T3 which was constructed after 1997 will emit less than 10 tons per year of a single HAP and less than 25 tons per year of a combination of HAPs. Therefore, 326 IAC 2-4.1 does not apply. T1, T2 and the two diesel engine, D7 and D8, were constructed before 1997, therefore those rules do not apply.

**326 IAC 3-5 (Continuous Monitoring of Emissions)**

This rule does not apply to the turbines or engines because these emission units are located in Madison County and are not steam generating units.

**326 IAC 6-2 (Particulate Emissions Limitations for Sources of Indirect Heating)**

The combustion turbines (T1, T2, and T3) are not subject to the requirements of 326 IAC 6-2 because they are not sources of indirect heating.

**326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes)**

Combustion turbines are not considered manufacturing processes. Therefore, the requirements of 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes) are not applicable to turbines T1, T2, and T3.

**326 IAC 7-1.1 (Sulfur Dioxide Emission Limitations)**

- (a) The potential to emit SO<sub>2</sub> emissions from each of the turbines, T1, T2, T3 is greater than 25 tons/year or 10 pounds/hour when operating on No.2 fuel oil. Therefore, the requirements of 326 IAC 7-1.1 are applicable. pursuant to 326 IAC 7-1.1-2, the SO<sub>2</sub> emissions from each of these turbines shall not exceed five-tenth (0.5) pounds per million British thermal units when operating on No.2 fuel oil

Note : There are no specific SO<sub>2</sub> emission limitations in 326 IAC 7-1.1-2 for units combusting natural gas only.

- (b) The potential to emit SO<sub>2</sub> emissions from each of the diesel engines, D7 and D8, is less than 25 tons/yr. Therefore, these units are not subject to the requirements of 326 IAC 326 IAC 7-1.
- (c) The potential to emit SO<sub>2</sub> emissions from the gas heater is less than 25 tons/yr. Therefore, the unit is not subject to the requirements of 326 IAC 326 IAC 7-1.

**326 IAC 2-7-24 (Streamlined Requirements)**

The Permittee shall comply with the following for the turbines T1 and T2:

- (a) NO<sub>x</sub> emissions from each of turbines shall be limited to the following:
- (1) Less than 42 ppmv at 15% oxygen while combusting natural gas.
  - (2) Less than 65 ppmv at 15% oxygen while combusting No. 2 fuel oil.
- (b) The sulfur content of any fuel used shall be limited to less than 0.17% sulfur by weight.
- (c) Visible emissions shall not exceed 20% opacity.

Compliance with the requirements above ensures compliance with the SO<sub>2</sub> emission limits in 326 IAC 7-1.1-2 and the NO<sub>x</sub> emission limits in 40 CFR 60, Subpart GG for turbines T1 and T2.

**326 IAC 9-1-2 (Carbon Monoxide Emission Requirements)**

This source is not among the listed source categories in 326 IAC 9-1-2. Therefore, the requirements of 326 IAC 9-1-2 are not applicable.

**326 IAC 10-4-16( Nitrogen Oxides)**

This rule shall not apply to any control period in 2009 or thereafter. The 2009 NO<sub>x</sub> allowances allocated under section 9 remain in effect for purposes of the Clean Air Interstate Rule (CAIR) NO<sub>x</sub> ozone season trading program in 326 IAC 24-3

**326 IAC 6-2 (Particulate Emissions Limitations for Sources of Indirect Heating)**

The natural gas-fired heaters are not subject to the requirements of 326 IAC 6-2 because they are not sources of indirect heating.

**326 IAC 6-3-2 (Particulate Emissions Limitations for Manufacturing Processes)**

The natural gas-fired heaters are not considered manufacturing processes. Therefore, the requirements of 326 IAC 6-3-2 are not applicable.

**326 IAC 8-9 (Volatile Organic Liquid Storage Vessels)**

This source is not located in Clark, Floyd, Lake, or Porter County. Therefore, the requirements of 326 IAC 8-9 are not applicable to the storage tanks at this source.

**Compliance Determination and Monitoring Requirements**

Permits issued under 326 IAC 2-7 are required to ensure that sources can demonstrate compliance with all applicable state and federal rules on a continuous basis. All state and federal rules contain compliance provisions; however, these provisions do not always fulfill the requirement for a continuous demonstration. When this occurs, IDEM, OAQ, in conjunction with the source, must develop specific conditions to satisfy 326 IAC 2-7-5. As a result, Compliance Determination Requirements are included in the permit. The Compliance Determination Requirements in Section D of the permit are those conditions that are found directly within state and federal rules and the violation of which serves as grounds for enforcement action.

If the Compliance Determination Requirements are not sufficient to demonstrate continuous compliance, they will be supplemented with Compliance Monitoring Requirements, also in Section D of the permit. Unlike Compliance Determination Requirements, failure to meet Compliance Monitoring conditions would serve as a trigger for corrective actions and not grounds for enforcement action. However, a violation in relation to a compliance monitoring condition will arise through a source's failure to take the appropriate corrective actions within a specific time period.

The compliance monitoring requirements applicable to this source are as follows:

- (a) In order to comply with the PSD minor limit for NOx, the water injection system and the lean premix combustion for NOx, control shall be in operation and control emissions from turbine T1, T2, and T3 when these units are in operation.
- (b) Testing requirements are as follows:

<b>Emission Unit</b>	<b>Control Device</b>	<b>Timeframe for Testing</b>	<b>Pollutant</b>	<b>Frequency of Testing</b>
Turbine T1	Water Injection	Within 5 years of last compliant stack test	CO, NOx	Every 5 Years
Turbine T2	Water Injection	Within 5 years of last compliant stack test	CO, NOx	Every 5 Years
Turbine T3	Lean Premix combustion	Within 5 years of last compliant stack test	CO, NOx	Every 5 Years

- (c) The emissions from the diesel fired engines (D7 and D8) are limited to less than 1.0 ton per year for each pollutant by limiting the usage of diesel fuel. Therefore, no stack testing is required for the diesel fired engines.

The compliance monitoring requirements applicable to this source are as follows:

Control	Parameter	Frequency	Range	Excursions and Exceedances
Turbine #1	Visible Emissions	Daily during daylight when combusting fuel oil	Normal-Abnormal	Response Steps
Turbine #2	Visible Emissions	Daily during daylight when combusting fuel oil	Normal-Abnormal	Response Steps
Turbine #3	Visible Emissions	Daily during daylight when combusting fuel oil	Normal-Abnormal	Response Steps

These monitoring conditions are necessary to ensure compliance with 326 IAC 5 (Opacity Regulations).

There are no specific compliance monitoring requirements for the diesel fired start-up engines (D7 and D8).

#### Recommendation

The staff recommends to the Commissioner that the Part 70 Operating Permit Renewal be approved. This recommendation is based on the following facts and conditions:

Unless otherwise stated, information used in this review was derived from the application and additional information submitted by the applicant.

An application for the purposes of this review was received on September 20, 2011.

#### Conclusion

The operation of this stationary gas turbine electric generating station shall be subject to the conditions of the attached Part 70 Operating Permit Renewal No. T 095-30940-00051.

#### IDEM Contact

- (a) Questions regarding this proposed permit can be directed to Anh Nguyen at the Indiana Department Environmental Management, Office of Air Quality, Permits Branch, 100 North Senate Avenue, MC 61-53 IGCN 1003, Indianapolis, Indiana 46204-2251 or by telephone at (317) 233-5334 or toll free at 1-800-451-6027 extension (3-5334).
- (b) A copy of the findings is available on the Internet at: <http://www.in.gov/ai/appfiles/idem-caats/>
- (c) For additional information about air permits and how the public and interested parties can participate, refer to the IDEM's Guide for Citizen Participation and Permit Guide on the Internet at: [www.idem.in.gov](http://www.idem.in.gov)

**Appendix A: Emission Calculations  
Limited PTE Summary**

**Company Name: Indiana Municipal Power Agency - Anderson Station  
Address: 6035 Park Rd., Anderson, IN 46011  
Renewal #: T095-30940-00051  
Reviewer: Anh Nguyen  
Date: September 20, 2011**

**Worst Case****PTE of the Turbines (T1,T2,T3):**

Pollutant	PM	PM10	SO <sub>2</sub>	NO <sub>x</sub>	VOC	CO	HAP	Tot HAP	CO <sub>2e</sub>
Unlimited PTE (tons/yr)	89.40	89.40	3760.20	6552.50	3.10	24.60	CH <sub>2</sub> O 5.35	7.35	1,148,021

**Methodology**

Uncontrolled PTE (tons/yr) = Worst Case PTE (tons/yr) between Combusting NG and No. 2 Fuel Oil.

**Worst Case****PTE of the Turbines (T1,T2,T3) after Control:**

Pollutant	PM	PM10	SO <sub>2</sub>	NO <sub>x</sub>	VOC	CO	HAP	Tot HAP	CO <sub>2e</sub>
Limited PTE (tons/yr)	26.59	26.59	26.59	240.49	246.23	8.46	CH <sub>2</sub> O 2.86	3.93	476,887

**Methodology**

Limited PTE (tons/yr) = Worst Case PTE (tons/yr) Between Combusting NG and No. 2 Fuel Oil.

**Limited Potential To Emit after Control for the entire source**

Emission Units	PM	PM10	SO <sub>2</sub>	NO <sub>x</sub>	VOC	CO	Total HAPs	single HAP	CO <sub>2e</sub>
Turbines (T1, T2, and T3)	#REF!	#REF!	#REF!	#REF!	#REF!	#REF!	#REF!		476,887
Diesel Engines (D7 and D8)	0.02	0.02	0.08	0.49	0.01	0.13	Negligible	0.03	73.06
NG Fired Heaters	#REF!	#REF!	#REF!	#REF!	#REF!	#REF!	0.02	0.015792	1,053
Storage Tanks* (Insignificant)	-	-	-	-	1.00	-	Negligible	Negligible	Negligible
<b>Total PTE</b>	<b>#REF!</b>	<b>#REF!</b>	<b>#REF!</b>	<b>#REF!</b>	<b>#REF!</b>	<b>#REF!</b>	<b>#REF!</b>	<b>0.05</b>	<b>478012.84</b>

\* The PTE of storage tanks was calculated using the EPA TANKS software and is less than 1.0 tons/yr.

**PTE of the Turbines (T1,T2,T3):**

**Appendix A: Emission Calculations**  
**Criteria Pollutants**  
**From Turbines T1, T2, and T3**

**Company Name: Indiana Municipal Power Agency - Anderson Station**  
**Address: 6035 Park Rd., Anderson, IN 46011**  
**Renewal #: T095-30940-00051**  
**Reviewer: Anh Nguyen**  
**Date: September 20, 2011**

**1. Unlimited PTE While Combusting NG :**

Heat Input Capacity MMBtu/hr	Potential Throughput MMCF/yr	Sulfur Content (S) (%)
1,720 (3 units total)	15067.2	0.00008 (sulfur content of NG)

Emission Factor in lbs/MMBtu	Pollutant					
	PM*	PM10*	SO <sub>2</sub>	NO <sub>x</sub>	VOC	CO
	6.60E-03	6.60E-03	7.52E-05 (0.94S)	3.20E-01	2.10E-03	0.082
<b>Unlimited PTE (tons/yr)</b>	<b>49.7</b>	<b>49.7</b>	<b>0.6</b>	<b>2410.8</b>	<b>15.8</b>	<b>617.8</b>

\*PM and PM10 emission factors are condensable and filterable PM combined. Assume PM10 emissions equal PM emissions.  
Emission Factors from AP-42, Chapter 3.1, Tables 3.1-1 and 3.1-2: Emission Factors for Stationary Gas Turbines (04/00).

**Methodology**

Unlimited PTE (tons/yr) = Max. Input Capacity (MMBtu/hr) x Emission Factor (lbs/MMBtu) x 8760 hr/yr x 1 ton/2000 lbs

**Appendix A: Emission Calculations**  
**Unlimited HAP Emissions**  
**From Three (3) Gas Turbines (T1, T2, and T3)**

**1. Unlimited PTE While Combusting NG:**

Max. Heat Input MMBtu/hr	(for NG)
1,720 (3 units total)	

Emission Factor in lbs/MMBtu	Pollutant					
	Formaldehyde	Toluene	Xylene	Acetaldehyde	Ethylbenzene	Total
	7.10E-04	1.30E-04	6.40E-05	4.00E-05	3.20E-05	0.001
<b>Unlimited PTE (tons/yr)</b>	<b>5.35</b>	<b>0.98</b>	<b>0.48</b>	<b>0.30</b>	<b>0.24</b>	<b>7.35</b>

Note: Emission factors are from AP-42, Table 3.1-3 for NG fired gas turbines (AP-42, 04/00).

**Methodology**

Unlimited PTE (tons/yr) = Max. Heat Input (MMBtu/hr) x Emission Factor (lbs/MMBtu) x 8760 hr/yr x 1 ton/2000 lbs

**Appendix A: Emissions Calculations**

**Natural Gas Combustion Only**

**MM BTU/HR >100**

**Greenhouse Gas Emissions**

**Company Name: Indiana Municipal Power Agency - Anderson Station**

**Address: 6035 Park Rd., Anderson, IN 46011**

**Renewal #: T095-30940-00051**

**Reviewer: Anh Nguyen**

**Date: September 20, 2011**

	Greenhouse Gas		
	CO2	CH4	N2O
Emission Factor in lb/MMcf	120,000	2.3	2.2
Potential Emission in tons/yr	904,032	17	17
Summed Potential Emissions in tons/yr	904,066		
CO2e Total in tons/yr	909,534		

**Methodology**

The N2O Emission Factor for uncontrolled is 2.2. The N2O Emission Factor for low Nox burner is 0.64.  
Emission Factors are from AP 42, Table 1.4-2 SCC #1-02-006-02, 1-01-006-02, 1-03-006-02, and 1-03-006-03.  
Greenhouse Warming Potentials (GWP) from Table A-1 of 40 CFR Part 98 Subpart A.  
Emission (tons/yr) = Throughput (MMCF/yr) x Emission Factor (lb/MMCF)/2,000 lb/ton  
CO2e (tons/yr) = CO2 Potential Emission ton/yr x CO2 GWP (1) + CH4 Potential Emission ton/yr x CH4

**Appendix A: Emission Calculations**  
**Industrial Boilers (> 100 mmBtu/hr)**  
**From Turbines T1, T2, and T3**  
**Fuel #2**

**Company Name: Indiana Municipal Power Agency - Anderson Station**  
**Address: 6035 Park Rd., Anderson, IN 46011**  
**Renewal #: T095-30940-00051**  
**Reviewer: Anh Nguyen**  
**Date: September 20, 2011**

**Unlimited PTE While Combusting No. 2 Fuel Oil before Control:**

Heat Input Capacity MMBtu/hr	Potential Throughput kgals/year	Sulfur Content (S) (%)
3 units total		
1,700	106371.43	0.5

Emission Factor in lbs/MMBtu	Pollutant					
	PM*	PM10*	SO <sub>2</sub>	NO <sub>x</sub>	VOC	CO
	1.20E-02	1.20E-02	5.05E-01 (1.01S)	8.80E-01	4.10E-04	0.003
<b>Unlimited PTE (tons/yr)</b>	<b>89.4</b>	<b>89.4</b>	<b>3760.2</b>	<b>6552.5</b>	<b>3.1</b>	<b>24.6</b>

\*PM and PM10 emission factors are condensable and filterable PM combined. Assume PM10 emissions equal PM emissions.  
Emission Factors from AP-42, Chapter 3.1, Tables 3.1-1 and 3.1-2: Emission Factors for Stationary Gas Turbines (04/00).

**Methodology**

Unlimited PTE (tons/yr) = Max. Input Capacity (MMBtu/hr) x Emission Factor (lbs/MMBtu) x 8760 hr/yr x 1 ton/2000 lbs

**2. Unlimited HAP PTE While Combusting No. 2 Fuel Oil:**

Max. Heat Input MMBtu/hr	(for No. 2 fuel)
1,720	(3 units total)

Emission Factor in lbs/MMBtu	Pollutant					
	Formaldehyde	Benzene	PAH	Naphthalene	1,3-Butadiene	Total
	2.80E-04	5.50E-05	4.00E-05	3.50E-05	1.60E-05	4.260E-04
<b>Unlimited PTE (tons/yr)</b>	<b>2.08</b>	<b>0.41</b>	<b>0.30</b>	<b>0.26</b>	<b>0.12</b>	<b>3.17</b>

Note: Emission factors are from AP-42, Table 3.1-4 for distillate oil-fired gas turbines (AP-42, 04/00).

**Methodology**

Unlimited PTE (tons/yr) = Max. Heat Input (MMBtu/hr) x Emission Factor (lbs/MMBtu) x 8760 hr/yr x 1 ton/2000 lbs

**Appendix A: Emissions Calculations****Natural Gas Combustion Only****MM BTU/HR >100****Greenhouse Gas Emissions****Company Name: Indiana Municipal Power Agency - Anderson Station****Address: 6035 Park Rd., Anderson, IN 46011****Renewal #: T095-30940-00051****Reviewer: Anh Nguyen****Date: September 20, 2011**

Emission Factor in lb/kgal	Greenhouse Gas		
	CO2	CH4	N2O
	21,500	0.216	0.26
Potential Emission in tons/yr	1,143,493	11	14
Summed Potential Emissions in tons/yr	1,143,518		
CO2e Total in tons/yr	1,148,021		

**Methodology**

The CO2 Emission Factor for #1 Fuel Oil is 21500. The CO2 Emission Factor for #2 Fuel Oil is 22300.

Emission Factors are from AP 42, Tables 1.3-3, 1.3-8, and 1.3-12 (SCC 1-03-005-01/02/03) Supplement E 9/99 (see erata file)

Greenhouse Warming Potentials (GWP) from Table A-1 of 40 CFR Part 98 Subpart A.

Emission (tons/yr) = Throughput (kgals/ yr) x Emission Factor (lb/kgal)/2,000 lb/ton

CO2e (tons/yr) = CO2 Potential Emission ton/yr x CO2 GWP (1) + CH4 Potential Emission ton/yr x CH4 GWP (21) + N2O Potential Emission ton/yr x N2O GWP (310).

fo1&amp;2ind.xls 9/95

updated 7/11

**Appendix A: Emission Calculations**  
**Criteria Pollutants**  
**From NG Turbines T1, T2, and T3 with Limits**

**Company Name: Indiana Municipal Power Agency - Anderson Station**  
**Address: 6035 Park Rd., Anderson, IN 46011**  
**Renewal #: T095-30940-00051**  
**Reviewer: Anh Nguyen**  
**Date: September 20, 2011**

Turbine T3 is a lean-premix unit which has the lowest NO<sub>x</sub> emissions. Therefore, the equivalent fuel usage limits were calculated based on the emission factors for Turbine T3.

**1. Limited PTE While Combusting Only NG after Control:**

Fuel Usage Limit MMCF/yr	MMBtu/hr	Sulfur Content (S) (%)
7,900 (3 units total)	901.83	0.00008 (sulfur content of NG)

Emission Factor in lbs/MMBtu	Pollutant					
	PM*	PM10*	SO <sub>2</sub>	NO <sub>x</sub> **	VOC	CO**
	6.60E-03	6.60E-03	7.52E-05 (0.94S)	0.0373	2.10E-03	0.061
<b>Limited PTE (tons/yr)</b>	<b>26.6</b>	<b>26.6</b>	<b>0.3</b>	<b>150.3</b>	<b>8.5</b>	<b>245.8</b>

\* PM and PM10 emission factors are condensable and filterable PM combined. Assume PM10 emissions equal PM emissions.

\*\* These are the emission factors for turbine T3, which were provided by the vendor. The NO<sub>x</sub> emission factor has been verified by the stack test on 03/31/04. Emission factors for PM/PM10, SO<sub>2</sub>, and VOC are from AP-42, Chapter 3.1, Tables 3.1-1 and 3.1-2: Emission Factors for Stationary Gas Turbines (04/00).

**1. Limited HAP PTE While Combusting NG:**

Fuel Usage Limit MMCF/yr
7,900 (3 units total)

Emission Factor in lbs/MMBtu	Pollutant					Total
	Formaldehyd	Toluene	Xylene	Acetaldehyd	Ethylbenzen	
	7.10E-04	1.30E-04	6.40E-05	4.00E-05	3.20E-05	0.001
<b>Limited PTE (tons/yr)</b>	<b>2.86</b>	<b>0.52</b>	<b>0.26</b>	<b>0.16</b>	<b>0.13</b>	<b>3.93</b>

Note: Emission factors are from AP-42, Table 3.1-3 for NG fired gas turbines (AP-42, 04/00).

**Methodology**

Limited PTE (tons/yr) = Fuel Usage Limit (MMCF/yr) x 1,020 MMBtu/MMCF x Emission Factor (lbs/MMBtu) x 1 ton/2000 lbs

**Appendix A: Emissions Calculations**  
**Natural Gas Combustion Only**  
**MM BTU/HR >100**  
**Greenhouse Gas Emissions**  
**Company Name: Indiana Municipal Power Agency - Anderson Station**  
**Address: 6035 Park Rd., Anderson, IN 46011**  
**Renewal #: T095-30940-00051**  
**Reviewer: Anh Nguyen**  
**Date: September 20, 2011**

	Greenhouse Gas		
	CO2	CH4	N2O
Emission Factor in lb/MMcf	120,000	2.3	2.2
Potential Emission in tons/yr	474,002	9	9
Summed Potential Emissions in tons/yr	474,020		
CO2e Total in tons/yr	476,887		

**Methodology**

The N2O Emission Factor for uncontrolled is 2.2. The N2O Emission Factor for low Nox burner is 0.64.  
Emission Factors are from AP 42, Table 1.4-2 SCC #1-02-006-02, 1-01-006-02, 1-03-006-02, and 1-03-006-03.  
Greenhouse Warming Potentials (GWP) from Table A-1 of 40 CFR Part 98 Subpart A.  
Emission (tons/yr) = Throughput (MMCF/yr) x Emission Factor (lb/MMCF)/2,000 lb/ton  
CO2e (tons/yr) = CO2 Potential Emission ton/yr x CO2 GWP (1) + CH4 Potential Emission ton/yr x

**Methodology**

Limited PTE (tons/yr) = Fuel Usage Limit (MMCF/yr) x 1,020 MMBtu/MMCF x Emission Factor (lbs/MMBtu) x 1 ton/2000 lbs

**Appendix A: Emission Calculations**  
**Limited HAP Emissions**  
**From Three (3) Gas Turbines (T1, T2, and T3)**

**Company Name: Indiana Municipal Power Agency - Anderson Station**

**Address: 6035 Park Rd., Anderson, IN 46011**

**Renewal #: T095-30940-00051**

**Reviewer: Anh Nguyen**

**Date: September 20, 2011**

**2. Limited PTE While Combusting Only No. 2 Fuel Oil after Control:**

Fuel Usage Limit  
kgal/yr

Sulfur Content (S)  
(%)

0.17 (permit condition)

20,153 (3 units total = (NG Usage Limit) / (0.392 MMCF/kgal))

Emission Factor in lbs/MMBtu	Pollutant					
	PM*	PM10*	SO <sub>2</sub>	NOx**	VOC	CO**
	1.20E-02	1.20E-02	1.72E-01 (1.01S)	0.1758	4.10E-04	0.0471
<b>Limited PTE (tons/yr)</b>	<b>16.81</b>	<b>16.81</b>	<b>240.49</b>	<b>246.23</b>	<b>0.57</b>	<b>65.97</b>

\* PM and PM10 emission factors are condensable and filterable PM combined. Assume PM10 emissions equal PM emissions.

\*\* These are the emission factors for turbine T3, which were provided by the vendor. The NOx emission factor has been verified by the stack test on 03/31/04. Emission factors for PM/PM10, SO<sub>2</sub>, and VOC are from AP-42, Chapter 3.1, Tables 3.1-1 and 3.1-2: Emission Factors for Stationary Gas Turbines (04/00).

**Methodology**

Limited PTE (tons/yr) = Fuel Usage Limit (kgal/yr) x 139 MMBtu/kgal x Emission Factor (lbs/MMBtu) x 1 ton/2000 lbs

**2. Limited HAP PTE While Combusting No. 2 Fuel Oil:**

Fuel Usage Limit  
kgal/yr

20,153 (3 units total = (NG Usage Limit) / (0.392 MMCF/kgal))

Emission Factor in lbs/MMBtu	Pollutant					
	Formaldehyd	Benzene	PAH	Naphthalene	3-Butadien	Total
	2.80E-04	5.50E-05	4.00E-05	3.50E-05	1.60E-05	4.260E-04
<b>Limited PTE (tons/yr)</b>	<b>3.92E-01</b>	<b>7.70E-02</b>	<b>5.60E-02</b>	<b>4.90E-02</b>	<b>2.24E-02</b>	<b>5.97E-01</b>

Note: Emission factors are from AP-42, Table 3.1-4 for distillate oil-fired gas turbines (AP-42, 04/00).

**Methodology**

Limited PTE (tons/yr) = Fuel Usage Limit (kgal/yr) x 139 MMBtu/kgal x Emission Factor (lbs/MMBtu) x 1 ton/2000 lbs

**Appendix A: Emissions Calculations  
 Natural Gas Combustion Only  
 MM BTU/HR >100  
 Greenhouse Gas Emissions**

**Company Name: Indiana Municipal Power Agency - Anderson Station  
 Address: 6035 Park Rd., Anderson, IN 46011  
 Renewal #: T095-30940-00051  
 Reviewer: Anh Nguyen  
 Date: September 20, 2011**

	Greenhouse Gas		
	CO2	CH4	N2O
Emission Factor in lb/kgal	21,500	0.216	0.26
Potential Emission in tons/yr	216,646	2	3
Summed Potential Emissions in tons/yr	216,651		
CO2e Total in tons/yr	217,504		

**Methodology**

The CO2 Emission Factor for #1 Fuel Oil is 21500. The CO2 Emission Factor for #2 Fuel Oil is 22300.  
 Emission Factors are from AP 42, Tables 1.3-3, 1.3-8, and 1.3-12 (SCC 1-03-005-01/02/03) Supplement E  
 9/99 (see erata file)  
 Greenhouse Warming Potentials (GWP) from Table A-1 of 40 CFR Part 98 Subpart A.  
 $Emission (tons/yr) = Throughput (kgals/ yr) \times Emission Factor (lb/kgal) / 2,000 lb/ton$   
 $CO2e (tons/yr) = CO2 Potential Emission ton/yr \times CO2 GWP (1) + CH4 Potential Emission ton/yr \times CH4 GWP (21) + N2O Potential Emission ton/yr \times N2O GWP (310).$

fo1&2ind.xls 9/95

updated 7/11

**Appendix A: Emission Calculations**  
**Fuel Usage Conversion Factors for Turbines T1 and T2**  
**Company Name: Indiana Municipal Power Agency - Anderson Station**  
**Address: 6035 Park Rd., Anderson, IN 46011**  
**Renewal #: T095-30940-00051**  
**Reviewer: Anh Nguyen**  
**Date: September 20, 2011**

Since the fuel usage limits were based on the usages in turbine T3 and the emission factors for turbines T1 and T2 are different from the ones for turbine T3, the following calculations show the fuel equivalent conversion factors for turbines T1 and T2. **to reflect the stack test data May 22, 2006 NOx will be assumed the large for both natural gas and diesel**

**1. While Combusting NG:**

**NOx and CO emissions from each Turbine T1, T2, T3 shall not exceed the emission limits listed below**

Emission Limits			NOx	CO	Source of EF
Emission Factors for T1 and T2	(lbs/MMBtu)	Water Injection	0.15	0.03	NOx emission factors AP-42, Chapter 3.1, Table 3.1-1, April 2000+ 15%
Natural Gas NOx/CO	(lbs/MMCF)		<b>152.49</b>	<b>30.60</b>	CO emission factors AP-42, Chapter 3.1, Table 3.1-1, April 2000
Emission Factors for T3	(lbs/MMBtu)	Lean-Premix	0.06	0.06	
Natural Gas NOx/CO	(lbs/MMCF)		<b>62.22</b>	<b>62.22</b>	
		<b>Nox ratio</b>	<b>2.45</b>	Natural gas T1 & T2/T3	

## Methodology

Worst Case Natural Gas NOx/CO (lb/MMCF) = E.F. (lb/MMBtu) \* 1,020 MMBtu/MMCF Natural Gas = 152.49 lb/MMCF

**2. No.2 fuel Combustion**

Emission Limits			NOx	CO	Source of EF
Emission Factors for T1 and T2	(lbs/MMBtu)	Water Injection	0.24	0.076	NOx emission factors AP-42, Chapter 3.1, Table 3.1-1, April 2000
Fuel NOx/CO	(lbs/Kgal)		<b>33.15</b>	<b>10.56</b>	CO emission factors AP-42, Chapter 3.1, Table 3.1-1, April 2000
Emission Factors for T3	(lbs/MMBtu)	Lean-Premix	0.18	0.05	
Fuel NOx /CO	(lbs/Kgal)		<b>24.44</b>	<b>6.55</b>	
		<b>Nox ratio</b>	<b>1.36</b>	fuel oil T1 & T2/T3	

## Summary

Natural Gas Equivalent limit shall be reduced by	<b>2.45</b>	for every one(1) MMSCF consumed by turbine T1 & T2
Natural Gas Equivalent limit shall be reduced by	<b>0.39</b>	for every one(1) Kgal consumed by turbine T3
Natural Gas Equivalent limit shall be reduced by	<b>0.53</b>	for every one(1) Kgal consumed by turbine T1 & T2
Natural gas NOx emission limit	<b>490.00</b>	lb/MMCF
Fuel oil NOx emission limit	<b>183.00</b>	lb/Kgal

**Worst Case Conversion Factor =**

Worst Case Emissions Equivalent Fuel Oil:

No. 2 (lb/Kgallon) = E.F (lb/MMBtu) \* 1 MMBtu/1,000,000 Btu \* 138,123 Btu/gallon \* 1,000 gallon/Kgal = 33.15 lb/Kgal

**Combustion in the Turbines under No-load Conditions**

Natural Gas Combustion		
T1 & T2	NOx Emissions	0.48 lb/MMBtu AP-42, Chapter 3.1, Table 3.1-1, April 2000 + 50%
	CO Emissions	0.082 lb/MMBtu AP-42, Chapter 3.1, Table 3.1-1, April 2000
Worst Case for Calculation		0.48 lb/MMBtu

**Worst Case Emissions - Natural Gas - No-Load:**

Natural Gas NOx/CO (lb/MMCF) = E.F. (lb/MMBtu) \* 1,020 MMBtu/MMCF Natural Gas = 490 lb/MMCF

No. 2 Fuel Oil Combustion		
	NOx Emissions	1.32 lb/MMBtu AP-42, Chapter 3.1, Table 3.1-1, April 2000 + 50%
	CO Emissions	0.0033 lb/MMBtu AP-42, Chapter 3.1, Table 3.1-1, April 2000
Worst Case for Calculation		1.32 lb/MMBtu

**Worst Case Emissions - No. 2 Fuel Oil - No-Load:**

No. 2 (lb/Kgallon) = E.F (lb/MMBtu) \* 1 MMBtu/1,000,000 Btu \* 138,123 Btu/gallon \* 1,000 gallon/Kgal = 183 lb/Kgal

**Appendix A: Emission Calculations**  
**Fuel Usage Conversion Factors for Turbines T1 and T2**  
**Company Name: Indiana Municipal Power Agency - Anderson Station**  
**Address: 6035 Park Rd., Anderson, IN 46011**  
**Renewal #: T095-30940-00051**  
**Reviewer: Anh Nguyen**  
**Date: September 20, 2011**

**Fuel Equivalency conversion Factor**

**Case #1 - How many MMCF of equivalent natural gas is equal to 1,000 gallons of fuel oil under normal conditions?**

<b>T1 &amp; T2</b>	NOx/CO Allowable Emission Rate with Natural Gas =	153 lb/MMCF
	NOx/CO Allowable Emission Rate with Fuel Oil =	33.15 lb/Kgal
	<u>Equivalent Amount of Natural Gas</u>	
	MMCF Equivalent Natural Gas = Fuel Oil Emission (lb) * 1 MMCF / 153 lb =	0.22 MMCF
	<u>Emissions Using 1 Kgal of Fuel Oil:</u>	
	NOx/CO (lb) = E.F. (lb/Kgal) * 1 Kgal =	33.15 lb

**0.22 MMCF of equivalent Natural Gas = 1 Kgal of No. 2 at normal operating conditions**

<b>T3</b>	NOx/CO Allowable Emission Rate with Natural Gas =	62.22 lb/MMCF
	NOx/CO Allowable Emission Rate with Fuel Oil =	24.44 lb/Kgal
	<u>Equivalent Amount of Natural Gas</u>	
	MMCF Equivalent Natural Gas = Fuel Oil Emission (lb) * 1 MMCF / 153 lb =	0.393 MMCF
	<u>Emissions Using 1 Kgal of Fuel Oil:</u>	
	NOx/CO (lb) = E.F. (lb/Kgal) * 1 Kgal =	24.44 lb

**0.39 MMCF of equivalent Natural Gas = 1 Kgal of No. 2 at normal operating conditions**

**Case #2 - How many MMCF of equivalent natural gas equals 1 MMCF of natural gas under no-load conditions?**

	<u>Emissions Using 1 MMCF under no-load conditions:</u>	
	NOx/CO (lb) = 1 MMCF - no-load * 490 lb/MMCF no-load =	490 lb
<b>T1&amp;T2</b>	<u>Equivalent Amount of Natural Gas</u>	
	MMCF Equivalent = 490 lb * 1 MMCF Equivalent / 153 lb =	3.2 MMCF
	<b>1 MMCF of Natural Gas under No-Load Conditions = 3.2 MMCF of Equivalent Natural Gas</b>	
<b>T3</b>	<u>Equivalent Amount of Natural Gas</u>	
	MMCF Equivalent = 490 lb * 1 MMCF Equivalent / 62.22 lb =	7.9 MMCF
	<b>1 MMCF of Natural Gas under No-Load Conditions = 7.9 MMCF of Equivalent Natural Gas</b>	

**Case #3 - How many MMCF of equivalent natural gas equals 1,000 gallons of fuel oil under no-load conditions?**

	<u>Emissions Using 1 Kgal No. 2 under no-load conditions:</u>	
	NOx/CO (lb) = 1 Kgal - no-load * 183 lb / Kgal - no-load =	183 lb
<b>T1&amp;T2</b>	<u>Equivalent Amount of Natural Gas</u>	
	MMCF Equivalent = 183 lb * 1 MMCF Equivalent / 153 lb =	1.20 MMCF
	<b>1 Kgal No. 2 Fuel Oil - No-load = 1.2 MMCF Equivalent Natural Gas</b>	
<b>T3</b>	<u>Equivalent Amount of Natural Gas</u>	
	MMCF Equivalent = 183 lb * 1 MMCF Equivalent / 62.22 lb =	2.94 MMCF
	<b>1 Kgal No. 2 Fuel Oil - No-load = 1.2 MMCF Equivalent Natural Gas</b>	

**Appendix A: Emission Calculations  
Criteria Pollutants  
From the Two (2) 630 HP Diesel Engines (D7 and D8)**

**Company Name: Indiana Municipal Power Agency - Anderson Station  
Address: 6035 Park Rd., Anderson, IN 46011  
Renewal #: T095-30940-00051  
Reviewer: Anh Nguyen  
Date: September 20, 2011**

**1. Unlimited PTE:**

Max. Power Output  
Horsepower (HP)

**1,260** (2 units total)

S = Weight % Sulfur  
**0.5**

	Pollutant					
Emission Factor in lbs/hp-hr	PM* 7.00E-04	PM10* 7.00E-04	SO <sub>2</sub> 4.05E-03 (8.09E-3S)	NO <sub>x</sub> 2.40E-02	**VOC 7.05E-04	CO 5.50E-03
<b>Unlimited Potential to Emit in tons/yr</b>	<b>3.86</b>	<b>3.86</b>	<b>22.3</b>	<b>132</b>	<b>3.89</b>	<b>30.4</b>

Note: Emission factors are from AP-42, Table 3.4-1 (AP-42, 10/96).

\*Assume PM10 emissions are equal to PM emissions.

\*\* Assume TOC (total organic compounds) emissions are equal to VOC emissions.

**Methodology**

Unlimited PTE (tons/yr) = Max. Power Output (hp) x Emission Factor (lbs/hp-hr) x 8760 hr/yr x 1 ton/2000 lbs

Max. Power Output  
Horsepower (HP)

**1,260** (2 units total)

Fuel Usage Limit  
gal/yr

**2,200** (2 units total)

S = Weight % Sulfur  
**0.5**

	Pollutant					
Emission Factor in lbs/MMBtu	PM* 0.10	PM10* 0.10	SO <sub>2</sub> 0.51 (1.01*S)	NO <sub>x</sub> 3.20	**VOC 0.09	CO 0.85
<b>Limited Potential to Emit in tons/yr</b>	<b>0.02</b>	<b>0.02</b>	<b>0.08</b>	<b>0.49</b>	<b>0.01</b>	<b>0.13</b>

Note: Emission factors are from AP-42, Table 3.4-1 (AP-42, 10/96).

\*Assume PM10 emissions are equal to PM emissions.

\*\* Assume TOC (total organic compounds) emissions are equal to VOC emissions.

Emissions from D7 & D8 shall not exceed the limit set for CO and NOx

CO (lbs/gal)	NOx (lbs/gal)
0.119	0.448

**Methodology**

Limited PTE (tons/yr) = Fuel Usage Limit (gal/yr) x 0.14 MMBtu/gal x Emission Factor (lbs/MMBtu) x 1 ton/2000 lbs

**Appendix A: Emission Calculations**

**Hazardous Air Pollutants (HAPs)**

**From the Two (2) 630 HP Diesel Engines (D7 and D8)**

**Company Name: Indiana Municipal Power Agency - Anderson Station**

**Address: 6035 Park Rd., Anderson, IN 46011**

**Renewal #: T095-30940-00051**

**Reviewer: Anh Nguyen**

**Date: September 20, 2011**

Max. Power Output  
Horsepower (HP)

Potential throughput  
HP-hr/yr

1,260	(2 units total)
-------	-----------------

1.10E+07

	Pollutant						
	Benzene	Toluene	Xylene	Formaldehyde	Acetaldehyde	Acrolein	Total PAH HAPs***
Emission Factor in lb/hp-hr****	5.43E-06	1.97E-06	1.35E-06	5.52E-07	1.76E-07	5.52E-08	1.48E-06
Potential Emission in tons/yr	3.00E-02	1.09E-02	7.46E-03	3.05E-03	9.74E-04	3.04E-04	8.19E-03

\*\*\*PAH = Polyaromatic Hydrocarbon (PAHs are considered HAPs, since they are considered Polycyclic Organic Matter)

\*\*\*\*Emission factors in lb/hp-hr were calculated using emission factors in lb/MMBtu and a brake specific fuel consumption of 7,000 Btu / hp-hr (AP-42 Table 3.3-1).

<b>Potential Emission of Total HAPs (tons/yr)</b>	<b>6.08E-02</b>
---	-----------------

**Green House Gas Emissions (GHG)**

	PTE			Limited		
	CO2	CH4	N2O	CO2	CH4	N2O
Emission Factor in lb/hp-hr	1.16E+00	6.35E-05	9.30E-06	1.16E+00	6.35E-05	9.30E-06
Potential Emission in tons/yr	6.40E+03	3.50E-01	5.13E-02	7.28E+01	3.98E-03	5.84E-04

	PTE	Limited
<b>Summed Potential Emissions in tons/yr</b>	<b>6402.21</b>	<b>72.80</b>
<b>CO2e Total in tons/yr</b>	<b>6425.07</b>	<b>73.06</b>

**Methodology**

Emission Factors are from AP 42 (Supplement B 10/96) Tables 3.4-1 , 3.4-2, 3.4-3, and 3.4-4.

CH4 and N2O Emission Factor from 40 CFR 98 Subpart C Table C-2.

Greenhouse Warming Potentials (GWP) from Table A-1 of 40 CFR Part 98 Subpart A.

Potential Throughput (hp-hr/yr) = [Output Horsepower Rating (hp)] \* [Maximum Hours Operated per Year]

Potential Emission (tons/yr) = [Potential Throughput (hp-hr/yr)] \* [Emission Factor (lb/hp-hr)] / [2,000 lb/ton]

CO2e (tons/yr) = CO2 Potential Emission ton/yr x CO2 GWP (1) + CH4 Potential Emission ton/yr x CH4 GWP (21) + N2O Potential Emission ton/yr x N2O GWP (310).

**Appendix A: Emission Calculations  
Natural Gas Combustion  
(MMBtu/hr < 100)  
From NG Fired Heaters (Insignificant)**

**Company Name: Indiana Municipal Power Agency - Anderson Station  
Address: 6035 Park Rd., Anderson, IN 46011  
Renewal #: T095-30940-00051  
Reviewer: Anh Nguyen  
Date: September 20, 2011**

Heat Input Capacity MMBtu/hr	Potential Throughput MMCF/yr					
2.003 (2 units total)	17.5					
Pollutant						
Emission Factor in lbs/MMCF	PM*	PM10*	SO <sub>2</sub>	**NO <sub>x</sub>	VOC	CO
	1.9	7.6	0.6	100	5.5	84.0
<b>Potential to Emit in tons/yr</b>	<b>0.02</b>	<b>0.07</b>	<b>5.3E-03</b>	<b>0.88</b>	<b>0.05</b>	<b>0.74</b>

\*PM and PM10 emission factors are condensable and filterable PM10 combined.

\*\*Emission factors for NO<sub>x</sub>: Uncontrolled = 100 lbs/MMCF.

Emission factors are from AP-42, Chapter 1.4, Tables 1.4-1, 1.4-2, and 1.4-3, SCC #1-02-006-02, 1-01-006-02, 1-03-006-02, and 1-03-006-03 (AP-42 Supplement D 07/98)

**Methodology**

All emission factors are based on normal firing.

MMBtu = 1,000,000 Btu

MMCF = 1,000,000 Cubic Feet of Gas

Potential Throughput (MMCF/yr) = Heat Input Capacity (MMBtu/hr) x 8,760 hrs/yr x 1 MMCF/1,000 MMBtu

Potential to Emit (tons/yr) = Potential Throughput (MMCF/yr) x Emission Factor (lbs/MMCF) x 1 ton/2000 lbs

See page 2 for HAPs emissions calculations.

updated 7/11

**Appendix A: Emissions Calculations  
Natural Gas Combustion Only  
MM BTU/HR <100  
HAPs Emissions**

HAPs - Organics					
Emission Factor in lb/MMcf	Benzene 2.1E-03	Dichlorobenze 1.2E-03	Formaldehyde 7.5E-02	Hexane 1.8E+00	Toluene 3.4E-03
Potential Emission in tons/yr	1.842E-05	1.053E-05	6.580E-04	1.579E-02	2.983E-05

  

HAPs - Metals					
Emission Factor in lb/MMcf	Lead 5.0E-04	Cadmium 1.1E-03	Chromium 1.4E-03	Manganese 3.8E-04	Nickel 2.1E-03
Potential Emission in tons/yr	4.387E-06	9.650E-06	1.228E-05	3.334E-06	1.842E-05

Methodology is the same as page 1.

The five highest organic and metal HAPs emission factors are provided above.

Additional HAPs emission factors are available in AP-42, Chapter 1.4.

See Page 3 for Greenhouse Gas calculations.

updated 7/11

**Appendix A: Emissions Calculations**  
**Natural Gas Combustion Only**  
**MM BTU/HR <100**  
**Greenhouse Gas Emissions**  
**Company Name: Indiana Municipal Power Agency - Anderson Station**  
**Address: 6035 Park Rd., Anderson, IN 46011**  
**Renewal #: T095-30940-00051**  
**Reviewer: Anh Nguyen**  
**Date: September 20, 2011**

	Greenhouse Gas		
	CO2	CH4	N2O
Emission Factor in lb/MMcf	120,000	2.3	2.2
Potential Emission in tons/yr	1,053	0	0
Summed Potential Emissions in tons/yr	1,053		
CO2e Total in tons/yr	1,053		

**Methodology**

The N2O Emission Factor for uncontrolled is 2.2. The N2O Emission Factor for low Nox burner is 0.64.  
 Emission Factors are from AP 42, Table 1.4-2 SCC #1-02-006-02, 1-01-006-02, 1-03-006-02, and 1-03-006-03.  
 Greenhouse Warming Potentials (GWP) from Table A-1 of 40 CFR Part 98 Subpart A.  
 Emission (tons/yr) = Throughput (MMCF/yr) x Emission Factor (lb/MMCF)/2,000 lb/ton  
 CO2e (tons/yr) = CO2 Potential Emission ton/yr x CO2 GWP (1) + CH4 Potential Emission ton/yr x CH4 GWP (21) + N2O Potential Emission ton/yr x N2O GWP (310).

updated 7/11



# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

*Mitchell E. Daniels Jr.*  
**Governor**

*Thomas W. Easterly*  
**Commissioner**

100 North Senate Avenue  
Indianapolis, Indiana 46204  
(317) 232-8603  
Toll Free (800) 451-6027  
[www.idem.IN.gov](http://www.idem.IN.gov)

## **SENT VIA U.S. MAIL: CONFIRMED DELIVERY AND SIGNATURE REQUESTED**

**TO:** Scott Berry  
Indiana Municipal Power Agency – Anderson Station  
11610 N College Ave  
Carmel, IN 46032

**DATE:** July 19, 2012

**FROM:** Matt Stuckey, Branch Chief  
Permits Branch  
Office of Air Quality

**SUBJECT:** Final Decision  
Title V - Renewal  
095 - 30940 - 00051

Enclosed is the final decision and supporting materials for the air permit application referenced above. Please note that this packet contains the original, signed, permit documents.

The final decision is being sent to you because our records indicate that you are the contact person for this application. However, if you are not the appropriate person within your company to receive this document, please forward it to the correct person.

A copy of the final decision and supporting materials has also been sent via standard mail to:  
Jack Alvey, Sr VP  
OAQ Permits Branch Interested Parties List

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178, or toll-free at 1-800-451-6027 (ext. 3-0178), and ask to speak to the permit reviewer who prepared the permit. If you think you have received this document in error, please contact Joanne Smiddie-Brush of my staff at 1-800-451-6027 (ext 3-0185), or via e-mail at [jbrush@idem.IN.gov](mailto:jbrush@idem.IN.gov).

Final Applicant Cover letter.dot 11/30/07



# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

*Mitchell E. Daniels Jr.*  
**Governor**

*Thomas W. Easterly*  
**Commissioner**

100 North Senate Avenue  
Indianapolis, Indiana 46204  
(317) 232-8603  
Toll Free (800) 451-6027  
[www.idem.IN.gov](http://www.idem.IN.gov)

July 19, 2012

TO: Anderson Public Library

From: Matthew Stuckey, Branch Chief  
Permits Branch  
Office of Air Quality

Subject: **Important Information for Display Regarding a Final Determination**

**Applicant Name: Indiana Municipal Power Agency – Anderson Station**  
**Permit Number: 095 - 30940 - 00051**

You previously received information to make available to the public during the public comment period of a draft permit. Enclosed is a copy of the final decision and supporting materials for the same project. Please place the enclosed information along with the information you previously received. To ensure that your patrons have ample opportunity to review the enclosed permit, **we ask that you retain this document for at least 60 days.**

The applicant is responsible for placing a copy of the application in your library. If the permit application is not on file, or if you have any questions concerning this public review process, please contact Joanne Smiddie-Brush, OAQ Permits Administration Section at 1-800-451-6027, extension 3-0185.

Enclosures  
Final Library.dot 11/30/07

# Mail Code 61-53

IDEM Staff	LPOGOST 7/19/2012 IMPA - Indiana Municipal Power Agcy - Anderson 095 - 30940 - 00051 final)			AFFIX STAMP HERE IF USED AS CERTIFICATE OF MAILING
Name and address of Sender		Indiana Department of Environmental Management Office of Air Quality – Permits Branch 100 N. Senate Indianapolis, IN 46204	Type of Mail:  <b>CERTIFICATE OF MAILING ONLY</b>	

Line	Article Number	Name, Address, Street and Post Office Address	Postage	Handling Charges	Act. Value (If Registered)	Insured Value	Due Send if COD	R.R. Fee	S.D. Fee	S.H. Fee	Rest. Del. Fee
											Remarks
1		Scott Berry IMPA - Indiana Municipal Power Agcy - Anderson 11610 N College Ave Carmel IN 46032 (Source CAATS) Via confirmed delivery									
2		Jack Alvey Sr VP IMPA - Indiana Municipal Power Agcy - Anderson 11610 N College Ave Carmel IN 46032 (RO CAATS)									
3		Madison County Commissioners 16 E. 9th Suite 104 Anderson IN 46016 (Local Official)									
4		Anderson Public Library 111 E. 12th St. Anderson IN 46016-2701 (Library)									
5		Anderson Town Council & Mayors Office P.O. Box 2100 Anderson IN 46018 (Local Official)									
6		Madison County Health Department 206 E 9th St Anderson IN 46016-1512 (Health Department)									
7											
8											
9											
10											
11											
12											
13											
14											
15											

Total number of pieces Listed by Sender	Total number of Pieces Received at Post Office	Postmaster, Per (Name of Receiving employee)	The full declaration of value is required on all domestic and international registered mail. The maximum indemnity payable for the reconstruction of nonnegotiable documents under Express Mail document reconstructing insurance is \$50,000 per piece subject to a limit of \$50, 000 per occurrence. The maximum indemnity payable on Express mil merchandise insurance is \$500. The maximum indemnity payable is \$25,000 for registered mail, sent with optional postal insurance. See <b>Domestic Mail Manual R900, S913, and S921</b> for limitations of coverage on inured and COD mail. See <b>International Mail Manual</b> for limitations o coverage on international mail. Special handling charges apply only to Standard Mail (A) and Standard Mail (B) parcels.
---	--	--	--