



# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

100 N. Senate Avenue • Indianapolis, IN 46204

(800) 451-6027 • (317) 232-8603 • [www.idem.IN.gov](http://www.idem.IN.gov)

**Michael R. Pence**  
Governor

**Thomas W. Easterly**  
Commissioner

TO: Interested Parties / Applicant

DATE: August 9, 2013

RE: Cargill Inc / 157-32522-00038

FROM: Matthew Stuckey, Branch Chief  
Permits Branch  
Office of Air Quality

## Notice of Decision: Approval – Effective Immediately

Please be advised that on behalf of the Commissioner of the Department of Environmental Management, I have issued a decision regarding the enclosed matter. Pursuant to IC 13-17-3-4 and 326 IAC 2, this permit modification is effective immediately, unless a petition for stay of effectiveness is filed and granted, and may be revoked or modified in accordance with the provisions of IC 13-15-7-1.

If you wish to challenge this decision, IC 4-21.5-3-7 and IC 13-15-7-3 require that you file a petition for administrative review. This petition may include a request for stay of effectiveness and must be submitted to the Office Environmental Adjudication, 100 North Senate Avenue, Government Center North, Suite N 501E, Indianapolis, IN 46204, **within eighteen (18) days of the mailing of this notice**. The filing of a petition for administrative review is complete on the earliest of the following dates that apply to the filing:

- (1) the date the document is delivered to the Office of Environmental Adjudication (OEA);
- (2) the date of the postmark on the envelope containing the document, if the document is mailed to OEA by U.S. mail; or
- (3) The date on which the document is deposited with a private carrier, as shown by receipt issued by the carrier, if the document is sent to the OEA by private carrier.

The petition must include facts demonstrating that you are either the applicant, a person aggrieved or adversely affected by the decision or otherwise entitled to review by law. Please identify the permit, decision, or other order for which you seek review by permit number, name of the applicant, location, date of this notice and all of the following:

- (1) the name and address of the person making the request;
- (2) the interest of the person making the request;
- (3) identification of any persons represented by the person making the request;
- (4) the reasons, with particularity, for the request;
- (5) the issues, with particularity, proposed for considerations at any hearing; and
- (6) identification of the terms and conditions which, in the judgment of the person making the request, would be appropriate in the case in question to satisfy the requirements of the law governing documents of the type issued by the Commissioner.

Pursuant to 326 IAC 2-7-18(d), any person may petition the U.S. EPA to object to the issuance of a Title V operating permit or modification within sixty (60) days of the end of the forty-five (45) day EPA review period. Such an objection must be based only on issues that were raised with reasonable specificity during the public comment period, unless the petitioner demonstrates that it was impracticable to raise such issues, or if the grounds for such objection arose after the comment period.

To petition the U.S. EPA to object to the issuance of a Title V operating permit, contact:

U.S. Environmental Protection Agency  
401 M Street  
Washington, D.C. 20406

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178. Callers from within Indiana may call toll-free at 1-800-451-6027, ext. 3-0178.



# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

*Michael R. Pence*  
Governor

*Thomas W. Easterly*  
Commissioner

100 North Senate Avenue  
Indianapolis, Indiana 46204  
(317) 232-8603  
Toll Free (800) 451-6027  
[www.idem.IN.gov](http://www.idem.IN.gov)

John Zoss, Facility Superintendent  
Cargill, Inc.- Soybean Processing Division  
1502 Wabash Avenue  
Lafayette, IN 47905

August 9, 2013

Re: 157-32522-00038  
Significant Permit Modification to  
Part 70 Renewal No.: T157-25200-00038

Dear Mr. Zoss:

Cargill, Inc. - Soybean Processing Division was issued a Part 70 Operating Permit Renewal (T157-25200-00038) on January 7, 2010 for a stationary soybean oil extraction plant consisting of conventional desolventizer system and flake desolventizer system. An application requesting changes to this permit was received on November 16, 2012. Pursuant to the provisions of 326 IAC 2-7-12, a significant permit modification to this permit is hereby approved as described in the attached Technical Support Document.

The modification consists of the addition of the following specifically regulated insignificant activities:

- (3) Equipment powered by diesel fuel fired or natural gas fired internal combustion engines of capacity equal to or less than five hundred thousand (500,000) Btu/hour, except where total capacity of equipment operated by one stationary source exceeds two million (2,000,000) Btu/hour.
  - (A) One (1) existing sixty-six (66) horsepower, non-emergency diesel powered air compressor, constructed in 2002, using a maximum of 8.8 gallons of #2 diesel fuel per hour.

This diesel powered air compressor is an affected facility under 40 CFR 63, Subpart ZZZZ.

- (3) Degreasing operations that do not exceed 145 gallons per 12 months, except if subject to 326 IAC 20-6:

One (1) parts washing station, constructed in 2002, with a maximum capacity of 145 gallons per year exhausting outside.

For your convenience, the entire Part 70 Operating Permit as modified, is attached.

Pursuant to 326 IAC 2-7-1(40), starting July 1, 2011, greenhouse gas (GHG) emissions are subject to regulation at a source with a potential to emit (PTE) of 100,000 tons per year or more of CO<sub>2</sub> equivalent emissions (CO<sub>2</sub>e). Therefore, CO<sub>2</sub>e emissions have been calculated for this source. Based on the calculations, the unlimited PTE of GHGs from the entire source is less than 100,000 tons of CO<sub>2</sub>e per year (see Appendix A for calculations). This did not require any changes to the permit.

A copy of the permit is available on the Internet at: <http://www.in.gov/ai/appfiles/idem-caats/>. For additional information about air permits and how the public and interested parties can participate, refer to the IDEM's Guide for Citizen Participation and Permit Guide on the Internet at: [www.idem.in.gov](http://www.idem.in.gov)

This decision is subject to the Indiana Administrative Orders and Procedures Act - IC 4-21.5-3-5. If you have any questions on this matter, please contact Deborah Cole, of my staff, at 317-234-5377 or 1-800-451-6027, ext 4-5377.

Sincerely,



Iryn Calilung, Section Chief  
Permits Branch  
Office of Air Quality

Attachments: Updated Permit, Technical Support Document, Calculations and Appendices

IC/dac

cc: File - Tippecanoe County  
Tippecanoe County Health Department  
U.S. EPA, Region V  
Compliance and Enforcement Branch



**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT**

*We Protect Hoosiers and Our Environment.*

*Michael R. Pence*  
Governor

*Thomas W. Easterly*  
Commissioner

100 North Senate Avenue  
Indianapolis, Indiana 46204  
(317) 232-8603  
Toll Free (800) 451-6027  
www.idem.IN.gov

**Part 70 Operating Permit Renewal  
OFFICE OF AIR QUALITY**

**Cargill, Inc. - Soybean Processing Division  
1502 Wabash Avenue  
Lafayette, Indiana 47905**


(herein known as the Permittee) is hereby authorized to operate subject to the conditions contained herein, the source described in Section A (Source Summary) of this permit.

**The Permittee must comply with all conditions of this permit. Noncompliance with any provisions of this permit is grounds for enforcement action; permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. Noncompliance with any provision of this permit, except any provision specifically designated as not federally enforceable, constitutes a violation of the Clean Air Act. It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. An emergency does constitute an affirmative defense in an enforcement action provided the Permittee complies with the applicable requirements set forth in Section B, Emergency Provisions.**

This permit is issued in accordance with 326 IAC 2 and 40 CFR Part 70 Appendix A and contains the conditions and provisions specified in 326 IAC 2-7 as required by 42 U.S.C. 7401, et. seq. (Clean Air Act as amended by the 1990 Clean Air Act Amendments), 40 CFR Part 70.6, IC 13-15 and IC 13-17. This permit also addresses certain new source review requirements for existing equipment and is intended to fulfill the new source review procedures pursuant to 326 IAC 2-2 and 326 IAC 2-7-10.5, applicable to those conditions.

Operation Permit No.: T157-25200-00038	
Issued by: <i>Original Signed by:</i> Donald F. Robin, P.E., Section Chief Permits Branch Office of Air Quality	Issuance Date: January 7, 2010  Expiration Date: January 7, 2015

First Significant Permit Modification No.: 157-29544-00038, issued December 10, 2010

Second Significant Permit Modification No.: 157-32522-00038	
Issued by:  Iryn Calilung, Section Chief Permits Branch Office of Air Quality	Issuance Date: August 9, 2013  Expiration Date: January 7, 2015

## TABLE OF CONTENTS

### A. SOURCE SUMMARY

- A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)] [326 IAC 2-7-1(22)]
- A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)]  
[326 IAC 2-7-5(15)]
- A.3 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-7-4(c)]  
[326 IAC 2-7-5(15)]
- A.4 Part 70 Permit Applicability [326 IAC 2-7-2]

### B. GENERAL CONDITIONS

- B.1 Definitions [326 IAC 2-7-1]
- B.2 Permit Term [326 IAC 2-7-5(2)] [326 IAC 2-1.1-9.5] [326 IAC 2-7-4(a)(1)(D)]  
[IC 13-15-3-6(a)]
- B.3 Term of Conditions [326 IAC 2-1.1-9.5]
- B.4 Enforceability [326 IAC 2-7-7] [IC 13-17-12]
- B.5 Severability [326 IAC 2-7-5(5)]
- B.6 Property Rights or Exclusive Privilege [326 IAC 2-7-5(6)(D)]
- B.7 Duty to Provide Information [326 IAC 2-7-5(6)(E)]
- B.8 Certification [326 IAC 2-7-4(f)] [326 IAC 2-7-6(1)] [326 IAC 2-7-5(3)(C)]
- B.9 Annual Compliance Certification [326 IAC 2-7-6(5)]
- B.10 Preventive Maintenance Plan [326 IAC 2-7-5(1),(3) and (13)] [326 IAC 2-7-6(1) and (6)]  
[326 IAC 1-6-3]
- B.11 Emergency Provisions [326 IAC 2-7-16]
- B.12 Permit Shield [326 IAC 2-7-15] [326 IAC 2-7-20] [326 IAC 2-7-12]
- B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5] [326 IAC 2-7-10.5]
- B.14 Termination of Right to Operate [326 IAC 2-7-10] [326 IAC 2-7-4(a)]
- B.15 Permit Modification, Reopening, Revocation and Reissuance, or Termination  
[326 IAC 2-7-5(6)(C)] [326 IAC 2-7-8(a)] [326 IAC 2-7-9]
- B.16 Permit Renewal [326 IAC 2-7-3] [326 IAC 2-7-4] [326 IAC 2-7-8(e)]
- B.17 Permit Amendment or Modification [326 IAC 2-7-11] [326 IAC 2-7-12]
- B.18 Permit Revision Under Economic Incentives and Other Programs [326 IAC 2-7-5(8)]  
[326 IAC 2-7-12(b)(2)]
- B.19 Operational Flexibility [326 IAC 2-7-20] [326 IAC 2-7-10.5]
- B.20 Source Modification Requirement [326 IAC 2-7-10.5]
- B.21 Inspection and Entry [326 IAC 2-7-6] [IC 13-14-2-2] [IC 13-30-3-1] [IC 13-17-3-2]
- B.22 Transfer of Ownership or Operational Control [326 IAC 2-7-11]
- B.23 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-7-5(7)] [326 IAC 2-1.1-7]
- B.24 Credible Evidence [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [62 FR 8314] [326 IAC 1-1-6]

### C. SOURCE OPERATION CONDITIONS

#### Emission Limitations and Standards [326 IAC 2-7-5(1)]

- C.1 Particulate Emission Limitations For Processes with Process Weight Rates  
Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]
- C.2 Opacity [326 IAC 5-1]
- C.3 Open Burning [326 IAC 4-1] [IC 13-17-9]
- C.4 Incineration [326 IAC 4-2] [326 IAC 9-1-2]
- C.5 Fugitive Dust Emissions [326 IAC 6-4]
- C.6 Stack Height [326 IAC 1-7]
- C.7 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

**Testing Requirements [326 IAC 2-7-6(1)]**

C.8 Performance Testing [326 IAC 3-6]

**Compliance Requirements [326 IAC 2-1.1-11]**

C.9 Compliance Requirements [326 IAC 2-1.1-11]

**Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]**

C.10 Compliance Monitoring [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

C.11 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

**Corrective Actions and Response Steps [326 IAC 2-7-5] [326 IAC 2-7-6]**

C.12 Emergency Reduction Plans [326 IAC 1-5-2] [326 IAC 1-5-3]

C.13 Risk Management Plan [326 IAC 2-7-5(12)] [40 CFR 68]

C.14 Response to Excursions or Exceedances [326 IAC 2-7-5] [326 IAC 2-7-6]

C.15 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5]  
[326 IAC 2-7-6]

**Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

C.16 Emission Statement [326 IAC 2-7-5(3)(C)(iii)] [326 IAC 2-7-5(7)] [326 IAC 2-7-19(c)]  
[326 IAC 2-6]

C.17 General Record Keeping Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [326 IAC 2-2]  
[326 IAC 2-3]

C.18 General Reporting Requirements [326 IAC 2-7-5(3)(C)] [326 IAC 2-1.1-11] [326 IAC 2-2]

**Stratospheric Ozone Protection**

C.19 Compliance with 40 CFR 82 and 326 IAC 22-1

**D.0. EMISSIONS UNIT OPERATION CONDITIONS - SOURCE-WIDE OPERATIONS**

**Emission Limitations and Standards [326 IAC 2-7-5(1)]**

D.0.1 Consent Decree Limitations

D.0.2 State Implementation Plan

**Compliance Determination Requirements**

D.0.3 Volatile Organic Compounds (VOC)

**Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

D.0.4 Record Keeping Requirement

**D.1. EMISSIONS UNIT OPERATION CONDITIONS - SOYBEAN PROCESSING FACILITIES**

**Emission Limitations and Standards [326 IAC 2-7-5(1)]**

D.1.1 PSD Minor Limit [326 IAC 2-2]

D.1.2 Best Available Control Technology (BACT) [326 IAC 2-2-3] [326 IAC 8-1-6]

D.1.3 Particulate Emission Limitations for Manufacturing Processes [326 IAC 6-3-2]

D.1.4 Preventive Maintenance Plan [326 IAC 2-7-5(12)]

**Compliance Determination Requirements**

D.1.5 Testing Requirements [326 IAC 2-7-6(1), (6)] [326 IAC 2-1.1-11]

D.1.6 VOC (BACT) Compliance [326 IAC 2-2]

D.1.7 Solvent Loss Ratio [326 IAC 2-2] [40 CFR 64]

D.1.8 Particulate Matter (PM) and Particulate Matter 10 (PM<sub>10</sub>)

**Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]**

- D.1.9 Visible Emission Notations
- D.1.10 Broken or Failed Bag Detection
- D.1.11 Cyclone Failure
- D.1.12 Mineral Oil Absorber [40 CFR 64]

**Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

- D.1.13 Record Keeping Requirement
- D.1.14 Reporting Requirements

**D.2. EMISSIONS UNIT OPERATION CONDITIONS - BOILERS**

**Emission Limitations and Standards [326 IAC 2-7-5(1)]**

- D.2.1 PSD Minor Limit [326 IAC 2-2]
- D.2.2 Particulate Matter Emissions [326 IAC 6-2-3] [326 IAC 6-2-4]
- D.2.3 Sulfur Dioxide (SO<sub>2</sub>) [326 IAC 7-1.1-1] [326 IAC 7-1.1-2]
- D.2.4 Preventive Maintenance Plan [326 IAC 2-7-5(12)]

**Compliance Determination Requirements**

- D.2.5 Sulfur Dioxide Emissions and Sulfur Content
- D.2.6 Testing Requirements [326 IAC 2-7-6(1), (6)] [326 IAC 2-1.1-11]

**Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]**

- D.2.7 Visible Emission Notations

**Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

- D.2.8 Record Keeping Requirement
- D.2.9 Reporting Requirements

**D.3. EMISSIONS UNIT OPERATION CONDITIONS - INSIGNIFICANT ACTIVITIES**

**Emission Limitations and Standards [326 IAC 2-7-5(1)]**

- D.3.1 Fugitive Dust Emissions [326 IAC 6-4-2]

**Compliance Determination Requirements**

- D.3.2 Control Measures

**D.4. EMISSIONS UNIT OPERATION CONDITIONS - INSIGNIFICANT ACTIVITIES**

**Emission Limitations and Standards [326 IAC 2-7-5(1)]**

- D.4.1 Volatile Organic Compounds (VOC) [326 IAC 8-3-2]

**E.1. NEW SOURCE PERFORMANCE STANDARDS (NSPS) FOR GRAIN ELEVATORS [40 CFR 60, SUBPART DD]**

- E.1.1 General Provision Relating to New Source Performance Standards [326 IAC 12-1] [40 CFR 60, Subpart A]
- E.1.2 Standards of Performance for Grain Elevators [40 CFR 60, Subpart DD] [326 IAC 12]

**E.2. NEW SOURCE PERFORMANCE STANDARDS (NSPS) FOR SMALL INDUSTRIAL-COMMERCIAL-INSTITUTIONAL STEAM GENERATING UNITS [40 CFR 60, SUBPART DC]**

- E.2.1 General Provision Relating to New Source Performance Standards [326 IAC 12-1] [40 CFR 60, Subpart A]
- E.2.2 Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units [40 CFR 60, Subpart Dc] [326 IAC 12]



**E.3. NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS: SOLVENT EXTRACTION FOR VEGETABLE OIL PRODUCTION [40 CFR 63, SUBPART GGGG]**

- E.3.1 General Provision Relating to NESHAP GGGG [326 IAC 20-1] [40 CFR 63, Subpart A]
- E.3.2 Solvent Extraction for Vegetable Oil Production [40 CFR 63, Subpart GGGG]

**E.4. NATIONAL EMISSIONS STANDARDS FOR HAZARDOUS AIR POLLUTANTS FOR STATIONARY RECIPROCATING INTERNAL COMBUSTION ENGINES [40 CFR 63, SUBPART ZZZZ]**

- E.4.1 General Provision Relating to NESHAP ZZZZ [326 IAC 20-1] [40 CFR 63, Subpart A]
- E.4.2 National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines [40 CFR 63, Subpart ZZZZ]

**CERTIFICATION**

**EMERGENCY OCCURRENCE REPORT**

**SEMI-ANNUAL NATURAL GAS FIRED BOILER CERTIFICATION**

**PART 70 USAGE REPORT**

**PART 70 SEMI ANNUAL REPORT**

**QUARTERLY REPORT**

**QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT**

**Attachment A - New Source Performance Standards for Grain Elevators**

**Attachment B - New Source Performance Standards for Small Industrial-Commercial-Institutional Steam Generating Units**

**Attachment C - National Emission Standards for Hazardous Air Pollutants: Solvent Extraction for Vegetable Oil Production**

**Attachment D - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines [40 CFR 63, Subpart ZZZZ]**

## SECTION A SOURCE SUMMARY

This permit is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ). The information describing the source contained in conditions A.1 through A.3 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this permit pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

### A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(14)] [326 IAC 2-7-1(22)]

---

The Permittee owns and operates a stationary soybean oil extraction plant consisting of conventional desolventizer system and flake desolventizer system.

Source Address:	1502 Wabash Avenue, Lafayette, Indiana 47905
General Source Phone Number:	(765) 420-6612
SIC Code:	2075 (Soybean Oil Mills)
County Location:	Tippecanoe
Source Location Status:	Attainment for all criteria pollutants
Source Status:	Part 70 Operating Permit Program Major Source, under PSD Rules Major Source, under Section 112 of the Clean Air Act Not 1 of 28 Source Categories

### A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)] [326 IAC 2-7-5(14)]

---

This stationary source consists of the following emission units and pollution control devices:

- (a) One (1) truck soybean receiving pit, constructed in 1989, with a maximum capacity of 25,000 bushels per hour, controlled by a receiving area baghouse #4 and exhausting at stack point # S-13.
- (b) One (1) totally enclosed truck soybean receiving pit drag conveyor (DC-431), constructed in 1989, with a maximum capacity of 25,000 bushels per hour, aspirated to baghouse #10, and exhausting at stack point # S-2.
- (c) One (1) totally enclosed soybean receiving pit drag conveyor (DC-432), constructed in 1989, with a maximum capacity of 25,000 bushels per hour, aspirated to baghouse #10, and exhausting at stack point # S-2.
- (d) One (1) rail soybean unloading system, constructed in 1956, with a maximum unloading capacity of 12,000 bushels per hour, controlled by baghouse #10 and exhausted at stack point S-2.
- (e) One (1) soybean receiving bucket elevator #301, constructed in 1989, with a maximum capacity of 25,000 bushels per hour, controlled by a baghouse #10 and exhausting at stack point # S-2.
- (f) Three (3) totally enclosed soybean drag conveyors (DC-441, 442, & 443) operated in series, constructed in 1988, each with a maximum capacity of 25,000 bushels per hour, each aspirated to baghouse #9 and exhausting at stack point # S-1.
- (g) One (1) totally enclosed soybean drag conveyor (DC-434), constructed in 1988, with a maximum capacity of 25,000 bushels per hour, aspirated to baghouse #10 and exhausting at stack point # S-2.
- (h) Four (4) soybean storage tanks, constructed in the 1950's, with a total capacity of

1,213,000 bushels.

- (i) Two (2) totally enclosed soybean drag conveyors (DC-436, & 437) operated in series, constructed in 1988, each with a maximum capacity of 5,000 bushels per hour, each aspirated to baghouse #10 and exhausting at stack point # S-2.
- (j) Two (2) totally enclosed soybean drag conveyors (DC-444, & 446) operated in series, constructed in 1988, each with a maximum capacity of 5,000 bushels per hour, each aspirated to baghouse #10 and exhausting at stack point # S-2.
- (k) One (1) soybean transfer bucket elevator #303, constructed in 1956, with a maximum capacity of 5,000 bushels per hour, controlled by a baghouse #10 and exhausting at stack point # S-2.
- (l) One (1) Texas shaker #2 screener, constructed in 1988, with a maximum capacity of 5,000 bushels per hour, controlled by a baghouse #1 and exhausting at stack point # S-3.
- (m) One (1) weed seed Kice, constructed in 1988, with a maximum capacity of 150 bushels per hour, controlled by a baghouse #1 and exhausting at stack point # S-3.
- (n) One (1) Kice #1, constructed in 1988, with a maximum capacity of 5,000 bushels per hour, controlled by a baghouse #1 and exhausting at stack point # S-3.
- (o) Two (2) totally enclosed soybean drag conveyors (DC-448, & 448A) operated in series, constructed in 1986 (DC-448) and 1996 (DC-448A), each with a maximum capacity of 5,000 bushels per hour, each aspirated to baghouse #1 and exhausting at stack point # S-3.
- (p) One (1) totally enclosed soybean screw conveyor (SC212), constructed in 1989 with a maximum capacity of 150 bushels per hour.
- (q) One (1) 29 MMBtu natural gas fired soybean column dryer, constructed in 1986, with a maximum capacity of 5,000 bushels per hour and exhausting at stack point # S-20.
- (r) Two (2) totally enclosed soybean drag conveyors (DC-449, & 450) operated in series, constructed in 1986, each with a maximum capacity of 5,000 bushels per hour, each aspirated to baghouse #10 and exhausting at stack point # S-2.
- (s) One (1) dry soybean transfer bucket elevator #307, constructed in 1986, with a maximum capacity of 5,000 bushels per hour, controlled by a baghouse #9 and exhausting at stack point # S-1.
- (t) One (1) totally enclosed dry soybean drag conveyor (DC-453), constructed in 1988, with a maximum capacity of 5,000 bushels per hour, aspirated to baghouse #9 and exhausting at stack point # S-1.
- (u) Eighteen (18) soybean bins (501, 502, 503, 506, 507, 508, 511, 512, 513, 516, 517, 518, 521, 522, 523, 526, 527, and 528), constructed in the 1930's, with a maximum total capacity of 261,000 bushels.
- (v) Two (2) totally enclosed soybean drag conveyors (DC-454, & 447) operated in series, constructed in 1986, each with a maximum capacity of 5,000 bushels per hour each, each aspirated to baghouse #10 and exhausting at stack point # S-2.
- (w) One (1) dry soybean transfer bucket elevator #304, constructed in 1956, with a maximum capacity of 5,000 bushels per hour, controlled by a baghouse #10 and exhausting at stack point # S-2.

- (x) One (1) totally enclosed dry soybean drag conveyor (DC-400A), constructed in 1986, with a maximum capacity of 5,000 bushels per hour, aspirated to baghouse #3 and exhausting at stack point # S-7.
- (y) One (1) soybean Thayer scale, constructed in 1986, with a maximum capacity of 5000 bushels per hour, controlled by a baghouse #3 and exhausting at stack point # S-7.
- (z) Two (2) weed seed bins (#207 & 208) constructed in 1930, with a maximum storage capacity of 14,000 bushels each, a total nominal throughput of 5,000 bushels per day.
- (aa) Two (2) totally enclosed soybean screw conveyors (SC 213 & 214), operated in series, constructed in 1986, each with a maximum capacity of 150 bushels per hour.
- (bb) Three (3) totally enclosed soybean meal drag conveyors (DC-427, 428, & 429) operated in series, constructed in 1988, each with a maximum capacity of 5,000 bushels per hour each.
- (cc) One (1) totally enclosed dry soybean drag conveyor (DC-400), constructed in 1986, with a maximum capacity of 5,000 bushels per hour, aspirated to baghouse #3 and exhausting at stack point # S-7.
- (dd) Five (5) soybean surge bins, constructed in 1930, with a total maximum capacity of 22,000 bushels, and a total maximum throughput of 3,350 bushels per hour.
- (ee) Five (5) sets of cracking rolls (EU-6), constructed between 1986 and 2004, with a total maximum capacity of 3,350 bushels per hour (100.5 tons per hour), controlled by bag house #3 and exhausted at stack point S-7.
- (ff) Two (2) totally enclosed cracked soybean drag conveyor (DC-401 & 403) operated in series, constructed in 1986, each with a maximum capacity of 3350 bushels per hour, aspirated to baghouse #3 and exhausting at stack point # S-7.
- (gg) One (1) primary Kice #1, constructed in 1986, with a maximum capacity of 3350 bushels per hour, aspirated to baghouse #3 and exhausting at stack point # S-7.
- (hh) Two (2) totally enclosed cracked soybean screw conveyors (SC-201 & 202) operated in series, constructed in 1986, each with a maximum capacity of 3350 bushels per hour, aspirated to baghouse #3 and exhausting at stack point # S-7.
- (ii) One (1) triple S shaker, constructed in 1994, with a maximum capacity of 3350 bushels per hour, controlled by a baghouse #3 and exhausting at stack point # S-7.
- (jj) One (1) hull grinder, constructed in 1986, with a maximum capacity of 6 tons per hour, controlled by a cyclone #3 and a baghouse #3 and exhausting at stack point # S-7.
- (kk) One (1) coarse cut aspiration, constructed in 1994, with a maximum capacity of 150 bushels per hour, controlled by a cyclone #1 and a baghouse #3 and exhausting at stack point # S-7.
- (ll) One (1) fine cut aspiration, constructed in 1994, with a maximum capacity of 150 bushels per hour, controlled by a cyclone #2 and a baghouse #3 and exhausting at stack point # S-7.
- (mm) One (1) rotary conditioner, constructed in 1982, with a maximum capacity of 3350 bushels per hour, controlled by a cyclone #4 and exhausting at stack point # S-5.
- (nn) Four (4) totally enclosed conditioned soybean drag conveyor (DC-404, 405, 406 & 407), constructed in 1986, each with a maximum capacity of 3350 bushels per hour, controlled

by a cyclone #4 and exhausting at stack point # S-5.

- (oo) Two (2) flaker banks #1 & 2, constructed in 1986, with a maximum total capacity of 100.5 tons per hour, controlled by a cyclone #4 and exhausting at stack point # S-5.
- (pp) Two (2) totally enclosed soybean flake screw conveyors (SC-206 & 207), constructed in 1986, with a total maximum capacity of 100.5 tons per hour, controlled by a cyclone #4 and exhausting at stack point # S-5.
- (qq) Two (2) expanders (EU-12), constructed in 1986, with a total maximum capacity of 833 bushels per hour (25 ton per hour), controlled by cyclone #4 and exhausted at stack point S-5.
- (rr) One (1) totally enclosed soybean flake drag conveyor (DC-409), constructed in 2005, with a maximum capacity 3350 bushels per hour, controlled by a cyclone #4 and exhausting at stack point # S-5.
- (ss) One (1) totally enclosed soybean flake drag conveyor (DC-410), constructed in 1986, with a maximum capacity of 100.5 tons per hour and exhausting at steam vents.
- (tt) One (1) totally enclosed soybean flake drag conveyor (DC-411), constructed in 1986, with a maximum capacity of 100.5 tons per hour and exhausting at safety vent.
- (uu) Two (2) fully enclosed, sealed conveyors, DC-412, and DC-413, and DT seal screw, constructed in 2006, with a maximum total capacity of 3,350 bushels per hour.
- (vv) One (1) totally enclosed soybean flake screw conveyor (SC-209), constructed in 1986, with a maximum capacity of 100.5 tons per hour.
- (ww) One (1) desolventizer/toaster (EU-16), constructed in 2006 with a maximum capacity of 3,350 bushels per hour controlled by the mineral oil system and exhausted at stack points S-15.

Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.

- (xx) One (1) dryer/cooler with three (3) dryer decks and one (1) cooler deck; constructed in 1988 (cooler deck), 1990 (1st dryer deck), 2006 (2<sup>nd</sup> & 3<sup>rd</sup> dryer decks), with a maximum total capacity of 3350 bushels per hour, controlled by four (4) integral cyclones identified as # 6, 7, 8, and 9, and exhausted at stack points # S-11, S-12, S-21, and S-25.

Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.

- (yy) One (1) totally enclosed soybean meal drag conveyor (DC-414), constructed in 1986, with a maximum capacity of 100.5 tons per hour.
- (zz) Two (2) totally enclosed soybean meal drag conveyors (DC 414A & 415), in series, constructed in 1986, each with a maximum capacity of 100.5 tons per hour controlled by a baghouse #2 and exhausting at stack point # S-6.
- (aaa) Three (3) meal sifters, constructed in 1986, with a maximum total capacity of 100.5 tons per hour.
- (bbb) One (1) totally enclosed oversized soybean meal drag conveyor (DC 416), constructed by 1986, with a maximum capacity of 100.5 tons per hour controlled by a baghouse #2 and exhausting at stack point # S-6.
- (ccc) One (1) totally enclosed soybean meal screw conveyor (SC 223), constructed in 1986, with a maximum capacity of 100.5 tons per hour controlled by a baghouse #2 and

exhausting at stack point # S-6.

- (ddd) Three soybean meal grinders, constructed in 1986, with a maximum total capacity of 100.5 tons per hour controlled by a baghouse #2 and exhausting at stack point # S-6.
- (eee) One (1) totally enclosed soybean meal screw conveyor (SC 221), constructed in 1986, with a maximum capacity of 100.5 tons per hour controlled by a baghouse #2 and exhausting at stack point # S-6.
- (fff) One (1) totally enclosed soybean meal drag conveyor (DC 417), constructed in 1986, with a maximum capacity of 100.5 tons per hour controlled by a baghouse #2 and exhausting at stack point # S-6.
- (ggg) One (1) dry soybean meal transfer bucket elevator (BE 300), constructed in 1986, with a maximum capacity of 100.5 tons per hour controlled by a baghouse #2 and exhausting at stack point # S-6.
- (hhh) Two (2) totally enclosed dry soybean meal drag conveyors (DC 418 & 419), in series, constructed in 1986, each with a maximum capacity of 100.5 tons per hour aspirated to a baghouse #2 and exhausting at stack point # S-6.
- (iii) One (1) 48% meal tank constructed in 1986 with a maximum capacity of 1,000 tons.
- (jjj) One (1) 44% meal tank constructed in 1986 with a maximum capacity of 500 tons.
- (kkk) One (1) truck soybean meal and hull loadout system, constructed in 1986, with a maximum capacity of 200 tons per hour and controlled by a baghouse #5 and exhausting at stack point # S-14.
- (lll) One (1) rail soybean meal and hull loadout system, constructed in 1986, with a maximum capacity of 200 tons per hour controlled by a baghouse #5 and exhausting at stack point # S-14.
- (mmm) One (1) pneumatic flake conveying system consisting of two material handling baghouses #6 and 7, constructed in 1989, with a maximum capacity of 31.5 tons per hour and exhausting at stack points # S-22 and 23.
- (nnn) One (1) pneumatic reject flake conveying system consisting of one material baghouse #8, constructed in 1986, with a maximum capacity of 9 tons per hour and exhausting at stack point # S-24.
- (ooo) One (1) totally enclosed soybean flake screw conveyor, constructed in 1989, with a maximum capacity of 9 tons per hour (SC 218).
- (ppp) Two (2) totally enclosed soybean flake drag conveyors (DC 461 & 462), in series, constructed in 1989, each with a maximum capacity of 200 tons per hour.
- (qqq) One (1) soybean flake loadout system, constructed in 1989, with a maximum capacity of 200 tons per hour controlled by a baghouse #7 and exhausting at stack point # S-23.
- (rrr) One (1) pod grinder, constructed in 1990, with a maximum capacity of 3 tons per hour controlled by baghouse # 10 and exhausted at stack point # S-2.
- (sss) One (1) pneumatic hull conveying system consisting of one material handling filter separator, constructed in 1986, with a maximum capacity of 6 tons per hour and exhausting at stack point # S-4.
- (ttt) One (1) flake desolventizer system, constructed in 1989, with a maximum capacity of

100.5 tons per hour and controlled by a mineral oil absorber system.

Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.

- (uuu) One (1) flake desolventizer system cooler collector, constructed in 1989, with a maximum capacity of 100.5 tons per hour equipped with a fabric filter media separator (baghouse #6) and exhausted at stack point S-22.

Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.

- (vvv) One (1) first stage rising film evaporator associated with the solvent extraction equipment (EU-13), constructed in 2006, with a maximum capacity of 20 tons of soybean oil per hour and controlled by the mineral oil system and exhausted at stack point S-15.

Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.

- (www) One (1) Iso-hexane conversion system (involving a rotocell condenser, a refrigerant type cooler with condenser and an additional cooling tower cell and pump), constructed in 2002, and controlled by the mineral oil system and exhausted at stack point S-15.

Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.

- (xxx) One (1) mineral oil absorber system, constructed in 1982, with a maximum capacity of 150 pounds of hexane per hour and exhausted at stack point S-15. Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.

- (yyy) One (1) solvent/water separator, constructed in 2002, with a maximum capacity of 600 gallons per minute and controlled by the mineral oil system and exhausted at stack point S-15.

Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.

- (zzz) One (1) boiler, identified as Boiler #1, constructed in 1955, with a heat input capacity of 60.0 MMBtu per hour, firing natural gas, distillate fuel oil, residual fuel oil, vegetable oil, animal fats ("tallow"), animal oils ("grease") or blends of these fuels. Emissions are exhausted to stack S-16.

- (aaaa) One (1) boiler, identified as Boiler #2, constructed in 1996, with a heat input capacity of 75.0 MMBtu per hour, firing natural gas, distillate fuel oil, residual fuel oil, vegetable oil, animal fats ("tallow"), animal oils ("grease") or blends of these fuels. Emissions are exhausted to stack S-17.

Under NSPS, Subpart Dc, this unit is considered to be an affected facility.

- (bbbb) Two (2) hexane tanks #809 A & B, constructed in 2002 and 2009, with a capacity of 18,800 and 18,800 gallons respectively, vented to the process for control except under emergency conditions when they are vented through the relief valve.

Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.

A.3 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-7-4(c)]  
[326 IAC 2-7-5(14)]

---

This stationary source also includes the following insignificant activities, as defined in 326 IAC 2-7-1(21):

- (a) An emission unit or activity whose potential uncontrolled emissions meet the exemption levels specified in 326 IAC 2-1.1-3(e)(1) or the exemption levels specified in the following,

whichever is lower:

- (1) For volatile organic compounds (VOC), the exemption limit is three (3) pounds per hour or fifteen (15) pounds per day.

And

For units with potential uncontrolled emissions of HAPs, that are not listed as insignificant in clauses (D) through (G) or defined as trivial in subdivision (40), an insignificant activity is any of the following:

- (1) Any unit, not regulated by a NESHAP, emitting greater than one (1) pound per day but less than five (5) pounds per day or one (1) ton per year of a single HAP.

Storage tanks emitting less than one (1) ton per year of a single HAP and less than fifteen (15) pounds per day of VOC.

- (1) Three (3) fuel oil storage tanks #860 A, B, and C, constructed in 1960, and with a maximum capacity of 25,000 gallons each.
  - (2) One (1) fuel oil storage tank #815, constructed in 1960, and with a maximum capacity of 125,000 gallons.
- (b) Emissions from a laboratory as defined in this clause. As used in this clause, "laboratory" means a place or activity devoted to experimental study or teaching, or to the testing and analysis of drugs, chemicals, chemical compounds or other substances, or similar activities, provided that the activities described in this clause are conducted on a laboratory scale. Activities are conducted on a laboratory scale if the containers used for reactions, transfers, and other handling of substances are designed to be easily and safely manipulated by one (1) person. If a facility manufactures or produces products for profit in any quantity, it shall not be considered to be a laboratory under this clause. Support activities necessary to the operation of the laboratory are considered to be part of the laboratory. Support activities do not include the provision of power to the laboratory from sources that provide power to multiple projects or from sources that would otherwise require permitting, such as boilers that provide power to an entire facility.
- (c) Combustion related activities, including the following:
- (1) Space heaters, process heaters, heat treat furnaces, or boilers using the following fuels:
    - (A) Natural gas-fired combustion sources with heat input equal to or less than ten million (10,000,000) British thermal units per hour.
    - (B) Propane or liquified petroleum gas or butane-fired combustion sources with heat input equal to or less than six million (6,000,000) British thermal units per hour.
  - (2) Combustion source flame safety purging on startup.
  - (3) Equipment powered by diesel fuel fired or natural gas fired internal combustion engines of capacity equal to or less than five hundred thousand (500,000) Btu/hour, except where total capacity of equipment operated by one stationary source exceeds two million (2,000,000) Btu/hour.
    - (A) One (1) sixty-six (66) horsepower, non-emergency diesel powered air compressor, constructed in 2002, using a maximum of 8.8 gallons of #2 diesel fuel per hour.



This diesel powered air compressor is an affected facility under 40 CFR 63, Subpart ZZZZ.

- (d) The following VOC and HAP storage containers:
  - (1) Storage tanks with capacity less than or equal to one thousand (1,000) gallons and annual throughputs equal to or less than twelve thousand (12,000) gallons.
  - (2) Vessels storing the following:
    - (A) Lubricating oils.
    - (B) Hydraulic oils.
    - (C) Machining fluids.
- (e) Cleaners and solvents characterized as:
  - (1) having a vapor pressure equal to or less than two (2.0) kilo Pascals (fifteen (15) millimeters of mercury or three-tenths (0.3) pound per square inch) measured at thirty-eight (38) degrees Centigrade (one hundred (100) degrees Fahrenheit); or
  - (2) having a vapor pressure equal to or less than seven-tenths (0.7) kilo Pascal (five (5) millimeters of mercury or one-tenth (0.1) pound per square inch) measured at twenty (20) degrees Centigrade (sixty-eight (68) degrees Fahrenheit);
  - (3) One (1) parts washing station, constructed in 2002, with a maximum capacity of 145 gallons per year and exhausting inside.
- (f) Closed loop heating and cooling systems.
- (g) Water based activities, including the following:
  - (1) Activities associated with the treatment of wastewater streams with an oil and grease content less than or equal to one percent (1%) by volume.
    - (A) Noncontact cooling tower systems with either of the following:
      - (i) Forced and induced draft cooling tower systems not regulated under a NESHAP.
- (h) Repair activities, including the following:
  - (1) Replacement or repair of electrostatic precipitators, bags in baghouses, and filters in other air filtration equipment.
  - (2) Heat exchanger cleaning and repair.
  - (3) Process vessel degassing and cleaning to prepare for internal repairs.
- (i) Asbestos abatement projects regulated by 326 IAC 14-10.
- (j) Equipment used to collect any material that might be released during a malfunction, process upset, or spill cleanup, including the following:
  - (1) Catch tanks.
  - (2) Temporary liquid separators.
  - (3) Tanks.
  - (4) Fluid handling equipment.

- (k) Blowdown for the following:
  - (1) Sight glass.
  - (2) Boiler.
  - (3) Cooling tower.
  - (4) Compressors.
  - (5) Pumps.
- (l) Activities associated with emergencies, including the following:
  - (1) Stationary fire pump engines manufactured in the 1960s. Therefore, these units are not subject to the requirements of 40 CFR 60, Subpart IIII.
- (m) Purge double block and bleed valves.
- (n) Paved and unpaved roads and parking lots with public access. [6-5-4]

A.4 Part 70 Permit Applicability [326 IAC 2-7-2]

This stationary source is required to have a Part 70 permit by 326 IAC 2-7-2 (Applicability) because:

- (a) It is a major source, as defined in 326 IAC 2-7-1(22);
- (b) It is a source in a source category designated by the United States Environmental Protection Agency (U.S. EPA) under 40 CFR 70.3 (Part 70 - Applicability).

## SECTION B GENERAL CONDITIONS

### B.1 Definitions [326 IAC 2-7-1]

---

Terms in this permit shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, the applicable definitions found in the statutes or regulations (IC 13-11, 326 IAC 1-2 and 326 IAC 2-7) shall prevail.

### B.2 Permit Term [326 IAC 2-7-5(2)] [326 IAC 2-1.1-9.5] [326 IAC 2-7-4(a)(1)(D)] [IC 13-15-3-6(a)]

---

- (a) This permit, T157-25200-00038, is issued for a fixed term of five (5) years from the issuance date of this permit, as determined in accordance with IC 4-21.5-3-5(f) and IC 13-15-5-3. Subsequent revisions, modifications, or amendments of this permit do not affect the expiration date of this permit.
- (b) If IDEM, OAQ, upon receiving a timely and complete renewal permit application, fails to issue or deny the permit renewal prior to the expiration date of this permit, this existing permit shall not expire and all terms and conditions shall continue in effect, including any permit shield provided in 326 IAC 2-7-15, until the renewal permit has been issued or denied.

### B.3 Term of Conditions [326 IAC 2-1.1-9.5]

---

Notwithstanding the permit term of a permit to construct, a permit to operate, or a permit modification, any condition established in a permit issued pursuant to a permitting program approved in the state implementation plan shall remain in effect until:

- (a) the condition is modified in a subsequent permit action pursuant to Title I of the Clean Air Act; or
- (b) the emission unit to which the condition pertains permanently ceases operation.

### B.4 Enforceability [326 IAC 2-7-7] [IC 13-17-12]

---

Unless otherwise stated, all terms and conditions in this permit, including any provisions designed to limit the source's potential to emit, are enforceable by IDEM, the United States Environmental Protection Agency (U.S. EPA) and by citizens in accordance with the Clean Air Act.

### B.5 Severability [326 IAC 2-7-5(5)]

---

The provisions of this permit are severable; a determination that any portion of this permit is invalid shall not affect the validity of the remainder of the permit.

### B.6 Property Rights or Exclusive Privilege [326 IAC 2-7-5(6)(D)]

---

This permit does not convey any property rights of any sort or any exclusive privilege.

### B.7 Duty to Provide Information [326 IAC 2-7-5(6)(E)]

---

- (a) The Permittee shall furnish to IDEM, OAQ, within a reasonable time, any information that IDEM, OAQ may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. Upon request, the Permittee shall also furnish to IDEM, OAQ copies of records required to be kept by this permit.
- (b) For information furnished by the Permittee to IDEM, OAQ, the Permittee may include a claim of confidentiality in accordance with 326 IAC 17.1. When furnishing copies of requested records directly to U. S. EPA, the Permittee may assert a claim of confidentiality in accordance with 40 CFR 2, Subpart B.

**B.8 Certification [326 IAC 2-7-4(f)] [326 IAC 2-7-6(1)] [326 IAC 2-7-5(3)(C)]**

---

- (a) A certification required by this permit meets the requirements of 326 IAC 2-7-6(1) if:
- (1) it contains a certification by a "responsible official" as defined by 326 IAC 2-7-1(34), and
  - (2) the certification states that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
- (b) The Permittee may use the attached Certification Form, or its equivalent with each submittal requiring certification. One (1) certification may cover multiple forms in one (1) submittal.
- (c) A "responsible official" is defined at 326 IAC 2-7-1(34).

**B.9 Annual Compliance Certification [326 IAC 2-7-6(5)]**

---

- (a) The Permittee shall annually submit a compliance certification report which addresses the status of the source's compliance with the terms and conditions contained in this permit, including emission limitations, standards, or work practices. All certifications shall cover the time period from January 1 to December 31 of the previous year, and shall be submitted no later than July 1 of each year to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V  
Air and Radiation Division, Air Enforcement Branch - Indiana (AE-17J)  
77 West Jackson Boulevard  
Chicago, Illinois 60604-3590

- (b) The annual compliance certification report required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
- (c) The annual compliance certification report shall include the following:
- (1) The appropriate identification of each term or condition of this permit that is the basis of the certification;
  - (2) The compliance status;
  - (3) Whether compliance was continuous or intermittent;
  - (4) The methods used for determining the compliance status of the source, currently and over the reporting period consistent with 326 IAC 2-7-5(3); and
  - (5) Such other facts, as specified in Sections D of this permit, as IDEM, OAQ may require to determine the compliance status of the source.

The submittal by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

**B.10 Preventive Maintenance Plan [326 IAC 2-7-5(12)][326 IAC 1-6-3]**

---

- (a) A Preventive Maintenance Plan meets the requirements of 326 IAC 1-6-3 if it includes, at a minimum:
- (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;
  - (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
  - (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

The Permittee shall implement the PMPs.

- (b) If required by specific condition(s) in Section D of this permit where no PMP was previously required, the Permittee shall prepare and maintain Preventive Maintenance Plans (PMPs) no later than ninety (90) days after issuance of this permit or ninety (90) days after initial start-up, whichever is later, including the following information on each facility:
- (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;
  - (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
  - (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

If, due to circumstances beyond the Permittee's control, the PMPs cannot be prepared and maintained within the above time frame, the Permittee may extend the date an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

The PMP extension notification does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

The Permittee shall implement the PMPs.

- (c) A copy of the PMPs shall be submitted to IDEM, OAQ upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. IDEM, OAQ may require the Permittee to revise its PMPs whenever lack of proper maintenance causes or is the primary contributor to an exceedance of any limitation on emissions. The PMPs and their submittal do not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

- (d) To the extent the Permittee is required by 40 CFR Part 60/63 to have an Operation Maintenance, and Monitoring (OMM) Plan for a unit, such Plan is deemed to satisfy the PMP requirements of 326 IAC 1-6-3 for that unit.

**B.11 Emergency Provisions [326 IAC 2-7-16]**

---

- (a) An emergency, as defined in 326 IAC 2-7-1(12), is not an affirmative defense for an action brought for noncompliance with a federal or state health-based emission limitation.
- (b) An emergency, as defined in 326 IAC 2-7-1(12), constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limitation if the affirmative defense of an emergency is demonstrated through properly signed, contemporaneous operating logs or other relevant evidence that describe the following:

- (1) An emergency occurred and the Permittee can, to the extent possible, identify the causes of the emergency;
- (2) The permitted facility was at the time being properly operated;
- (3) During the period of an emergency, the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards or other requirements in this permit;
- (4) For each emergency lasting one (1) hour or more, the Permittee notified IDEM, OAQ, within four (4) daytime business hours after the beginning of the emergency, or after the emergency was discovered or reasonably should have been discovered;

Telephone Number: 1-800-451-6027 (ask for Office of Air Quality, Compliance and Enforcement Branch), or  
Telephone Number: 317-233-0178 (ask for Office of Air Quality, Compliance and Enforcement Branch)  
Facsimile Number: 317-233-6865

- (5) For each emergency lasting one (1) hour or more, the Permittee submitted the attached Emergency Occurrence Report Form or its equivalent, either by mail or facsimile to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

within two (2) working days of the time when emission limitations were exceeded due to the emergency.

The notice fulfills the requirement of 326 IAC 2-7-5(3)(C)(ii) and must contain the following:

- (A) A description of the emergency;
- (B) Any steps taken to mitigate the emissions; and
- (C) Corrective actions taken.

The notification which shall be submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

- (6) The Permittee immediately took all reasonable steps to correct the emergency.
- (c) In any enforcement proceeding, the Permittee seeking to establish the occurrence of an emergency has the burden of proof.
- (d) This emergency provision supersedes 326 IAC 1-6 (Malfunctions). This permit condition is in addition to any emergency or upset provision contained in any applicable requirement.
- (e) The Permittee seeking to establish the occurrence of an emergency shall make records available upon request to ensure that failure to implement a PMP did not cause or contribute to an exceedance of any limitations on emissions. However, IDEM, OAQ may require that the Preventive Maintenance Plans required under 326 IAC 2-7-4(c)(8) be revised in response to an emergency.
- (f) Failure to notify IDEM, OAQ by telephone or facsimile of an emergency lasting more than one (1) hour in accordance with (b)(4) and (5) of this condition shall constitute a violation of 326 IAC 2-7 and any other applicable rules.
- (g) If the emergency situation causes a deviation from a technology-based limit, the Permittee may continue to operate the affected emitting facilities during the emergency provided the Permittee immediately takes all reasonable steps to correct the emergency and minimize emissions.

**B.12 Permit Shield [326 IAC 2-7-15] [326 IAC 2-7-20] [326 IAC 2-7-12]**

---

- (a) Pursuant to 326 IAC 2-7-15, the Permittee has been granted a permit shield. The permit shield provides that compliance with the conditions of this permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that either the applicable requirements are included and specifically identified in this permit or the permit contains an explicit determination or concise summary of a determination that other specifically identified requirements are not applicable. The Indiana statutes from IC 13 and rules from 326 IAC, referenced in conditions in this permit, are those applicable at the time the permit was issued. The issuance or possession of this permit shall not alone constitute a defense against an alleged violation of any law, regulation or standard, except for the requirement to obtain a Part 70 permit under 326 IAC 2-7 or for applicable requirements for which a permit shield has been granted.  
  
This permit shield does not extend to applicable requirements which are promulgated after the date of issuance of this permit unless this permit has been modified to reflect such new requirements.
- (b) If, after issuance of this permit, it is determined that the permit is in nonconformance with an applicable requirement that applied to the source on the date of permit issuance, IDEM, OAQ, shall immediately take steps to reopen and revise this permit and issue a compliance order to the Permittee to ensure expeditious compliance with the applicable requirement until the permit is reissued. The permit shield shall continue in effect so long as the Permittee is in compliance with the compliance order.
- (c) No permit shield shall apply to any permit term or condition that is determined after issuance of this permit to have been based on erroneous information supplied in the permit application. Erroneous information means information that the Permittee knew to

be false, or in the exercise of reasonable care should have been known to be false, at the time the information was submitted.

- (d) Nothing in 326 IAC 2-7-15 or in this permit shall alter or affect the following:
- (1) The provisions of Section 303 of the Clean Air Act (emergency orders), including the authority of the U.S. EPA under Section 303 of the Clean Air Act;
  - (2) The liability of the Permittee for any violation of applicable requirements prior to or at the time of this permit's issuance;
  - (3) The applicable requirements of the acid rain program, consistent with Section 408(a) of the Clean Air Act; and
  - (4) The ability of U.S. EPA to obtain information from the Permittee under Section 114 of the Clean Air Act.
- (e) This permit shield is not applicable to any change made under 326 IAC 2-7-20(b)(2) (Sections 502(b)(10) of the Clean Air Act changes) and 326 IAC 2-7-20(c)(2) (trading based on State Implementation Plan (SIP) provisions).
- (f) This permit shield is not applicable to modifications eligible for group processing until after IDEM, OAQ, has issued the modifications. [326 IAC 2-7-12(c)(7)]
- (g) This permit shield is not applicable to minor Part 70 permit modifications until after IDEM, OAQ, has issued the modification. [326 IAC 2-7-12(b)(8)]

**B.13** Prior Permits Superseded [326 IAC 2-1.1-9.5] [326 IAC 2-7-10.5]

- (a) All terms and conditions of permits established prior to T157-25200-00038 and issued pursuant to permitting programs approved into the state implementation plan have been either:
- (1) incorporated as originally stated,
  - (2) revised under 326 IAC 2-7-10.5, or
  - (3) deleted under 326 IAC 2-7-10.5.
- (b) Provided that all terms and conditions are accurately reflected in this combined permit, all previous registrations and permits are superseded by this combined new source review and part 70 operating permit.

**B.14** Termination of Right to Operate [326 IAC 2-7-10][326 IAC 2-7-4(a)]

The Permittee's right to operate this source terminates with the expiration of this permit unless a timely and complete renewal application is submitted at least nine (9) months prior to the date of expiration of the source's existing permit, consistent with 326 IAC 2-7-3 and 326 IAC 2-7-4(a).

**B.15** Permit Modification, Reopening, Revocation and Reissuance, or Termination [326 IAC 2-7-5(6)(C)] [326 IAC 2-7-8(a)] [326 IAC 2-7-9]

- (a) This permit may be modified, reopened, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a Part 70 Operating Permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any condition of this permit. [326 IAC 2-7-5(6)(C)] The notification by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).



- (b) This permit shall be reopened and revised under any of the circumstances listed in IC 13-15-7-2 or if IDEM, OAQ determines any of the following:
  - (1) That this permit contains a material mistake.
  - (2) That inaccurate statements were made in establishing the emissions standards or other terms or conditions.
  - (3) That this permit must be revised or revoked to assure compliance with an applicable requirement. [326 IAC 2-7-9(a)(3)]
- (c) Proceedings by IDEM, OAQ to reopen and revise this permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of this permit for which cause to reopen exists. Such reopening and revision shall be made as expeditiously as practicable. [326 IAC 2-7-9(b)]
- (d) The reopening and revision of this permit, under 326 IAC 2-7-9(a), shall not be initiated before notice of such intent is provided to the Permittee by IDEM, OAQ at least thirty (30) days in advance of the date this permit is to be reopened, except that IDEM, OAQ may provide a shorter time period in the case of an emergency. [326 IAC 2-7-9(c)]

B.16 Permit Renewal [326 IAC 2-7-3] [326 IAC 2-7-4] [326 IAC 2-7-8(e)]

- (a) The application for renewal shall be submitted using the application form or forms prescribed by IDEM, OAQ and shall include the information specified in 326 IAC 2-7-4. Such information shall be included in the application for each emission unit at this source, except those emission units included on the trivial or insignificant activities list contained in 326 IAC 2-7-1(21) and 326 IAC 2-7-1(40). The renewal application does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

Request for renewal shall be submitted to:

Indiana Department of Environmental Management  
Permit Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

- (b) A timely renewal application is one that is:
  - (1) Submitted at least nine (9) months prior to the date of the expiration of this permit; and
  - (2) If the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
- (c) If the Permittee submits a timely and complete application for renewal of this permit, the source's failure to have a permit is not a violation of 326 IAC 2-7 until IDEM, OAQ takes final action on the renewal application, except that this protection shall cease to apply if, subsequent to the completeness determination, the Permittee fails to submit by the deadline specified, pursuant to 326 IAC 2-7-4(a)(2)(D), in writing by IDEM, OAQ any additional information identified as being needed to process the application.

**B.17 Permit Amendment or Modification [326 IAC 2-7-11] [326 IAC 2-7-12]**

---

- (a) Permit amendments and modifications are governed by the requirements of 326 IAC 2-7-11 or 326 IAC 2-7-12 whenever the Permittee seeks to amend or modify this permit.
- (b) Any application requesting an amendment or modification of this permit shall be submitted to:
- Indiana Department of Environmental Management  
Permit Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251
- Any such application does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).
- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-7-11(c)(3)]

**B.18 Permit Revision Under Economic Incentives and Other Programs [326 IAC 2-7-5(8)] [326 IAC 2-7-12(b)(2)]**

---

- (a) No Part 70 permit revision or notice shall be required under any approved economic incentives, marketable Part 70 permits, emissions trading, and other similar programs or processes for changes that are provided for in a Part 70 permit.
- (b) Notwithstanding 326 IAC 2-7-12(b)(1) and 326 IAC 2-7-12(c)(1), minor Part 70 permit modification procedures may be used for Part 70 modifications involving the use of economic incentives, marketable Part 70 permits, emissions trading, and other similar approaches to the extent that such minor Part 70 permit modification procedures are explicitly provided for in the applicable State Implementation Plan (SIP) or in applicable requirements promulgated or approved by the U.S. EPA.

**B.19 Operational Flexibility [326 IAC 2-7-20] [326 IAC 2-7-10.5]**

---

- (a) The Permittee may make any change or changes at the source that are described in 326 IAC 2-7-20(b) or (c) without a prior permit revision, if each of the following conditions is met:
- (1) The changes are not modifications under any provision of Title I of the Clean Air Act;
  - (2) Any preconstruction approval required by 326 IAC 2-7-10.5 has been obtained;
  - (3) The changes do not result in emissions which exceed the limitations provided in this permit (whether expressed herein as a rate of emissions or in terms of total emissions);
  - (4) The Permittee notifies the:
- Indiana Department of Environmental Management  
Permit Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V  
Air and Radiation Division, Regulation Development Branch - Indiana (AR-18J)  
77 West Jackson Boulevard  
Chicago, Illinois 60604-3590

in advance of the change by written notification at least ten (10) days in advance of the proposed change. The Permittee shall attach every such notice to the Permittee's copy of this permit; and

- (5) The Permittee maintains records on-site, on a rolling five (5) year basis, which document all such changes and emission trades that are subject to 326 IAC 2-7-20(b) or (c). The Permittee shall make such records available, upon reasonable request, for public review.

Such records shall consist of all information required to be submitted to IDEM, OAQ in the notices specified in 326 IAC 2-7-20(b) or (c).

- (b) The Permittee may make Section 502(b)(10) of the Clean Air Act changes (this term is defined at 326 IAC 2-7-1(36)) without a permit revision, subject to the constraint of 326 IAC 2-7-20(a). For each such Section 502(b)(10) of the Clean Air Act change, the required written notification shall include the following:

- (1) A brief description of the change within the source;
- (2) The date on which the change will occur;
- (3) Any change in emissions; and
- (4) Any permit term or condition that is no longer applicable as a result of the change.

The notification which shall be submitted is not considered an application form, report or compliance certification. Therefore, the notification by the Permittee does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

- (c) Emission Trades [326 IAC 2-7-20(c)]  
The Permittee may trade emissions increases and decreases at the source, where the applicable SIP provides for such emission trades without requiring a permit revision, subject to the constraints of Section (a) of this condition and those in 326 IAC 2-7-20(c).
- (d) Alternative Operating Scenarios [326 IAC 2-7-20(d)]  
The Permittee may make changes at the source within the range of alternative operating scenarios that are described in the terms and conditions of this permit in accordance with 326 IAC 2-7-5(9). No prior notification of IDEM, OAQ, or U.S. EPA is required.
- (e) Backup fuel switches specifically addressed in, and limited under, Section D of this permit shall not be considered alternative operating scenarios. Therefore, the notification requirements of part (a) of this condition do not apply.

B.21 Source Modification Requirement [326 IAC 2-7-10.5]

A modification, construction, or reconstruction is governed by the requirements of 326 IAC 2.

B.21 Inspection and Entry [326 IAC 2-7-6] [IC 13-14-2-2] [IC 13-30-3-1] [IC 13-17-3-2]

Upon presentation of proper identification cards, credentials, and other documents as may be required by law, and subject to the Permittee's right under all applicable laws and regulations to

assert that the information collected by the agency is confidential and entitled to be treated as such, the Permittee shall allow IDEM, OAQ, U.S. EPA, or an authorized representative to perform the following:

- (a) Enter upon the Permittee's premises where a Part 70 source is located, or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
- (b) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, have access to and copy any records that must be kept under the conditions of this permit;
- (c) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, inspect any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit;
- (d) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, sample or monitor substances or parameters for the purpose of assuring compliance with this permit or applicable requirements; and
- (e) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, utilize any photographic, recording, testing, monitoring, or other equipment for the purpose of assuring compliance with this permit or applicable requirements.

B.22 Transfer of Ownership or Operational Control [326 IAC 2-7-11]

- (a) The Permittee must comply with the requirements of 326 IAC 2-7-11 whenever the Permittee seeks to change the ownership or operational control of the source and no other change in the permit is necessary.
- (b) Any application requesting a change in the ownership or operational control of the source shall contain a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new Permittee. The application shall be submitted to:  
  
Indiana Department of Environmental Management  
Permit Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251  
  
Any such application does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).
- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-7-11(c)(3)]

B.23 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-7-5(7)] [326 IAC 2-1.1-7]

- (a) The Permittee shall pay annual fees to IDEM, OAQ within thirty (30) calendar days of receipt of a billing. Pursuant to 326 IAC 2-7-19(b), if the Permittee does not receive a bill from IDEM, OAQ the applicable fee is due April 1 of each year.
- (b) Except as provided in 326 IAC 2-7-19(e), failure to pay may result in administrative enforcement action or revocation of this permit.
- (c) The Permittee may call the following telephone numbers: 1-800-451-6027 or 317-233-4230 (ask for OAQ, Billing, Licensing, and Training Section), to determine the appropriate permit fee.

B.24 Credible Evidence [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [62 FR 8314] [326 IAC 1-1-6]

For the purpose of submitting compliance certifications or establishing whether or not the Permittee has violated or is in violation of any condition of this permit, nothing in this permit shall preclude the use, including the exclusive use, of any credible evidence or information relevant to whether the Permittee would have been in compliance with the condition of this permit if the appropriate performance or compliance test or procedure had been performed.

## SECTION C SOURCE OPERATION CONDITIONS

Entire Source

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

#### C.1 Particulate Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2(e)(2), particulate emissions from any process not exempt under 326 IAC 6-3-1(b) or (c) which has a maximum process weight rate less than 100 pounds per hour and the methods in 326 IAC 6-3-2(b) through (d) do not apply shall not exceed 0.551 pounds per hour.

#### C.2 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-1 (Applicability) and 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

- (a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

#### C.3 Open Burning [326 IAC 4-1] [IC 13-17-9]

The Permittee shall not open burn any material except as provided in 326 IAC 4-1-3, 326 IAC 4-1-4 or 326 IAC 4-1-6. The previous sentence notwithstanding, the Permittee may open burn in accordance with an open burning approval issued by the Commissioner under 326 IAC 4-1-4.1.

#### C.4 Incineration [326 IAC 4-2] [326 IAC 9-1-2]

The Permittee shall not operate an incinerator except as provided in 326 IAC 4-2 or in this permit. The Permittee shall not operate a refuse incinerator or refuse burning equipment except as provided in 326 IAC 9-1-2 or in this permit.

#### C.5 Fugitive Dust Emissions [326 IAC 6-4]

The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions). 326 IAC 6-4-2(4) is not federally enforceable.

#### C.6 Stack Height [326 IAC 1-7]

The Permittee shall comply with the applicable provisions of 326 IAC 1-7 (Stack Height Provisions), for all exhaust stacks through which a potential (before controls) of twenty-five (25) tons per year or more of particulate matter or sulfur dioxide is emitted. The provisions of 326 IAC 1-7-1(3), 326 IAC 1-7-2, 326 IAC 1-7-3(c) and (d), 326 IAC 1-7-4, and 326 IAC 1-7-5(a), (b), and (d) are not federally enforceable.

#### C.7 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

- (a) Notification requirements apply to each owner or operator. If the combined amount of regulated asbestos containing material (RACM) to be stripped, removed or disturbed is at least 260 linear feet on pipes or 160 square feet on other facility components, or at least thirty-five (35) cubic feet on all facility components, then the notification requirements of

326 IAC 14-10-3 are mandatory. All demolition projects require notification whether or not asbestos is present.

- (b) The Permittee shall ensure that a written notification is sent on a form provided by the Commissioner at least ten (10) working days before asbestos stripping or removal work or before demolition begins, per 326 IAC 14-10-3, and shall update such notice as necessary, including, but not limited to the following:
  - (1) When the amount of affected asbestos containing material increases or decreases by at least twenty percent (20%); or
  - (2) If there is a change in the following:
    - (A) Asbestos removal or demolition start date;
    - (B) Removal or demolition contractor; or
    - (C) Waste disposal site.
- (c) The Permittee shall ensure that the notice is postmarked or delivered according to the guidelines set forth in 326 IAC 14-10-3(2).
- (d) The notice to be submitted shall include the information enumerated in 326 IAC 14-10-3(3).

All required notifications shall be submitted to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

The notice shall include a signed certification from the owner or operator that the information provided in this notification is correct and that only Indiana licensed workers and project supervisors will be used to implement the asbestos removal project. The notifications do not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

- (e) **Procedures for Asbestos Emission Control**  
The Permittee shall comply with the applicable emission control procedures in 326 IAC 14-10-4 and 40 CFR 61.145(c). Per 326 IAC 14-10-1, emission control requirements are applicable for any removal or disturbance of RACM greater than three (3) linear feet on pipes or three (3) square feet on any other facility components or a total of at least 0.75 cubic feet on all facility components.
- (f) **Demolition and Renovation**  
The Permittee shall thoroughly inspect the affected facility or part of the facility where the demolition or renovation will occur for the presence of asbestos pursuant to 40 CFR 61.145(a).
- (g) **Indiana Licensed Asbestos Inspector**  
The Permittee shall comply with 326 IAC 14-10-1(a) that requires the owner or operator, prior to a renovation/demolition, to use an Indiana Licensed Asbestos Inspector to thoroughly inspect the affected portion of the facility for the presence of asbestos. The requirement to use an Indiana Licensed Asbestos inspector is not federally enforceable.

### **Testing Requirements [326 IAC 2-7-6(1)]**

#### C.8 Performance Testing [326 IAC 3-6]

---

- (a) For performance testing required by this permit, a test protocol, except as provided elsewhere in this permit, shall be submitted to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

no later than thirty-five (35) days prior to the intended test date. The protocol submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

- (b) The Permittee shall notify IDEM, OAQ of the actual test date at least fourteen (14) days prior to the actual test date. The notification submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).
- (c) Pursuant to 326 IAC 3-6-4(b), all test reports must be received by IDEM, OAQ not later than forty-five (45) days after the completion of the testing. An extension may be granted by IDEM, OAQ if the Permittee submits to IDEM, OAQ a reasonable written explanation not later than five (5) days prior to the end of the initial forty-five (45) day period.

#### Compliance Requirements [326 IAC 2-1.1-11]

#### C.9 Compliance Requirements [326 IAC 2-1.1-11]

---

The commissioner may require stack testing, monitoring, or reporting at any time to assure compliance with all applicable requirements by issuing an order under 326 IAC 2-1.1-11. Any monitoring or testing shall be performed in accordance with 326 IAC 3 or other methods approved by the commissioner or the U. S. EPA.

#### Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]

#### C.10 Compliance Monitoring [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

---

Unless otherwise specified in this permit, for all monitoring requirements not already legally required, the Permittee shall be allowed up to ninety (90) days from the date of permit issuance or of initial start-up, whichever is later, to begin such monitoring. If due to circumstances beyond the Permittee's control, any monitoring equipment required by this permit cannot be installed and operated no later than ninety (90) days after permit issuance or the date of initial startup, whichever is later, the Permittee may extend the compliance schedule related to the equipment for an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

in writing, prior to the end of the initial ninety (90) day compliance schedule, with full justification of the reasons for the inability to meet this date.

The notification which shall be submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).



Unless otherwise specified in the approval for the new emission unit(s), compliance monitoring for new emission units or emission units added through a source modification shall be implemented when operation begins.

**C.11 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]**

---

- (a) When required by any condition of this permit, an analog instrument used to measure a parameter related to the operation of an air pollution control device shall have a scale such that the expected maximum reading for the normal range shall be no less than twenty percent (20%) of full scale.
- (b) The Permittee may request that the IDEM, OAQ approve the use of an instrument that does not meet the above specifications provided the Permittee can demonstrate that an alternative instrument specification will adequately ensure compliance with permit conditions requiring the measurement of the parameters.

**Corrective Actions and Response Steps [326 IAC 2-7-5] [326 IAC 2-7-6]**

**C.12 Emergency Reduction Plans [326 IAC 1-5-2] [326 IAC 1-5-3]**

---

Pursuant to 326 IAC 1-5-2 (Emergency Reduction Plans; Submission):

- (a) The Permittee shall maintain the most recently submitted written emergency reduction plans (ERPs) consistent with safe operating procedures.
- (b) Upon direct notification by IDEM, OAQ that a specific air pollution episode level is in effect, the Permittee shall immediately put into effect the actions stipulated in the approved ERP for the appropriate episode level. [326 IAC 1-5-3]

**C.13 Risk Management Plan [326 IAC 2-7-5(11)] [40 CFR 68]**

---

If a regulated substance, as defined in 40 CFR 68, is present at a source in more than a threshold quantity, the Permittee must comply with the applicable requirements of 40 CFR 68.

**C.14 Response to Excursions or Exceedances [326 IAC 2-7-5] [326 IAC 2-7-6]**

---

Upon detecting an excursion where a response step is required by the D Section or an exceedance of a limitation in this permit:

- (a) The Permittee shall take reasonable response steps to restore operation of the emissions unit (including any control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing excess emissions.
- (b) The response shall include minimizing the period of any startup, shutdown or malfunction. The response may include, but is not limited to, the following:
  - (1) initial inspection and evaluation;
  - (2) recording that operations returned or are returning to normal without operator action (such as through response by a computerized distribution control system);  
or
  - (3) any necessary follow-up actions to return operation to normal or usual manner of operation.
- (c) A determination of whether the Permittee has used acceptable procedures in response to an excursion or exceedance will be based on information available, which may include, but is not limited to, the following:
  - (1) monitoring results;

- (2) review of operation and maintenance procedures and records; and/or
- (3) inspection of the control device, associated capture system, and the process.
- (d) Failure to take reasonable response steps shall be considered a deviation from the permit.
- (e) The Permittee shall record the reasonable response steps taken.

**C.15 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5] [326 IAC 2-7-6]**

- (a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this permit exceed the level specified in any condition of this permit, the Permittee shall submit a description of its response actions to IDEM, OAQ, no later than seventy-five (75) days after the date of the test.
- (b) A retest to demonstrate compliance shall be performed no later than one hundred eighty (180) days after the date of the test. Should the Permittee demonstrate to IDEM, OAQ that retesting in one hundred eighty (180) days is not practicable, IDEM, OAQ may extend the retesting deadline.
- (c) IDEM, OAQ reserves the authority to take any actions allowed under law in response to noncompliant stack tests.

The response action documents submitted pursuant to this condition do require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

**Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

**C.16 Emission Statement [326 IAC 2-7-5(3)(C)(iii)] [326 IAC 2-7-5(7)] [326 IAC 2-7-19(c)] [326 IAC 2-6]**

Pursuant to 326 IAC 2-6-3(a)(1), the Permittee shall submit by July 1 of each year an emission statement covering the previous calendar year. The emission statement shall contain, at a minimum, the information specified in 326 IAC 2-6-4(c) and shall meet the following requirements:

- (1) Indicate estimated actual emissions of all pollutants listed in 326 IAC 2-6-4(a);
- (2) Indicate estimated actual emissions of regulated pollutants as defined by 326 IAC 2-7-1(32) ("Regulated pollutant, which is used only for purposes of Section 19 of this rule") from the source, for purpose of fee assessment.

The statement must be submitted to:

Indiana Department of Environmental Management  
Technical Support and Modeling Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-50 IGCN 1003  
Indianapolis, Indiana 46204-2251

The emission statement does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

**C.17 General Record Keeping Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [326 IAC 2-2] [326 IAC 2-3]**

- (a) Records of all required monitoring data, reports and support information required by this permit shall be retained for a period of at least five (5) years from the date of monitoring sample, measurement, report, or application. Support information includes the following:

- (AA) All calibration and maintenance records.
- (BB) All original strip chart recordings for continuous monitoring instrumentation.
- (CC) Copies of all reports required by the FESOP
- (DD)

Records of required monitoring information include the following:

- (AA) The date, place as defined in this permit, and time of sampling or measurements.
- (BB) The dates analyses were performed.
- (CC) The company or entity that performed the analyses.
- (DD) The analytical techniques or methods used.
- (EE) The results of such analyses.
- (FF) The operating conditions as existing at the time of sampling or measurement.

These records shall be physically present or electronically accessible at the source location for a minimum of three (3) years. The records may be stored elsewhere for the remaining two (2) years as long as they are available upon request. If the Commissioner makes a request for records to the Permittee, the Permittee shall furnish the records to the Commissioner within a reasonable time.

- (b) Unless otherwise specified in this permit, for all record keeping requirements not already legally required, the Permittee shall be allowed up to ninety (90) days from the date of permit issuance or the date of initial start-up, whichever is later, to begin such record keeping.
- (c) If there is a reasonable possibility (as defined in 326 IAC 2-2-8(b)(6)(A), 326 IAC 2-2-8(b)(6)(b), 326 IAC 2-3-2(l)(6)(A), and/or 326 IAC 2-3-2(l)(6)(B) that a "project" (as defined in 326 IAC 2-2-1(qq) and/or 326 IAC 2-3-1(ll)) at an existing emissions unit, other than projects at a source with a Plantwide Applicability Limitation (PAL), which is not part of a "major modification" (as defined in 326 IAC 2-2-1(dd) and/or 326 IAC 2-3-1(y)) may result in significant emissions increase and the Permittee elects to utilize the "projected actual emissions" (as defined in 326 IAC 2-2-1(pp) and/or 326 IAC 2-3-1(kk)), the Permittee shall comply with following:
  - (1) Before beginning actual construction of the "project" (as defined in 326 IAC 2-2-1(oo) and/or 326 IAC 2-3-1(jj)) at an existing emissions unit, document and maintain the following records:
    - (A) A description of the project.
    - (B) Identification of any emissions unit whose emissions of a regulated new source review pollutant could be affected by the project.
    - (C) A description of the applicability test used to determine that the project is not a major modification for any regulated NSR pollutant, including:
      - (i) Baseline actual emissions;
      - (ii) Projected actual emissions;
      - (iii) Amount of emissions excluded under section 326 IAC 2-2-1(pp)(2)(A)(iii) and/or 326 IAC 2-3-1(kk)(2)(A)(iii); and
      - (iv) An explanation for why the amount was excluded, and any netting calculations, if applicable.

- (d) If there is a reasonable possibility (as defined in 326 IAC 2-2-8(b)(6)(A) and/or 326 IAC 2-3-2(l)(6)(A)) that a "project" (as defined in 326 IAC 2-2-1~~(qq)~~(oo) and/or 326 IAC 2-3-1(jj) ) at an existing emissions unit, other than projects at a source with a Plantwide Applicability Limitation (PAL), which is not part of a "major modification" (as defined in 326 IAC 2-2-1(dd) and/or 326 IAC 2-3-1(y)) may result in significant emissions increase and the Permittee elects to utilize the "projected actual emissions" (as defined in 326 IAC 2-2-1(pp) and/or 326 IAC 2-3-1(kk)), the Permittee shall comply with following:
- (1) Monitor the emissions of any regulated NSR pollutant that could increase as a result of the project and that is emitted by any existing emissions unit identified in (1)(B) above; and
  - (2) Calculate and maintain a record of the annual emissions, in tons per year on a calendar year basis, for a period of five (5) years following resumption of regular operations after the change, or for a period of ten (10) years following resumption of regular operations after the change if the project increases the design capacity of or the potential to emit that regulated NSR pollutant at the emissions unit.

C.18 General Reporting Requirements [326 IAC 2-7-5(3)(C)] [326 IAC 2-1.1-11] [326 IAC 2-2]

- (a) The Permittee shall submit the attached Quarterly Deviation and Compliance Monitoring Report or its equivalent. Proper notice submittal under Section B - Emergency Provisions satisfies the reporting requirements of paragraph (a) of Section C - General Reporting. Any deviation from permit requirements, the date(s) of each deviation, the cause of the deviation, and the response steps taken must be reported except that a deviation required to be reported pursuant to an applicable requirement that exists independent of this permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. This report shall be submitted not later than thirty (30) days after the end of the reporting period. The Quarterly Deviation and Compliance Monitoring Report shall include a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34). A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit.
- (b) The address for report submittal is:
- Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251
- (c) Unless otherwise specified in this permit, any notice, report, or other submission required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
- (d) Reporting periods are based on calendar years, unless otherwise specified in this permit. For the purpose of this permit "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.
- (e) If the Permittee is required to comply with the recordkeeping provisions of (d) in Section C - General Record Keeping Requirements for any "project" (as defined in 326 IAC 2-2-1(oo) and/or 326 IAC 2-3-1(jj)) at an existing emissions unit, and the project meets the following criteria, then the Permittee shall submit a report to IDEM, OAQ:

- (1) The annual emissions, in tons per year, from the project identified in (c)(1) in Section C- General Record Keeping Requirements exceed the baseline actual emissions, as documented and maintained under Section C- General Record Keeping Requirements (c)(1)(C)(i), by a significant amount, as defined in 326 IAC 2-2-1(ww) and/or 326 IAC 2-3-1(pp), for that regulated NSR pollutant, and
  - (2) The emissions differ from the preconstruction projection as documented and maintained under Section C - General Record Keeping Requirements (c)(1)(C)(ii).
- (f) The report for project at an existing emissions unit shall be submitted no later than sixty (60) days after the end of the year and contain the following:
- (1) The name, address, and telephone number of the major stationary source.
  - (2) The annual emissions calculated in accordance with (d)(1) and (2) in Section C - General Record Keeping Requirements.
  - (3) The emissions calculated under the actual-to-projected actual test stated in 326 IAC 2-2-2(d)(3) and/or 326 IAC 2-3-2(c)(3).
  - (4) Any other information that the Permittee wishes to include in this report such as an explanation as to why the emissions differ from the preconstruction projection.

Reports required in this part shall be submitted to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

- (g) The Permittee shall make the information required to be documented and maintained in accordance with (c) in Section C- General Record Keeping Requirements available for review upon a request for inspection by IDEM, OAQ. The general public may request this information from the IDEM, OAQ under 326 IAC 17.1.

### **Stratospheric Ozone Protection**

#### **C.19 Compliance with 40 CFR 82 and 326 IAC 22-1**

---

Pursuant to 40 CFR 82 (Protection of Stratospheric Ozone), Subpart F, except as provided for motor vehicle air conditioners in Subpart B, the Permittee shall comply with applicable standards for recycling and emissions reduction.

## SECTION D.0 FACILITY OPERATION CONDITIONS - Source Wide Limitations

Source-Wide Operations
------------------------

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

#### D.0.1 Consent Decree Limitations

Pursuant to the Consent Decree entered by the United States District Court for the District of Minnesota on March 3, 2006 in United States v. Cargill, Inc. No. 05-2037 (D.Minn.), the Permittee shall comply with the following emission limitations:

The Compliance Ratio shall be less than or equal to one (1).

#### D.0.2 State Implementation Plan

Pursuant to the Consent Decree entered by the United States District Court for the District of Minnesota on March 3, 2006 in United States v. Cargill, Inc. No. 05-2037 (D.Minn.), the Permittee shall apply to have the limitations in Condition D.0.1 incorporated into the State Implementation Plan.

### Compliance Determination Requirements

#### D.0.3 Volatile Organic Compounds (VOC)

The Permittee shall use the following equation to determine compliance with Condition D.0.1:

Specialty Solvent Loss Factor	Conventional Solvent Loss Factor
1.0 gal/ton	0.175 gal/ton

$$ComplianceRatio = \frac{ActualSolventLoss}{\sum_{i=1}^n ((Oilseed)_i * (SLF)_i)}$$

Where:

Actual Solvent Loss = Gallons of actual solvent loss during previous 12 operating months  
Oilseed = Tons of each oilseed type "i" (Specialty and Conventional) processed during the previous 12 operating months

SLF = The corresponding solvent loss ratio limit (gal/ton) for oilseed "i" listed in above Table

### Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

#### D.0.4 Record Keeping Requirements

(a) To document the compliance status with Condition D.0.1, the Permittee shall maintain records in accordance with (1) through (3) below. Records maintained for (1) through (3) shall be taken as stated below and shall be complete and sufficient to establish compliance with the Compliance Ratio established in Condition D.0.1.

- (1) Gallons of actual solvent loss during previous 12 operating months.
- (2) Types of oilseed processed during the previous 12 operating months.

- (3) Tons of each oilseed type "i" (Specialty and Conventional) processed during the previous 12 operating months.
- (b) Section C - General Record Keeping Requirements contains the Permittee's obligation with regard to the records required by this condition.

## SECTION D.1 FACILITY OPERATION CONDITIONS - Soybean Processing Facilities

### Facility Description [326 IAC 2-7-5(15)]

- (a) One (1) truck soybean receiving pit, constructed in 1989, with a maximum capacity of 25,000 bushels per hour, controlled by a receiving area baghouse #4 and exhausting at stack point # S-13.
- (b) One (1) totally enclosed truck soybean receiving pit drag conveyor (DC-431), constructed in 1989, with a maximum capacity of 25,000 bushels per hour, aspirated to baghouse #10, and exhausting at stack point # S-2.
- (c) One (1) totally enclosed soybean receiving pit drag conveyor (DC-432), constructed in 1989, with a maximum capacity of 25,000 bushels per hour, aspirated to baghouse #10, and exhausting at stack point # S-2.
- (d) One (1) rail soybean unloading system, constructed in 1956, with a maximum unloading capacity of 12,000 bushels per hour, controlled by baghouse #10 and exhausted at stack point S-2.
- (e) One (1) soybean receiving bucket elevator #301, constructed in 1989, with a maximum capacity of 25,000 bushels per hour, controlled by a baghouse #10 and exhausting at stack point # S-2.
- (f) Three (3) totally enclosed soybean drag conveyors (DC-441, 442, & 443) operated in series, constructed in 1988, each with a maximum capacity of 25,000 bushels per hour, each aspirated to baghouse #9 and exhausting at stack point # S-1.
- (g) One (1) totally enclosed soybean drag conveyor (DC-434), constructed in 1988, with a maximum capacity of 25,000 bushels per hour, aspirated to baghouse #10 and exhausting at stack point # S-2.
- (h) Four (4) soybean storage tanks, constructed in the 1950's, with a total capacity of 1,213,000 bushels.
- (i) Two (2) totally enclosed soybean drag conveyors (DC-436, & 437) operated in series, constructed in 1988, each with a maximum capacity of 5,000 bushels per hour, each aspirated to baghouse #10 and exhausting at stack point # S-2.
- (j) Two (2) totally enclosed soybean drag conveyors (DC-444, & 446) operated in series, constructed in 1988, each with a maximum capacity of 5,000 bushels per hour, each aspirated to baghouse #10 and exhausting at stack point # S-2.
- (k) One (1) soybean transfer bucket elevator #303, constructed in 1956, with a maximum capacity of 5,000 bushels per hour, controlled by a baghouse #10 and exhausting at stack point # S-2.
- (l) One (1) Texas shaker #2 screener, constructed in 1988, with a maximum capacity of 5,000 bushels per hour, controlled by a baghouse #1 and exhausting at stack point # S-3.
- (m) One (1) weed seed Kice, constructed in 1988, with a maximum capacity of 150 bushels per hour, controlled by a baghouse #1 and exhausting at stack point # S-3.
- (n) One (1) Kice #1, constructed in 1988, with a maximum capacity of 5,000 bushels per hour, controlled by a baghouse #1 and exhausting at stack point # S-3.
- (o) Two (2) totally enclosed soybean drag conveyors (DC-448, & 448A) operated in series, constructed in 1986 (DC-448) and 1996 (DC-448A), each with a maximum capacity of 5,000 bushels per hour, each aspirated to baghouse #1 and exhausting at stack point # S-3.
- (p) One (1) totally enclosed soybean screw conveyor (SC212), constructed in 1989 with a maximum



capacity of 150 bushels per hour.

- (q) One (1) 29 MMBtu natural gas fired soybean column dryer, constructed in 1986, with a maximum capacity of 5,000 bushels per hour and exhausting at stack point # S-20.
- (r) Two (2) totally enclosed soybean drag conveyors (DC-449, & 450) operated in series, constructed in 1986, each with a maximum capacity of 5,000 bushels per hour, each aspirated to baghouse #10 and exhausting at stack point # S-2.
- (s) One (1) dry soybean transfer bucket elevator #307, constructed in 1986, with a maximum capacity of 5,000 bushels per hour, controlled by a baghouse #9 and exhausting at stack point # S-1.
- (t) One (1) totally enclosed dry soybean drag conveyor (DC-453), constructed in 1988, with a maximum capacity of 5,000 bushels per hour, aspirated to baghouse #9 and exhausting at stack point # S-1.
- (u) Eighteen (18) soybean bins (501, 502, 503, 506, 507, 508, 511, 512, 513, 516, 517, 518, 521, 522, 523, 526, 527, and 528), constructed in the 1930's, with a maximum total capacity of 261,000 bushels.
- (v) Two (2) totally enclosed soybean drag conveyors (DC-454, & 447) operated in series, constructed in 1986, each with a maximum capacity of 5,000 bushels per hour each, each aspirated to baghouse #10 and exhausting at stack point # S-2.
- (w) One (1) dry soybean transfer bucket elevator #304, constructed in 1956, with a maximum capacity of 5,000 bushels per hour, controlled by a baghouse #10 and exhausting at stack point # S-2.
- (x) One (1) totally enclosed dry soybean drag conveyor (DC-400A), constructed in 1986, with a maximum capacity of 5,000 bushels per hour, aspirated to baghouse #3 and exhausting at stack point # S-7.
- (y) One (1) soybean Thayer scale, constructed in 1986, with a maximum capacity of 5000 bushels per hour, controlled by a baghouse #3 and exhausting at stack point # S-7.
- (z) Two (2) weed seed bins (#207 & 208) constructed in 1930, with a maximum storage capacity of 14,000 bushels each, a total nominal throughput of 5,000 bushels per day.
- (aa) Two (2) totally enclosed soybean screw conveyors (SC 213 & 214), operated in series, constructed in 1986, each with a maximum capacity of 150 bushels per hour.
- (bb) Three (3) totally enclosed soybean meal drag conveyors (DC-427, 428, & 429) operated in series, constructed in 1988, each with a maximum capacity of 5,000 bushels per hour each.
- (cc) One (1) totally enclosed dry soybean drag conveyor (DC-400), constructed in 1986, with a maximum capacity of 5,000 bushels per hour, aspirated to baghouse #3 and exhausting at stack point # S-7.
- (dd) Five (5) soybean surge bins, constructed in 1930, with a total maximum capacity of 22,000 bushels, and a total maximum throughput of 3,350 bushels per hour.
- (ee) Five (5) sets of cracking rolls (EU-6), constructed between 1986 and 2004, with a total maximum capacity of 3,350 bushels per hour (100.5 tons per hour), controlled by bag house #3 and exhausted at stack point S-7.
- (ff) Two (2) totally enclosed cracked soybean drag conveyor (DC-401 & 403) operated in series, constructed in 1986, each with a maximum capacity of 3350 bushels per hour, aspirated to baghouse #3 and exhausting at stack point # S-7.

- (gg) One (1) primary Kice #1, constructed in 1986, with a maximum capacity of 3350 bushels per hour, aspirated to baghouse #3 and exhausting at stack point # S-7.
- (hh) Two (2) totally enclosed cracked soybean screw conveyors (SC-201 & 202) operated in series, constructed in 1986, each with a maximum capacity of 3350 bushels per hour, aspirated to baghouse #3 and exhausting at stack point # S-7.
- (ii) One (1) triple S shaker, constructed in 1994, with a maximum capacity of 3350 bushels per hour, controlled by a baghouse #3 and exhausting at stack point # S-7.
- (jj) One (1) hull grinder, constructed in 1986, with a maximum capacity of 6 tons per hour, controlled by a cyclone #3 and a baghouse #3 and exhausting at stack point # S-7.
- (kk) One (1) coarse cut aspiration, constructed in 1994, with a maximum capacity of 150 bushels per hour, controlled by a cyclone #1 and a baghouse #3 and exhausting at stack point # S-7.
- (ll) One (1) fine cut aspiration, constructed in 1994, with a maximum capacity of 150 bushels per hour, controlled by a cyclone #2 and a baghouse #3 and exhausting at stack point # S-7.
- (mm) One (1) rotary conditioner, constructed in 1982, with a maximum capacity of 3350 bushels per hour, controlled by a cyclone #4 and exhausting at stack point # S-5.
- (nn) Four (4) totally enclosed conditioned soybean drag conveyor (DC-404, 405, 406 & 407), constructed in 1986, each with a maximum capacity of 3350 bushels per hour, controlled by a cyclone #4 and exhausting at stack point # S-5.
- (oo) Two (2) flaker banks #1 & 2, constructed in 1986, with a maximum total capacity of 100.5 tons per hour, controlled by a cyclone #4 and exhausting at stack point # S-5.
- (pp) Two (2) totally enclosed soybean flake screw conveyors (SC-206 & 207), constructed in 1986, with a total maximum capacity of 100.5 tons per hour, controlled by a cyclone #4 and exhausting at stack point # S-5.
- (qq) Two (2) expanders (EU-12), constructed in 1986, with a total maximum capacity of 833 bushels per hour (25 ton per hour), controlled by cyclone #4 and exhausted at stack point S-5.
- (rr) One (1) totally enclosed soybean flake drag conveyor (DC-409), constructed in 2005, with a maximum capacity 3350 bushels per hour, controlled by a cyclone #4 and exhausting at stack point # S-5.
- (ss) One (1) totally enclosed soybean flake drag conveyor (DC-410), constructed in 1986, with a maximum capacity of 100.5 tons per hour and exhausting at steam vents.
- (tt) One (1) totally enclosed soybean flake drag conveyor (DC-411), constructed in 1986, with a maximum capacity of 100.5 tons per hour and exhausting at safety vent.
- (uu) Two (2) fully enclosed, sealed conveyors, DC-412, and DC-413, and DT seal screw, constructed in 2006, with a maximum total capacity of 3,350 bushels per hour.
- (vv) One (1) totally enclosed soybean flake screw conveyor (SC-209), constructed in 1986, with a maximum capacity of 100.5 tons per hour.
- (ww) One (1) desolventizer/toaster (EU-16), constructed in 2006 with a maximum capacity of 3,350 bushels per hour controlled by the mineral oil system and exhausted at stack points S-15.

Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.

- (xx) One (1) dryer/cooler with three (3) dryer decks and one (1) cooler deck; constructed in 1988 (cooler deck), 1990 (1st dryer deck), 2006 (2<sup>nd</sup> & 3<sup>rd</sup> dryer decks), with a maximum total capacity of 3350 bushels per hour, controlled by four (4) integral cyclones identified as # 6, 7, 8, and 9, and exhausted at stack points # S-11, S-12, S-21, and S-25. Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.
- (yy) One (1) totally enclosed soybean meal drag conveyor (DC-414), constructed in 1986, with a maximum capacity of 100.5 tons per hour.
- (zz) Two (2) totally enclosed soybean meal drag conveyors (DC 414A & 415), in series, constructed in 1986, each with a maximum capacity of 100.5 tons per hour controlled by a baghouse #2 and exhausting at stack point # S-6.
- (aaa) Three (3) meal sifters, constructed in 1986, with a maximum total capacity of 100.5 tons per hour.
- (bbb) One (1) totally enclosed oversized soybean meal drag conveyor (DC 416), constructed by 1986, with a maximum capacity of 100.5 tons per hour controlled by a baghouse #2 and exhausting at stack point # S-6.
- (ccc) One (1) totally enclosed soybean meal screw conveyor (SC 223), constructed in 1986, with a maximum capacity of 100.5 tons per hour controlled by a baghouse #2 and exhausting at stack point # S-6.
- (ddd) Three soybean meal grinders, constructed in 1986, with a maximum total capacity of 100.5 tons per hour controlled by a baghouse #2 and exhausting at stack point # S-6.
- (eee) One (1) totally enclosed soybean meal screw conveyor (SC 221), constructed in 1986, with a maximum capacity of 100.5 tons per hour controlled by a baghouse #2 and exhausting at stack point # S-6.
- (fff) One (1) totally enclosed soybean meal drag conveyor (DC 417), constructed in 1986, with a maximum capacity of 100.5 tons per hour controlled by a baghouse #2 and exhausting at stack point # S-6.
- (ggg) One (1) dry soybean meal transfer bucket elevator (BE 300), constructed in 1986, with a maximum capacity of 100.5 tons per hour controlled by a baghouse #2 and exhausting at stack point # S-6.
- (hhh) Two (2) totally enclosed dry soybean meal drag conveyors (DC 418 & 419), in series, constructed in 1986, each with a maximum capacity of 100.5 tons per hour aspirated to a baghouse #2 and exhausting at stack point # S-6.
- (iii) One (1) 48% meal tank constructed in 1986 with a maximum capacity of 1,000 tons.
- (jjj) One (1) 44% meal tank constructed in 1986 with a maximum capacity of 500 tons.
- (kkk) One (1) truck soybean meal and hull loadout system, constructed in 1986, with a maximum capacity of 200 tons per hour and controlled by a baghouse #5 and exhausting at stack point # S-14.
- (lll) One (1) rail soybean meal and hull loadout system, constructed in 1986, with a maximum capacity of 200 tons per hour controlled by a baghouse #5 and exhausting at stack point # S-14.
- (mmm) One (1) pneumatic flake conveying system consisting of two material handling baghouses #6 and 7, constructed in 1989, with a maximum capacity of 31.5 tons per hour and exhausting at stack points # S-22 and 23.
- (nnn) One (1) pneumatic reject flake conveying system consisting of one material baghouse #8, constructed in 1986, with a maximum capacity of 9 tons per hour and exhausting at stack point # S-

24.

- (ooo) One (1) totally enclosed soybean flake screw conveyor, constructed in 1989, with a maximum capacity of 9 tons per hour (SC 218).
- (ppp) Two (2) totally enclosed soybean flake drag conveyors (DC 461 & 462), in series, constructed in 1989, each with a maximum capacity of 200 tons per hour.
- (qqq) One (1) soybean flake loadout system, constructed in 1989, with a maximum capacity of 200 tons per hour controlled by a baghouse #7 and exhausting at stack point # S-23.
- (rrr) One (1) pod grinder, constructed in 1990, with a maximum capacity of 3 tons per hour controlled by baghouse # 10 and exhausted at stack point # S-2.
- (sss) One (1) pneumatic hull conveying system consisting of one material handling filter separator, constructed in 1986, with a maximum capacity of 6 tons per hour and exhausting at stack point # S-4.
- (ttt) One (1) flake desolventizer system, constructed in 1989, with a maximum capacity of 100.5 tons per hour and controlled by a mineral oil absorber system.
- Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.
- (uuu) One (1) flake desolventizer system cooler collector, constructed in 1989, with a maximum capacity of 100.5 tons per hour equipped with a fabric filter media separator (baghouse #6) and exhausted at stack point S-22.
- Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.
- (vvv) One (1) first stage rising film evaporator associated with the solvent extraction equipment (EU-13), constructed in 2006, with a maximum capacity of 20 tons of soybean oil per hour and controlled by the mineral oil system and exhausted at stack point S-15.
- Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.
- (www) One (1) Iso-hexane conversion system (involving a rotocell condenser, a refrigerant type cooler with condenser and an additional cooling tower cell and pump), constructed in 2002, and controlled by the mineral oil system and exhausted at stack point S-15.
- Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.
- (xxx) One (1) mineral oil absorber system, constructed in 1982, with a maximum capacity of 150 pounds of hexane per hour and exhausted at stack point S-15.
- Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.
- (yyy) One (1) solvent/water separator, constructed in 2002, with a maximum capacity of 600 gallons per minute and controlled by the mineral oil system and exhausted at stack point S-15.
- Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.
- (zzz) One (1) boiler, identified as Boiler #1, constructed in 1955, with a heat input capacity of 60.0 MMBtu per hour, firing natural gas, distillate fuel oil, residual fuel oil, vegetable oil, animal fats ("tallow"), animal oils ("grease") or blends of these fuels. Emissions are exhausted to stack S-16.
- (aaaa) One (1) boiler, identified as Boiler #2, constructed in 1996, with a heat input capacity of 75.0 MMBtu per hour, firing natural gas, distillate fuel oil, residual fuel oil, vegetable oil, animal fats ("tallow"),

animal oils ("grease") or blends of these fuels. Emissions are exhausted to stack S-17.

Under NSPS, Subpart Dc, this unit is considered to be an affected facility.

(bbbb) Two (2) hexane tanks #809 A & B, constructed in 2002 and 2009, with a capacity of 18,800 and 18,800 gallons respectively, vented to the process for control except under emergency conditions when they are vented through the relief valve.

Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

**Emission Limitations and Standards [326 IAC 2-7-5(1)]**

**D.1.1 PSD Minor Limit [326 IAC 2-2]**

Pursuant to SSM157-11361-00038, issued on December 3, 2001,:

- (a) The soybean processed by the plant shall be limited to 821,250 tons per twelve (12) consecutive month period, with compliance demonstrated at the end of each month. This soybean limitation is required to limit the potential to emit of PM, and PM<sub>10</sub> emissions of 140.2 and 72.6 tons per twelve (12) consecutive months, respectively.
- (b) The soybean received by the dump bed trucks shall be limited to 82,125 tons per twelve (12) consecutive month period, with compliance demonstrated at the end of each month.
- (c) The reject flakes loadout shall be limited to 2,400 tons per twelve (12) consecutive month period, with compliance demonstrated at the end of each month.
- (d) The total natural gas or natural gas equivalent to Boiler no. 1 and Boiler no. 2 shall not exceed 794.13 million cubic feet per year.
- (e) The following facilities' PM and PM<sub>10</sub> emissions rates shall be limited as follows:

Facility	Control	Air Flow Rate Limit (dscfm)	Grain Loading Limit (gr/dscf)	PM Limit (lbs/hour)	PM <sub>10</sub> Limit (lbs/hour)
Grain receiving system (Truck Soybean Receiving Pit)	Baghouse #4	14,000	0.003	0.360	0.360
Grain storage loading (bin vent emissions resulting from filling the four soybean storage tanks and 18 soybean storage bins from the grain receiving system)	No PM/PM10 control device	infinite	0.01	15.0	8.36

Facility	Control	Air Flow Rate Limit (dscfm)	Grain Loading Limit (gr/dscf)	PM Limit (lbs/hour)	PM <sub>10</sub> Limit (lbs/hour)
Grain storage unloading (DC-431, DC-432, rail soybean unloading system, bucket elevator #301, DC-434, DC-436, DC-437, DC-444, DC-446, bucket elevator #303, DC-454, DC-447, bucket elevator #304, DC-449, DC-450, and a pod grinder)	Baghouse #10	24,000	0.003	0.617	0.617
Bean screener (Texas shaker #2 screen, weed seed Kice, Kice #1, DC-448, and DC-448A)	Baghouse #1	14,000	0.0033	0.136	0.4
Grain tanks and silos loading (bin vent emissions resulting from filling the four soybean storage tanks and 18 soybean storage bins from the column dryer)	No PM/PM10 control device	-	-	3.05	1.72
Grain tanks and silos unloading (DC-441, DC-442, DC-443, bucket elevator #307, and DC-453)	Baghouse #9	16,200	0.003	0.417	0.417
Soybean cracking & hulling system (Soybean Thayer scale, DC-400A, DC-400, EU-6, DC-401, DC-403, primary Kice #1, SC-201, SC-202, triple S shaker, hull grinder, coarse cut aspiration, and fine cut aspiration)	Baghouse #3	21,000	0.03	0.540	0.540
Soybean flaking (rotary conditioner, DC-404, DC-405, DC-406, DC-407, flaker banks 1 & 2, SC-206, SC-207, EU-12, and DC-409)	Cyclone #4	17,000	0.006	0.874	0.874
Hull transfer (pneumatic hull conveying system)	No PM/PM10 control device	320	0.003	0.008	0.008
DTDC meal dryers	Integral Cyclone #6	10,000	0.007	0.600	0.600
DTDC meal dryers	Integral Cyclone #7	10,000	0.007	0.600	0.600
Meal coolers	Integral Cyclone #8	8,000	0.015 (PM) 0.019 (PM <sub>10</sub> )	1.029	1.30
Meal coolers	Integral Cyclone #9	8,000			

Facility	Control	Air Flow Rate Limit (dscfm)	Grain Loading Limit (gr/dscf)	PM Limit (lbs/hour)	PM <sub>10</sub> Limit (lbs/hour)
Meal sizing and grinding (DC-414A, DC-415, DC-416, SC-223, 3 soybean meal grinders, SC-221, DC-417, BE-300, DC-418, and DC-419)	Baghouse #2	5,500	0.005	0.236	0.236
FDS cooler collector	Baghouse #6	22,000	0.008	1.51	1.51
Truck and Rail soybean meal and hull loadout systems	Baghouse #5	16,000	0.004	0.549	0.549
Flake loadout (flake loadout system and pneumatic flake conveying system)	Integral Baghouse #7	10,000	0.004	0.343	0.343
Reject flake storage Based on 2400 tons of reject flake loadout	Baghouse #8	3,000	0.013	0.334	0.334
Hull blend back (pneumatic hull conveying system)	No PM/PM10 control device	320	0.01	0.027	0.027
Boiler no. 1 and 2	No PM/PM10 control device	794.13 Million cubic feet of natural gas or equivalent	-	7.60 lb per MMCF	7.60 lb per MMCF

Compliance with the above limits shall limit the PM and PM<sub>10</sub> emissions from the project permitted under SSM 157-11361-00038 to less than twenty-five (25) and fifteen (15) tons per twelve (12) consecutive month period, respectively, and render the requirements of 326 IAC 2-2 not applicable to SSM 157-11361-00038 for PM and PM<sub>10</sub>.

D.1.2 Best Available Control Technology (BACT) [326 IAC 2-2-3] [326 IAC 8-1-6]

Pursuant to 326 IAC 2-2-3 (BACT Requirements) as determined in SSM 157-11361-00038, the Permittee shall control volatile organic compound (VOC) emissions from the conventional and the specialty soybean oil extraction processes as follows:

(a)	<u>Facility</u>	<u>Control</u>	<u>VOC (Hexane) Emission Limit</u>
	Oil extractor	Mineral oil absorber system	0.012 gal/ton soybean
	Meal dryers	No VOC control device	0.0042 gal/ton soybean
	Meal cooler	No VOC control device	0.0 gal/ton soybean
	FDS Cooler collector	No VOC control device	0.391 gal/ton soybean
	Whole soybean extraction plant		0.503 gals/ton soybean processed
	Maximum annual		821,250 tons

soybean process  
 throughput

- (b) BACT for fugitive hexane loss shall include an annual leak check in accordance with Cargill's standard operating procedures accompanied by continuous monitoring of the process area by flammable gas monitors. The leak check shall be conducted in conjunction with the annual maintenance shutdown of the facility.

For emergency repairs and/or maintenance completed between annual maintenance shutdowns, a leak check shall be completed on the affected system before hexane is reintroduced into the system. Any leaks detected shall be repaired prior to introducing hexane into the system.

- (1) The Permittee shall immediately tag all detected leaks with a weatherproof and readily visible identification tag with a distinct number. Once a leaking component is detected, first-attempt repairs must be done within five days and be completed within 15 days of detecting the leaking components. If the repair can not be accomplished within 15 days, then the Permittee shall send a notice of inability to repair to the OAQ within 20 days of detecting the leak. The notice must be received by the Compliance Branch, Office of Air Quality, 100 North Senate Avenue, MC 61-53 IGCN 1003, Indianapolis, IN 46204-2251 within 20 days after the leak was detected. At a minimum the notice shall include the following:
- (A) Equipment, operator, and instrument identification number, and date of leak detection
  - (B) Measured concentration (ppm) and background (ppm)
  - (C) Leak identification number associated with the corresponding tag
  - (D) Reason of inability to repair within 5 to 15 days of detection

**D.1.3 Particulate Emission Limitations for Manufacturing Processes [326 IAC 6-3-2]**

Pursuant to 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes), particulate emissions from each of following operations shall not exceed the pound per hour limit listed in the table below:

Unit	Process Weight Rate (ton/hr)	PM Limit (lb/hr)
Truck Soybean receiving pit	750	73.93
DC-431	750	73.93
DC-432	750	73.93
rail soybean unloading system	360	65.09
soybean receiving bucket elevator #301	750	73.93
DC-441	750	73.93
DC-442	750	73.93
DC-443	750	73.93
DC-434	750	73.93
DC-436	150	55.44
DC-437	150	55.44
DC-444	150	55.44
DC-446	150	55.44
soybean transfer bucket elevator #303	150	55.44



Unit	Process Weight Rate (ton/hr)	PM Limit (lb/hr)
Texas shaker #2 screener	150	55.44
weed seed Kice	150	55.44
Kice #1	150	55.44
DC-448	150	55.44
DC-448A	150	55.44
DC-449	150	55.44
DC-450	150	55.44
soybean transfer bucket elevator #307	150	55.44
DC-453	150	55.44
DC-454	150	55.44
DC-447	150	55.44
dry soybean transfer bucket elevator #304	150	55.44
DC-400A	150	55.44
soybean Thayer scale	150	55.44
DC-400	150	55.44
Cracker Roll 1 (EU-6)	20.1	30.61
Cracker Roll 2 (EU 6)	20.1	30.61
Cracker Roll 3 (EU 6)	20.1	30.61
Cracker Roll 4 (EU 6)	20.1	30.61
Cracker Roll 5 (EU 6)	20.1	30.61
DC-401	100.5	51.33
DC-403	100.5	51.33
primary Kice #1	100.5	51.33
SC-201	100.5	51.33
SC-202	100.5	51.33
triple S shaker	100.5	51.33
hull grinder	6	12.23
coarse cut aspiration	4.5	11.23
fine cut aspiration	4.5	11.23
DC-414A	100.5	51.33
DC-415	100.5	51.33
DC-416	100.5	51.33
SC-223	100.5	51.33
Meal grinder #1	33.5	40.93
Meal grinder #2	33.5	40.93
Meal grinder #3	33.5	40.93
SC-221	100.5	51.33
DC-417	100.5	51.33
BE-300	100.5	51.33
DC-418	100.5	51.33
DC-419	100.5	51.33
truck soybean meal & hull loadout system	200	58.51
rail soybean meal & hull loadout system	200	58.51
pneumatic flake conveying system	31.5	40.39
pneumatic reject flake conveying system	9	17.87
soybean flake loadout system	200	58.51

Unit	Process Weight Rate (ton/hr)	PM Limit (lb/hr)
pod grinder	3	8.56
FDS cooler collector	100.5	51.33
rotary conditioner	100.5	51.33
DC-404	100.5	51.33
DC-405	100.5	51.33
DC-406	100.5	51.33
DC-407	100.5	51.33
flaker bank #1 & #2	100.5	51.33
SC-206	100.5	51.33
SC-207	100.5	51.33
EU-12	25	35.43
DC-409	100.5	51.33
Column dryer	150	55.44
4 soybean storage tanks	93.75	50.63
SC-212	4.5	11.23
18 storage bins	93.75	50.63
2 weed seed bins (207 & 208)	150	55.44
SC-213	150	55.44
SC-214	150	55.44
DC-427	150	55.44
DC-428	150	55.44
DC-429	150	55.44
5 surge bins	100.5	51.33
DC-410	100.5	51.33
DC-411	100.5	51.33
DC-412, DC-413, DC seal screw	100.5	51.33
SC-209	100.5	51.33
DC-414	100.5	51.33
3 meal sifters	100.5	51.33
SC-218	9	17.87
DC-461	200	58.51
DC-462	200	58.51
pneumatic hull conveying system	6	12.23

The pounds per hour limitations were calculated using the following equations:

Interpolation of the data for the process weight rate up to sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 4.10 P^{0.67} \quad \text{where } E = \text{rate of emission in pounds per hour and} \\ P = \text{process weight rate in tons per hour}$$

Interpolation and extrapolation of the data for the process weight rate in excess of sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 55.0 P^{0.11} - 40 \quad \text{where } E = \text{rate of emission in pounds per hour and} \\ P = \text{process weight rate in tons per hour}$$

The baghouses and cyclones used for control shall be in operation at all times their associated units are in operation, in order to comply with these limits. The column dryer, DC-412, DC-413, DC seal screw, SC-209, DC-414, and the 3 meal sifters shall have a control device installed in

order to comply these limits.

**D.1.4 Preventive Maintenance Plan [326 IAC 2-7-5(12)][326 IAC 1-6-3]**

---

A Preventive Maintenance Plan is required for this facility and any control devices. Section B - Preventive Maintenance Plan contains the Permittee's obligation with regard to the preventive maintenance plan required by this condition.

**Compliance Determination Requirements**

**D.1.5 Testing Requirements [326 IAC 2-7-6(1),(6)] [326 IAC 2-1.1-11] [40 CFR 60, Subpart DD]**

---

- (a) In order to demonstrate compliance with Conditions D.1.1 and D.1.3 and 40 CFR 60, Subpart DD (New Source Performance Standards for Grain Elevators), the Permittee shall perform PM and PM-10 testing of the following:

- Receiving area baghouse (#4)
- Receiving area baghouse (#10)
- Storage tank area baghouse (#9)
- Screening area baghouse (#1)
- Cracking system bag house (#3)
- Flaking Cyclone #4
- Meal sizing and screening (Baghouse #2)
- DTDC meal dryer #1 (Cyclone #6)
- DTDC meal cooler #1 (Cyclone #8)
- Hull storage (Cyclone #3)

not later than 180 days of publication of the new or revised condensable PM test method(s) referenced in the U. S. EPA's Final Rule for Implementation of the New Source Review (NSR) Program for Particulate Matter Less Than 2.5 Micrometers (PM<sub>2.5</sub>), signed on May 8th, 2008 utilizing methods approved by the Commissioner at least once every five (5) years from the date of the most recent valid compliance demonstration. Testing shall be conducted in accordance with the provisions of 326 IAC 3-6 (Source Sampling Procedures). Section C - Performance Testing contains the Permittee's obligation with regard to the performance testing required by this condition. PM-10 includes filterable and condensable PM.

- (b) In order to demonstrate compliance with Condition D.1.2, the Permittee shall perform VOC testing of the Mineral oil absorber utilizing methods approved by the Commissioner at least once every five (5) years from the date of the most recent valid compliance demonstration. Testing shall be conducted in accordance with the provisions of 326 IAC 3-6 (Source Sampling Procedures). Section C - Performance Testing contains the Permittee's obligation with regard to the performance testing required by this condition.

**D.1.6 VOC (BACT) Compliance [326 IAC 2-2]**

---

Compliance with Condition D.1.2 shall be demonstrated within 30 days of the end of each month by determining the average of twelve (12) consecutive month period of the followings:

- (a) The amount of VOC (hexane) used per calendar month.
- (b) The amounts of soybean processed by the conventional and specialty processes.
- (c) The gallons of hexane used per ton of soybean processed by the conventional and specialty processes.

**D.1.7 Solvent Loss Ratio [326 IAC 2-2] [40 CFR 64]**

---

Compliance with Condition D.1.2 shall be demonstrated within 30 days of the end of each month by determining the average of twelve (12) consecutive month period in the following manner:

Calculate a compliance ratio, which compares the actual VOC loss to the allowable VOC loss for the previous twelve (12) months. The equation to calculate a compliance ratio follows:

(a) Compliance Ratio = (Actual VOC loss) / (Allowable VOC loss) (Eq. 1)

(b) Equation 1 can also be expressed as a function of total solvent loss as shown in Equation 2.

(c) Compliance Ratio = 
$$\frac{[f * \text{Actual Solvent Loss}]}{1.00\{[(\text{Soybean processed})_C * (\text{SLF}_C)] + [(\text{Soybean processed})_S * (\text{SLF}_S)]\}}$$
 (Eq. 2)

f = The weighted average volume fraction of VOC in solvent received during the previous twelve (12) operating months, dimensionless

1.00 = The average volume fraction of VOC in solvent in the baseline performance data, dimensionless

Actual Solvent Loss = Gallons of actual solvent loss during previous twelve (12) operating month

SLF<sub>S</sub> = 1.5 gals/ton (for new source, specialty soybean process)

SLF<sub>C</sub> = 0.2 gals/ton (for existing source, conventional soybean process)

#### D.1.8 Particulate Matter (PM) and Particulate Matter 10 (PM<sub>10</sub>)

---

In order to comply with Conditions D.1.1 and D.1.3, the baghouses and cyclones shall be in operation and control emissions from the associated facilities at all times when the associated facilities are in operation.

### Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

#### D.1.9 Visible Emissions Notations

---

- (a) Visible emission notations of the stack exhaust S-13, S-2, S-1, S-3, S-20, S-7, S-5, S-11, S-12, S-21, S-25, S-6, S-14, S-4, S-22, S-23, and S-24 shall be performed once per day during normal daylight operations when exhausting to the atmosphere. A trained employee shall record whether emissions are normal or abnormal.
- (b) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.
- (c) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- (d) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.
- (e) If abnormal emissions are observed, the Permittee shall take reasonable response. Section C - Response to Excursions or Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition. Failure to take response steps shall be considered a deviation from this permit.

#### D.1.10 Broken or Failed Bag Detection

---

- (a) For a single compartment baghouse controlling emissions from a process operated continuously, a failed unit and the associated process shall be shut down immediately

until the failed unit has been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).

- (b) For a single compartment baghouse controlling emissions from a batch process, the feed to the process shall be shut down immediately until the failed unit has been repaired or replaced. The emissions unit shall be shut down no later than the completion of the processing of the material in the process line. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions).

Bag failure can be indicated by a significant drop in the baghouse's pressure reading with abnormal visible emissions, by an opacity violation, or by other means such as gas temperature, flow rate, air infiltration, leaks, dust traces or triboflows.

#### D.1.11 Cyclone Failure

---

In the event that cyclone failure has been observed:

A failed unit and the associated process shall be shut down immediately until the failed unit has been repaired or replaced. Operations may continue only if the event qualifies as an emergency and the Permittee satisfies the requirements of the emergency provisions of this permit (Section B - Emergency Provisions). Failure to take response steps shall be considered a deviation from this permit.

#### D.1.12 Mineral Oil Absorber [40 CFR 64]

---

- (a) The absorber shall operate at all times the oil extractor process is in operation within the mineral oil flow rate range of five (5) to thirty (30) gallons per minute or the average flow rate determined during the latest VOC (hexane) compliance test.
- (b) The Permittee shall monitor and record the mineral oil flow rate at least once per day. The Preventive Maintenance Plan for the absorber shall contain troubleshooting contingency and corrective actions for when the flow rate readings are outside of the normal range for any one reading.
- (c) The instruments used for determining the flow rate shall be subject to approval by IDEM, OAQ, and shall be calibrated or replaced at least once every six (6) months.
- (d) The gauge employed to take the mineral oil flow across the scrubber shall have a scale such that the expected normal reading shall be no less than 20 percent of full scale and be accurate within  $\pm 10\%$  of full scale reading. The instrument shall be quality assured and maintained as specified by the vendor.
- (e) In the event that the absorber's failure has been observed, an inspection will be conducted. Based upon the findings of the inspection, any corrective actions will be devised within twenty-four (24) hours of discovery and will include a timetable for completion.
- (f) The mineral oil to the mineral oil stripping column shall be kept at a minimum of 180°F for adequate stripping of the absorbed hexane from the oil. When the process is in operation, an electronic data management system (EDMS) shall record the instantaneous temperature on a frequency of not less than every two hours. As an alternate to installing an EDMS, manual readings shall be taken every two hours.

### **Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

#### D.1.13 Record Keeping Requirements

---

- (a) To document the compliance status with Conditions D.1.1 and D.1.3 the Permittee shall

maintain records of the following:

- (1) Visible emission notations of the stack exhaust during normal operation required under Condition D.1.9. The Permittee shall include in its daily record when a visible emission notation is not taken and the reason for the lack of a notation (e.g. the process did not operate that day).
- (b) To document the compliance status with Condition D.1.2(a), the Permittee shall maintain records of the following as required under Conditions D.1.6 and D.1.12:
  - (1) The amount of VOC (hexane) used per calendar month.
  - (2) The amounts of soybean processed by the conventional and specialty processes.
  - (3) The gallons of hexane used per ton of soybean processed by the conventional and specialty processes.
  - (4) The daily record of the mineral oil flow rate.
  - (5) The events of the absorber's failure, findings of the inspections subsequent to absorber's failure, the corrective actions taken, and the time table for completion.
  - (6) The operating temperatures of the mineral oil absorber.
  - (7) The temperature of the mineral oil stripping column.
- (c) To document the compliance status with Condition D.1.2(b):
  - (1) The Permittee shall maintain records of the following to verify compliance with the enhanced inspection, maintenance, and repair program.
    - (A) Equipment inspected;
    - (B) Date of inspection; and
    - (C) Determination of whether a leak was detected.
  - (2) If a leak is detected, the Permittee shall record the following information to verify compliance with the enhanced inspection, maintenance, and repair program.
    - (A) The equipment, operator, and instrument identification number;
    - (B) Measured concentration;
    - (C) Leak identification number associated with the corresponding tag;
    - (D) Date of repair;
    - (E) Reason for non-repair if unable to repair within 5 to 15 days of detection;
    - (F) Maintenance recheck if repaired-date, concentration, background; and
    - (G) Any appropriate comments.
- (d) To document the compliance status with Condition D.1.2(a), the Permittee shall maintain records of the solvent loss ratio and all information used to calculate the ratio as required under Condition D.1.7.

- (e) Section C - General Record Keeping Requirements contains the Permittee's obligation with regard to the records required by this condition.

#### D.1.14 Reporting Requirements

---

- (a) A quarterly summary of the information to document the compliance status with Conditions D.1.1(a), (b), and (c) shall be submitted not later than thirty (30) days after the end of the quarter being reported. Section C - General Reporting contains the Permittee's obligation with regard to the reporting required by this condition. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "Responsible Official" as defined by 326 IAC 2-7-1(34).
- (b) A quarterly summary of the information to document the compliance status with Condition D.1.2(a) shall be submitted not later than thirty (30) days after the end of the quarter being reported. Section C - General Reporting contains the Permittee's obligation with regard to the reporting required by this condition. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "Responsible Official" as defined by 326 IAC 2-7-1(34).

## SECTION D.2

## FACILITY OPERATION CONDITIONS - Boilers

### Facility Description [326 IAC 2-7-5(15)]

- (1) One (1) boiler, Model no. VLP, Erie City Iron Works, identified as Boiler #1, constructed in 1955, with a heat input capacity of 60.0 MMBtu per hour, firing natural gas, distillate fuel oil, residual fuel oil, vegetable oil, animal fats ("tallow"), animal oils ("grease") or blends of these fuels. Emissions are exhausted to stack S-16.
- (2) One (1) boiler, Model no. NS-C-57, Nebraska Boiler Company, identified as Boiler #2, constructed in 1996, with a heat input capacity of 75.0 MMBtu per hour, firing natural gas, distillate fuel oil, residual fuel oil, vegetable oil, animal fats ("tallow"), animal oils ("grease") or blends of these fuels. Emissions are exhausted to stack S-17.

Under NSPS, Subpart Dc, this unit is considered to be an affected facility.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

#### D.2.1 Particulate Matter Emissions [326 IAC 6-2-3] [326 IAC 6-2-4]

- (a) Pursuant to 326 IAC 6-2-3(d) (Particulate Matter Emission Limitations for Sources of Indirect Heating), the PM emissions from Boiler #1 shall be limited to 0.447 pounds per MMBtu heat input.
- (b) Pursuant to CP 157-5397, and 326 IAC 6-2-4 (Particulate Matter Emission Limitations for Sources of Indirect Heating), the PM emissions from Boiler #2 shall be limited to 0.304 pounds per MMBtu heat input.

#### D.2.2 PSD Minor Limit [326 IAC 2-2]

- (a) The input of fuel oil no.2 and no. 2 equivalents to Boiler #1 and Boiler #2 shall be limited to 102 and 1042 Kgal measured as no. 2 fuel oil per twelve (12) consecutive month period, with compliance demonstrated at the end of each month, respectively. For compliance purposes, the following equivalencies shall be used.

1Kgal of no. 4 fuel oil = 1.00 Kgal of no. 2 fuel oil  
1Kgal of no. 5 fuel oil = 1.16 Kgal of no. 2 fuel oil  
1Kgal of no. 6 fuel oil = 1.16 Kgal of no. 2 fuel oil

This usage limit is equivalent to a potential to emit of 39.0 tons of sulfur dioxide per year.

- (b) The input of natural gas and natural gas equivalents to Boiler #1 and Boiler #2 shall be limited to 314 MMCF and 657 MMCF of natural gas per twelve (12) consecutive month period, with compliance demonstrated at the end of each month, respectively. Compliance with these limits are necessary to restrict nitrogen oxide emissions from Boiler #1 and Boiler #2 to less than 22 tons per year and 46 tons per year, respectively.
- (c) When burning vegetable oil, or blends of vegetable oil and distillate fuel oil, nitrogen oxide emissions shall not exceed 0.162 pounds per million Btu heat input.
- (d) When burning grease, tallow, or blends of grease or tallow and fuels other than residual fuel oil, nitrogen oxide emissions shall not exceed 0.195 pounds per million Btu heat input.
- (e) Pursuant to Condition D.1.1, the combined input of natural gas and natural gas



equivalents to Boiler #1 and Boiler #2 shall be limited to 794.13 MMCF of natural gas per twelve (12) consecutive month period, with compliance demonstrated at the end of each month. Compliance with this limit is necessary to restrict nitrogen oxide emissions from Boiler #1 and Boiler #2 to less than 39.7 tons per year.

For compliance purposes, the following equivalencies shall be used.

1 Kgal of no. 2 fuel oil	= 0.143 MMCF of natural gas
1 Kgal of no. 4 fuel oil	= 0.143 MMCF of natural gas
1 Kgal of no. 5 fuel oil	= 0.393 MMCF of natural gas
1 Kgal of no. 6 fuel oil	= 0.393 MMCF of natural gas
1 Kgal of vegetable oil	= 0.209 MMCF of natural gas
1 Kgal of tallow	= 0.247 MMCF of natural gas
1 Kgal of grease	= 0.093 MMCF of natural gas

Compliance with this condition makes the Prevention of Significant Deterioration (PSD) rules (326 IAC 2-2) not applicable.

#### D.2.3 Sulfur Dioxide (SO<sub>2</sub>) [326 IAC 7-1.1-1] [326 IAC 7-1.1-2]

---

Pursuant to 326 IAC 7-1.2 (SO<sub>2</sub> Emissions Limitations):

- (a) The SO<sub>2</sub> emissions from the sixty (60) MMBtu per hour Boiler #1 shall not exceed five tenths (0.5) pounds per million Btu heat input when combusting distillate fuel oil; and
- (b) The SO<sub>2</sub> emissions from the sixty (60) MMBtu per hour Boiler #1 shall not exceed one and sixth tenths (1.6) pounds per million Btu heat input when combusting residual fuel oil.

#### D.2.4 Preventive Maintenance Plan [326 IAC 2-7-5(12)][326 IAC 1-6-3]

---

A Preventive Maintenance Plan is required for the boilers. Section B - Preventive Maintenance Plan contains the Permittee's obligation with regard to the preventive maintenance plan required by this condition.

### Compliance Determination Requirements

#### D.2.5 Sulfur Dioxide Emissions and Sulfur Content

---

Compliance with Condition D.2.3 shall be determined utilizing one of the following options:

- (a) Pursuant to 326 IAC 3-7-4, the Permittee shall demonstrate that the sulfur dioxide emissions from Boiler #1 do not exceed five-tenths (0.5) pound per million Btu heat input by:
  - (1) Providing vendor analysis of fuel oil delivered, if accompanied by a vendor certification, or;
  - (2) Analyzing the fuel oil sample to determine the sulfur content of the fuel oil via the procedures in 40 CFR 60, Appendix A, Method 19.
    - (A) Fuel oil samples may be collected from the fuel oil tank immediately after the fuel oil tank is filled and before any fuel oil is combusted; and
    - (B) If a partially empty fuel oil tank is refilled, a new sample and analysis would be required upon filling.
- (b) Compliance may also be determined by conducting a stack test for sulfur dioxide emissions from Boiler #1 and Boiler #2 using 40 CFR 60, Appendix A, Method 6 in accordance with the procedures in 326 IAC 3-6.

A determination of noncompliance pursuant to any of the methods specified in (a) and (b) above shall not be refuted by evidence of compliance pursuant to another method.

#### D.2.6 Testing Requirements [326 IAC 2-7-6(1),(6)] [326 IAC 2-1.1-11]

In order to demonstrate compliance with Condition D.2.2:

- (a) No later than 180 days from the commencement of vegetable oil combustion, the Permittee shall conduct performance tests for nitrogen oxide emissions on either Boiler #1 or Boiler #2 during vegetable oil combustion, and furnish the Commissioner a written report of the results of such performance tests.
- (b) No later than 180 days from the commencement of tallow combustion, the Permittee shall conduct performance tests for nitrogen oxide emissions on either Boiler #1 or Boiler #2 during tallow combustion, and furnish the Commissioner a written report of the results of such performance tests.
- (c) No later than 180 days from the commencement of grease combustion, the Permittee shall conduct performance tests for nitrogen oxide emissions on either Boiler #1 or Boiler #2 during grease combustion, and furnish the Commissioner a written report of the results of such performance tests.

#### D.2.7 Maintenance of Continuous Opacity Monitoring Equipment [326 IAC 2-7-5(3)(A)(iii)]

- (a) Prior to combusting residual fuel oil (fuel oils #4, #5, and #6) in Boiler no. 2 (S-17), the Permittee shall install, calibrate, maintain, and operate a COMS for measuring the opacity of the emissions from Boiler no. 2 discharged to the atmosphere and record the output of the system when combusting residual fuel oil. In addition, prompt corrective action shall be initiated whenever indicated.
- (b) All COMS shall meet the performance specifications of 40 CFR 60, Appendix B, Performance Specification No. 1, and are subject to monitor system certification requirements pursuant to 326 IAC 3-5.
- (c) In the event that a breakdown of a COMS occurs, a record shall be made of the times and reasons of the breakdown and efforts made to correct the problem.
- (d) Whenever a COMS is malfunctioning or is down for maintenance or repairs for a period of twenty-four (24) hours or more and a backup COMS is not online within twenty-four (24) hours of shutdown or malfunction of the primary COMS, the Permittee shall provide a certified opacity reader, who may be an employee of the Permittee or an independent contractor, to self-monitor the emissions from the emission unit stack.
  - (1) Visible emission readings shall be performed in accordance with 40 CFR 60, Appendix A, Method 9, for a minimum of five (5) consecutive six (6) minute averaging periods beginning not more than twenty-four (24) hours after the start of the malfunction or down time.
  - (2) Method 9 opacity readings shall be repeated for a minimum of five (5) consecutive six (6) minute averaging periods at least twice per day during daylight operations, with at least four (4) hours between each set of readings, until a COMS is online.
  - (3) Method 9 readings may be discontinued once a COMS is online.
  - (4) Any opacity exceedances determined by Method 9 readings shall be reported with the Quarterly Opacity Exceedances Reports.

- (e) Nothing in this permit shall excuse the Permittee from complying with the requirements to operate a continuous opacity monitoring system pursuant to 326 IAC 3-5, (and 40 CFR 60 and/or 40 CFR 63).

### **Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]**

#### **D.2.8 Visible Emissions Notations**

---

- (a) The Permittee shall perform visible emission notations of the Boiler #1 stack exhaust once per day during normal daylight operations, when combusting fuels other than natural gas. A trained employee shall record whether emissions are normal or abnormal.
- (b) The Permittee shall perform visible emission notations of the Boiler #2 stack exhaust once per day during normal daylight operations, when combusting fuels other than natural gas, if there is no COMS installed or if the COMS is down for maintenance or under breakdown. A trained employee shall record whether emissions are normal or abnormal.
- (c) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.
- (d) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- (e) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.
- (f) If abnormal emissions are observed, the Permittee shall take reasonable response. Section C - Response to Excursions or Exceedances contains the Permittee's obligation with regard to the reasonable response steps required by this condition. Failure to take response steps shall be considered a deviation from this permit.

### **Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

#### **D.2.9 Record Keeping Requirements**

---

- (a) To document the compliance status with Condition D.2.5 (a) (if selected), the Permittee shall keep a record of all fuel oil analysis.
- (b) To document the compliance status with Condition D.2.8(a) and (b), the Permittee shall maintain a record of visible emission notations of the Boiler #1 stack exhaust, and also the Boiler #2 stack exhaust if there is no COMS installed or if the COMS is malfunctioning or down for maintenance or repair. The Permittee shall include in its daily record when a visible emission notation is not taken and the reason for the lack of a notation (e.g. the process did not operate that day).
- (c) To document the compliance status with Condition D.2.2, the Permittee shall maintain the record of all the fuels burned in Boiler #1 and Boiler #2.
- (d) Section C - General Record Keeping Requirements contains the Permittee's obligation with regard to the records required by this condition. The Permittee shall retain records of all recording/monitoring data and support information for a period of five (5) years, or longer if specified elsewhere in this permit, from the date of the monitoring sample, measurement, or report. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit.

#### D.2.10 Reporting Requirements

---

- (a) The natural gas boiler certification shall be submitted not later than thirty (30) days after the end of the six (6) month period being reported. Section C - General Reporting contains the Permittee's obligation with regard to the reporting required by this condition. The natural gas-fired boiler certification submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).
  
- (b) A quarterly summary of the information to document compliance with Condition D.2.2 shall be submitted not later than thirty (30) days after the end of the six (6) month period being reported. Section C - General Reporting contains the Permittee's obligation with regard to the reporting required by this condition. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34).

## SECTION D.3

## FACILITY OPERATION CONDITIONS - Insignificant Activities

### Facility Description [326 IAC 2-7-5(15)] Insignificant Activities

- (a) Paved and unpaved roads and parking lots with public access. [326 IAC 6-5-4]

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

#### D.3.1 Fugitive Dust Emissions [326 IAC 6-4-2]

---

Pursuant to 326 IAC 6-4-2 (Fugitive Dust Emission Limitation), the fugitive dust shall not be visible crossing the boundary or property line of a source.

### Compliance Determination Requirements

#### D.3.2 Control Measures

---

Fugitive particulate matter emissions resulting from paved roads, unpaved roads and parking lots shall be controlled by using one or more of the following measures:

- (a) Paved roads and parking lots:
- (1) Cleaning by sweeping.
  - (2) Flushing.
  - (3) An equivalent alternate measure.
- (b) Unpaved roads and parking lots:
- (1) Paving with a material such as asphalt or concrete.
  - (2) Treating with a suitable and effective oil or chemical dust suppressant approved by the commissioner. The frequency shall be as on a needed basis.
  - (3) Spraying with water, the frequency of application shall be on a needed basis.
  - (4) Double chip and seal the road surface and maintain on an as needed basis.
  - (5) An equivalent alternate measures.

## SECTION D.4

## FACILITY OPERATION CONDITIONS

### Facility Description [326 IAC 2-7-5(15)]

- (1) One (1) parts washing station, constructed in 2002, with a maximum capacity of 145 gallons per year and exhausting inside.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### D.4.1 Volatile Organic Compounds (VOC) [326 IAC 8-3-2]

- (a) Pursuant to 326 IAC 8-3-2(a) (Cold Cleaner Degreaser Control Equipment and Operating Requirements, the owner or operator of a cold cleaner degreaser shall ensure that the following control equipment and operating requirements are met:
  - (1) Equip the degreaser with a cover.
  - (2) Equip the degreaser with a device for draining cleaned parts.
  - (3) Close the cover whenever articles are not being handled in the degreaser.
  - (4) Drain cleaned articles for at least fifteen (15) seconds or until dripping ceases.
  - (5) Provide a permanent, conspicuous label that lists the operating requirements in subdivisions (3), (4), (6), and (7).
  - (6) Store waste solvent only in closed containers.
  - (7) Prohibit the disposal or transfer of waste solvent in such a manner could allow greater than twenty percent (20%) of the waste solvent by weight to evaporate.
- (b) The owner or operator of a cold cleaner degreaser subject to this subsection shall ensure the following additional control equipment and operating requirements are met:
  - (1) Equip the degreaser with one (1) of the following control devices if the solvent is heated to a temperature of greater than forty-eight and nine-tenths (48.9) degrees Celsius (one hundred twenty (120) degrees Fahrenheit):
    - (A) A freeboard that attains a freeboard ratio of seventy-five hundredths (0.75) or greater.
    - (B) A water cover when solvent used is insoluble in, and heavier than, water.
    - (C) A refrigerated chiller.
    - (D) Carbon adsorption.
    - (E) An alternative system of demonstrated equivalent or better control as those outlined in clauses (A) through (D) that is approved by the department. An alternative system shall be submitted to the U.S. EPA as a SIP revision.

- (2) Ensure that the degreaser cover is designed so that it can be easily operated with one (1) hand if the solvent is agitated or heated.
- (3) If used, solvent spray:
  - (A) must be a solid, fluid stream; and
  - (B) shall be applied at a pressure that does not cause excessive splashing.

## SECTION E.1 NEW SOURCE PERFORMANCE STANDARDS (NSPS) FOR GRAIN ELEVATORS [40 CFR 60, Subpart DD]

### Facility Description [326 IAC 2-7-5(15)]

- (a) One (1) truck soybean receiving pit, constructed in 1989, with a maximum capacity of 25,000 bushels per hour, controlled by a receiving area baghouse #4 and exhausting at stack point # S-13.
- (b) One (1) totally enclosed truck soybean receiving pit drag conveyor (DC-431), constructed in 1989, with a maximum capacity of 25,000 bushels per hour, aspirated to baghouse #10, and exhausting at stack point # S-2.
- (c) One (1) totally enclosed soybean receiving pit drag conveyor (DC-432), constructed in 1989, with a maximum capacity of 25,000 bushels per hour, aspirated to baghouse #10, and exhausting at stack point # S-2.
- (d) One (1) rail soybean unloading system, constructed in 1956, with a maximum unloading capacity of 12,000 bushels per hour, controlled by baghouse #10 and exhausted at stack point S-2.
- (e) One (1) soybean receiving bucket elevator #301, constructed in 1989, with a maximum capacity of 25,000 bushels per hour, controlled by a baghouse #10 and exhausting at stack point # S-2.
- (f) Three (3) totally enclosed soybean drag conveyors (DC-441, 442, & 443) operated in series, constructed in 1988, each with a maximum capacity of 25,000 bushels per hour, each aspirated to baghouse #9 and exhausting at stack point # S-1.
- (g) One (1) totally enclosed soybean drag conveyor (DC-434), constructed in 1988, with a maximum capacity of 25,000 bushels per hour, aspirated to baghouse #10 and exhausting at stack point # S-2.
- (h) Four (4) soybean storage tanks, constructed in the 1950's, with a total capacity of 1,213,000 bushels.
- (i) Two (2) totally enclosed soybean drag conveyors (DC-436, & 437) operated in series, constructed in 1988, each with a maximum capacity of 5,000 bushels per hour, each aspirated to baghouse #10 and exhausting at stack point # S-2.
- (j) Two (2) totally enclosed soybean drag conveyors (DC-444, & 446) operated in series, constructed in 1988, each with a maximum capacity of 5,000 bushels per hour, each aspirated to baghouse #10 and exhausting at stack point # S-2.
- (k) One (1) soybean transfer bucket elevator #303, constructed in 1956, with a maximum capacity of 5,000 bushels per hour, controlled by a baghouse #10 and exhausting at stack point # S-2.
- (l) One (1) Texas shaker #2 screener, constructed in 1988, with a maximum capacity of 5,000 bushels per hour, controlled by a baghouse #1 and exhausting at stack point # S-3.
- (m) One (1) weed seed Kice, constructed in 1988, with a maximum capacity of 150 bushels per hour, controlled by a baghouse #1 and exhausting at stack point # S-3.
- (n) One (1) Kice #1, constructed in 1988, with a maximum capacity of 5,000 bushels per hour, controlled by a baghouse #1 and exhausting at stack point # S-3.



- (o) Two (2) totally enclosed soybean drag conveyors (DC-448, & 448A) operated in series, constructed in 1986 (DC-448) and 1996 (DC-448A), each with a maximum capacity of 5,000 bushels per hour, each aspirated to baghouse #1 and exhausting at stack point # S-3.
- (p) One (1) totally enclosed soybean screw conveyor (SC212), constructed in 1989 with a maximum capacity of 150 bushels per hour.
- (q) Two (2) totally enclosed soybean drag conveyors (DC-449, & 450) operated in series, constructed in 1986, each with a maximum capacity of 5,000 bushels per hour, each aspirated to baghouse #10 and exhausting at stack point # S-2.
- (r) One (1) dry soybean transfer bucket elevator #307, constructed in 1986, with a maximum capacity of 5,000 bushels per hour, controlled by a baghouse #9 and exhausting at stack point # S-1.
- (s) One (1) totally enclosed dry soybean drag conveyor (DC-453), constructed in 1988, with a maximum capacity of 5,000 bushels per hour, aspirated to baghouse #9 and exhausting at stack point # S-1.
- (t) Eighteen (18) soybean bins (501, 502, 503, 506, 507, 508, 511, 512, 513, 516, 517, 518, 521, 522, 523, 526, 527, and 528), constructed in the 1930's, with a maximum total capacity of 261,000 bushels.
- (u) Two (2) totally enclosed soybean drag conveyors (DC-454, & 447) operated in series, constructed in 1986, each with a maximum capacity of 5,000 bushels per hour each, each aspirated to baghouse #10 and exhausting at stack point # S-2.
- (v) One (1) dry soybean transfer bucket elevator #304, constructed in 1956, with a maximum capacity of 5,000 bushels per hour, controlled by a baghouse #10 and exhausting at stack point # S-2.
- (w) One (1) totally enclosed dry soybean drag conveyor (DC-400A), constructed in 1986, with a maximum capacity of 5,000 bushels per hour, aspirated to baghouse #3 and exhausting at stack point # S-7.
- (x) One (1) soybean Thayer scale, constructed in 1986, with a maximum capacity of 5000 bushels per hour, controlled by a baghouse #3 and exhausting at stack point # S-7.
- (y) Two (2) weed seed bins (#207 & 208) constructed in 1930, with a maximum storage capacity of 14,000 bushels each, a total nominal throughput of 5,000 bushels per day.
- (z) Two (2) totally enclosed soybean screw conveyors (SC 213 & 214), operated in series, constructed in 1986, each with a maximum capacity of 150 bushels per hour.
- (aa) Three (3) totally enclosed soybean meal drag conveyors (DC-427, 428, & 429) operated in series, constructed in 1988, each with a maximum capacity of 5,000 bushels per hour each.
- (bb) One (1) totally enclosed dry soybean drag conveyor (DC-400), constructed in 1986, with a maximum capacity of 5,000 bushels per hour, aspirated to baghouse #3 and exhausting at stack point # S-7.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

E.1.1 General Provisions Relating to New Source Performance Standards [326 IAC 12-1] [40 CFR 60, Subpart A]

- (a) The provisions of 40 CFR 60, Subpart A – General Provisions, which are incorporated by

reference in 326 IAC 12-1, apply to the facilities described in this SECTION E.1, except when otherwise specified in 40 CFR 60, Subpart DD.

- (b) Pursuant to 40 CFR 60.19, the Permittee shall submit all required notifications and reports to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Ave.  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

E.1.2 Standards of Performance for Grain Elevators [40 CFR 60, Subpart DD] [326 IAC 12]

Pursuant to 40 CFR 60, Subpart DD, the Permittee shall comply with the provisions of Standards of Performance Standards of Performance for Grain Elevators, which are incorporated by reference as 326 IAC 12, (included as attachment A of this permit) as specified as follows:

- (1) 40 CFR 60.300
- (2) 40 CFR 60.301
- (3) 40 CFR 60.302(b)(c)(1)(2)(3)
- (4) 40 CFR 60.303
- (5) 40 CFR 60.304

## SECTION E.2 NEW SOURCE PERFORMANCE STANDARDS (NSPS) FOR SMALL INDUSTRIAL-COMMERCIAL-INSTITUTIONAL STEAM GENERATING UNITS [40 CFR 60, Subpart Dc]

### Facility Description [326 IAC 2-7-5(15)]

- (1) One (1) boiler, Model no. NS-C-57, Nebraska Boiler Company, identified as Boiler #2, constructed in 1996, with a heat input capacity of 75.0 MMBtu per hour, firing natural gas, distillate fuel oil, residual fuel oil, vegetable oil, animal fats ("tallow"), animal oils ("grease") or blends of these fuels. Emissions are exhausted to stack S-17.

Under NSPS, Subpart Dc, this unit is considered to be an affected facility.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### E.2.1 General Provisions Relating to New Source Performance Standards [326 IAC 12-1] [40 CFR 60, Subpart A]

- (a) The provisions of 40 CFR 60, Subpart A – General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the facilities described in this SECTION E.1, except when otherwise specified in 40 CFR 60, Subpart Dc.
- (b) Pursuant to 40 CFR 60.19, the Permittee shall submit all required notifications and reports to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Ave.  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

### E.2.2 Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units [40 CFR 60, Subpart Dc] [326 IAC 12]

Pursuant to 40 CFR 60, Subpart Dc, the Permittee shall comply with the provisions of Standards of Performance Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units, which are incorporated by reference as 326 IAC 12, (included as attachment B of this permit) as specified as follows:

- (1) 40 CFR 60.40c  
(2) 40 CFR 60.41c  
(3) 40 CFR 60.42c(d)(e)(g)(h)(i)  
(4) 40 CFR 60.43c(c)(d)  
(5) 40 CFR 60.44c(a)(b)(c)(e)(g)(h)(i)(j)  
(6) 40 CFR 60.45c(a)(c)  
(7) 40 CFR 60.46c  
(8) 40 CFR 60.47c  
(9) 40 CFR 60.48c all except (f)(3)

### SECTION E.3 NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS: SOLVENT EXTRACTION FOR VEGETABLE OIL PRODUCTION [40 CFR 63, Subpart GGGG]

#### Facility Description [326 IAC 2-7-5(15)]

- (a) One (1) desolventizer/toaster (EU-16), constructed in 2006 with a maximum capacity of 3,350 bushels per hour controlled by the mineral oil system and exhausted at stack points S-15.
- Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.
- (b) One (1) dryer/cooler with three (3) dryer decks and one (1) cooler deck; constructed in 1988 (cooler deck), 1990 (1st dryer deck), 2006 (2<sup>nd</sup> & 3<sup>rd</sup> dryer decks), with a maximum total capacity of 3350 bushels per hour, controlled by four (4) integral cyclones identified as # 6, 7, 8, and 9, and exhausted at stack points # S-11, S-12, S-21, and S-25.
- Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.
- (c) One (1) flake desolventizer system, constructed in 1989, with a maximum capacity of 100.5 tons per hour and controlled by a mineral oil absorber system.
- Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.
- (c) One (1) flake desolventizer system cooler collector, constructed in 1989, with a maximum capacity of 100.5 tons per hour equipped with a fabric filter media separator (baghouse #6) and exhausted at stack point S-22.
- Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.
- (d) One (1) Iso-hexane conversion system (involving a rotocell condenser, a refrigerant type cooler with condenser and an additional cooling tower cell and pump), constructed in 2002, and controlled by the mineral oil system and exhausted at stack point S-15.
- Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.
- (e) One (1) mineral oil absorber system, constructed in 1982, with a maximum capacity of 150 pounds of hexane per hour and exhausted at stack point S-15.
- Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.
- (f) One (1) solvent/water separator, constructed in 2002, with a maximum capacity of 600 gallons per minute and controlled by the mineral oil system and exhausted at stack point S-15.
- Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.
- (g) Two (2) hexane tanks #809 A & B, constructed in 2002 and 2009, with a capacity of 18,800 and 18,800 gallons respectively, vented to the process for control except under emergency conditions when they are vented through the flame arrester.
- Under NESHAP, Subpart GGGG, this unit is considered to be an affected facility.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

#### E.3.1 General Provisions Relating to NESHAP GGGG [326 IAC 20-1] [40 CFR Part 63, Subpart A]

- (a) Pursuant to 40 CFR 63.4480, the Permittee shall comply with the provisions of 40 CFR Part 63, Subpart A – General Provisions, which are incorporated by reference as 326 IAC 20-1-1, as specified in 40 CFR Part 63, Subpart GGGG in accordance with schedule in

40 CFR 63 Subpart GGGG.

- (b) Pursuant to 40 CFR 63.10, the Permittee shall submit all required notifications and reports to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V  
Air and Radiation Division, Air Enforcement Branch - Indiana (AE-17J)  
77 West Jackson Boulevard  
Chicago, Illinois 60604-3590

E.3.2 Solvent Extraction for Vegetable Oil Production NESHAP [326 IAC 20-60][40 CFR Part 63, Subpart GGGG]

---

The Permittee which engages in production of vegetable oil shall comply with the following provisions of 40 CFR 63, Subpart GGGG (included as Attachment C of this permit), as specified as follows:

- (1) 40 CFR 63.2830
- (2) 40 CFR 63.2831
- (3) 40 CFR 63.2832(a)
- (4) 40 CFR 63.2833
- (5) 40 CFR 63.2834(a)
- (6) 40 CFR 63.2840 all except (e)
- (7) 40 CFR 63.2850(a)(b)(d)(e)(1)(i)(iii)(2)
- (8) 40 CFR 63.2851
- (9) 40 CFR 63.2852
- (10) 40 CFR 63.2853
- (11) 40 CFR 63.2854
- (12) 40 CFR 63.2855
- (13) 40 CFR 63.2860
- (14) 40 CFR 63.2861
- (15) 40 CFR 63.2862
- (16) 40 CFR 63.2863
- (17) 40 CFR 63.2870
- (18) 40 CFR 63.2871
- (19) 40 CFR 63.2872

**SECTION E.4 National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (40 CFR 63.6580, Subpart ZZZZ) which is incorporated by reference as 326 IAC 12-1.**

**Facility Description [326 IAC 2-7-5(15)]**

- (A) One (1) sixty-six (66) horsepower, non-emergency diesel powered air compressor, constructed in 2002, using a maximum of 8.8 gallons of #2 diesel fuel per hour.

This diesel powered air compressor is an affected facility under 40 CFR 63, Subpart ZZZZ.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

**E.4.1 General Provisions Relating to NESHAP ZZZZ [326 IAC 12-1] [40 CFR 60, Subpart A]**

- (a) The provisions of 40 CFR 60, Subpart A – General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the facilities described in this Section E.4, except when otherwise specified in 40 CFR 63, Subpart ZZZZ.

- (b) Pursuant to 40 CFR 60.19, the Permittee shall submit all required notifications and reports to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Ave.  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

**E.4.2 National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines [40 CFR Part 63, Subpart ZZZZ] [326 IAC 20]**

Pursuant to 40 CFR Part 60, Subpart IIII, the Permittee shall comply with the provisions of Standards of Performance for National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines, which are incorporated by reference as 326 IAC 20, for the emergency generator as follows. The full text of Subpart ZZZZ may be found in Attachment A to this permit.

The emission unit is subject to the following portions of Subpart ZZZZ:

- (1) 63.6602, Table 2c - No. 2
- (2) 63.6605
- (3) 63.6625 (e), (h), (i)
- (4) 63.6640
- (5) 63.6655 (a), (d), (e)

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH  
PART 70 OPERATING PERMIT  
CERTIFICATION**

Source Name: Cargill, Inc. - Soybean Processing Division  
Source Address: 1502 Wabash Avenue, Lafayette, Indiana 47905  
Part 70 Permit No.: T157-25200-00038

**This certification shall be included when submitting monitoring, testing reports/results or other documents as required by this permit.**

Please check what document is being certified:

- Annual Compliance Certification Letter
- Test Result (specify)
- Report (specify)
- Notification (specify)
- Affidavit (specify)
- Other (specify)

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Signature:

Printed Name:

Title/Position:

Phone:

Date:

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251  
Phone: (317) 233-0178  
Fax: (317) 233-6865**

**PART 70 OPERATING PERMIT  
EMERGENCY OCCURRENCE REPORT**

Source Name: Cargill, Inc. - Soybean Processing Division  
Source Address: 1502 Wabash Avenue, Lafayette, Indiana 47905  
Part 70 Permit No.: T157-25200-00038

**This form consists of 2 pages**

**Page 1 of 2**

- This is an emergency as defined in 326 IAC 2-7-1(12)
- The Permittee must notify the Office of Air Quality (OAQ), within four (4) business hours (1-800-451-6027 or 317-233-0178, ask for Compliance Section); and
  - The Permittee must submit notice in writing or by facsimile within two (2) working days (Facsimile Number: 317-233-6865), and follow the other requirements of 326 IAC 2-7-16.

If any of the following are not applicable, mark N/A

Facility/Equipment/Operation:
Control Equipment:
Permit Condition or Operation Limitation in Permit:
Description of the Emergency:
Describe the cause of the Emergency:



If any of the following are not applicable, mark N/A

Page 2 of 2

Date/Time Emergency started:
Date/Time Emergency was corrected:
Was the facility being properly operated at the time of the emergency?    Y    N
Type of Pollutants Emitted: TSP, PM-10, SO <sub>2</sub> , VOC, NO <sub>x</sub> , CO, Pb, other:
Estimated amount of pollutant(s) emitted during emergency:
Describe the steps taken to mitigate the problem:
Describe the corrective actions/response steps taken:
Describe the measures taken to minimize emissions:
If applicable, describe the reasons why continued operation of the facilities are necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw materials of substantial economic value:

Form Completed by: \_\_\_\_\_

Title / Position: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH**

**PART 70 OPERATING PERMIT  
SEMI-ANNUAL NATURAL GAS FIRED BOILER CERTIFICATION**

Source Name: Cargill, Inc. - Soybean Processing Division  
Source Address: 1502 Wabash Avenue, Lafayette, Indiana 47905  
Part 70 Permit No.: T157-25200-00038

Natural Gas Only  
 Alternate Fuel burned  
From: \_\_\_\_\_ To: \_\_\_\_\_

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Signature:

Printed Name:

Title/Position:

Phone:

Date:

## INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT OFFICE OF AIR QUALITY COMPLIANCE AND ENFORCEMENT BRANCH

### Part 70 Semi Annual Report (Submit Report Quarterly)

Source Name: Cargill, Inc. - Soybean Processing Division  
 Source Address: 1502 Wabash Avenue, Lafayette, Indiana 47905  
 Part 70 Permit No.: T157-25200-00038  
 Facility: Boiler No. 2 (Capacity 75 million Btu per hour)  
 Parameter: SO<sub>2</sub>  
 Limit: 0.5 lbs/MMBtu sulfur dioxide for distillate and residual fuel oil rolled on 30 days average.

Month: \_\_\_\_\_ Year: \_\_\_\_\_

Day	Type Fuel Combusted	Sulfur dioxide (this Day)	Sulfur dioxide (for the last 29 days)	Sulfur dioxide Avg. (for the last 30 days)	Day	Type Fuel Combusted	Sulfur dioxide (this Day)	Sulfur dioxide (for the last 29 days)	Sulfur dioxide Avg. (for the last 30 days)
1					17				
2					18				
3					19				
4					20				
5					21				
6					22				
7					23				
8					24				
9					25				
10					26				
11					27				
12					28				
13					29				
14					30				
15					31				
16					no. of deviations				

- No deviation occurred in this month.
- Deviation/s occurred in this month.  
 Deviation has been reported on:

Comments for Noncompliance: \_\_\_\_\_  
Corrective Action Taken: \_\_\_\_\_

Method of Determining Sulfur Content: \_\_\_\_\_

Submitted by: \_\_\_\_\_  
Title / Position: \_\_\_\_\_  
Signature: \_\_\_\_\_  
Date: \_\_\_\_\_  
Phone: \_\_\_\_\_

## INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT OFFICE OF AIR QUALITY COMPLIANCE AND ENFORCEMENT BRANCH

### Part 70 Quarterly Report

Source Name: Cargill, Inc. - Soybean Processing Division  
 Source Address: 1502 Wabash Avenue, Lafayette, Indiana 47905  
 Part 70 Permit No.: T157-25200-00038  
 Facility: Entire Plant / Dump Bed Truck Unloading / Reject Flakes Loadout  
 Pollutant: PM and PM<sub>10</sub>  
 Limits: Soybeans Processed by Plant: 821,250 tons per 12 month period.  
 Soybeans Received by Trucks: 82,125 tons per 12 month period.  
 Reject Flakes Loadout: 2,400 tons per 12 month period.

MONTHS \_\_\_\_\_ TO \_\_\_\_\_ YEAR: \_\_\_\_\_

Soybeans Processed By Plant	This Month	Previous 11 Months	12 Month Total
Conventional: Month 1			
Conventional: Month 2			
Conventional: Month 3			
Specialty: Month 1			
Specialty: Month 2			
Specialty: Month 3			
Both Types: Month 1			
Both Types: Month 2			
Both Types: Month 3			

Soybeans Received By Trucks	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

Reject Flakes Loadout	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

Submitted by: \_\_\_\_\_

Title/Position: \_\_\_\_\_

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH**

**Part 70 Quarterly Report**

Source Name: Cargill, Inc. - Soybean Processing Division  
Source Address: 1502 Wabash Avenue, Lafayette, Indiana 47905  
Part 70 Permit No.: T157-25200-00038  
Facility: Boiler no. 2 (75 MMBTU/HR)  
Pollutant: SO<sub>2</sub>  
Limit: 1042 Kgal as no. 2 fuel oil per twelve (12) consecutive months

YEAR:

Month	Column 1	Column 2	Column 1 + Column 2
	Total fuel usage as No. 2 fuel oil (Kgal) This Month	Total fuel usage as No. 2 fuel oil (Kgal) Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

Conversion: 1.00 Kgal no. 4 fuel oil = 1.00 Kgal no. 2 fuel oil  
1.00 Kgal no. 5 fuel oil = 1.16 Kgal no. 2 fuel oil  
1.00 Kgal no. 6 fuel oil = 1.16 Kgal no. 2 fuel oil

Submitted by: \_\_\_\_\_  
Title/Position: \_\_\_\_\_  
Signature: \_\_\_\_\_  
Date: \_\_\_\_\_  
Phone: \_\_\_\_\_

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH**

**Part 70 Quarterly Report**

Source Name: Cargill, Inc. - Soybean Processing Division  
Source Address: 1502 Wabash Avenue, Lafayette, Indiana 47905  
Part 70 Permit No.: T157-25200-00038  
Facility: Boiler #1 (60 MMBTU/HR)  
Pollutant: SO<sub>2</sub>  
Limit: 102 Kgal as no. 2 fuel oil per twelve (12) consecutive month period.

YEAR:

Month	Column 1	Column 2	Column 1 + Column 2
	Fuel Usage as No. 2 Fuel Oil (Kgal) This Month	Fuel Usage as No. 2 Fuel Oil (Kgal) Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

Conversion: 1.00 Kgal no. 4 fuel oil = 1.00 Kgal no. 2 fuel oil  
1.00 Kgal no. 5 fuel oil = 1.16 Kgal no. 2 fuel oil  
1.00 Kgal no. 6 fuel oil = 1.16 Kgal no. 2 fuel oil

Submitted by: \_\_\_\_\_  
Title/Position: \_\_\_\_\_  
Signature: \_\_\_\_\_  
Date: \_\_\_\_\_  
Phone: \_\_\_\_\_

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH**

**Part 70 Quarterly Report**

Source Name: Cargill, Inc. - Soybean Processing Division  
Source Address: 1502 Wabash Avenue, Lafayette, Indiana 47905  
Part 70 Permit No.: T157-25200-00038  
Facility: Boiler #2 (75 MMBTU/HR)  
Pollutant: NOx  
Limits: 657 MMCF per twelve (12) consecutive month period. (46 tons of NOx per year.)  
Boiler #1 and Boiler #2 must total less than 794 MMCF per twelve (12) consecutive month period. (39.7 tons of NOx per year.)

YEAR:

Month	Column 1	Column 2	Column 1 + Column 2
	Natural Gas Usage (MMCF) This Month	Natural Gas Usage (MMCF) Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

Conversion:

1 Kgal of no. 2 fuel oil = 0.143 MMCF of natural gas  
1 Kgal of no. 4 fuel oil = 0.143 MMCF of natural gas  
1 Kgal of no. 5 fuel oil = 0.393 MMCF of natural gas  
1 Kgal of no. 6 fuel oil = 0.393 MMCF of natural gas  
1 Kgal of vegetable oil = 0.209 MMCF of natural gas  
1 Kgal of tallow = 0.247 MMCF of natural gas  
1 Kgal of grease = 0.093 MMCF of natural gas

Submitted by: \_\_\_\_\_  
Title/Position: \_\_\_\_\_  
Signature: \_\_\_\_\_  
Date: \_\_\_\_\_  
Phone: \_\_\_\_\_



**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
 OFFICE OF AIR QUALITY  
 COMPLIANCE AND ENFORCEMENT BRANCH**

**Part 70 Quarterly Report**

Source Name: Cargill, Inc. - Soybean Processing Division  
 Source Address: 1502 Wabash Avenue, Lafayette, Indiana 47905  
 Part 70 Permit No.: T157-25200-00038  
 Facility: Boiler #1 (60 MMBTU/HR)  
 Pollutant: NOx  
 Limits: 314 MMCF per twelve (12) consecutive month period. (22 tons of NOx per year.)  
 Boiler #1 and Boiler #2 must total less than 794 MMCF per twelve (12) consecutive month period. (39.7 tons of NOx per year.)

YEAR:

Month	Column 1	Column 2	Column 1 + Column 2
	Natural Gas Usage (MMCF) This Month	Natural Gas Usage (MMCF) Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

Conversion:

1 Kgal of no. 2 fuel oil = 0.143 MMCF of natural gas  
 1 Kgal of no. 4 fuel oil = 0.143 MMCF of natural gas  
 1 Kgal of no. 5 fuel oil = 0.393 MMCF of natural gas  
 1 Kgal of no. 6 fuel oil = 0.393 MMCF of natural gas  
 1 Kgal of vegetable oil = 0.209 MMCF of natural gas  
 1 Kgal of tallow = 0.247 MMCF of natural gas  
 1 Kgal of grease = 0.093 MMCF of natural gas

Submitted by: \_\_\_\_\_  
 Title/Position: \_\_\_\_\_  
 Signature: \_\_\_\_\_  
 Date: \_\_\_\_\_  
 Phone: \_\_\_\_\_

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
 OFFICE OF AIR QUALITY  
 COMPLIANCE AND ENFORCEMENT BRANCH**

**Part 70 Quarterly Report**

Source Name: Cargill, Inc. - Soybean Processing Division  
 Source Address: 1502 Wabash Avenue, Lafayette, Indiana 47905  
 Part 70 Permit No.: T157-25200-00038  
 Facility: Boiler #1 (60 MMBTU/HR) and Boiler #2 (75 MMBTU/HR)  
 Pollutant: PM and PM<sub>10</sub>  
 Limit: 794.13MMCF of natural gas per 12 consecutive month (7.60 lb of PM or PM<sub>10</sub> per MMCF of natural gas each)

YEAR:

Month	Column 1	Column 2	Column 1 + Column 2
	Total Natural Gas usage (MMCF) This Month	Total Natural Gas usage (MMCF) Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

Conversion:

1.00 Kgal no. 2 fuel oil = 0.434 MMCF natural gas  
 1.00 Kgal no. 4 fuel oil = 1.12 MMCF natural gas  
 1.00 Kgal no. 5 fuel oil =  $[(9.19(S)+4.72)/7.6]$  MMCF natural gas  
 1.00 Kgal no. 6 fuel oil = 1.513 MMCF natural gas

Submitted by: \_\_\_\_\_  
 Title/Position: \_\_\_\_\_  
 Signature: \_\_\_\_\_  
 Date: \_\_\_\_\_  
 Phone: \_\_\_\_\_

## INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT OFFICE OF AIR QUALITY COMPLIANCE AND ENFORCEMENT BRANCH

### Part 70 Quarterly Report

Source Name: Cargill, Inc. - Soybean Processing Division  
 Source Address: 1502 Wabash Avenue, Lafayette, Indiana 47905  
 Part 70 Permit No.: T157-25200-00038  
 Facility: Whole Soybean Extraction Plant  
 Pollutant: VOC  
 Limit: 0.503 gal/ton soybean processed, according to either of the following equations:

$$\text{Compliance Ratio} = (\text{Actual VOC loss}) / (\text{Allowable VOC loss}) \quad (\text{Eq. 1})$$

$$\text{Compliance Ratio} = [f * \text{Actual Solvent Loss} / \{1.00[(\text{Soybean processed})_C * (\text{SLF}_C)] + \{(\text{Soybean processed})_S * (\text{SLF}_S)\}] \quad (\text{Eq. 2})$$

f = The weighted average volume fraction of VOC in solvent received during the previous twelve (12) operating months, dimensionless

1.00 = The average volume fraction of VOC in solvent in the baseline performance data, dimensionless

Actual Solvent Loss = Gallons of actual solvent loss during previous twelve (12) operating month

SLF<sub>S</sub> = 1.5 gals/ton (for new source, specialty soybean process)

SLF<sub>C</sub> = 0.2 gals/ton (for existing source, conventional soybean process)

YEAR:

Month	Column 1	Column 2	Column 1 + Column 2
	This Month	Previous 11 Months	12 Month Total
Month 1			
Month 2			
Month 3			

Submitted by: \_\_\_\_\_

Title/Position: \_\_\_\_\_

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH  
PART 70 OPERATING PERMIT  
QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT**

Source Name: Cargill, Inc. - Soybean Processing Division  
Source Address: 1502 Wabash Avenue, Lafayette, Indiana 47905  
Part 70 Permit No.: T157-25200-00038

**Months: \_\_\_\_\_ to \_\_\_\_\_ Year: \_\_\_\_\_**

Page 1 of 2

<p>This report shall be submitted quarterly based on a calendar year. Proper notice submittal under Section B - Emergency Provisions satisfies the reporting requirements of paragraph (a) of Section C - General Reporting. Any deviation from the requirements of this permit, the date(s) of each deviation, the probable cause of the deviation, and the response steps taken must be reported. A deviation required to be reported pursuant to an applicable requirement that exists independent of the permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. Additional pages may be attached if necessary. If no deviations occurred, please specify in the box marked "No deviations occurred this reporting period".</p>	
<p><input type="checkbox"/> NO DEVIATIONS OCCURRED THIS REPORTING PERIOD.</p>	
<p><input type="checkbox"/> THE FOLLOWING DEVIATIONS OCCURRED THIS REPORTING PERIOD</p>	
<p><b>Permit Requirement</b> (specify permit condition #)</p>	
<p><b>Date of Deviation:</b></p>	<p><b>Duration of Deviation:</b></p>
<p><b>Number of Deviations:</b></p>	
<p><b>Probable Cause of Deviation:</b></p>	
<p><b>Response Steps Taken:</b></p>	
<p><b>Permit Requirement</b> (specify permit condition #)</p>	
<p><b>Date of Deviation:</b></p>	<p><b>Duration of Deviation:</b></p>
<p><b>Number of Deviations:</b></p>	
<p><b>Probable Cause of Deviation:</b></p>	
<p><b>Response Steps Taken:</b></p>	

<b>Permit Requirement (specify permit condition #)</b>	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	
<b>Permit Requirement (specify permit condition #)</b>	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	
<b>Permit Requirement (specify permit condition #)</b>	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	

Form Completed by: \_\_\_\_\_

Title / Position: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

**Attachment A**  
**to Part 70 Operating Permit Renewal No. T157-25200-00038**

Cargill, Inc. - Soybean Processing Division  
1502 Wabash Avenue, Lafayette, IN 47905

**Subpart DD—Standards of Performance for Grain Elevators**

**Source:** 43 FR 34347, Aug. 3, 1978, unless otherwise noted.

**§ 60.300 Applicability and designation of affected facility.**

(a) The provisions of this subpart apply to each affected facility at any grain terminal elevator or any grain storage elevator, except as provided under §60.304(b). The affected facilities are each truck unloading station, truck loading station, barge and ship unloading station, barge and ship loading station, railcar loading station, railcar unloading station, grain dryer, and all grain handling operations.

(b) Any facility under paragraph (a) of this section which commences construction, modification, or reconstruction after August 3, 1978, is subject to the requirements of this part.

[43 FR 34347, Aug. 3, 1978, as amended at 52 FR 42434, Nov. 5, 1988]

**§ 60.301 Definitions.**

As used in this subpart, all terms not defined herein shall have the meaning given them in the Act and in subpart A of this part.

(a) *Grain* means corn, wheat, sorghum, rice, rye, oats, barley, and soybeans.

(b) *Grain elevator* means any plant or installation at which grain is unloaded, handled, cleaned, dried, stored, or loaded.

(c) *Grain terminal elevator* means any grain elevator which has a permanent storage capacity of more than 88,100 m<sup>3</sup> (ca. 2.5 million U.S. bushels), except those located at animal food manufacturers, pet food manufacturers, cereal manufacturers, breweries, and livestock feedlots.

(d) *Permanent storage capacity* means grain storage capacity which is inside a building, bin, or silo.

(e) *Railcar* means railroad hopper car or boxcar.

(f) *Grain storage elevator* means any grain elevator located at any wheat flour mill, wet corn mill, dry corn mill (human consumption), rice mill, or soybean oil extraction plant which has a permanent grain storage capacity of 35,200 m<sup>3</sup> (ca. 1 million bushels).

(g) *Process emission* means the particulate matter which is collected by a capture system.

(h) *Fugitive emission* means the particulate matter which is not collected by a capture system and is released directly into the atmosphere from an affected facility at a grain elevator.

(i) *Capture system* means the equipment such as sheds, hoods, ducts, fans, dampers, etc. used to collect particulate matter generated by an affected facility at a grain elevator.

(j) *Grain unloading station* means that portion of a grain elevator where the grain is transferred from a truck, railcar, barge, or ship to a receiving hopper.

(k) *Grain loading station* means that portion of a grain elevator where the grain is transferred from the elevator to a truck, railcar, barge, or ship.

(l) *Grain handling operations* include bucket elevators or legs (excluding legs used to unload barges or ships), scale hoppers and surge bins (garners), turn heads, scalpers, cleaners, trippers, and the headhouse and other such structures.

(m) *Column dryer* means any equipment used to reduce the moisture content of grain in which the grain flows from the top to the bottom in one or more continuous packed columns between two perforated metal sheets.

(n) *Rack dryer* means any equipment used to reduce the moisture content of grain in which the grain flows from the top to the bottom in a cascading flow around rows of baffles (racks).

(o) *Unloading leg* means a device which includes a bucket-type elevator which is used to remove grain from a barge or ship.

[43 FR 34347, Aug. 3, 1978, as amended at 65 FR 61759, Oct. 17, 2000]

**§ 60.302 Standard for particulate matter.**

(a) On and after the 60th day of achieving the maximum production rate at which the affected facility will be operated, but no later than 180 days after initial startup, no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere any gases which exhibit greater than 0 percent opacity from any:

- (1) Column dryer with column plate perforation exceeding 2.4 mm diameter (ca. 0.094 inch).
- (2) Rack dryer in which exhaust gases pass through a screen filter coarser than 50 mesh.

(b) On and after the date on which the performance test required to be conducted by §60.8 is completed, no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any affected facility except a grain dryer any process emission which:

- (1) Contains particulate matter in excess of 0.023 g/dscm (ca. 0.01 gr/dscf).
- (2) Exhibits greater than 0 percent opacity.

(c) On and after the 60th day of achieving the maximum production rate at which the affected facility will be operated, but no later than 180 days after initial startup, no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere any fugitive emission from:

- (1) Any individual truck unloading station, railcar unloading station, or railcar loading station, which exhibits greater than 5 percent opacity.
- (2) Any grain handling operation which exhibits greater than 0 percent opacity.
- (3) Any truck loading station which exhibits greater than 10 percent opacity.
- (4) Any barge or ship loading station which exhibits greater than 20 percent opacity.

(d) The owner or operator of any barge or ship unloading station shall operate as follows:

(1) The unloading leg shall be enclosed from the top (including the receiving hopper) to the center line of the bottom pulley and ventilation to a control device shall be maintained on both sides of the leg and the grain receiving hopper.

(2) The total rate of air ventilated shall be at least 32.1 actual cubic meters per cubic meter of grain handling capacity (ca. 40 ft<sup>3</sup> /bu).

(3) Rather than meet the requirements of paragraphs (d)(1) and (2) of this section the owner or operator may use other methods of emission control if it is demonstrated to the Administrator's satisfaction that they would reduce emissions of particulate matter to the same level or less.

**§ 60.303 Test methods and procedures.**

(a) In conducting the performance tests required in §60.8, the owner or operator shall use as reference methods and procedures the test methods in appendix A of this part or other methods and procedures as specified in this section, except as provided in §60.8(b). Acceptable alternative methods and procedures are given in paragraph (c) of this section.

(b) The owner or operator shall determine compliance with the particulate matter standards in §60.302 as follows:

(1) Method 5 shall be used to determine the particulate matter concentration and the volumetric flow rate of the effluent gas. The sampling time and sample volume for each run shall be at least 60 minutes and 1.70 dscm (60 dscf). The probe and filter holder shall be operated without heaters.

(2) Method 2 shall be used to determine the ventilation volumetric flow rate.

(3) Method 9 and the procedures in §60.11 shall be used to determine opacity.

(c) The owner or operator may use the following as alternatives to the reference methods and procedures specified in this section:

(1) For Method 5, Method 17 may be used.

[54 FR 6674, Feb. 14, 1989]

**§ 60.304 Modifications.**

(a) The factor 6.5 shall be used in place of "annual asset guidelines repair allowance percentage," to determine whether a capital expenditure as defined by §60.2 has been made to an existing facility.

(b) The following physical changes or changes in the method of operation shall not by themselves be considered a modification of any existing facility:

(1) The addition of gravity loadout spouts to existing grain storage or grain transfer bins.

(2) The installation of automatic grain weighing scales.

(3) Replacement of motor and drive units driving existing grain handling equipment.

(4) The installation of permanent storage capacity with no increase in hourly grain handling capacity.



**Attachment B**  
**to Part 70 Operating Permit Renewal No. T157-25200-00038**

Cargill, Inc. - Soybean Processing Division  
1502 Wabash Avenue, Lafayette, IN 47905

**Subpart Dc—Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units**

**Source:** 72 FR 32759, June 13, 2007, unless otherwise noted.

**§ 60.40c Applicability and delegation of authority.**

(a) Except as provided in paragraphs (d), (e), (f), and (g) of this section, the affected facility to which this subpart applies is each steam generating unit for which construction, modification, or reconstruction is commenced after June 9, 1989 and that has a maximum design heat input capacity of 29 megawatts (MW) (100 million British thermal units per hour (MMBtu/hr)) or less, but greater than or equal to 2.9 MW (10 MMBtu/hr).

(b) In delegating implementation and enforcement authority to a State under section 111(c) of the Clean Air Act, §60.48c(a)(4) shall be retained by the Administrator and not transferred to a State.

(c) Steam generating units that meet the applicability requirements in paragraph (a) of this section are not subject to the sulfur dioxide (SO<sub>2</sub>) or particulate matter (PM) emission limits, performance testing requirements, or monitoring requirements under this subpart (§§60.42c, 60.43c, 60.44c, 60.45c, 60.46c, or 60.47c) during periods of combustion research, as defined in §60.41c.

(d) Any temporary change to an existing steam generating unit for the purpose of conducting combustion research is not considered a modification under §60.14.

(e) Heat recovery steam generators that are associated with combined cycle gas turbines and meet the applicability requirements of subpart KKKK of this part are not subject to this subpart. This subpart will continue to apply to all other heat recovery steam generators that are capable of combusting more than or equal to 2.9 MW (10 MMBtu/hr) heat input of fossil fuel but less than or equal to 29 MW (100 MMBtu/hr) heat input of fossil fuel. If the heat recovery steam generator is subject to this subpart, only emissions resulting from combustion of fuels in the steam generating unit are subject to this subpart. (The gas turbine emissions are subject to subpart GG or KKKK, as applicable, of this part).

(f) Any facility covered by subpart AAAA of this part is not subject by this subpart.

(g) Any facility covered by an EPA approved State or Federal section 111(d)/129 plan implementing subpart BBBB of this part is not subject by this subpart.

[72 FR 32759, June 13, 2007, as amended at 74 FR 5090, Jan. 28, 2009]

**§ 60.41c Definitions.**

As used in this subpart, all terms not defined herein shall have the meaning given them in the Clean Air Act and in subpart A of this part.

*Annual capacity factor* means the ratio between the actual heat input to a steam generating unit from an individual fuel or combination of fuels during a period of 12 consecutive calendar months and the potential heat input to the steam generating unit from all fuels had the steam generating unit been operated for 8,760 hours during that 12-month period at the maximum design heat input capacity. In the case of steam generating units that are rented or leased, the actual heat input shall be determined based on the combined heat input from all operations of the affected facility during a period of 12 consecutive calendar months.

*Coal* means all solid fuels classified as anthracite, bituminous, subbituminous, or lignite by the American Society of Testing and Materials in ASTM D388 (incorporated by reference, see §60.17), coal refuse, and petroleum coke. Coal-derived synthetic fuels derived from coal for the purposes of creating useful heat, including but not limited to solvent refined coal, gasified coal not meeting the definition of natural gas, coal-oil mixtures, and coal-water mixtures, are also included in this definition for the purposes of this subpart.

*Coal refuse* means any by-product of coal mining or coal cleaning operations with an ash content greater than 50 percent (by weight) and a heating value less than 13,900 kilojoules per kilogram (kJ/kg) (6,000 Btu per pound (Btu/lb) on a dry basis.

*Cogeneration steam generating unit* means a steam generating unit that simultaneously produces both electrical (or mechanical) and thermal energy from the same primary energy source.

*Combined cycle system* means a system in which a separate source (such as a stationary gas turbine, internal combustion engine, or kiln) provides exhaust gas to a steam generating unit.

*Combustion research* means the experimental firing of any fuel or combination of fuels in a steam generating unit for the purpose of conducting research and development of more efficient combustion or more effective prevention or control of air pollutant emissions from combustion, provided that, during these periods of research and development, the heat generated is not used for any purpose other than preheating combustion air for use by that steam generating unit ( *i.e.* , the heat generated is released to the atmosphere without being used for space heating, process heating, driving pumps, preheating combustion air for other units, generating electricity, or any other purpose).

*Conventional technology* means wet flue gas desulfurization technology, dry flue gas desulfurization technology, atmospheric fluidized bed combustion technology, and oil hydrodesulfurization technology.

*Distillate oil* means fuel oil that complies with the specifications for fuel oil numbers 1 or 2, as defined by the American Society for Testing and Materials in ASTM D396 (incorporated by reference, see §60.17) or diesel fuel oil numbers 1 or 2, as defined by the American Society for Testing and Materials in ASTM D975 (incorporated by reference, see §60.17).

*Dry flue gas desulfurization technology* means a SO<sub>2</sub> control system that is located between the steam generating unit and the exhaust vent or stack, and that removes sulfur oxides from the combustion gases of the steam generating unit by contacting the combustion gases with an alkaline reagent and water, whether introduced separately or as a premixed slurry or solution and forming a dry powder material. This definition includes devices where the dry powder material is subsequently converted to another form. Alkaline reagents used in dry flue gas desulfurization systems include, but are not limited to, lime and sodium compounds.

*Duct burner* means a device that combusts fuel and that is placed in the exhaust duct from another source (such as a stationary gas turbine, internal combustion engine, kiln, etc.) to allow the firing of additional fuel to heat the exhaust gases before the exhaust gases enter a steam generating unit.

*Emerging technology* means any SO<sub>2</sub> control system that is not defined as a conventional technology under this section, and for which the owner or operator of the affected facility has received approval from the Administrator to operate as an emerging technology under §60.48c(a)(4).

*Federally enforceable* means all limitations and conditions that are enforceable by the Administrator, including the requirements of 40 CFR parts 60 and 61, requirements within any applicable State implementation plan, and any permit requirements established under 40 CFR 52.21 or under 40 CFR 51.18 and 51.24.

*Fluidized bed combustion technology* means a device wherein fuel is distributed onto a bed (or series of beds) of limestone aggregate (or other sorbent materials) for combustion; and these materials are forced upward in the device by the flow of combustion air and the gaseous products of combustion. Fluidized bed combustion technology includes, but is not limited to, bubbling bed units and circulating bed units.

*Fuel pretreatment* means a process that removes a portion of the sulfur in a fuel before combustion of the fuel in a steam generating unit.

*Heat input* means heat derived from combustion of fuel in a steam generating unit and does not include the heat derived from preheated combustion air, recirculated flue gases, or exhaust gases from other sources (such as stationary gas turbines, internal combustion engines, and kilns).

*Heat transfer medium* means any material that is used to transfer heat from one point to another point.

*Maximum design heat input capacity* means the ability of a steam generating unit to combust a stated maximum amount of fuel (or combination of fuels) on a steady state basis as determined by the physical design and characteristics of the steam generating unit.

*Natural gas* means:

(1) A naturally occurring mixture of hydrocarbon and nonhydrocarbon gases found in geologic formations beneath the earth's surface, of which the principal constituent is methane; or

(2) Liquefied petroleum (LP) gas, as defined by the American Society for Testing and Materials in ASTM D1835 (incorporated by reference, see §60.17); or

(3) A mixture of hydrocarbons that maintains a gaseous state at ISO conditions. Additionally, natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 34 and 43 megajoules (MJ) per dry standard cubic meter (910 and 1,150 Btu per dry standard cubic foot).

*Noncontinental area* means the State of Hawaii, the Virgin Islands, Guam, American Samoa, the Commonwealth of Puerto Rico, or the Northern Mariana Islands.

*Oil* means crude oil or petroleum, or a liquid fuel derived from crude oil or petroleum, including distillate oil and residual oil.

*Potential sulfur dioxide emission rate* means the theoretical SO<sub>2</sub> emissions (nanograms per joule (ng/J) or lb/MMBtu heat input) that would result from combusting fuel in an uncleaned state and without using emission control systems.

*Process heater* means a device that is primarily used to heat a material to initiate or promote a chemical reaction in which the material participates as a reactant or catalyst.

*Residual oil* means crude oil, fuel oil that does not comply with the specifications under the definition of distillate oil, and all fuel oil numbers 4, 5, and 6, as defined by the American Society for Testing and Materials in ASTM D396 (incorporated by reference, see §60.17).

*Steam generating unit* means a device that combusts any fuel and produces steam or heats water or heats any heat transfer medium. This term includes any duct burner that combusts fuel and is part of a combined cycle system. This term does not include process heaters as defined in this subpart.

*Steam generating unit operating day* means a 24-hour period between 12:00 midnight and the following midnight during which any fuel is combusted at any time in the steam generating unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period.

*Wet flue gas desulfurization technology* means an SO<sub>2</sub> control system that is located between the steam generating unit and the exhaust vent or stack, and that removes sulfur oxides from the combustion gases of the steam generating unit by contacting the combustion gases with an alkaline slurry or solution and forming a liquid material. This definition includes devices where the liquid material is subsequently converted to another form. Alkaline reagents used in wet flue gas desulfurization systems include, but are not limited to, lime, limestone, and sodium compounds.

*Wet scrubber system* means any emission control device that mixes an aqueous stream or slurry with the exhaust gases from a steam generating unit to control emissions of PM or SO<sub>2</sub>.

*Wood* means wood, wood residue, bark, or any derivative fuel or residue thereof, in any form, including but not limited to sawdust, sanderdust, wood chips, scraps, slabs, millings, shavings, and processed pellets made from wood or other forest residues.

[72 FR 32759, June 13, 2007, as amended at 74 FR 5090, Jan. 28, 2009]

**§ 60.42c Standard for sulfur dioxide (SO<sub>2</sub>).**

(a) Except as provided in paragraphs (b), (c), and (e) of this section, on and after the date on which the performance test is completed or required to be completed under §60.8, whichever date comes first, the owner or operator of an affected facility that combusts only coal shall neither: cause to be discharged into the atmosphere from the affected facility any gases that contain SO<sub>2</sub> in excess of 87 ng/J (0.20 lb/MMBtu) heat input or 10 percent (0.10) of the potential SO<sub>2</sub> emission rate (90 percent reduction), nor cause to be discharged into the atmosphere from the affected facility any gases that contain SO<sub>2</sub> in excess of 520 ng/J (1.2 lb/MMBtu) heat input. If coal is combusted with other fuels, the affected facility shall neither: cause to be discharged into the atmosphere from the affected facility any gases that contain SO<sub>2</sub> in excess of 87 ng/J (0.20 lb/MMBtu) heat input or 10 percent (0.10) of the potential SO<sub>2</sub> emission rate (90 percent reduction), nor cause to be discharged into the atmosphere from the affected facility any gases that contain SO<sub>2</sub> in excess of the emission limit is determined pursuant to paragraph (e)(2) of this section.

(b) Except as provided in paragraphs (c) and (e) of this section, on and after the date on which the performance test is completed or required to be completed under §60.8, whichever date comes first, the owner or operator of an affected facility that:

(1) Combusts only coal refuse alone in a fluidized bed combustion steam generating unit shall neither:

(i) Cause to be discharged into the atmosphere from that affected facility any gases that contain SO<sub>2</sub> in excess of 87 ng/J (0.20 lb/MMBtu) heat input or 20 percent (0.20) of the potential SO<sub>2</sub> emission rate (80 percent reduction); nor

(ii) Cause to be discharged into the atmosphere from that affected facility any gases that contain SO<sub>2</sub> in excess of SO<sub>2</sub> in excess of 520 ng/J (1.2 lb/MMBtu) heat input. If coal is fired with coal refuse, the affected facility subject to paragraph (a) of this section. If oil or any other fuel (except coal) is fired with coal refuse, the affected facility is subject to the 87 ng/J (0.20 lb/MMBtu) heat input SO<sub>2</sub> emissions limit or the 90 percent SO<sub>2</sub> reduction requirement specified in paragraph (a) of this section and the emission limit is determined pursuant to paragraph (e)(2) of this section.

(2) Combusts only coal and that uses an emerging technology for the control of SO<sub>2</sub> emissions shall neither:

(i) Cause to be discharged into the atmosphere from that affected facility any gases that contain SO<sub>2</sub> in excess of 50 percent (0.50) of the potential SO<sub>2</sub> emission rate (50 percent reduction); nor

(ii) Cause to be discharged into the atmosphere from that affected facility any gases that contain SO<sub>2</sub> in excess of 260 ng/J (0.60 lb/MMBtu) heat input. If coal is combusted with other fuels, the affected facility is subject to the 50 percent SO<sub>2</sub> reduction requirement specified in this paragraph and the emission limit determined pursuant to paragraph (e)(2) of this section.

(c) On and after the date on which the initial performance test is completed or required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that combusts coal, alone or in combination with any other fuel, and is listed in paragraphs (c)(1), (2), (3), or (4) of this section shall cause to be discharged into the atmosphere from that affected facility any gases that contain SO<sub>2</sub> in excess of the emission limit determined pursuant to paragraph (e)(2) of this section. Percent reduction requirements are not applicable to affected facilities under paragraphs (c)(1), (2), (3), or (4).

- (1) Affected facilities that have a heat input capacity of 22 MW (75 MMBtu/hr) or less.
- (2) Affected facilities that have an annual capacity for coal of 55 percent (0.55) or less and are subject to a federally enforceable requirement limiting operation of the affected facility to an annual capacity factor for coal of 55 percent (0.55) or less.
- (3) Affected facilities located in a noncontinental area.
- (4) Affected facilities that combust coal in a duct burner as part of a combined cycle system where 30 percent (0.30) or less of the heat entering the steam generating unit is from combustion of coal in the duct burner and 70 percent (0.70) or more of the heat entering the steam generating unit is from exhaust gases entering the duct burner.
- (d) On and after the date on which the initial performance test is completed or required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that combusts oil shall cause to be discharged into the atmosphere from that affected facility any gases that contain SO<sub>2</sub> in excess of 215 ng/J (0.50 lb/MMBtu) heat input; or, as an alternative, no owner or operator of an affected facility that combusts oil shall combust oil in the affected facility that contains greater than 0.5 weight percent sulfur. The percent reduction requirements are not applicable to affected facilities under this paragraph.
- (e) On and after the date on which the initial performance test is completed or required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that combusts coal, oil, or coal and oil with any other fuel shall cause to be discharged into the atmosphere from that affected facility any gases that contain SO<sub>2</sub> in excess of the following:
- (1) The percent of potential SO<sub>2</sub> emission rate or numerical SO<sub>2</sub> emission rate required under paragraph (a) or (b)(2) of this section, as applicable, for any affected facility that
- (i) Combusts coal in combination with any other fuel;
- (ii) Has a heat input capacity greater than 22 MW (75 MMBtu/hr); and
- (iii) Has an annual capacity factor for coal greater than 55 percent (0.55); and
- (2) The emission limit determined according to the following formula for any affected facility that combusts coal, oil, or coal and oil with any other fuel:

$$E_s = \frac{(K_a H_a + K_b H_b + K_c H_c)}{(H_a + H_b + H_c)}$$

Where:

E<sub>s</sub>= SO<sub>2</sub> emission limit, expressed in ng/J or lb/MMBtu heat input;

K<sub>a</sub>= 520 ng/J (1.2 lb/MMBtu);

K<sub>b</sub>= 260 ng/J (0.60 lb/MMBtu);

K<sub>c</sub>= 215 ng/J (0.50 lb/MMBtu);

H<sub>a</sub>= Heat input from the combustion of coal, except coal combusted in an affected facility subject to paragraph (b)(2) of this section, in Joules (J) [MMBtu];

$H_b$  = Heat input from the combustion of coal in an affected facility subject to paragraph (b)(2) of this section, in J (MMBtu); and

$H_c$  = Heat input from the combustion of oil, in J (MMBtu).

(f) Reduction in the potential SO<sub>2</sub> emission rate through fuel pretreatment is not credited toward the percent reduction requirement under paragraph (b)(2) of this section unless:

(1) Fuel pretreatment results in a 50 percent (0.50) or greater reduction in the potential SO<sub>2</sub> emission rate; and

(2) Emissions from the pretreated fuel (without either combustion or post-combustion SO<sub>2</sub> control) are equal to or less than the emission limits specified under paragraph (b)(2) of this section.

(g) Except as provided in paragraph (h) of this section, compliance with the percent reduction requirements, fuel oil sulfur limits, and emission limits of this section shall be determined on a 30-day rolling average basis.

(h) For affected facilities listed under paragraphs (h)(1), (2), or (3) of this section, compliance with the emission limits or fuel oil sulfur limits under this section may be determined based on a certification from the fuel supplier, as described under §60.48c(f), as applicable.

(1) Distillate oil-fired affected facilities with heat input capacities between 2.9 and 29 MW (10 and 100 MMBtu/hr).

(2) Residual oil-fired affected facilities with heat input capacities between 2.9 and 8.7 MW (10 and 30 MMBtu/hr).

(3) Coal-fired facilities with heat input capacities between 2.9 and 8.7 MW (10 and 30 MMBtu/hr).

(i) The SO<sub>2</sub> emission limits, fuel oil sulfur limits, and percent reduction requirements under this section apply at all times, including periods of startup, shutdown, and malfunction.

(j) For affected facilities located in noncontinental areas and affected facilities complying with the percent reduction standard, only the heat input supplied to the affected facility from the combustion of coal and oil is counted under this section. No credit is provided for the heat input to the affected facility from wood or other fuels or for heat derived from exhaust gases from other sources, such as stationary gas turbines, internal combustion engines, and kilns.

[72 FR 32759, June 13, 2007, as amended at 74 FR 5090, Jan. 28, 2009]

**§ 60.43c Standard for particulate matter (PM).**

(a) On and after the date on which the initial performance test is completed or required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that commenced construction, reconstruction, or modification on or before February 28, 2005, that combusts coal or combusts mixtures of coal with other fuels and has a heat input capacity of 8.7 MW (30 MMBtu/hr) or greater, shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of the following emission limits:

(1) 22 ng/J (0.051 lb/MMBtu) heat input if the affected facility combusts only coal, or combusts coal with other fuels and has an annual capacity factor for the other fuels of 10 percent (0.10) or less.

(2) 43 ng/J (0.10 lb/MMBtu) heat input if the affected facility combusts coal with other fuels, has an annual capacity factor for the other fuels greater than 10 percent (0.10), and is subject to a federally enforceable requirement limiting operation of the affected facility to an annual capacity factor greater than 10 percent (0.10) for fuels other than coal.

(b) On and after the date on which the initial performance test is completed or required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that commenced construction, reconstruction, or modification on or before February 28, 2005, that combusts wood or combusts mixtures of wood with other fuels (except coal) and has a heat input capacity of 8.7 MW (30 MMBtu/hr) or greater, shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of the following emissions limits:

(1) 43 ng/J (0.10 lb/MMBtu) heat input if the affected facility has an annual capacity factor for wood greater than 30 percent (0.30); or

(2) 130 ng/J (0.30 lb/MMBtu) heat input if the affected facility has an annual capacity factor for wood of 30 percent (0.30) or less and is subject to a federally enforceable requirement limiting operation of the affected facility to an annual capacity factor for wood of 30 percent (0.30) or less.

(c) On and after the date on which the initial performance test is completed or required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that can combust coal, wood, or oil and has a heat input capacity of 8.7 MW (30 MMBtu/hr) or greater shall cause to be discharged into the atmosphere from that affected facility any gases that exhibit greater than 20 percent opacity (6-minute average), except for one 6-minute period per hour of not more than 27 percent opacity. Owners and operators of an affected facility that elect to install, calibrate, maintain, and operate a continuous emissions monitoring system (CEMS) for measuring PM emissions according to the requirements of this subpart and are subject to a federally enforceable PM limit of 0.030 lb/MMBtu or less are exempt from the opacity standard specified in this paragraph.

(d) The PM and opacity standards under this section apply at all times, except during periods of startup, shutdown, or malfunction.

(e)(1) On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that commences construction, reconstruction, or modification after February 28, 2005, and that combusts coal, oil, wood, a mixture of these fuels, or a mixture of these fuels with any other fuels and has a heat input capacity of 8.7 MW (30 MMBtu/hr) or greater shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of 13 ng/J (0.030 lb/MMBtu) heat input, except as provided in paragraphs (e)(2), (e)(3), and (e)(4) of this section.

(2) As an alternative to meeting the requirements of paragraph (e)(1) of this section, the owner or operator of an affected facility for which modification commenced after February 28, 2005, may elect to meet the requirements of this paragraph. On and after the date on which the initial performance test is completed or required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that commences modification after February 28, 2005 shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of both:

(i) 22 ng/J (0.051 lb/MMBtu) heat input derived from the combustion of coal, oil, wood, a mixture of these fuels, or a mixture of these fuels with any other fuels; and

(ii) 0.2 percent of the combustion concentration (99.8 percent reduction) when combusting coal, oil, wood, a mixture of these fuels, or a mixture of these fuels with any other fuels.

(3) On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that commences modification after February 28, 2005, and that combusts over 30 percent wood (by heat input) on an annual basis and has a heat input capacity of 8.7 MW (30 MMBtu/hr) or greater shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of 43 ng/J (0.10 lb/MMBtu) heat input.

(4) On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, an owner or operator of an affected facility that commences construction, reconstruction, or modification after February 28, 2005, and that combusts only oil that

contains no more than 0.50 weight percent sulfur or a mixture of 0.50 weight percent sulfur oil with other fuels not subject to a PM standard under §60.43c and not using a post-combustion technology (except a wet scrubber) to reduce PM or SO<sub>2</sub> emissions is not subject to the PM limit in this section.

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009]

**§ 60.44c Compliance and performance test methods and procedures for sulfur dioxide.**

(a) Except as provided in paragraphs (g) and (h) of this section and §60.8(b), performance tests required under §60.8 shall be conducted following the procedures specified in paragraphs (b), (c), (d), (e), and (f) of this section, as applicable. Section 60.8(f) does not apply to this section. The 30-day notice required in §60.8(d) applies only to the initial performance test unless otherwise specified by the Administrator.

(b) The initial performance test required under §60.8 shall be conducted over 30 consecutive operating days of the steam generating unit. Compliance with the percent reduction requirements and SO<sub>2</sub> emission limits under §60.42c shall be determined using a 30-day average. The first operating day included in the initial performance test shall be scheduled within 30 days after achieving the maximum production rate at which the affect facility will be operated, but not later than 180 days after the initial startup of the facility. The steam generating unit load during the 30-day period does not have to be the maximum design heat input capacity, but must be representative of future operating conditions.

(c) After the initial performance test required under paragraph (b) of this section and §60.8, compliance with the percent reduction requirements and SO<sub>2</sub> emission limits under §60.42c is based on the average percent reduction and the average SO<sub>2</sub> emission rates for 30 consecutive steam generating unit operating days. A separate performance test is completed at the end of each steam generating unit operating day, and a new 30-day average percent reduction and SO<sub>2</sub> emission rate are calculated to show compliance with the standard.

(d) If only coal, only oil, or a mixture of coal and oil is combusted in an affected facility, the procedures in Method 19 of appendix A of this part are used to determine the hourly SO<sub>2</sub> emission rate (E<sub>ho</sub>) and the 30-day average SO<sub>2</sub> emission rate (E<sub>ao</sub>). The hourly averages used to compute the 30-day averages are obtained from the CEMS. Method 19 of appendix A of this part shall be used to calculate E<sub>ao</sub> when using daily fuel sampling or Method 6B of appendix A of this part.

(e) If coal, oil, or coal and oil are combusted with other fuels:

(1) An adjusted E<sub>ho</sub> (E<sub>ho0</sub>) is used in Equation 19–19 of Method 19 of appendix A of this part to compute the adjusted E<sub>ao</sub> (E<sub>ao0</sub>). The E<sub>ho0</sub> is computed using the following formula:

$$E_{ho0} = \frac{E_{ho} - E_w(1 - X_k)}{X_k}$$

Where:

E<sub>ho0</sub> = Adjusted E<sub>ho</sub>, ng/J (lb/MMBtu);

E<sub>ho</sub> = Hourly SO<sub>2</sub> emission rate, ng/J (lb/MMBtu);

E<sub>w</sub> = SO<sub>2</sub> concentration in fuels other than coal and oil combusted in the affected facility, as determined by fuel sampling and analysis procedures in Method 9 of appendix A of this part, ng/J (lb/MMBtu). The value E<sub>w</sub> for each fuel lot is used for each hourly average during the time that the lot is being combusted. The owner or operator does not have to measure E<sub>w</sub> if the owner or operator elects to assume E<sub>w</sub> = 0.

X<sub>k</sub> = Fraction of the total heat input from fuel combustion derived from coal and oil, as determined by applicable procedures in Method 19 of appendix A of this part.



(2) The owner or operator of an affected facility that qualifies under the provisions of §60.42c(c) or (d) (where percent reduction is not required) does not have to measure the parameters  $E_w$  or  $X_k$  if the owner or operator of the affected facility elects to measure emission rates of the coal or oil using the fuel sampling and analysis procedures under Method 19 of appendix A of this part.

(f) Affected facilities subject to the percent reduction requirements under §60.42c(a) or (b) shall determine compliance with the  $SO_2$  emission limits under §60.42c pursuant to paragraphs (d) or (e) of this section, and shall determine compliance with the percent reduction requirements using the following procedures:

(1) If only coal is combusted, the percent of potential  $SO_2$  emission rate is computed using the following formula:

$$\%P_s = 100 \left( 1 - \frac{\%R_g}{100} \right) \left( 1 - \frac{\%R_f}{100} \right)$$

Where:

$\%P_s$  = Potential  $SO_2$  emission rate, in percent;

$\%R_g$  =  $SO_2$  removal efficiency of the control device as determined by Method 19 of appendix A of this part, in percent; and

$\%R_f$  =  $SO_2$  removal efficiency of fuel pretreatment as determined by Method 19 of appendix A of this part, in percent.

(2) If coal, oil, or coal and oil are combusted with other fuels, the same procedures required in paragraph (f)(1) of this section are used, except as provided for in the following:

(i) To compute the  $\%P_s$ , an adjusted  $\%R_g$  ( $\%R_{gO}$ ) is computed from  $E_{aoO}$  from paragraph (e)(1) of this section and an adjusted average  $SO_2$  inlet rate ( $E_{aiO}$ ) using the following formula:

$$\%R_{gO} = 100 \left( 1 - \frac{E_{aoO}}{E_{aiO}} \right)$$

Where:

$\%R_{gO}$  = Adjusted  $\%R_g$ , in percent;

$E_{aoO}$  = Adjusted  $E_{ao}$ , ng/J (lb/MMBtu); and

$E_{aiO}$  = Adjusted average  $SO_2$  inlet rate, ng/J (lb/MMBtu).

(ii) To compute  $E_{aiO}$ , an adjusted hourly  $SO_2$  inlet rate ( $E_{hiO}$ ) is used. The  $E_{hiO}$  is computed using the following formula:

$$E_{hiO} = \frac{E_{hi} - E_w(1 - X_1)}{X_1}$$

Where:

$E_{hiO}$  = Adjusted  $E_{hi}$ , ng/J (lb/MMBtu);

$E_{hi}$  = Hourly SO<sub>2</sub> inlet rate, ng/J (lb/MMBtu);

$E_w$  = SO<sub>2</sub> concentration in fuels other than coal and oil combusted in the affected facility, as determined by fuel sampling and analysis procedures in Method 19 of appendix A of this part, ng/J (lb/MMBtu). The value  $E_w$  for each fuel lot is used for each hourly average during the time that the lot is being combusted. The owner or operator does not have to measure  $E_w$  if the owner or operator elects to assume  $E_w = 0$ ; and

$X_k$  = Fraction of the total heat input from fuel combustion derived from coal and oil, as determined by applicable procedures in Method 19 of appendix A of this part.

(g) For oil-fired affected facilities where the owner or operator seeks to demonstrate compliance with the fuel oil sulfur limits under §60.42c based on shipment fuel sampling, the initial performance test shall consist of sampling and analyzing the oil in the initial tank of oil to be fired in the steam generating unit to demonstrate that the oil contains 0.5 weight percent sulfur or less. Thereafter, the owner or operator of the affected facility shall sample the oil in the fuel tank after each new shipment of oil is received, as described under §60.46c(d)(2).

(h) For affected facilities subject to §60.42c(h)(1), (2), or (3) where the owner or operator seeks to demonstrate compliance with the SO<sub>2</sub> standards based on fuel supplier certification, the performance test shall consist of the certification from the fuel supplier, as described in §60.48c(f), as applicable.

(i) The owner or operator of an affected facility seeking to demonstrate compliance with the SO<sub>2</sub> standards under §60.42c(c)(2) shall demonstrate the maximum design heat input capacity of the steam generating unit by operating the steam generating unit at this capacity for 24 hours. This demonstration shall be made during the initial performance test, and a subsequent demonstration may be requested at any other time. If the demonstrated 24-hour average firing rate for the affected facility is less than the maximum design heat input capacity stated by the manufacturer of the affected facility, the demonstrated 24-hour average firing rate shall be used to determine the annual capacity factor for the affected facility; otherwise, the maximum design heat input capacity provided by the manufacturer shall be used.

(j) The owner or operator of an affected facility shall use all valid SO<sub>2</sub> emissions data in calculating %P<sub>s</sub> and  $E_{ho}$  under paragraphs (d), (e), or (f) of this section, as applicable, whether or not the minimum emissions data requirements under §60.46c(f) are achieved. All valid emissions data, including valid data collected during periods of startup, shutdown, and malfunction, shall be used in calculating %P<sub>s</sub> or  $E_{ho}$  pursuant to paragraphs (d), (e), or (f) of this section, as applicable.

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009]

**§ 60.45c Compliance and performance test methods and procedures for particulate matter.**

(a) The owner or operator of an affected facility subject to the PM and/or opacity standards under §60.43c shall conduct an initial performance test as required under §60.8, and shall conduct subsequent performance tests as requested by the Administrator, to determine compliance with the standards using the following procedures and reference methods, except as specified in paragraph (c) of this section.

(1) Method 1 of appendix A of this part shall be used to select the sampling site and the number of traverse sampling points.

(2) Method 3A or 3B of appendix A–2 of this part shall be used for gas analysis when applying Method 5 or 5B of appendix A–3 of this part or 17 of appendix A–6 of this part.

(3) Method 5, 5B, or 17 of appendix A of this part shall be used to measure the concentration of PM as follows:

(i) Method 5 of appendix A of this part may be used only at affected facilities without wet scrubber systems.

(ii) Method 17 of appendix A of this part may be used at affected facilities with or without wet scrubber systems provided the stack gas temperature does not exceed a temperature of 160 °C (320 °F). The procedures of Sections 8.1 and 11.1 of Method 5B of appendix A of this part may be used in Method 17 of appendix A of this part only if Method 17 of appendix A of this part is used in conjunction with a wet scrubber system. Method 17 of appendix A of this part shall not be used in conjunction with a wet scrubber system if the effluent is saturated or laden with water droplets.

(iii) Method 5B of appendix A of this part may be used in conjunction with a wet scrubber system.

(4) The sampling time for each run shall be at least 120 minutes and the minimum sampling volume shall be 1.7 dry standard cubic meters (dscm) [60 dry standard cubic feet (dscf)] except that smaller sampling times or volumes may be approved by the Administrator when necessitated by process variables or other factors.

(5) For Method 5 or 5B of appendix A of this part, the temperature of the sample gas in the probe and filter holder shall be monitored and maintained at 160 ±14 °C (320±25 °F).

(6) For determination of PM emissions, an oxygen (O<sub>2</sub>) or carbon dioxide (CO<sub>2</sub>) measurement shall be obtained simultaneously with each run of Method 5, 5B, or 17 of appendix A of this part by traversing the duct at the same sampling location.

(7) For each run using Method 5, 5B, or 17 of appendix A of this part, the emission rates expressed in ng/J (lb/MMBtu) heat input shall be determined using:

(i) The O<sub>2</sub> or CO<sub>2</sub> measurements and PM measurements obtained under this section, (ii) The dry basis F factor, and

(iii) The dry basis emission rate calculation procedure contained in Method 19 of appendix A of this part.

(8) Method 9 of appendix A–4 of this part shall be used for determining the opacity of stack emissions.

(b) The owner or operator of an affected facility seeking to demonstrate compliance with the PM standards under §60.43c(b)(2) shall demonstrate the maximum design heat input capacity of the steam generating unit by operating the steam generating unit at this capacity for 24 hours. This demonstration shall be made during the initial performance test, and a subsequent demonstration may be requested at any other time. If the demonstrated 24-hour average firing rate for the affected facility is less than the maximum design heat input capacity stated by the manufacturer of the affected facility, the demonstrated 24-hour average firing rate shall be used to determine the annual capacity factor for the affected facility; otherwise, the maximum design heat input capacity provided by the manufacturer shall be used.

(c) In place of PM testing with Method 5 or 5B of appendix A–3 of this part or Method 17 of appendix A–6 of this part, an owner or operator may elect to install, calibrate, maintain, and operate a CEMS for monitoring PM emissions discharged to the atmosphere and record the output of the system. The owner or operator of an affected facility who elects to continuously monitor PM emissions instead of conducting performance testing using Method 5 or 5B of appendix A–3 of this part or Method 17 of appendix A–6 of this part shall install, calibrate, maintain, and operate a CEMS and shall comply with the requirements specified in paragraphs (c)(1) through (c)(14) of this section.

(1) Notify the Administrator 1 month before starting use of the system.

(2) Notify the Administrator 1 month before stopping use of the system.

(3) The monitor shall be installed, evaluated, and operated in accordance with §60.13 of subpart A of this part.

(4) The initial performance evaluation shall be completed no later than 180 days after the date of initial startup of the affected facility, as specified under §60.8 of subpart A of this part or within 180 days of

notification to the Administrator of use of CEMS if the owner or operator was previously determining compliance by Method 5, 5B, or 17 of appendix A of this part performance tests, whichever is later.

(5) The owner or operator of an affected facility shall conduct an initial performance test for PM emissions as required under §60.8 of subpart A of this part. Compliance with the PM emission limit shall be determined by using the CEMS specified in paragraph (d) of this section to measure PM and calculating a 24-hour block arithmetic average emission concentration using EPA Reference Method 19 of appendix A of this part, section 4.1.

(6) Compliance with the PM emission limit shall be determined based on the 24-hour daily (block) average of the hourly arithmetic average emission concentrations using CEMS outlet data.

(7) At a minimum, valid CEMS hourly averages shall be obtained as specified in paragraph (c)(7)(i) of this section for 75 percent of the total operating hours per 30-day rolling average.

(i) At least two data points per hour shall be used to calculate each 1-hour arithmetic average.

(ii) [Reserved]

(8) The 1-hour arithmetic averages required under paragraph (c)(7) of this section shall be expressed in ng/J or lb/MMBtu heat input and shall be used to calculate the boiler operating day daily arithmetic average emission concentrations. The 1-hour arithmetic averages shall be calculated using the data points required under §60.13(e)(2) of subpart A of this part.

(9) All valid CEMS data shall be used in calculating average emission concentrations even if the minimum CEMS data requirements of paragraph (c)(7) of this section are not met.

(10) The CEMS shall be operated according to Performance Specification 11 in appendix B of this part.

(11) During the correlation testing runs of the CEMS required by Performance Specification 11 in appendix B of this part, PM and O<sub>2</sub>(or CO<sub>2</sub>) data shall be collected concurrently (or within a 30- to 60-minute period) by both the continuous emission monitors and performance tests conducted using the following test methods.

(i) For PM, Method 5 or 5B of appendix A-3 of this part or Method 17 of appendix A-6 of this part shall be used; and

(ii) After July 1, 2010 or after Method 202 of appendix M of part 51 has been revised to minimize artifact measurement and notice of that change has been published in the Federal Register, whichever is later, for condensable PM emissions, Method 202 of appendix M of part 51 shall be used; and

(iii) For O<sub>2</sub> (or CO<sub>2</sub>), Method 3A or 3B of appendix A-2 of this part, as applicable shall be used.

(12) Quarterly accuracy determinations and daily calibration drift tests shall be performed in accordance with procedure 2 in appendix F of this part. Relative Response Audit's must be performed annually and Response Correlation Audits must be performed every 3 years.

(13) When PM emissions data are not obtained because of CEMS breakdowns, repairs, calibration checks, and zero and span adjustments, emissions data shall be obtained by using other monitoring systems as approved by the Administrator or EPA Reference Method 19 of appendix A of this part to provide, as necessary, valid emissions data for a minimum of 75 percent of total operating hours on a 30-day rolling average.

(14) After July 1, 2011, within 90 days after the date of completing each performance evaluation required by paragraph (c)(11) of this section, the owner or operator of the affected facility must either submit the test data to EPA by successfully entering the data electronically into EPA's WebFIRE data base available at

<http://cfpub.epa.gov/oarweb/index.cfm?action=fire.main> or mail a copy to: United States Environmental Protection Agency; Energy Strategies Group; 109 TW Alexander DR; Mail Code: D243-01; RTP, NC 27711.

(d) The owner or operator of an affected facility seeking to demonstrate compliance under §60.43c(e)(4) shall follow the applicable procedures under §60.48c(f). For residual oil-fired affected facilities, fuel supplier certifications are only allowed for facilities with heat input capacities between 2.9 and 8.7 MW (10 to 30 MMBtu/hr).

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009]

**§ 60.46c Emission monitoring for sulfur dioxide.**

(a) Except as provided in paragraphs (d) and (e) of this section, the owner or operator of an affected facility subject to the SO<sub>2</sub> emission limits under §60.42c shall install, calibrate, maintain, and operate a CEMS for measuring SO<sub>2</sub> concentrations and either O<sub>2</sub> or CO<sub>2</sub> concentrations at the outlet of the SO<sub>2</sub> control device (or the outlet of the steam generating unit if no SO<sub>2</sub> control device is used), and shall record the output of the system. The owner or operator of an affected facility subject to the percent reduction requirements under §60.42c shall measure SO<sub>2</sub> concentrations and either O<sub>2</sub> or CO<sub>2</sub> concentrations at both the inlet and outlet of the SO<sub>2</sub> control device.

(b) The 1-hour average SO<sub>2</sub> emission rates measured by a CEMS shall be expressed in ng/J or lb/MMBtu heat input and shall be used to calculate the average emission rates under §60.42c. Each 1-hour average SO<sub>2</sub> emission rate must be based on at least 30 minutes of operation, and shall be calculated using the data points required under §60.13(h)(2). Hourly SO<sub>2</sub> emission rates are not calculated if the affected facility is operated less than 30 minutes in a 1-hour period and are not counted toward determination of a steam generating unit operating day.

(c) The procedures under §60.13 shall be followed for installation, evaluation, and operation of the CEMS.

(1) All CEMS shall be operated in accordance with the applicable procedures under Performance Specifications 1, 2, and 3 of appendix B of this part.

(2) Quarterly accuracy determinations and daily calibration drift tests shall be performed in accordance with Procedure 1 of appendix F of this part.

(3) For affected facilities subject to the percent reduction requirements under §60.42c, the span value of the SO<sub>2</sub> CEMS at the inlet to the SO<sub>2</sub> control device shall be 125 percent of the maximum estimated hourly potential SO<sub>2</sub> emission rate of the fuel combusted, and the span value of the SO<sub>2</sub> CEMS at the outlet from the SO<sub>2</sub> control device shall be 50 percent of the maximum estimated hourly potential SO<sub>2</sub> emission rate of the fuel combusted.

(4) For affected facilities that are not subject to the percent reduction requirements of §60.42c, the span value of the SO<sub>2</sub> CEMS at the outlet from the SO<sub>2</sub> control device (or outlet of the steam generating unit if no SO<sub>2</sub> control device is used) shall be 125 percent of the maximum estimated hourly potential SO<sub>2</sub> emission rate of the fuel combusted.

(d) As an alternative to operating a CEMS at the inlet to the SO<sub>2</sub> control device (or outlet of the steam generating unit if no SO<sub>2</sub> control device is used) as required under paragraph (a) of this section, an owner or operator may elect to determine the average SO<sub>2</sub> emission rate by sampling the fuel prior to combustion. As an alternative to operating a CEMS at the outlet from the SO<sub>2</sub> control device (or outlet of the steam generating unit if no SO<sub>2</sub> control device is used) as required under paragraph (a) of this section, an owner or operator may elect to determine the average SO<sub>2</sub> emission rate by using Method 6B of appendix A of this part. Fuel sampling shall be conducted pursuant to either paragraph (d)(1) or (d)(2) of this section. Method 6B of appendix A of this part shall be conducted pursuant to paragraph (d)(3) of this section.

(1) For affected facilities combusting coal or oil, coal or oil samples shall be collected daily in an as-fired condition at the inlet to the steam generating unit and analyzed for sulfur content and heat content according

the Method 19 of appendix A of this part. Method 19 of appendix A of this part provides procedures for converting these measurements into the format to be used in calculating the average SO<sub>2</sub> input rate.

(2) As an alternative fuel sampling procedure for affected facilities combusting oil, oil samples may be collected from the fuel tank for each steam generating unit immediately after the fuel tank is filled and before any oil is combusted. The owner or operator of the affected facility shall analyze the oil sample to determine the sulfur content of the oil. If a partially empty fuel tank is refilled, a new sample and analysis of the fuel in the tank would be required upon filling. Results of the fuel analysis taken after each new shipment of oil is received shall be used as the daily value when calculating the 30-day rolling average until the next shipment is received. If the fuel analysis shows that the sulfur content in the fuel tank is greater than 0.5 weight percent sulfur, the owner or operator shall ensure that the sulfur content of subsequent oil shipments is low enough to cause the 30-day rolling average sulfur content to be 0.5 weight percent sulfur or less.

(3) Method 6B of appendix A of this part may be used in lieu of CEMS to measure SO<sub>2</sub> at the inlet or outlet of the SO<sub>2</sub> control system. An initial stratification test is required to verify the adequacy of the Method 6B of appendix A of this part sampling location. The stratification test shall consist of three paired runs of a suitable SO<sub>2</sub> and CO<sub>2</sub> measurement train operated at the candidate location and a second similar train operated according to the procedures in §3.2 and the applicable procedures in section 7 of Performance Specification 2 of appendix B of this part. Method 6B of appendix A of this part, Method 6A of appendix A of this part, or a combination of Methods 6 and 3 of appendix A of this part or Methods 6C and 3A of appendix A of this part are suitable measurement techniques. If Method 6B of appendix A of this part is used for the second train, sampling time and timer operation may be adjusted for the stratification test as long as an adequate sample volume is collected; however, both sampling trains are to be operated similarly. For the location to be adequate for Method 6B of appendix A of this part 24-hour tests, the mean of the absolute difference between the three paired runs must be less than 10 percent (0.10).

(e) The monitoring requirements of paragraphs (a) and (d) of this section shall not apply to affected facilities subject to §60.42c(h) (1), (2), or (3) where the owner or operator of the affected facility seeks to demonstrate compliance with the SO<sub>2</sub> standards based on fuel supplier certification, as described under §60.48c(f), as applicable.

(f) The owner or operator of an affected facility operating a CEMS pursuant to paragraph (a) of this section, or conducting as-fired fuel sampling pursuant to paragraph (d)(1) of this section, shall obtain emission data for at least 75 percent of the operating hours in at least 22 out of 30 successive steam generating unit operating days. If this minimum data requirement is not met with a single monitoring system, the owner or operator of the affected facility shall supplement the emission data with data collected with other monitoring systems as approved by the Administrator.

#### **§ 60.47c Emission monitoring for particulate matter.**

(a) Except as provided in paragraphs (c), (d), (e), (f), and (g) of this section, the owner or operator of an affected facility combusting coal, oil, or wood that is subject to the opacity standards under §60.43c shall install, calibrate, maintain, and operate a continuous opacity monitoring system (COMS) for measuring the opacity of the emissions discharged to the atmosphere and record the output of the system. The owner or operator of an affected facility subject to an opacity standard in §60.43c(c) and that is not required to install a COMS due to paragraphs (c), (d), (e), or (f) of this section that elects not to install a COMS shall conduct a performance test using Method 9 of appendix A-4 of this part and the procedures in §60.11 to demonstrate compliance with the applicable limit in §60.43c and shall comply with either paragraphs (a)(1), (a)(2), or (a)(3) of this section. If during the initial 60 minutes of observation all 6-minute averages are less than 10 percent and all individual 15-second observations are less than or equal to 20 percent, the observation period may be reduced from 3 hours to 60 minutes.

(1) Except as provided in paragraph (a)(2) and (a)(3) of this section, the owner or operator shall conduct subsequent Method 9 of appendix A-4 of this part performance tests using the procedures in paragraph (a) of this section according to the applicable schedule in paragraphs (a)(1)(i) through (a)(1)(iv) of this section, as determined by the most recent Method 9 of appendix A-4 of this part performance test results.

(i) If no visible emissions are observed, a subsequent Method 9 of appendix A-4 of this part performance test must be completed within 12 calendar months from the date that the most recent performance test was conducted;

(ii) If visible emissions are observed but the maximum 6-minute average opacity is less than or equal to 5 percent, a subsequent Method 9 of appendix A-4 of this part performance test must be completed within 6 calendar months from the date that the most recent performance test was conducted;

(iii) If the maximum 6-minute average opacity is greater than 5 percent but less than or equal to 10 percent, a subsequent Method 9 of appendix A-4 of this part performance test must be completed within 3 calendar months from the date that the most recent performance test was conducted; or

(iv) If the maximum 6-minute average opacity is greater than 10 percent, a subsequent Method 9 of appendix A-4 of this part performance test must be completed within 30 calendar days from the date that the most recent performance test was conducted.

(2) If the maximum 6-minute opacity is less than 10 percent during the most recent Method 9 of appendix A-4 of this part performance test, the owner or operator may, as an alternative to performing subsequent Method 9 of appendix A-4 of this part performance tests, elect to perform subsequent monitoring using Method 22 of appendix A-7 of this part according to the procedures specified in paragraphs (a)(2)(i) and (ii) of this section.

(i) The owner or operator shall conduct 10 minute observations (during normal operation) each operating day the affected facility fires fuel for which an opacity standard is applicable using Method 22 of appendix A-7 of this part and demonstrate that the sum of the occurrences of any visible emissions is not in excess of 5 percent of the observation period ( *i.e.* , 30 seconds per 10 minute period). If the sum of the occurrence of any visible emissions is greater than 30 seconds during the initial 10 minute observation, immediately conduct a 30 minute observation. If the sum of the occurrence of visible emissions is greater than 5 percent of the observation period ( *i.e.* , 90 seconds per 30 minute period) the owner or operator shall either document and adjust the operation of the facility and demonstrate within 24 hours that the sum of the occurrence of visible emissions is equal to or less than 5 percent during a 30 minute observation ( *i.e.* , 90 seconds) or conduct a new Method 9 of appendix A-4 of this part performance test using the procedures in paragraph (a) of this section within 30 calendar days according to the requirements in §60.45c(a)(8).

(ii) If no visible emissions are observed for 30 operating days during which an opacity standard is applicable, observations can be reduced to once every 7 operating days during which an opacity standard is applicable. If any visible emissions are observed, daily observations shall be resumed.

(3) If the maximum 6-minute opacity is less than 10 percent during the most recent Method 9 of appendix A-4 of this part performance test, the owner or operator may, as an alternative to performing subsequent Method 9 of appendix A-4 performance tests, elect to perform subsequent monitoring using a digital opacity compliance system according to a site-specific monitoring plan approved by the Administrator. The observations shall be similar, but not necessarily identical, to the requirements in paragraph (a)(2) of this section. For reference purposes in preparing the monitoring plan, see OAQPS "Determination of Visible Emission Opacity from Stationary Sources Using Computer-Based Photographic Analysis Systems." This document is available from the U.S. Environmental Protection Agency (U.S. EPA); Office of Air Quality and Planning Standards; Sector Policies and Programs Division; Measurement Policy Group (D243-02), Research Triangle Park, NC 27711. This document is also available on the Technology Transfer Network (TTN) under Emission Measurement Center Preliminary Methods.

(b) All COMS shall be operated in accordance with the applicable procedures under Performance Specification 1 of appendix B of this part. The span value of the opacity COMS shall be between 60 and 80 percent.

(c) Owners and operators of an affected facilities that burn only distillate oil that contains no more than 0.5 weight percent sulfur and/or liquid or gaseous fuels with potential sulfur dioxide emission rates of 26 ng/J (0.060 lb/MMBtu) heat input or less and that do not use a post-combustion technology to reduce SO<sub>2</sub> or PM

emissions and that are subject to an opacity standard in §60.43c(c) are not required to operate a COMS if they follow the applicable procedures in §60.48c(f).

(d) Owners or operators complying with the PM emission limit by using a PM CEMS must calibrate, maintain, operate, and record the output of the system for PM emissions discharged to the atmosphere as specified in §60.45c(c). The CEMS specified in paragraph §60.45c(c) shall be operated and data recorded during all periods of operation of the affected facility except for CEMS breakdowns and repairs. Data is recorded during calibration checks, and zero and span adjustments.

(e) Owners and operators of an affected facility that is subject to an opacity standard in §60.43c(c) and that does not use post-combustion technology (except a wet scrubber) for reducing PM, SO<sub>2</sub>, or carbon monoxide (CO) emissions, burns only gaseous fuels or fuel oils that contain less than or equal to 0.5 weight percent sulfur, and is operated such that emissions of CO discharged to the atmosphere from the affected facility are maintained at levels less than or equal to 0.15 lb/MMBtu on a boiler operating day average basis is not required to operate a COMS. Owners and operators of affected facilities electing to comply with this paragraph must demonstrate compliance according to the procedures specified in paragraphs (e)(1) through (4) of this section; or

(1) You must monitor CO emissions using a CEMS according to the procedures specified in paragraphs (e)(1)(i) through (iv) of this section.

(i) The CO CEMS must be installed, certified, maintained, and operated according to the provisions in §60.58b(i)(3) of subpart Eb of this part.

(ii) Each 1-hour CO emissions average is calculated using the data points generated by the CO CEMS expressed in parts per million by volume corrected to 3 percent oxygen (dry basis).

(iii) At a minimum, valid 1-hour CO emissions averages must be obtained for at least 90 percent of the operating hours on a 30-day rolling average basis. The 1-hour averages are calculated using the data points required in §60.13(h)(2).

(iv) Quarterly accuracy determinations and daily calibration drift tests for the CO CEMS must be performed in accordance with procedure 1 in appendix F of this part.

(2) You must calculate the 1-hour average CO emissions levels for each steam generating unit operating day by multiplying the average hourly CO output concentration measured by the CO CEMS times the corresponding average hourly flue gas flow rate and divided by the corresponding average hourly heat input to the affected source. The 24-hour average CO emission level is determined by calculating the arithmetic average of the hourly CO emission levels computed for each steam generating unit operating day.

(3) You must evaluate the preceding 24-hour average CO emission level each steam generating unit operating day excluding periods of affected source startup, shutdown, or malfunction. If the 24-hour average CO emission level is greater than 0.15 lb/MMBtu, you must initiate investigation of the relevant equipment and control systems within 24 hours of the first discovery of the high emission incident and, take the appropriate corrective action as soon as practicable to adjust control settings or repair equipment to reduce the 24-hour average CO emission level to 0.15 lb/MMBtu or less.

(4) You must record the CO measurements and calculations performed according to paragraph (e) of this section and any corrective actions taken. The record of corrective action taken must include the date and time during which the 24-hour average CO emission level was greater than 0.15 lb/MMBtu, and the date, time, and description of the corrective action.

(f) Owners and operators of an affected facility that is subject to an opacity standard in §60.43c(c) and that uses a bag leak detection system to monitor the performance of a fabric filter (baghouse) according to the most recent requirements in section §60.48Da of this part is not required to operate a COMS.



(g) Owners and operators of an affected facility that is subject to an opacity standard in §60.43c(c) and that burns only gaseous fuels or fuel oils that contain less than or equal to 0.5 weight percent sulfur and operates according to a written site-specific monitoring plan approved by the permitting authority is not required to operate a COMS. This monitoring plan must include procedures and criteria for establishing and monitoring specific parameters for the affected facility indicative of compliance with the opacity standard.

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009]

**§ 60.48c Reporting and recordkeeping requirements.**

(a) The owner or operator of each affected facility shall submit notification of the date of construction or reconstruction and actual startup, as provided by §60.7 of this part. This notification shall include:

(1) The design heat input capacity of the affected facility and identification of fuels to be combusted in the affected facility.

(2) If applicable, a copy of any federally enforceable requirement that limits the annual capacity factor for any fuel or mixture of fuels under §60.42c, or §60.43c.

(3) The annual capacity factor at which the owner or operator anticipates operating the affected facility based on all fuels fired and based on each individual fuel fired.

(4) Notification if an emerging technology will be used for controlling SO<sub>2</sub> emissions. The Administrator will examine the description of the control device and will determine whether the technology qualifies as an emerging technology. In making this determination, the Administrator may require the owner or operator of the affected facility to submit additional information concerning the control device. The affected facility is subject to the provisions of §60.42c(a) or (b)(1), unless and until this determination is made by the Administrator.

(b) The owner or operator of each affected facility subject to the SO<sub>2</sub> emission limits of §60.42c, or the PM or opacity limits of §60.43c, shall submit to the Administrator the performance test data from the initial and any subsequent performance tests and, if applicable, the performance evaluation of the CEMS and/or COMS using the applicable performance specifications in appendix B of this part.

(c) In addition to the applicable requirements in §60.7, the owner or operator of an affected facility subject to the opacity limits in §60.43c(c) shall submit excess emission reports for any excess emissions from the affected facility that occur during the reporting period and maintain records according to the requirements specified in paragraphs (c)(1) through (3) of this section, as applicable to the visible emissions monitoring method used.

(1) For each performance test conducted using Method 9 of appendix A-4 of this part, the owner or operator shall keep the records including the information specified in paragraphs (c)(1)(i) through (iii) of this section.

(i) Dates and time intervals of all opacity observation periods;

(ii) Name, affiliation, and copy of current visible emission reading certification for each visible emission observer participating in the performance test; and

(iii) Copies of all visible emission observer opacity field data sheets;

(2) For each performance test conducted using Method 22 of appendix A-4 of this part, the owner or operator shall keep the records including the information specified in paragraphs (c)(2)(i) through (iv) of this section.

(i) Dates and time intervals of all visible emissions observation periods;

- (ii) Name and affiliation for each visible emission observer participating in the performance test;
  - (iii) Copies of all visible emission observer opacity field data sheets; and
  - (iv) Documentation of any adjustments made and the time the adjustments were completed to the affected facility operation by the owner or operator to demonstrate compliance with the applicable monitoring requirements.
- (3) For each digital opacity compliance system, the owner or operator shall maintain records and submit reports according to the requirements specified in the site-specific monitoring plan approved by the Administrator
- (d) The owner or operator of each affected facility subject to the SO<sub>2</sub> emission limits, fuel oil sulfur limits, or percent reduction requirements under §60.42c shall submit reports to the Administrator.
- (e) The owner or operator of each affected facility subject to the SO<sub>2</sub> emission limits, fuel oil sulfur limits, or percent reduction requirements under §60.42c shall keep records and submit reports as required under paragraph (d) of this section, including the following information, as applicable.
- (1) Calendar dates covered in the reporting period.
  - (2) Each 30-day average SO<sub>2</sub> emission rate (ng/J or lb/MMBtu), or 30-day average sulfur content (weight percent), calculated during the reporting period, ending with the last 30-day period; reasons for any noncompliance with the emission standards; and a description of corrective actions taken.
  - (3) Each 30-day average percent of potential SO<sub>2</sub> emission rate calculated during the reporting period, ending with the last 30-day period; reasons for any noncompliance with the emission standards; and a description of the corrective actions taken.
  - (4) Identification of any steam generating unit operating days for which SO<sub>2</sub> or diluent (O<sub>2</sub> or CO<sub>2</sub>) data have not been obtained by an approved method for at least 75 percent of the operating hours; justification for not obtaining sufficient data; and a description of corrective actions taken.
  - (5) Identification of any times when emissions data have been excluded from the calculation of average emission rates; justification for excluding data; and a description of corrective actions taken if data have been excluded for periods other than those during which coal or oil were not combusted in the steam generating unit.
  - (6) Identification of the F factor used in calculations, method of determination, and type of fuel combusted.
  - (7) Identification of whether averages have been obtained based on CEMS rather than manual sampling methods.
  - (8) If a CEMS is used, identification of any times when the pollutant concentration exceeded the full span of the CEMS.
  - (9) If a CEMS is used, description of any modifications to the CEMS that could affect the ability of the CEMS to comply with Performance Specifications 2 or 3 of appendix B of this part.
  - (10) If a CEMS is used, results of daily CEMS drift tests and quarterly accuracy assessments as required under appendix F, Procedure 1 of this part.
  - (11) If fuel supplier certification is used to demonstrate compliance, records of fuel supplier certification as described under paragraph (f)(1), (2), (3), or (4) of this section, as applicable. In addition to records of fuel supplier certifications, the report shall include a certified statement signed by the owner or operator of the

affected facility that the records of fuel supplier certifications submitted represent all of the fuel combusted during the reporting period.

(f) Fuel supplier certification shall include the following information:

(1) For distillate oil:

(i) The name of the oil supplier;

(ii) A statement from the oil supplier that the oil complies with the specifications under the definition of distillate oil in §60.41c; and

(iii) The sulfur content or maximum sulfur content of the oil.

(2) For residual oil:

(i) The name of the oil supplier;

(ii) The location of the oil when the sample was drawn for analysis to determine the sulfur content of the oil, specifically including whether the oil was sampled as delivered to the affected facility, or whether the sample was drawn from oil in storage at the oil supplier's or oil refiner's facility, or other location;

(iii) The sulfur content of the oil from which the shipment came (or of the shipment itself); and

(iv) The method used to determine the sulfur content of the oil.

(3) For coal:

(i) The name of the coal supplier;

(ii) The location of the coal when the sample was collected for analysis to determine the properties of the coal, specifically including whether the coal was sampled as delivered to the affected facility or whether the sample was collected from coal in storage at the mine, at a coal preparation plant, at a coal supplier's facility, or at another location. The certification shall include the name of the coal mine (and coal seam), coal storage facility, or coal preparation plant (where the sample was collected);

(iii) The results of the analysis of the coal from which the shipment came (or of the shipment itself) including the sulfur content, moisture content, ash content, and heat content; and

(iv) The methods used to determine the properties of the coal.

(4) For other fuels:

(i) The name of the supplier of the fuel;

(ii) The potential sulfur emissions rate or maximum potential sulfur emissions rate of the fuel in ng/J heat input; and

(iii) The method used to determine the potential sulfur emissions rate of the fuel.

(g)(1) Except as provided under paragraphs (g)(2) and (g)(3) of this section, the owner or operator of each affected facility shall record and maintain records of the amount of each fuel combusted during each operating day.

(2) As an alternative to meeting the requirements of paragraph (g)(1) of this section, the owner or operator of an affected facility that combusts only natural gas, wood, fuels using fuel certification in §60.48c(f) to demonstrate compliance with the SO<sub>2</sub> standard, fuels not subject to an emissions standard (excluding opacity), or a mixture of these fuels may elect to record and maintain records of the amount of each fuel combusted during each calendar month.

(3) As an alternative to meeting the requirements of paragraph (g)(1) of this section, the owner or operator of an affected facility or multiple affected facilities located on a contiguous property unit where the only fuels combusted in any steam generating unit (including steam generating units not subject to this subpart) at that property are natural gas, wood, distillate oil meeting the most current requirements in §60.42C to use fuel certification to demonstrate compliance with the SO<sub>2</sub> standard, and/or fuels, excluding coal and residual oil, not subject to an emissions standard (excluding opacity) may elect to record and maintain records of the total amount of each steam generating unit fuel delivered to that property during each calendar month.

(h) The owner or operator of each affected facility subject to a federally enforceable requirement limiting the annual capacity factor for any fuel or mixture of fuels under §60.42c or §60.43c shall calculate the annual capacity factor individually for each fuel combusted. The annual capacity factor is determined on a 12-month rolling average basis with a new annual capacity factor calculated at the end of the calendar month.

(i) All records required under this section shall be maintained by the owner or operator of the affected facility for a period of two years following the date of such record.

(j) The reporting period for the reports required under this subpart is each six-month period. All reports shall be submitted to the Administrator and shall be postmarked by the 30th day following the end of the reporting period.

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009]

**Attachment C**  
**to Part 70 Operating Permit Renewal No. T157-25200-00038**

Cargill, Inc. - Soybean Processing Division  
1502 Wabash Avenue, Lafayette, IN 47905

**Subpart GGGG—National Emission Standards for Hazardous Air Pollutants: Solvent Extraction for Vegetable Oil Production**

**Source:** 66 FR 19011, Apr. 12, 2001, unless otherwise noted.

**What This Subpart Covers**

**§ 63.2830 What is the purpose of this subpart?**

This subpart establishes national emission standards for hazardous air pollutants (NESHAP) for emissions during vegetable oil production. This subpart limits hazardous air pollutant (HAP) emissions from specified vegetable oil production processes. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emission standards.

**§ 63.2831 Where can I find definitions of key words used in this subpart?**

You can find definitions of key words used in this subpart in §63.2872.

**§ 63.2832 Am I subject to this subpart?**

(a) You are an affected source subject to this subpart if you meet all of the criteria listed in paragraphs (a)(1) and (2) of this section:

(1) You own or operate a vegetable oil production process that is a major source of HAP emissions or is collocated within a plant site with other sources that are individually or collectively a major source of HAP emissions.

(i) A *vegetable oil production process* is defined in §63.2872. In general, it is the collection of continuous process equipment and activities that produce crude vegetable oil and meal products by removing oil from oilseeds listed in Table 1 to §63.2840 through direct contact with an organic solvent, such as a hexane isomer blend.

(ii) A major source of HAP emissions is a plant site that emits or has the potential to emit any single HAP at a rate of 10 tons (9.07 megagrams) or more per year or any combination of HAP at a rate of 25 tons (22.68 megagrams) or more per year.

(2) Your vegetable oil production process processes any combination of eight types of oilseeds listed in paragraphs (a)(2)(i) through (viii) of this section:

(i) Corn germ;

(ii) Cottonseed;

(iii) Flax;

(iv) Peanut;

(v) Rapeseed (for example, canola);

- (vi) Safflower;
- (vii) Soybean; and
- (viii) Sunflower.

(b) You are not subject to this subpart if your vegetable oil production process meets any of the criteria listed in paragraphs (b)(1) through (4) of this section:

- (1) It uses only mechanical extraction techniques that use no organic solvent to remove oil from a listed oilseed.
- (2) It uses only batch solvent extraction and batch desolventizing equipment.
- (3) It processes only agricultural products that are not listed oilseeds as defined in §63.2872.
- (4) It functions only as a research and development facility and is not a major source.

(c) As listed in §63.1(c)(5) of the General Provisions, if your HAP emissions increase such that you become a major source, then you are subject to all of the requirements of this subpart.

**§ 63.2833 Is my source categorized as existing or new?**

(a) This subpart applies to each existing and new affected source. You must categorize your vegetable oil production process as either an existing or a new source in accordance with the criteria in Table 1 of this section, as follows:

**Table 1 to §63.2833—Categorizing Your Source as Existing or New**

<b>If your affected source...</b>	<b>And if...</b>	<b>Then your affected source...</b>
(1) was constructed or began construction before May 26, 2000	reconstruction has not occurred	is an existing source.
(2) began reconstruction, as defined in §63.2, on or after May 26, 2000	(i) reconstruction was part of a scheduled plan to comply with the existing source requirements of this subpart; and (ii) reconstruction was completed no later than 3 years after the effective date of this subpart	remains an existing source.
(3) began a significant modification, as defined in §63.2872, at any time on an existing source	the modification does not constitute reconstruction	remains an existing source.
(4) began a significant modification, as defined in §63.2872, at any time on a new source	the modification does not constitute reconstruction	remains a new source.
(5) began reconstruction on or after May 26, 2000	reconstruction was completed later than 3 years after the effective date of this subpart	is a new source
(6) began construction on or after May 26, 2000		is a new source.

(b) *Reconstruction of a source.* Any affected source is reconstructed if components are replaced so that the criteria in the definition of *reconstruction* in §63.2 are satisfied. In general, a vegetable oil production process

is reconstructed if the fixed capital cost of the new components exceeds 50 percent of the fixed capital cost for constructing a new vegetable oil production process, and it is technically and economically feasible for the reconstructed source to meet the relevant new source requirements of this subpart. The effect of reconstruction on the categorization of your existing and new affected source is described in paragraphs (b)(1) and (2) of this section:

(1) After reconstruction of an existing source, the affected source is recategorized as a new source and becomes subject to the new source requirements of this subpart.

(2) After reconstruction of a new source, the affected source remains categorized as a new source and remains subject to the new source requirements of this subpart.

(c) *Significant modification of a source.* A significant modification to an affected source is a term specific to this subpart and is defined in §63.2872.

(1) In general, a significant modification to your source consists of adding new equipment or the modification of existing equipment within the affected source that significantly affects solvent losses from the affected source. Examples include adding or replacing extractors, desolventizer-toasters (conventional and specialty), and meal dryer-coolers. All other significant modifications must meet the criteria listed in paragraphs (c)(1)(i) and (ii) of this section:

(i) The fixed capital cost of the modification represents a significant percentage of the fixed capital cost of building a comparable new vegetable oil production process.

(ii) It does not constitute reconstruction as defined in §63.2.

(2) A significant modification has no effect on the categorization of your source as existing and new. An existing source remains categorized as an existing source and subject to the existing source requirements of this subpart. A new source remains categorized as a new source and subject to the new source requirements of this subpart.

(d) Changes in the type of oilseed processed by your affected source does not affect the categorization of your source as new or existing. Recategorizing an affected source from existing to new occurs only when you add or modify process equipment within the source which meets the definition of *reconstruction*.

**§ 63.2834 When do I have to comply with the standards in this subpart?**

You must comply with this subpart in accordance with one of the schedules in Table 1 of this section, as follows:

**Table 1 of §63.2834—Compliance Dates for Existing and New Sources**

<b>If your affected source is categorized as...</b>	<b>And if...</b>	<b>Then your compliance date is...</b>
(a) an existing source		3 years after the effective date of this subpart.
(b) a new source	you startup your affected source before the effective date of this subpart	the effective date of this subpart.
(c) a new source	you startup your affected source on or after the effective date of this subpart	your startup date.

## Standards

### § 63.2840 What emission requirements must I meet?

For each facility meeting the applicability criteria in §63.2832, you must comply with either the requirements specified in paragraphs (a) through (d), or the requirements in paragraph (e) of this section.

(a)(1) The emission requirements limit the number of gallons of HAP lost per ton of listed oilseeds processed. For each operating month, you must calculate a compliance ratio which compares your actual HAP loss to your allowable HAP loss for the previous 12 operating months as shown in Equation 1 of this section. An operating month, as defined in §63.2872, is any calendar month in which a source processes a listed oilseed, excluding any entire calendar month in which the source operated under an initial startup period subject to §63.2850(c)(2) or (d)(2) or a malfunction period subject to §63.2850(e)(2). Equation 1 of this section follows:

$$\text{Compliance Ratio} = \frac{\text{Actual Hap Loss}}{\text{Allowable Hap Loss}} \quad (\text{Eq. 1})$$

(2) Equation 1 of this section can also be expressed as a function of total solvent loss as shown in Equation 2 of this section. Equation 2 of this section follows:

$$\text{Compliance Ratio} = \frac{f * \text{Actual Solvent Loss}}{0.64 * \sum_{i=1}^n ((\text{Oilseed})_i * (\text{SLF})_i)} \quad (\text{Eq. 2})$$

Where:

f = The weighted average volume fraction of HAP in solvent received during the previous 12 operating months, as determined in §63.2854, dimensionless.

0.64 = The average volume fraction of HAP in solvent in the baseline performance data, dimensionless.

Actual Solvent Loss = Gallons of actual solvent loss during previous 12 operating months, as determined in §63.2853.

Oilseed = Tons of each oilseed type "i" processed during the previous 12 operating months, as shown in §63.2855.

SLF = The corresponding solvent loss factor (gal/ton) for oilseed "i" listed in Table 1 of this section, as follows:



**Table 1 of §63.2840—Oilseed Solvent Loss Factors for Determining Allowable HAP Loss**

Type of oilseed process	A source that...	Oilseed solvent loss factor (gal/ton)	
		Existing sources	New sources
(i) Corn Germ, Wet Milling	processes corn germ that has been separated from other corn components using a “wet” process of centrifuging a slurry steeped in a dilute sulfurous acid solution	0.4	0.3
(ii) Corn Germ, Dry Milling	processes corn germ that has been separated from the other corn components using a “dry” process of mechanical chafing and air sifting	0.7	0.7
(iii) Cottonseed, Large	processes 120,000 tons or more of a combination of cottonseed and other listed oilseeds during all normal operating periods in a 12 operating month period	0.5	0.4
(iv) Cottonseed, Small	processes less than 120,000 tons of a combination of cottonseed and other listed oilseeds during all normal operating periods in a 12 operating month period	0.7	0.4
(v) Flax	processes flax	0.6	0.6
(vi) Peanuts	processes peanuts	1.2	0.7
(vii) Rapeseed	processes rapeseed	0.7	0.3
(viii) Safflower	processes safflower	0.7	0.7
(ix) Soybean, Conventional	uses a conventional style desolventizer to produce crude soybean oil products and soybean animal feed products	0.2	0.2
(x) Soybean, Specialty	uses a special style desolventizer to produce soybean meal products for human and animal consumption	1.7	1.5
(xi) Soybean, Combination Plant with Low Specialty Production	processes soybeans in both specialty and conventional desolventizers and the quantity of soybeans processed in specialty desolventizers during normal operating periods is less than 3.3 percent of total soybeans processed during all normal operating periods in a 12 operating month period. The corresponding solvent loss factor is an overall value and applies to the total quantity of soybeans processed.	0.25	0.25
(xii) Sunflower	processes sunflower	0.4	0.3

(b) When your source has processed listed oilseed for 12 operating months, calculate the compliance ratio by the end of each calendar month following an operating month using Equation 2 of this section. When calculating your compliance ratio, consider the conditions and exclusions in paragraphs (b)(1) through (6) of this section:

(1) If your source processes any quantity of listed oilseeds in a calendar month and the source is not operating under an initial startup period or malfunction period subject to §63.2850, then you must categorize the month as an operating month, as defined in §63.2872.

(2) The 12-month compliance ratio may include operating months occurring prior to a source shutdown and operating months that follow after the source resumes operation.

(3) If your source shuts down and processes no listed oilseed for an entire calendar month, then you must categorize the month as a nonoperating month, as defined in §63.2872. Exclude any nonoperating months from the compliance ratio determination.

(4) If your source is subject to an initial startup period as defined in §63.2872, exclude from the compliance ratio determination any solvent and oilseed information recorded for the initial startup period.

(5) If your source is subject to a malfunction period as defined in §63.2872, exclude from the compliance ratio determination any solvent and oilseed information recorded for the malfunction period.

(6) For sources processing cottonseed or specialty soybean, the solvent loss factor you use to determine the compliance ratio may change each operating month depending on the tons of oilseed processed during all normal operating periods in a 12 operating month period.

(c) If the compliance ratio is less than or equal to 1.00, your source was in compliance with the HAP emission requirements for the previous operating month.

(d) To determine the compliance ratio in Equation 2 of this section, you must select the appropriate oilseed solvent loss factor from Table 1 of this section. First, determine whether your source is new or existing using Table 1 of §63.2833. Then, under the appropriate existing or new source column, select the oilseed solvent loss factor that corresponds to each type oilseed or process operation for each operating month.

(e) *Low-HAP solvent option.* For all vegetable oil production processes subject to this subpart, you must exclusively use solvent where the volume fraction of each HAP comprises 1 percent or less by volume of the solvent (low-HAP solvent) in each delivery, and you must meet the requirements in paragraphs (e)(1) through (5) of this section. Your vegetable oil production process is not subject to the requirements in §§63.2850 through 63.2870 unless specifically referenced in paragraphs (e)(1) through (5) of this section.

(1) You shall determine the HAP content of your solvent in accordance with the specifications in §63.2854(b)(1).

(2) You shall maintain documentation of the HAP content determination for each delivery of the solvent at the facility at all times.

(3) You must submit an initial notification for existing sources in accordance with §63.2860(a).

(4) You must submit an initial notification for new and reconstructed sources in accordance with §63.2860(b).

(5) You must submit an annual compliance certification in accordance with §63.2861(a). The certification should only include the information required under §63.2861(a)(1) and (2), and a certification indicating whether the source complied with all of the requirements in paragraph (e) of this section.

(f) You may change compliance options for your source if you submit a notice to the Administrator at least 60 days prior to changing compliance options. If your source changes from the low-HAP solvent option to the compliance ratio determination option, you must determine the compliance ratio for the most recent 12 operating months beginning with the first month after changing compliance options.

[66 FR 19011, Apr. 12, 2001, as amended at 69 FR 53341, Sept. 1, 2004]

## **Compliance Requirements**

### **§ 63.2850 How do I comply with the hazardous air pollutant emission standards?**

(a) *General requirements.* The requirements in paragraphs (a)(1)(i) through (iv) of this section apply to all affected sources:

(1) Submit the necessary notifications in accordance with §63.2860, which include:

- (i) Initial notifications for existing sources.
- (ii) Initial notifications for new and reconstructed sources.
- (iii) Initial notifications for significant modifications to existing or new sources.
- (iv) Notification of compliance status.

(2) Develop and implement a plan for demonstrating compliance in accordance with §63.2851.

(3) Develop a written startup, shutdown and malfunction (SSM) plan in accordance with the provisions in §63.2852.

(4) Maintain all the necessary records you have used to demonstrate compliance with this subpart in accordance with §63.2862.

(5) Submit the reports in paragraphs (a)(5)(i) through (iii) of this section:

- (i) Annual compliance certifications in accordance with §63.2861(a).
- (ii) Periodic SSM reports in accordance with §63.2861(c).
- (iii) Immediate SSM reports in accordance with §63.2861(d).

(6) Submit all notifications and reports and maintain all records required by the General Provisions for performance testing if you add a control device that destroys solvent.

(b) *Existing sources under normal operation.* You must meet all of the requirements listed in paragraph (a) of this section and table 1 of this section for sources under normal operation, and the schedules for demonstrating compliance for existing sources under normal operation in table 2 of this section.

(c) *New sources.* Your new source, including a source that is categorized as new due to reconstruction, must meet the requirements associated with one of two compliance options. Within 15 days of the startup date, you must choose to comply with one of the options listed in paragraph (c)(1) or (2) of this section:

(1) *Normal operation.* Upon startup of your new source, you must meet all of the requirements listed in §63.2850(a) and table 1 of this section for sources under normal operation, and the schedules for demonstrating compliance for new sources under normal operation in table 2 of this section.

(2) *Initial startup period.* For up to 6 calendar months after the startup date of your new source, you must meet all of the requirements listed in paragraph (a) of this section and table 1 of this section for sources operating under an initial startup period, and the schedules for demonstrating compliance for new sources operating under an initial startup period in Table 2 of this section. After a maximum of 6 calendar months, your new source must then meet all of the requirements listed in table 1 of this section for sources under normal operation.

(d) *Existing or new sources that have been significantly modified.* Your existing or new source that has been significantly modified must meet the requirements associated with one of two compliance options. Within 15 days of the modified source startup date, you must choose to comply with one of the options listed in paragraph (d)(1) or (2) of this section:

(1) *Normal operation.* Upon startup of your significantly modified existing or new source, you must meet all of the requirements listed in paragraph (a) of this section and table 1 of this section for sources under

normal operation, and the schedules for demonstrating compliance for an existing or new source that has been significantly modified in table 2 of this section.

(2) *Initial startup period.* For up to 3 calendar months after the startup date of your significantly modified existing or new source, you must meet all of the requirements listed in paragraph (a) of this section and table 1 of this section for sources operating under an initial startup period, and the schedules for demonstrating compliance for a significantly modified existing or new source operating under an initial startup period in table 2 of this section. After a maximum of 3 calendar months, your new or existing source must meet all of the requirements listed in Table 1 of this section for sources under normal operation.

(e) *Existing or new sources experiencing a malfunction.* A *malfunction* is defined in §63.2. In general, it means any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment or process equipment to function in a usual manner. If your existing or new source experiences an unscheduled shutdown as a result of a malfunction, continues to operate during a malfunction (including the period reasonably necessary to correct the malfunction), or starts up after a shutdown resulting from a malfunction, then you must meet the requirements associated with one of two compliance options. Routine or scheduled process startups and shutdowns resulting from, but not limited to, market demands, maintenance activities, and switching types of oilseed processed, are not startups or shutdowns resulting from a malfunction and, therefore, do not qualify for this provision. Within 15 days of the beginning date of the malfunction, you must choose to comply with one of the options listed in paragraphs (e)(1) through (2) of this section:

(1) *Normal operation.* Your source must meet all of the requirements listed in paragraph (a) of this section and one of the options listed in paragraphs (e)(1)(i) through (iii) of this section:

(i) Existing source normal operation requirements in paragraph (b) of this section.

(ii) New source normal operation requirements in paragraph (c)(1) of this section.

(iii) Normal operation requirements for sources that have been significantly modified in paragraph (d)(1) of this section.

(2) *Malfunction period.* Throughout the malfunction period, you must meet all of the requirements listed in paragraph (a) of this section and Table 1 of this section for sources operating during a malfunction period. At the end of the malfunction period, your source must then meet all of the requirements listed in table 1 of this section for sources under normal operation. Table 1 of this section follows:

**Table 1 of §63.2850—Requirements for Compliance with HAP Emission Standards**

<b>Are you required to . . .</b>	<b>For periods of normal operation?</b>	<b>For initial startup periods subject to §63.2850(c)(2) or (d)(2)?</b>	<b>For malfunction periods subject to §63.2850(e)(2)?</b>
(a) Operate and maintain your source in accordance with general duty provisions of §63.6(e)?	Yes. Additionally, the HAP emission limits will apply.	Yes, you are required to minimize emissions to the extent practicable throughout the initial startup period. Such measures should be described in the SSM plan.	Yes, you are required to minimize emissions to the extent practicable throughout the initial startup period. Such measures should be described in the SSM plan.
(b) Determine and record the extraction solvent loss in gallons from your source?	Yes, as described in §63.2853	Yes, as described in §63.2862(e)	Yes, as described in §63.2862(e).
(c) Record the volume fraction of HAP present at greater than 1 percent by	Yes	Yes	Yes.

Are you required to . . .	For periods of normal operation?	For initial startup periods subject to §63.2850(c)(2) or (d)(2)?	For malfunction periods subject to §63.2850(e)(2)?
volume and gallons of extraction solvent in shipment received?			
(d) Determine and record the tons of each oilseed type processed by your source?	Yes, as described in §63.2855	No	No.
(e) Determine the weighted average volume fraction of HAP in extraction solvent received as described in §63.2854 by the end of the following calendar month?	Yes	No. Except for solvent received by a new or reconstructed source commencing operation under an initial startup period, the HAP volume fraction in any solvent received during an initial startup period is included in the weighted average HAP determination for the next operating month	No, the HAP volume fraction in any solvent received during a malfunction period is included in the weighted average HAP determination for the next operating month.
(f) Determine and record the actual solvent loss, weighted average volume fraction HAP, oilseed processed and compliance ratio for each 12 operating month period as described in §63.2840 by the end of the following calendar month?	Yes,	No, these requirements are not applicable because your source is not required to determine the compliance ratio with data recorded for an initial startup period	No, these requirements are not applicable because your source is not required to determine the compliance ratio with data recorded for a malfunction period.
(g) Submit a Notification of Compliance Status or Annual Compliance Certification as appropriate?	Yes, as described in §§63.2860(d) and 63.2861(a)	No. However, you may be required to submit an annual compliance certification for previous operating months, if the deadline for the annual compliance certification happens to occur during the initial startup period	No. However, you may be required to submit an annual compliance certification for previous operating months, if the deadline for the annual compliance certification happens to occur during the malfunction period.
(h) Submit a Deviation Notification Report by the end of the calendar month following the month in which you determined that the compliance ratio exceeds 1.00 as described in §63.2861(b)?	Yes	No, these requirements are not applicable because your source is not required to determine the compliance ratio with data recorded for an initial startup period	No, these requirements are not applicable because your source is not required to determine the compliance ratio with data recorded for a malfunction period.
(i) Submit a Periodic SSM Report as described in §63.2861(c)?	No, a SSM activity is not categorized as normal operation	Yes	Yes.
(j) Submit an Immediate SSM Report as described in §63.2861(d)?	No, a SSM activity is not categorized as	Yes, only if your source does not follow the SSM plan	Yes, only if your source does not follow the SSM plan.

Are you required to . . .	For periods of normal operation?	For initial startup periods subject to §63.2850(c)(2) or (d)(2)?	For malfunction periods subject to §63.2850(e)(2)?
	normal operation		

**Table 2 of §63.2850—Schedules for Demonstrating Compliance Under Various Source Operating Modes**

If your source is . . .	and is operating under . . .	then your recordkeeping schedule . . .	You must determine your first compliance ratio by the end of the calendar month following . . .	Base your first compliance ratio on information recorded . . .
(a) Existing	Normal operation	Begins on the compliance date	The first 12 operating months after the compliance date	During the first 12 operating months after the compliance date.
(b) New	(1) Normal operation	Begins on the startup date of your new source	The first 12 operating months after the startup date of the new source	During the first 12 operating months after the startup date of the new source.
	(2) An initial startup period	Begins on the startup date of your new source	The first 12 operating months after termination of the initial startup period, which can last for up to 6 months	During the first 12 operating months after the initial startup period, which can last for up to 6 months.
(c) Existing or new that has been significantly modified	(1) Normal operation	Resumes on the startup date of the modified source	The first operating month after the startup date of the modified source	During the previous 11 operating months prior to the significant modification and the first operating month following the initial startup date of the source.
	(2) An initial startup period	Resumes on the startup date of the modified source	The first operating month after termination of the initial startup period, which can last up to 3 months	During the 11 operating months before the significant modification and the first operating month after the initial startup period.

[66 FR 19011, Apr. 12, 2001, as amended at 71 FR 20463, Apr. 20, 2006]

**§ 63.2851 What is a plan for demonstrating compliance?**

(a) You must develop and implement a written plan for demonstrating compliance that provides the detailed procedures you will follow to monitor and record data necessary for demonstrating compliance with this subpart. Procedures followed for quantifying solvent loss from the source and amount of oilseed processed vary from source to source because of site-specific factors such as equipment design characteristics and operating conditions. Typical procedures include one or more accurate measurement methods such as weigh scales, volumetric displacement, and material mass balances. Because the industry does not have a uniform set of procedures, you must develop and implement your own site-specific plan for demonstrating compliance before the compliance date for your source. You must also incorporate the plan for demonstrating compliance by reference in the source's title V permit and keep the plan on-site and readily available as long as the source is operational. If you make any changes to the plan for demonstrating compliance, then you must keep all previous versions of the plan and make them readily available for

inspection for at least 5 years after each revision. The plan for demonstrating compliance must include the items in paragraphs (a)(1) through (7) of this section:

- (1) The name and address of the owner or operator.
- (2) The physical address of the vegetable oil production process.
- (3) A detailed description of all methods of measurement your source will use to determine your solvent losses, HAP content of solvent, and the tons of each type of oilseed processed.
- (4) When each measurement will be made.
- (5) Examples of each calculation you will use to determine your compliance status. Include examples of how you will convert data measured with one parameter to other terms for use in compliance determination.
- (6) Example logs of how data will be recorded.
- (7) A plan to ensure that the data continue to meet compliance demonstration needs.

(b) The responsible agency of these NESHAP may require you to revise your plan for demonstrating compliance. The responsible agency may require reasonable revisions if the procedures lack detail, are inconsistent or do not accurately determine solvent loss, HAP content of the solvent, or the tons of oilseed processed.

#### **§ 63.2852 What is a startup, shutdown, and malfunction plan?**

You must develop a written SSM plan in accordance with §63.6(e)(3). You must complete the SSM plan before the compliance date for your source. You must also keep the SSM plan on-site and readily available as long as the source is operational. The SSM plan provides detailed procedures for operating and maintaining your source to minimize emissions during a qualifying SSM event for which the source chooses the §63.2850(e)(2) malfunction period, or the §63.2850(c)(2) or (d)(2) initial startup period. The SSM plan must specify a program of corrective action for malfunctioning process and air pollution control equipment and reflect the best practices now in use by the industry to minimize emissions. Some or all of the procedures may come from plans you developed for other purposes such as a Standard Operating Procedure manual or an Occupational Safety and Health Administration Process Safety Management plan. To qualify as a SSM plan, other such plans must meet all the applicable requirements of these NESHAP.

[66 FR 19011, Apr. 12, 2001, as amended at 67 FR 16321, Apr. 5, 2002; 71 FR 20463, Apr. 20, 2006]

#### **§ 63.2853 How do I determine the actual solvent loss?**

By the end of each calendar month following an operating month, you must determine the total solvent loss in gallons for the previous operating month. The total solvent loss for an operating month includes all solvent losses that occur during normal operating periods within the operating month. If you have determined solvent losses for 12 or more operating months, then you must also determine the 12 operating months rolling sum of actual solvent loss in gallons by summing the monthly actual solvent loss for the previous 12 operating months. The 12 operating months rolling sum of solvent loss is the "actual solvent loss," which is used to calculate your compliance ratio as described in §63.2840.

(a) To determine the actual solvent loss from your source, follow the procedures in your plan for demonstrating compliance to determine the items in paragraphs (a)(1) through (7) of this section:

(1) *The dates that define each operating status period during a calendar month.* The dates that define each operating status period include the beginning date of each calendar month and the date of any change in the source operating status. If the source maintains the same operating status during an entire calendar month, these dates are the beginning and ending dates of the calendar month. If, prior to the effective date of this

rule, your source determines the solvent loss on an *accounting month*, as defined in §63.2872, rather than a calendar month basis, and you have 12 complete accounting months of approximately equal duration in a calendar year, you may substitute the accounting month time interval for the calendar month time interval. If you choose to use an accounting month rather than a calendar month, you must document this measurement frequency selection in your plan for demonstrating compliance, and you must remain on this schedule unless you request and receive written approval from the agency responsible for these NESHAP.

(2) *Source operating status.* You must categorize the operating status of your source for each recorded time interval in accordance with criteria in Table 1 of this section, as follows:

**Table 1 of §63.2853—Categorizing Your Source Operating Status**

If during a recorded time interval . . .	then your source operating status is . . .
(i) Your source processes any amount of listed oilseed and source is not operating under an initial startup operating period or a malfunction period subject to §63.2850(c)(2), (d)(2), or (e)(2)	A normal operating period.
(ii) Your source processes no agricultural product and your source is not operating under an initial startup period or malfunction period subject to §63.2850(c)(2), (d)(2), or (e)(2)	A nonoperating period.
(iii) You choose to operate your source under an initial startup period subject to §63.2850(c)(2) or (d)(2)	An initial startup period.
(iv) You choose to operate your source under a malfunction period subject to §63.2850(e)(2)	A malfunction period.
(v) Your source processes agricultural products not defined as listed oilseed	An exempt period.

(3) *Measuring the beginning and ending solvent inventory.* You are required to measure and record the solvent inventory on the beginning and ending dates of each normal operating period that occurs during an operating month. An operating month is any calendar month with at least one normal operating period. You must consistently follow the procedures described in your plan for demonstrating compliance, as specified in §63.2851, to determine the extraction solvent inventory, and maintain readily available records of the actual solvent loss inventory, as described in §63.2862(c)(1). In general, you must measure and record the solvent inventory only when the source is actively processing any type of agricultural product. When the source is not active, some or all of the solvent working capacity is transferred to solvent storage tanks which can artificially inflate the solvent inventory.

(4) *Gallons of extraction solvent received.* Record the total gallons of extraction solvent received in each shipment. For most processes, the gallons of solvent received represents purchases of delivered solvent added to the solvent storage inventory. However, if your process refines additional vegetable oil from off-site sources, recovers solvent from the off-site oil, and adds it to the on-site solvent inventory, then you must determine the quantity of recovered solvent and include it in the gallons of extraction solvent received.

(5) *Solvent inventory adjustments.* In some situations, solvent losses determined directly from the measured solvent inventory and quantity of solvent received is not an accurate estimate of the “actual solvent loss” for use in determining compliance ratios. In such cases, you may adjust the total solvent loss for each normal operating period as long as you provide a reasonable justification for the adjustment. Situations that may require adjustments of the total solvent loss include, but are not limited to, situations in paragraphs (a)(5)(i) and (ii) of this section:

(i) *Solvent destroyed in a control device.* You may use a control device to reduce solvent emissions to meet the emission standard. The use of a control device does not alter the emission limit for the source. If you use a control device that reduces solvent emissions through destruction of the solvent instead of recovery, then determine the gallons of solvent that enter the control device and are destroyed there during each normal operating period. All solvent destroyed in a control device during a normal operating period can be



subtracted from the total solvent loss. Examples of destructive emission control devices include catalytic incinerators, boilers, or flares. Identify and describe, in your plan for demonstrating compliance, each type of reasonable and sound measurement method that you use to quantify the gallons of solvent entering and exiting the control device and to determine the destruction efficiency of the control device. You may use design evaluations to document the gallons of solvent destroyed or removed by the control device instead of performance testing under §63.7. The design evaluations must be based on the procedures and options described in §63.985(b)(1)(i)(A) through (C) or §63.11, as appropriate. All data, assumptions, and procedures used in such evaluations must be documented and available for inspection. If you use performance testing to determine solvent flow rate to the control device or destruction efficiency of the device, follow the procedures as outlined in §63.997(e)(1) and (2). Instead of periodic performance testing to demonstrate continued good operation of the control device, you may develop a monitoring plan, following the procedures outlined in §63.988(c) and using operational parametric measurement devices such as fan parameters, percent measurements of lower explosive limits, and combustion temperature.

(ii) Changes in solvent working capacity. In records you keep on-site, document any process modifications resulting in changes to the solvent working capacity in your vegetable oil production process. *Solvent working capacity* is defined in §63.2872. In general, solvent working capacity is the volume of solvent normally retained in solvent recovery equipment such as the extractor, desolventizer-toaster, solvent storage, working tanks, mineral oil absorber, condensers, and oil/solvent distillation system. If the change occurs during a normal operating period, you must determine the difference in working solvent volume and make a one-time documented adjustment to the solvent inventory.

(b) Use Equation 1 of this section to determine the actual solvent loss occurring from your affected source for all normal operating periods recorded within a calendar month. Equation 1 of this section follows:

Monthly Actual

$$\text{Solvent (gal)} = \sum_{i=1}^n (\text{SOLV}_B - \text{SOLV}_E + \text{SOLV}_R \pm \text{SOLV}_A)_i \quad (\text{Eq. 1})$$

Where:

SOLV<sub>B</sub>= Gallons of solvent in the inventory at the beginning of normal operating period "i" as determined in paragraph (a)(3) of this section.

SOLV<sub>E</sub>= Gallons of solvent in the inventory at the end of normal operating period "i" as determined in paragraph (a)(3) of this section.

SOLV<sub>R</sub>= Gallons of solvent received between the beginning and ending inventory dates of normal operating period "i" as determined in paragraph (a)(4) of this section.

SOLV<sub>A</sub>= Gallons of solvent added or removed from the extraction solvent inventory during normal operating period "i" as determined in paragraph (a)(5) of this section.

n = Number of normal operating periods in a calendar month.

(c) The actual solvent loss is the total solvent losses during normal operating periods for the previous 12 operating months. You determine your actual solvent loss by summing the monthly actual solvent losses for the previous 12 operating months. You must record the actual solvent loss by the end of each calendar month following an operating month. Use the actual solvent loss in Equation 2 of §63.2840 to determine the compliance ratio. Actual solvent loss does not include losses that occur during operating status periods listed in paragraphs (c)(1) through (4) of this section. If any one of these four operating status periods span an entire month, then the month is treated as nonoperating and there is no compliance ratio determination.

(1) Nonoperating periods as described in paragraph (a)(2)(ii) of this section.

- (2) Initial startup periods as described in §63.2850(c)(2) or (d)(2).
- (3) Malfunction periods as described in §63.2850(e)(2).
- (4) Exempt operation periods as described in paragraph (a)(2)(v) of this section.

**§ 63.2854 How do I determine the weighted average volume fraction of HAP in the actual solvent loss?**

(a) This section describes the information and procedures you must use to determine the weighted average volume fraction of HAP in extraction solvent received for use in your vegetable oil production process. By the end of each calendar month following an operating month, determine the weighted average volume fraction of HAP in extraction solvent received since the end of the previous operating month. If you have determined the monthly weighted average volume fraction of HAP in solvent received for 12 or more operating months, then also determine an overall weighted average volume fraction of HAP in solvent received for the previous 12 operating months. Use the volume fraction of HAP determined as a 12 operating months weighted average in Equation 2 of §63.2840 to determine the compliance ratio.

(b) To determine the volume fraction of HAP in the extraction solvent determined as a 12 operating months weighted average, you must comply with paragraphs (b)(1) through (3) of this section:

(1) Record the volume fraction of each HAP comprising more than 1 percent by volume of the solvent in each delivery of solvent, including solvent recovered from off-site oil. To determine the HAP content of the material in each delivery of solvent, the reference method is EPA Method 311 of appendix A of this part. You may use EPA Method 311, an approved alternative method, or any other reasonable means for determining the HAP content. Other reasonable means of determining HAP content include, but are not limited to, a material safety data sheet or a manufacturer's certificate of analysis. A certificate of analysis is a legal and binding document provided by a solvent manufacturer. The purpose of a certificate of analysis is to list the test methods and analytical results that determine chemical properties of the solvent and the volume percentage of all HAP components present in the solvent at quantities greater than 1 percent by volume. You are not required to test the materials that you use, but the Administrator may require a test using EPA Method 311 (or an approved alternative method) to confirm the reported HAP content. However, if the results of an analysis by EPA Method 311 are different from the HAP content determined by another means, the EPA Method 311 results will govern compliance determinations.

(2) Determine the weighted average volume fraction of HAP in the extraction solvent each operating month. The weighted average volume fraction of HAP for an operating month includes all solvent received since the end of the last operating month, regardless of the operating status at the time of the delivery. Determine the monthly weighted average volume fraction of HAP by summing the products of the HAP volume fraction of each delivery and the volume of each delivery and dividing the sum by the total volume of all deliveries as expressed in Equation 1 of this section. Record the result by the end of each calendar month following an operating month. Equation 1 of this section follows:

$$\begin{array}{l} \text{Monthly Weighted} \\ \text{Average HAP Content} \\ \text{of Extraction Solvent} \\ \text{(volume fraction)} \end{array} = \frac{\sum_{i=1}^n (\text{Received}_i * \text{Content}_i)}{\text{Total Received}} \quad (\text{Eq. 1})$$

Where:

Received<sub>i</sub>= Gallons of extraction solvent received in delivery "i."

Content<sub>i</sub>= The volume fraction of HAP in extraction solvent delivery "i."

Total Received = Total gallons of extraction solvent received since the end of the previous operating month.

n = Number of extraction solvent deliveries since the end of the previous operating month.

(3) Determine the volume fraction of HAP in your extraction solvent as a 12 operating months weighted average. When your source has processed oilseed for 12 operating months, sum the products of the monthly weighted average HAP volume fraction and corresponding volume of solvent received, and divide the sum by the total volume of solvent received for the 12 operating months, as expressed by Equation 2 of this section. Record the result by the end of each calendar month following an operating month and use it in Equation 2 of §63.2840 to determine the compliance ratio. Equation 2 of this section follows:

$$\begin{array}{l} \text{12-Month Weighted} \\ \text{Average of HAP Content} \\ \text{in Solvent Received} \\ \text{(volume fraction)} \end{array} = \frac{\sum_{i=1}^{12} (\text{Received}_i * \text{Content}_i)}{\text{Total Received}} \quad (\text{Eq. 2})$$

Where:

Received<sub>i</sub> = Gallons of extraction solvent received in operating month "i" as determined in accordance with §63.2853(a)(4).

Content<sub>i</sub> = Average volume fraction of HAP in extraction solvent received in operating month "i" as determined in accordance with paragraph (b)(1) of this section.

Total Received = Total gallons of extraction solvent received during the previous 12 operating months.

#### § 63.2855 How do I determine the quantity of oilseed processed?

All oilseed measurements must be determined on an *as received* basis, as defined in §63.2872. The *as received* basis refers to the oilseed chemical and physical characteristics as initially received by the source and prior to any oilseed handling and processing. By the end of each calendar month following an operating month, you must determine the tons as received of each listed oilseed processed for the operating month. The total oilseed processed for an operating month includes the total of each oilseed processed during all normal operating periods that occur within the operating month. If you have determined the tons of oilseed processed for 12 or more operating months, then you must also determine the 12 operating months rolling sum of each type oilseed processed by summing the tons of each type of oilseed processed for the previous 12 operating months. The 12 operating months rolling sum of each type of oilseed processed is used to calculate the compliance ratio as described in §63.2840.

(a) To determine the tons as received of each type of oilseed processed at your source, follow the procedures in your plan for demonstrating compliance to determine the items in paragraphs (a)(1) through (5) of this section:

(1) *The dates that define each operating status period.* The dates that define each operating status period include the beginning date of each calendar month and the date of any change in the source operating status. If, prior to the effective date of this rule, your source determines the oilseed inventory on an accounting month rather than a calendar month basis, and you have 12 complete accounting months of approximately equal duration in a calendar year, you may substitute the accounting month time interval for the calendar month time interval. If you choose to use an accounting month rather than a calendar month, you must document this measurement frequency selection in your plan for demonstrating compliance, and you must remain on this schedule unless you request and receive written approval from the agency responsible for these NESHAP. The dates on each oilseed inventory log must be consistent with the dates recorded for the solvent inventory.

(2) *Source operating status.* You must categorize the source operation for each recorded time interval. The source operating status for each time interval recorded on the oilseed inventory for each type of oilseed

must be consistent with the operating status recorded on the solvent inventory logs as described in §63.2853(a)(2).

(3) *Measuring the beginning and ending inventory for each oilseed.* You are required to measure and record the oilseed inventory on the beginning and ending dates of each normal operating period that occurs during an operating month. An operating month is any calendar month with at least one normal operating period. You must consistently follow the procedures described in your plan for demonstrating compliance, as specified in §63.2851, to determine the oilseed inventory on an as received basis and maintain readily available records of the oilseed inventory as described by §63.2862(c)(3).

(4) *Tons of each oilseed received.* Record the type of oilseed and tons of each shipment of oilseed received and added to your on-site storage.

(5) *Oilseed inventory adjustments.* In some situations, determining the quantity of oilseed processed directly from the measured oilseed inventory and quantity of oilseed received is not an accurate estimate of the tons of oilseed processed for use in determining compliance ratios. For example, spoiled and molded oilseed removed from storage but not processed by your source will result in an overestimate of the quantity of oilseed processed. In such cases, you must adjust the oilseed inventory and provide a justification for the adjustment. Situations that may require oilseed inventory adjustments include, but are not limited to, the situations listed in paragraphs (a)(5)(i) through (v) of this section:

(i) Oilseed that mold or otherwise become unsuitable for processing.

(ii) Oilseed you sell before it enters the processing operation.

(iii) Oilseed destroyed by an event such as a process malfunction, fire, or natural disaster.

(iv) Oilseed processed through operations prior to solvent extraction such as screening, dehulling, cracking, drying, and conditioning; but that are not routed to the solvent extractor for further processing.

(v) Periodic physical measurements of inventory. For example, some sources periodically empty oilseed storage silos to physically measure the current oilseed inventory. This periodic measurement procedure typically results in a small inventory correction. The correction factor, usually less than 1 percent, may be used to make an adjustment to the source's oilseed inventory that was estimated previously with indirect measurement techniques. To make this adjustment, your plan for demonstrating compliance must provide for such an adjustment.

(b) Use Equation 1 of this section to determine the quantity of each oilseed type processed at your affected source during normal operating periods recorded within a calendar month. Equation 1 of this section follows:

$$\begin{array}{l} \text{Monthly Quantity} \\ \text{of Each Oilseed} \\ \text{Processed (tons)} \end{array} = \sum_{i=1}^n (SEED_B - SEED_E + SEED_R \pm SEED_A) \quad (Eq. 1)$$

Where:

SEED<sub>B</sub>= Tons of oilseed in the inventory at the beginning of normal operating period "i" as determined in accordance with paragraph (a)(3) of this section.

SEED<sub>E</sub>= Tons of oilseed in the inventory at the end of normal operating period "i" as determined in accordance with paragraph (a)(3) of this section.

SEED<sub>R</sub>= Tons of oilseed received during normal operating period "i" as determined in accordance with paragraph (a)(4) of this section.

SEED<sub>A</sub> = Tons of oilseed added or removed from the oilseed inventory during normal operating period "i" as determined in accordance with paragraph (a)(5) of this section.

n = Number of normal operating periods in the calendar month during which this type oilseed was processed.

(c) The quantity of each oilseed processed is the total tons of each type of listed oilseed processed during normal operating periods in the previous 12 operating months. You determine the tons of each oilseed processed by summing the monthly quantity of each oilseed processed for the previous 12 operating months. You must record the 12 operating months quantity of each type of oilseed processed by the end of each calendar month following an operating month. Use the 12 operating months quantity of each type of oilseed processed to determine the compliance ratio as described in §63.2840. The quantity of oilseed processed does not include oilseed processed during the operating status periods in paragraphs (c)(1) through (4) of this section:

(1) Nonoperating periods as described in §63.2853 (a)(2)(ii).

(2) Initial startup periods as described in §63.2850(c)(2) or (d)(2).

(3) Malfunction periods as described in §63.2850(e)(2).

(4) Exempt operation periods as described in §63.2853 (a)(2)(v).

(5) If any one of these four operating status periods span an entire calendar month, then the calendar month is treated as a nonoperating month and there is no compliance ratio determination.

#### **Notifications, Reports, and Records**

##### **§ 63.2860 What notifications must I submit and when?**

You must submit the one-time notifications listed in paragraphs (a) through (d) of this section to the responsible agency:

(a) *Initial notification for existing sources.* For an existing source, submit an initial notification to the agency responsible for these NESHAP no later than 120 days after the effective date of this subpart. In the notification, include the items in paragraphs (a)(1) through (5) of this section:

(1) The name and address of the owner or operator.

(2) The physical address of the vegetable oil production process.

(3) Identification of the relevant standard, such as the vegetable oil production NESHAP, and compliance date.

(4) A brief description of the source including the types of listed oilseeds processed, nominal operating capacity, and type of desolventizer(s) used.

(5) A statement designating the source as a major source of HAP or a demonstration that the source meets the definition of an area source. An area source is a source that is not a major source and is not collocated within a plant site with other sources that are individually or collectively a major source.

(b) *Initial notifications for new and reconstructed sources.* New or reconstructed sources must submit a series of notifications before, during, and after source construction per the schedule listed in §63.9. The information requirements for the notifications are the same as those listed in the General Provisions with the exceptions listed in paragraphs (b)(1) and (2) of this section:

(1) The application for approval of construction does not require the specific HAP emission data required in §63.5(d)(1)(ii)(H) and (iii), (d)(2) and (d)(3)(ii). The application for approval of construction would include, instead, a brief description of the source including the types of listed oilseeds processed, nominal operating capacity, and type of desolventizer(s) used.

(2) The notification of actual startup date must also include whether you have elected to operate under an initial startup period subject to §63.2850(c)(2) and provide an estimate and justification for the anticipated duration of the initial startup period.

(c) *Significant modification notifications.* Any existing or new source that plans to undergo a significant modification as defined in §63.2872 must submit two reports as described in paragraphs (c)(1) and (2) of this section:

(1) Initial notification. You must submit an initial notification to the agency responsible for these NESHAP 30 days prior to initial startup of the significantly modified source. The initial notification must demonstrate that the proposed changes qualify as a significant modification. The initial notification must include the items in paragraphs (c)(1)(i) and (ii) of this section:

(i) The expected startup date of the modified source.

(ii) A description of the significant modification including a list of the equipment that will be replaced or modified. If the significant modification involves changes other than adding or replacing extractors, desolventizer-toasters (conventional and specialty), and meal dryer-coolers, then you must also include the fixed capital cost of the new components, expressed as a percentage of the fixed capital cost to build a comparable new vegetable oil production process; supporting documentation for the cost estimate; and documentation that the proposed changes will significantly affect solvent losses.

(2) Notification of actual startup. You must submit a notification of actual startup date within 15 days after initial startup of the modified source. The notification must include the items in paragraphs (c)(2)(i) through (iv) of this section:

(i) The initial startup date of the modified source.

(ii) An indication whether you have elected to operate under an initial startup period subject to §63.2850(d)(2).

(iii) The anticipated duration of any initial startup period.

(iv) A justification for the anticipated duration of any initial startup period.

(d) *Notification of compliance status.* As an existing, new, or reconstructed source, you must submit a notification of compliance status report to the responsible agency no later than 60 days after determining your initial 12 operating months compliance ratio. If you are an existing source, you generally must submit this notification no later than 50 calendar months after the effective date of these NESHAP (36 calendar months for compliance, 12 operating months to record data, and 2 calendar months to complete the report). If you are a new or reconstructed source, the notification of compliance status is generally due no later than 20 calendar months after initial startup (6 calendar months for the initial startup period, 12 operating months to record data, and 2 calendar months to complete the report). The notification of compliance status must contain the items in paragraphs (d)(1) through (6) of this section:

(1) The name and address of the owner or operator.

(2) The physical address of the vegetable oil production process.

(3) Each listed oilseed type processed during the previous 12 operating months.

(4) Each HAP identified under §63.2854(a) as being present in concentrations greater than 1 percent by volume in each delivery of solvent received during the 12 operating months period used for the initial compliance determination.

(5) A statement designating the source as a major source of HAP or a demonstration that the source qualifies as an area source. An area source is a source that is not a major source and is not collocated within a plant site with other sources that are individually or collectively a major source.

(6) A compliance certification indicating whether the source complied with all of the requirements of this subpart throughout the 12 operating months used for the initial source compliance determination. This certification must include a certification of the items in paragraphs (d)(6)(i) through (iii) of this section:

(i) The plan for demonstrating compliance (as described in §63.2851) and SSM plan (as described in §63.2852) are complete and available on-site for inspection.

(ii) You are following the procedures described in the plan for demonstrating compliance.

(iii) The compliance ratio is less than or equal to 1.00.

**§ 63.2861 What reports must I submit and when?**

After the initial notifications, you must submit the reports in paragraphs (a) through (d) of this section to the agency responsible for these NESHAP at the appropriate time intervals:

(a) *Annual compliance certifications.* The first annual compliance certification is due 12 calendar months after you submit the notification of compliance status. Each subsequent annual compliance certification is due 12 calendar months after the previous annual compliance certification. The annual compliance certification provides the compliance status for each operating month during the 12 calendar months period ending 60 days prior to the date on which the report is due. Include the information in paragraphs (a)(1) through (6) of this section in the annual certification:

(1) The name and address of the owner or operator.

(2) The physical address of the vegetable oil production process.

(3) Each listed oilseed type processed during the 12 calendar months period covered by the report.

(4) Each HAP identified under §63.2854(a) as being present in concentrations greater than 1 percent by volume in each delivery of solvent received during the 12 calendar months period covered by the report.

(5) A statement designating the source as a major source of HAP or a demonstration that the source qualifies as an area source. An area source is a source that is not a major source and is not collocated within a plant site with other sources that are individually or collectively a major source.

(6) A compliance certification to indicate whether the source was in compliance for each compliance determination made during the 12 calendar months period covered by the report. For each such compliance determination, you must include a certification of the items in paragraphs (a)(6)(i) through (ii) of this section:

(i) You are following the procedures described in the plan for demonstrating compliance.

(ii) The compliance ratio is less than or equal to 1.00.

(b) *Deviation notification report.* Submit a deviation report for each compliance determination you make in which the compliance ratio exceeds 1.00 as determined under §63.2840(c). Submit the deviation report by the end of the month following the calendar month in which you determined the deviation. The deviation notification report must include the items in paragraphs (b)(1) through (4) of this section:

- (1) The name and address of the owner or operator.
- (2) The physical address of the vegetable oil production process.
- (3) Each listed oilseed type processed during the 12 operating months period for which you determined the deviation.
- (4) The compliance ratio comprising the deviation. You may reduce the frequency of submittal of the deviation notification report if the agency responsible for these NESHAP does not object as provided in §63.10(e)(3)(iii).

(c) *Periodic startup, shutdown, and malfunction report.* If you choose to operate your source under an initial startup period subject to §63.2850(c)(2) or (d)(2) or a malfunction period subject to §63.2850(e)(2), you must submit a periodic SSM report by the end of the calendar month following each month in which the initial startup period or malfunction period occurred. The periodic SSM report must include the items in paragraphs (c)(1) through (3) of this section:

- (1) The name, title, and signature of a source's responsible official who is certifying that the report accurately states that all actions taken during the initial startup or malfunction period were consistent with the SSM plan.
- (2) A description of events occurring during the time period, the date and duration of the events, and reason the time interval qualifies as an initial startup period or malfunction period.
- (3) An estimate of the solvent loss during the initial startup or malfunction period with supporting documentation.

(d) *Immediate SSM reports.* If you handle a SSM during an initial startup period subject to §63.2850(c)(2) or (d)(2) or a malfunction period subject to §63.2850(e)(2) differently from procedures in the SSM plan and the relevant emission requirements in §63.2840 are exceeded, then you must submit an immediate SSM report. Immediate SSM reports consist of a telephone call or facsimile transmission to the responsible agency within 2 working days after starting actions inconsistent with the SSM plan, followed by a letter within 7 working days after the end of the event. The letter must include the items in paragraphs (d)(1) through (3) of this section:

- (1) The name, title, and signature of a source's responsible official who is certifying the accuracy of the report, an explanation of the event, and the reasons for not following the SSM plan.
- (2) A description and date of the SSM event, its duration, and reason it qualifies as a SSM.
- (3) An estimate of the solvent loss for the duration of the SSM event with supporting documentation.

[66 FR 19011, Apr. 12, 2001, as amended at 67 FR 16321, Apr. 5, 2002]

#### **§ 63.2862 What records must I keep?**

- (a) You must satisfy the recordkeeping requirements of this section by the compliance date for your source specified in Table 1 of §63.2834.
- (b) Prepare a plan for demonstrating compliance (as described in §63.2851) and a SSM plan (as described in §63.2852). In these two plans, describe the procedures you will follow in obtaining and recording data, and determining compliance under normal operations or a SSM subject to the §63.2850(c)(2) or (d)(2) initial startup period or the §63.2850(e)(2) malfunction period. Complete both plans before the compliance date for your source and keep them on-site and readily available as long as the source is operational.



(c) If your source processes any listed oilseed, record the items in paragraphs (c)(1) through (5) of this section:

(1) For the solvent inventory, record the information in paragraphs (c)(1)(i) through (vii) of this section in accordance with your plan for demonstrating compliance:

(i) Dates that define each operating status period during a calendar month.

(ii) The operating status of your source such as normal operation, nonoperating, initial startup period, malfunction period, or exempt operation for each recorded time interval.

(iii) Record the gallons of extraction solvent in the inventory on the beginning and ending dates of each normal operating period.

(iv) The gallons of all extraction solvent received, purchased, and recovered during each calendar month.

(v) All extraction solvent inventory adjustments, additions or subtractions. You must document the reason for the adjustment and justify the quantity of the adjustment.

(vi) The total solvent loss for each calendar month, regardless of the source operating status.

(vii) The actual solvent loss in gallons for each operating month.

(2) For the weighted average volume fraction of HAP in the extraction solvent, you must record the items in paragraphs (c)(2)(i) through (iii) of this section:

(i) The gallons of extraction solvent received in each delivery.

(ii) The volume fraction of each HAP exceeding 1 percent by volume in each delivery of extraction solvent.

(iii) The weighted average volume fraction of HAP in extraction solvent received since the end of the last operating month as determined in accordance with §63.2854(b)(2).

(3) For each type of listed oilseed processed, record the items in paragraphs (c)(3)(i) through (vi) of this section, in accordance with your plan for demonstrating compliance:

(i) The dates that define each operating status period. These dates must be the same as the dates entered for the extraction solvent inventory.

(ii) The operating status of your source such as normal operation, nonoperating, initial startup period, malfunction period, or exempt operation for each recorded time interval. On the log for each type of listed oilseed that is not being processed during a normal operating period, you must record which type of listed oilseed is being processed in addition to the source operating status.

(iii) The oilseed inventory for the type of listed oilseed being processed on the beginning and ending dates of each normal operating period.

(iv) The tons of each type of listed oilseed received at the affected source each normal operating period.

(v) All listed oilseed inventory adjustments, additions or subtractions for normal operating periods. You must document the reason for the adjustment and justify the quantity of the adjustment.

(vi) The tons of each type of listed oilseed processed during each operating month.

(d) After your source has processed listed oilseed for 12 operating months, and you are not operating during an initial startup period as described in §63.2850(c)(2) or (d)(2), or a malfunction period as described in §63.2850(e)(2), record the items in paragraphs (d)(1) through (5) of this section by the end of the calendar month following each operating month:

(1) The 12 operating months rolling sum of the actual solvent loss in gallons as described in §63.2853(c).

(2) The weighted average volume fraction of HAP in extraction solvent received for the previous 12 operating months as described in §63.2854(b)(3).

(3) The 12 operating months rolling sum of each type of listed oilseed processed at the affected source in tons as described in §63.2855(c).

(4) A determination of the compliance ratio. Using the values from §§63.2853, 63.2854, 63.2855, and Table 1 of §63.2840, calculate the compliance ratio using Equation 2 of §63.2840.

(5) A statement of whether the source is in compliance with all of the requirements of this subpart. This includes a determination of whether you have met all of the applicable requirements in §63.2850.

(e) For each SSM event subject to an initial startup period as described in §63.2850(c)(2) or (d)(2), or a malfunction period as described in §63.2850(e)(2), record the items in paragraphs (e)(1) through (3) of this section by the end of the calendar month following each month in which the initial startup period or malfunction period occurred:

(1) A description and date of the SSM event, its duration, and reason it qualifies as an initial startup or malfunction.

(2) An estimate of the solvent loss in gallons for the duration of the initial startup or malfunction period with supporting documentation.

(3) A checklist or other mechanism to indicate whether the SSM plan was followed during the initial startup or malfunction period.

#### **§ 63.2863 In what form and how long must I keep my records?**

(a) Your records must be in a form suitable and readily available for review in accordance with §63.10(b)(1).

(b) As specified in §63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record on-site for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, in accordance with §3.10(b)(1). You can keep the records off-site for the remaining 3 years.

#### **Other Requirements and Information**

#### **§ 63.2870 What parts of the General Provisions apply to me?**

Table 1 of this section shows which parts of the General Provisions in §§63.1 through 63.15 apply to you. Table 1 of §63.2870 follows:

**Table 1 of §63.2870—Applicability of 40 CFR Part 63, Subpart A, to 40 CFR, Part 63, Subpart GGGG**

<b>General provisions citation</b>	<b>Subject of citation</b>	<b>Brief description of requirement</b>	<b>Applies to subpart</b>	<b>Explanation</b>
§63.1	Applicability	Initial applicability determination; applicability after standard established; permit requirements; extensions; notifications	Yes	
§63.2	Definitions	Definitions for part 63 standards	Yes	Except as specifically provided in this subpart.
§63.3	Units and abbreviations	Units and abbreviations for part 63 standards	Yes	
§63.4	Prohibited activities and circumvention	Prohibited activities; compliance date; circumvention; severability	Yes	
§63.5	Construction/reconstruction	Applicability; applications; approvals	Yes	Except for subsections of §63.5 as listed below.
§63.5(c)	[Reserved]			
§63.5(d)(1)(ii)(H)	Application for approval	Type and quantity of HAP, operating parameters	No	All sources emit HAP. Subpart GGGG does not require control from specific emission points.
§63.5(d)(1)(ii)(I)	[Reserved]			
§63.5(d)(1)(iii), (d)(2), (d)(3)(ii)		Application for approval	No	The requirements of the application for approval for new, reconstructed and significantly modified sources are described in §63.2860(b) and (c) of subpart GGGG. General provision requirements for identification of HAP emission points or estimates of actual emissions are not required. Descriptions of control and methods, and the estimated and actual control efficiency of such do not apply. Requirements for describing control equipment and the estimated and actual control efficiency of such equipment apply only to control equipment to which

General provisions citation	Subject of citation	Brief description of requirement	Applies to subpart	Explanation
				the subpart GGGG requirements for quantifying.
§63.6	Applicability of General Provisions	Applicability	Yes	Except for subsections of §63.6 as listed below.
§63.6(b)(1)–(3)	Compliance dates, new and reconstructed sources		No	Section 63.2834 of subpart GGGG specifies the compliance dates for new and reconstructed sources.
§63.6(b)(6)	[Reserved]			
§63.6(c)(3)–(4)	[Reserved]			
§63.6(d)	[Reserved]			
§63.6(e)(1) through (e)(3)(ii) and §63.6(e)(3)(v) through (vii)	Operation and maintenance requirements		Yes	Minimize emissions to the extent practical.
§63.6(e)(3)(iii)	Operation and maintenance requirements		No	Minimize emissions to the extent practical
§63.6(e)(3)(iv)	Operation and maintenance requirements		No	Report SSM and in accordance with §63.2861(c) and (d).
§63.6(e)(3)(viii)	Operation and maintenance requirements		Yes	Except, report each revision to your SSM plan in accordance with §63.2861(c) rather than §63.10(d)(5) as required under §63.6(e)(3) (viii).
§63.6(e)(3)(ix)	Title V permit		Yes	
§63.6(f)–(g)	Compliance with nonopacity emission standards except during SSM	Comply with emission standards at all times except during SSM	No	Subpart GGGG does not have nonopacity requirements.
§63.6(h)	Opacity/Visible emission (VE) standards		No	Subpart GGGG has no opacity or VE standards.
§63.6(i)	Compliance extension	Procedures and criteria for responsible agency to grant compliance extension	Yes	
§63.6(j)	Presidential compliance exemption	President may exempt source category from requirement to comply with subpart	Yes	
§63.7	Performance testing requirements	Schedule, conditions, notifications and procedures	Yes	Subpart GGGG requires performance testing only if the source applies

General provisions citation	Subject of citation	Brief description of requirement	Applies to subpart	Explanation
				additional control that destroys solvent. Section 63.2850(a)(6) requires sources to follow the performance testing guidelines of the General Provisions if a control is added.
§63.8	Monitoring requirements		No	Subpart GGGG does not require monitoring other than as specified therein.
§63.9	Notification requirements	Applicability and state delegation	Yes	Except for subsections of §63.9 as listed below.
§63.9(b)(2)	Notification requirements	Initial notification requirements for existing sources	No	Section 63.2860(a) of subpart GGGG specifies the requirements of the initial notification for existing sources.
§63.9(b)(3)–(5)	Notification requirements	Notification requirement for certain new/reconstructed sources	Yes	Except the information requirements differ as described in §63.2860(b) of subpart GGGG.
§63.9(e)	Notification of performance test	Notify responsible agency 60 days ahead	Yes	Applies only if performance testing is performed.
§63.9(f)	Notification of VE/opacity observations	Notify responsible agency 30 days ahead	No	Subpart GGGG has no opacity or VE standards.
§63.9(g)	Additional notifications when using a continuous monitoring system (CMS)	Notification of performance evaluation; Notification using COMS data; notification that exceeded criterion for relative accuracy	No	Subpart GGGG has no CMS requirements.
§63.9(h)	Notification of compliance status	Contents	No	Section 63.2860(d) of subpart GGGG specifies requirements for the notification of compliance status.
§63.10	Recordkeeping/reporting	Schedule for reporting, record storage	Yes	Except for subsections of §63.10 as listed below.
§63.10(b)(2)(i)	Recordkeeping	Record SSM event	Yes	Applicable to periods when sources must implement their SSM plan as specified in subpart GGGG.

<b>General provisions citation</b>	<b>Subject of citation</b>	<b>Brief description of requirement</b>	<b>Applies to subpart</b>	<b>Explanation</b>
§63.10(b)(2)(ii)–(iii)	Recordkeeping	Malfunction of air pollution equipment	No	Applies only if air pollution control equipment has been added to the process and is necessary for the source to meet the emission limit.
§63.10(b)(2)(vi)	Recordkeeping	CMS recordkeeping	No	Subpart GGGG has no CMS requirements.
§63.10(b)(2)(viii)–(ix)	Recordkeeping	Conditions of performance test	Yes	Applies only if performance tests are performed. Subpart GGGG does not have any CMS opacity or VE observation requirements.
§63.10(b)(2)(x)–(xii)	Recordkeeping	CMS, performance testing, and opacity and VE observations recordkeeping	No	Subpart GGGG does not require CMS.
§63.10(c)	Recordkeeping	Additional CMS recordkeeping	No	Subpart GGGG does not require CMS.
§63.10(d)(2)	Reporting	Reporting performance test results	Yes	Applies only if performance testing is performed.
§63.10(d)(3)	Reporting	Reporting opacity or VE observations	No	Subpart GGGG has no opacity or VE standards.
§63.10(d)(4)	Reporting	Progress reports	Yes	Applies only if a condition of compliance extension exists.
§63.10(d)(5)	Reporting	SSM reporting	No	Section 63.2861(c) and (d) specify SSM reporting requirements.
§63.10(e)	Reporting	Additional CMS reports	No	Subpart GGGG does not require CMS.
§63.11	Control device requirements	Requirements for flares	Yes	Applies only if your source uses a flare to control solvent emissions. Subpart GGGG does not require flares.
§63.12	State authority and delegations	State authority to enforce standards	Yes	
§63.13	State/regional addresses	Addresses where reports, notifications, and requests are sent	Yes	
§63.14	Incorporation by reference	Test methods incorporated by reference	Yes	
§63.15	Availability of information	Public and	Yes	

General provisions citation	Subject of citation	Brief description of requirement	Applies to subpart	Explanation
	and confidentiality	confidential information		

[66 FR 19011, Apr. 12, 2001, as amended at 67 FR 16321, Apr. 5, 2002; 71 FR 20463, Apr. 20, 2006]

**§ 63.2871 Who implements and enforces this subpart?**

(a) This subpart can be implemented by us, the U.S. EPA, or a delegated authority such as your State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency, as well as the U.S. EPA, has the authority to implement and enforce this subpart. You should contact your U.S. EPA Regional Office to find out if this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under section 40 CFR part 63, subpart E, the authorities contained in paragraph (c) of this section are retained by the Administrator of the U.S. EPA and are not transferred to the State, local, or tribal agency.

(c) The authorities that will not be delegated to State, local, or tribal agencies are as follows:

- (1) Approval of alternative nonopacity emissions standards under §63.6(g).
- (2) Approval of alternative opacity standards under §63.6(h)(9).
- (3) Approval of major alternatives to test methods under §63.7(e)(2)(ii) and (f) and as defined in §63.90.
- (4) Approval of major alternatives to monitoring under §63.8(f) and as defined in §63.90.
- (5) Approval of major alternatives to recordkeeping and reporting under §63.10(f) and as defined in §63.90.

**§ 63.2872 What definitions apply to this subpart?**

Terms used in this subpart are defined in the sources listed:

- (a) The Clean Air Act, section 112(a).
- (b) In 40 CFR 63.2, the NESHAP General Provisions.
- (c) In this section as follows:

*Accounting month* means a time interval defined by a business firm during which corporate economic and financial factors are determined on a consistent and regular basis. An accounting month will consist of approximately 4 to 5 calendar weeks and each accounting month will be of approximate equal duration. An accounting month may not correspond exactly to a calendar month, but 12 accounting months will correspond exactly to a calendar year.

*Actual solvent loss* means the gallons of solvent lost from a source during 12 operating months as determined in accordance with §63.2853.

*Agricultural product* means any commercially grown plant or plant product.

*Allowable HAP loss* means the gallons of HAP that would have been lost from a source if the source was operating at the solvent loss factor for each listed oilseed type. The allowable HAP loss in gallons is determined by multiplying the tons of each oilseed type processed during the previous 12 operating months, as determined in accordance with §63.2855, by the corresponding oilseed solvent loss factor (gal/ton) listed in Table 1 of §63.2840, and by the dimensionless constant 0.64, and summing the result for all oilseed types processed.

*Area source* means any source that does not meet the major source definition.

*As received* is the basis upon which all oilseed measurements must be determined and refers to the oilseed chemical and physical characteristics as initially received by the source and prior to any oilseed handling and processing.

*Batch operation* means any process that operates in a manner where the addition of raw material and withdrawal of product do not occur simultaneously. Typically, raw material is added to a process, operational steps occur, and a product is removed from the process. More raw material is then added to the process and the cycle repeats.

*Calendar month* means 1 month as specified in a calendar.

*Compliance date* means the date on which monthly compliance recordkeeping begins. For existing sources, recordkeeping typically begins 3 years after the effective date of the subpart. For new and reconstructed sources, recordkeeping typically begins upon initial startup, except as noted in §63.2834.

*Compliance ratio* means a ratio of the actual HAP loss in gallons from the previous 12 operating months to an allowable HAP loss in gallons, which is determined by using oilseed solvent loss factors in Table 1 of §63.2840, the weighted average volume fraction of HAP in solvent received for the previous 12 operating months, and the tons of each type of listed oilseed processed in the previous 12 operating months. Months during which no listed oilseed is processed, or months during which the §63.2850(c)(2) or (d)(2) initial startup period or the §63.2850(e)(2) malfunction period applies, are excluded from this calculation. Equation 2 of §63.2840 is used to calculate this value. If the value is less than or equal to 1.00, the source is in compliance. If the value is greater than 1.00, the source is deviating from compliance.

*Continuous operation* means any process that adds raw material and withdraws product simultaneously. Mass, temperature, concentration and other properties typically approach steady-state conditions.

*Conventional desolventizer* means a desolventizer toaster that operates with indirect and direct-contact steam to remove solvent from the extracted meal. Oilseeds processed in a conventional desolventizer produce crude vegetable oil and crude meal products, such as animal feed.

*Corn germ dry milling* means a source that processes corn germ that has been separated from the other corn components using a "dry" process of mechanical chafing and air sifting.

*Corn germ wet milling* means a source that processes corn germ that has been separated from other corn components using a "wet" process of centrifuging a slurry steeped in a dilute sulfurous acid solution.

*Exempt period* means a period of time during which a source processes agricultural products not defined as listed oilseed.

*Extraction solvent* means an organic chemical medium used to remove oil from an oilseed. Typically, the extraction solvent is a commercial grade of hexane isomers which have an approximate HAP content of 64 percent by volume.

*Hazardous air pollutant (HAP)* means any substance or mixture of substances listed as a hazardous air pollutant under section 112(b) of the Clean Air Act, as of April 12, 2001.



*Initial startup date* means the first calendar day that a new, reconstructed or significantly modified source processes any listed oilseed.

*Initial startup period* means a period of time from the initial startup date of a new, reconstructed or significantly modified source, for which you choose to operate the source under an initial startup period subject to §63.2850(c)(2) or (d)(2). During an initial startup period, a source complies with the standards by minimizing HAP emissions to the extent practical. The initial startup period following initial startup of a new or reconstructed source may not exceed 6 calendar months. The initial startup period following a significant modification may not exceed 3 calendar months. Solvent and oilseed inventory information recorded during the initial startup period is excluded from use in any compliance ratio determinations.

*Large cottonseed plant* means a vegetable oil production process that processes 120,000 tons or more of cottonseed and other listed oilseed during all normal operating periods in a 12 operating months period used to determine compliance.

*Malfunction period* means a period of time between the beginning and end of a process malfunction and the time reasonably necessary for a source to correct the malfunction for which you choose to operate the source under a malfunction period subject to §63.2850(e)(2). This period may include the duration of an unscheduled process shutdown, continued operation during a malfunction, or the subsequent process startup after a shutdown resulting from a malfunction. During a malfunction period, a source complies with the standards by minimizing HAP emissions to the extent practical. Therefore, solvent and oilseed inventory information recorded during a malfunction period is excluded from use in any compliance ratio determinations.

*Mechanical extraction* means removing vegetable oil from oilseeds using only mechanical devices such as presses or screws that physically force the oil from the oilseed. Mechanical extraction techniques use no organic solvents to remove oil from an oilseed.

*Nonoperating period* means any period of time in which a source processes no agricultural product. This operating status does not apply during any period in which the source operates under an initial startup period as described in §63.2850(c)(2) or (d)(2), or a malfunction period, as described in §63.2850(e)(2).

*Normal operating period* means any period of time in which a source processes a listed oilseed that is not categorized as an initial startup period as described in §63.2850(c)(2) or (d)(2), or a malfunction period, as described in §63.2850(e)(2). At the beginning and ending dates of a normal operating period, solvent and oilseed inventory information is recorded and included in the compliance ratio determination.

*Oilseed or listed oilseed* means the following agricultural products: corn germ, cottonseed, flax, peanut, rapeseed (for example, canola), safflower, soybean, and sunflower.

*Oilseed solvent loss factor* means a ratio expressed as gallons of solvent loss per ton of oilseed processed. The solvent loss factors are presented in Table 1 of §63.2840 and are used to determine the allowable HAP loss.

*Operating month* means any calendar or accounting month in which a source processes any quantity of listed oilseed, excluding any entire calendar or accounting month in which the source operated under an initial startup period as described in §63.2850(c)(2) or (d)(2), or a malfunction period as described in §63.2850(e)(2). An operating month may include time intervals characterized by several types of operating status. However, an operating month must have at least one normal operating period.

*Significant modification* means the addition of new equipment or the modification of existing equipment that:

- (1) Significantly affects solvent losses from your vegetable oil production process;
- (2) The fixed capital cost of the new components represents a significant percentage of the fixed capital cost of building a comparable new vegetable oil production process;

(3) The fixed capital cost of the new equipment does not constitute reconstruction as defined in §63.2; and

(4) Examples of significant modifications include replacement of or major changes to solvent recovery equipment such as extractors, desolventizer-toasters/dryer-coolers, flash desolventizers, and distillation equipment associated with the mineral oil system, and equipment affecting desolventizing efficiency and steady-state operation of your vegetable oil production process such as flaking mills, oilseed heating and conditioning equipment, and cracking mills.

*Small cottonseed plant* means a vegetable oil production process that processes less than 120,000 tons of cottonseed and other listed oilseed during all normal operating periods in a 12 operating months period used to determine compliance.

*Solvent extraction* means removing vegetable oil from listed oilseed using an organic solvent in a direct-contact system.

*Solvent working capacity* means the volume of extraction solvent normally retained in solvent recovery equipment. Examples include components such as the solvent extractor, desolventizer-toaster, solvent storage and working tanks, mineral oil absorption system, condensers, and oil/solvent distillation system.

*Specialty desolventizer* means a desolventizer that removes excess solvent from soybean meal using vacuum conditions, energy from superheated solvent vapors, or reduced operating conditions (e.g., temperature) as compared to the typical operation of a conventional desolventizer. Soybeans processed in a specialty desolventizer result in high-protein vegetable meal products for human and animal consumption, such as calf milk replacement products and meat extender products.

*Vegetable oil production process* means the equipment comprising a continuous process for producing crude vegetable oil and meal products, including specialty soybean products, in which oil is removed from listed oilseeds through direct contact with an organic solvent. Process equipment typically includes the following components: oilseed preparation operations (including conditioning, drying, dehulling, and cracking), solvent extractors, desolventizer-toasters, meal dryers, meal coolers, meal conveyor systems, oil distillation units, solvent evaporators and condensers, solvent recovery system (also referred to as a mineral oil absorption system), vessels storing solvent-laden materials, and crude meal packaging and storage vessels. A vegetable oil production process does not include vegetable oil refining operations (including operations such as bleaching, hydrogenation, and deodorizing) and operations that engage in additional chemical treatment of crude soybean meals produced in specialty desolventizer units (including operations such as soybean isolate production).

[66 FR 19011, Apr. 12, 2001, as amended at 71 FR 20464, Apr. 20, 2006]

## Attachment D

Cargill, Inc. - Soybean Processing Division  
1502 Wabash Avenue, Lafayette, IN 47905

### Title 40: Protection of Environment

#### PART 63—NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS FOR SOURCE CATEGORIES (CONTINUED)

##### Subpart ZZZZ—National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

SOURCE: 69 FR 33506, June 15, 2004, unless otherwise noted.

#### What This Subpart Covers

##### § 63.6580 What is the purpose of subpart ZZZZ?

Subpart ZZZZ establishes national emission limitations and operating limitations for hazardous air pollutants (HAP) emitted from stationary reciprocating internal combustion engines (RICE) located at major and area sources of HAP emissions. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emission limitations and operating limitations.

[73 FR 3603, Jan. 18, 2008]

##### § 63.6585 Am I subject to this subpart?

You are subject to this subpart if you own or operate a stationary RICE at a major or area source of HAP emissions, except if the stationary RICE is being tested at a stationary RICE test cell/stand.

- (a) A stationary RICE is any internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work and which is not mobile. Stationary RICE differ from mobile RICE in that a stationary RICE is not a non-road engine as defined at 40 CFR 1068.30, and is not used to propel a motor vehicle or a vehicle used solely for competition.
- (b) A major source of HAP emissions is a plant site that emits or has the potential to emit any single HAP at a rate of 10 tons (9.07 megagrams) or more per year or any combination of HAP at a rate of 25 tons (22.68 megagrams) or more per year, except that for oil and gas production facilities, a major source of HAP emissions is determined for each surface site.
- (c) An area source of HAP emissions is a source that is not a major source.
- (d) If you are an owner or operator of an area source subject to this subpart, your status as an entity subject to a standard or other requirements under this subpart does not subject you to the obligation to obtain a permit under 40 CFR part 70 or 71, provided you are not required to obtain a permit under 40 CFR 70.3(a) or 40 CFR 71.3(a) for a reason other than your status as an area source under this subpart. Notwithstanding the previous sentence, you must continue to comply with the provisions of this subpart as applicable.
- (e) If you are an owner or operator of a stationary RICE used for national security purposes, you may be eligible to request an exemption from the requirements of this subpart as described in 40 CFR part 1068, subpart C.

(f) The emergency stationary RICE listed in paragraphs (f)(1) through (3) of this section are not subject to this subpart. The stationary RICE must meet the definition of an emergency stationary RICE in § 63.6675, which includes operating according to the provisions specified in § 63.6640(f).

(1) Existing residential emergency stationary RICE located at an area source of HAP emissions that do not operate or are not contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in § 63.6640(f)(2)(ii) and (iii) and that do not operate for the purpose specified in § 63.6640(f)(4)(ii).

(2) Existing commercial emergency stationary RICE located at an area source of HAP emissions that do not operate or are not contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in § 63.6640(f)(2)(ii) and (iii) and that do not operate for the purpose specified in § 63.6640(f)(4)(ii).

(3) Existing institutional emergency stationary RICE located at an area source of HAP emissions that do not operate or are not contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in § 63.6640(f)(2)(ii) and (iii) and that do not operate for the purpose specified in § 63.6640(f)(4)(ii).

[69 FR 33506, June 15, 2004, as amended at 73 FR 3603, Jan. 18, 2008; 78 FR 6700, Jan. 30, 2013]

#### **§ 63.6590 What parts of my plant does this subpart cover?**

This subpart applies to each affected source.

(a) *Affected source.* An affected source is any existing, new, or reconstructed stationary RICE located at a major or area source of HAP emissions, excluding stationary RICE being tested at a stationary RICE test cell/stand.

(1) *Existing stationary RICE.*

(i) For stationary RICE with a site rating of more than 500 brake horsepower (HP) located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before December 19, 2002.

(ii) For stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.

(iii) For stationary RICE located at an area source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.

(iv) A change in ownership of an existing stationary RICE does not make that stationary RICE a new or reconstructed stationary RICE.

(2) *New stationary RICE.* (i) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions is new if you commenced construction of the stationary RICE on or after December 19, 2002.

(ii) A stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.

(iii) A stationary RICE located at an area source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.

(3) *Reconstructed stationary RICE.* (i) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions is reconstructed if you meet the definition of reconstruction in § 63.2 and reconstruction is commenced on or after December 19, 2002.

(ii) A stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions is reconstructed if you meet the definition of reconstruction in § 63.2 and reconstruction is commenced on or after June 12, 2006.

(iii) A stationary RICE located at an area source of HAP emissions is reconstructed if you meet the definition of reconstruction in § 63.2 and reconstruction is commenced on or after June 12, 2006.

(b) *Stationary RICE subject to limited requirements.* (1) An affected source which meets either of the criteria in paragraphs (b)(1)(i) through (ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of § 63.6645(f).

(i) The stationary RICE is a new or reconstructed emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions that does not operate or is not contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in § 63.6640(f)(2)(ii) and (iii).

(ii) The stationary RICE is a new or reconstructed limited use stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.

(2) A new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis must meet the initial notification requirements of § 63.6645(f) and the requirements of §§ 63.6625(c), 63.6650(g), and 63.6655(c). These stationary RICE do not have to meet the emission limitations and operating limitations of this subpart.

(3) The following stationary RICE do not have to meet the requirements of this subpart and of subpart A of this part, including initial notification requirements:

(i) Existing spark ignition 2 stroke lean burn (2SLB) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;

(ii) Existing spark ignition 4 stroke lean burn (4SLB) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;

(iii) Existing emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions that does not operate or is not contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in § 63.6640(f)(2)(ii) and (iii).

(iv) Existing limited use stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;

(v) Existing stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis;

(c) *Stationary RICE subject to Regulations under 40 CFR Part 60.* An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines. No further requirements apply for such engines under this part.

- (1) A new or reconstructed stationary RICE located at an area source;
- (2) A new or reconstructed 2SLB stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;
- (3) A new or reconstructed 4SLB stationary RICE with a site rating of less than 250 brake HP located at a major source of HAP emissions;
- (4) A new or reconstructed spark ignition 4 stroke rich burn (4SRB) stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;
- (5) A new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis;
- (6) A new or reconstructed emergency or limited use stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;
- (7) A new or reconstructed compression ignition (CI) stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008; 75 FR 9674, Mar. 3, 2010; 75 FR 37733, June 30, 2010; 75 FR 51588, Aug. 20, 2010; 78 FR 6700, Jan. 30, 2013]

#### **§ 63.6595 When do I have to comply with this subpart?**

(a) *Affected sources.* (1) If you have an existing stationary RICE, excluding existing non-emergency CI stationary RICE, with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the applicable emission limitations, operating limitations and other requirements no later than June 15, 2007. If you have an existing non-emergency CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, an existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or an existing stationary CI RICE located at an area source of HAP emissions, you must comply with the applicable emission limitations, operating limitations, and other requirements no later than May 3, 2013. If you have an existing stationary SI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or an existing stationary SI RICE located at an area source of HAP emissions, you must comply with the applicable emission limitations, operating limitations, and other requirements no later than October 19, 2013.

(2) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions before August 16, 2004, you must comply with the applicable emission limitations and operating limitations in this subpart no later than August 16, 2004.

(3) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions after August 16, 2004, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(4) If you start up your new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions before January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart no later than January 18, 2008.

(5) If you start up your new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions after January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(6) If you start up your new or reconstructed stationary RICE located at an area source of HAP emissions before January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart no later than January 18, 2008.

(7) If you start up your new or reconstructed stationary RICE located at an area source of HAP emissions after January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(b) *Area sources that become major sources.* If you have an area source that increases its emissions or its potential to emit such that it becomes a major source of HAP, the compliance dates in paragraphs (b)(1) and (2) of this section apply to you.

(1) Any stationary RICE for which construction or reconstruction is commenced after the date when your area source becomes a major source of HAP must be in compliance with this subpart upon startup of your affected source.

(2) Any stationary RICE for which construction or reconstruction is commenced before your area source becomes a major source of HAP must be in compliance with the provisions of this subpart that are applicable to RICE located at major sources within 3 years after your area source becomes a major source of HAP.

(c) If you own or operate an affected source, you must meet the applicable notification requirements in § 63.6645 and in 40 CFR part 63, subpart A.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008; 75 FR 9675, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010; 78 FR 6701, Jan. 30, 2013]

## **Emission and Operating Limitations**

### **§ 63.6600 What emission limitations and operating limitations must I meet if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?**

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in § 63.6620 and Table 4 to this subpart.

(a) If you own or operate an existing, new, or reconstructed spark ignition 4SRB stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 1a to this subpart and the operating limitations in Table 1b to this subpart which apply to you.

(b) If you own or operate a new or reconstructed 2SLB stationary RICE with a site rating of more than 500 brake HP located at major source of HAP emissions, a new or reconstructed 4SLB stationary RICE with a

site rating of more than 500 brake HP located at major source of HAP emissions, or a new or reconstructed CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 2a to this subpart and the operating limitations in Table 2b to this subpart which apply to you.

(c) If you own or operate any of the following stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the emission limitations in Tables 1a, 2a, 2c, and 2d to this subpart or operating limitations in Tables 1b and 2b to this subpart: an existing 2SLB stationary RICE; an existing 4SLB stationary RICE; a stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis; an emergency stationary RICE; or a limited use stationary RICE.

(d) If you own or operate an existing non-emergency stationary CI RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 2c to this subpart and the operating limitations in Table 2b to this subpart which apply to you.

[73 FR 3605, Jan. 18, 2008, as amended at 75 FR 9675, Mar. 3, 2010]

**§ 63.6601 What emission limitations must I meet if I own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 brake HP and less than or equal to 500 brake HP located at a major source of HAP emissions?**

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in § 63.6620 and Table 4 to this subpart. If you own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at major source of HAP emissions manufactured on or after January 1, 2008, you must comply with the emission limitations in Table 2a to this subpart and the operating limitations in Table 2b to this subpart which apply to you.

[73 FR 3605, Jan. 18, 2008, as amended at 75 FR 9675, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010]

**§ 63.6602 What emission limitations and other requirements must I meet if I own or operate an existing stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions?**

If you own or operate an existing stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations and other requirements in Table 2c to this subpart which apply to you. Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in § 63.6620 and Table 4 to this subpart.

[78 FR 6701, Jan. 30, 2013]

**§ 63.6603 What emission limitations, operating limitations, and other requirements must I meet if I own or operate an existing stationary RICE located at an area source of HAP emissions?**

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in § 63.6620 and Table 4 to this subpart.

(a) If you own or operate an existing stationary RICE located at an area source of HAP emissions, you must comply with the requirements in Table 2d to this subpart and the operating limitations in Table 2b to this subpart that apply to you.



(b) If you own or operate an existing stationary non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP that meets either paragraph (b)(1) or (2) of this section, you do not have to meet the numerical CO emission limitations specified in Table 2d of this subpart. Existing stationary non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP that meet either paragraph (b)(1) or (2) of this section must meet the management practices that are shown for stationary non-emergency CI RICE with a site rating of less than or equal to 300 HP in Table 2d of this subpart.

(1) The area source is located in an area of Alaska that is not accessible by the Federal Aid Highway System (FAHS).

(2) The stationary RICE is located at an area source that meets paragraphs (b)(2)(i), (ii), and (iii) of this section.

(i) The only connection to the FAHS is through the Alaska Marine Highway System (AMHS), or the stationary RICE operation is within an isolated grid in Alaska that is not connected to the statewide electrical grid referred to as the Alaska Railbelt Grid.

(ii) At least 10 percent of the power generated by the stationary RICE on an annual basis is used for residential purposes.

(iii) The generating capacity of the area source is less than 12 megawatts, or the stationary RICE is used exclusively for backup power for renewable energy.

(c) If you own or operate an existing stationary non-emergency CI RICE with a site rating of more than 300 HP located on an offshore vessel that is an area source of HAP and is a nonroad vehicle that is an Outer Continental Shelf (OCS) source as defined in 40 CFR 55.2, you do not have to meet the numerical CO emission limitations specified in Table 2d of this subpart. You must meet all of the following management practices:

(1) Change oil every 1,000 hours of operation or annually, whichever comes first. Sources have the option to utilize an oil analysis program as described in § 63.6625(i) in order to extend the specified oil change requirement.

(2) Inspect and clean air filters every 750 hours of operation or annually, whichever comes first, and replace as necessary.

(3) Inspect fuel filters and belts, if installed, every 750 hours of operation or annually, whichever comes first, and replace as necessary.

(4) Inspect all flexible hoses every 1,000 hours of operation or annually, whichever comes first, and replace as necessary.

(d) If you own or operate an existing non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP emissions that is certified to the Tier 1 or Tier 2 emission standards in Table 1 of 40 CFR 89.112 and that is subject to an enforceable state or local standard that requires the engine to be replaced no later than June 1, 2018, you may until January 1, 2015, or 12 years after the installation date of the engine (whichever is later), but not later than June 1, 2018, choose to comply with the management practices that are shown for stationary non-emergency CI RICE with a site rating of less than or equal to 300 HP in Table 2d of this subpart instead of the applicable emission limitations in Table 2d, operating limitations in Table 2b, and crankcase ventilation system requirements in § 63.6625(g). You must comply with the emission limitations in Table 2d and operating limitations in Table 2b that apply for non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP

emissions by January 1, 2015, or 12 years after the installation date of the engine (whichever is later), but not later than June 1, 2018. You must also comply with the crankcase ventilation system requirements in § 63.6625(g) by January 1, 2015, or 12 years after the installation date of the engine (whichever is later), but not later than June 1, 2018.

(e) If you own or operate an existing non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP emissions that is certified to the Tier 3 (Tier 2 for engines above 560 kilowatt (kW)) emission standards in Table 1 of 40 CFR 89.112, you may comply with the requirements under this part by meeting the requirements for Tier 3 engines (Tier 2 for engines above 560 kW) in 40 CFR part 60 subpart IIII instead of the emission limitations and other requirements that would otherwise apply under this part for existing non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP emissions.

(f) An existing non-emergency SI 4SLB and 4SRB stationary RICE with a site rating of more than 500 HP located at area sources of HAP must meet the definition of remote stationary RICE in § 63.6675 on the initial compliance date for the engine, October 19, 2013, in order to be considered a remote stationary RICE under this subpart. Owners and operators of existing non-emergency SI 4SLB and 4SRB stationary RICE with a site rating of more than 500 HP located at area sources of HAP that meet the definition of remote stationary RICE in § 63.6675 of this subpart as of October 19, 2013 must evaluate the status of their stationary RICE every 12 months. Owners and operators must keep records of the initial and annual evaluation of the status of the engine. If the evaluation indicates that the stationary RICE no longer meets the definition of remote stationary RICE in § 63.6675 of this subpart, the owner or operator must comply with all of the requirements for existing non-emergency SI 4SLB and 4SRB stationary RICE with a site rating of more than 500 HP located at area sources of HAP that are not remote stationary RICE within 1 year of the evaluation.

[75 FR 9675, Mar. 3, 2010, as amended at 75 FR 51589, Aug. 20, 2010; 76 FR 12866, Mar. 9, 2011; 78 FR 6701, Jan. 30, 2013]

#### **§ 63.6604 What fuel requirements must I meet if I own or operate a stationary CI RICE?**

(a) If you own or operate an existing non-emergency, non-black start CI stationary RICE with a site rating of more than 300 brake HP with a displacement of less than 30 liters per cylinder that uses diesel fuel, you must use diesel fuel that meets the requirements in 40 CFR 80.510(b) for nonroad diesel fuel.

(b) Beginning January 1, 2015, if you own or operate an existing emergency CI stationary RICE with a site rating of more than 100 brake HP and a displacement of less than 30 liters per cylinder that uses diesel fuel and operates or is contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in § 63.6640(f)(2)(ii) and (iii) or that operates for the purpose specified in § 63.6640(f)(4)(ii), you must use diesel fuel that meets the requirements in 40 CFR 80.510(b) for nonroad diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to January 1, 2015, may be used until depleted.

(c) Beginning January 1, 2015, if you own or operate a new emergency CI stationary RICE with a site rating of more than 500 brake HP and a displacement of less than 30 liters per cylinder located at a major source of HAP that uses diesel fuel and operates or is contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in § 63.6640(f)(2)(ii) and (iii), you must use diesel fuel that meets the requirements in 40 CFR 80.510(b) for nonroad diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to January 1, 2015, may be used until depleted.

(d) Existing CI stationary RICE located in Guam, American Samoa, the Commonwealth of the Northern Mariana Islands, at area sources in areas of Alaska that meet either § 63.6603(b)(1) or § 63.6603(b)(2), or are on offshore vessels that meet § 63.6603(c) are exempt from the requirements of this section.

[78 FR 6702, Jan. 30, 2013]

### **General Compliance Requirements**

#### **§ 63.6605 What are my general requirements for complying with this subpart?**

(a) You must be in compliance with the emission limitations, operating limitations, and other requirements in this subpart that apply to you at all times.

(b) At all times you must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.

[75 FR 9675, Mar. 3, 2010, as amended at 78 FR 6702, Jan. 30, 2013]

### **Testing and Initial Compliance Requirements**

#### **§ 63.6610 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?**

If you own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions you are subject to the requirements of this section.

(a) You must conduct the initial performance test or other initial compliance demonstrations in Table 4 to this subpart that apply to you within 180 days after the compliance date that is specified for your stationary RICE in § 63.6595 and according to the provisions in § 63.7(a)(2).

(b) If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004 and own or operate stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must demonstrate initial compliance with either the proposed emission limitations or the promulgated emission limitations no later than February 10, 2005 or no later than 180 days after startup of the source, whichever is later, according to § 63.7(a)(2)(ix).

(c) If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004 and own or operate stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, and you chose to comply with the proposed emission limitations when demonstrating initial compliance, you must conduct a second performance test to demonstrate compliance with the promulgated emission limitations by December 13, 2007 or after startup of the source, whichever is later, according to § 63.7(a)(2)(ix).

(d) An owner or operator is not required to conduct an initial performance test on units for which a performance test has been previously conducted, but the test must meet all of the conditions described in paragraphs (d)(1) through (5) of this section.

(1) The test must have been conducted using the same methods specified in this subpart, and these methods must have been followed correctly.

- (2) The test must not be older than 2 years.
- (3) The test must be reviewed and accepted by the Administrator.
- (4) Either no process or equipment changes must have been made since the test was performed, or the owner or operator must be able to demonstrate that the results of the performance test, with or without adjustments, reliably demonstrate compliance despite process or equipment changes.
- (5) The test must be conducted at any load condition within plus or minus 10 percent of 100 percent load.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3605, Jan. 18, 2008]

**§ 63.6611 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a new or reconstructed 4SLB SI stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions?**

If you own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions, you must conduct an initial performance test within 240 days after the compliance date that is specified for your stationary RICE in § 63.6595 and according to the provisions specified in Table 4 to this subpart, as appropriate.

[73 FR 3605, Jan. 18, 2008, as amended at 75 FR 51589, Aug. 20, 2010]

**§ 63.6612 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate an existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing stationary RICE located at an area source of HAP emissions?**

If you own or operate an existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing stationary RICE located at an area source of HAP emissions you are subject to the requirements of this section.

(a) You must conduct any initial performance test or other initial compliance demonstration according to Tables 4 and 5 to this subpart that apply to you within 180 days after the compliance date that is specified for your stationary RICE in § 63.6595 and according to the provisions in § 63.7(a)(2).

(b) An owner or operator is not required to conduct an initial performance test on a unit for which a performance test has been previously conducted, but the test must meet all of the conditions described in paragraphs (b)(1) through (4) of this section.

(1) The test must have been conducted using the same methods specified in this subpart, and these methods must have been followed correctly.

(2) The test must not be older than 2 years.

(3) The test must be reviewed and accepted by the Administrator.

(4) Either no process or equipment changes must have been made since the test was performed, or the owner or operator must be able to demonstrate that the results of the performance test, with or without adjustments, reliably demonstrate compliance despite process or equipment changes.

[75 FR 9676, Mar. 3, 2010, as amended at 75 FR 51589, Aug. 20, 2010]

**§ 63.6615 When must I conduct subsequent performance tests?**

If you must comply with the emission limitations and operating limitations, you must conduct subsequent performance tests as specified in Table 3 of this subpart.

**§ 63.6620 What performance tests and other procedures must I use?**

(a) You must conduct each performance test in Tables 3 and 4 of this subpart that applies to you.

(b) Each performance test must be conducted according to the requirements that this subpart specifies in Table 4 to this subpart. If you own or operate a non-operational stationary RICE that is subject to performance testing, you do not need to start up the engine solely to conduct the performance test. Owners and operators of a non-operational engine can conduct the performance test when the engine is started up again. The test must be conducted at any load condition within plus or minus 10 percent of 100 percent load for the stationary RICE listed in paragraphs (b)(1) through (4) of this section.

(1) Non-emergency 4SRB stationary RICE with a site rating of greater than 500 brake HP located at a major source of HAP emissions.

(2) New non-emergency 4SLB stationary RICE with a site rating of greater than or equal to 250 brake HP located at a major source of HAP emissions.

(3) New non-emergency 2SLB stationary RICE with a site rating of greater than 500 brake HP located at a major source of HAP emissions.

(4) New non-emergency CI stationary RICE with a site rating of greater than 500 brake HP located at a major source of HAP emissions.

(c) [Reserved]

(d) You must conduct three separate test runs for each performance test required in this section, as specified in § 63.7(e)(3). Each test run must last at least 1 hour, unless otherwise specified in this subpart.

(e)(1) You must use Equation 1 of this section to determine compliance with the percent reduction requirement:

$$\frac{C_i - C_o}{C_i} \times 100 = R \quad (\text{Eq. 1})$$

Where:

$C_i$  = concentration of carbon monoxide (CO), total hydrocarbons (THC), or formaldehyde at the control device inlet,

$C_o$  = concentration of CO, THC, or formaldehyde at the control device outlet, and

R = percent reduction of CO, THC, or formaldehyde emissions.

(2) You must normalize the CO, THC, or formaldehyde concentrations at the inlet and outlet of the control device to a dry basis and to 15 percent oxygen, or an equivalent percent carbon dioxide ( $\text{CO}_2$ ). If

pollutant concentrations are to be corrected to 15 percent oxygen and CO<sub>2</sub> concentration is measured in lieu of oxygen concentration measurement, a CO<sub>2</sub> correction factor is needed. Calculate the CO<sub>2</sub> correction factor as described in paragraphs (e)(2)(i) through (iii) of this section.

(i) Calculate the fuel-specific F<sub>o</sub> value for the fuel burned during the test using values obtained from Method 19, Section 5.2, and the following equation:

$$F_o = \frac{0.209 F_d}{F_c} \quad (\text{Eq. 2})$$

Where:

F<sub>o</sub> = Fuel factor based on the ratio of oxygen volume to the ultimate CO<sub>2</sub> volume produced by the fuel at zero percent excess air.

0.209 = Fraction of air that is oxygen, percent/100.

F<sub>d</sub> = Ratio of the volume of dry effluent gas to the gross calorific value of the fuel from Method 19, dsm<sup>3</sup> /J (dscf/10<sup>6</sup> Btu).

F<sub>c</sub> = Ratio of the volume of CO<sub>2</sub> produced to the gross calorific value of the fuel from Method 19, dsm<sup>3</sup> /J (dscf/10<sup>6</sup> Btu)

(ii) Calculate the CO<sub>2</sub> correction factor for correcting measurement data to 15 percent O<sub>2</sub>, as follows:

$$X_{CO_2} = \frac{5.9}{F_o} \quad (\text{Eq. 3})$$

Where:

X<sub>CO<sub>2</sub></sub> = CO<sub>2</sub> correction factor, percent.

5.9 = 20.9 percent O<sub>2</sub> —15 percent O<sub>2</sub>, the defined O<sub>2</sub> correction value, percent.

(iii) Calculate the CO, THC, and formaldehyde gas concentrations adjusted to 15 percent O<sub>2</sub> using CO<sub>2</sub> as follows:

$$C_{adj} = C_d \frac{X_{CO_2}}{\%CO_2} \quad (\text{Eq. 4})$$

Where:

C<sub>adj</sub> = Calculated concentration of CO, THC, or formaldehyde adjusted to 15 percent O<sub>2</sub>.

C<sub>d</sub> = Measured concentration of CO, THC, or formaldehyde, uncorrected.

X<sub>CO<sub>2</sub></sub> = CO<sub>2</sub> correction factor, percent.

%CO<sub>2</sub> = Measured CO<sub>2</sub> concentration measured, dry basis, percent.

(f) If you comply with the emission limitation to reduce CO and you are not using an oxidation catalyst, if you comply with the emission limitation to reduce formaldehyde and you are not using NSCR, or if you comply with the emission limitation to limit the concentration of formaldehyde in the stationary RICE exhaust and you are not using an oxidation catalyst or NSCR, you must petition the Administrator for operating limitations to be established during the initial performance test and continuously monitored thereafter; or for approval of no operating limitations. You must not conduct the initial performance test until after the petition has been approved by the Administrator.

(g) If you petition the Administrator for approval of operating limitations, your petition must include the information described in paragraphs (g)(1) through (5) of this section.

(1) Identification of the specific parameters you propose to use as operating limitations;

(2) A discussion of the relationship between these parameters and HAP emissions, identifying how HAP emissions change with changes in these parameters, and how limitations on these parameters will serve to limit HAP emissions;

(3) A discussion of how you will establish the upper and/or lower values for these parameters which will establish the limits on these parameters in the operating limitations;

(4) A discussion identifying the methods you will use to measure and the instruments you will use to monitor these parameters, as well as the relative accuracy and precision of these methods and instruments; and

(5) A discussion identifying the frequency and methods for recalibrating the instruments you will use for monitoring these parameters.

(h) If you petition the Administrator for approval of no operating limitations, your petition must include the information described in paragraphs (h)(1) through (7) of this section.

(1) Identification of the parameters associated with operation of the stationary RICE and any emission control device which could change intentionally ( e.g., operator adjustment, automatic controller adjustment, etc.) or unintentionally ( e.g., wear and tear, error, etc.) on a routine basis or over time;

(2) A discussion of the relationship, if any, between changes in the parameters and changes in HAP emissions;

(3) For the parameters which could change in such a way as to increase HAP emissions, a discussion of whether establishing limitations on the parameters would serve to limit HAP emissions;

(4) For the parameters which could change in such a way as to increase HAP emissions, a discussion of how you could establish upper and/or lower values for the parameters which would establish limits on the parameters in operating limitations;

(5) For the parameters, a discussion identifying the methods you could use to measure them and the instruments you could use to monitor them, as well as the relative accuracy and precision of the methods and instruments;

(6) For the parameters, a discussion identifying the frequency and methods for recalibrating the instruments you could use to monitor them; and

(7) A discussion of why, from your point of view, it is infeasible or unreasonable to adopt the parameters as operating limitations.

(i) The engine percent load during a performance test must be determined by documenting the calculations, assumptions, and measurement devices used to measure or estimate the percent load in a specific application. A written report of the average percent load determination must be included in the notification of compliance status. The following information must be included in the written report: the engine model number, the engine manufacturer, the year of purchase, the manufacturer's site-rated brake horsepower, the ambient temperature, pressure, and humidity during the performance test, and all assumptions that were made to estimate or calculate percent load during the performance test must be

clearly explained. If measurement devices such as flow meters, kilowatt meters, beta analyzers, stain gauges, etc. are used, the model number of the measurement device, and an estimate of its accurate in percentage of true value must be provided.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9676, Mar. 3, 2010; 78 FR 6702, Jan. 30, 2013]

**§ 63.6625 What are my monitoring, installation, collection, operation, and maintenance requirements?**

(a) If you elect to install a CEMS as specified in Table 5 of this subpart, you must install, operate, and maintain a CEMS to monitor CO and either O<sub>2</sub> or CO<sub>2</sub> according to the requirements in paragraphs (a)(1) through (4) of this section. If you are meeting a requirement to reduce CO emissions, the CEMS must be installed at both the inlet and outlet of the control device. If you are meeting a requirement to limit the concentration of CO, the CEMS must be installed at the outlet of the control device.

(1) Each CEMS must be installed, operated, and maintained according to the applicable performance specifications of 40 CFR part 60, appendix B.

(2) You must conduct an initial performance evaluation and an annual relative accuracy test audit (RATA) of each CEMS according to the requirements in § 63.8 and according to the applicable performance specifications of 40 CFR part 60, appendix B as well as daily and periodic data quality checks in accordance with 40 CFR part 60, appendix F, procedure 1.

(3) As specified in § 63.8(c)(4)(ii), each CEMS must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period. You must have at least two data points, with each representing a different 15-minute period, to have a valid hour of data.

(4) The CEMS data must be reduced as specified in § 63.8(g)(2) and recorded in parts per million or parts per billion (as appropriate for the applicable limitation) at 15 percent oxygen or the equivalent CO<sub>2</sub> concentration.

(b) If you are required to install a continuous parameter monitoring system (CPMS) as specified in Table 5 of this subpart, you must install, operate, and maintain each CPMS according to the requirements in paragraphs (b)(1) through (6) of this section. For an affected source that is complying with the emission limitations and operating limitations on March 9, 2011, the requirements in paragraph (b) of this section are applicable September 6, 2011.

(1) You must prepare a site-specific monitoring plan that addresses the monitoring system design, data collection, and the quality assurance and quality control elements outlined in paragraphs (b)(1)(i) through (v) of this section and in § 63.8(d). As specified in § 63.8(f)(4), you may request approval of monitoring system quality assurance and quality control procedures alternative to those specified in paragraphs (b)(1) through (5) of this section in your site-specific monitoring plan.

(i) The performance criteria and design specifications for the monitoring system equipment, including the sample interface, detector signal analyzer, and data acquisition and calculations;

(ii) Sampling interface ( e.g., thermocouple) location such that the monitoring system will provide representative measurements;

(iii) Equipment performance evaluations, system accuracy audits, or other audit procedures;

(iv) Ongoing operation and maintenance procedures in accordance with provisions in § 63.8(c)(1)(ii) and (c)(3); and



(v) Ongoing reporting and recordkeeping procedures in accordance with provisions in § 63.10(c), (e)(1), and (e)(2)(i).

(2) You must install, operate, and maintain each CPMS in continuous operation according to the procedures in your site-specific monitoring plan.

(3) The CPMS must collect data at least once every 15 minutes (see also § 63.6635).

(4) For a CPMS for measuring temperature range, the temperature sensor must have a minimum tolerance of 2.8 degrees Celsius (5 degrees Fahrenheit) or 1 percent of the measurement range, whichever is larger.

(5) You must conduct the CPMS equipment performance evaluation, system accuracy audits, or other audit procedures specified in your site-specific monitoring plan at least annually.

(6) You must conduct a performance evaluation of each CPMS in accordance with your site-specific monitoring plan.

(c) If you are operating a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must monitor and record your fuel usage daily with separate fuel meters to measure the volumetric flow rate of each fuel. In addition, you must operate your stationary RICE in a manner which reasonably minimizes HAP emissions.

(d) If you are operating a new or reconstructed emergency 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions, you must install a non-resettable hour meter prior to the startup of the engine.

(e) If you own or operate any of the following stationary RICE, you must operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission-related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions:

(1) An existing stationary RICE with a site rating of less than 100 HP located at a major source of HAP emissions;

(2) An existing emergency or black start stationary RICE with a site rating of less than or equal to 500 HP located at a major source of HAP emissions;

(3) An existing emergency or black start stationary RICE located at an area source of HAP emissions;

(4) An existing non-emergency, non-black start stationary CI RICE with a site rating less than or equal to 300 HP located at an area source of HAP emissions;

(5) An existing non-emergency, non-black start 2SLB stationary RICE located at an area source of HAP emissions;

(6) An existing non-emergency, non-black start stationary RICE located at an area source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis.

(7) An existing non-emergency, non-black start 4SLB stationary RICE with a site rating less than or equal to 500 HP located at an area source of HAP emissions;

(8) An existing non-emergency, non-black start 4SRB stationary RICE with a site rating less than or equal to 500 HP located at an area source of HAP emissions;

(9) An existing, non-emergency, non-black start 4SLB stationary RICE with a site rating greater than 500 HP located at an area source of HAP emissions that is operated 24 hours or less per calendar year; and

(10) An existing, non-emergency, non-black start 4SRB stationary RICE with a site rating greater than 500 HP located at an area source of HAP emissions that is operated 24 hours or less per calendar year.

(f) If you own or operate an existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing emergency stationary RICE located at an area source of HAP emissions, you must install a non-resettable hour meter if one is not already installed.

(g) If you own or operate an existing non-emergency, non-black start CI engine greater than or equal to 300 HP that is not equipped with a closed crankcase ventilation system, you must comply with either paragraph (g)(1) or paragraph (2) of this section. Owners and operators must follow the manufacturer's specified maintenance requirements for operating and maintaining the open or closed crankcase ventilation systems and replacing the crankcase filters, or can request the Administrator to approve different maintenance requirements that are as protective as manufacturer requirements. Existing CI engines located at area sources in areas of Alaska that meet either § 63.6603(b)(1) or § 63.6603(b)(2) do not have to meet the requirements of this paragraph (g). Existing CI engines located on offshore vessels that meet § 63.6603(c) do not have to meet the requirements of this paragraph (g).

(1) Install a closed crankcase ventilation system that prevents crankcase emissions from being emitted to the atmosphere, or

(2) Install an open crankcase filtration emission control system that reduces emissions from the crankcase by filtering the exhaust stream to remove oil mist, particulates and metals.

(h) If you operate a new, reconstructed, or existing stationary engine, you must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup in Tables 1a, 2a, 2c, and 2d to this subpart apply.

(i) If you own or operate a stationary CI engine that is subject to the work, operation or management practices in items 1 or 2 of Table 2c to this subpart or in items 1 or 4 of Table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.

(j) If you own or operate a stationary SI engine that is subject to the work, operation or management practices in items 6, 7, or 8 of Table 2c to this subpart or in items 5, 6, 7, 9, or 11 of Table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Acid Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Acid Number increases by more than 3.0 milligrams of potassium hydroxide (KOH) per gram from Total Acid Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3606, Jan. 18, 2008; 75 FR 9676, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010; 76 FR 12866, Mar. 9, 2011; 78 FR 6703, Jan. 30, 2013]

**§ 63.6630 How do I demonstrate initial compliance with the emission limitations, operating limitations, and other requirements?**

(a) You must demonstrate initial compliance with each emission limitation, operating limitation, and other requirement that applies to you according to Table 5 of this subpart.

(b) During the initial performance test, you must establish each operating limitation in Tables 1b and 2b of this subpart that applies to you.

(c) You must submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in § 63.6645.

(d) Non-emergency 4SRB stationary RICE complying with the requirement to reduce formaldehyde emissions by 76 percent or more can demonstrate initial compliance with the formaldehyde emission limit by testing for THC instead of formaldehyde. The testing must be conducted according to the requirements in Table 4 of this subpart. The average reduction of emissions of THC determined from the performance test must be equal to or greater than 30 percent.

(e) The initial compliance demonstration required for existing non-emergency 4SLB and 4SRB stationary RICE with a site rating of more than 500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year must be conducted according to the following requirements:

(1) The compliance demonstration must consist of at least three test runs.

(2) Each test run must be of at least 15 minute duration, except that each test conducted using the method in appendix A to this subpart must consist of at least one measurement cycle and include at least 2 minutes of test data phase measurement.

(3) If you are demonstrating compliance with the CO concentration or CO percent reduction requirement, you must measure CO emissions using one of the CO measurement methods specified in Table 4 of this subpart, or using appendix A to this subpart.

(4) If you are demonstrating compliance with the THC percent reduction requirement, you must measure THC emissions using Method 25A, reported as propane, of 40 CFR part 60, appendix A.

(5) You must measure O<sub>2</sub> using one of the O<sub>2</sub> measurement methods specified in Table 4 of this subpart. Measurements to determine O<sub>2</sub> concentration must be made at the same time as the measurements for CO or THC concentration.

(6) If you are demonstrating compliance with the CO or THC percent reduction requirement, you must measure CO or THC emissions and O<sub>2</sub> emissions simultaneously at the inlet and outlet of the control device.

[69 FR 33506, June 15, 2004, as amended at 78 FR 6704, Jan. 30, 2013]

### **Continuous Compliance Requirements**

#### **§ 63.6635 How do I monitor and collect data to demonstrate continuous compliance?**

(a) If you must comply with emission and operating limitations, you must monitor and collect data according to this section.

(b) Except for monitor malfunctions, associated repairs, required performance evaluations, and required quality assurance or control activities, you must monitor continuously at all times that the stationary RICE is operating. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions.

(c) You may not use data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities in data averages and calculations used to report emission or operating levels. You must, however, use all the valid data collected during all other periods.

[69 FR 33506, June 15, 2004, as amended at 76 FR 12867, Mar. 9, 2011]

#### **§ 63.6640 How do I demonstrate continuous compliance with the emission limitations, operating limitations, and other requirements?**

(a) You must demonstrate continuous compliance with each emission limitation, operating limitation, and other requirements in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply to you according to methods specified in Table 6 to this subpart.

(b) You must report each instance in which you did not meet each emission limitation or operating limitation in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply to you. These instances are deviations from the emission and operating limitations in this subpart. These deviations must be reported according to the requirements in § 63.6650. If you change your catalyst, you must reestablish the values of the operating parameters measured during the initial performance test. When you reestablish the values of your operating parameters, you must also conduct a performance test to demonstrate that you are meeting the required emission limitation applicable to your stationary RICE.

(c) The annual compliance demonstration required for existing non-emergency 4SLB and 4SRB stationary RICE with a site rating of more than 500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year must be conducted according to the following requirements:

(1) The compliance demonstration must consist of at least one test run.

(2) Each test run must be of at least 15 minute duration, except that each test conducted using the method in appendix A to this subpart must consist of at least one measurement cycle and include at least 2 minutes of test data phase measurement.

(3) If you are demonstrating compliance with the CO concentration or CO percent reduction requirement, you must measure CO emissions using one of the CO measurement methods specified in Table 4 of this subpart, or using appendix A to this subpart.

(4) If you are demonstrating compliance with the THC percent reduction requirement, you must measure THC emissions using Method 25A, reported as propane, of 40 CFR part 60, appendix A.

(5) You must measure O<sub>2</sub> using one of the O<sub>2</sub> measurement methods specified in Table 4 of this subpart. Measurements to determine O<sub>2</sub> concentration must be made at the same time as the measurements for CO or THC concentration.

(6) If you are demonstrating compliance with the CO or THC percent reduction requirement, you must measure CO or THC emissions and O<sub>2</sub> emissions simultaneously at the inlet and outlet of the control device.

(7) If the results of the annual compliance demonstration show that the emissions exceed the levels specified in Table 6 of this subpart, the stationary RICE must be shut down as soon as safely possible, and appropriate corrective action must be taken (e.g., repairs, catalyst cleaning, catalyst replacement). The stationary RICE must be retested within 7 days of being restarted and the emissions must meet the levels specified in Table 6 of this subpart. If the retest shows that the emissions continue to exceed the specified levels, the stationary RICE must again be shut down as soon as safely possible, and the stationary RICE may not operate, except for purposes of startup and testing, until the owner/operator demonstrates through testing that the emissions do not exceed the levels specified in Table 6 of this subpart.

(d) For new, reconstructed, and rebuilt stationary RICE, deviations from the emission or operating limitations that occur during the first 200 hours of operation from engine startup (engine burn-in period) are not violations. Rebuilt stationary RICE means a stationary RICE that has been rebuilt as that term is defined in 40 CFR 94.11(a).

(e) You must also report each instance in which you did not meet the requirements in Table 8 to this subpart that apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing emergency stationary RICE, an existing limited use stationary RICE, or an existing stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart, except for the initial notification requirements: a new or reconstructed stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new or reconstructed emergency stationary RICE, or a new or reconstructed limited use stationary RICE.

(f) If you own or operate an emergency stationary RICE, you must operate the emergency stationary RICE according to the requirements in paragraphs (f)(1) through (4) of this section. In order for the engine to be considered an emergency stationary RICE under this subpart, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency

situations for 50 hours per year, as described in paragraphs (f)(1) through (4) of this section, is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1) through (4) of this section, the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines.

(1) There is no time limit on the use of emergency stationary RICE in emergency situations.

(2) You may operate your emergency stationary RICE for any combination of the purposes specified in paragraphs (f)(2)(i) through (iii) of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraphs (f)(3) and (4) of this section counts as part of the 100 hours per calendar year allowed by this paragraph (f)(2).

(i) Emergency stationary RICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency RICE beyond 100 hours per calendar year.

(ii) Emergency stationary RICE may be operated for emergency demand response for periods in which the Reliability Coordinator under the North American Electric Reliability Corporation (NERC) Reliability Standard EOP-002-3, Capacity and Energy Emergencies (incorporated by reference, see § 63.14), or other authorized entity as determined by the Reliability Coordinator, has declared an Energy Emergency Alert Level 2 as defined in the NERC Reliability Standard EOP-002-3.

(iii) Emergency stationary RICE may be operated for periods where there is a deviation of voltage or frequency of 5 percent or greater below standard voltage or frequency.

(3) Emergency stationary RICE located at major sources of HAP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing and emergency demand response provided in paragraph (f)(2) of this section. The 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

(4) Emergency stationary RICE located at area sources of HAP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing and emergency demand response provided in paragraph (f)(2) of this section. Except as provided in paragraphs (f)(4)(i) and (ii) of this section, the 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

(i) Prior to May 3, 2014, the 50 hours per year for non-emergency situations can be used for peak shaving or non-emergency demand response to generate income for a facility, or to otherwise supply power as part of a financial arrangement with another entity if the engine is operated as part of a peak shaving (load management program) with the local distribution system operator and the power is provided only to the facility itself or to support the local distribution system.

(ii) The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:

(A) The engine is dispatched by the local balancing authority or local transmission and distribution system operator.

(B) The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.

(C) The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.

(D) The power is provided only to the facility itself or to support the local transmission and distribution system.

(E) The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine owner or operator.

[69 FR 33506, June 15, 2004, as amended at 71 FR 20467, Apr. 20, 2006; 73 FR 3606, Jan. 18, 2008; 75 FR 9676, Mar. 3, 2010; 75 FR 51591, Aug. 20, 2010; 78 FR 6704, Jan. 30, 2013]

## **Notifications, Reports, and Records**

### **§ 63.6645 What notifications must I submit and when?**

(a) You must submit all of the notifications in §§ 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), 63.9(b) through (e), and (g) and (h) that apply to you by the dates specified if you own or operate any of the following;

(1) An existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions.

(2) An existing stationary RICE located at an area source of HAP emissions.

(3) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.

(4) A new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 HP located at a major source of HAP emissions.

(5) This requirement does not apply if you own or operate an existing stationary RICE less than 100 HP, an existing stationary emergency RICE, or an existing stationary RICE that is not subject to any numerical emission standards.

(b) As specified in § 63.9(b)(2), if you start up your stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions before the effective date of this subpart, you must submit an Initial Notification not later than December 13, 2004.

(c) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions on or after August 16, 2004, you must submit an Initial Notification not later than 120 days after you become subject to this subpart.

(d) As specified in § 63.9(b)(2), if you start up your stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions before the effective date of this subpart

and you are required to submit an initial notification, you must submit an Initial Notification not later than July 16, 2008.

(e) If you start up your new or reconstructed stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions on or after March 18, 2008 and you are required to submit an initial notification, you must submit an Initial Notification not later than 120 days after you become subject to this subpart.

(f) If you are required to submit an Initial Notification but are otherwise not affected by the requirements of this subpart, in accordance with § 63.6590(b), your notification should include the information in § 63.9(b)(2)(i) through (v), and a statement that your stationary RICE has no additional requirements and explain the basis of the exclusion (for example, that it operates exclusively as an emergency stationary RICE if it has a site rating of more than 500 brake HP located at a major source of HAP emissions).

(g) If you are required to conduct a performance test, you must submit a Notification of Intent to conduct a performance test at least 60 days before the performance test is scheduled to begin as required in § 63.7(b)(1).

(h) If you are required to conduct a performance test or other initial compliance demonstration as specified in Tables 4 and 5 to this subpart, you must submit a Notification of Compliance Status according to § 63.9(h)(2)(ii).

(1) For each initial compliance demonstration required in Table 5 to this subpart that does not include a performance test, you must submit the Notification of Compliance Status before the close of business on the 30th day following the completion of the initial compliance demonstration.

(2) For each initial compliance demonstration required in Table 5 to this subpart that includes a performance test conducted according to the requirements in Table 3 to this subpart, you must submit the Notification of Compliance Status, including the performance test results, before the close of business on the 60th day following the completion of the performance test according to § 63.10(d)(2).

(i) If you own or operate an existing non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP emissions that is certified to the Tier 1 or Tier 2 emission standards in Table 1 of 40 CFR 89.112 and subject to an enforceable state or local standard requiring engine replacement and you intend to meet management practices rather than emission limits, as specified in § 63.6603(d), you must submit a notification by March 3, 2013, stating that you intend to use the provision in § 63.6603(d) and identifying the state or local regulation that the engine is subject to.

[73 FR 3606, Jan. 18, 2008, as amended at 75 FR 9677, Mar. 3, 2010; 75 FR 51591, Aug. 20, 2010; 78 FR 6705, Jan. 30, 2013]

### **§ 63.6650 What reports must I submit and when?**

(a) You must submit each report in Table 7 of this subpart that applies to you.

(b) Unless the Administrator has approved a different schedule for submission of reports under § 63.10(a), you must submit each report by the date in Table 7 of this subpart and according to the requirements in paragraphs (b)(1) through (b)(9) of this section.

(1) For semiannual Compliance reports, the first Compliance report must cover the period beginning on the compliance date that is specified for your affected source in § 63.6595 and ending on June 30 or December 31, whichever date is the first date following the end of the first calendar half after the compliance date that is specified for your source in § 63.6595.



(2) For semiannual Compliance reports, the first Compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date follows the end of the first calendar half after the compliance date that is specified for your affected source in § 63.6595.

(3) For semiannual Compliance reports, each subsequent Compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.

(4) For semiannual Compliance reports, each subsequent Compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date is the first date following the end of the semiannual reporting period.

(5) For each stationary RICE that is subject to permitting regulations pursuant to 40 CFR part 70 or 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6 (a)(3)(iii)(A), you may submit the first and subsequent Compliance reports according to the dates the permitting authority has established instead of according to the dates in paragraphs (b)(1) through (b)(4) of this section.

(6) For annual Compliance reports, the first Compliance report must cover the period beginning on the compliance date that is specified for your affected source in § 63.6595 and ending on December 31.

(7) For annual Compliance reports, the first Compliance report must be postmarked or delivered no later than January 31 following the end of the first calendar year after the compliance date that is specified for your affected source in § 63.6595.

(8) For annual Compliance reports, each subsequent Compliance report must cover the annual reporting period from January 1 through December 31.

(9) For annual Compliance reports, each subsequent Compliance report must be postmarked or delivered no later than January 31.

(c) The Compliance report must contain the information in paragraphs (c)(1) through (6) of this section.

(1) Company name and address.

(2) Statement by a responsible official, with that official's name, title, and signature, certifying the accuracy of the content of the report.

(3) Date of report and beginning and ending dates of the reporting period.

(4) If you had a malfunction during the reporting period, the compliance report must include the number, duration, and a brief description for each type of malfunction which occurred during the reporting period and which caused or may have caused any applicable emission limitation to be exceeded. The report must also include a description of actions taken by an owner or operator during a malfunction of an affected source to minimize emissions in accordance with § 63.6605(b), including actions taken to correct a malfunction.

(5) If there are no deviations from any emission or operating limitations that apply to you, a statement that there were no deviations from the emission or operating limitations during the reporting period.

(6) If there were no periods during which the continuous monitoring system (CMS), including CEMS and CPMS, was out-of-control, as specified in § 63.8(c)(7), a statement that there were no periods during which the CMS was out-of-control during the reporting period.

(d) For each deviation from an emission or operating limitation that occurs for a stationary RICE where you are not using a CMS to comply with the emission or operating limitations in this subpart, the Compliance report must contain the information in paragraphs (c)(1) through (4) of this section and the information in paragraphs (d)(1) and (2) of this section.

(1) The total operating time of the stationary RICE at which the deviation occurred during the reporting period.

(2) Information on the number, duration, and cause of deviations (including unknown cause, if applicable), as applicable, and the corrective action taken.

(e) For each deviation from an emission or operating limitation occurring for a stationary RICE where you are using a CMS to comply with the emission and operating limitations in this subpart, you must include information in paragraphs (c)(1) through (4) and (e)(1) through (12) of this section.

(1) The date and time that each malfunction started and stopped.

(2) The date, time, and duration that each CMS was inoperative, except for zero (low-level) and high-level checks.

(3) The date, time, and duration that each CMS was out-of-control, including the information in § 63.8(c)(8).

(4) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of malfunction or during another period.

(5) A summary of the total duration of the deviation during the reporting period, and the total duration as a percent of the total source operating time during that reporting period.

(6) A breakdown of the total duration of the deviations during the reporting period into those that are due to control equipment problems, process problems, other known causes, and other unknown causes.

(7) A summary of the total duration of CMS downtime during the reporting period, and the total duration of CMS downtime as a percent of the total operating time of the stationary RICE at which the CMS downtime occurred during that reporting period.

(8) An identification of each parameter and pollutant (CO or formaldehyde) that was monitored at the stationary RICE.

(9) A brief description of the stationary RICE.

(10) A brief description of the CMS.

(11) The date of the latest CMS certification or audit.

(12) A description of any changes in CMS, processes, or controls since the last reporting period.

(f) Each affected source that has obtained a title V operating permit pursuant to 40 CFR part 70 or 71 must report all deviations as defined in this subpart in the semiannual monitoring report required by 40 CFR 70.6 (a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If an affected source submits a Compliance report pursuant to Table 7 of this subpart along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the Compliance report includes all required

information concerning deviations from any emission or operating limitation in this subpart, submission of the Compliance report shall be deemed to satisfy any obligation to report the same deviations in the semiannual monitoring report. However, submission of a Compliance report shall not otherwise affect any obligation the affected source may have to report deviations from permit requirements to the permit authority.

(g) If you are operating as a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must submit an annual report according to Table 7 of this subpart by the date specified unless the Administrator has approved a different schedule, according to the information described in paragraphs (b)(1) through (b)(5) of this section. You must report the data specified in (g)(1) through (g)(3) of this section.

(1) Fuel flow rate of each fuel and the heating values that were used in your calculations. You must also demonstrate that the percentage of heat input provided by landfill gas or digester gas is equivalent to 10 percent or more of the total fuel consumption on an annual basis.

(2) The operating limits provided in your federally enforceable permit, and any deviations from these limits.

(3) Any problems or errors suspected with the meters.

(h) If you own or operate an emergency stationary RICE with a site rating of more than 100 brake HP that operates or is contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in § 63.6640(f)(2)(ii) and (iii) or that operates for the purpose specified in § 63.6640(f)(4)(ii), you must submit an annual report according to the requirements in paragraphs (h)(1) through (3) of this section.

(1) The report must contain the following information:

(i) Company name and address where the engine is located.

(ii) Date of the report and beginning and ending dates of the reporting period.

(iii) Engine site rating and model year.

(iv) Latitude and longitude of the engine in decimal degrees reported to the fifth decimal place.

(v) Hours operated for the purposes specified in § 63.6640(f)(2)(ii) and (iii), including the date, start time, and end time for engine operation for the purposes specified in § 63.6640(f)(2)(ii) and (iii).

(vi) Number of hours the engine is contractually obligated to be available for the purposes specified in § 63.6640(f)(2)(ii) and (iii).

(vii) Hours spent for operation for the purpose specified in § 63.6640(f)(4)(ii), including the date, start time, and end time for engine operation for the purposes specified in § 63.6640(f)(4)(ii). The report must also identify the entity that dispatched the engine and the situation that necessitated the dispatch of the engine.

(viii) If there were no deviations from the fuel requirements in § 63.6604 that apply to the engine (if any), a statement that there were no deviations from the fuel requirements during the reporting period.

(ix) If there were deviations from the fuel requirements in § 63.6604 that apply to the engine (if any), information on the number, duration, and cause of deviations, and the corrective action taken.

(2) The first annual report must cover the calendar year 2015 and must be submitted no later than March 31, 2016. Subsequent annual reports for each calendar year must be submitted no later than March 31 of the following calendar year.

(3) The annual report must be submitted electronically using the subpart specific reporting form in the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data Exchange (CDX) ( [www.epa.gov/cdx](http://www.epa.gov/cdx) ). However, if the reporting form specific to this subpart is not available in CEDRI at the time that the report is due, the written report must be submitted to the Administrator at the appropriate address listed in § 63.13.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9677, Mar. 3, 2010; 78 FR 6705, Jan. 30, 2013]

### **§ 63.6655 What records must I keep?**

(a) If you must comply with the emission and operating limitations, you must keep the records described in paragraphs (a)(1) through (a)(5), (b)(1) through (b)(3) and (c) of this section.

(1) A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted, according to the requirement in § 63.10(b)(2)(xiv).

(2) Records of the occurrence and duration of each malfunction of operation ( *i.e.*, process equipment) or the air pollution control and monitoring equipment.

(3) Records of performance tests and performance evaluations as required in § 63.10(b)(2)(viii).

(4) Records of all required maintenance performed on the air pollution control and monitoring equipment.

(5) Records of actions taken during periods of malfunction to minimize emissions in accordance with § 63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation.

(b) For each CEMS or CPMS, you must keep the records listed in paragraphs (b)(1) through (3) of this section.

(1) Records described in § 63.10(b)(2)(vi) through (xi).

(2) Previous ( *i.e.*, superseded) versions of the performance evaluation plan as required in § 63.8(d)(3).

(3) Requests for alternatives to the relative accuracy test for CEMS or CPMS as required in § 63.8(f)(6)(i), if applicable.

(c) If you are operating a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must keep the records of your daily fuel usage monitors.

(d) You must keep the records required in Table 6 of this subpart to show continuous compliance with each emission or operating limitation that applies to you.

(e) You must keep records of the maintenance conducted on the stationary RICE in order to demonstrate that you operated and maintained the stationary RICE and after-treatment control device (if any) according to your own maintenance plan if you own or operate any of the following stationary RICE;

(1) An existing stationary RICE with a site rating of less than 100 brake HP located at a major source of HAP emissions.

(2) An existing stationary emergency RICE.

(3) An existing stationary RICE located at an area source of HAP emissions subject to management practices as shown in Table 2d to this subpart.

(f) If you own or operate any of the stationary RICE in paragraphs (f)(1) through (2) of this section, you must keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. The owner or operator must document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for non-emergency operation. If the engine is used for the purposes specified in § 63.6640(f)(2)(ii) or (iii) or § 63.6640(f)(4)(ii), the owner or operator must keep records of the notification of the emergency situation, and the date, start time, and end time of engine operation for these purposes.

(1) An existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions that does not meet the standards applicable to non-emergency engines.

(2) An existing emergency stationary RICE located at an area source of HAP emissions that does not meet the standards applicable to non-emergency engines.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9678, Mar. 3, 2010; 75 FR 51592, Aug. 20, 2010; 78 FR 6706, Jan. 30, 2013]

#### **§ 63.6660 In what form and how long must I keep my records?**

(a) Your records must be in a form suitable and readily available for expeditious review according to § 63.10(b)(1).

(b) As specified in § 63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record readily accessible in hard copy or electronic form for at least 5 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to § 63.10(b)(1).

[69 FR 33506, June 15, 2004, as amended at 75 FR 9678, Mar. 3, 2010]

#### **Other Requirements and Information**

#### **§ 63.6665 What parts of the General Provisions apply to me?**

Table 8 to this subpart shows which parts of the General Provisions in §§ 63.1 through 63.15 apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with any of the requirements of the General Provisions specified in Table 8: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing stationary RICE that combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, an existing emergency

stationary RICE, or an existing limited use stationary RICE. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in the General Provisions specified in Table 8 except for the initial notification requirements: A new stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new emergency stationary RICE, or a new limited use stationary RICE.

[75 FR 9678, Mar. 3, 2010]

#### **§ 63.6670 Who implements and enforces this subpart?**

(a) This subpart is implemented and enforced by the U.S. EPA, or a delegated authority such as your State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency (as well as the U.S. EPA) has the authority to implement and enforce this subpart. You should contact your U.S. EPA Regional Office to find out whether this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under 40 CFR part 63, subpart E, the authorities contained in paragraph (c) of this section are retained by the Administrator of the U.S. EPA and are not transferred to the State, local, or tribal agency.

(c) The authorities that will not be delegated to State, local, or tribal agencies are:

(1) Approval of alternatives to the non-opacity emission limitations and operating limitations in § 63.6600 under § 63.6(g).

(2) Approval of major alternatives to test methods under § 63.7(e)(2)(ii) and (f) and as defined in § 63.90.

(3) Approval of major alternatives to monitoring under § 63.8(f) and as defined in § 63.90.

(4) Approval of major alternatives to recordkeeping and reporting under § 63.10(f) and as defined in § 63.90.

(5) Approval of a performance test which was conducted prior to the effective date of the rule, as specified in § 63.6610(b).

#### **§ 63.6675 What definitions apply to this subpart?**

Terms used in this subpart are defined in the Clean Air Act (CAA); in 40 CFR 63.2, the General Provisions of this part; and in this section as follows:

*Alaska Railbelt Grid* means the service areas of the six regulated public utilities that extend from Fairbanks to Anchorage and the Kenai Peninsula. These utilities are Golden Valley Electric Association; Chugach Electric Association; Matanuska Electric Association; Homer Electric Association; Anchorage Municipal Light & Power; and the City of Seward Electric System.

*Area source* means any stationary source of HAP that is not a major source as defined in part 63.

*Associated equipment* as used in this subpart and as referred to in section 112(n)(4) of the CAA, means equipment associated with an oil or natural gas exploration or production well, and includes all equipment from the well bore to the point of custody transfer, except glycol dehydration units, storage vessels with potential for flash emissions, combustion turbines, and stationary RICE.

*Backup power for renewable energy* means an engine that provides backup power to a facility that generates electricity from renewable energy resources, as that term is defined in Alaska Statute 42.45.045(l)(5) (incorporated by reference, see § 63.14).

*Black start engine* means an engine whose only purpose is to start up a combustion turbine.

*CAA* means the Clean Air Act (42 U.S.C. 7401 *et seq.*, as amended by Public Law 101-549, 104 Stat. 2399).

*Commercial emergency stationary RICE* means an emergency stationary RICE used in commercial establishments such as office buildings, hotels, stores, telecommunications facilities, restaurants, financial institutions such as banks, doctor's offices, and sports and performing arts facilities.

*Compression ignition* means relating to a type of stationary internal combustion engine that is not a spark ignition engine.

*Custody transfer* means the transfer of hydrocarbon liquids or natural gas: After processing and/or treatment in the producing operations, or from storage vessels or automatic transfer facilities or other such equipment, including product loading racks, to pipelines or any other forms of transportation. For the purposes of this subpart, the point at which such liquids or natural gas enters a natural gas processing plant is a point of custody transfer.

*Deviation* means any instance in which an affected source subject to this subpart, or an owner or operator of such a source:

- (1) Fails to meet any requirement or obligation established by this subpart, including but not limited to any emission limitation or operating limitation;
- (2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this subpart and that is included in the operating permit for any affected source required to obtain such a permit; or
- (3) Fails to meet any emission limitation or operating limitation in this subpart during malfunction, regardless of whether or not such failure is permitted by this subpart.
- (4) Fails to satisfy the general duty to minimize emissions established by § 63.6(e)(1)(i).

*Diesel engine* means any stationary RICE in which a high boiling point liquid fuel injected into the combustion chamber ignites when the air charge has been compressed to a temperature sufficiently high for auto-ignition. This process is also known as compression ignition.

*Diesel fuel* means any liquid obtained from the distillation of petroleum with a boiling point of approximately 150 to 360 degrees Celsius. One commonly used form is fuel oil number 2. Diesel fuel also includes any non-distillate fuel with comparable physical and chemical properties ( e.g. biodiesel) that is suitable for use in compression ignition engines.

*Digester gas* means any gaseous by-product of wastewater treatment typically formed through the anaerobic decomposition of organic waste materials and composed principally of methane and CO<sub>2</sub> .

*Dual-fuel engine* means any stationary RICE in which a liquid fuel (typically diesel fuel) is used for compression ignition and gaseous fuel (typically natural gas) is used as the primary fuel.

*Emergency stationary RICE* means any stationary reciprocating internal combustion engine that meets all of the criteria in paragraphs (1) through (3) of this definition. All emergency stationary RICE must comply with the requirements specified in § 63.6640(f) in order to be considered emergency stationary RICE. If the engine does not comply with the requirements specified in § 63.6640(f), then it is not considered to be an emergency stationary RICE under this subpart.

(1) The stationary RICE is operated to provide electrical power or mechanical work during an emergency situation. Examples include stationary RICE used to produce power for critical networks or equipment (including power supplied to portions of a facility) when electric power from the local utility (or the normal power source, if the facility runs on its own power production) is interrupted, or stationary RICE used to pump water in the case of fire or flood, etc.

(2) The stationary RICE is operated under limited circumstances for situations not included in paragraph (1) of this definition, as specified in § 63.6640(f).

(3) The stationary RICE operates as part of a financial arrangement with another entity in situations not included in paragraph (1) of this definition only as allowed in § 63.6640(f)(2)(ii) or (iii) and § 63.6640(f)(4)(i) or (ii).

*Engine startup* means the time from initial start until applied load and engine and associated equipment reaches steady state or normal operation. For stationary engine with catalytic controls, engine startup means the time from initial start until applied load and engine and associated equipment, including the catalyst, reaches steady state or normal operation.

*Four-stroke engine* means any type of engine which completes the power cycle in two crankshaft revolutions, with intake and compression strokes in the first revolution and power and exhaust strokes in the second revolution.

*Gaseous fuel* means a material used for combustion which is in the gaseous state at standard atmospheric temperature and pressure conditions.

*Gasoline* means any fuel sold in any State for use in motor vehicles and motor vehicle engines, or nonroad or stationary engines, and commonly or commercially known or sold as gasoline.

*Glycol dehydration unit* means a device in which a liquid glycol (including, but not limited to, ethylene glycol, diethylene glycol, or triethylene glycol) absorbent directly contacts a natural gas stream and absorbs water in a contact tower or absorption column (absorber). The glycol contacts and absorbs water vapor and other gas stream constituents from the natural gas and becomes "rich" glycol. This glycol is then regenerated in the glycol dehydration unit reboiler. The "lean" glycol is then recycled.

*Hazardous air pollutants (HAP)* means any air pollutants listed in or pursuant to section 112(b) of the CAA.

*Institutional emergency stationary RICE* means an emergency stationary RICE used in institutional establishments such as medical centers, nursing homes, research centers, institutions of higher education, correctional facilities, elementary and secondary schools, libraries, religious establishments, police stations, and fire stations.

*ISO standard day conditions* means 288 degrees Kelvin (15 degrees Celsius), 60 percent relative humidity and 101.3 kilopascals pressure.

*Landfill gas* means a gaseous by-product of the land application of municipal refuse typically formed through the anaerobic decomposition of waste materials and composed principally of methane and CO<sub>2</sub>.



*Lean burn engine* means any two-stroke or four-stroke spark ignited engine that does not meet the definition of a rich burn engine.

*Limited use stationary RICE* means any stationary RICE that operates less than 100 hours per year.

*Liquefied petroleum gas* means any liquefied hydrocarbon gas obtained as a by-product in petroleum refining of natural gas production.

*Liquid fuel* means any fuel in liquid form at standard temperature and pressure, including but not limited to diesel, residual/crude oil, kerosene/naphtha (jet fuel), and gasoline.

*Major Source*, as used in this subpart, shall have the same meaning as in § 63.2, except that:

(1) Emissions from any oil or gas exploration or production well (with its associated equipment (as defined in this section)) and emissions from any pipeline compressor station or pump station shall not be aggregated with emissions from other similar units, to determine whether such emission points or stations are major sources, even when emission points are in a contiguous area or under common control;

(2) For oil and gas production facilities, emissions from processes, operations, or equipment that are not part of the same oil and gas production facility, as defined in § 63.1271 of subpart HHH of this part, shall not be aggregated;

(3) For production field facilities, only HAP emissions from glycol dehydration units, storage vessel with the potential for flash emissions, combustion turbines and reciprocating internal combustion engines shall be aggregated for a major source determination; and

(4) Emissions from processes, operations, and equipment that are not part of the same natural gas transmission and storage facility, as defined in § 63.1271 of subpart HHH of this part, shall not be aggregated.

*Malfunction* means any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner which causes, or has the potential to cause, the emission limitations in an applicable standard to be exceeded. Failures that are caused in part by poor maintenance or careless operation are not malfunctions.

*Natural gas* means a naturally occurring mixture of hydrocarbon and non-hydrocarbon gases found in geologic formations beneath the Earth's surface, of which the principal constituent is methane. Natural gas may be field or pipeline quality.

*Non-selective catalytic reduction (NSCR)* means an add-on catalytic nitrogen oxides (NO<sub>x</sub>) control device for rich burn engines that, in a two-step reaction, promotes the conversion of excess oxygen, NO<sub>x</sub>, CO, and volatile organic compounds (VOC) into CO<sub>2</sub>, nitrogen, and water.

*Oil and gas production facility* as used in this subpart means any grouping of equipment where hydrocarbon liquids are processed, upgraded (i.e., remove impurities or other constituents to meet contract specifications), or stored prior to the point of custody transfer; or where natural gas is processed, upgraded, or stored prior to entering the natural gas transmission and storage source category. For purposes of a major source determination, facility (including a building, structure, or installation) means oil and natural gas production and processing equipment that is located within the boundaries of an individual surface site as defined in this section. Equipment that is part of a facility will typically be located within close proximity to other equipment located at the same facility. Pieces of production equipment or groupings of equipment located on different oil and gas leases, mineral fee tracts, lease tracts, subsurface or surface unit areas, surface fee tracts, surface lease tracts, or separate surface sites,

whether or not connected by a road, waterway, power line or pipeline, shall not be considered part of the same facility. Examples of facilities in the oil and natural gas production source category include, but are not limited to, well sites, satellite tank batteries, central tank batteries, a compressor station that transports natural gas to a natural gas processing plant, and natural gas processing plants.

*Oxidation catalyst* means an add-on catalytic control device that controls CO and VOC by oxidation.

*Peaking unit or engine* means any standby engine intended for use during periods of high demand that are not emergencies.

*Percent load* means the fractional power of an engine compared to its maximum manufacturer's design capacity at engine site conditions. Percent load may range between 0 percent to above 100 percent.

*Potential to emit* means the maximum capacity of a stationary source to emit a pollutant under its physical and operational design. Any physical or operational limitation on the capacity of the stationary source to emit a pollutant, including air pollution control equipment and restrictions on hours of operation or on the type or amount of material combusted, stored, or processed, shall be treated as part of its design if the limitation or the effect it would have on emissions is federally enforceable. For oil and natural gas production facilities subject to subpart HH of this part, the potential to emit provisions in § 63.760(a) may be used. For natural gas transmission and storage facilities subject to subpart HHH of this part, the maximum annual facility gas throughput for storage facilities may be determined according to § 63.1270(a)(1) and the maximum annual throughput for transmission facilities may be determined according to § 63.1270(a)(2).

*Production field facility* means those oil and gas production facilities located prior to the point of custody transfer.

*Production well* means any hole drilled in the earth from which crude oil, condensate, or field natural gas is extracted.

*Propane* means a colorless gas derived from petroleum and natural gas, with the molecular structure  $C_3H_8$ .

*Remote stationary RICE* means stationary RICE meeting any of the following criteria:

- (1) Stationary RICE located in an offshore area that is beyond the line of ordinary low water along that portion of the coast of the United States that is in direct contact with the open seas and beyond the line marking the seaward limit of inland waters.
- (2) Stationary RICE located on a pipeline segment that meets both of the criteria in paragraphs (2)(i) and (ii) of this definition.
  - (i) A pipeline segment with 10 or fewer buildings intended for human occupancy and no buildings with four or more stories within 220 yards (200 meters) on either side of the centerline of any continuous 1-mile (1.6 kilometers) length of pipeline. Each separate dwelling unit in a multiple dwelling unit building is counted as a separate building intended for human occupancy.
  - (ii) The pipeline segment does not lie within 100 yards (91 meters) of either a building or a small, well-defined outside area (such as a playground, recreation area, outdoor theater, or other place of public assembly) that is occupied by 20 or more persons on at least 5 days a week for 10 weeks in any 12-month period. The days and weeks need not be consecutive. The building or area is considered occupied for a full day if it is occupied for any portion of the day.

(iii) For purposes of this paragraph (2), the term pipeline segment means all parts of those physical facilities through which gas moves in transportation, including but not limited to pipe, valves, and other appurtenance attached to pipe, compressor units, metering stations, regulator stations, delivery stations, holders, and fabricated assemblies. Stationary RICE located within 50 yards (46 meters) of the pipeline segment providing power for equipment on a pipeline segment are part of the pipeline segment. Transportation of gas means the gathering, transmission, or distribution of gas by pipeline, or the storage of gas. A building is intended for human occupancy if its primary use is for a purpose involving the presence of humans.

(3) Stationary RICE that are not located on gas pipelines and that have 5 or fewer buildings intended for human occupancy and no buildings with four or more stories within a 0.25 mile radius around the engine. A building is intended for human occupancy if its primary use is for a purpose involving the presence of humans.

*Residential emergency stationary RICE* means an emergency stationary RICE used in residential establishments such as homes or apartment buildings.

*Responsible official* means responsible official as defined in 40 CFR 70.2.

*Rich burn engine* means any four-stroke spark ignited engine where the manufacturer's recommended operating air/fuel ratio divided by the stoichiometric air/fuel ratio at full load conditions is less than or equal to 1.1. Engines originally manufactured as rich burn engines, but modified prior to December 19, 2002 with passive emission control technology for NO<sub>x</sub> (such as pre-combustion chambers) will be considered lean burn engines. Also, existing engines where there are no manufacturer's recommendations regarding air/fuel ratio will be considered a rich burn engine if the excess oxygen content of the exhaust at full load conditions is less than or equal to 2 percent.

*Site-rated HP* means the maximum manufacturer's design capacity at engine site conditions.

*Spark ignition* means relating to either: A gasoline-fueled engine; or any other type of engine with a spark plug (or other sparking device) and with operating characteristics significantly similar to the theoretical Otto combustion cycle. Spark ignition engines usually use a throttle to regulate intake air flow to control power during normal operation. Dual-fuel engines in which a liquid fuel (typically diesel fuel) is used for CI and gaseous fuel (typically natural gas) is used as the primary fuel at an annual average ratio of less than 2 parts diesel fuel to 100 parts total fuel on an energy equivalent basis are spark ignition engines.

*Stationary reciprocating internal combustion engine (RICE)* means any reciprocating internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work and which is not mobile. Stationary RICE differ from mobile RICE in that a stationary RICE is not a non-road engine as defined at 40 CFR 1068.30, and is not used to propel a motor vehicle or a vehicle used solely for competition.

*Stationary RICE test cell/stand* means an engine test cell/stand, as defined in subpart PPPPP of this part, that tests stationary RICE.

*Stoichiometric* means the theoretical air-to-fuel ratio required for complete combustion.

*Storage vessel with the potential for flash emissions* means any storage vessel that contains a hydrocarbon liquid with a stock tank gas-to-oil ratio equal to or greater than 0.31 cubic meters per liter and an American Petroleum Institute gravity equal to or greater than 40 degrees and an actual annual average hydrocarbon liquid throughput equal to or greater than 79,500 liters per day. Flash emissions occur when dissolved hydrocarbons in the fluid evolve from solution when the fluid pressure is reduced.

*Subpart* means 40 CFR part 63, subpart ZZZZ.

*Surface site* means any combination of one or more graded pad sites, gravel pad sites, foundations, platforms, or the immediate physical location upon which equipment is physically affixed.

*Two-stroke engine* means a type of engine which completes the power cycle in single crankshaft revolution by combining the intake and compression operations into one stroke and the power and exhaust operations into a second stroke. This system requires auxiliary scavenging and inherently runs lean of stoichiometric.

[69 FR 33506, June 15, 2004, as amended at 71 FR 20467, Apr. 20, 2006; 73 FR 3607, Jan. 18, 2008; 75 FR 9679, Mar. 3, 2010; 75 FR 51592, Aug. 20, 2010; 76 FR 12867, Mar. 9, 2011; 78 FR 6706, Jan. 30, 2013]

**Table 1a to Subpart ZZZZ of Part 63—Emission Limitations for Existing, New, and Reconstructed Spark Ignition, 4SRB Stationary RICE > 500 HP Located at a Major Source of HAP Emissions**

As stated in §§ 63.6600 and 63.6640, you must comply with the following emission limitations at 100 percent load plus or minus 10 percent for existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions:

For each . . .	You must meet the following emission limitation, except during periods of startup . . .	During periods of startup you must . . .
1. 4SRB stationary RICE	a. Reduce formaldehyde emissions by 76 percent or more. If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004, you may reduce formaldehyde emissions by 75 percent or more until June 15, 2007 or	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. <sup>1</sup>
	b. Limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O <sub>2</sub>	

<sup>1</sup>Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

[75 FR 9679, Mar. 3, 2010, as amended at 75 FR 51592, Aug. 20, 2010]

**Table 1b to Subpart ZZZZ of Part 63—Operating Limitations for Existing, New, and Reconstructed SI 4SRB Stationary RICE >500 HP Located at a Major Source of HAP Emissions**

As stated in §§ 63.6600, 63.6603, 63.6630 and 63.6640, you must comply with the following operating limitations for existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions:

**TABLE 1B TO SUBPART ZZZZ OF PART 63—OPERATING LIMITATIONS FOR EXISTING, NEW, AND RECONSTRUCTED SI 4SRB STATIONARY RICE >500 HP LOCATED AT A MAJOR SOURCE OF HAP EMISSIONS**

<b>For each . . .</b>	<b>You must meet the following operating limitation, except during periods of startup . . .</b>
1. existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions complying with the requirement to reduce formaldehyde emissions by 76 percent or more (or by 75 percent or more, if applicable) and using NSCR; or existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O <sub>2</sub> and using NSCR;	a. maintain your catalyst so that the pressure drop across the catalyst does not change by more than 2 inches of water at 100 percent load plus or minus 10 percent from the pressure drop across the catalyst measured during the initial performance test; and b. maintain the temperature of your stationary RICE exhaust so that the catalyst inlet temperature is greater than or equal to 750 °F and less than or equal to 1250 °F. <sup>1</sup>
2. existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions complying with the requirement to reduce formaldehyde emissions by 76 percent or more (or by 75 percent or more, if applicable) and not using NSCR; or	Comply with any operating limitations approved by the Administrator.
existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O <sub>2</sub> and not using NSCR.	

<sup>1</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.8(f) for a different temperature range.

**Table 2a to Subpart ZZZZ of Part 63—Emission Limitations for New and Reconstructed 2SLB and Compression Ignition Stationary RICE >500 HP and New and Reconstructed 4SLB Stationary RICE ≥250 HP Located at a Major Source of HAP Emissions**

As stated in §§ 63.6600 and 63.6640, you must comply with the following emission limitations for new and reconstructed lean burn and new and reconstructed compression ignition stationary RICE at 100 percent load plus or minus 10 percent:

For each . . .	You must meet the following emission limitation, except during periods of startup . . .	During periods of startup you must . . .
1. 2SLB stationary RICE	a. Reduce CO emissions by 58 percent or more; or b. Limit concentration of formaldehyde in the stationary RICE exhaust to 12 ppmvd or less at 15 percent O <sub>2</sub> . If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004, you may limit concentration of formaldehyde to 17 ppmvd or less at 15 percent O <sub>2</sub> until June 15, 2007	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. <sup>1</sup>
2. 4SLB stationary RICE	a. Reduce CO emissions by 93 percent or more; or	
	b. Limit concentration of formaldehyde in the stationary RICE exhaust to 14 ppmvd or less at 15 percent O <sub>2</sub>	
3. CI stationary RICE	a. Reduce CO emissions by 70 percent or more; or	
	b. Limit concentration of formaldehyde in the stationary RICE exhaust to 580 ppbvd or less at 15 percent O <sub>2</sub>	

<sup>1</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

[75 FR 9680, Mar. 3, 2010]

**Table 2b to Subpart ZZZZ of Part 63—Operating Limitations for New and Reconstructed 2SLB and CI Stationary RICE >500 HP Located at a Major Source of HAP Emissions, New and Reconstructed 4SLB Stationary RICE ≥250 HP Located at a Major Source of HAP Emissions, Existing CI Stationary RICE >500 HP**

As stated in §§ 63.6600, 63.6601, 63.6603, 63.6630, and 63.6640, you must comply with the following operating limitations for new and reconstructed 2SLB and CI stationary RICE >500 HP located at a major source of HAP emissions; new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions; and existing CI stationary RICE >500 HP:

**TABLE 2B TO SUBPART ZZZZ OF PART 63—OPERATING LIMITATIONS FOR NEW AND RECONSTRUCTED 2SLB AND CI STATIONARY RICE >500 HP LOCATED AT A MAJOR SOURCE OF HAP EMISSIONS, NEW AND RECONSTRUCTED 4SLB STATIONARY RICE ≥250 HP LOCATED AT A MAJOR SOURCE OF HAP EMISSIONS, EXISTING CI STATIONARY RICE >500 HP**

For each . . .	You must meet the following operating limitation, except during periods of startup . . .
1. New and reconstructed 2SLB and CI stationary RICE >500 HP located at a major source of HAP emissions and new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions complying with the requirement to reduce CO emissions and using an oxidation catalyst; and New and reconstructed 2SLB and CI stationary RICE >500 HP located at a major source of HAP emissions and new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust and using an oxidation catalyst.	a. maintain your catalyst so that the pressure drop across the catalyst does not change by more than 2 inches of water at 100 percent load plus or minus 10 percent from the pressure drop across the catalyst that was measured during the initial performance test; and b. maintain the temperature of your stationary RICE exhaust so that the catalyst inlet temperature is greater than or equal to 450 °F and less than or equal to 1350 °F. <sup>1</sup>
2. Existing CI stationary RICE >500 HP complying with the requirement to limit or reduce the concentration of CO in the stationary RICE exhaust and using an oxidation catalyst	a. maintain your catalyst so that the pressure drop across the catalyst does not change by more than 2 inches of water from the pressure drop across the catalyst that was measured during the initial performance test; and
	b. maintain the temperature of your stationary RICE exhaust so that the catalyst inlet temperature is greater than or equal to 450 °F and less than or equal to 1350 °F. <sup>1</sup>
3. New and reconstructed 2SLB and CI stationary RICE >500 HP located at a major source of HAP emissions and new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions complying with the requirement to reduce CO emissions and not using an oxidation catalyst; and	Comply with any operating limitations approved by the Administrator.

<p><b>For each . . .</b></p>	<p><b>You must meet the following operating limitation, except during periods of startup . . .</b></p>
<p>New and reconstructed 2SLB and CI stationary RICE &gt;500 HP located at a major source of HAP emissions and new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust and not using an oxidation catalyst; and</p>	
<p>existing CI stationary RICE &gt;500 HP complying with the requirement to limit or reduce the concentration of CO in the stationary RICE exhaust and not using an oxidation catalyst.</p>	

<sup>1</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.8(f) for a different temperature range.

[78 FR 6707, Jan. 30, 2013]



**Table 2c to Subpart ZZZZ of Part 63—Requirements for Existing Compression Ignition Stationary RICE Located at a Major Source of HAP Emissions and Existing Spark Ignition Stationary RICE ≤500 HP Located at a Major Source of HAP Emissions**

As stated in §§ 63.6600, 63.6602, and 63.6640, you must comply with the following requirements for existing compression ignition stationary RICE located at a major source of HAP emissions and existing spark ignition stationary RICE ≤500 HP located at a major source of HAP emissions:

**TABLE 2C TO SUBPART ZZZZ OF PART 63—REQUIREMENTS FOR EXISTING COMPRESSION IGNITION STATIONARY RICE LOCATED AT A MAJOR SOURCE OF HAP EMISSIONS AND EXISTING SPARK IGNITION STATIONARY RICE ≤500 HP LOCATED AT A MAJOR SOURCE OF HAP EMISSIONS**

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
1. Emergency stationary CI RICE and black start stationary CI RICE <sup>1</sup>	a. Change oil and filter every 500 hours of operation or annually, whichever comes first. <sup>2</sup> b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. <sup>3</sup>
2. Non-Emergency, non-black start stationary CI RICE <100 HP	a. Change oil and filter every 1,000 hours of operation or annually, whichever comes first. <sup>2</sup> b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>	
3. Non-Emergency, non-black start CI stationary RICE 100≤HP≤300 HP	Limit concentration of CO in the stationary RICE exhaust to 230 ppmvd or less at 15 percent O <sub>2</sub> .	

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
4. Non-Emergency, non-black start CI stationary RICE 300>HP≤500.” is corrected to read “4. Non-Emergency, non-black start CI stationary RICE 300<HP≤500.	a. Limit concentration of CO in the stationary RICE exhaust to 49 ppmvd or less at 15 percent O <sub>2</sub> ; or b. Reduce CO emissions by 70 percent or more.	
5. Non-Emergency, non-black start stationary CI RICE >500 HP	a. Limit concentration of CO in the stationary RICE exhaust to 23 ppmvd or less at 15 percent O <sub>2</sub> ; or b. Reduce CO emissions by 70 percent or more.	
6. Emergency stationary SI RICE and black start stationary SI RICE. <sup>1</sup>	a. Change oil and filter every 500 hours of operation or annually, whichever comes first; <sup>2</sup> b. Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>	
7. Non-Emergency, non-black start stationary SI RICE <100 HP that are not 2SLB stationary RICE	a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first; <sup>2</sup> b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first, and replace as necessary;	
	c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>	

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
8. Non-Emergency, non-black start 2SLB stationary SI RICE <100 HP	a. Change oil and filter every 4,320 hours of operation or annually, whichever comes first; <sup>2</sup> b. Inspect spark plugs every 4,320 hours of operation or annually, whichever comes first, and replace as necessary;	
	c. Inspect all hoses and belts every 4,320 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>	
9. Non-emergency, non-black start 2SLB stationary RICE 100≤HP≤500	Limit concentration of CO in the stationary RICE exhaust to 225 ppmvd or less at 15 percent O <sub>2</sub> .	
10. Non-emergency, non-black start 4SLB stationary RICE 100≤HP≤500	Limit concentration of CO in the stationary RICE exhaust to 47 ppmvd or less at 15 percent O <sub>2</sub> .	
11. Non-emergency, non-black start 4SRB stationary RICE 100≤HP≤500	Limit concentration of formaldehyde in the stationary RICE exhaust to 10.3 ppmvd or less at 15 percent O <sub>2</sub> .	
12. Non-emergency, non-black start stationary RICE 100≤HP≤500 which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis	Limit concentration of CO in the stationary RICE exhaust to 177 ppmvd or less at 15 percent O <sub>2</sub> .	

<sup>1</sup> If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the work practice requirements on the schedule required in Table 2c of this subpart, or if performing the work practice on the required schedule would otherwise pose an unacceptable risk under federal, state, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under federal, state, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under federal, state, or local law has abated. Sources must report any failure to perform the work practice on the schedule required and the federal, state or local law under which the risk was deemed unacceptable.

<sup>2</sup> Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in Table 2c of this subpart.

<sup>3</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

[78 FR 6708, Jan. 30, 2013, as amended at 78 FR 14457, Mar. 6, 2013]

**Table 2d to Subpart ZZZZ of Part 63—Requirements for Existing Stationary RICE Located at Area Sources of HAP Emissions**

As stated in §§ 63.6603 and 63.6640, you must comply with the following requirements for existing stationary RICE located at area sources of HAP emissions:

**TABLE 2D TO SUBPART ZZZZ OF PART 63—REQUIREMENTS FOR EXISTING STATIONARY RICE LOCATED AT AREA SOURCES OF HAP EMISSIONS**

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
1. Non-Emergency, non-black start CI stationary RICE ≤300 HP	a. Change oil and filter every 1,000 hours of operation or annually, whichever comes first; <sup>1</sup> b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply.
2. Non-Emergency, non-black start CI stationary RICE 300<HP≤500	a. Limit concentration of CO in the stationary RICE exhaust to 49 ppmvd at 15 percent O <sub>2</sub> ; or	
	b. Reduce CO emissions by 70 percent or more.	
3. Non-Emergency, non-black start CI stationary RICE >500 HP	a. Limit concentration of CO in the stationary RICE exhaust to 23 ppmvd at 15 percent O <sub>2</sub> ; or	
	b. Reduce CO emissions by 70 percent or more.	

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
4. Emergency stationary CI RICE and black start stationary CI RICE. <sup>2</sup>	a. Change oil and filter every 500 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; and	
	c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	
5. Emergency stationary SI RICE; black start stationary SI RICE; non-emergency, non-black start 4SLB stationary RICE >500 HP that operate 24 hours or less per calendar year; non-emergency, non-black start 4SRB stationary RICE >500 HP that operate 24 hours or less per calendar year. <sup>2</sup>	a. Change oil and filter every 500 hours of operation or annually, whichever comes first; <sup>1</sup> ; b. Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; and c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	
6. Non-emergency, non-black start 2SLB stationary RICE	a. Change oil and filter every 4,320 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect spark plugs every 4,320 hours of operation or annually, whichever comes first, and replace as necessary; and	

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
	c. Inspect all hoses and belts every 4,320 hours of operation or annually, whichever comes first, and replace as necessary.	
7. Non-emergency, non-black start 4SLB stationary RICE ≤500 HP	a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first, and replace as necessary; and	
	c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary.	
8. Non-emergency, non-black start 4SLB remote stationary RICE >500 HP	a. Change oil and filter every 2,160 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect spark plugs every 2,160 hours of operation or annually, whichever comes first, and replace as necessary; and	
	c. Inspect all hoses and belts every 2,160 hours of operation or annually, whichever comes first, and replace as necessary.	
9. Non-emergency, non-black start 4SLB stationary RICE >500 HP that are not remote stationary RICE and that operate more than 24 hours per calendar year	Install an oxidation catalyst to reduce HAP emissions from the stationary RICE.	

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
10. Non-emergency, non-black start 4SRB stationary RICE ≤500 HP	a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first, and replace as necessary; and	
	c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary.	
11. Non-emergency, non-black start 4SRB remote stationary RICE >500 HP	a. Change oil and filter every 2,160 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect spark plugs every 2,160 hours of operation or annually, whichever comes first, and replace as necessary; and	
	c. Inspect all hoses and belts every 2,160 hours of operation or annually, whichever comes first, and replace as necessary.	
12. Non-emergency, non-black start 4SRB stationary RICE >500 HP that are not remote stationary RICE and that operate more than 24 hours per calendar year	Install NSCR to reduce HAP emissions from the stationary RICE.	
13. Non-emergency, non-black start stationary RICE which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis	a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first; <sup>1</sup> b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first, and replace as necessary; and	

For each . . .	<b>You must meet the following requirement, except during periods of startup . . .</b>	<b>During periods of startup you must . . .</b>
	c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary.	

<sup>1</sup> Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in Table 2d of this subpart.

<sup>2</sup> If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in Table 2d of this subpart, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under federal, state, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under federal, state, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under federal, state, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the federal, state or local law under which the risk was deemed unacceptable.

[78 FR 6709, Jan. 30, 2013]



**Table 3 to Subpart ZZZZ of Part 63—Subsequent Performance Tests**

As stated in §§ 63.6615 and 63.6620, you must comply with the following subsequent performance test requirements:

**TABLE 3 TO SUBPART ZZZZ OF PART 63—SUBSEQUENT PERFORMANCE TESTS**

<b>For each . . .</b>	<b>Complying with the requirement to . . .</b>	<b>You must . . .</b>
1. New or reconstructed 2SLB stationary RICE >500 HP located at major sources; new or reconstructed 4SLB stationary RICE ≥250 HP located at major sources; and new or reconstructed CI stationary RICE >500 HP located at major sources	Reduce CO emissions and not using a CEMS	Conduct subsequent performance tests semiannually. <sup>1</sup>
2. 4SRB stationary RICE ≥5,000 HP located at major sources	Reduce formaldehyde emissions	Conduct subsequent performance tests semiannually. <sup>1</sup>
3. Stationary RICE >500 HP located at major sources and new or reconstructed 4SLB stationary RICE 250≤HP≤500 located at major sources	Limit the concentration of formaldehyde in the stationary RICE exhaust	Conduct subsequent performance tests semiannually. <sup>1</sup>
4. Existing non-emergency, non-black start CI stationary RICE >500 HP that are not limited use stationary RICE	Limit or reduce CO emissions and not using a CEMS	Conduct subsequent performance tests every 8,760 hours or 3 years, whichever comes first.
5. Existing non-emergency, non-black start CI stationary RICE >500 HP that are limited use stationary RICE	Limit or reduce CO emissions and not using a CEMS	Conduct subsequent performance tests every 8,760 hours or 5 years, whichever comes first.

<sup>1</sup> After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

**Table 4 to Subpart ZZZZ of Part 63—Requirements for Performance Tests**

As stated in §§ 63.6610, 63.6611, 63.6612, 63.6620, and 63.6640, you must comply with the following requirements for performance tests for stationary RICE:

**TABLE 4 TO SUBPART ZZZZ OF PART 63. REQUIREMENTS FOR PERFORMANCE TESTS**

For each . . .	Complying with the requirement to . . .	You must . . .	Using . . .	According to the following requirements . . .
1. 2SLB, 4SLB, and CI stationary RICE	a. reduce CO emissions	i. Measure the O <sub>2</sub> at the inlet and outlet of the control device; and	(1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A, or ASTM Method D6522-00 (Reapproved 2005). <sup>a c</sup>	(a) Measurements to determine O <sub>2</sub> must be made at the same time as the measurements for CO concentration.
		ii. Measure the CO at the inlet and the outlet of the control device	(1) ASTM D6522-00 (Reapproved 2005) <sup>a b c</sup> or Method 10 of 40 CFR part 60, appendix A	(a) The CO concentration must be at 15 percent O <sub>2</sub> , dry basis.
2. 4SRB stationary RICE	a. reduce formaldehyde emissions	i. Select the sampling port location and the number of traverse points; and	(1) Method 1 or 1A of 40 CFR part 60, appendix A § 63.7(d)(1)(i)	(a) sampling sites must be located at the inlet and outlet of the control device.
		ii. Measure O <sub>2</sub> at the inlet and outlet of the control device; and	(1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A, or ASTM Method D6522-00 (Reapproved 2005). <sup>a</sup>	(a) measurements to determine O <sub>2</sub> concentration must be made at the same time as the measurements for formaldehyde or THC concentration.
		iii. Measure moisture content at the inlet and outlet of the control device; and	(1) Method 4 of 40 CFR part 60, appendix A, or Test Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348-03. <sup>a</sup>	(a) measurements to determine moisture content must be made at the same time and location as the measurements for formaldehyde or THC concentration.
		iv. If demonstrating compliance with the formaldehyde percent reduction requirement, measure formaldehyde at the inlet and the outlet of the control device	(1) Method 320 or 323 of 40 CFR part 63, appendix A; or ASTM D6348-03, <sup>a</sup> provided in ASTM D6348-03 Annex A5 (Analyte Spiking Technique), the percent R must be greater than or equal to 70 and less than or equal to 130	(a) formaldehyde concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs.

For each . . .	Complying with the requirement to . . .	You must . . .	Using . . .	According to the following requirements . . .
		v. If demonstrating compliance with the THC percent reduction requirement, measure THC at the inlet and the outlet of the control device	(1) Method 25A, reported as propane, of 40 CFR part 60, appendix A	(a) THC concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs.
3. Stationary RICE	a. limit the concentration of formaldehyde or CO in the stationary RICE exhaust	i. Select the sampling port location and the number of traverse points; and	(1) Method 1 or 1A of 40 CFR part 60, appendix A § 63.7(d)(1)(i)	(a) if using a control device, the sampling site must be located at the outlet of the control device.
		ii. Determine the O <sub>2</sub> concentration of the stationary RICE exhaust at the sampling port location; and	(1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A, or ASTM Method D6522-00 (Reapproved 2005). <sup>a</sup>	(a) measurements to determine O <sub>2</sub> concentration must be made at the same time and location as the measurements for formaldehyde or CO concentration.
		iii. Measure moisture content of the stationary RICE exhaust at the sampling port location; and	(1) Method 4 of 40 CFR part 60, appendix A, or Test Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348-03. <sup>a</sup>	(a) measurements to determine moisture content must be made at the same time and location as the measurements for formaldehyde or CO concentration.
		iv. Measure formaldehyde at the exhaust of the stationary RICE; or	(1) Method 320 or 323 of 40 CFR part 63, appendix A; or ASTM D6348-03, <sup>a</sup> provided in ASTM D6348-03 Annex A5 (Analyte Spiking Technique), the percent R must be greater than or equal to 70 and less than or equal to 130	(a) Formaldehyde concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs.
		v. measure CO at the exhaust of the stationary RICE.	(1) Method 10 of 40 CFR part 60, appendix A, ASTM Method D6522-00 (2005), <sup>a</sup> Method 320 of 40 CFR part 63, appendix A, or ASTM D6348-03. <sup>a</sup>	(a) CO concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs.

<sup>a</sup> Incorporated by reference, see 40 CFR 63.14. You may also obtain copies from University Microfilms International, 300 North Zeeb Road, Ann Arbor, MI 48106.

<sup>b</sup> You may also use Method 320 of 40 CFR part 63, appendix A, or ASTM D6348-03.

<sup>c</sup> ASTM-D6522-00 (2005) may be used to test both CI and SI stationary RICE.

[78 FR 6711, Jan. 30, 2013]

**Table 5 to Subpart ZZZZ of Part 63—Initial Compliance With Emission Limitations, Operating Limitations, and Other Requirements**

As stated in §§ 63.6612, 63.6625 and 63.6630, you must initially comply with the emission and operating limitations as required by the following:

**TABLE 5 TO SUBPART ZZZZ OF PART 63—INITIAL COMPLIANCE WITH EMISSION LIMITATIONS, OPERATING LIMITATIONS, AND OTHER REQUIREMENTS**

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if . . .
1. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP located at an area source of HAP	a. Reduce CO emissions and using oxidation catalyst, and using a CPMS	i. The average reduction of emissions of CO determined from the initial performance test achieves the required CO percent reduction; and ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b); and iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.
2. Non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP located at an area source of HAP	a. Limit the concentration of CO, using oxidation catalyst, and using a CPMS	i. The average CO concentration determined from the initial performance test is less than or equal to the CO emission limitation; and
		ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b); and
		iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if . . .
<p>3. New or reconstructed non-emergency 2SLB stationary RICE &gt;500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, non-emergency stationary CI RICE &gt;500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE &gt;500 HP located at an area source of HAP</p>	<p>a. Reduce CO emissions and not using oxidation catalyst</p>	<p>i. The average reduction of emissions of CO determined from the initial performance test achieves the required CO percent reduction; and                      ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in § 63.6625(b); and                      iii. You have recorded the approved operating parameters (if any) during the initial performance test.</p>
<p>4. Non-emergency stationary CI RICE &gt;500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE &gt;500 HP located at an area source of HAP</p>	<p>a. Limit the concentration of CO, and not using oxidation catalyst</p>	<p>i. The average CO concentration determined from the initial performance test is less than or equal to the CO emission limitation; and                      ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in § 63.6625(b); and</p>
		<p>iii. You have recorded the approved operating parameters (if any) during the initial performance test.</p>
<p>5. New or reconstructed non-emergency 2SLB stationary RICE &gt;500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, non-emergency stationary CI RICE &gt;500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE &gt;500 HP located at an area source of HAP</p>	<p>a. Reduce CO emissions, and using a CEMS</p>	<p>i. You have installed a CEMS to continuously monitor CO and either O<sub>2</sub> or CO<sub>2</sub> at both the inlet and outlet of the oxidation catalyst according to the requirements in § 63.6625(a); and                      ii. You have conducted a performance evaluation of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B; and</p>
		<p>iii. The average reduction of CO calculated using § 63.6620 equals or exceeds the required percent reduction. The initial test comprises the first 4-hour period after successful validation of the CEMS. Compliance is based on the average percent reduction achieved during the 4-hour period.</p>
<p>6. Non-emergency stationary CI RICE &gt;500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE &gt;500 HP located at an area source of HAP</p>	<p>a. Limit the concentration of CO, and using a CEMS</p>	<p>i. You have installed a CEMS to continuously monitor CO and either O<sub>2</sub> or CO<sub>2</sub> at the outlet of the oxidation catalyst according to the requirements in § 63.6625(a); and</p>

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if . . .
		ii. You have conducted a performance evaluation of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B; and
		iii. The average concentration of CO calculated using § 63.6620 is less than or equal to the CO emission limitation. The initial test comprises the first 4-hour period after successful validation of the CEMS. Compliance is based on the average concentration measured during the 4-hour period.
7. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP	a. Reduce formaldehyde emissions and using NSCR	i. The average reduction of emissions of formaldehyde determined from the initial performance test is equal to or greater than the required formaldehyde percent reduction, or the average reduction of emissions of THC determined from the initial performance test is equal to or greater than 30 percent; and
		ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b); and
		iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.
8. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP	a. Reduce formaldehyde emissions and not using NSCR	i. The average reduction of emissions of formaldehyde determined from the initial performance test is equal to or greater than the required formaldehyde percent reduction or the average reduction of emissions of THC determined from the initial performance test is equal to or greater than 30 percent; and
		ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in § 63.6625(b); and
		iii. You have recorded the approved operating parameters (if any) during the initial performance test.

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if . . .
<p>9. New or reconstructed non-emergency stationary RICE &gt;500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE 250≤HP≤500 located at a major source of HAP, and existing non-emergency 4SRB stationary RICE &gt;500 HP located at a major source of HAP</p>	<p>a. Limit the concentration of formaldehyde in the stationary RICE exhaust and using oxidation catalyst or NSCR</p>	<p>i. The average formaldehyde concentration, corrected to 15 percent O<sub>2</sub>, dry basis, from the three test runs is less than or equal to the formaldehyde emission limitation; and                      ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b); and</p>
		<p>iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.</p>
<p>10. New or reconstructed non-emergency stationary RICE &gt;500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE 250≤HP≤500 located at a major source of HAP, and existing non-emergency 4SRB stationary RICE &gt;500 HP located at a major source of HAP</p>	<p>a. Limit the concentration of formaldehyde in the stationary RICE exhaust and not using oxidation catalyst or NSCR</p>	<p>i. The average formaldehyde concentration, corrected to 15 percent O<sub>2</sub>, dry basis, from the three test runs is less than or equal to the formaldehyde emission limitation; and                      ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in § 63.6625(b); and</p>
		<p>iii. You have recorded the approved operating parameters (if any) during the initial performance test.</p>
<p>11. Existing non-emergency stationary RICE 100≤HP≤500 located at a major source of HAP, and existing non-emergency stationary CI RICE 300&lt;HP≤500 located at an area source of HAP</p>	<p>a. Reduce CO emissions</p>	<p>i. The average reduction of emissions of CO or formaldehyde, as applicable determined from the initial performance test is equal to or greater than the required CO or formaldehyde, as applicable, percent reduction.</p>
<p>12. Existing non-emergency stationary RICE 100≤HP≤500 located at a major source of HAP, and existing non-emergency stationary CI RICE 300&lt;HP≤500 located at an area source of HAP</p>	<p>a. Limit the concentration of formaldehyde or CO in the stationary RICE exhaust</p>	<p>i. The average formaldehyde or CO concentration, as applicable, corrected to 15 percent O<sub>2</sub>, dry basis, from the three test runs is less than or equal to the formaldehyde or CO emission limitation, as applicable.</p>
<p>13. Existing non-emergency 4SLB stationary RICE &gt;500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year</p>	<p>a. Install an oxidation catalyst</p>	<p>i. You have conducted an initial compliance demonstration as specified in § 63.6630(e) to show that the average reduction of emissions of CO is 93 percent or more, or the average CO concentration is less than or equal to 47 ppmvd at 15 percent O<sub>2</sub>;</p>

For each . . .	Complying with the requirement to . . .	You have demonstrated initial compliance if . . .
		ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b), or you have installed equipment to automatically shut down the engine if the catalyst inlet temperature exceeds 1350 °F.
14. Existing non-emergency 4SRB stationary RICE >500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year	a. Install NSCR	i. You have conducted an initial compliance demonstration as specified in § 63.6630(e) to show that the average reduction of emissions of CO is 75 percent or more, the average CO concentration is less than or equal to 270 ppmvd at 15 percent O <sub>2</sub> , or the average reduction of emissions of THC is 30 percent or more;
		ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b), or you have installed equipment to automatically shut down the engine if the catalyst inlet temperature exceeds 1250 °F.

[78 FR 6712, Jan. 30, 2013]



**Table 6 to Subpart ZZZZ of Part 63—Continuous Compliance With Emission Limitations, and Other Requirements**

As stated in § 63.6640, you must continuously comply with the emissions and operating limitations and work or management practices as required by the following:

**TABLE 6 TO SUBPART ZZZZ OF PART 63—CONTINUOUS COMPLIANCE WITH EMISSION LIMITATIONS, AND OTHER REQUIREMENTS**

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
1. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, and new or reconstructed non-emergency CI stationary RICE >500 HP located at a major source of HAP	a. Reduce CO emissions and using an oxidation catalyst, and using a CPMS	i. Conducting semiannual performance tests for CO to demonstrate that the required CO percent reduction is achieved <sup>a</sup> ; and ii. Collecting the catalyst inlet temperature data according to § 63.6625(b); and iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and
		v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
2. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, and new or reconstructed non-emergency CI stationary RICE >500 HP located at a major source of HAP	a. Reduce CO emissions and not using an oxidation catalyst, and using a CPMS	i. Conducting semiannual performance tests for CO to demonstrate that the required CO percent reduction is achieved <sup>a</sup> ; and ii. Collecting the approved operating parameter (if any) data according to § 63.6625(b); and iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
3. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, new or reconstructed non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP	a. Reduce CO emissions or limit the concentration of CO in the stationary RICE exhaust, and using a CEMS	i. Collecting the monitoring data according to § 63.6625(a), reducing the measurements to 1-hour averages, calculating the percent reduction or concentration of CO emissions according to § 63.6620; and ii. Demonstrating that the catalyst achieves the required percent reduction of CO emissions over the 4-hour averaging period, or that the emission remain at or below the CO concentration limit; and
		iii. Conducting an annual RATA of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B, as well as daily and periodic data quality checks in accordance with 40 CFR part 60, appendix F, procedure 1.
4. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP	a. Reduce formaldehyde emissions and using NSCR	i. Collecting the catalyst inlet temperature data according to § 63.6625(b); and
		ii. Reducing these data to 4-hour rolling averages; and
		iii. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and
		iv. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
5. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP	a. Reduce formaldehyde emissions and not using NSCR	i. Collecting the approved operating parameter (if any) data according to § 63.6625(b); and
		ii. Reducing these data to 4-hour rolling averages; and
		iii. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
6. Non-emergency 4SRB stationary RICE with a brake HP $\geq 5,000$ located at a major source of HAP	a. Reduce formaldehyde emissions	Conducting semiannual performance tests for formaldehyde to demonstrate that the required formaldehyde percent reduction is achieved, or to demonstrate that the average reduction of emissions of THC determined from the performance test is equal to or greater than 30 percent. <sup>a</sup>
7. New or reconstructed non-emergency stationary RICE $>500$ HP located at a major source of HAP and new or reconstructed non-emergency 4SLB stationary RICE $250 \leq \text{HP} \leq 500$ located at a major source of HAP	a. Limit the concentration of formaldehyde in the stationary RICE exhaust and using oxidation catalyst or NSCR	i. Conducting semiannual performance tests for formaldehyde to demonstrate that your emissions remain at or below the formaldehyde concentration limit <sup>a</sup> ; and ii. Collecting the catalyst inlet temperature data according to § 63.6625(b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and
		v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
8. New or reconstructed non-emergency stationary RICE $>500$ HP located at a major source of HAP and new or reconstructed non-emergency 4SLB stationary RICE $250 \leq \text{HP} \leq 500$ located at a major source of HAP	a. Limit the concentration of formaldehyde in the stationary RICE exhaust and not using oxidation catalyst or NSCR	i. Conducting semiannual performance tests for formaldehyde to demonstrate that your emissions remain at or below the formaldehyde concentration limit <sup>a</sup> ; and ii. Collecting the approved operating parameter (if any) data according to § 63.6625(b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
<p>9. Existing emergency and black start stationary RICE ≤500 HP located at a major source of HAP, existing non-emergency stationary RICE &lt;100 HP located at a major source of HAP, existing emergency and black start stationary RICE located at an area source of HAP, existing non-emergency stationary CI RICE ≤300 HP located at an area source of HAP, existing non-emergency 2SLB stationary RICE located at an area source of HAP, existing non-emergency stationary SI RICE located at an area source of HAP which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, existing non-emergency 4SLB and 4SRB stationary RICE ≤500 HP located at an area source of HAP, existing non-emergency 4SLB and 4SRB stationary RICE &gt;500 HP located at an area source of HAP that operate 24 hours or less per calendar year, and existing non-emergency 4SLB and 4SRB stationary RICE &gt;500 HP located at an area source of HAP that are remote stationary RICE</p>	<p>a. Work or Management practices</p>	<p>i. Operating and maintaining the stationary RICE according to the manufacturer's emission-related operation and maintenance instructions; or                      ii. Develop and follow your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.</p>
<p>10. Existing stationary CI RICE &gt;500 HP that are not limited use stationary RICE</p>	<p>a. Reduce CO emissions, or limit the concentration of CO in the stationary RICE exhaust, and using oxidation catalyst</p>	<p>i. Conducting performance tests every 8,760 hours or 3 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and</p>
		<p>ii. Collecting the catalyst inlet temperature data according to § 63.6625(b); and</p>
		<p>iii. Reducing these data to 4-hour rolling averages; and</p>
		<p>iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and</p>

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
		v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
11. Existing stationary CI RICE >500 HP that are not limited use stationary RICE	a. Reduce CO emissions, or limit the concentration of CO in the stationary RICE exhaust, and not using oxidation catalyst	i. Conducting performance tests every 8,760 hours or 3 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and
		ii. Collecting the approved operating parameter (if any) data according to § 63.6625(b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.
12. Existing limited use CI stationary RICE >500 HP	a. Reduce CO emissions or limit the concentration of CO in the stationary RICE exhaust, and using an oxidation catalyst	i. Conducting performance tests every 8,760 hours or 5 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and
		ii. Collecting the catalyst inlet temperature data according to § 63.6625(b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
		v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.
13. Existing limited use CI stationary RICE >500 HP	a. Reduce CO emissions or limit the concentration of CO in the stationary RICE exhaust, and not using an oxidation catalyst	i. Conducting performance tests every 8,760 hours or 5 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and
		ii. Collecting the approved operating parameter (if any) data according to § 63.6625(b); and
		iii. Reducing these data to 4-hour rolling averages; and
		iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.
14. Existing non-emergency 4SLB stationary RICE >500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year	a. Install an oxidation catalyst	i. Conducting annual compliance demonstrations as specified in § 63.6640(c) to show that the average reduction of emissions of CO is 93 percent or more, or the average CO concentration is less than or equal to 47 ppmvd at 15 percent O <sub>2</sub> ; and either ii. Collecting the catalyst inlet temperature data according to § 63.6625(b), reducing these data to 4-hour rolling averages; and maintaining the 4-hour rolling averages within the limitation of greater than 450 °F and less than or equal to 1350 °F for the catalyst inlet temperature; or iii. Immediately shutting down the engine if the catalyst inlet temperature exceeds 1350 °F.

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
15. Existing non-emergency 4SRB stationary RICE >500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year	a. Install NSCR	i. Conducting annual compliance demonstrations as specified in § 63.6640(c) to show that the average reduction of emissions of CO is 75 percent or more, the average CO concentration is less than or equal to 270 ppmvd at 15 percent O <sub>2</sub> , or the average reduction of emissions of THC is 30 percent or more; and either ii. Collecting the catalyst inlet temperature data according to § 63.6625(b), reducing these data to 4-hour rolling averages; and maintaining the 4-hour rolling averages within the limitation of greater than or equal to 750 °F and less than or equal to 1250 °F for the catalyst inlet temperature; or iii. Immediately shutting down the engine if the catalyst inlet temperature exceeds 1250 °F.

<sup>a</sup> After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

[78 FR 6715, Jan. 30, 2013]

**Table 7 to Subpart ZZZZ of Part 63—Requirements for Reports**

As stated in § 63.6650, you must comply with the following requirements for reports:

**TABLE 7 TO SUBPART ZZZZ OF PART 63—REQUIREMENTS FOR REPORTS**

For each . . .	You must submit a . . .	The report must contain . . .	You must submit the report . . .
1. Existing non-emergency, non-black start stationary RICE $100 \leq \text{HP} \leq 500$ located at a major source of HAP; existing non-emergency, non-black start stationary CI RICE $>500$ HP located at a major source of HAP; existing non-emergency 4SRB stationary RICE $>500$ HP located at a major source of HAP; existing non-emergency, non-black start stationary CI RICE $>300$ HP located at an area source of HAP; new or reconstructed non-emergency stationary RICE $>500$ HP located at a major source of HAP; and new or reconstructed non-emergency 4SLB stationary RICE $250 \leq \text{HP} \leq 500$ located at a major source of HAP	Compliance report	a. If there are no deviations from any emission limitations or operating limitations that apply to you, a statement that there were no deviations from the emission limitations or operating limitations during the reporting period. If there were no periods during which the CMS, including CEMS and CPMS, was out-of-control, as specified in § 63.8(c)(7), a statement that there were not periods during which the CMS was out-of-control during the reporting period; or	i. Semiannually according to the requirements in § 63.6650(b)(1)-(5) for engines that are not limited use stationary RICE subject to numerical emission limitations; and ii. Annually according to the requirements in § 63.6650(b)(6)-(9) for engines that are limited use stationary RICE subject to numerical emission limitations.
		b. If you had a deviation from any emission limitation or operating limitation during the reporting period, the information in § 63.6650(d). If there were periods during which the CMS, including CEMS and CPMS, was out-of-control, as specified in § 63.8(c)(7), the information in § 63.6650(e); or	i. Semiannually according to the requirements in § 63.6650(b).
		c. If you had a malfunction during the reporting period, the information in § 63.6650(c)(4).	i. Semiannually according to the requirements in § 63.6650(b).
2. New or reconstructed non-emergency stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis	Report	a. The fuel flow rate of each fuel and the heating values that were used in your calculations, and you must demonstrate that the percentage of heat input provided by landfill gas or digester gas, is equivalent to 10 percent or more of the gross heat input on an annual basis; and	i. Annually, according to the requirements in § 63.6650.



For each . . .	You must submit a . . .	The report must contain . . .	You must submit the report . . .
		b. The operating limits provided in your federally enforceable permit, and any deviations from these limits; and	i. See item 2.a.i.
		c. Any problems or errors suspected with the meters.	i. See item 2.a.i.
3. Existing non-emergency, non-black start 4SLB and 4SRB stationary RICE >500 HP located at an area source of HAP that are not remote stationary RICE and that operate more than 24 hours per calendar year	Compliance report	a. The results of the annual compliance demonstration, if conducted during the reporting period.	i. Semiannually according to the requirements in § 63.6650(b)(1)-(5).
4. Emergency stationary RICE that operate or are contractually obligated to be available for more than 15 hours per year for the purposes specified in § 63.6640(f)(2)(ii) and (iii) or that operate for the purposes specified in § 63.6640(f)(4)( ii)	Report	a. The information in § 63.6650(h)(1)	i. annually according to the requirements in § 63.6650(h)(2)-(3).

[78 FR 6719, Jan. 30, 2013]

**Table 8 to Subpart ZZZZ of Part 63—Applicability of General Provisions to Subpart ZZZZ.**

As stated in § 63.6665, you must comply with the following applicable general provisions.

<b>General provisions citation</b>	<b>Subject of citation</b>	<b>Applies to subpart</b>	<b>Explanation</b>
§ 63.1	General applicability of the General Provisions	Yes.	
§ 63.2	Definitions	Yes	Additional terms defined in § 63.6675.
§ 63.3	Units and abbreviations	Yes.	
§ 63.4	Prohibited activities and circumvention	Yes.	
§ 63.5	Construction and reconstruction	Yes.	
§ 63.6(a)	Applicability	Yes.	
§ 63.6(b)(1)-(4)	Compliance dates for new and reconstructed sources	Yes.	
§ 63.6(b)(5)	Notification	Yes.	
§ 63.6(b)(6)	[Reserved]		
§ 63.6(b)(7)	Compliance dates for new and reconstructed area sources that become major sources	Yes.	
§ 63.6(c)(1)-(2)	Compliance dates for existing sources	Yes.	
§ 63.6(c)(3)-(4)	[Reserved]		
§ 63.6(c)(5)	Compliance dates for existing area sources that become major sources	Yes.	
§ 63.6(d)	[Reserved]		
§ 63.6(e)	Operation and maintenance	No.	
§ 63.6(f)(1)	Applicability of standards	No.	
§ 63.6(f)(2)	Methods for determining compliance	Yes.	
§ 63.6(f)(3)	Finding of compliance	Yes.	
§ 63.6(g)(1)-(3)	Use of alternate standard	Yes.	
§ 63.6(h)	Opacity and visible emission standards	No	Subpart ZZZZ does not contain opacity or visible emission standards.
§ 63.6(i)	Compliance extension procedures and criteria	Yes.	

<b>General provisions citation</b>	<b>Subject of citation</b>	<b>Applies to subpart</b>	<b>Explanation</b>
§ 63.6(j)	Presidential compliance exemption	Yes.	
§ 63.7(a)(1)-(2)	Performance test dates	Yes	Subpart ZZZZ contains performance test dates at §§ 63.6610, 63.6611, and 63.6612.
§ 63.7(a)(3)	CAA section 114 authority	Yes.	
§ 63.7(b)(1)	Notification of performance test	Yes	Except that § 63.7(b)(1) only applies as specified in § 63.6645.
§ 63.7(b)(2)	Notification of rescheduling	Yes	Except that § 63.7(b)(2) only applies as specified in § 63.6645.
§ 63.7(c)	Quality assurance/test plan	Yes	Except that § 63.7(c) only applies as specified in § 63.6645.
§ 63.7(d)	Testing facilities	Yes.	
§ 63.7(e)(1)	Conditions for conducting performance tests	No.	Subpart ZZZZ specifies conditions for conducting performance tests at § 63.6620.
§ 63.7(e)(2)	Conduct of performance tests and reduction of data	Yes	Subpart ZZZZ specifies test methods at § 63.6620.
§ 63.7(e)(3)	Test run duration	Yes.	
§ 63.7(e)(4)	Administrator may require other testing under section 114 of the CAA	Yes.	
§ 63.7(f)	Alternative test method provisions	Yes.	
§ 63.7(g)	Performance test data analysis, recordkeeping, and reporting	Yes.	
§ 63.7(h)	Waiver of tests	Yes.	
§ 63.8(a)(1)	Applicability of monitoring requirements	Yes	Subpart ZZZZ contains specific requirements for monitoring at § 63.6625.
§ 63.8(a)(2)	Performance specifications	Yes.	
§ 63.8(a)(3)	[Reserved]		
§ 63.8(a)(4)	Monitoring for control devices	No.	
§ 63.8(b)(1)	Monitoring	Yes.	
§ 63.8(b)(2)-(3)	Multiple effluents and multiple monitoring systems	Yes.	

<b>General provisions citation</b>	<b>Subject of citation</b>	<b>Applies to subpart</b>	<b>Explanation</b>
§ 63.8(c)(1)	Monitoring system operation and maintenance	Yes.	
§ 63.8(c)(1)(i)	Routine and predictable SSM	No	
§ 63.8(c)(1)(ii)	SSM not in Startup Shutdown Malfunction Plan	Yes.	
§ 63.8(c)(1)(iii)	Compliance with operation and maintenance requirements	No	
§ 63.8(c)(2)-(3)	Monitoring system installation	Yes.	
§ 63.8(c)(4)	Continuous monitoring system (CMS) requirements	Yes	Except that subpart ZZZZ does not require Continuous Opacity Monitoring System (COMS).
§ 63.8(c)(5)	COMS minimum procedures	No	Subpart ZZZZ does not require COMS.
§ 63.8(c)(6)-(8)	CMS requirements	Yes	Except that subpart ZZZZ does not require COMS.
§ 63.8(d)	CMS quality control	Yes.	
§ 63.8(e)	CMS performance evaluation	Yes	Except for § 63.8(e)(5)(ii), which applies to COMS.
		Except that § 63.8(e) only applies as specified in § 63.6645.	
§ 63.8(f)(1)-(5)	Alternative monitoring method	Yes	Except that § 63.8(f)(4) only applies as specified in § 63.6645.
§ 63.8(f)(6)	Alternative to relative accuracy test	Yes	Except that § 63.8(f)(6) only applies as specified in § 63.6645.
§ 63.8(g)	Data reduction	Yes	Except that provisions for COMS are not applicable. Averaging periods for demonstrating compliance are specified at §§ 63.6635 and 63.6640.
§ 63.9(a)	Applicability and State delegation of notification requirements	Yes.	
§ 63.9(b)(1)-(5)	Initial notifications	Yes	Except that § 63.9(b)(3) is reserved.

General provisions citation	Subject of citation	Applies to subpart	Explanation
		Except that § 63.9(b) only applies as specified in § 63.6645.	
§ 63.9(c)	Request for compliance extension	Yes	Except that § 63.9(c) only applies as specified in § 63.6645.
§ 63.9(d)	Notification of special compliance requirements for new sources	Yes	Except that § 63.9(d) only applies as specified in § 63.6645.
§ 63.9(e)	Notification of performance test	Yes	Except that § 63.9(e) only applies as specified in § 63.6645.
§ 63.9(f)	Notification of visible emission (VE)/opacity test	No	Subpart ZZZZ does not contain opacity or VE standards.
§ 63.9(g)(1)	Notification of performance evaluation	Yes	Except that § 63.9(g) only applies as specified in § 63.6645.
§ 63.9(g)(2)	Notification of use of COMS data	No	Subpart ZZZZ does not contain opacity or VE standards.
§ 63.9(g)(3)	Notification that criterion for alternative to RATA is exceeded	Yes	If alternative is in use.
		Except that § 63.9(g) only applies as specified in § 63.6645.	
§ 63.9(h)(1)-(6)	Notification of compliance status	Yes	Except that notifications for sources using a CEMS are due 30 days after completion of performance evaluations. § 63.9(h)(4) is reserved.
			Except that § 63.9(h) only applies as specified in § 63.6645.
§ 63.9(i)	Adjustment of submittal deadlines	Yes.	
§ 63.9(j)	Change in previous information	Yes.	
§ 63.10(a)	Administrative provisions for recordkeeping/reporting	Yes.	
§ 63.10(b)(1)	Record retention	Yes	Except that the most recent 2 years of data do not have to be retained on site.
§ 63.10(b)(2)(i)-(v)	Records related to SSM	No.	

<b>General provisions citation</b>	<b>Subject of citation</b>	<b>Applies to subpart</b>	<b>Explanation</b>
§ 63.10(b)(2)(vi)-(xi)	Records	Yes.	
§ 63.10(b)(2)(xii)	Record when under waiver	Yes.	
§ 63.10(b)(2)(xiii)	Records when using alternative to RATA	Yes	For CO standard if using RATA alternative.
§ 63.10(b)(2)(xiv)	Records of supporting documentation	Yes.	
§ 63.10(b)(3)	Records of applicability determination	Yes.	
§ 63.10(c)	Additional records for sources using CEMS	Yes	Except that § 63.10(c)(2)-(4) and (9) are reserved.
§ 63.10(d)(1)	General reporting requirements	Yes.	
§ 63.10(d)(2)	Report of performance test results	Yes.	
§ 63.10(d)(3)	Reporting opacity or VE observations	No	Subpart ZZZZ does not contain opacity or VE standards.
§ 63.10(d)(4)	Progress reports	Yes.	
§ 63.10(d)(5)	Startup, shutdown, and malfunction reports	No.	
§ 63.10(e)(1) and (2)(i)	Additional CMS Reports	Yes.	
§ 63.10(e)(2)(ii)	COMS-related report	No	Subpart ZZZZ does not require COMS.
§ 63.10(e)(3)	Excess emission and parameter exceedances reports	Yes.	Except that § 63.10(e)(3)(i) (C) is reserved.
§ 63.10(e)(4)	Reporting COMS data	No	Subpart ZZZZ does not require COMS.
§ 63.10(f)	Waiver for recordkeeping/reporting	Yes.	
§ 63.11	Flares	No.	
§ 63.12	State authority and delegations	Yes.	
§ 63.13	Addresses	Yes.	
§ 63.14	Incorporation by reference	Yes.	
§ 63.15	Availability of information	Yes.	

[75 FR 9688, Mar. 3, 2010, as amended at 78 FR 6720, Jan. 30, 2013]

## Appendix A—Protocol for Using an Electrochemical Analyzer to Determine Oxygen and Carbon Monoxide Concentrations From Certain Engines

### 1.0 SCOPE AND APPLICATION. WHAT IS THIS PROTOCOL?

This protocol is a procedure for using portable electrochemical (EC) cells for measuring carbon monoxide (CO) and oxygen (O<sub>2</sub>) concentrations in controlled and uncontrolled emissions from existing stationary 4-stroke lean burn and 4-stroke rich burn reciprocating internal combustion engines as specified in the applicable rule.

#### 1.1 Analytes. What does this protocol determine?

This protocol measures the engine exhaust gas concentrations of carbon monoxide (CO) and oxygen (O<sub>2</sub>).

Analyte	CAS No.	Sensitivity
Carbon monoxide (CO)	630-08-0	Minimum detectable limit should be 2 percent of the nominal range or 1 ppm, whichever is less restrictive.
Oxygen (O <sub>2</sub> )	7782-44-7	

#### 1.2 Applicability. When is this protocol acceptable?

This protocol is applicable to 40 CFR part 63, subpart ZZZZ. Because of inherent cross sensitivities of EC cells, you must not apply this protocol to other emissions sources without specific instruction to that effect.

#### 1.3 Data Quality Objectives. How good must my collected data be?

Refer to Section 13 to verify and document acceptable analyzer performance.

#### 1.4 Range. What is the targeted analytical range for this protocol?

The measurement system and EC cell design(s) conforming to this protocol will determine the analytical range for each gas component. The nominal ranges are defined by choosing up-scale calibration gas concentrations near the maximum anticipated flue gas concentrations for CO and O<sub>2</sub>, or no more than twice the permitted CO level.

#### 1.5 Sensitivity. What minimum detectable limit will this protocol yield for a particular gas component?

The minimum detectable limit depends on the nominal range and resolution of the specific EC cell used, and the signal to noise ratio of the measurement system. The minimum detectable limit should be 2 percent of the nominal range or 1 ppm, whichever is less restrictive.

### 2.0 SUMMARY OF PROTOCOL

In this protocol, a gas sample is extracted from an engine exhaust system and then conveyed to a portable EC analyzer for measurement of CO and O<sub>2</sub> gas concentrations. This method provides measurement system performance specifications and sampling protocols to ensure reliable data. You may use additions to, or modifications of vendor supplied measurement systems (e.g., heated or unheated sample lines, thermocouples, flow meters, selective gas scrubbers, etc.) to meet the design

specifications of this protocol. Do not make changes to the measurement system from the as-verified configuration (Section 3.12).

### 3.0 DEFINITIONS

**3.1 Measurement System.** The total equipment required for the measurement of CO and O<sub>2</sub> concentrations. The measurement system consists of the following major subsystems:

**3.1.1 Data Recorder.** A strip chart recorder, computer or digital recorder for logging measurement data from the analyzer output. You may record measurement data from the digital data display manually or electronically.

**3.1.2 Electrochemical (EC) Cell.** A device, similar to a fuel cell, used to sense the presence of a specific analyte and generate an electrical current output proportional to the analyte concentration.

**3.1.3 Interference Gas Scrubber.** A device used to remove or neutralize chemical compounds that may interfere with the selective operation of an EC cell.

**3.1.4 Moisture Removal System.** Any device used to reduce the concentration of moisture in the sample stream so as to protect the EC cells from the damaging effects of condensation and to minimize errors in measurements caused by the scrubbing of soluble gases.

**3.1.5 Sample Interface.** The portion of the system used for one or more of the following: sample acquisition; sample transport; sample conditioning or protection of the EC cell from any degrading effects of the engine exhaust effluent; removal of particulate matter and condensed moisture.

**3.2 Nominal Range.** The range of analyte concentrations over which each EC cell is operated (normally 25 percent to 150 percent of up-scale calibration gas value). Several nominal ranges can be used for any given cell so long as the calibration and repeatability checks for that range remain within specifications.

**3.3 Calibration Gas.** A vendor certified concentration of a specific analyte in an appropriate balance gas.

**3.4 Zero Calibration Error.** The analyte concentration output exhibited by the EC cell in response to zero-level calibration gas.

**3.5 Up-Scale Calibration Error.** The mean of the difference between the analyte concentration exhibited by the EC cell and the certified concentration of the up-scale calibration gas.

**3.6 Interference Check.** A procedure for quantifying analytical interference from components in the engine exhaust gas other than the targeted analytes.

**3.7 Repeatability Check.** A protocol for demonstrating that an EC cell operated over a given nominal analyte concentration range provides a stable and consistent response and is not significantly affected by repeated exposure to that gas.

**3.8 Sample Flow Rate.** The flow rate of the gas sample as it passes through the EC cell. In some situations, EC cells can experience drift with changes in flow rate. The flow rate must be monitored and documented during all phases of a sampling run.

**3.9 Sampling Run.** A timed three-phase event whereby an EC cell's response rises and plateaus in a sample conditioning phase, remains relatively constant during a measurement data phase, then declines during a refresh phase. The sample conditioning phase exposes the EC cell to the gas sample for a length of time sufficient to reach a constant response. The measurement data phase is the time interval



during which gas sample measurements can be made that meet the acceptance criteria of this protocol. The refresh phase then purges the EC cells with CO-free air. The refresh phase replenishes requisite O<sub>2</sub> and moisture in the electrolyte reserve and provides a mechanism to de-gas or desorb any interference gas scrubbers or filters so as to enable a stable CO EC cell response. There are four primary types of sampling runs: pre-sampling calibrations; stack gas sampling; post-sampling calibration checks; and measurement system repeatability checks. Stack gas sampling runs can be chained together for extended evaluations, providing all other procedural specifications are met.

*3.10 Sampling Day.* A time not to exceed twelve hours from the time of the pre-sampling calibration to the post-sampling calibration check. During this time, stack gas sampling runs can be repeated without repeated recalibrations, providing all other sampling specifications have been met.

*3.11 Pre-Sampling Calibration/Post-Sampling Calibration Check.* The protocols executed at the beginning and end of each sampling day to bracket measurement readings with controlled performance checks.

*3.12 Performance-Established Configuration.* The EC cell and sampling system configuration that existed at the time that it initially met the performance requirements of this protocol.

#### 4.0 INTERFERENCES.

When present in sufficient concentrations, NO and NO<sub>2</sub> are two gas species that have been reported to interfere with CO concentration measurements. In the likelihood of this occurrence, it is the protocol user's responsibility to employ and properly maintain an appropriate CO EC cell filter or scrubber for removal of these gases, as described in Section 6.2.12.

#### 5.0 SAFETY. [RESERVED]

#### 6.0 EQUIPMENT AND SUPPLIES.

##### *6.1 What equipment do I need for the measurement system?*

The system must maintain the gas sample at conditions that will prevent moisture condensation in the sample transport lines, both before and as the sample gas contacts the EC cells. The essential components of the measurement system are described below.

##### *6.2 Measurement System Components.*

*6.2.1 Sample Probe.* A single extraction-point probe constructed of glass, stainless steel or other non-reactive material, and of length sufficient to reach any designated sampling point. The sample probe must be designed to prevent plugging due to condensation or particulate matter.

*6.2.2 Sample Line.* Non-reactive tubing to transport the effluent from the sample probe to the EC cell.

*6.2.3 Calibration Assembly (optional).* A three-way valve assembly or equivalent to introduce calibration gases at ambient pressure at the exit end of the sample probe during calibration checks. The assembly must be designed such that only stack gas or calibration gas flows in the sample line and all gases flow through any gas path filters.

*6.2.4 Particulate Filter (optional).* Filters before the inlet of the EC cell to prevent accumulation of particulate material in the measurement system and extend the useful life of the components. All filters must be fabricated of materials that are non-reactive to the gas mixtures being sampled.

**6.2.5 Sample Pump.** A leak-free pump to provide undiluted sample gas to the system at a flow rate sufficient to minimize the response time of the measurement system. If located upstream of the EC cells, the pump must be constructed of a material that is non-reactive to the gas mixtures being sampled.

**6.2.8 Sample Flow Rate Monitoring.** An adjustable rotameter or equivalent device used to adjust and maintain the sample flow rate through the analyzer as prescribed.

**6.2.9 Sample Gas Manifold (optional).** A manifold to divert a portion of the sample gas stream to the analyzer and the remainder to a by-pass discharge vent. The sample gas manifold may also include provisions for introducing calibration gases directly to the analyzer. The manifold must be constructed of a material that is non-reactive to the gas mixtures being sampled.

**6.2.10 EC cell.** A device containing one or more EC cells to determine the CO and O<sub>2</sub> concentrations in the sample gas stream. The EC cell(s) must meet the applicable performance specifications of Section 13 of this protocol.

**6.2.11 Data Recorder.** A strip chart recorder, computer or digital recorder to make a record of analyzer output data. The data recorder resolution (i.e., readability) must be no greater than 1 ppm for CO; 0.1 percent for O<sub>2</sub>; and one degree (either °C or °F) for temperature. Alternatively, you may use a digital or analog meter having the same resolution to observe and manually record the analyzer responses.

**6.2.12 Interference Gas Filter or Scrubber.** A device to remove interfering compounds upstream of the CO EC cell. Specific interference gas filters or scrubbers used in the performance-established configuration of the analyzer must continue to be used. Such a filter or scrubber must have a means to determine when the removal agent is exhausted. Periodically replace or replenish it in accordance with the manufacturer's recommendations.

## 7.0 REAGENTS AND STANDARDS. WHAT CALIBRATION GASES ARE NEEDED?

**7.1 Calibration Gases.** CO calibration gases for the EC cell must be CO in nitrogen or CO in a mixture of nitrogen and O<sub>2</sub>. Use CO calibration gases with labeled concentration values certified by the manufacturer to be within ± 5 percent of the label value. Dry ambient air (20.9 percent O<sub>2</sub>) is acceptable for calibration of the O<sub>2</sub> cell. If needed, any lower percentage O<sub>2</sub> calibration gas must be a mixture of O<sub>2</sub> in nitrogen.

**7.1.1 Up-Scale CO Calibration Gas Concentration.** Choose one or more up-scale gas concentrations such that the average of the stack gas measurements for each stack gas sampling run are between 25 and 150 percent of those concentrations. Alternatively, choose an up-scale gas that does not exceed twice the concentration of the applicable outlet standard. If a measured gas value exceeds 150 percent of the up-scale CO calibration gas value at any time during the stack gas sampling run, the run must be discarded and repeated.

### 7.1.2 Up-Scale O<sub>2</sub> Calibration Gas Concentration.

Select an O<sub>2</sub> gas concentration such that the difference between the gas concentration and the average stack gas measurement or reading for each sample run is less than 15 percent O<sub>2</sub>. When the average exhaust gas O<sub>2</sub> readings are above 6 percent, you may use dry ambient air (20.9 percent O<sub>2</sub>) for the up-scale O<sub>2</sub> calibration gas.

**7.1.3 Zero Gas.** Use an inert gas that contains less than 0.25 percent of the up-scale CO calibration gas concentration. You may use dry air that is free from ambient CO and other combustion gas products (e.g., CO<sub>2</sub>).

## 8.0 SAMPLE COLLECTION AND ANALYSIS

### 8.1 Selection of Sampling Sites.

**8.1.1 Control Device Inlet.** Select a sampling site sufficiently downstream of the engine so that the combustion gases should be well mixed. Use a single sampling extraction point near the center of the duct (e.g., within the 10 percent centroidal area), unless instructed otherwise.

**8.1.2 Exhaust Gas Outlet.** Select a sampling site located at least two stack diameters downstream of any disturbance (e.g., turbocharger exhaust, crossover junction or recirculation take-off) and at least one-half stack diameter upstream of the gas discharge to the atmosphere. Use a single sampling extraction point near the center of the duct (e.g., within the 10 percent centroidal area), unless instructed otherwise.

**8.2 Stack Gas Collection and Analysis.** Prior to the first stack gas sampling run, conduct that the pre-sampling calibration in accordance with Section 10.1. Use Figure 1 to record all data. Zero the analyzer with zero gas. Confirm and record that the scrubber media color is correct and not exhausted. Then position the probe at the sampling point and begin the sampling run at the same flow rate used during the up-scale calibration. Record the start time. Record all EC cell output responses and the flow rate during the "sample conditioning phase" once per minute until constant readings are obtained. Then begin the "measurement data phase" and record readings every 15 seconds for at least two minutes (or eight readings), or as otherwise required to achieve two continuous minutes of data that meet the specification given in Section 13.1. Finally, perform the "refresh phase" by introducing dry air, free from CO and other combustion gases, until several minute-to-minute readings of consistent value have been obtained. For each run use the "measurement data phase" readings to calculate the average stack gas CO and O<sub>2</sub> concentrations.

**8.3 EC Cell Rate.** Maintain the EC cell sample flow rate so that it does not vary by more than  $\pm 10$  percent throughout the pre-sampling calibration, stack gas sampling and post-sampling calibration check. Alternatively, the EC cell sample flow rate can be maintained within a tolerance range that does not affect the gas concentration readings by more than  $\pm 3$  percent, as instructed by the EC cell manufacturer.

## 9.0 QUALITY CONTROL (RESERVED)

## 10.0 CALIBRATION AND STANDARDIZATION

**10.1 Pre-Sampling Calibration.** Conduct the following protocol once for each nominal range to be used on each EC cell before performing a stack gas sampling run on each field sampling day. Repeat the calibration if you replace an EC cell before completing all of the sampling runs. There is no prescribed order for calibration of the EC cells; however, each cell must complete the measurement data phase during calibration. Assemble the measurement system by following the manufacturer's recommended protocols including for preparing and preconditioning the EC cell. Assure the measurement system has no leaks and verify the gas scrubbing agent is not depleted. Use Figure 1 to record all data.

**10.1.1 Zero Calibration.** For both the O<sub>2</sub> and CO cells, introduce zero gas to the measurement system (e.g., at the calibration assembly) and record the concentration reading every minute until readings are constant for at least two consecutive minutes. Include the time and sample flow rate. Repeat the steps in this section at least once to verify the zero calibration for each component gas.

**10.1.2 Zero Calibration Tolerance.** For each zero gas introduction, the zero level output must be less than or equal to  $\pm 3$  percent of the up-scale gas value or  $\pm 1$  ppm, whichever is less restrictive, for the CO channel and less than or equal to  $\pm 0.3$  percent O<sub>2</sub> for the O<sub>2</sub> channel.

**10.1.3 Up-Scale Calibration.** Individually introduce each calibration gas to the measurement system (e.g., at the calibration assembly) and record the start time. Record all EC cell output responses and the flow rate during this “sample conditioning phase” once per minute until readings are constant for at least two minutes. Then begin the “measurement data phase” and record readings every 15 seconds for a total of two minutes, or as otherwise required. Finally, perform the “refresh phase” by introducing dry air, free from CO and other combustion gases, until readings are constant for at least two consecutive minutes. Then repeat the steps in this section at least once to verify the calibration for each component gas. Introduce all gases to flow through the entire sample handling system (i.e., at the exit end of the sampling probe or the calibration assembly).

**10.1.4 Up-Scale Calibration Error.** The mean of the difference of the “measurement data phase” readings from the reported standard gas value must be less than or equal to  $\pm 5$  percent or  $\pm 1$  ppm for CO or  $\pm 0.5$  percent O<sub>2</sub>, whichever is less restrictive, respectively. The maximum allowable deviation from the mean measured value of any single “measurement data phase” reading must be less than or equal to  $\pm 2$  percent or  $\pm 1$  ppm for CO or  $\pm 0.5$  percent O<sub>2</sub>, whichever is less restrictive, respectively.

**10.2 Post-Sampling Calibration Check.** Conduct a stack gas post-sampling calibration check after the stack gas sampling run or set of runs and within 12 hours of the initial calibration. Conduct up-scale and zero calibration checks using the protocol in Section 10.1. Make no changes to the sampling system or EC cell calibration until all post-sampling calibration checks have been recorded. If either the zero or up-scale calibration error exceeds the respective specification in Sections 10.1.2 and 10.1.4 then all measurement data collected since the previous successful calibrations are invalid and re-calibration and re-sampling are required. If the sampling system is disassembled or the EC cell calibration is adjusted, repeat the calibration check before conducting the next analyzer sampling run.

## 11.0 ANALYTICAL PROCEDURE

The analytical procedure is fully discussed in Section 8.

## 12.0 CALCULATIONS AND DATA ANALYSIS

Determine the CO and O<sub>2</sub> concentrations for each stack gas sampling run by calculating the mean gas concentrations of the data recorded during the “measurement data phase”.

## 13.0 PROTOCOL PERFORMANCE

Use the following protocols to verify consistent analyzer performance during each field sampling day.

**13.1 Measurement Data Phase Performance Check.** Calculate the mean of the readings from the “measurement data phase”. The maximum allowable deviation from the mean for each of the individual readings is  $\pm 2$  percent, or  $\pm 1$  ppm, whichever is less restrictive. Record the mean value and maximum deviation for each gas monitored. Data must conform to Section 10.1.4. The EC cell flow rate must conform to the specification in Section 8.3.

*Example: A measurement data phase is invalid if the maximum deviation of any single reading comprising that mean is greater than  $\pm 2$  percent or  $\pm 1$  ppm (the default criteria). For example, if the mean = 30 ppm, single readings of below 29 ppm and above 31 ppm are disallowed).*

**13.2 Interference Check.** Before the initial use of the EC cell and interference gas scrubber in the field, and semi-annually thereafter, challenge the interference gas scrubber with NO and NO<sub>2</sub> gas standards that are generally recognized as representative of diesel-fueled engine NO and NO<sub>2</sub> emission values. Record the responses displayed by the CO EC cell and other pertinent data on Figure 1 or a similar form.

*13.2.1 Interference Response.* The combined NO and NO<sub>2</sub> interference response should be less than or equal to  $\pm 5$  percent of the up-scale CO calibration gas concentration.

*13.3 Repeatability Check.* Conduct the following check once for each nominal range that is to be used on the CO EC cell within 5 days prior to each field sampling program. If a field sampling program lasts longer than 5 days, repeat this check every 5 days. Immediately repeat the check if the EC cell is replaced or if the EC cell is exposed to gas concentrations greater than 150 percent of the highest up-scale gas concentration.

*13.3.1 Repeatability Check Procedure.* Perform a complete EC cell sampling run (all three phases) by introducing the CO calibration gas to the measurement system and record the response. Follow Section 10.1.3. Use Figure 1 to record all data. Repeat the run three times for a total of four complete runs. During the four repeatability check runs, do not adjust the system except where necessary to achieve the correct calibration gas flow rate at the analyzer.

*13.3.2 Repeatability Check Calculations.* Determine the highest and lowest average "measurement data phase" CO concentrations from the four repeatability check runs and record the results on Figure 1 or a similar form. The absolute value of the difference between the maximum and minimum average values recorded must not vary more than  $\pm 3$  percent or  $\pm 1$  ppm of the up-scale gas value, whichever is less restrictive.

14.0 POLLUTION PREVENTION (RESERVED)

15.0 WASTE MANAGEMENT (RESERVED)

16.0 ALTERNATIVE PROCEDURES (RESERVED)

17.0 REFERENCES

- (1) "Development of an Electrochemical Cell Emission Analyzer Test Protocol", Topical Report, Phil Juneau, Emission Monitoring, Inc., July 1997.
- (2) "Determination of Nitrogen Oxides, Carbon Monoxide, and Oxygen Emissions from Natural Gas-Fired Engines, Boilers, and Process Heaters Using Portable Analyzers", EMC Conditional Test Protocol 30 (CTM-30), Gas Research Institute Protocol GRI-96/0008, Revision 7, October 13, 1997.
- (3) "ICAC Test Protocol for Periodic Monitoring", EMC Conditional Test Protocol 34 (CTM-034), The Institute of Clean Air Companies, September 8, 1999.
- (4) "Code of Federal Regulations", Protection of Environment, 40 CFR, Part 60, Appendix A, Methods 1-4; 10.



"												
"												

[78 FR 6721, Jan. 30, 2013]

**Indiana Department of Environmental Management  
Office of Air Quality**

Technical Support Document (TSD) for a  
Part 70 Significant Permit Modification

**Source Description and Location**

Source Name:	Cargill, Inc. - Soybean Processing Division
Source Location:	1502 Wabash Avenue, Lafayette, Indiana 47905
County:	Tippecanoe
SIC Code:	2075 (Soybean Oil Mills)
Operation Permit No.:	T157-25200-00038
Operation Permit Issuance Date:	January 7, 2012
Permit Modification No.:	157-32522-00038
Permit Reviewer:	Deborah Cole

**Existing Approvals**

The source was issued Part 70 Operating Permit No. 057-25200-00038 on January 7, 2010.

The source has since received the following approvals:

- (a) Significant Permit Modification No. 057-29544-00038, issued on December 10, 2010.

**County Attainment Status**

The source is located in Tippecanoe County.

Pollutant	Designation
SO <sub>2</sub>	Better than national standards.
CO	Unclassifiable or attainment effective November 15, 1990.
O <sub>3</sub>	Unclassifiable or attainment effective June 15, 2004, for the 8-hour ozone standard. <sup>1</sup>
PM <sub>10</sub>	Unclassifiable effective November 15, 1990.
NO <sub>2</sub>	Cannot be classified or better than national standards.
Pb	Not designated.

<sup>1</sup>Unclassifiable or attainment effective October 18, 2000, for the 1-hour ozone standard which was revoked effective June 15, 2005.

Unclassifiable or attainment effective April 5, 2005, for PM<sub>2.5</sub>.

- (a) **Ozone Standards**  
Volatile organic compounds (VOC) and Nitrogen Oxides (NOx) are regulated under the Clean Air Act (CAA) for the purposes of attaining and maintaining the National Ambient Air Quality Standards (NAAQS) for ozone. Therefore, VOC and NOx emissions are considered when evaluating the rule applicability relating to ozone. Tippecanoe County has been designated as attainment or unclassifiable for ozone. Therefore, VOC and NOx emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2.



- (b) **PM<sub>2.5</sub>**  
Tippecanoe County has been classified as attainment for PM<sub>2.5</sub>. On May 8, 2008 U.S. EPA promulgated the requirements for Prevention of Significant Deterioration (PSD) for PM<sub>2.5</sub> emissions. These rules became effective on July 15, 2008. On May 4, 2011 the air pollution control board issued an emergency rule establishing the direct PM<sub>2.5</sub> significant level at ten (10) tons per year. This rule became effective, June 28, 2011. Therefore, direct PM<sub>2.5</sub>, SO<sub>2</sub>, and NO<sub>x</sub> emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2. See the State Rule Applicability – Entire Source section.
- (c) **Other Criteria Pollutants**  
Tippecanoe County has been classified as attainment or unclassifiable in Indiana for all regulated. Therefore, these emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2.

### Fugitive Emissions

This type of operation is not one of the twenty-eight (28) listed source categories under 326 IAC 2-2, 326 IAC 2-3, or 326 IAC 2-7, however, there is an applicable New Source Performance Standard that was in effect on August 7, 1980, therefore fugitive emissions are counted toward the determination of PSD, Emission Offset, and Part 70 Permit applicability.

### Source Status

The table below summarizes the potential to emit of the entire source, prior to the proposed modification, after consideration of all enforceable limits established in the effective permits:

Pollutant	Emissions (ton/yr)*
PM	348.16
PM <sub>10</sub>	711.73
PM <sub>2.5</sub>	711.73
SO <sub>2</sub>	42.62
VOC	45.77
NO <sub>x</sub>	51.70
CO	68.97
GHGs as CO <sub>2</sub> e	333.55
HAPs	27.92

\*This table was compiled from limited PTE emission calculations contained in the First TV Renewal # 157-25200-00038, issued on January 7, 2010.

- (a) This existing source is a major stationary source, under PSD (326 IAC 2-2), because PTE of PM<sub>10</sub> and PM<sub>2.5</sub> is emitted at a rate of 250 tons per year or more, emissions of GHGs are less than one hundred thousand (100,000 tons of CO<sub>2</sub> equivalent emissions (CO<sub>2</sub>e per year and it is not one of the twenty-eight (28) listed source categories, as specified in 326 IAC 2-2-1(ff)(1).
- (b) This existing source is a major source of HAPs, as defined in 40 CFR 63.2, because HAP emissions are greater than ten (10) tons per year for a single HAP. Therefore, this source is a major source under Section 112 of the Clean Air Act (CAA).

### Description of Proposed Modification

The Office of Air Quality (OAQ) has reviewed a modification application, submitted by Cargill, Inc. - Soybean Processing Division, on November 16, 2012 relating to the addition of two insignificant activities at the facility located in Lafayette, Indiana. The application was submitted in response to a violation letter, dated October 16, 2012, received from the Indiana Department of Environmental Management. The letter is a result of an inspection done on June 13, 2012 by an IDEM OAQ compliance inspector which revealed that the source constructed and operated two specifically regulated insignificant activities without a permit: a sixty-six (66) horsepower diesel powered air compressor and a parts washer.

The following are the new emissions units:

- (a) One (1) sixty-six (66) horsepower, non-emergency diesel powered air compressor, constructed in 2002, using a maximum of 8.8 gallons of #2 diesel fuel per hour.

This diesel powered air compressor is an affected facility under 40 CFR 63, Subpart ZZZZ.

- (b) One (1) parts washing station, constructed in 2002, with a maximum capacity of 145 gallons per year exhausting inside.

### Enforcement Issues

IDEM is aware that equipment has been operated prior to receipt of the proper permit. IDEM is reviewing this matter and will take the appropriate action. This proposed approval is intended to satisfy the requirements of the construction permit rules.

### Emission Calculations

See Appendix A of this Technical Support Document for detailed emission calculations.

### Permit Level Determination – Part 70

Pursuant to 326 IAC 2-1.1-1(16), Potential to Emit is defined as “the maximum capacity of a stationary source or emission unit to emit any air pollutant under its physical and operational design. Any physical or operational limitation on the capacity of a source to emit an air pollutant, including air pollution control equipment and restrictions on hours of operation or type or amount of material combusted, stored, or processed shall be treated as part of its design if the limitation is enforceable by the U. S. EPA, IDEM, or the appropriate local air pollution control agency.”

The following table is used to determine the appropriate permit level under 326 IAC 2-7-10.5. This table reflects the PTE of the diesel generator and the parts washer before controls. Control equipment is not considered federally enforceable until it has been required in a federally enforceable permit.

<b>Increase in PTE Before Controls of the Modification</b>	
<b>Pollutant</b>	<b>Potential To Emit (ton/yr)</b>
PM	0.64
PM <sub>10</sub>	0.64
PM <sub>2.5</sub>	0.64
SO <sub>2</sub>	0.59
NO <sub>x</sub>	8.96
VOC	1.22
CO	1.93
Single HAPs	<10
Total HAPs	<25

(a) Approval to Construct

This modification is not subject to the source modification requirements under 326 IAC 2-7-10.5 because the emissions are at exemption levels.

(b) Approval to Operate

The modification will be incorporated into the Part 70 Operating Permit through a significant permit modification issued pursuant to 326 IAC 2-7-12(d)(1), because the modification incorporates applicable portions of the National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines, 40 CFR 63, Subpart ZZZZ under Title I of the Clean Air Act (CAA).

**Permit Level Determination – PSD**

This modification to an existing major stationary source is not major because the emissions increase is less than the PSD major source thresholds. Therefore, pursuant to 326 IAC 2-2, the PSD requirements do not apply.

Process/ Emission Unit	PM	PM <sub>10</sub>	PM <sub>2.5</sub>	VOC	CO	SO <sub>2</sub>	NO <sub>x</sub>	GHG
Diesel Air Compressor	0.64	0.64	0.64	0.73	1.93	0.59	8.96	333.55
Parts Washer	-	-	-	0.49	-	-	-	-
<b>Total</b>	<b>0.64</b>	<b>0.64</b>	<b>0.64</b>	<b>1.12</b>	<b>1.93</b>	<b>0.59</b>	<b>8.96</b>	<b>333.55</b>
<b>PSD Significant Levels</b>	<b>25</b>	<b>15</b>	<b>10</b>	<b>40</b>	<b>100</b>	<b>40</b>	<b>40</b>	<b>75,000</b>

**Federal Rule Applicability Determination**

The following federal rules are applicable to the source due to this modification:

**NSPS**

- (a) The requirements of the New Source Performance Standard for Stationary Compression Ignition Internal combustion Engines, 40 CFR 60, Subpart IIII (326 IAC 12), are not included in the permit, since the one (1) emergency air compressor was manufactured before April 1, 2006.

- (b) The requirements of the New Source Performance Standard for Stationary Spark Ignition Internal Combustion Engines, 40 CFR 60, subpart JJJJ (326 IAC 12), are not included in the permit since the one (1) emergency air compressor was manufactured before July 1, 2008.
- (c) There are no New Source Performance Standards (NSPS)(326 IAC 12 and 40 CFR Part 60) applicable to this proposed modification.

### **NESHAP**

- (a) The requirements of the National Emission Standards for Hazardous Air Pollutants for Halogenated Solvent Cleaning, 40 CFR 63, Subpart T, are not included in the permit since the parts washer does not use any solvent containing any of the target HAPs as defined in § 63.460.
- (b) This generator is subject to the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (40 CFR 63.6580, Subpart ZZZZ), which is incorporated by reference as 326 IAC 20-82. The unit subject to this rule is the one (1) 66 horsepower diesel fired air compressor.

The emission unit is subject to the following portions of Subpart ZZZZ:

- (1) 63.6602, Table 2c - No. 2
- (2) 63.6605
- (3) 63.6625 (e), (h), (i)
- (4) 63.6640
- (5) 63.6655 (a), (d), (e)

The provisions of 40 CFR 63 Subpart A – General Provisions, which are incorporated as 326 IAC 20-1-1, apply to the facility described in this section except when otherwise specified in 40 CFR 63 Subpart ZZZZ.

- (c) There are no other National Emission Standards for Hazardous Air Pollutants (NESHAP), 40 CFR Part 63, applicable to this proposed modification.

### **CAM**

Since there are no controls associated with the new units, the requirements of 40 CFR Part 64, CAM are not applicable to any of the new units as part of this modification.

<b>State Rule Applicability Determination</b>
---

The following state rule is applicable to the source due to the modification:

#### **D.4.1 Volatile Organic Compounds (VOC) [326 IAC 8-3-2]**

- (a) Pursuant to 326 IAC 8-3-2(a) (Cold Cleaner Degreaser Control Equipment and Operating Requirements, the owner or operator of a cold cleaner degreaser shall ensure that the following control equipment and operating requirements are met:
  - (1) Equip the degreaser with a cover.
  - (2) Equip the degreaser with a device for draining cleaned parts.
  - (3) Close the cover whenever articles are not being handled in the degreaser.
  - (4) Drain cleaned articles for at least fifteen (15) seconds or until dripping ceases.

- (5) Provide a permanent, conspicuous label that lists the operating requirements in subdivisions (3), (4), (6), and (7).
  - (6) Store waste solvent only in closed containers.
  - (7) Prohibit the disposal or transfer of waste solvent in such a manner could allow greater than twenty percent (20%) of the waste solvent by weight to evaporate.
- (b) The owner or operator of a cold cleaner degreaser subject to this subsection shall ensure the following additional control equipment and operating requirements are met:
- (1) Equip the degreaser with one (1) of the following control devices if the solvent is heated to a temperature of greater than forty-eight and nine-tenths (48.9) degrees Celsius (one hundred twenty (120) degrees Fahrenheit):
    - (A) A freeboard that attains a freeboard ratio of seventy-five hundredths (0.75) or greater.
    - (B) A water cover when solvent used is insoluble in, and heavier than, water.
    - (C) A refrigerated chiller.
    - (D) Carbon adsorption.
    - (E) An alternative system of demonstrated equivalent or better control as those outlined in clauses (A) through (D) that is approved by the department. An alternative system shall be submitted to the U.S. EPA as a SIP revision.
  - (2) Ensure that the degreaser cover is designed so that it can be easily operated with one (1) hand if the solvent is agitated or heated.
  - (3) If used, solvent spray:
    - (A) must be a solid, fluid stream; and
    - (B) shall be applied at a pressure that does not cause excessive splashing.

...

### Compliance Determination and Monitoring Requirements

Permits issued under 326 IAC 2-7 are required to ensure that sources can demonstrate compliance with all applicable state and federal rules on a continuous basis. All state and federal rules contain compliance provisions; however, these provisions do not always fulfill the requirement for a continuous demonstration. When this occurs, IDEM, OAQ, in conjunction with the source, must develop specific conditions to satisfy 326 IAC 2-7-5. As a result, Compliance Determination Requirements are included in the permit. The Compliance Determination Requirements in Section D of the permit are those conditions that are found directly within state and federal rules and the violation of which serves as grounds for enforcement action.

If the Compliance Determination Requirements are not sufficient to demonstrate continuous compliance, they will be supplemented with Compliance Monitoring Requirements, also in Section D of the permit. Unlike Compliance Determination Requirements, failure to meet Compliance

Monitoring conditions would serve as a trigger for corrective actions and not grounds for enforcement action. However, a violation in relation to a compliance monitoring condition will arise through a source's failure to take the appropriate corrective actions within a specific time period.

There are no compliance monitoring requirements for the new units involved in this modification.

### Proposed Changes

The changes listed below have been made to Part 70 Operating Permit No. T157-25200-00038. Deleted language appears as ~~strike throughs~~ and new language appears in **bold**:

A.3 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-7-4(c)]  
[326 IAC 2-7-5(15)]

This stationary source also includes the following insignificant activities, as defined in 326 IAC 2-7-1(21):

...

- (3) **One (1) sixty-six (66) horsepower, non-emergency diesel powered air compressor, constructed in 2002, using a maximum of 8.8 gallons of #2 diesel fuel per hour.**

**This diesel powered air compressor is an affected facility under 40 CFR 63, Subpart ZZZZ.**

...

- (e) Cleaners and solvents characterized as:

...

- (3) **One (1) parts washing station, constructed in 2002, with a maximum capacity of 145 gallons per year, exhausting inside.**

...

#### SECTION D.4

#### FACILITY OPERATION CONDITIONS

##### Facility Description [326 IAC 2-7-5(15)] Insignificant Activity

**One (1) parts washing station, constructed in 2002, with a maximum capacity of 145 gallons per year, exhausting inside.**

**(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)**

##### D.4.1 Volatile Organic Compounds (VOC) [326 IAC 8-3-2]

- (a) Pursuant to 326 IAC 8-3-2(a) (Cold Cleaner Degreaser Control Equipment and Operating Requirements, the owner or operator of a cold cleaner degreaser shall ensure that the following control equipment and operating requirements are met:

- (1) Equip the degreaser with a cover.
- (2) Equip the degreaser with a device for draining cleaned parts.
- (3) Close the cover whenever articles are not being handled in the degreaser.

- (4) Drain cleaned articles for at least fifteen (15) seconds or until dripping ceases.**
  - (5) Provide a permanent, conspicuous label that lists the operating requirements in subdivisions (3), (4), (6), and (7).**
  - (6) Store waste solvent only in closed containers.**
  - (7) Prohibit the disposal or transfer of waste solvent in such a manner could allow greater than twenty percent (20%) of the waste solvent by weight to evaporate.**
- (b) The owner or operator of a cold cleaner degreaser subject to this subsection shall ensure the following additional control equipment and operating requirements are met:**
- (1) Equip the degreaser with one (1) of the following control devices if the solvent is heated to a temperature of greater than forty-eight and nine-tenths (48.9) degrees Celsius (one hundred twenty (120) degrees Fahrenheit):**
    - (A) A freeboard that attains a freeboard ratio of seventy-five hundredths (0.75) or greater.**
    - (B) A water cover when solvent used is insoluble in, and heavier than, water.**
    - (C) A refrigerated chiller.**
    - (D) Carbon adsorption.**
    - (E) An alternative system of demonstrated equivalent or better control as those outlined in clauses (A) through (D) that is approved by the department. An alternative system shall be submitted to the U.S. EPA as a SIP revision.**
  - (2) Ensure that the degreaser cover is designed so that it can be easily operated with one (1) hand if the solvent is agitated or heated.**
  - (3) If used, solvent spray:**
    - (A) must be a solid, fluid stream; and**
    - (B) shall be applied at a pressure that does not cause excessive splashing.**

...

**SECTION E.4 National Emissions Standards for Hazardous Air pollutants for Stationary Reciprocating Internal Combustion Engines (40 CFR 63.6580, Subpart ZZZZ) which is incorporated by reference as 326 IAC 12-1.**

**Facility Description [326 IAC 2-7-5(15)] Insignificant Activities**

- (3) One (1) sixty-six (66) horsepower, non-emergency diesel powered air compressor, constructed in 2002, using a maximum of 8.8 gallons of #2 diesel fuel per hour.

This diesel powered air compressor is an affected facility under 40 CFR 63, Subpart ZZZZ.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

**E.4.1 General Provisions Relating to NESHAP ZZZZ [326 IAC 12-1] [40 CFR 60, Subpart A]**

- (a) The provisions of 40 CFR 60, Subpart A – General Provisions, which are incorporated by reference in 326 IAC 12-1-1, apply to the facilities described in this Section E.4, except when otherwise specified in 40 CFR 63, Subpart ZZZZ.

- (b) Pursuant to 40 CFR 60.19, the Permittee shall submit all required notifications and reports to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Ave.  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

**E.4.2 National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines [40 CFR Part 63, Subpart ZZZZ] [326 IAC 20]**

Pursuant to 40 CFR Part 60, Subpart IIII, the Permittee shall comply with the provisions of Standards of Performance for National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines, which are incorporated by reference as 326 IAC 20, for the emergency generator as follows. The full text of Subpart ZZZZ may be found in Attachment A to this permit.

The emission unit is subject to the following portions of Subpart ZZZZ:

- (1) 63.6602, Table 2c - No. 2
- (2) 63.6605
- (3) 63.6625 (e), (h), (i)
- (4) 63.6640
- (5) 63.6655 (a), (d), (e)



**Additional Changes:**

*On October 27, 2010, the Indiana Air Pollution Control Board issued revisions to 326 IAC 2. These revisions resulted in changes to the rule cites listed in the permit but these changes are not changes to the underlying provisions of the rule.*

*Additionally, IDEM, OAQ has decided to make revisions to the permit as described below in order to update the language to match the most current version of the applicable rule, to eliminate redundancy within the permit and to provide clarification regarding the requirements of specific conditions.*

**SECTION A SOURCE SUMMARY**

...

A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(~~15~~)(14)] [326 IAC 2-7-1(22)]  
The Permittee owns and operates a stationary soybean oil extraction plant consisting of conventional desolventizer system and flake desolventizer system.

...

A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)] [326 IAC 2-7-5(~~15~~)(14)]  
This stationary source consists of the following emission units and pollution control devices:

...

A.3 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-7-4(c)] [326 IAC 2-7-5(~~15~~)(14)]  
This stationary source also includes the following insignificant activities, as defined in 326 IAC 2-7-1 (21):

...

**SECTION B GENERAL CONDITIONS**

...

B.10 Preventive Maintenance Plan [326 IAC 2-7-5(1),(3) and (13) (12) [326 IAC 2-7-6(1) and (6)] [326 IAC 1-6-3]  
(a) A Preventive Maintenance Plan meets the requirements of 326 IAC 1-6-3 if it includes, at a minimum:

...

B.11 Emergency Provisions [326 IAC 2-7-16]  
(a) An emergency, as defined in 326 IAC 2-7-1(12), is not an affirmative defense for an action brought for noncompliance with a federal or state health-based emission limitation.

...

(e) The Permittee seeking to establish the occurrence of an emergency shall make records available upon request to ensure that failure to implement a PMP did not cause or contribute to an exceedance of any limitations on emissions. However, IDEM, OAQ may require that the Preventive Maintenance Plans required under 326 IAC 2-7-4(c)(~~9~~)(8) be revised in response to an emergency.

...

B.19 Operational Flexibility [326 IAC 2-7-20] [326 IAC 2-7-10.5]

- (a) The Permittee may make any change or changes at the source that are described in 326 IAC 2-7-20(b), ~~or (c), or (e)~~ without a prior permit revision, if each of the following conditions is met:

...

- (5) The Permittee maintains records on-site, on a rolling five (5) year basis, which document all such changes and emission trades that are subject to 326 IAC 2-7-20(b), ~~or (c), or (e)~~. The Permittee shall make such records available, upon reasonable request, for public review.

Such records shall consist of all information required to be submitted to IDEM, OAQ in the notices specified in 326 IAC 2-7-20(b), ~~or (c), or (e), and (e)(2)~~.

**SECTION C SOURCE OPERATION CONDITIONS**

Entire Source
---------------

...

C.13 Risk Management Plan [326 IAC 2-7-5(~~42~~) (11)] [40 CFR 68]

If a regulated substance, as defined in 40 CFR 68, is present at a source in more than a threshold quantity, the Permittee must comply with the applicable requirements of 40 CFR 68.

...

C.17 General Record Keeping Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [326 IAC 2-2] [326 IAC 2-3]

- (a) Records of all required monitoring data, reports and support information required by this permit shall be retained for a period of at least five (5) years from the date of monitoring sample, measurement, report, or application. **Support information includes the following:**

- (AA) All calibration and maintenance records.
- (BB) All original strip chart recordings for continuous monitoring instrumentation.
- (CC) Copies of all reports required by the FESOP
- (DD)

Records of required monitoring information include the following:

- (AA) The date, place as defined in this permit, and time of sampling or measurements.
- (BB) The dates analyses were performed.
- (CC) The company or entity that performed the analyses.
- (DD) The analytical techniques or methods used.
- (EE) The results of such analyses.
- (FF) The operating conditions as existing at the time of sampling or measurement.

...

- (c) If there is a reasonable possibility (as defined in ~~40 CFR 51.165(a)(6)(vi)(A), 40 CFR 51.165(a)(6)(vi)(B), 40 CFR 51.166(r)(6)(vi)(a), and/or 40 CFR 51.166(r)(6)(vi)(b)~~) **326 IAC 2-2-8(b)(6)(A), 326 IAC 2-2-8(b)(6)(b), 326 IAC 2-3-2(I)(6)(A), and/or 326 IAC 2-3-2(I)(6)(B)** that a "project" (as defined in 326 IAC 2-2-1(qq) and/or 326 IAC 2-3-1(II)) at

an existing emissions unit, other than projects at a source with a Plantwide Applicability Limitation (PAL), which is not part of a "major modification" (as defined in 326 IAC 2-2-1(~~ee~~)(**dd**) and/or 326 IAC 2-3-1(~~z~~)(**y**)) may result in significant emissions increase and the Permittee elects to utilize the "projected actual emissions" (as defined in 326 IAC 2-2-1(~~ff~~)(**pp**) and/or 326 IAC 2-3-1(~~mm~~)(**kk**)), the Permittee shall comply with following:

(1) Before beginning actual construction of the "project" (as defined in 326 IAC 2-2-1(~~qq~~)(**oo**) and/or 326 IAC 2-3-1(~~ll~~)(**jj**)) at an existing emissions unit, document and maintain the following records:

...  
(C) A description of the applicability test used to determine that the project is not a major modification for any regulated NSR pollutant, including:

...  
(iii) Amount of emissions excluded under section 326 IAC 2-2-1(~~rr~~)(**pp**)(2)(A)(iii) and/or 326 IAC 2-3-1(~~nn~~)(**kk**)(2)(A)(iii); and

...  
(d) If there is a reasonable possibility (as defined in ~~40 CFR 51.165(a)(6)(vi)(A) and/or 40 CFR 51.166(r)(6)(vi)(a)~~ **326 IAC 2-2-8(b)(6)(A) and/or 326 IAC 2-3-2(I)(6)(A)**) that a "project" (as defined in 326 IAC 2-2-1(~~qq~~)(**oo**) and/or 326 IAC 2-3-1(~~ll~~)(**jj**)) at an existing emissions unit, other than projects at a source with a Plantwide Applicability Limitation (PAL), which is not part of a "major modification" (as defined in 326 IAC 2-2-1(~~ee~~)(**dd**) and/or 326 IAC 2-3-1(~~z~~)(**y**)) may result in significant emissions increase and the Permittee elects to utilize the "projected actual emissions" (as defined in 326 IAC 2-2-1(~~ff~~)(**pp**) and/or 326 IAC 2-3-1(~~mm~~)(**kk**)), the Permittee shall comply with following:

...  
C.18 General Reporting Requirements [326 IAC 2-7-5(3)(C)] [326 IAC 2-1.1-11] [326 IAC 2-2]

(a) The Permittee shall submit the attached Quarterly Deviation and Compliance Monitoring Report or its equivalent. **Proper notice submittal under Section B - Emergency Provisions satisfies the reporting requirements of paragraph (a) of Section C - General Reporting.** Any deviation from permit requirements, the date(s) of each deviation, the cause of the deviation, and the response steps taken must be reported except that a deviation required to be reported pursuant to an applicable requirement that exists independent of this permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. This report shall be submitted not later than thirty (30) days after the end of the reporting period. The Quarterly Deviation and Compliance Monitoring Report shall include a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(34). A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit.

...  
(e) If the Permittee is required to comply with the recordkeeping provisions of (d) in Section C - General Record Keeping Requirements for any "project" (as defined in 326 IAC 2-2-1(~~qq~~)(**oo**) and/or 326 IAC 2-3-1 (~~ll~~)(**jj**)) at an existing emissions unit, and the project meets the following criteria, then the Permittee shall submit a report to IDEM, OAQ:

(1) The annual emissions, in tons per year, from the project identified in (c)(1) in Section C- General Record Keeping Requirements exceed the baseline actual emissions, as documented and maintained under Section C- General Record Keeping Requirements (c)(1)(C)(i), by a significant amount, as defined in

326 IAC 2-2-1 ~~(xx)~~(**ww**) and/or 326 IAC 2-3-1~~(qq)~~(**pp**), for that regulated NSR pollutant, and

...

**SECTION D.1 FACILITY OPERATION CONDITIONS - Soybean Processing Facilities**

...

**D.1.4 Preventive Maintenance Plan [326 IAC 2-7-5~~(13)~~ (12)][326 IAC 1-6-3]**

A Preventive Maintenance Plan is required for this facility and any control devices. Section B - Preventive Maintenance Plan contains the Permittee's obligation with regard to the preventive maintenance plan required by this condition.

...

**SECTION D.2 FACILITY OPERATION CONDITIONS - Boilers**

...

**D.2.4 Preventive Maintenance Plan [326 IAC 2-7-5~~(13)~~(12)][326 IAC 1-6-3]**

A Preventive Maintenance Plan is required for the boilers. Section B - Preventive Maintenance Plan contains the Permittee's obligation with regard to the preventive maintenance plan required by this condition.

...

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH  
PART 70 OPERATING PERMIT  
QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT**

Source Name: Cargill, Inc. - Soybean Processing Division  
Source Address: 1502 Wabash Avenue, Lafayette, Indiana 47905  
Part 70 Permit No.: T157-25200-00038

Months: \_\_\_\_\_ to \_\_\_\_\_ Year: \_\_\_\_\_

This report shall be submitted quarterly based on a calendar year. **Proper notice submittal under Section B - Emergency Provisions satisfies the reporting requirements of paragraph (a) of Section C - General Reporting.** Any deviation from the requirements of this permit, the date(s) of each deviation, the probable cause of the deviation, and the response steps taken must be reported. A deviation required to be reported pursuant to an applicable requirement that exists independent of the permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. Additional pages may be attached if necessary. If no deviations occurred, please specify in the box marked "No deviations occurred this reporting period".

...

Pursuant to 326 IAC 2-7-1(40), starting July 1, 2011, greenhouse gas (GHG) emissions are subject to regulation at a source with a potential to emit (PTE) of 100,000 tons per year or more of CO<sub>2</sub> equivalent emissions (CO<sub>2</sub>e). Therefore, CO<sub>2</sub>e emissions have been calculated for this source. Based on the calculations, the unlimited PTE of GHGs from the entire source is less than 100,000 tons of CO<sub>2</sub>e per year (see Appendix A for calculations). This did not require any changes to the permit.

### **Conclusion and Recommendation**

The operation of this proposed modification shall be subject to the conditions of the attached proposed Part 70 Significant Permit Modification. The staff recommends to the Commissioner that this Part 70 Significant Permit Modification be approved.

### **IDEM Contact**

- (a) Questions regarding this proposed permit can be directed to Deborah Cole at the Indiana Department Environmental Management, Office of Air Quality, Permits Branch, 100 North Senate Avenue, MC 61-53 IGCN 1003, Indianapolis, Indiana 46204-2251 or by telephone at (317) 234-5377 or toll free at 1-800-451-6027 extension 4-5377.
- (b) A copy of the findings is available on the Internet at: <http://www.in.gov/ai/appfiles/idem-caats/>
- (c) For additional information about air permits and how the public and interested parties can participate, refer to the IDEM's Guide for Citizen Participation and Permit Guide on the Internet at: [www.idem.in.gov](http://www.idem.in.gov)

**Appendix A: Emissions Calculations  
Summary**

**Company Name: Cargill, Inc. - Soybean Processing Division**  
**Address: 1503 Wabash Avenue, Lafayette, Indiana 47905**  
**Part 70 Operating Permit Renewal No.: 157-25200-00038**  
**Significant Permit Modification No.: 157-32522-00038**  
**Reviewer: Deborah Cole**

<b>Potential to Emit (ton/yr)</b>									
<b>Process / Control</b>	<b>PM</b>	<b>PM<sub>10</sub></b>	<b>SO<sub>2</sub></b>	<b>VOC</b>	<b>NO<sub>x</sub></b>	<b>CO</b>	<b>GHG</b>	<b>HAPs</b>	<b>n-Hexane</b>
Units Controlled by Baghouses	4,157.20	1,262.85	-	-	-	-	-	-	-
Units Controlled by Cyclone	480.02	196.07	-	-	-	-	-	-	-
Column Dryer	92.24	23.55	3.62	0.70	12.70	10.67	15,335	0.03	0.03
Uncontrolled Units	195.22	624.31	-	-	-	-	-	-	-
Units Routed to MOS with PM Emissions	0.14	0.14	-	-	-	-	-	-	-
Source Wide Hexane / Also VOC	-	-	-	2118.85	-	-	-	1356.06	1356.06
Boilers	33.24	33.24	295.65	3.25	199.94	58.30	-	1.13	1.06
Air Compressor	0.64	0.64	0.59	0.73	8.96	1.93	333.55	0.01	-
Parts Washer	-	-	-	0.49	-	-	-	-	-
<b>Total</b>	<b>4,958.69</b>	<b>2,140.81</b>	<b>299.86</b>	<b>2,124.01</b>	<b>221.60</b>	<b>70.90</b>	<b>15,668.72</b>	<b>1,357.22</b>	<b>1,357.15</b>

<b>Controlled Potential to Emit (ton/yr)</b>									
<b>Process / Control</b>	<b>PM</b>	<b>PM<sub>10</sub></b>	<b>SO<sub>2</sub></b>	<b>VOC</b>	<b>NO<sub>x</sub></b>	<b>CO</b>	<b>GHG</b>	<b>HAPs</b>	<b>n-Hexane</b>
Units Controlled by Baghouses	23.60	22.47	-	-	-	-	-	-	-
Units Controlled by Cyclone	18.10	18.10	-	-	-	-	-	-	-
Column Dryer	92.24	23.55	3.62	0.70	12.70	10.67	15,335	0.03	0.03
Uncontrolled Units	195.22	624.31	-	-	-	-	-	-	-
Units Routed to MOS with PM Emissions	0.14	0.14	-	-	-	-	-	-	-
Source Wide Hexane / Also VOC	-	-	-	1105.93	-	-	-	707.80	707.80
Boilers	33.24	33.24	295.65	3.25	199.94	58.30	-	1.13	1.06
Air Compressor	0.64	0.64	0.59	0.73	8.96	1.93	333.55	0.01	-
Parts Washer	-	-	-	0.49	-	-	-	-	-
<b>Total</b>	<b>363.17</b>	<b>722.44</b>	<b>299.86</b>	<b>1,111.10</b>	<b>221.60</b>	<b>70.90</b>	<b>15,668.72</b>	<b>708.96</b>	<b>708.89</b>

<b>Limited Potential to Emit (ton/yr)</b>									
<b>Process / Control</b>	<b>PM</b>	<b>PM<sub>10</sub></b>	<b>SO<sub>2</sub></b>	<b>VOC</b>	<b>NO<sub>x</sub></b>	<b>CO</b>	<b>GHG</b>	<b>HAPs</b>	<b>n-Hexane</b>
Units Controlled by Baghouses	22.64	23.42	-	-	-	-	-	-	-
Units Controlled by Cyclone	18.10	20.47	-	-	-	-	-	-	-
Column Dryer	92.24	23.55	3.62	0.70	12.70	10.67	15,335	0.03	0.03
Uncontrolled Units	195.22	624.31	-	-	-	-	-	-	-
Units Routed to MOS with PM Emissions	6.75	6.75	-	-	-	-	-	-	-
Source Wide Hexane / Also VOC	-	-	-	41.83	-	-	-	26.77	26.77
Boilers	13.23	13.23	39.00	3.25	39.00	58.30	-	1.13	1.06
Air Compressor	0.64	0.64	0.59	0.73	8.96	1.93	333.55	0.01	-
Parts Washer	-	-	-	0.49	-	-	-	-	-
<b>Total</b>	<b>348.80</b>	<b>712.37</b>	<b>43.21</b>	<b>46.99</b>	<b>60.66</b>	<b>70.90</b>	<b>15,668.72</b>	<b>27.93</b>	<b>27.86</b>

**Appendix A: Emissions Calculations  
Baghouses**

**Company Name: Cargill, Inc. - Soybean Processing Division**  
**Address: 1503 Wabash Avenue, Lafayette, Indiana 47905**  
**Part 70 Operating Permit Renewal No.: 157-25200-00038**  
**Significant Permit Modification No.: 157-32522-00038**  
**Reviewer: Deborah Cole**

Process / Units	Baghouse ID #	Flow Rate (dscfm)	PM Outlet Grain Loading (gr/dscf)	Control Efficiency %	Controlled PM (lb/hr)	Controlled PM (ton/yr)	Limited PM (ton/yr)	Limited PM <sub>10</sub> (ton/yr)
Receiving Area Baghouse (Truck Soybean Receiving Pit)	4	14000	0.003	99%	0.360	1.577	1.58	1.58
Bean Screener Baghouse (Texas shaker #2 screen, weed seed Kice, Kice #1, DC-448, and DC-448A)	1	11000	0.00144	99%	0.136	0.595	0.60	1.75
Cracking System Baghouse (Soybean Thayer scale, DC-400A, DC-400, EU-6, DC-401, DC-403, primary Kice #1, SC-201, SC-202, triple S shaker, hull grinder, coarse cut aspiration, and fine cut aspiration)	3	21000	0.003	99%	0.540	2.365	2.37	2.37
Receiving Area Baghouse <sup>b</sup> (DC-431, DC-432, rail soybean unloading system, bucket elevator #301, DC-434, DC-436, DC-437, DC-444, DC-446, bucket elevator #303, DC-454, DC-447, bucket elevator #304, DC-449, DC-450, and a pod grinder)	10	24000	0.003	99%	0.617	2.703	2.70	2.70
Storage Tank Area Baghouse (DC-441, DC-442, DC-443, bucket elevator #307, and DC-453)	9	16200	0.003	99%	0.417	1.825	1.83	1.83
Meal Sizing and Screening (DC-414A, DC-415, DC-416, SC-223, 3 soybean meal grinders, SC-221, DC-417, BE-300, DC-418, and DC-419)	2	5500	0.005	99%	0.236	1.032	1.03	1.03
Pneumatic Flake Conveying System & FDS Cooler Collector	6	22000	0.008	99%	1.509	6.608	6.61	6.61
Pneumatic Reject Flake Conveying System	8	3000	0.013	99%	0.334	1.464	1.46	1.46
Truck and Rail soybean meal and hull loadout systems	5	16000	0.004	99%	0.549	2.403	2.40	2.40
<b>The following process has control(s) integral to the process:</b>								
Flake Loadout System (flake loadout system and pneumatic flake conveying system)	7	10000	0.004	99%	0.343	1.502	1.50	1.50
<b>Total:</b>					<b>5.04</b>	<b>22.07</b>	<b>22.08</b>	<b>23.24</b>

**Methodology:**

PM<sub>10</sub> assumed to be the equal to PM.

Controlled PM (ton/yr) = Flow rate (dscfm) x Grain Loading (gr/dscf) x 1 lb/7000 grains x 60 minutes/hr x 8760 hr/yr x 1 ton/2000 lb

Process / Units	Limited Throughput (ton/hr)	PM EF (lb/ton)	PM <sub>10</sub> EF (lb/ton)	Capture Efficiency %	Fugitive PM Emissions (ton/yr)	Fugitive PM <sub>10</sub> Emissions (ton/yr)	EF Source
Straight Truck	9.375	0.18	0.059	92.5%	0.55	0.18	AP-42, Table 9.9.1-1
Hopper Truck and Rail Receiving System	84.375	0.035	0.0078	92.5%	0.97	0.22	AP-42, Table 9.9.1-1
<b>Total:</b>					<b>1.52</b>	<b>0.40</b>	

**Methodology:**

Fugitive PM/PM<sub>10</sub> (ton/hr) = Limited Throughput (ton/hr) \* EF (lb/ton) \* 8760 (hr/yr) \* 1 ton/2000lb \* (1 - Capture Efficiency (%))

Process / Units	Throughput	PM EF	PM <sub>10</sub> EF	Potential to Emit PM	Potential to Emit PM <sub>10</sub>	EF Source
	(ton/hr)	(lb/ton)	(lb/ton)	(ton/yr)	(ton/yr)	
Truck soybean receiving pit	93.75	0.18	0.059	73.91	24.23	AP-42, Table 9.9.1-1
DC-431	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-432	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
rail soybean unloading system	93.75	0.032	0.0078	13.14	3.20	AP-42, Table 9.9.1-1
soybean receiving bucket elevator #301	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-441	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-442	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-443	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-434	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-436	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-437	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-444	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-446	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
soybean transfer bucket elevator #303	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
Texas shaker #2 screener	93.75	0.075	0.019	30.80	7.80	AP-42, Table 9.9.1-1
weed seed Kice	4.5	0.075	0.019	1.48	0.37	AP-42, Table 9.9.1-1
Kice #1	93.75	0.075	0.019	30.80	7.80	AP-42, Table 9.9.1-1
DC-448	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-448A	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-449	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-450	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
soybean transfer bucket elevator #307	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-453	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-454	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-447	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
dry soybean transfer bucket elevator #304	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-400A	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
soybean Thayer scale	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-400	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
Cracker Roll 1 (EU-6)	18.75	3.3	0.825	271.01	67.75	FIRE SCC 3-02-007-85**
Cracker Roll 2 (EU-6)	18.75	3.3	0.825	271.01	67.75	FIRE SCC 3-02-007-85**
Cracker Roll 3 (EU-6)	18.75	3.3	0.825	271.01	67.75	FIRE SCC 3-02-007-85**
Cracker Roll 4 (EU-6)	18.75	3.3	0.825	271.01	67.75	FIRE SCC 3-02-007-85**
Cracker Roll 5 (EU-6)	18.75	3.3	0.825	271.01	67.75	FIRE SCC 3-02-007-85**
DC-401	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-403	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
primary Kice #1	93.75	0.075	0.019	30.80	7.80	AP-42, Table 9.9.1-1
SC-201	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
SC-202	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
triple S shaker	93.75	0.075	0.019	30.80	7.80	AP-42, Table 9.9.1-1
hull grinder*	6	NA	NA	0.04	0.04	See note
coarse cut aspiration	4.5	0.061	0.034	1.20	0.67	AP-42, Table 9.9.1-1
fine cut aspiration	4.5	0.061	0.034	1.20	0.67	AP-42, Table 9.9.1-1
DC-414A	76.56	0.27	0.068	90.54	22.63	AP-42, Table 9.9.1-1
DC-415	76.56	0.27	0.068	90.54	22.63	AP-42, Table 9.9.1-1
DC-416	76.56	0.27	0.068	90.54	22.63	AP-42, Table 9.9.1-1
SC-223	38.28	0.27	0.068	45.27	11.32	AP-42, Table 9.9.1-1
Meal grinder #1	12.76	2	0.5	111.78	27.94	FIRE SCC 3-02-007-86**
Meal grinder #2	12.76	2	0.5	111.78	27.94	FIRE SCC 3-02-007-86**
Meal grinder #3	12.76	2	0.5	111.78	27.94	FIRE SCC 3-02-007-86**
SC-221	38.28	0.27	0.068	45.27	11.32	AP-42, Table 9.9.1-1
DC-417	76.56	0.27	0.068	90.54	22.63	AP-42, Table 9.9.1-1
BE-300	76.56	0.27	0.068	90.54	22.63	AP-42, Table 9.9.1-1
DC-418	76.56	0.27	0.068	90.54	22.63	AP-42, Table 9.9.1-1
DC-419	76.56	0.27	0.068	90.54	22.63	AP-42, Table 9.9.1-1
truck soybean meal and hull loadout system	76.56	0.27	0.068	90.54	22.63	AP-42, Table 9.9.1-1
pneumatic flake conveying system	31.5	0.27	0.068	37.25	9.31	AP-42, Table 9.9.1-1
pneumatic reject flake conveying system	9	0.27	0.068	10.64	2.66	AP-42, Table 9.9.1-1
soybean flake loadout system*	31.5	0.27	0.068	1.50	1.50	See note
pod grinder	3	2	0.5	26.28	6.57	FIRE SCC 3-02-007-86**
FDS Cooler Collector	93.75	NA	NA	660.75	165.19	See note***

**Total: 4,157.20 1,262.85**

\*This unit has an integral control device, therefore potential to emit is evaluated post control.

\*\*No data is given on PM<sub>10</sub> emission factor. Therefore, per AP-42 9.9.1-1 Note h a conservative estimate that PM10 = 25% of PM has been used.

**Methodology:**

Uncontrolled PM/PM<sub>10</sub> (ton/hr) = Throughput (ton/hr) \* EF (lb/ton) \* 8760 (hr/yr) \* 1 ton/2000lb

\*\*\*Uncontrolled PM/PM<sub>10</sub>(ton/hr) = Controlled PM / (1 - Control Efficiency (%))

Note: The Permittee has provided the throughputs based on the federally enforceable source wide throughput limit and the amount of product actually processed at each step of the operation.

1) Conservative estimate that PM10 = 25% of PM per AP-42 9.9.1-1 Note h



**Appendix A: Emissions Calculations  
Cyclones**

**Company Name: Cargill, Inc. - Soybean Processing Division**  
**Address: 1503 Wabash Avenue, Lafayette, Indiana 47905**  
**Part 70 Operating Permit Renewal No.: 157-25200-00038**  
**Significant Permit Modification No.: 157-32522-00038**  
**Reviewer: Deborah Cole**

Process / Units	Control Device ID#	Flow Rate (dscfm)	PM Outlet Grain Loading (gr/dscf)	PM <sub>10</sub> Outlet Grain Loading (gr/dscf)	Controlled PM (lb/hr)	Controlled PM <sub>10</sub> (lb/hr)	Controlled PM (ton/yr)	Controlled PM <sub>10</sub> (ton/yr)	Limited PM (ton/yr)	Limited PM <sub>10</sub> (ton/yr)
Flaking Cyclone (rotary conditioner, DC-404, DC-405, DC-406, DC-407, flaker banks 1 & 2, SC-206, SC-207, EU-12, and DC-409)	Cyclone#4	17000	0.006	0.006	0.87	0.87	3.83	3.83	3.83	3.83
<b>The following control devices are considered integral to the process:</b>										
DTDC Meal Dryer	Cyclone#6	10000	0.007	0.007	0.60	0.60	2.63	2.63	2.63	2.63
DTDC Meal Dryer	Cyclone#7	10000	0.007	0.007	0.60	0.60	2.63	2.63	2.63	2.63
DTDC Meal Cooler	Cyclone#8	8000	0.015	0.019	1.03	1.30	4.51	4.51	4.51	5.69
DTDC Meal Cooler	Cyclone#9	8000	0.015	0.019	1.03	1.30	4.51	4.51	4.51	5.69
Hull Storage (hull grinder)*	Cyclone#3	320	0.003	0.003	0.01	0.01	0.04	0.04	N/A	N/A

**Total: 4.13 4.68 18.10 18.10 18.1 20.5**

**Methodology:**

Controlled PM/PM<sub>10</sub> (ton/yr) = Flow rate (dscfm) x Grain Loading (gr/dscf) x 1 lb/7000 grains x 60 minutes/hr x 8760 hr/yr x 1 ton/2000 lb

Process / Units	Control Device ID#	Throughput (ton/hr)	PM EF (lb/ton)	PM <sub>10</sub> EF (lb/ton)	Control Efficiency (%)	Controlled PM (ton/yr)	Controlled PM <sub>10</sub> (ton/yr)	EF Source
Coarse Cut Aspiration*	Cyclone #1	4.5	0.061	0.034	99.6%	0.0048	0.0027	AP-42, Table 9.9.1-1
Fine Cut Aspiration*	Cyclone #2	4.5	0.061	0.034	99.6%	0.0048	0.0027	AP-42, Table 9.9.1-1

**Total: 0.0096 0.0054**

**Methodology:**

Controlled PM/PM<sub>10</sub>/PM<sub>2.5</sub> (ton/yr) = Throughput (ton/hr) \* EF (lb/ton) \* 8760 (hr/yr) \* 1 ton/2000lb \* (1 - Control Efficiency)

\*Cyclones #1, #2, and #3 route to baghouse #3. Emissions from these units are counted towards total emissions after baghouse #3 on Baghouses page.

Process / Units	Throughput (ton/hr)	PM EF (lb/ton)	PM <sub>10</sub> EF (lb/ton)	Potential to Emit PM (ton/yr)	Potential to Emit PM <sub>10</sub> (ton/yr)	EF Source
rotary conditioner	93.75	0.1	0.025	41.06	10.27	FIRE 3-02-007-87*
DC-404	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-405	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-406	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
DC-407	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
flaker bank #1 & #2	93.75	0.57	0.143	234.06	58.51	FIRE 3-02-007-88*
SC-206	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
SC-207	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
EU-12	25	0.27	0.27	29.57	29.57	AP-42, Table 9.9.1-1
DC-409	93.75	0.061	0.034	25.05	13.96	AP-42, Table 9.9.1-1
Coarse Cut Aspiration	4.5	0.061	0.034	Calculated in Baghouses		AP-42, Table 9.9.1-1
Fine Cut Aspiration	4.5	0.061	0.034	Calculated in Baghouses		AP-42, Table 9.9.1-1

**Total:      480.02      196.07**

**Methodology:**

Uncontrolled PM/PM<sub>10</sub> (ton/hr) = Throughput (ton/hr) \* EF (lb/ton) \* 8760 (hr/yr) \* 1 ton/2000lb

Note: The Permittee has provided the throughputs based on the federally enforceable source wide throughput limit and the amount of product actually processed at each step of the operation.

\*No data is given on PM<sub>10</sub> emission factor. Therefore, per AP-42 9.9.1-1 Note h a conservative estimate that PM10 = 25% of PM has been used.

**Appendix A: Emissions Calculations  
Natural Gas Combustion Only**

**Column Dryer**

**Company Name: Cargill, Inc. - Soybean Processing Division**  
**Address: 1503 Wabash Avenue, Lafayette, Indiana 47905**  
**Part 70 Operating Permit Renewal No.: 157-25200-00038**  
**Significant Permit Modification No.: 157-32522-00038**  
**Reviewer: Deborah Cole**

Heat Input Capacity  
MMBtu/hr

Potential Throughput  
MMCF/yr

29.0

254.0

Emission Factor in lb/MMCF	Pollutant					
	PM*	PM10*	SO2	NOx	VOC	CO
	1.9	7.6	28.5	100 **see below	5.5	84
Potential Emission in tons/yr	0.2	1.0	3.6	12.7	0.7	10.7

\*PM emission factor is filterable PM only. PM10 emission factor is filterable and condensable PM10 combined.

\*\*Emission Factors for NOx: Uncontrolled = 100, Low NOx Burner = 50, Low NOx Burners/Flue gas recirculation = 32

**Methodology**

All emission factors are based on normal firing.

MMBtu = 1,000,000 Btu

MMCF = 1,000,000 Cubic Feet of Gas

Emission Factors are from AP 42, Chapter 1.4, Tables 1.4-1, 1.4-2, 1.4-3, SCC #1-02-006-02, 1-01-006-02, 1-03-006-02, and 1-03-006-03

Potential Throughput (MMCF) = Heat Input Capacity (MMBtu/hr) x 8,760 hrs/yr x 1 MMCF/1,000 MMBtu

Emission (tons/yr) = Throughput (MMCF/yr) x Emission Factor (lb/MMCF)/2,000 lb/ton

See page 7 for HAPs emissions calculations.

Emission Factor in lb/MMcf	HAPs - Organics				
	Benzene	Dichlorobenzene	Formaldehyde	Hexane	Toluene
	2.1E-03	1.2E-03	7.5E-02	1.8E+00	3.4E-03
Potential Emission in tons/yr	3.045E-05	1.740E-05	1.088E-03	2.610E-02	4.930E-05

Emission Factor in lb/MMcf	HAPs - Metals				
	Lead	Cadmium	Chromium	Manganese	Nickel
	5.0E-04	1.1E-03	1.4E-03	3.8E-04	2.1E-03
Potential Emission in tons/yr	7.250E-06	1.595E-05	2.030E-05	5.510E-06	3.045E-05

Methodology is the same as page 6.

The five highest organic and metal HAPs emission factors are provided above.

Additional HAPs emission factors are available in AP-42, Chapter 1.4.

Process / Unties	Throughput (ton/hr)	PM EF (lb/ton)	PM <sub>10</sub> EF (lb/ton)	Potential to Emit PM (ton/yr)	Potential to Emit PM <sub>10</sub> (ton/yr)
Column dryer *	93.75	0.22	0.055	90.34	22.58

**Methodology:**

\*Process emissions only.

Uncontrolled PM/PM<sub>10</sub>(ton/yr) = Throughput (ton/hr) \* EF (lb/ton) \* 8760 (hr/yr) \* 1 ton/2000lb

Emission Factor from AP-42, Table 9.9.1-1.

Note: The Permittee has provided the throughputs based on the federally enforceable source wide throughput limit and the amount of product actually processed at each step of the operation.

Column Dryer	PM	PM <sub>10</sub>	SO <sub>2</sub>	VOC	NO <sub>x</sub>	CO	HAPs	Hexane
Total	92.24	23.55	3.6	0.7	12.7	10.7	2.736E-02	2.610E-02

Emission Factor in lb/MMcf	Greenhouse Gas		
	CO2	CH4	N2O
	120,000	2.3	2.2
Potential Emission in tons/yr	15,242	0.29	0.28
Summed Potential Emissions in tons/yr	15,243		
CO2e Total in tons/yr	15,335		

**Methodology**

The N2O Emission Factor for uncontrolled is 2.2. The N2O Emission Factor for low Nox burner is 0.64.

Emission Factors are from AP 42, Table 1.4-2 SCC #1-02-006-02, 1-01-006-02, 1-03-006-02, and 1-03-006-03.

Global Warming Potentials (GWP) from Table A-1 of 40 CFR Part 98 Subpart A.

Emission (tons/yr) = Throughput (MMCF/yr) x Emission Factor (lb/MMCF)/2,000 lb/ton

CO2e (tons/yr) = CO2 Potential Emission ton/yr x CO2 GWP (1) + CH4 Potential Emission ton/yr x CH4 GWP (21) + N2O

**Appendix A: Emissions Calculations  
Uncontrolled Units**

**Company Name: Cargill, Inc. - Soybean Processing Division  
Address: 1503 Wabash Avenue, Lafayette, Indiana 47905  
Part 70 Operating Permit Renewal No.: 157-25200-00038  
Significant Permit Modification No.: 157-32522-00038  
Reviewer: Deborah Cole**

<b>Process / Unties</b>	<b>Throughput (ton/hr)</b>	<b>PM EF (lb/ton)</b>	<b>PM<sub>10</sub> EF (lb/ton)</b>	<b>Potential to Emit PM (ton/yr)</b>	<b>Potential to Emit PM<sub>10</sub> (ton/yr)</b>
4 soybean storage tanks	93.75	0.025	0.0063	10.27	2.59
SC-212	4.50	0.061	0.0063	1.20	0.12
18 storage bins (501 -503, 506-508, 511-513, 516-518, 521-523, 526-528)	93.75	0.025	0.0063	10.27	2.59
2 weed seed bins (207 and 208)	93.75	0.025	0.0063	10.27	2.59
SC-213	4.50	0.061	0.034	1.20	0.67
SC-214	4.50	0.061	0.034	1.20	0.67
DC-427	93.75	0.061	0.034	25.05	13.96
DC-428	93.75	0.061	0.034	25.05	13.96
DC-429	93.75	0.061	0.034	25.05	13.96
5 surge bins	93.75	0.025	0.0063	10.27	2.59
DC-410	93.75	0.061	0.034	25.05	13.96
DC-411	93.75	0.061	0.034	25.05	13.96
DC-412, DC-413, and DC seal screw	76.56	0.27	0.068	90.54	22.63
SC-209	76.56	0.27	0.068	90.54	22.63
DC-414	76.56	0.27	0.068	90.54	22.63
3 meal sifters	76.56	0.27	0.068	90.54	22.63
SC-218	9.00	0.27	0.068	10.64	2.66
DC-461	31.50	0.27	0.068	37.25	9.31
DC-462	31.50	0.27	0.068	37.25	9.31
pneumatic hull conveying system	6.00	0.27	0.068	7.10	1.77

**Total: 624.31 195.22**

**Methodology:**

Uncontrolled PM/PM<sub>10</sub>(lb/hr) = Throughput (ton/hr) \* EF (lb/ton)

Uncontrolled PM/PM<sub>10</sub>(ton/yr) = Throughput (ton/hr) \* EF (lb/ton) \* 8760 (hr/yr) \* 1 ton/2000lb

Emission Factors from AP-42, Table 9.9.1-1.

Note: The Permittee has provided the throughputs based on the federally enforceable source wide throughput limit and the amount of product actually processed at each step of the operation.

**Appendix A: Emissions Calculations**

**Particulate Emissions from Units Vented to the Mineral Oil Absorber System**

**Company Name: Cargill, Inc. - Soybean Processing Division**

**Address: 1503 Wabash Avenue, Lafayette, Indiana 47905**

**Part 70 Operating Permit Renewal No.: 157-25200-00038**

**Significant Permit Modification No.: 157-32522-00038**

**Reviewer: Deborah Cole**

**48% Meal Tank**

Given: 0.1 gr/dscf  
1.02E+07 cubic feet of displacement per year

$$\begin{array}{rcccccccc} 0.1 & / & 7,000 & \times & 1.02E+07 & / & 8760 & = & 0.02 \\ \text{(gr/dscf)} & & \text{(gr/lb)} & & \text{(cf/yr)} & & \text{(hr/yr)} & & \text{(lb/hr)} \\ \\ 0.02 & \times & 8760 & / & 2000 & = & 0.07 & & \\ \text{(lb/hr)} & & \text{(hr/yr)} & & \text{(lb/ton)} & & \text{(ton/year)} & & \end{array}$$

**44% Meal Tank**

Given: 0.1 gr/dscf  
8.75E+06 cubic feet of displacement per year

$$\begin{array}{rcccccccc} 0.1 & / & 7,000 & \times & 8.75E+06 & / & 8760 & = & 0.01 \\ \text{(gr/dscf)} & & \text{(gr/lb)} & & \text{(cf/yr)} & & \text{(hr/yr)} & & \text{(lb/hr)} \\ \\ 0.01 & \times & 8760 & / & 2000 & = & 0.06 & & \\ \text{(lb/hr)} & & \text{(hr/yr)} & & \text{(lb/ton)} & & \text{(ton/year)} & & \end{array}$$

The gr/dscf are based on engineering estimates and process knowledge provided by the source.  
The cubic feet of air displaced per year was calculated by the source by converting the potential throughput of meal in tons/year to a volume assuming an average density of 40 pounds per cubic feet.

**Appendix A: Emissions Calculations  
Hexane Emissions**

**Company Name: Cargill, Inc. - Soybean Processing Division**  
**Address: 1503 Wabash Avenue, Lafayette, Indiana 47905**  
**Part 70 Operating Permit Renewal No.: 157-25200-00038**  
**Significant Permit Modification No.: 157-32522-00038**  
**Reviewer: Deborah Cole**

Hexane (VOC) emissions

Density of hexane	=	5.6	lb /gal
Process limit of soybean	=	821,250	tons/yr
	=	100.50	tons/hr

Hexane is lost from the extraction and desolventizing operations in soybean extraction and in refining plants. These include:

Point sources

- a) Vent system gas during normal operation
- b) Meal dryers
- c) Meal cooler

Fugitive emissions

- d) Solvent samples

Bound in product/by-product

- e) Desolventized flakes (meal)
- f) Process wastewater

Main gas vent (Mineral Oil Absorber System) - controls EU-16, flake desolventizer system, EU-13, iso-hexane conversion system, and solvent/water separator

Given:	3000	ppm outlet from vent - provided by the source in SSM No. 157-11361-00038
	300	cubic feet per minute flowrate
	8760	hours per year operating rate
	95%	control efficiency based on AP-24 Chapter 9.11
3000	x	86.17 / 3.82E+08 = 6.76E-04
(ppm)		(lb/lbmol) (cf ppm / lbmol) (lb/cf)
6.76E-04	x	300 x 60 = 12.17
(lb/cf)		(cf/min) (min/hr) (lb/hr)
12.17	x	8760 / 2000 = 53.31 controlled emissions
(lb/hr)		(hr/yr) (lb/ton) (ton/year)
53.31	/	(1 - 95%) = 1066.23 uncontrolled emissions
(ton/year)		(ton/year)

FDS Cooler Collector

Given:	1000	ppm outlet from vent - provided by the source in SSM No. 157-11361-00038
	22000	cubic feet per minute flowrate
	6000	hours per year operating rate
1000	x	86.17 / 3.82E+08 = 2.25E-04
(ppm)		(lb/lbmol) (cf ppm / lbmol) (lb/cf)
2.25E-04	x	22000 x 60 = 297.5
(lb/cf)		(cf/min) (min/hr) (lb/hr)
297.53	x	6000 / 2000 = 892.6
(lb/hr)		(hr/yr) (lb/ton) (ton/year)

Dryer/Cooler

Given:	20	ppm outlet from vent - provided by the source in SSM No. 157-11361-00038
	8500	cubic feet per minute flowrate
	8760	hours per year operating rate
20	x	86.17 / 3.82E+08 = 4.51E-06
(ppm)		(lb/lbmol) (cf ppm / lbmol) (lb/cf)
4.51E-06	x	8500 x 60 = 2.30
(lb/cf)		(cf/min) (min/hr) (lb/hr)
2.30	x	8760 / 2000 = 10.07
(lb/hr)		(hr/yr) (lb/ton) (ton/year)

48% Meal Tank

Given:	200		ppm outlet from vent - provided by the source in SSM No. 157-11361-00038			
	1.02E+07		cubic feet of displacement per year			
	200	x	86.17	/	3.82E+08	= 4.51E-05
	(ppm)		(lb/lbmol)		(cf ppm / lbmol)	(lb/cf)
	4.51E-05	x	1.02E+07	/	2000	= 0.23
	(lb/cf)		(cf/yr)		(lb/ton)	(lb/hr)
	0.23	x	8760	/	2000	= 1.01
	(lb/hr)		(hr/yr)		(lb/ton)	(ton/year)

44% Meal Tank

Given:	70		ppm outlet from vent - provided by the source in SSM No. 157-11361-00038			
	8.75E+06		cubic feet of displacement per year			
	70	x	86.17	/	3.82E+08	= 1.58E-05
	(ppm)		(lb/lbmol)		(cf ppm / lbmol)	(lb/cf)
	1.58E-05	x	8.75E+06	/	2000	= 0.07
	(lb/cf)		(cf/yr)		(lb/ton)	(lb/hr)
	0.07	x	8760	/	2000	= 0.30
	(lb/hr)		(hr/yr)		(lb/ton)	(ton/year)

Air Emissions - Products and Byproducts

Soybean Meal

Given:	30		ppm hexane concentration in product - provided by the source in SSM No. 157-11361-00038			
	323299		tons meal produced per year			
	30	x	323299	/	1000000	= 9.70
	(ppm)		(tons/yr)		(ppm)	(ton/year)

Soybean Oil

Given:	90		ppm hexane concentration in product - provided by the source in SSM No. 157-11361-00038			
	162608		tons soy oil produced per year			
	90	x	162608	/	1000000	= 14.63
	(ppm)		(tons/yr)		(ppm)	(ton/yr)

Soybean Flake

Given:	250		ppm hexane concentration in product - provided by the source in SSM No. 157-11361-00038			
	273750		tons soy flake produced per year			
	250	x	273750	/	1000000	= 68.44
	(ppm)		(tons/yr)		(ppm)	(ton/yr)

Process Wastewater

Given:	10		ppm hexane concentration in water - provided by the source in SSM No. 157-11361-00038			
	40		gpm flowrate			
	40	x	8.345	x	60	= 20028
	(gal/min)		(lb/gal)		(min/hr)	(lb/hr)
	20028	x	10	/	1000000	= 0.20
	(lb/hr)		(ppm)		(ppm)	(lb/hr)
	0.20	x	8760	/	2000	= 0.88
	(lb/hr)		(hr/yr)		(lb/ton)	(ton/year)

Air Emissions - Fugitives

Sampling/Hexane Unloading

Given:	53		Hexane samples are collected per year - provided by the source in SSM No. 157-11361-00038			
	0.1		gallon volume sample collected			
	5.5		pounds per gallon (density of hexane)			
	53	x	0.1	x	5.5	= 29
	(sample/yr)		(gallon/sample)		(lb/gal)	(lb/yr)
	29	/	2000	=	0.01	
	(lb/yr)		(lb/ton)		(ton/year)	

General Fugitives

Based on past experience and knowledge of the process Cargill estimates an additional 55 tons of hexane will be lost through various other fugitive sources.

Process Weight Based Losses Controlled	
Type of Hexane Loss	Annual Average (lb/ton)
<b>Air Emissions - Point Sources</b>	
MOS Final Vent	0.130
FDS Cooler Collector	2.17
Dryer/Cooler	0.025
48% Meal Tank	0.002
44% Meal Tank	0.001
<b>SUBTOTAL</b>	<b>2.33</b>
<b>Air Emissions - Fugitive</b>	
Sampling/Hexane Unloading	0.00004
General	0.1339
<b>SUBTOTAL</b>	<b>0.1340</b>
<b>Products and Byproducts</b>	
Meal	0.024
Oil	0.036
Flake	0.167
Proc. Wastewater	0.002
<b>SUBTOTAL</b>	<b>0.228</b>
<b>TOTAL</b>	<b>2.69</b>

Assumptions: 821,250 tons of soybeans processed per year

Process Weight Based Losses Controlled	
Type of Hexane Loss	Annual Average (gal/ton)
<b>Air Emissions - Point Sources</b>	
MOS Final Vent	0.02
FDS Cooler Collector	0.39
Dryer/Cooler	0.004
48% Meal Tank	0.0004
44% Meal Tank	0.0001
<b>SUBTOTAL</b>	<b>0.416</b>
<b>Air Emissions - Fugitive</b>	
Sampling/Hexane Unloading	0.00001
General	0.02392
<b>SUBTOTAL</b>	<b>0.0239</b>
<b>Products and Byproducts</b>	
Meal	0.0042
Oil	0.0064
Flake	0.0298
Decanted Water	0.0004
<b>SUBTOTAL</b>	<b>0.041</b>
<b>TOTAL</b>	<b>0.481</b>

Assumptions: 821,250 tons of soybeans processed per year

Type of Hexane Loss	Total Controlled Hexane Loss (ton/yr)
<b>Air Emissions - Point Sources</b>	
MOS Final Vent	53.31
FDS Cooler Collector	892.58
Dryer/Cooler	10.07
48% Meal Tank	1.01
44% Meal Tank	0.30
<b>SUBTOTAL</b>	<b>957</b>
<b>Air Emissions - Fugitive</b>	
Sampling/Hexane Unloading	0.01
General	55.00
<b>SUBTOTAL</b>	<b>55.01</b>
<b>Products and Byproducts</b>	
Meal	9.70
Oil	14.63
Flake	68.44
Proc. Wastewater	0.88
<b>SUBTOTAL</b>	<b>93.65</b>
<b>TOTAL</b>	<b>1105.93</b>

Type of Hexane Loss	Total Uncontrolled Hexane Loss (ton/yr)
<b>Air Emissions - Point Sources</b>	
Mos Final Vent	1066.23
FDS Cooler Collector	892.58
Dryer/Cooler	10.07
48% Meal Tank	1.01
44%Meal Tank	0.30
<b>SUBTOTAL</b>	<b>1970.19</b>
<b>Air Emissions - Fugitive</b>	
Sampling/Hexane Unloading	0.01
General	55.00
<b>SUBTOTAL</b>	<b>55.01</b>
<b>Products and Byproducts</b>	
Meal	9.70
Oil	14.63
Flake	68.44
Proc. Wastewater	0.88
<b>SUBTOTAL</b>	<b>93.65</b>
<b>TOTAL</b>	<b>2118.85</b>

Note: The Permittee has provided the throughputs based on the federally enforceable source wide throughput limit and the amount of product actually processed at each step of the operation.

HAP Fraction (n-Hexane) = 64%	wt. %	Industry standard factor (for example, see 40 CFR 63, Subpart GGGG)
<b>Total Controlled n-Hexane Loss (ton/yr)</b>	707.80	
<b>Total Uncontrolled n-Hexane Loss (ton/yr)</b>	1356.06	



**Appendix A: Emissions Calculations**

**Boilers When Using Vegetable Oil**

**Company Name: Cargill, Inc. - Soybean Processing Division**  
**Address: 1503 Wabash Avenue, Lafayette, Indiana 47905**  
**Part 70 Operating Permit Renewal No.: 157-25200-00038**  
**Significant Permit Modification No.: 157-32522-00038**  
**Reviewer: Deborah Cole**

1st Boiler 60 MMBtu/hr

V.O. Flow rate:	3550.2959 lb/hr
Density:	7.657 lb/gal
Fuel Use:	463.66669 gal/hr
Heat Value:	129403.3 Btu/gal
Heat by V.O.:	60000000 Btu/hr

Maximum % veg. oil: 100.00%

Linear scaling of test data:

$$\frac{100.00\% \text{ maximum}}{85.78\% \text{ as tested}} = 1.17 \text{ (scaling factor)}$$

	NG / #2 oil / #6 oil emission factor	NG / #2 oil / #6 oil ton / year	85.8% veg. oil emission factor	100.0% veg. oil emission factor	100.0% veg. oil ton / year	Worst Case PTE ton / year
PM:	0.0562 lb/MMBtu	14.78 tons/year	0.0185 lb/MMBtu	0.0122 lb/MMBtu	3.21 tons/year	14.78 tons/year
PM <sub>10</sub> :	0.0562 lb/MMBtu	14.78 tons/year	0.0185 lb/MMBtu	0.0122 lb/MMBtu	3.21 tons/year	14.78 tons/year
SO <sub>2</sub> :	0.5000 lb/MMBtu	131.40 tons/year	0.0250 lb/MMBtu	0.0000 lb/MMBtu	0.00 tons/year	131.40 tons/year
NOx:	0.3381 lb/MMBtu	88.86 tons/year	0.1618 lb/MMBtu	0.1326 lb/MMBtu	34.84 tons/year	88.86 tons/year
VOC:	0.0055 lb/MMBtu	1.45 tons/year	0.0024 lb/MMBtu	0.0019 lb/MMBtu	0.49 tons/year	1.45 tons/year
CO:	0.0840 lb/MMBtu	22.08 tons/year	0.0965 lb/MMBtu	0.0986 lb/MMBtu	25.91 tons/year	25.91 tons/year

2nd Boiler 75 MMBtu/hr

V.O. Flow rate:	4441.2751 lb/hr
Density:	7.702 lb/gal
Fuel Use:	576.63919 gal/hr
Heat Value:	130064 Btu/gal
Heat by V.O.:	75000000 Btu/hr

Maximum % vegetable oil: 100.00%

Linear scaling of test data:

$$\frac{100.00\% \text{ maximum}}{85.78\% \text{ as tested}} = 1.17 \text{ (scaling factor)}$$

	NG / #2 oil / #6 oil emission factor	NG / #2 oil / #6 oil ton / year	85.8% veg. oil emission factor	100.0% veg. oil emission factor	100.0% veg. oil ton / year	Worst Case PTE ton / year
PM:	0.0562 lb/MMBtu	18.47 tons/year	0.0185 lb/MMBtu	0.0122 lb/MMBtu	4.02 tons/year	18.47 tons/year
PM <sub>10</sub> :	0.0562 lb/MMBtu	18.47 tons/year	0.0185 lb/MMBtu	0.0122 lb/MMBtu	4.02 tons/year	18.47 tons/year
SO <sub>2</sub> :	0.5000 lb/MMBtu	164.25 tons/year	0.0250 lb/MMBtu	0.0000 lb/MMBtu	0.00 tons/year	164.25 tons/year
NOx:	0.3381 lb/MMBtu	111.08 tons/year	0.1618 lb/MMBtu	0.1326 lb/MMBtu	43.55 tons/year	111.08 tons/year
VOC:	0.0055 lb/MMBtu	1.81 tons/year	0.0024 lb/MMBtu	0.0019 lb/MMBtu	0.62 tons/year	1.81 tons/year
CO:	0.0840 lb/MMBtu	27.59 tons/year	0.0965 lb/MMBtu	0.0986 lb/MMBtu	32.39 tons/year	32.39 tons/year

The vegetable oil emission calculations are based on emission tests conducted January 18 and January 23, 2001 on the EP#26 stack at the Cargill facility in Iowa Falls, IA. Baseline emission factors are from EPA document AP-42.

Methodology:

$$\text{(baseline emission at 0\% vegetable oil) + ((change in emission between 0\% and tested \% vegetable oil) * (scaling factor))} \\ = \text{(emission at the desired \% vegetable oil)}$$

Note: In cases where linear scaling of an emission decrease results in a negative emission factor, the emission factor is listed as zero lb/MMBtu.

TOTAL:

	Total Worst Case PTE ton / year
PM:	33.24 tons/year
PM <sub>10</sub> :	33.24 tons/year
SO <sub>2</sub> :	295.65 tons/year
NOx:	199.94 tons/year
VOC:	3.25 tons/year
CO:	58.30 tons/year

**Appendix A: Emissions Calculations**

**Boilers When using Tallow**

**Company Name: Cargill, Inc. - Soybean Processing Division**

**Address: 1503 Wabash Avenue, Lafayette, Indiana 47905**

**Part 70 Operating Permit Renewal No.: 157-25200-00038**

**Significant Permit Modification No.: 157-32522-00038**

**Reviewer: Deborah Cole**

1st Boiler 60 MMBtu/hr

T. Flow rate:	3550.2959 lb/hr
Density:	7.51 lb/gal
Fuel Use:	472.74246 gal/hr
Heat Value:	126919 Btu/gal
Heat by T.:	60000000 Btu/hr

Maximum % tallow: 100.00%

Linear scaling of test data:

$$\frac{100.00\% \text{ maximum}}{50.00\% \text{ assumed}} = 2.00 \text{ (scaling factor)}$$

	NG / #2 oil / #6 oil emission factor	NG / #2 oil / #6 oil ton / year	50.0% tallow emission factor	100.0% tallow emission factor	100.0% tallow ton / year	Worst Case PTE ton / year
PM:	0.0562 lb/MMBtu	14.78 tons/year	0.0540 lb/MMBtu	0.0518 lb/MMBtu	13.61 tons/year	14.78 tons/year
PM <sub>10</sub> :	0.0562 lb/MMBtu	14.78 tons/year	0.0540 lb/MMBtu	0.0518 lb/MMBtu	13.61 tons/year	14.78 tons/year
SO <sub>2</sub> :	0.5000 lb/MMBtu	131.40 tons/year	0.0000 lb/MMBtu	0.0000 lb/MMBtu	0.00 tons/year	131.40 tons/year
NO <sub>x</sub> :	0.3381 lb/MMBtu	88.86 tons/year	0.1950 lb/MMBtu	0.0519 lb/MMBtu	13.63 tons/year	88.86 tons/year
VOC:	0.0055 lb/MMBtu	1.45 tons/year	0.0050 lb/MMBtu	0.0045 lb/MMBtu	1.18 tons/year	1.45 tons/year
CO:	0.0840 lb/MMBtu	22.08 tons/year	0.0160 lb/MMBtu	0.0000 lb/MMBtu	0.00 tons/year	22.08 tons/year

2nd Boiler 75 MMBtu/hr

T. Flow rate:	4437.8698 lb/hr
Density:	7.51 lb/gal
Fuel Use:	590.92807 gal/hr
Heat Value:	126919 Btu/gal
Heat by T.:	75000000 Btu/hr

Maximum % tallow: 100.00%

Linear scaling of test data:

$$\frac{100.00\% \text{ maximum}}{50.00\% \text{ estimated}} = 2.00 \text{ (scaling factor)}$$

	NG / #2 oil / #6 oil emission factor	NG / #2 oil / #6 oil ton / year	50.0% tallow emission factor	100.0% tallow emission factor	100.0% tallow ton / year	Worst Case PTE ton / year
PM:	0.0562 lb/MMBtu	18.47 tons/year	0.0540 lb/MMBtu	0.0518 lb/MMBtu	17.01 tons/year	18.47 tons/year
PM <sub>10</sub> :	0.0562 lb/MMBtu	18.47 tons/year	0.0540 lb/MMBtu	0.0518 lb/MMBtu	17.01 tons/year	18.47 tons/year
SO <sub>2</sub> :	0.5000 lb/MMBtu	164.25 tons/year	0.0000 lb/MMBtu	0.0000 lb/MMBtu	0.00 tons/year	164.25 tons/year
NO <sub>x</sub> :	0.3381 lb/MMBtu	111.08 tons/year	0.1950 lb/MMBtu	0.0519 lb/MMBtu	17.04 tons/year	111.08 tons/year
VOC:	0.0055 lb/MMBtu	1.81 tons/year	0.0050 lb/MMBtu	0.0045 lb/MMBtu	1.48 tons/year	1.81 tons/year
CO:	0.0840 lb/MMBtu	27.59 tons/year	0.0160 lb/MMBtu	0.0000 lb/MMBtu	0.00 tons/year	27.59 tons/year

The tallow emission calculations are based on emission tests conducted in Wapello County, IA, which indicated the highest emission results for tallow combustion. Baseline emission factors are from EPA document AP-42.

Methodology:

$$\text{(baseline emission at 0\% tallow) + ((change in emission between 0\% and tested \% tallow) * (scaling factor))} \\ = \text{(emission at the desired \% tallow)}$$

Note: In cases where linear scaling of an emission decrease results in a negative emission factor, the emission factor is listed as zero lb/MMBtu.

TOTAL:

	Total Worst Case PTE ton / year
PM:	33.24 tons/year
PM <sub>10</sub> :	33.24 tons/year
SO <sub>2</sub> :	295.65 tons/year
NO <sub>x</sub> :	199.94 tons/year
VOC:	3.25 tons/year
CO:	49.67 tons/year

**Appendix A: Emissions Calculations**

**Boilers When Using Grease**

**Company Name: Cargill, Inc. - Soybean Processing Division**

**Address: 1503 Wabash Avenue, Lafayette, Indiana 47905**

**Part 70 Operating Permit Renewal No.: 157-25200-00038**

**Significant Permit Modification No.: 157-32522-00038**

**Reviewer: Deborah Cole**

1st Boiler 60 MMBtu/hr

G. Flow rate:	3434.4591 lb/hr
Density:	7.506 lb/gal
Fuel Use:	457.56183 gal/hr
Heat Value:	131129.82 Btu/gal
Heat by G.:	60000000 Btu/hr

Maximum % grease: 100.00%

Linear scaling of test data:

$$\frac{100.00\% \text{ maximum}}{50.00\% \text{ assumed}} = 2.00 \text{ (scaling factor)}$$

	NG / #2 oil / #6 oil emission factor	NG / #2 oil / #6 oil ton / year	50.0% grease emission factor	100.0% grease emission factor	100.0% grease ton / year	Worst Case PTE ton / year
PM:	0.0562 lb/MMBtu	14.78 tons/year	0.0410 lb/MMBtu	0.0258 lb/MMBtu	6.77 tons/year	14.78 tons/year
PM <sub>10</sub> :	0.0562 lb/MMBtu	14.78 tons/year	0.0410 lb/MMBtu	0.0258 lb/MMBtu	6.77 tons/year	14.78 tons/year
SO <sub>2</sub> :	0.5000 lb/MMBtu	131.40 tons/year	0.0020 lb/MMBtu	0.0000 lb/MMBtu	0.00 tons/year	131.40 tons/year
NOx:	0.3381 lb/MMBtu	88.86 tons/year	0.0710 lb/MMBtu	0.0000 lb/MMBtu	0.00 tons/year	88.86 tons/year
VOC:	0.0055 lb/MMBtu	1.45 tons/year	0.0020 lb/MMBtu	0.0000 lb/MMBtu	0.00 tons/year	1.45 tons/year
CO:	0.0840 lb/MMBtu	22.08 tons/year	0.0220 lb/MMBtu	0.0000 lb/MMBtu	0.00 tons/year	22.08 tons/year

2nd Boiler 75 MMBtu/hr

G. Flow rate:	4293.0738 lb/hr
Density:	7.506 lb/gal
Fuel Use:	571.95228 gal/hr
Heat Value:	131129.82 Btu/gal
Heat by G.:	75000000 Btu/hr

Maximum % grease: 100.00%

Linear scaling of test data:

$$\frac{100.00\% \text{ maximum}}{50.00\% \text{ estimated}} = 2.00 \text{ (scaling factor)}$$

	NG / #2 oil / #6 oil emission factor	NG / #2 oil / #6 oil ton / year	50.0% grease emission factor	100.0% grease emission factor	100.0% grease ton / year	Worst Case PTE ton / year
PM:	0.0562 lb/MMBtu	18.47 tons/year	0.0410 lb/MMBtu	0.0258 lb/MMBtu	8.47 tons/year	18.47 tons/year
PM <sub>10</sub> :	0.0562 lb/MMBtu	18.47 tons/year	0.0410 lb/MMBtu	0.0258 lb/MMBtu	8.47 tons/year	18.47 tons/year
SO <sub>2</sub> :	0.5000 lb/MMBtu	164.25 tons/year	0.0020 lb/MMBtu	0.0000 lb/MMBtu	0.00 tons/year	164.25 tons/year
NOx:	0.3381 lb/MMBtu	111.08 tons/year	0.0710 lb/MMBtu	0.0000 lb/MMBtu	0.00 tons/year	111.08 tons/year
VOC:	0.0055 lb/MMBtu	1.81 tons/year	0.0020 lb/MMBtu	0.0000 lb/MMBtu	0.00 tons/year	1.81 tons/year
CO:	0.0840 lb/MMBtu	27.59 tons/year	0.0220 lb/MMBtu	0.0000 lb/MMBtu	0.00 tons/year	27.59 tons/year

The grease emission calculations are based on emission tests conducted in Wapello County, IA, which indicated the highest emission results for grease combustion. Baseline emission factors are from EPA document AP-42.

Methodology:

$$\text{(baseline emission at 0\% grease) + ((change in emission between 0\% and tested \% grease) * (scaling factor))} \\ = \text{(emission at the desired \% grease)}$$

Note: In cases where linear scaling of an emission decrease results in a negative emission factor, the emission factor is listed as zero lb/MMBtu.

**TOTAL:**

	Total Worst Case PTE ton / year
PM:	33.24 tons/year
PM <sub>10</sub> :	33.24 tons/year
SO <sub>2</sub> :	295.65 tons/year
NOx:	199.94 tons/year
VOC:	3.25 tons/year
CO:	49.67 tons/year

**Appendix A: Emissions Calculations  
Natural Gas Combustion Only  
MM BTU/HR <100**

**Company Name: Cargill, Inc. - Soybean Processing Division**  
**Address: 1503 Wabash Avenue, Lafayette, Indiana 47905**  
**Part 70 Operating Permit Renewal No.: 157-25200-00038**  
**Significant Permit Modification No.: 157-32522-00038**  
**Reviewer: Deborah Cole**

Heat Input Capacity  
MMBtu/hr

Potential Throughput  
MMCF/yr

135.0

1182.6

HAPs - Organics					
Emission Factor in lb/l	Benzene	Dichlorobenzene	Formaldehyde	Hexane	Toluene
	2.1E-03	1.2E-03	7.5E-02	1.8E+00	3.4E-03
Potential Emission in tc	1.242E-03	7.096E-04	4.435E-02	1.064E+00	2.010E-03

HAPs - Metals					
Emission Factor in lb/l	Lead	Cadmium	Chromium	Manganese	Nickel
	5.0E-04	1.1E-03	1.4E-03	3.8E-04	2.1E-03
Potential Emission in tc	2.957E-04	6.504E-04	8.278E-04	2.247E-04	1.242E-03

All emission factors are based on normal firing.

MMBtu = 1,000,000 Btu

MMCF = 1,000,000 Cubic Feet of Gas

Emission Factors are from AP 42, Chapter 1.4, Tables 1.4-1, 1.4-2, 1.4-3, SCC #1-02-006-02, 1-01-006-02, 1-03-006-02, and 1-03-006-03

Potential Throughput (MMCF) = Heat Input Capacity (MMBtu/hr) x 8,760 hrs/yr x 1 MMCF/1,000 MMBtu

Emission (tons/yr) = Throughput (MMCF/yr) x Emission Factor (lb/MMCF)/2,000 lb/ton

The five highest organic and metal HAPs emission factors are provided above.

Additional HAPs emission factors are available in AP-42, Chapter 1.4.

**Appendix A: Emissions Calculations**  
**Commercial/Institutional/Residential Combustors (< 100 mmBtu/hr)**  
**#2 Fuel Oil**

**Company Name:** Cargill, Inc. - Soybean Processing Division  
**Address:** 1503 Wabash Avenue, Lafayette, Indiana 47905  
**Part 70 Operating Permit Renewal No.:** 157-25200-00038  
**Significant Permit Modification No.:** 157-32522-00038  
**Reviewer:** Deborah Cole

Heat Input Capacity MMBtu/hr	Potential Throughput kgals/year
135	8447.1429

HAPs - Metals					
Emission Factor in lb/mmBtu	Arsenic 4.0E-06	Beryllium 3.0E-06	Cadmium 3.0E-06	Chromium 3.0E-06	Lead 9.0E-06
Potential Emission in tons/yr	2.37E-03	1.77E-03	1.77E-03	1.77E-03	5.32E-03

HAPs - Metals (continued)				
Emission Factor in lb/mmBtu	Mercury 3.0E-06	Manganese 6.0E-06	Nickel 3.0E-06	Selenium 1.5E-05
Potential Emission in tons/yr	1.77E-03	3.55E-03	1.77E-03	8.87E-03

**Methodology**

No data was available in AP-42 for organic HAPs.  
 Potential Emissions (tons/year) = Throughput (mmBtu/hr)\*Emission Factor (lb/mmBtu)\*8,760 hrs/yr / 2,000 lb/ton

No HAP data was available in AP-42 for #6 fuel oil for boilers with capacities less than 100 MMBtu/hr.

Natural Gas combustion has the highest organic HAPs and #2 fuel oil combustion has the highest metallic HAPs.

**Appendix A: Emissions Calculations**

**Company Name: Cargill, Inc. - Soybean Processing Division**  
**Address: 1503 Wabash Avenue, Lafayette, Indiana 47905**  
**Part 70 Operating Permit Renewal No.: 157-25200-00038**  
**Significant Permit Modification No.: 157-32522-00038**  
**Reviewer: Deborah Cole**

Veg. Oil:	$\frac{0.161818 \text{ lb NOx}^*}{\text{MMBtu}}$	$\frac{129403.3 \text{ Btu}^*}{\text{gal}}$	$\frac{\text{MM gal}}{1000 \text{ Kgal}} =$	$\frac{20.93981 \text{ lb NOx}}{\text{Kgal}}$	NG:	$\frac{100 \text{ lb NOx}}{\text{MMcf}}$
			$1 \text{ Kgal} =$	$\frac{20.93981 \text{ lb/NOx}}{100 \text{ lb/NOx}} =$		$0.209398 \text{ MMcf}$
<hr/>	<hr/>	<hr/>	<hr/>	<hr/>	<hr/>	<hr/>
657 MMcf *	1000 gal *	129403.3 Btu *	0.161818 lb NOx *	ton =		32.85 ton NOx
yr	0.209398 MMcf	gal	1000000 Btu	2000 lb		yr
314 MMcf *	1000 gal *	129403.3 Btu *	0.161818 lb NOx *	ton =		15.7 ton NOx
yr	0.209398 MMcf	gal	1000000 Btu	2000 lb		yr
794 MMcf *	1000 gal *	129403.3 Btu *	0.161818 lb NOx *	ton =		39.7 ton NOx
yr	0.209398 MMcf	gal	1000000 Btu	2000 lb		yr
Tallow:	$\frac{0.195 \text{ lb NOx}^*}{\text{MMBtu}}$	$\frac{126919 \text{ Btu}^*}{\text{gal}}$	$\frac{\text{MM gal}}{1000 \text{ Kgal}} =$	$\frac{24.74921 \text{ lb NOx}}{\text{Kgal}}$	NG:	$\frac{100 \text{ lb NOx}}{\text{MMcf}}$
			$1 \text{ Kgal} =$	$\frac{24.74921 \text{ lb/NOx}}{100 \text{ lb/NOx}} =$		$0.247492 \text{ MMcf}$
<hr/>	<hr/>	<hr/>	<hr/>	<hr/>	<hr/>	<hr/>
657 MMcf *	1000 gal *	126919 Btu *	0.195 lb NOx *	ton =		32.85 ton NOx
yr	0.247492 MMcf	gal	1000000 Btu	2000 lb		yr
314 MMcf *	1000 gal *	126919 Btu *	0.195 lb NOx *	ton =		15.7 ton NOx
yr	0.247492 MMcf	gal	1000000 Btu	2000 lb		yr
794 MMcf *	1000 gal *	126919 Btu *	0.195 lb NOx *	ton =		39.7 ton NOx
yr	0.247492 MMcf	gal	1000000 Btu	2000 lb		yr
Grease:	$\frac{0.071 \text{ lb NOx}^*}{\text{MMBtu}}$	$\frac{131129.8 \text{ Btu}^*}{\text{gal}}$	$\frac{\text{MM gal}}{1000 \text{ Kgal}} =$	$\frac{9.310217 \text{ lb NOx}}{\text{Kgal}}$	NG:	$\frac{100 \text{ lb NOx}}{\text{MMcf}}$
			$1 \text{ Kgal} =$	$\frac{9.310217 \text{ lb/NOx}}{100 \text{ lb/NOx}} =$		$0.093102 \text{ MMcf}$
<hr/>	<hr/>	<hr/>	<hr/>	<hr/>	<hr/>	<hr/>
657 MMcf *	1000 gal *	131129.8 Btu *	0.071 lb NOx *	ton =		32.85 ton NOx
yr	0.093102 MMcf	gal	1000000 Btu	2000 lb		yr
314 MMcf *	1000 gal *	131129.8 Btu *	0.071 lb NOx *	ton =		15.7 ton NOx
yr	0.093102 MMcf	gal	1000000 Btu	2000 lb		yr
794 MMcf *	1000 gal *	131129.8 Btu *	0.071 lb NOx *	ton =		39.7 ton NOx
yr	0.093102 MMcf	gal	1000000 Btu	2000 lb		yr

**Appendix A: Emission Calculations**  
**Reciprocating Internal Combustion Engines - Diesel Fuel**  
**Output Rating (<=600 HP)**  
**Maximum Input Rate (<=4.2 MMBtu/hr)**

**Company Name: Cargill, Inc. - Soybean Processing Division**  
**Address: 1503 Wabash Avenue, Lafayette, Indiana 47905**  
**Part 70 Operating Permit Renewal No.: 157-25200-00038**  
**Significant Permit Modification No.: 157-32522-00038**  
**Reviewer: Deborah Cole**

**B. Emissions calculated based on output rating (hp)**

Output Horsepower Rating (hp)	66.0	Non Emergency Diesel powered air compressor
Maximum Hours Operated per Year	8760	
Potential Throughput (hp-hr/yr)	578,160	

	Pollutant						
	PM*	PM10*	direct PM2.5*	SO2	NOx	VOC	CO
Emission Factor in lb/hp-hr	0.0022	0.0022	0.0022	0.0021	0.0310	0.0025	0.0067
Potential Emission in tons/yr	0.64	0.64	0.64	0.59	8.96	0.73	1.93

\*PM and PM2.5 emission factors are assumed to be equivalent to PM10 emission factors. No information was given regarding which method was used to determine the factor or the fraction of PM10 which is condensable.

**Hazardous Air Pollutants (HAPs)**

	Pollutant							
	Benzene	Toluene	Xylene	1,3-Butadiene	Formaldehyde	Acetaldehyde	Acrolein	Total PAH HAPs***
Emission Factor in lb/hp-hr****	6.53E-06	2.86E-06	2.00E-06	2.74E-07	8.26E-06	5.37E-06	6.48E-07	1.18E-06
Potential Emission in tons/yr	0.002	0.001	0.001	0.000	0.002	0.002	0.000	0.000

\*\*\*PAH = Polyaromatic Hydrocarbon (PAHs are considered HAPs, since they are considered Polycyclic Organic Matter)

\*\*\*\*Emission factors in lb/hp-hr were calculated using emission factors in lb/MMBtu and a brake specific fuel consumption of 7,000 Btu / hp-hr (AP-42 Table 3.3-1).

<b>Potential Emission of Total HAPs (tons/yr)</b>	<b>7.84E-03</b>
---	-----------------

**Green House Gas Emissions (GHG)**

	Pollutant		
	CO2	CH4	N2O
Emission Factor in lb/hp-hr	1.15E+00	4.63E-05	9.26E-06
Potential Emission in tons/yr	3.32E+02	1.34E-02	2.68E-03

<b>Summed Potential Emissions in tons/yr</b>	<b>3.32E+02</b>
<b>CO2e Total in tons/yr</b>	<b>3.34E+02</b>

**Methodology**

Emission Factors are from AP42 (Supplement B 10/96), Tables 3.3-1 and 3.3-2  
 CH4 and N2O Emission Factor from 40 CFR 98 Subpart C Table C-2.  
 Global Warming Potentials (GWP) from Table A-1 of 40 CFR Part 98 Subpart A.

**Option B Methodology**

Potential Throughput (hp-hr/yr) = [Output Horsepower Rating (hp)] \* [Maximum Hours Operated per Year]  
 Potential Emission (tons/yr) = [Potential Throughput (hp-hr/yr)] \* [Emission Factor (lb/hp-hr)] / [2,000 lb/ton]  
 CO2e (tons/yr) = CO2 Potential Emission ton/yr x CO2 GWP (1) + CH4 Potential Emission ton/yr x CH4 GWP (21) + N2O Potential Emission ton/yr x N2O GWP (310).

**Appendix A: Emission Calculations  
VOC and HAP Emissions from Parts Washer**

**Company Name: Cargill, Inc. - Soybean Processing Division**  
**Address: 1503 Wabash Avenue, Lafayette, Indiana 47905**  
**Part 70 Operating Permit Renewal No.: 157-25200-00038**  
**Significant Permit Modification No.: 157-32522-00038**  
**Reviewer: Deborah Cole**

Material	Density (lbs/gal)	Maximum Usage (gal/yr)	Weight % VOC	Weight % Xylene	Weight % Cumene	Weight % Perchloroethylene	PTE VOC (tons/yr)	PTE Xylene (tons/yr)	PTE Cumene (tons/yr)	PTE Perchloroethylene (tons/yr)
Safety-Kleen Premium Solvent	6.70	145	100%	0.00%	0.00%	0.00%	0.49	0.00	0.00	0.00
<b>Total:</b>							<b>0.49</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>

**Note:**  
As a worst-case scenario, the calculations above assume a solvent usage rate of 145 gallons per year for the parts washer station. The source reuses the solvent used for cleaning and expects to use less than 145 gallons per year.

**Methodology**  
PTE VOC/HAP (tons/yr) = Density (lbs/gal) x Maximum Usage (gal/yr) x Weight % VOC or HAP x 1 ton/2,000 lbs





# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

100 N. Senate Avenue • Indianapolis, IN 46204  
(800) 451-6027 • (317) 232-8603 • [www.idem.IN.gov](http://www.idem.IN.gov)

**Michael R. Pence**  
*Governor*

**Thomas W. Easterly**  
*Commissioner*

TO: Tippecanoe County Public Library

From: Matthew Stuckey, Branch Chief  
Permits Branch  
Office of Air Quality

Subject: **Important Information for Display Regarding a Final Determination**

**Applicant Name: Cargill, Inc**  
**Permit Number: 157-32522-00038**

You previously received information to make available to the public during the public comment period of a draft permit. Enclosed is a copy of the final decision and supporting materials for the same project. Please place the enclosed information along with the information you previously received. To ensure that your patrons have ample opportunity to review the enclosed permit, **we ask that you retain this document for at least 60 days.**

The applicant is responsible for placing a copy of the application in your library. If the permit application is not on file, or if you have any questions concerning this public review process, please contact Joanne Smiddie-Brush, OAQ Permits Administration Section at 1-800-451-6027, extension 3-0185.

Enclosures  
Final Library.dot 6/13/2013



# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

100 N. Senate Avenue • Indianapolis, IN 46204  
(800) 451-6027 • (317) 232-8603 • [www.idem.IN.gov](http://www.idem.IN.gov)

**Michael R. Pence**  
Governor

**Thomas W. Easterly**  
Commissioner

## SENT VIA U.S. MAIL: CONFIRMED DELIVERY AND SIGNATURE REQUESTED

TO: John Zoss  
Cargill, Inc - Soybean Processing Div  
1502 Wabash Ave  
Lafayette, IN 47905

DATE: August 9, 2013

FROM: Matt Stuckey, Branch Chief  
Permits Branch  
Office of Air Quality

SUBJECT: Final Decision  
Title V  
157-32522-00038

Enclosed is the final decision and supporting materials for the air permit application referenced above. Please note that this packet contains the original, signed, permit documents.

The final decision is being sent to you because our records indicate that you are the contact person for this application. However, if you are not the appropriate person within your company to receive this document, please forward it to the correct person.


A copy of the final decision and supporting materials has also been sent via standard mail to:

Aaron Clotts, Consultant  
OAQ Permits Branch Interested Parties List

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178, or toll-free at 1-800-451-6027 (ext. 3-0178), and ask to speak to the permit reviewer who prepared the permit. If you think you have received this document in error, please contact Joanne Smiddie-Brush of my staff at 1-800-451-6027 (ext 3-0185), or via e-mail at [jbrush@idem.IN.gov](mailto:jbrush@idem.IN.gov).

Final Applicant Cover letter.dot 6/13/2013

# Mail Code 61-53

IDEM Staff	DPABST 8/9/2013 Cargill, Inc - Soybean Processing Div 157-32522-00038 (Final)		AFFIX STAMP HERE IF USED AS CERTIFICATE OF MAILING	
Name and address of Sender		Indiana Department of Environmental Management Office of Air Quality – Permits Branch 100 N. Senate Indianapolis, IN 46204	Type of Mail:  <b>CERTIFICATE OF MAILING ONLY</b>	

Line	Article Number	Name, Address, Street and Post Office Address	Postage	Handing Charges	Act. Value (If Registered)	Insured Value	Due Send if COD	R.R. Fee	S.D. Fee	S.H. Fee	Rest. Del. Fee	Remarks
1		John Zoss Cargill, Inc - Soybean Processing Div 1502 Wabash Ave Lafayette IN 47905 (Source CAATS)										
2		Tippecanoe County Commissioners 20 N 3rd St, County Office Building Lafayette IN 47901 (Local Official)										
3		Tippecanoe County Health Department 20 N. 3rd St Lafayette IN 47901-1211 (Health Department)										
4		Lafayette City Council and Mayors Office 20 North 6th Street Lafayette IN 47901-1411 (Local Official)										
5		Tippecanoe County Public Library 627 South Street Lafayette IN 47901-1470 (Library)										
6		Ms. Geneva Werner 3212 Longlois Drive Lafayette IN 47904-1718 (Affected Party)										
7		Mrs. Phyllis Owens 3600 Cypress Lane Lafayette IN 47905 (Affected Party)										
8		Mr. Jerry White 4317 Amesbury Drive West Lafayette IN 47906 (Affected Party)										
9		Ms. Rose Filley 5839 Lookout Drive West Lafayette IN 47906 (Affected Party)										
10		Mr. William Cramer 128 Seminole Drive West Lafayette IN 47906 (Affected Party)										
11		Mr. Robert Kelley 2555 S 30th Street Lafayette IN 44909 (Affected Party)										
12		West Lafayette City Council and Mayors Office 609 W. Navajo West Lafayette IN 47906 (Local Official)										
13		Mr. Aaron Clotts AECOM First Natl Bank Bldg 332 Minnesota St # E1000 St Paul MN 55101 (Consultant)										
14												
15												

Total number of pieces Listed by Sender	Total number of Pieces Received at Post Office	Postmaster, Per (Name of Receiving employee)	The full declaration of value is required on all domestic and international registered mail. The maximum indemnity payable for the reconstruction of nonnegotiable documents under Express Mail document reconstructing insurance is \$50,000 per piece subject to a limit of \$50, 000 per occurrence. The maximum indemnity payable on Express mil merchandise insurance is \$500. The maximum indemnity payable is \$25,000 for registered mail, sent with optional postal insurance. See <b>Domestic Mail Manual R900, S913, and S921</b> for limitations of coverage on inured and COD mail. See <b>International Mail Manual</b> for limitations o coverage on international mail. Special handling charges apply only to Standard Mail (A) and Standard Mail (B) parcels.
---	--	--	--