



## INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

100 N. Senate Avenue • Indianapolis, IN 46204

(800) 451-6027 • (317) 232-8603 • [www.idem.IN.gov](http://www.idem.IN.gov)

Michael R. Pence  
Governor

Thomas W. Easterly  
Commissioner

TO: Interested Parties / Applicant

DATE: August 22, 2013

RE: Allison Transmission, Inc. - Speedway Main Campus / 097 - 33236 - 00310

FROM: Matthew Stuckey, Branch Chief  
Permits Branch  
Office of Air Quality

### Notice of Decision: Approval – Effective Immediately

Please be advised that on behalf of the Commissioner of the Department of Environmental Management, I have issued a decision regarding the enclosed matter. Pursuant to IC 13-17-3-4 and 326 IAC 2, this permit modification is effective immediately, unless a petition for stay of effectiveness is filed and granted, and may be revoked or modified in accordance with the provisions of IC 13-15-7-1.

If you wish to challenge this decision, IC 4-21.5-3-7 and IC 13-15-7-3 require that you file a petition for administrative review. This petition may include a request for stay of effectiveness and must be submitted to the Office Environmental Adjudication, 100 North Senate Avenue, Government Center North, Suite N 501E, Indianapolis, IN 46204, **within eighteen (18) days of the mailing of this notice**. The filing of a petition for administrative review is complete on the earliest of the following dates that apply to the filing:

- (1) the date the document is delivered to the Office of Environmental Adjudication (OEA);
- (2) the date of the postmark on the envelope containing the document, if the document is mailed to OEA by U.S. mail; or
- (3) The date on which the document is deposited with a private carrier, as shown by receipt issued by the carrier, if the document is sent to the OEA by private carrier.

The petition must include facts demonstrating that you are either the applicant, a person aggrieved or adversely affected by the decision or otherwise entitled to review by law. Please identify the permit, decision, or other order for which you seek review by permit number, name of the applicant, location, date of this notice and all of the following:

- (1) the name and address of the person making the request;
- (2) the interest of the person making the request;
- (3) identification of any persons represented by the person making the request;
- (4) the reasons, with particularity, for the request;
- (5) the issues, with particularity, proposed for considerations at any hearing; and
- (6) identification of the terms and conditions which, in the judgment of the person making the request, would be appropriate in the case in question to satisfy the requirements of the law governing documents of the type issued by the Commissioner.



A State that Works

Pursuant to 326 IAC 2-7-18(d), any person may petition the U.S. EPA to object to the issuance of a Title V operating permit or modification within sixty (60) days of the end of the forty-five (45) day EPA review period. Such an objection must be based only on issues that were raised with reasonable specificity during the public comment period, unless the petitioner demonstrates that it was impracticable to raise such issues, or if the grounds for such objection arose after the comment period.

To petition the U.S. EPA to object to the issuance of a Title V operating permit, contact:

U.S. Environmental Protection Agency  
401 M Street  
Washington, D.C. 20406

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178. Callers from within Indiana may call toll-free at 1-800-451-6027, ext. 3-0178.



# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

100 N. Senate Avenue • Indianapolis, IN 46204

(800) 451-6027 • (317) 232-8603 • [www.idem.IN.gov](http://www.idem.IN.gov)

Michael R. Pence  
Governor

Thomas W. Easterly  
Commissioner

Matthew Littell  
Allison Transmission, Inc. - Speedway Main Campus  
One Allison Way  
Indianapolis, IN 46222

August 22, 2013

Re: 097-33236-00310  
Significant Permit Modification to  
Part 70 Renewal No.: T097-27011-00310

Dear Matthew Littell:

Allison Transmission, Inc. - Speedway Main Campus was issued a Part 70 Operating Permit Renewal No. T097-27011-00310 on March 23, 2010 for a stationary transmission manufacturing and testing plant located at One Allison Way, Indianapolis, IN. An application to modify the source was received on May 15, 2013. Pursuant to the provisions of 326 IAC 2-7-12, a significant permit modification to this permit is hereby approved as described in the attached Technical Support Document.

For your convenience, the entire Part 70 Operating Permit Renewal as modified is attached.

A copy of the permit is available on the Internet at: <http://www.in.gov/ai/appfiles/idem-caats/>. For additional information about air permits and how the public and interested parties can participate, refer to the IDEM's Guide for Citizen Participation and Permit Guide on the Internet at: [www.idem.in.gov](http://www.idem.in.gov)

This decision is subject to the Indiana Administrative Orders and Procedures Act - IC 4-21.5-3-5. If you have any questions on this matter, please contact Heath Hartley, of my staff, at 317-232-8217 or 1-800-451-6027, and ask for extension 2-8217.

Sincerely,

Nathan C. Bell, Section Chief  
Permits Branch  
Office of Air Quality

Attachment(s): Updated Permit, Technical Support Document and Appendix A

NB/hh

cc: File - Marion County  
Marion County Health Department  
U.S. EPA, Region V  
Compliance and Enforcement Branch





# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

100 N. Senate Avenue • Indianapolis, IN 46204

(800) 451-6027 • (317) 232-8603 • [www.idem.IN.gov](http://www.idem.IN.gov)

Michael R. Pence  
Governor

Thomas W. Easterly  
Commissioner

## Part 70 Operating Permit Renewal OFFICE OF AIR QUALITY

**Allison Transmission, Inc. - Speedway Main Campus**  
**One Allison Way, Mail Code: M-29**  
**Indianapolis, Indiana 46222**


(herein known as the Permittee) is hereby authorized to operate subject to the conditions contained herein, the source described in Section A (Source Summary) of this permit.

**The Permittee must comply with all conditions of this permit. Noncompliance with any provisions of this permit is grounds for enforcement action; permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. Noncompliance with any provision of this permit, except any provision specifically designated as not federally enforceable, constitutes a violation of the Clean Air Act. It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. An emergency does constitute an affirmative defense in an enforcement action provided the Permittee complies with the applicable requirements set forth in Section B, Emergency Provisions.**

This permit is issued in accordance with 326 IAC 2 and 40 CFR Part 70 Appendix A and contains the conditions and provisions specified in 326 IAC 2-7 as required by 42 U.S.C. 7401, et. seq. (Clean Air Act as amended by the 1990 Clean Air Act Amendments), 40 CFR Part 70.6, IC 13-15 and IC 13-17.

|   |  |
|---|--|
| Operation Permit No.: T 097-27011-00310   |  |
| Issued by: Original Signed<br>Don Robin, P.E., Section Chief<br>Permits Branch, Office of Air Quality | Issuance Date: March 23, 2010<br><br>Expiration Date: March 23, 2015 |

First Administrative Amendment No. 097-29691-00310, issued on December 9, 2010; and  
First Minor Source Modification No. 097-30495-00310, issued on June 9, 2011.  
First Significant Permit Modification No. 097-30499-00310, issued on August 4, 2011.  
First Significant Permit Modification No. 097-31784-00310, issued on August 17, 2012.

|   |   |
|---|---|
| Second Significant Permit Modification No. 097-33236-00310  |   |
| Issued by:<br><br>Nathan C. Bell, Section Chief<br>Permits Branch<br>Office of Air Quality | Issuance Date: August 22, 2013<br><br>Expiration Date: March 23, 2015 |



## TABLE OF CONTENTS

### A SOURCE SUMMARY

- A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(14)] [326 IAC 2-7-1(22)]
- A.2 Part 70 Source Definition [326 IAC 2-7-1(22)]
- A.3 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)]  
[326 IAC 2-7-5(14)]
- A.4 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-7-4(c)]  
[326 IAC 2-7-5(14)]
- A.5 Part 70 Permit Applicability [326 IAC 2-7-2]

### B GENERAL CONDITIONS

- B.1 Definitions [326 IAC 2-7-1]
- B.2 Permit Term [326 IAC 2-7-5(2)] [326 IAC 2-1.1-9.5] [326 IAC 2-7-4(a)(1)(D)]  
[IC 13-15-3-6(a)]
- B.3 Term of Conditions [326 IAC 2-1.1-9.5]
- B.4 Enforceability [326 IAC 2-7-7]
- B.5 Severability [326 IAC 2-7-5(5)]
- B.6 Property Rights or Exclusive Privilege [326 IAC 2-7-5(6)(D)]
- B.7 Duty to Provide Information [326 IAC 2-7-5(6)(E)]
- B.8 Certification [326 IAC 2-7-4(f)] [326 IAC 2-7-6(1)] [326 IAC 2-7-5(3)(C)]
- B.9 Annual Compliance Certification [326 IAC 2-7-6(5)]
- B.10 Preventive Maintenance Plan [326 IAC 2-7-5(12)] [326 IAC 1-6-3]
- B.11 Emergency Provisions [326 IAC 2-7-16]
- B.12 Permit Shield [326 IAC 2-7-15] [326 IAC 2-7-20] [326 IAC 2-7-12]
- B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5] [326 IAC 2-7-10.5]
- B.14 Termination of Right to Operate [326 IAC 2-7-10] [326 IAC 2-7-4(a)]
- B.15 Permit Modification, Reopening, Revocation and Reissuance, or Termination  
[326 IAC 2-7-5(6)(C)] [326 IAC 2-7-8(a)] [326 IAC 2-7-9]
- B.16 Permit Renewal [326 IAC 2-7-3] [326 IAC 2-7-4] [326 IAC 2-7-8(e)]
- B.17 Permit Amendment or Modification [326 IAC 2-7-11] [326 IAC 2-7-12]
- B.18 Permit Revision Under Economic Incentives and Other Programs [326 IAC 2-7-5(8)]  
[326 IAC 2-7-12(b)(2)]
- B.19 Operational Flexibility [326 IAC 2-7-20] [326 IAC 2-7-10.5]
- B.20 Source Modification Requirement [326 IAC 2-7-10.5]
- B.21 Inspection and Entry [326 IAC 2-7-6] [IC 13-14-2-2] [IC 13-30-3-1]
- B.22 Transfer of Ownership or Operational Control [326 IAC 2-7-11]
- B.23 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-7-5(7)] [326 IAC 2-1.1-7]
- B.24 Credible Evidence [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [62 FR 8314] [326 IAC 1-1-6]

### C SOURCE OPERATION CONDITIONS

#### Emission Limitations and Standards [326 IAC 2-7-5(1)]

- C.1 Particulate Emission Limitations For Processes with Process Weight Rates Less Than  
One Hundred (100) Pounds per Hour [326 IAC 6 3 2]
- C.2 Opacity [326 IAC 5-1]
- C.3 Open Burning [326 IAC 4-1] [IC 13-17-9]
- C.4 Incineration [326 IAC 4-2] [326 IAC 9-1-2]
- C.5 Fugitive Dust Emissions [326 IAC 6-4]
- C.6 Stack Height [326 IAC 1-7]
- C.7 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]

#### Testing Requirements [326 IAC 2-7-6(1)]

- C.8 Performance Testing [326 IAC 3-6]

**Compliance Requirements [326 IAC 2-1.1-11]**

C.9 Compliance Requirements [326 IAC 2-1.1-11]

**Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]**

C.10 Compliance Monitoring [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

**Corrective Actions and Response Steps [326 IAC 2-7-5] [326 IAC 2-7-6]**

C.11 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

C.12 Emergency Reduction Plans [326 IAC 1-5-2] [326 IAC 1-5-3]

C.13 Risk Management Plan [326 IAC 2-7-5(11)] [40 CFR 68]

C.14 Response to Excursions or Exceedances [326 IAC 2-7-5] [326 IAC 2-7-6]

C.15 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5]  
[326 IAC 2-7-6]

**Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

C.16 Emission Statement [326 IAC 2-7-5(3)(C)(iii)] [326 IAC 2-7-5(7)] [326 IAC 2-7-19(c)]  
[326 IAC 2-6]

C.17 General Record Keeping Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [326 IAC 2-2]  
[326 IAC 2-3]

C.18 General Reporting Requirements [326 IAC 2-7-5(3)(C)] [326 IAC 2-1.1-11] [326 IAC 2-2]  
[326 IAC 2-3]

**Stratospheric Ozone Protection**

C.19 Compliance with 40 CFR 82 and 326 IAC 22-1

**D.1 FACILITY OPERATION CONDITIONS - Two (2) Union Iron Works Boilers**

**Emission Limitations and Standards [326 IAC 2-7-5(1)]**

D.1.1 Particulate Emission Limitations for Sources of Indirect Heating [326 IAC 6-2-2]

D.1.2 Preventive Maintenance Plan [326 IAC 2-7-5(12)]

**D.2 FACILITY OPERATION CONDITIONS - Emission Unit ID ETC (25 Test Cells)**

**Emission Limitations and Standards [326 IAC 2-7-5(1)]**

D.2.1 Particulate Matter Limitations Except Lake County [326 IAC 6.5-1-2(a)]

D.2.2 Sulfur Dioxide (SO<sub>2</sub>) [326 IAC 7-1.1-1]

D.2.3 PSD Minor Limit [326 IAC 2-2]

D.2.4 Preventive Maintenance Plan [326 IAC 2-7-5(12)]

**Compliance Determination Requirements**

D.2.5 Sulfur Dioxide Emissions and Sulfur Content

D.2.6 Emission Factors and Performance Testing

**Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

D.2.7 Record Keeping Requirements

D.2.8 Reporting Requirements

**D.3 FACILITY OPERATION CONDITIONS - Emission Unit ID DTC (4 Transmission Reliability Test Cells)**

**Emission Limitations and Standards [326 IAC 2-7-5(1)]**

D.3.1 Particulate Matter Limitations Except Lake County [326 IAC 6.5-1-2(a)]

D.3.2 PSD Minor Limit [326 IAC 2-2]

D.3.3 Preventive Maintenance Plan [326 IAC 2-7-5(12)]

**Compliance Determination Requirements**

D.3.4 Emission Factors and Performance Testing

**Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

D.3.5 Record Keeping Requirements

D.3.6 Reporting Requirements

**D.4 FACILITY CONDITIONS - Emission Unit ID PTS14 (5 Transmission Test Stands)**

**Emission Limitations and Standards [326 IAC 2-7-5(1)]**

D.4.1 Particulate Matter Limitations Except Lake County [326 IAC 6.5-1-2(a)]

D.4.2 PSD Minor Limit [326 IAC 2-2]

D.4.3 Preventive Maintenance Plan [326 IAC 2-7-5(12)]

**Compliance Determination Requirements**

D.4.4 Emission Factors and Performance Testing

**Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

D.4.5 Record Keeping Requirements

D.4.6 Reporting Requirements

**D.5 FACILITY OPERATION CONDITIONS - Cold Cleaning Degreasing**

**Emission Limitations and Standards [326 IAC 2-7-5(1)]**

D.5.1 Volatile Organic Compounds [326 IAC 8-3-2] [326 IAC 8-3-5]

**D.6 FACILITY OPERATION CONDITIONS - Emission Unit ID ETC702 (Test Cell 702)**

**Emission Limitations and Standards [326 IAC 2-7-5(1)]**

D.6.1 Particulate Matter Limitations Except Lake County [326 IAC 6.5-1-2(a)]

D.6.2 PSD Minor Limit [326 IAC 2-2] [Significant Source Modification 097-15550-00310]

D.6.3 Preventive Maintenance Plan [326 IAC 2-7-5(12)]

**Compliance Determination Requirements**

D.6.4 Emission Factors and Performance Testing

**Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

D.6.4 Record Keeping Requirements

D.6.5 Reporting Requirements

**D.7 FACILITY OPERATION CONDITIONS - Emission Unit ID BLR6**

**Emission Limitations and Standards [326 IAC 2-7-5(1)]**

D.7.1 Particulate Emission Limitations for Sources of Indirect Heating [326 IAC 6-2-4]

D.7.2 Preventive Maintenance Plan [326 IAC 2-7-5(12)]

**D.8 FACILITY OPERATION CONDITIONS - Insignificant Activities**

**Emission Limitations and Standards [326 IAC 2-7-5(1)]**

D.8.1 Particulate Matter Limitations Except Lake County [326 IAC 6.5-1-2(a)]

**Compliance Determination Requirements**

D.8.2 Particulate Control

## **D.9 FACILITY OPERATION CONDITIONS - Emission Unit ID ETC55**

### **Emission Limitations and Standards [326 IAC 2-7-5(1)]**

- D.9.1 Particulate Matter Limitations Except Lake County [326 IAC 6.5-1-2(a)]
- D.9.2 PSD Minor Limit [326 IAC 2-2]
- D.9.3 Nonattainment NSR Minor Limit [326 IAC 2-1.1-5]
- D.9.4 Sulfur Dioxide (SO<sub>2</sub>) [326 IAC 7-1.1-1]
- D.9.5 Preventive Maintenance Plan [326 IAC 2-7-5(12)]

### **Compliance Determination Requirements**

- D.9.6 NO<sub>x</sub> Emissions Determination
- D.9.7 CO Emissions Determination
- D.9.8 SO<sub>2</sub> Emissions Determination
- D.9.9 Sulfur Dioxide Emissions and Sulfur Content

### **Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

- D.9.10 Record Keeping Requirements
- D.9.11 Reporting Requirements

## **E.1 New Source Performance Standards [326 IAC 2-7-5(1)] [326 IAC 12-1] [40 CFR 60, Subpart Dc]**

- E.1.1 General Provision Relating to New Source Performance Standards [326 IAC 12]  
[40 CFR 60, Subpart A]
- E.1.2 Standard of Performance for Small Industrial-Commercial Institutional Steam Generating  
Units [326 IAC 12] [40 CFR 60, Subpart Dc]

## **E.2 New Source Performance Standards [326 IAC 2-7-5(1)] [326 IAC 12-1] [40 CFR 60, Subpart IIII]**

- E.2.1 General Provisions Relating to National Emission Standards for Hazardous Air Pollutants  
under 40 CFR Part 60 [326 IAC 12-1] [40 CFR Part 60, Subpart A]
- E.2.2 Standard of Performance for Stationary Compression Ignition Internal Combustion  
Engines [326 IAC 12] [40 CFR 60, Subpart IIII]
- E.2.3 Standard of Performance for Stationary Compression Ignition Internal Combustion  
Engines [326 IAC 12] [40 CFR 60, Subpart IIII]

## **E.3 National Emission Standards for Hazardous Air Pollutants [326 IAC 2-7-5(1)] [326 IAC 20-1] [40 CFR 63, Subpart CCCCCC]**

- E.3.1 General Provision Relating National Emission Standards for Hazardous Air Pollutants  
[326 IAC 20] [40 CFR 63, Subpart A]
- E.3.2 Standard National Emission Standards for Hazardous Air Pollutants for Gasoline  
Dispensing Facilities [326 IAC 20] [40 CFR Part 63.11110, Subpart CCCCCC]

## **E.4 National Emission Standards for Hazardous Air Pollutants [326 IAC 2-7-5(1)] [326 IAC 20-1] [40 CFR 63, Subpart WWWWWW]**

- E.4.1 General Provision Relating to National Emission Standards for Hazardous Air Pollutants  
[326 IAC 20] [40 CFR 63, Subpart A]
- E.4.2 National Emission Standards for Hazardous Air Pollutants for Plating and Polishing  
Operations [326 IAC 20] [40 CFR 63, Subpart WWWWWW]

## **E.5 FACILITY OPERATION CONDITIONS**

- E.5.1 General Provision Relating to New Source Performance Standards (NSPS)  
[40 CFR 60, Subpart A] [326 IAC 12]
- E.5.2 Stationary Combustion Turbines NSPS Requirements [40 CFR 60, Subpart KKKK]  
[326 IAC 12]



**E.6 FACILITY OPERATION CONDITIONS**

- E.6.1 General Provision Relating to National Emission Standards for Hazardous Air Pollutants [326 IAC 20] [40 CFR 63, Subpart A]
- E.6.2 Stationary Reciprocating Internal Combustion Engines NESHP [326 IAC 20-82] [40 CFR 63, Subpart ZZZZ]

**E.7 ORDER OF THE COMMISSIONER**

- E.7.1 Agency Determination and Order of the Commissioner

Certification

- Emergency Occurrence Report (2 pages)
- Part 70 Usage Report (Emission Unit ETC - Diesel fuel use in Test Cell 39N)
- Part 70 Usage Report (Emission Unit DTC)
- Part 70 Usage Report (Emission Unit PTS14: Test Stands O-1 and O-2)
- Part 70 Usage Report (Emission Unit PTS14: Test Stands O-24 and O-25)
- Part 70 Usage Report (Emission Unit PTS14: Test Stand O-31)
- Part 70 Usage Report (Emission Unit ETC702)
- Part 70 Quarterly Reports (NO<sub>x</sub>, CO and SO<sub>2</sub>)
- Quarterly Deviation and Compliance Monitoring Report (2 pages)
- Attachment A - 40 CFR 60, Subpart Dc, Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units
- Attachment B - 40 CFR 60, Subpart IIII, Standards of Performance for Stationary Compression Ignition Internal Combustion Engines
- Attachment C - 40 CFR 63, Subpart CCCCC, National Emissions Standards for Hazardous Air Pollutants for Source Category: Gasoline Dispensing Facilities
- Attachment D - 40 CFR 63, Subpart WWWW, National Emissions Standards for Hazardous Air Pollutants: Area Source Standards for Plating and Polishing Operations
- Attachment E - 40 CFR 60, Subpart KKKK, Standards of Performance for Stationary Combustion Turbines
- Attachment F - 40 CFR 63, Subpart ZZZZ, National Emissions Standards for Hazardous Air Pollutants Reciprocating Internal Combustion Engines

## SECTION A

## SOURCE SUMMARY

This permit is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ). The information describing the source contained in conditions A.1 through A.3 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this permit pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

### A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(14)] [326 IAC 2-7-1(22)]

---

The Permittee owns and operates a stationary transmission manufacturing and testing plant under a Standard Industrial Classification Code (SIC) of 3714 (establishments primarily engaged in manufacturing motor vehicle parts and accessories).

|                              |  |
|------------------------------|--|
| Source Address:              | One Allison Way, Mail Code: M-29, Indianapolis, Indiana 46222  |
| General Source Phone Number: | 317-242-2818   |
| SIC Code:                    | 3714   |
| County Location:             | Marion   |
| Source Location Status:      | Nonattainment for PM <sub>2.5</sub> standard<br>Attainment for all other criteria pollutants   |
| Source Status:               | Part 70 Operating Permit Program<br>Major Source, under PSD and Nonattainment NSR<br>Minor Source, under Section 112 of the Clean Air Act<br>Nested Source with fossil fuel fired boilers (or combinations thereof) totaling more than two hundred fifty million (250,000,000) British thermal units per hour heat input, as 1 of 28 Source Categories, within a non-listed source |

### A.2 Part 70 Source Definition [326 IAC 2-7-1(22)]

---

This transmission manufacturing and testing plant consists of three (3) plants:

- (a) Plant 3 is located at One Allison Way, Mail Code: M-29, Indianapolis, IN 46222; and
- (b) Plants 12 and 14 are both located at 901 Grande Avenue, Indianapolis, IN 46222.

Since the three (3) plants are located on contiguous or adjacent properties, belong to the same industrial grouping and are under common control of the same entity, they will be considered one (1) source, effective from the date of issuance of this Part 70 permit.

### A.3 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)] [326 IAC 2-7-5(14)]

---

This stationary source consists of the following emission units and pollution control devices:

- (a) One (1) Union Iron Works Boiler, identified as emission unit BLR 4, capable of combusting only natural gas, with a maximum capacity of seventy two (72) million British thermal units (MMBtu) Btu per hour, exhausting out one stack identified as stack ID# 3107 and constructed in 1953.
- (b) One (1) Union Iron Works Boiler, identified as emission unit BLR 5, capable of combusting only natural gas, with a maximum capacity of ninety six (96) million British thermal units (MMBtu) Btu per hour, exhausting out one stack identified as stack ID# 3108 and constructed in 1969.

- (c) Emission Unit ETC consists of the following twenty five (25) engineering development transmission test cells; 701, 704, 705, 706, 707, 709, 710, 711, 712, 32N, 32S, 38N, 39N, 39S, 40N, 40S, 41N, 41S, 48N, 48S, 49N, 49S, 50, 51N and 51S. The emissions from each test cell 701, 704, 705, 706, 707, 709, 710, 711, 712, 32N, 32S, 38N, 39N, 39S, 40N, 40S, 41N, 41S, 48N, 48S, 49N, 49S, 50, 51N and 51S are exhausted out Stack/Vent PTE 057, PTE 065, PTE 067 PTE 069, PTE 071, PTE 075, PTE 077, PTE 079, PTE 080, PTE 008, PTE 006, PTE 011, PTE 018, PTE 020, PTE 013, PTE 014, PTE 023, PTE 021, PTE 040, PTE 041, PTE 086, PTE 087, PTE 093, PTE 084, and PTE 082, respectively. All test cells were constructed prior to 1977. Test cell 39N was modified during the 1980's. The table below lists the fuel type and engine type that each cell is capable of accommodating based on the physical characteristics of each cell.

| Test Cell ID | Fuel Type          | Engine Type                  | Estimated Maximum Engine Size in Horsepower  |
|--------------|--------------------|------------------------------|--|
| 701          | Diesel             | Reciprocating or Gas Turbine | 4000   |
| 704          | Diesel             | Reciprocating                | 2400   |
| 705          | Diesel             | Reciprocating or Gas Turbine | 2400 for reciprocating; 4000 for gas turbine |
| 706          | Diesel             | Reciprocating                | 4000   |
| 707          | Diesel             | Reciprocating                | 2400   |
| 709          | Diesel             | Reciprocating                | 2400   |
| 710          | Diesel             | Reciprocating                | 1500   |
| 711          | Diesel             | Reciprocating                | 2400   |
| 712          | Diesel             | Reciprocating                | 1500   |
| 32N          | Diesel             | Reciprocating                | 2400   |
| 32S          | Diesel             | Reciprocating                | 1500   |
| 38N          | Diesel             | Reciprocating                | 4000   |
| 39N          | Diesel             | Reciprocating                | 2400   |
| 39S          | Diesel             | Reciprocating                | 1500   |
| 40N          | Diesel             | Reciprocating                | 1500   |
| 40S          | Diesel             | Reciprocating                | 1500   |
| 41N          | Diesel             | Reciprocating                | 1200   |
| 41S          | Diesel             | Reciprocating                | 1200   |
| 48N          | Diesel             | Reciprocating                | 1200   |
| 48S          | Diesel             | Reciprocating                | 1200   |
| 49N          | Diesel             | Reciprocating                | 1500   |
| 49S          | Diesel             | Reciprocating                | 1500   |
| 50           | Diesel             | Reciprocating                | 2400   |
| 51N          | Diesel             | Reciprocating                | 1200   |
| 51S          | Gasoline or Diesel | Reciprocating                | 700  |

- (d) Emission unit DTC consists of the following four (4) transmission reliability test cells, TC-107, TC-109, TC-111 and TC-112. The emissions from test cells TC-107, TC-109, TC-111 and TC-112 are exhausted out stacks PTE045, PTE043, PTE049 and PTE050, respectively. All test cells were constructed in 1985. The following engines can be used in any one of the individual test cells mentioned above:

| Test Cell ID | Fuel Type | Engine Type   | Estimated Maximum Engine Size in Horsepower |
|--------------|-----------|---------------|---|
| TC-107       | Diesel    | Reciprocating | 1500  |
| TC-109       | Diesel    | Reciprocating | 1500  |
| TC-111       | Diesel    | Reciprocating | 1500  |
| TC-112       | Diesel    | Reciprocating | 1500  |

- (e) Emission unit PTS14 consists of the following five (5) transmission test stands, identified as test stand O-1, O-2, O-24, O-25 and O-31. Test stands O-1, O-2, O-24, O-25 and O-31 were constructed in 1978, 1979, 1986, 1986, and 1984 respectively. The emissions from test stands O-1, O-2, O-24, O-25 and O-31 are exhausted out stacks 14041, 14038, 14024, 14023, and 14045, respectively.

| Test Cell ID | Fuel Type | Engine Type   | Estimated Maximum Engine Size in Horsepower |
|--------------|-----------|---------------|---|
| O-1          | Diesel    | Reciprocating | 2400  |
| O-2          | Diesel    | Reciprocating | 2400  |
| O-24         | Diesel    | Reciprocating | 600   |
| O-25         | Diesel    | Reciprocating | 600   |
| O-31         | Diesel    | Reciprocating | 2400  |

- (f) Cold solvent degreasing using mineral spirits identified as emission unit CSD. Emissions are vented inside the building. Each degreasing unit was installed prior to 1977. [326 IAC 8-3-2] [326 IAC 8-3-8]
- (g) Transmission Test Cell 702, identified as Emission Unit ID ETC702, consisting of one (1) reciprocating engine firing diesel fuel, with an estimated maximum engine size of 4000 hp, and exhausting at Stack/ Vent IDs PTE062 and PTE062A. This emission unit can accommodate engines of greater than 600 horsepower. Constructed in 2002.
- (h) One (1) natural gas-fired boiler, identified as Emission Unit ID BLR6, constructed in 2011, with a maximum heat input of 99 million Btu per hour, equipped with low-NO<sub>x</sub> burners and flue gas recirculation.
- (i) Hydrochloric Acid Tanks in Plating Room
- (j) Transmission Test Cell 55, identified as ETC55, permitted in 2013, consisting of two reciprocating diesel-fired engines, with an estimated maximum engine size of 4,000 hp each, exhausting to Stacks/Vents PTE93 and PTE94.

A.4 Specifically Regulated Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-7-4(c)]  
[326 IAC 2-7-5(14)]

---

This stationary source also includes the following insignificant activities which are specifically regulated, as defined in 326 IAC 2-7-1(21):

- (a) Natural gas-fired combustion sources with heat input equal to or less than ten million (10,000,000) Btu per hour. [326 IAC 6.5-1-2]
- (b) Emergency diesel generators not exceeding 1600 horsepower. [326 IAC 6.5-1-2(a)]
- (c) Emergency Stationary fire pumps. [326 IAC 6.5-1-2(a)]
- (d) Grinding and machining operations controlled with fabric filters, scrubbers, mist collectors, wet collectors and electrostatic precipitators with a design grain loading of less than or equal to 0.03 grains per actual cubic foot and a gas flow rate less than or equal to 4000 actual cubic feet per minute, including the following: deburring; buffing; polishing; abrasive blasting; pneumatic conveying; and woodworking operations. [326 IAC 6.5-1-2(a)]
- (1) Shot Blast controlled with fabric filters. [326 IAC 6.5-1-2(a)]
- (e) Heat Treating. [326 IAC 6.5-1-2(a)]

- (f) Activities or categories of activities with individual HAP emissions not previously identified. Any unit emitting greater than 1 pound per day but less than 5 pounds per day or 1 ton per year of a single HAP.
  - (1) Production welding - manganese [326 IAC 6.5-1-2(a)]
- (g) Paved and unpaved roads and parking lots with public access. [326 IAC 6-4]
- (h) Two (2) maintenance paint booths [326 IAC 6.5-1-2(a)]
- (i) Cleaners and solvents characterized as having a vapor pressure equal to or less than: two (2.0) kilo Pascals (fifteen (15) millimeters of mercury or three-tenths (0.3) pound per square inch) measured at thirty-eight (38) degrees Centigrade (one hundred (100) degrees Fahrenheit); or seven-tenths (0.7) kilo Pascal (five (5) millimeters of mercury or one-tenth (0.1) pound per square inch) measured at twenty (20) degrees Centigrade (sixty-eight (68) degrees Fahrenheit); the use of which, for all cleaners and solvents combined, does not exceed one hundred forty-five (145) gallons per twelve (12) months, including:
  - One (1) cold solvent degreasing unit using mineral spirits identified as emission unit CSD-1, approved in 2012 for construction, exhausting inside. [326 IAC 8-3-2]  
[326 IAC 8-3-8]

**A.5 Part 70 Permit Applicability [326 IAC 2-7-2]**

---

This stationary source is required to have a Part 70 permit by 326 IAC 2-7-2 (Applicability) because:

- (a) It is a major source, as defined in 326 IAC 2-7-1(22);
- (b) It is a source in a source category designated by the United States Environmental Protection Agency (U.S. EPA) under 40 CFR 70.3 (Part 70 - Applicability).

## **SECTION B GENERAL CONDITIONS**

### **B.1 Definitions [326 IAC 2-7-1]**

Terms in this permit shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, the applicable definitions found in the statutes or regulations (IC 13-11, 326 IAC 1-2 and 326 IAC 2-7) shall prevail.

### **B.2 Permit Term [326 IAC 2-7-5(2)] [326 IAC 2-1.1-9.5] [326 IAC 2-7-4(a)(1)(D)] [IC 13-15-3-6(a)]**

- (a) This permit, T097-27011-00310, is issued for a fixed term of five (5) years from the issuance date of this permit, as determined in accordance with IC 4-21.5-3-5(f) and IC 13-15-5-3. Subsequent revisions, modifications, or amendments of this permit do not affect the expiration date of this permit.
- (b) If IDEM, OAQ, upon receiving a timely and complete renewal permit application, fails to issue or deny the permit renewal prior to the expiration date of this permit, this existing permit shall not expire and all terms and conditions shall continue in effect, including any permit shield provided in 326 IAC 2-7-15, until the renewal permit has been issued or denied.

### **B.3 Term of Conditions [326 IAC 2-1.1-9.5]**

Notwithstanding the permit term of a permit to construct, a permit to operate, or a permit modification, any condition established in a permit issued pursuant to a permitting program approved in the state implementation plan shall remain in effect until:

- (a) the condition is modified in a subsequent permit action pursuant to Title I of the Clean Air Act; or
- (b) the emission unit to which the condition pertains permanently ceases operation.

### **B.4 Enforceability [326 IAC 2-7-7] [IC 13-17-12]**

Unless otherwise stated, all terms and conditions in this permit, including any provisions designed to limit the source's potential to emit, are enforceable by IDEM, the United States Environmental Protection Agency (U.S. EPA) and by citizens in accordance with the Clean Air Act.

### **B.5 Severability [326 IAC 2-7-5(5)]**

The provisions of this permit are severable; a determination that any portion of this permit is invalid shall not affect the validity of the remainder of the permit.

### **B.6 Property Rights or Exclusive Privilege [326 IAC 2-7-5(6)(D)]**

This permit does not convey any property rights of any sort or any exclusive privilege.

### **B.7 Duty to Provide Information [326 IAC 2-7-5(6)(E)]**

- (a) The Permittee shall furnish to IDEM, OAQ, within a reasonable time, any information that IDEM, OAQ may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. Upon request, the Permittee shall also furnish to IDEM, OAQ copies of records required to be kept by this permit.
- (b) For information furnished by the Permittee to IDEM, OAQ, the Permittee may include a claim of confidentiality in accordance with 326 IAC 17.1. When furnishing copies of requested records directly to U. S. EPA, the Permittee may assert a claim of confidentiality in accordance with 40 CFR 2, Subpart B.

**B.8 Certification [326 IAC 2-7-4(f)] [326 IAC 2-7-6(1)] [326 IAC 2-7-5(3)(C)]**

---

- (a) A certification required by this permit meets the requirements of 326 IAC 2-7-6(1) if:
  - (i) it contains a certification by a "responsible official" as defined by 326 IAC 2-7-1(35), and
  - (ii) the certification states that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
- (b) The Permittee may use the attached Certification Form, or its equivalent with each submittal requiring certification. One (1) certification may cover multiple forms in one (1) submittal.
- (c) A "responsible official" is defined at 326 IAC 2-7-1(35).

**B.9 Annual Compliance Certification [326 IAC 2-7-6(5)]**

---

- (a) The Permittee shall annually submit a compliance certification report which addresses the status of the source's compliance with the terms and conditions contained in this permit, including emission limitations, standards, or work practices. All certifications shall cover the time period from January 1 to December 31 of the previous year, and shall be submitted no later than April 15 of each year to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V  
Air and Radiation Division, Air Enforcement Branch - Indiana (AE-17J)  
77 West Jackson Boulevard  
Chicago, Illinois 60604-3590
- (b) The annual compliance certification report required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
- (c) The annual compliance certification report shall include the following:
  - (1) The appropriate identification of each term or condition of this permit that is the basis of the certification;
  - (2) The compliance status;
  - (3) Whether compliance was continuous or intermittent;
  - (4) The methods used for determining the compliance status of the source, currently and over the reporting period consistent with 326 IAC 2-7-5(3); and

- (5) Such other facts, as specified in Sections D of this permit, as IDEM, OAQ may require to determine the compliance status of the source.  
The submittal by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).

**B.10 Preventive Maintenance Plan [326 IAC 2-7-5(12)] [326 IAC 1-6-3]**

---

- (a) A Preventive Maintenance Plan meets the requirements of 326 IAC 1-6-3 if it includes, at a minimum:

- (1) Identification of the individual(s) by job title responsible for inspecting, maintaining, and repairing emission control devices;
- (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
- (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

The Permittee shall implement the PMPs.

- (b) If required by specific condition(s) in Section D of this permit where no PMP was previously required, the Permittee shall prepare and maintain Preventive Maintenance Plans (PMPs) no later than ninety (90) days after issuance of this permit or ninety (90) days after initial start-up, whichever is later, including the following information on each facility:

- (1) Identification of the individual(s) by job title responsible for inspecting, maintaining, and repairing emission control devices;
- (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
- (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

If, due to circumstances beyond the Permittee's control, the PMPs cannot be prepared and maintained within the above time frame, the Permittee may extend the date an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

The PMP extension notification does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).

The Permittee shall implement the PMPs.

- (c) A copy of the PMPs shall be submitted to IDEM, OAQ upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. IDEM, OAQ may require the Permittee to revise its PMPs whenever lack of proper maintenance causes or is the primary contributor to an exceedance of any limitation on emissions.



The PMPs and their submittal do not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).

- (d) To the extent the Permittee is required by 40 CFR Part 60/63 to have an Operation Maintenance, and Monitoring (OMM) Plan for a unit, such Plan is deemed to satisfy the PMP requirements of 326 IAC 1-6-3 for that unit.

**B.11 Emergency Provisions [326 IAC 2-7-16]**

---

- (a) An emergency, as defined in 326 IAC 2-7-1(12), is not an affirmative defense for an action brought for noncompliance with a federal or state health-based emission limitation.

- (b) An emergency, as defined in 326 IAC 2-7-1(12), constitutes an affirmative defense to an action brought for noncompliance with a technology-based emission limitation if the affirmative defense of an emergency is demonstrated through properly signed, contemporaneous operating logs or other relevant evidence that describe the following:

- (1) An emergency occurred and the Permittee can, to the extent possible, identify the causes of the emergency;
- (2) The permitted facility was at the time being properly operated;
- (3) During the period of an emergency, the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards or other requirements in this permit;
- (4) For each emergency lasting one (1) hour or more, the Permittee notified IDEM, OAQ, within four (4) daytime business hours after the beginning of the emergency, or after the emergency was discovered or reasonably should have been discovered;

Telephone Number: 1-800-451-6027 (ask for Office of Air Quality,  
Compliance and Enforcement Branch), or  
Telephone Number: 317-233-0178 (ask for Compliance and Enforcement  
Branch)  
Facsimile Number: 317-233-6865

- (5) For each emergency lasting one (1) hour or more, the Permittee submitted the attached Emergency Occurrence Report Form or its equivalent, either by mail or facsimile to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

within two (2) working days of the time when emission limitations were exceeded due to the emergency.

The notice fulfills the requirement of 326 IAC 2-7-5(3)(C)(ii) and must contain the following:

- (A) A description of the emergency;
- (B) Any steps taken to mitigate the emissions; and

(C) Corrective actions taken.

The notification which shall be submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).

(6) The Permittee immediately took all reasonable steps to correct the emergency.

- (c) In any enforcement proceeding, the Permittee seeking to establish the occurrence of an emergency has the burden of proof.
- (d) This emergency provision supersedes 326 IAC 1-6 (Malfunctions). This permit condition is in addition to any emergency or upset provision contained in any applicable requirement.
- (e) The Permittee seeking to establish the occurrence of an emergency shall make records available upon request to ensure that failure to implement a PMP did not cause or contribute to an exceedance of any limitations on emissions. However, IDEM, OAQ may require that the Preventive Maintenance Plans required under 326 IAC 2-7-4(c)(8) be revised in response to an emergency.
- (f) Failure to notify IDEM, OAQ by telephone or facsimile of an emergency lasting more than one (1) hour in accordance with (b)(4) and (5) of this condition shall constitute a violation of 326 IAC 2-7 and any other applicable rules.
- (g) If the emergency situation causes a deviation from a technology-based limit, the Permittee may continue to operate the affected emitting facilities during the emergency provided the Permittee immediately takes all reasonable steps to correct the emergency and minimize emissions.

B.12 Permit Shield [326 IAC 2-7-15] [326 IAC 2-7-20] [326 IAC 2-7-12]

- (a) Pursuant to 326 IAC 2-7-15, the Permittee has been granted a permit shield. The permit shield provides that compliance with the conditions of this permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that either the applicable requirements are included and specifically identified in this permit or the permit contains an explicit determination or concise summary of a determination that other specifically identified requirements are not applicable. The Indiana statutes from IC 13 and rules from 326 IAC, referenced in conditions in this permit, are those applicable at the time the permit was issued. The issuance or possession of this permit shall not alone constitute a defense against an alleged violation of any law, regulation or standard, except for the requirement to obtain a Part 70 permit under 326 IAC 2-7 or for applicable requirements for which a permit shield has been granted.

This permit shield does not extend to applicable requirements which are promulgated after the date of issuance of this permit unless this permit has been modified to reflect such new requirements.

- (b) In addition to the nonapplicability determinations set forth in Sections D of this permit, the IDEM, OAQ has made the following determinations regarding this source:
  - (1) The requirements of the New Source Performance Standard for Fossil-Fuel Fired Steam Generators for Which Construction is Commenced after August 17, 1971, 326 IAC 12 and 40 CFR 60.40, Subpart D are not included in the permit for

Boilers 4 and 5 identified as Emission Unit ID BLR 4 and BLR 5. Construction of these units commenced prior to August 17, 1971 and each has a capacity less than 250 MMBtu/hr. Boiler 6 identified as Emission Unit ID BLR6 is also not subject because it was approved in 2011 for construction and has a capacity of 99 MMBtu/hr.

- (2) The requirements of the New Source Performance Standard for Electric Utility Steam Generating Units for Which Construction is Commenced After September 18, 1978, 326 IAC 12 and 40 CFR 60.40a, Subpart Da are not included in the permit because Boilers 4 and 5 identified as Emission Unit ID BLR 4 and BLR 5 has less than two hundred and fifty (250) million Btu per hour heat input and each unit commenced construction prior to August 17, 1971. Boiler 6 identified as Emission Unit ID BLR6 is also not subject because it was approved in 2011 for construction and has a capacity of 99 MMBtu/hr.
- (3) The requirements of the New Source Performance Standard for Industrial-Commercial-Institutional Steam Generating Units, 326 IAC 12 and 40 CFR 60.40b, Subpart Db are not included in the permit because Boilers 4 and 5 identified as Emission Unit ID BLR 4 and BLR 5 has less than two hundred and fifty (250) million Btu per hour heat input and each unit commenced construction prior to August 17, 1971. Boiler 6 identified as Emission Unit ID BLR6 is also not subject because it was approved in 2011 for construction and has a capacity of 99 MMBtu/hr.
- (4) The requirements of the New Source Performance Standard for Industrial-Commercial-Institutional Steam Generating Units, 326 IAC 12 and 40 CFR 60.40c, Subpart Dc are not included in the permit for Boilers 4 and 5 identified as Emission Unit ID BLR 4 and BLR 5 because each unit commenced construction prior June 9, 1989.
- (5) The requirements of the New Source Performance Standard for Stationary Gas Turbines, 326 IAC 12 and 40 CFR 60.330 Subpart GG, are not included in the permit because there are no stationary gas turbines with a heat input at peak load equal to or greater than 10 MMBtu/hr that was constructed, reconstruction or was modified after the applicability date of the NSPS of October 3, 1977.
- (6) Reserved
- (7) The requirements of the New Source Performance Standard for Stationary Spark Ignition Internal Combustion Engines, 326 IAC 12 and 40 CFR 60.4230, Subpart JJJJ are not included in the permit because there are no spark ignition internal combustion engines in operation at the facility.
- (8) Reserved
- (9) The requirements of the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Industrial Process Cooling Towers, 326 IAC 20, 40 CFR 63, Subpart Q are not included in the permit because Allison Transmission is not a major source of HAP emissions.
- (10) The requirements of the National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines, 326 IAC 20, 40 CFR 63, Subpart YYYY, because the source is not a major source of hazardous air pollutants (HAP). This rule, promulgated on August 29, 2003, is applicable to stationary turbines located at a major source of hazardous air pollutants. Allison

Transmission does not have the potential to emit single or combined HAPs at major source levels.

- (11) Reserved
  - (12) The requirements of the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Site Remediation, 326 IAC 20, 40 CFR 63, Subpart GGGGG are not included in the permit because it is not a major source of HAP emissions and the site remediation project is owned and operated by a third party.
  - (13) The requirements of the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Engine Test Cells/Test Stands, 326 IAC 20, 40 CFR 63, Subpart PPPPP are not included in the permit because it is not a major source of HAP emissions.
  - (14) The requirements of the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Nine Metal Fabrication and Finishing Source Categories, 326 IAC 20, 40 CFR 63, Subpart XXXXXX are not included in the permit because the source is not primarily engaged in the operations in any of the nine source categories listed in this subpart. Additionally Table 1 (Regulated Categories and Entities Potentially Affected) found on page 42979 of the Federal Register dated July 23, 2008 does not list NAICS code 336350 which describes the source's primary operations.
  - (15) The requirements of the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Halogenated Solvent Cleaning, 326 IAC 20, 40 CFR 63.460, Subpart T are not included in the permit because the source does not utilize any solvent specifically identified in 40 CFR 63.460(a) in a total concentration greater than five percent (5.0%) by weight as a cleaning or drying agent in an individual batch vapor, in-line vapor, in-line cold or batch cold solvent cleaning machine. Wipe cleaning activities, such as using a rag containing halogenated solvent or a spray cleaner using halogenated solvent are not covered under the provisions of this Subpart.
  - (16) The requirements of the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Steel Pickling-HCl Process Facilities and Hydrochloric Acid Regeneration Plants, 326 IAC 20, 40 CFR 63.1155, Subpart CCC are not included in the permit because the source is not a major source of hazardous air pollutants (HAP) nor are the tanks parts of facilities that are major sources of HAP.
- (c) If, after issuance of this permit, it is determined that the permit is in nonconformance with an applicable requirement that applied to the source on the date of permit issuance, IDEM, OAQ, shall immediately take steps to reopen and revise this permit and issue a compliance order to the Permittee to ensure expeditious compliance with the applicable requirement until the permit is reissued. The permit shield shall continue in effect so long as the Permittee is in compliance with the compliance order.
  - (d) No permit shield shall apply to any permit term or condition that is determined after issuance of this permit to have been based on erroneous information supplied in the permit application. Erroneous information means information that the Permittee knew to be false, or in the exercise of reasonable care should have been known to be false, at the time the information was submitted.

- (e) Nothing in 326 IAC 2-7-15 or in this permit shall alter or affect the following:
  - (1) The provisions of Section 303 of the Clean Air Act (emergency orders), including the authority of the U.S. EPA under Section 303 of the Clean Air Act;
  - (2) The liability of the Permittee for any violation of applicable requirements prior to or at the time of this permit's issuance;
  - (3) The applicable requirements of the acid rain program, consistent with Section 408(a) of the Clean Air Act; and
  - (4) The ability of U.S. EPA to obtain information from the Permittee under Section 114 of the Clean Air Act.
- (f) This permit shield is not applicable to any change made under 326 IAC 2-7-20(b)(2) (Sections 502(b)(10) of the Clean Air Act changes) and 326 IAC 2-7-20(c)(2) (trading based on State Implementation Plan (SIP) provisions).
- (g) This permit shield is not applicable to modifications eligible for group processing until after IDEM, OAQ, has issued the modifications. [326 IAC 2-7-12(c)(7)]
- (h) This permit shield is not applicable to minor Part 70 permit modifications until after IDEM, OAQ, has issued the modification. [326 IAC 2-7-12(b)(8)]

**B.13 Prior Permits Superseded [326 IAC 2-1.1-9.5] [326 IAC 2-7-10.5]**

---

- (a) All terms and conditions of permits established prior to T097-27011-00310 and issued pursuant to permitting programs approved into the state implementation plan have been either:
  - (1) incorporated as originally stated,
  - (2) revised under 326 IAC 2-7-10.5, or
  - (3) deleted under 326 IAC 2-7-10.5.
- (b) Provided that all terms and conditions are accurately reflected in this permit, all previous registrations and permits are superseded by this Part 70 operating permit.

**B.14 Termination of Right to Operate [326 IAC 2-7-10] [326 IAC 2-7-4(a)]**

---

The Permittee's right to operate this source terminates with the expiration of this permit unless a timely and complete renewal application is submitted at least nine (9) months prior to the date of expiration of the source's existing permit, consistent with 326 IAC 2-7-3 and 326 IAC 2-7-4(a).

**B.15 Permit Modification, Reopening, Revocation and Reissuance, or Termination [326 IAC 2-7-5(6)(C)] [326 IAC 2-7-8(a)] [326 IAC 2-7-9]**

---

- (a) This permit may be modified, reopened, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a Part 70 Operating Permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any condition of this permit. [326 IAC 2-7-5(6)(C)] The notification by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).

- (b) This permit shall be reopened and revised under any of the circumstances listed in IC 13-15-7-2 or if IDEM, OAQ determines any of the following:
  - (1) That this permit contains a material mistake.
  - (2) That inaccurate statements were made in establishing the emissions standards or other terms or conditions.
  - (3) That this permit must be revised or revoked to assure compliance with an applicable requirement. [326 IAC 2-7-9(a)(3)]
- (c) Proceedings by IDEM, OAQ to reopen and revise this permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of this permit for which cause to reopen exists. Such reopening and revision shall be made as expeditiously as practicable. [326 IAC 2-7-9(b)]
- (d) The reopening and revision of this permit, under 326 IAC 2-7-9(a), shall not be initiated before notice of such intent is provided to the Permittee by IDEM, OAQ at least thirty (30) days in advance of the date this permit is to be reopened, except that IDEM, OAQ may provide a shorter time period in the case of an emergency. [326 IAC 2-7-9(c)]

**B.16 Permit Renewal [326 IAC 2-7-3] [326 IAC 2-7-4] [326 IAC 2-7-8(e)]**

---

- (a) The application for renewal shall be submitted using the application form or forms prescribed by IDEM, OAQ and shall include the information specified in 326 IAC 2-7-4. Such information shall be included in the application for each emission unit at this source, except those emission units included on the trivial or insignificant activities list contained in 326 IAC 2-7-1(21) and 326 IAC 2-7-1(40). The renewal application does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).

Request for renewal shall be submitted to:

Indiana Department of Environmental Management  
Permit Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

- (b) A timely renewal application is one that is:
  - (1) Submitted at least nine (9) months prior to the date of the expiration of this permit; and
  - (2) If the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
- (c) If the Permittee submits a timely and complete application for renewal of this permit, the source's failure to have a permit is not a violation of 326 IAC 2-7 until IDEM, OAQ takes final action on the renewal application, except that this protection shall cease to apply if, subsequent to the completeness determination, the Permittee fails to submit by the deadline specified, pursuant to 326 IAC 2-7-4(a)(2)(D), in writing by IDEM, OAQ any additional information identified as being needed to process the application.

**B.17 Permit Amendment or Modification [326 IAC 2-7-11] [326 IAC 2-7-12]**

---

- (a) Permit amendments and modifications are governed by the requirements of 326 IAC 2-7-11 or 326 IAC 2-7-12 whenever the Permittee seeks to amend or modify this permit.

- (b) Any application requesting an amendment or modification of this permit shall be submitted to:

Indiana Department of Environmental Management  
Permit Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

Any such application does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).

- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-7-11(c)(3)]

**B.18 Permit Revision Under Economic Incentives and Other Programs [326 IAC 2-7-5(8)] [326 IAC 2-7-12(b)(2)]**

---

- (a) No Part 70 permit revision or notice shall be required under any approved economic incentives, marketable Part 70 permits, emissions trading, and other similar programs or processes for changes that are provided for in a Part 70 permit.
- (b) Notwithstanding 326 IAC 2-7-12(b)(1) and 326 IAC 2-7-12(c)(1), minor Part 70 permit modification procedures may be used for Part 70 modifications involving the use of economic incentives, marketable Part 70 permits, emissions trading, and other similar approaches to the extent that such minor Part 70 permit modification procedures are explicitly provided for in the applicable State Implementation Plan (SIP) or in applicable requirements promulgated or approved by the U.S. EPA.

**B.19 Operational Flexibility [326 IAC 2-7-20] [326 IAC 2-7-10.5]**

---

- (a) The Permittee may make any change or changes at the source that are described in 326 IAC 2-7-20(b) or (c) without a prior permit revision, if each of the following conditions is met:
- (1) The changes are not modifications under any provision of Title I of the Clean Air Act;
  - (2) Any preconstruction approval required by 326 IAC 2-7-10.5 has been obtained;
  - (3) The changes do not result in emissions which exceed the limitations provided in this permit (whether expressed herein as a rate of emissions or in terms of total emissions);

- (4) The Permittee notifies the:

Indiana Department of Environmental Management  
Permit Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

and

United States Environmental Protection Agency, Region V  
Air and Radiation Division, Regulation Development Branch - Indiana (AR-18J)  
77 West Jackson Boulevard  
Chicago, Illinois 60604-3590

in advance of the change by written notification at least ten (10) days in advance of the proposed change. The Permittee shall attach every such notice to the Permittee's copy of this permit; and

- (5) The Permittee maintains records on-site, on a rolling five (5) year basis, which document all such changes and emission trades that are subject to 326 IAC 2-7-20(b) or (c). The Permittee shall make such records available, upon reasonable request, for public review.

Such records shall consist of all information required to be submitted to IDEM, OAQ in the notices specified in 326 IAC 2-7-20(b)(1) and (c)(1).

- (b) The Permittee may make Section 502(b)(10) of the Clean Air Act changes (this term is defined at 326 IAC 2-7-1(36)) without a permit revision, subject to the constraint of 326 IAC 2-7-20(a). For each such Section 502(b)(10) of the Clean Air Act change, the required written notification shall include the following:

- (1) A brief description of the change within the source;
- (2) The date on which the change will occur;
- (3) Any change in emissions; and
- (4) Any permit term or condition that is no longer applicable as a result of the change.

The notification which shall be submitted is not considered an application form, report or compliance certification. Therefore, the notification by the Permittee does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).

- (c) Emission Trades [326 IAC 2-7-20(c)]  
The Permittee may trade emissions increases and decreases at the source, where the applicable SIP provides for such emission trades without requiring a permit revision, subject to the constraints of Section (a) of this condition and those in 326 IAC 2-7-20(c).
- (d) Alternative Operating Scenarios [326 IAC 2-7-20(d)]  
The Permittee may make changes at the source within the range of alternative operating scenarios that are described in the terms and conditions of this permit in accordance with 326 IAC 2-7-5(9). No prior notification of IDEM, OAQ, or U.S. EPA is required.



- (e) Backup fuel switches specifically addressed in, and limited under, Section D of this permit shall not be considered alternative operating scenarios. Therefore, the notification requirements of part (a) of this condition do not apply.

**B.20 Source Modification Requirement [326 IAC 2-7-10.5]**

---

A modification, construction, or reconstruction is governed by the requirements of 326 IAC 2.

**B.21 Inspection and Entry [326 IAC 2-7-6] [IC 13-14-2-2] [IC 13-30-3-1] [IC 13-17-3-2]**

---

Upon presentation of proper identification cards, credentials, and other documents as may be required by law, and subject to the Permittee's right under all applicable laws and regulations to assert that the information collected by the agency is confidential and entitled to be treated as such, the Permittee shall allow IDEM, OAQ, U.S. EPA, or an authorized representative to perform the following:

- (a) Enter upon the Permittee's premises where a Part 70 source is located, or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
- (b) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, have access to and copy any records that must be kept under the conditions of this permit;
- (c) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, inspect any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit;
- (d) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, sample or monitor substances or parameters for the purpose of assuring compliance with this permit or applicable requirements; and
- (e) As authorized by the Clean Air Act, IC 13-14-2-2, IC 13-17-3-2, and IC 13-30-3-1, utilize any photographic, recording, testing, monitoring, or other equipment for the purpose of assuring compliance with this permit or applicable requirements.

**B.22 Transfer of Ownership or Operational Control [326 IAC 2-7-11]**

---

- (a) The Permittee must comply with the requirements of 326 IAC 2-7-11 whenever the Permittee seeks to change the ownership or operational control of the source and no other change in the permit is necessary.
- (b) Any application requesting a change in the ownership or operational control of the source shall contain a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new Permittee. The application shall be submitted to:

Indiana Department of Environmental Management  
Permit Administration and Support Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

Any such application does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).

- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-7-11(c)(3)]

**B.23 Annual Fee Payment [326 IAC 2-7-19] [326 IAC 2-7-5(7)] [326 IAC 2-1.1-7]**

---

- (a) The Permittee shall pay annual fees to IDEM, OAQ within thirty (30) calendar days of receipt of a billing. Pursuant to 326 IAC 2-7-19(b), if the Permittee does not receive a bill from IDEM, OAQ the applicable fee is due April 1 of each year.
- (b) Except as provided in 326 IAC 2-7-19(e), failure to pay may result in administrative enforcement action or revocation of this permit.
- (c) The Permittee may call the following telephone numbers: 1-800-451-6027 or 317-233-4230 (ask for OAQ, Billing, Licensing, and Training Section), to determine the appropriate permit fee.

**B.24 Credible Evidence [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [62 FR 8314] [326 IAC 1-1-6]**

---

For the purpose of submitting compliance certifications or establishing whether or not the Permittee has violated or is in violation of any condition of this permit, nothing in this permit shall preclude the use, including the exclusive use, of any credible evidence or information relevant to whether the Permittee would have been in compliance with the emission limitation, standard or rule if the appropriate performance or compliance test or procedure had been performed.

## SECTION C

## SOURCE OPERATION CONDITIONS

Entire Source

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

**C.1 Particulate Emission Limitations For Processes with Process Weight Rates Less Than One Hundred (100) Pounds per Hour [326 IAC 6-3-2]**

Pursuant to 326 IAC 6-3-2(e)(2), particulate emissions from any process not exempt under 326 IAC 6-3-1(b) or (c) which has a maximum process weight rate less than 100 pounds per hour and the methods in 326 IAC 6-3-2(b) through (d) do not apply shall not exceed 0.551 pounds per hour.

**C.2 Opacity [326 IAC 5-1]**

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-1 (Applicability) and 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this permit:

- (a) Opacity shall not exceed an average of thirty percent (30%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

**C.3 Open Burning [326 IAC 4-1] [IC 13-17-9]**

The Permittee shall not open burn any material except as provided in 326 IAC 4-1-3, 326 IAC 4-1-4 or 326 IAC 4-1-6. The previous sentence notwithstanding, the Permittee may open burn in accordance with an open burning approval issued by the Commissioner under 326 IAC 4-1-4.1. 326 IAC 4-1-3(a)(2)(D) and (E); 4-1-3(b)(2)(A)&(B); 4-1-3(b)(3)(D), 4-1-3(b)(4) & (5); 4-1-3(c)(1)(B)-(F); 4-1-3(C)(2)(B); 4-1-3(c)(6); 4-1-3(c)(8); and 4-1-6 are not federally enforceable.

**C.4 Incineration [326 IAC 4-2] [326 IAC 9-1-2]**

The Permittee shall not operate an incinerator except as provided in 326 IAC 4-2 or in this permit. The Permittee shall not operate a refuse incinerator or refuse burning equipment except as provided in 326 IAC 9-1-2 or in this permit.

**C.5 Fugitive Dust Emissions [326 IAC 6-4]**

The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions). 326 IAC 6-4-2(4) is not federally enforceable.

**C.6 Stack Height [326 IAC 1-7]**

The Permittee shall comply with the applicable provisions of 326 IAC 1-7 (Stack Height Provisions), for all exhaust stacks through which a potential (before controls) of twenty-five (25) tons per year or more of particulate matter or sulfur dioxide is emitted. The provisions of 326 IAC 1-7-1(3), 326 IAC 1-7-2, 326 IAC 1-7-3(c) and (d), 326 IAC 1-7-4, and 326 IAC 1-7-5(a), (b), and (d) are not federally enforceable.

**C.7 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61, Subpart M]**

---

- (a) Notification requirements apply to each owner or operator. If the combined amount of regulated asbestos containing material (RACM) to be stripped, removed or disturbed is at least 260 linear feet on pipes or 160 square feet on other facility components, or at least thirty-five (35) cubic feet on all facility components, then the notification requirements of 326 IAC 14-10-3 are mandatory. All demolition projects require notification whether or not asbestos is present.
- (b) The Permittee shall ensure that a written notification is sent on a form provided by the Commissioner at least ten (10) working days before asbestos stripping or removal work or before demolition begins, per 326 IAC 14-10-3, and shall update such notice as necessary, including, but not limited to the following:
  - (1) When the amount of affected asbestos containing material increases or decreases by at least twenty percent (20%); or
  - (2) If there is a change in the following:
    - (A) Asbestos removal or demolition start date;
    - (B) Removal or demolition contractor; or
    - (C) Waste disposal site.
- (c) The Permittee shall ensure that the notice is postmarked or delivered according to the guidelines set forth in 326 IAC 14-10-3(2).
- (d) The notice to be submitted shall include the information enumerated in 326 IAC 14-10-3(3).

All required notifications shall be submitted to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

The notice shall include a signed certification from the owner or operator that the information provided in this notification is correct and that only Indiana licensed workers and project supervisors will be used to implement the asbestos removal project. The notifications do not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).

- (e) **Procedures for Asbestos Emission Control**  
The Permittee shall comply with the applicable emission control procedures in 326 IAC 14-10-4 and 40 CFR 61.145(c). Per 326 IAC 14-10-1, emission control requirements are applicable for any removal or disturbance of RACM greater than three (3) linear feet on pipes or three (3) square feet on any other facility components or a total of at least 0.75 cubic feet on all facility components.

- (f) Demolition and Renovation  
The Permittee shall thoroughly inspect the affected facility or part of the facility where the demolition or renovation will occur for the presence of asbestos pursuant to 40 CFR 61.145(a).
- (g) Indiana Licensed Asbestos Inspector  
The Permittee shall comply with 326 IAC 14-10-1(a) that requires the owner or operator, prior to a renovation/demolition, to use an Indiana Licensed Asbestos Inspector to thoroughly inspect the affected portion of the facility for the presence of asbestos. The requirement to use an Indiana Licensed Asbestos inspector is not federally enforceable.

### **Testing Requirements [326 IAC 2-7-6(1)]**

#### **C.8 Performance Testing [326 IAC 3-6]**

---

- (a) For performance testing required by this permit, a test protocol, except as provided elsewhere in this permit, shall be submitted to:  
  
Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251  
  
no later than thirty-five (35) days prior to the intended test date. The protocol submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).
- (b) The Permittee shall notify IDEM, OAQ of the actual test date at least fourteen (14) days prior to the actual test date. The notification submitted by the Permittee does not require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).
- (c) Pursuant to 326 IAC 3-6-4(b), all test reports must be received by IDEM, OAQ not later than forty-five (45) days after the completion of the testing. An extension may be granted by IDEM, OAQ if the Permittee submits to IDEM, OAQ a reasonable written explanation not later than five (5) days prior to the end of the initial forty-five (45) day period.
- (d) In addition to any other testing required by this permit if at any time the Permittee replaces a control device that is used to comply with an emission limitation listed in Section D, then the Permittee shall conduct a performance test no later than one hundred eighty (180) days after installation of the replacement control device in accordance with this Condition.

### **Compliance Requirements [326 IAC 2-1.1-11]**

#### **C.9 Compliance Requirements [326 IAC 2-1.1-11]**

---

The commissioner may require stack testing, monitoring, or reporting at any time to assure compliance with all applicable requirements by issuing an order under 326 IAC 2-1.1-11. Any monitoring or testing shall be performed in accordance with 326 IAC 3 or other methods approved by the commissioner or the U. S. EPA.

### **Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]**

#### **C.10 Compliance Monitoring [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]**

---

Unless otherwise specified in this permit, for all monitoring requirements not already legally required, the Permittee shall be allowed up to ninety (90) days from the date of permit issuance or

of initial start-up, whichever is later to begin such monitoring. If due to circumstances beyond the Permittee's control, any monitoring equipment required by this permit cannot be installed and operated no later than ninety (90) days after permit issuance or the date of initial startup, whichever is later, the Permittee may extend the compliance schedule related to the equipment for an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

in writing, prior to the end of the initial ninety (90) day compliance schedule, with full justification of the reasons for the inability to meet this date.

The notification which shall be submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).

Unless otherwise specified in the approval for the new emission unit(s), compliance monitoring for new emission units or emission units added through a source modification shall be implemented when operation begins.

---

C.11 Instrument Specifications [326 IAC 2-1.1-11] [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

- (a) When required by any condition of this permit, an analog instrument used to measure a parameter related to the operation of an air pollution control device shall have a scale such that the expected maximum reading for the normal range shall be no less than twenty percent (20%) of full scale.
- (b) The Permittee may request that the IDEM, OAQ approve the use of an instrument that does not meet the above specifications provided the Permittee can demonstrate that an alternative instrument specification will adequately ensure compliance with permit conditions requiring the measurement of the parameters.

**Corrective Actions and Response Steps [326 IAC 2-7-5] [326 IAC 2-7-6]**

---

C.12 Emergency Reduction Plans [326 IAC 1-5-2] [326 IAC 1-5-3]

Pursuant to 326 IAC 1-5-2 (Emergency Reduction Plans; Submission):

- (a) The Permittee shall maintain the most recently submitted written emergency reduction plans (ERPs) consistent with safe operating procedures.
- (b) Upon direct notification by IDEM, OAQ that a specific air pollution episode level is in effect, the Permittee shall immediately put into effect the actions stipulated in the approved ERP for the appropriate episode level. [326 IAC 1-5-3]

---

C.13 Risk Management Plan [326 IAC 2-7-5(11)] [40 CFR 68]

If a regulated substance, as defined in 40 CFR 68, is present at a source in more than a threshold quantity, the Permittee must comply with the applicable requirements of 40 CFR 68.

---

C.14 Response to Excursions or Exceedances [326 IAC 2-7-5] [326 IAC 2-7-6]

Upon detecting an excursion where a response step is required by the D Section or an exceedance of a limitation in this permit:

- (a) The Permittee shall take reasonable response steps to restore operation of the emissions unit (including any control device and associated capture system) to its normal or usual

manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing excess emissions.

- (b) The response shall include minimizing the period of any startup, shutdown or malfunction. The response may include, but is not limited to, the following:
  - (1) initial inspection and evaluation;
  - (2) recording that operations returned or are returning to normal without operator action (such as through response by a computerized distribution control system); or
  - (3) any necessary follow-up actions to return operation to normal or usual manner of operation.
- (c) A determination of whether the Permittee has used acceptable procedures in response to an excursion or exceedance will be based on information available, which may include, but is not limited to, the following:
  - (1) monitoring results;
  - (2) review of operation and maintenance procedures and records; and/or
  - (3) inspection of the control device, associated capture system, and the process.
- (d) Failure to take reasonable response steps shall be considered a deviation from the permit.
- (e) The Permittee shall record the reasonable response steps taken.

**C.15 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5] [326 IAC 2-7-6]**

- (a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this permit exceed the level specified in any condition of this permit, the Permittee shall submit a description of its response actions to IDEM, OAQ, no later than seventy-five (75) days after the date of the test.
- (b) A retest to demonstrate compliance shall be performed no later than one hundred eighty (180) days after the date of the test. Should the Permittee demonstrate to IDEM, OAQ that retesting in one hundred eighty (180) days is not practicable, IDEM, OAQ may extend the retesting deadline.
- (c) IDEM, OAQ reserves the authority to take any actions allowed under law in response to noncompliant stack tests.

The response action documents submitted pursuant to this condition do require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).

**Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

**C.16 Emission Statement [326 IAC 2-7-5(3)(C)(iii)] [326 IAC 2-7-5(7)] [326 IAC 2-7-19(c)] [326 IAC 2-6]**

- (a) Pursuant to 326 IAC 2-6-3(a)(1), the Permittee shall submit by July 1 of each year an emission statement covering the previous calendar year.
- (b) The emission statement shall contain, at a minimum, the information specified in 326 IAC 2-6-4(c) and shall meet the following requirements:

- (1) Indicate estimated actual emissions of all pollutants listed in 326 IAC 2-6-4(a);
- (2) Indicate estimated actual emissions of regulated pollutants as defined by 326 IAC 2-7-1(32) ("Regulated pollutant, which is used only for purposes of Section 19 of this rule") from the source, for purpose of fee assessment.

The statement must be submitted to:

Indiana Department of Environmental Management  
Technical Support and Modeling Section, Office of Air Quality  
100 North Senate Avenue  
MC 61-50 IGCN 1003  
Indianapolis, Indiana 46204-2251

The emission statement does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1-(34).

C.17 General Record Keeping Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-6] [326 IAC 2-2]  
[326 IAC 2-3]

---

- (a) Records of all required monitoring data, reports and support information required by this permit shall be retained for a period of at least five (5) years from the date of monitoring sample, measurement, report, or application. Support information includes the following:
  - (AA) All calibration and maintenance records.
  - (BB) All original strip chart recordings for continuous monitoring instrumentation.
  - (CC) Copies of all reports required by the Part 70 permit.Records of required monitoring information include the following:
  - (AA) The date, place, as defined in this permit, and time of sampling or measurements.
  - (BB) The dates the analyses were performed.
  - (CC) The company or entity that performed the analyses.
  - (DD) The analytical techniques or methods used.
  - (EE) The results of such analyses.
  - (FF) The operating conditions as existing at the time of sampling or measurement.These records shall be physically present or electronically accessible at the source location for a minimum of three (3) years. The records may be stored elsewhere for the remaining two (2) years as long as they are available upon request. If the Commissioner makes a request for records to the Permittee, the Permittee shall furnish the records to the Commissioner within a reasonable time.
- (b) Unless otherwise specified in this permit, for all record keeping requirements not already legally required, the Permittee shall be allowed up to ninety (90) days from the date of permit issuance or the date of initial start-up, whichever is later, to begin such record keeping.
- (c) If there is a reasonable possibility (as defined in 326 IAC 2-2-8(b)(6)(A), 326 IAC 2-2-8(b)(6)(B), 326 IAC 2-3-2(l)(6)(A), and/or 326 IAC 2-3-2(l)(6)(B)) that a "project" (as defined in 326 IAC 2-2-1(oo) and/or 326 IAC 2-3-1(jj)) at an existing emissions unit, other than projects at a source with a Plantwide Applicability Limitation (PAL), which is not part of a "major modification" (as defined in 326 IAC 2-2-1(dd) and/or 326 IAC 2-3-1(y)) may result in significant emissions increase and the Permittee elects to utilize the "projected actual emissions" (as defined in 326 IAC 2-2-1(pp) and/or 326 IAC 2-3-1(kk)), the Permittee shall comply with following:



- (1) Before beginning actual construction of the "project" (as defined in 326 IAC 2-2-1(o) and/or 326 IAC 2-3-1(j)) at an existing emissions unit, document and maintain the following records:
  - (A) A description of the project.
  - (B) Identification of any emissions unit whose emissions of a regulated new source review pollutant could be affected by the project.
  - (C) A description of the applicability test used to determine that the project is not a major modification for any regulated NSR pollutant, including:
    - (i) Baseline actual emissions;
    - (ii) Projected actual emissions;
    - (iii) Amount of emissions excluded under section 326 IAC 2-2-1(p)(2)(A)(iii) and/or 326 IAC 2-3-1(k)(2)(A)(iii); and
    - (iv) An explanation for why the amount was excluded, and any netting calculations, if applicable.
- (d) If there is a reasonable possibility (as defined in 326 IAC 2-2-8(b)(6)(A) and/or 326 IAC 2-3-2(l)(6)(A)) that a "project" (as defined in 326 IAC 2-2-1(o) and/or 326 IAC 2-3-1(j)) at an existing emissions unit, other than projects at a source with a Plantwide Applicability Limitation (PAL), which is not part of a "major modification" (as defined in 326 IAC 2-2-1(d) and/or 326 IAC 2-3-1(y)) may result in significant emissions increase and the Permittee elects to utilize the "projected actual emissions" (as defined in 326 IAC 2-2-1(p) and/or 326 IAC 2-3-1(k)), the Permittee shall comply with following:
  - (1) Monitor the emissions of any regulated NSR pollutant that could increase as a result of the project and that is emitted by any existing emissions unit identified in (1)(B) above; and
  - (2) Calculate and maintain a record of the annual emissions, in tons per year on a calendar year basis, for a period of five (5) years following resumption of regular operations after the change, or for a period of ten (10) years following resumption of regular operations after the change if the project increases the design capacity of or the potential to emit that regulated NSR pollutant at the emissions unit.

C.18 General Reporting Requirements [326 IAC 2-7-5(3)(C)] [326 IAC 2-1.1-11] [326 IAC 2-2]  
[326 IAC 2-3]

- 
- (a) The Permittee shall submit the attached Quarterly Deviation and Compliance Monitoring Report or its equivalent. Proper notice submittal under Section B –Emergency Provisions satisfies the reporting requirements of this paragraph. Any deviation from permit requirements, the date(s) of each deviation, the cause of the deviation, and the response steps taken must be reported- except that a deviation required to be reported pursuant to an applicable requirement that exists independent of this permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. This report shall be submitted not later than thirty (30) days after the end of the reporting period. The Quarterly Deviation and Compliance Monitoring Report shall include a certification that meets the requirements of 326 IAC 2-7-6(1) by a

"responsible official" as defined by 326 IAC 2-7-1(35). A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit.

- (b) The address for report submittal is:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

- (c) Unless otherwise specified in this permit, any notice, report, or other submission required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.
- (d) Reporting periods are based on calendar years, unless otherwise specified in this permit. For the purpose of this permit "calendar year" means the twelve (12) month period from January 1 to December 31 inclusive.
- (e) If the Permittee is required to comply with the recordkeeping provisions of (d) in Section C - General Record Keeping Requirements for any "project" (as defined in 326 IAC 2-2-1(oo) and/or 326 IAC 2-3-1(jj)) at an existing emissions unit, and the project meets the following criteria, then the Permittee shall submit a report to IDEM, OAQ:
- (1) The annual emissions, in tons per year, from the project identified in (c)(1) in Section C- General Record Keeping Requirements exceed the baseline actual emissions, as documented and maintained under Section C- General Record Keeping Requirements (c)(1)(C)(i), by a significant amount, as defined in 326 IAC 2-2-1(ww) and/or 326 IAC 2-3-1(pp), for that regulated NSR pollutant, and
  - (2) The emissions differ from the preconstruction projection as documented and maintained under Section C - General Record Keeping Requirements (c)(1)(C)(ii).
- (f) The report for project at an existing emissions unit shall be submitted no later than sixty (60) days after the end of the year and contain the following:
- (1) The name, address, and telephone number of the major stationary source.
  - (2) The annual emissions calculated in accordance with (d)(1) and (2) in Section C - General Record Keeping Requirements.
  - (3) The emissions calculated under the actual-to-projected actual test stated in 326 IAC 2-2-2(d)(3) and/or 326 IAC 2-3-2(c)(3).
  - (4) Any other information that the Permittee wishes to include in this report such as an explanation as to why the emissions differ from the preconstruction projection.

Reports required in this part shall be submitted to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

- (g) The Permittee shall make the information required to be documented and maintained in accordance with (c) in Section C- General Record Keeping Requirements available for review upon a request for inspection by IDEM, OAQ. The general public may request this information from the IDEM, OAQ under 326 IAC 17.1.

### **Stratospheric Ozone Protection**

#### **C.19 Compliance with 40 CFR 82 and 326 IAC 22-1**

---

Pursuant to 40 CFR 82 (Protection of Stratospheric Ozone), Subpart F, except as provided for motor vehicle air conditioners in Subpart B, the Permittee shall comply with applicable standards for recycling and emissions reduction.

## SECTION D.1

## FACILITY OPERATION CONDITIONS

### Facility Description [326 IAC 2-7-5(14)]

- (a) One (1) Union Iron Works Boiler, identified as emission unit BLR 4, capable of combusting only natural gas, with a maximum capacity of seventy two (72) million British thermal units (MMBtu) Btu per hour, exhausting out one stack identified as stack ID# 3107 and constructed in 1953.
- (b) One (1) Union Iron Works Boiler, identified as emission unit BLR 5, capable of combusting -only natural gas, with a maximum capacity of ninety six (96) million British thermal units (MMBtu) Btu per hour, exhausting out one stack identified as stack ID# 3108 and constructed in 1969.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

#### D.1.1 Particulate Rules: Marion County [326 IAC 6.5-6-2(a)] [326 IAC 6.5-6-2(b)]

- (a) Pursuant to 326 IAC 6.5-6-2(a), filterable particulate (PM) emissions from emission units BLR 4 and BLR 5 shall be limited to:
  - (1) 0.15 pounds per million Btu for each emission unit; and
  - (2) 39.3 tons per year for all emission units combined.
- (b) Pursuant to 326 IAC 6.5-6-2(b), compliance with the filterable particulate (PM) emissions limit in Condition D.1.1(a) shall be determined at the end of each month based on the sum of the monthly calculated emissions for the most recent twelve (12) consecutive month period. The monthly emissions shall be calculated using AP-42 emissions factors or alternative emission factors approved by the Commissioner.

#### D.1.2 Preventive Maintenance Plan [326 IAC 2-7-5(12)]

A Preventive Maintenance Plan is required for emission units BLR 4 and BLR 5. Section B - Preventive Maintenance Plan contains the Permittee's obligation with regard to the preventive maintenance plan required by this condition.

### Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

#### D.1.3 Record Keeping Requirements

- (a) To document the compliance status with Condition D.1.1(b), the Permittee shall maintain monthly fuel usage records for each boiler BLR 4 and BLR 5.
- (b) Section C - General Record Keeping Requirements contains the Permittee's obligation with regard to the records required to be maintained by this condition.

#### D.1.4 Reporting Requirements

A quarterly summary of the information to document the compliance status with Condition D.1.1(b) shall be not later than thirty (30) days after the end of the calendar quarter being reported. Section C - General Reporting contains the Permittee's obligation with regard to the reporting required by this condition. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).

## SECTION D.2 FACILITY OPERATION CONDITIONS

### Facility Description [326 IAC 2-7-5(14)]

- (c) Emission Unit ETC consists of the following twenty five (25) engineering development transmission test cells; 701, 704, 705, 706, 707, 709, 710, 711, 712, 32N, 32S, 38N, 39N, 39S, 40N, 40S, 41N, 41S, 48N, 48S, 49N, 49S, 50, 51N and 51S. The emissions from each test cell 701, 704, 705, 706, 707, 709, 710, 711, 712, 32N, 32S, 38N, 39N, 39S, 40N, 40S, 41N, 41S, 48N, 48S, 49N, 49S, 50, 51N and 51S are exhausted out Stack/Vent PTE 057, PTE 065, PTE 067 PTE 069, PTE 071, PTE 075, PTE 077, PTE 079, PTE 080, PTE 008, PTE 006, PTE 011, PTE 018, PTE 020, PTE 013, PTE 014, PTE 023, PTE 021, PTE 040, PTE 041, PTE 086, PTE 087, PTE 093, PTE 084, and PTE 082, respectively. All test cells were constructed prior to 1977. Test cell 39N was modified during the 1980's. The table below lists the fuel type and engine type that each cell is capable of accommodating based on the physical characteristics of each cell.

| Test Cell ID | Fuel Type | Engine Type                  | Estimated Maximum Engine Size in Horsepower  |
|--------------|-----------|------------------------------|--|
| 701          | Diesel    | Reciprocating or Gas Turbine | 4000   |
| 704          | Diesel    | Reciprocating                | 2400   |
| 705          | Diesel    | Reciprocating or Gas Turbine | 2400 for reciprocating; 4000 for gas turbine |
| 706          | Diesel    | Reciprocating                | 4000   |
| 707          | Diesel    | Reciprocating                | 2400   |
| 709          | Diesel    | Reciprocating                | 2400   |
| 710          | Diesel    | Reciprocating                | 1500   |
| 711          | Diesel    | Reciprocating                | 2400   |
| 712          | Diesel    | Reciprocating                | 1500   |
| 32N          | Diesel    | Reciprocating                | 2400   |
| 32S          | Diesel    | Reciprocating                | 1500   |
| 38N          | Diesel    | Reciprocating                | 4000   |
| 39N          | Diesel    | Reciprocating                | 2400   |
| 39S          | Diesel    | Reciprocating                | 1500   |
| 40N          | Diesel    | Reciprocating                | 1500   |
| 40S          | Diesel    | Reciprocating                | 1500   |
| 41N          | Diesel    | Reciprocating                | 1200   |
| 41S          | Diesel    | Reciprocating                | 1200   |
| 48N          | Diesel    | Reciprocating                | 1200   |
| 48S          | Diesel    | Reciprocating                | 1200   |

| Test Cell ID | Fuel Type          | Engine Type   | Estimated Maximum Engine Size in Horsepower |
|--------------|--------------------|---------------|---|
| 49N          | Diesel             | Reciprocating | 1500  |
| 49S          | Diesel             | Reciprocating | 1500  |
| 50           | Diesel             | Reciprocating | 2400  |
| 51N          | Diesel             | Reciprocating | 1200  |
| 51S          | Gasoline or Diesel | Reciprocating | 700   |

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

#### D.2.1 Particulate Matter Limitations Except Lake County [326 IAC 6.5-1-2(a)]

Pursuant to 326 IAC 6.5-1-2(a) (Particulate Matter Limitations Except Lake County), particulate (PM) emissions from each of the twenty five (25) Test Cells covered under Emissions Unit ETC shall not exceed three hundredths (0.03) grains per dry standard cubic foot of exhaust air.

#### D.2.2 Sulfur Dioxide (SO<sub>2</sub>) [326 IAC 7-1.1-1]

Pursuant to 326 IAC 7-1.1-1 (SO<sub>2</sub> Emissions Limitations), Sulfur Dioxide (SO<sub>2</sub>) emissions from Test Cells 701, 704, 705, 706, 707, 709, 711, 32N, 38N and 50 shall each not exceed five tenths (0.5) pounds per million Btu heat input.

#### D.2.3 PSD Minor Limit [326 IAC 2-2]

Pursuant to 326 IAC 2-2 (Prevention of Significant Deterioration (PSD) Requirements), the following conditions shall apply:

- (a) NO<sub>x</sub> emissions from diesel fuel fired reciprocating engines utilized in Test Cell 39N shall be limited to less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (b) The input of diesel fuel to reciprocating engines utilized in Test Cell 39N shall be less than 182,481 gallons per twelve (12) consecutive month period with compliance determined at the end of each month. For the purposes of determining compliance, each gallon of diesel fuel burned in reciprocating engines that are equal to or less than 600 horsepower shall be equivalent to one and thirty seven hundredths (1.37) gallons of diesel fuel burned in reciprocating engines that are greater than 600 horsepower.

Compliance with the above limits shall render 326 IAC 2-2 (Prevention of Significant Deterioration) not applicable.

#### D.2.4 Preventive Maintenance Plan [326 IAC 2-7-5(12)]

A Preventive Maintenance Plan is required for Emission Unit ETC. Section B - Preventive Maintenance Plan contains the Permittee's obligation with regard to the preventive maintenance plan required by this condition.

## Compliance Determination Requirements

### D.2.5 Sulfur Dioxide Emissions and Sulfur Content

Compliance for Test Cells 701, 704, 705, 706, 707, 709, 711, 32N, 38N and 50 shall be determined utilizing one of the following options:

- (a) Pursuant to 326 IAC 3-7-4, the Permittee shall demonstrate that the sulfur dioxide emissions do not exceed five-tenths (0.5) pounds per million Btu heat input by:
  - (1) Providing vendor analysis of fuel delivered, if accompanied by a certification; or
  - (2) Analyzing the oil sample to determine the sulfur content of the oil via the procedures in 40 CFR 60, Appendix A, Method 19.
    - (A) Oil samples may be collected from the fuel tank immediately after the fuel tank is filled and before any oil is combusted; and
    - (B) If a partially empty fuel tank is refilled, a new sample and analysis would be required upon filling; or
- (b) Compliance may also be determined by conducting a stack test for sulfur dioxide emissions, using 40 CFR 60, Appendix A, Method 6 in accordance with the procedures in 326 IAC 3-6.

A determination of noncompliance pursuant to either of the methods specified in (a) or (b) above shall not be refuted by evidence of compliance pursuant to the other method.

### D.2.6 Emission Factors and Performance Testing

- (a) The Permittee shall use the following NOx emissions factors in conjunction with the actual throughput of diesel fuel fired in reciprocating engines utilized in Test Cell 39N to determine compliance with emissions limitation in Condition D.2.3:

| Reciprocating Engine Size<br>(horsepower) | NOx emissions factor                              |
|---|---|
| 600 or less                               | 0.6042 pounds per gallon of diesel fuel combusted |
| greater than 600                          | 0.4384 pounds per gallon of diesel fuel combusted |

- (b) Monthly NOx emissions shall be determined by the following equation:  
$$\text{NOx emissions (tons)} = (0.6042 \text{ lbs/gal} \times \text{gal throughput for engines 600 hp or less} + 0.4384 \text{ lbs/gal} \times \text{gal throughput for engines greater than 600 hp}) / 2,000 \text{ lbs NOx per ton NOx}$$
- (c) Pursuant to IC 13-15-7-1, IC 13-15-7-2, 326 IC 2-1.1-9(2) and 326 IAC 2-1.1-11 the IDEM, OAQ reserves the authority to require the Permittee to conduct performance tests to verify the emissions factors of this permit.
- (d) After issuance of this permit, if the performance test results indicate a discrepancy between the emission factors and the actual emissions rate observed during the test, the Permittee shall inform IDEM, OAQ, Permits Branch of such variation no later than 90 days of the submission of performance test report to IDEM.

- (e) Pursuant to IC 13-15-7-1, IC 13-15-7-2 and 326 IC 2-1.1-9(2), the IDEM, OAQ may re-evaluate the permit conditions and emissions factors. IDEM, OAQ may, at its discretion, use the authority under IC 13-15-7-2, IC 13-15-7-2 and/or 326 IAC 2-1.1-9(2) to re-open and revise the permit to more closely reflect the actual performance test results using permit amendment or modification procedures.

### **Record Keeping and Reporting Requirement [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

#### **D.2.7 Record Keeping Requirements**

---

- (a) To document the compliance status with Condition D.2.2, the Permittee shall maintain records in accordance with (1) through (6) below. Records necessary to demonstrate compliance shall be available not later than thirty (30) days of the end of each compliance period.
- (1) Calendar dates covered in the compliance determination period;
  - (2) Actual fuel oil usage since last compliance determination period and equivalent sulfur dioxide emissions;
  - (3) A certification, signed by the owner or operator which is not necessarily the responsible official, that the records of the fuel supplier certifications represent all of the fuel combusted during the period; and
- If the fuel supplier certification is used to demonstrate compliance the following, as a minimum, shall be maintained:
- (4) Fuel supplier certifications.
  - (5) The name of the fuel supplier; and
  - (6) A statement from the fuel supplier that certifies the sulfur content of the fuel oil.
- (b) To document the compliance status with Condition D.2.3 and Condition D.2.6, the Permittee shall:
- (1) Maintain monthly records of the diesel fuel throughput in Test Cell 39N for engines 600 horsepower or less and maintain monthly records of diesel fuel throughput in Test Cell 39N for engines greater than 600 horsepower.
  - (2) Maintain records of NOx emissions on a monthly basis using the emissions factors in Condition D.2.6 in conjunction with monthly diesel fuel throughput in test Cell 39N to calculate emissions from Test Cell 39N.
- (c) Section C - General Record Keeping Requirements contains the Permittee's obligation with regard to the records required to be maintained by this condition.

#### **D.2.8 Reporting Requirements**

---

A quarterly summary of the information to document the compliance status with Condition D.2.3 and Condition D.2.6 shall be submitted not later than thirty (30) days after the end of the calendar quarter being reported. Section C - General Reporting contains the Permittee's obligation with regard to the reporting required by this condition. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).



## SECTION D.3

## FACILITY OPERATION CONDITIONS

### Facility Description [326 IAC 2-7-5(14)]

- (d) Emission unit DTC consists of the following four (4) transmission reliability test cells, TC-107, TC-109, TC-111 and TC-112. The emissions from test cells TC-107, TC-109, TC-111 and TC-112 are exhausted out stacks PTE045, PTE043, PTE049 and PTE050, respectively. All test cells were constructed in 1985. The following engines can be used in any one of the individual test cells mentioned above:

| Test Cell ID | Fuel Type | Engine Type   | Estimated Maximum Engine Size in Horsepower |
|--------------|-----------|---------------|---|
| TC-107       | Diesel    | Reciprocating | 1500  |
| TC-109       | Diesel    | Reciprocating | 1500  |
| TC-111       | Diesel    | Reciprocating | 1500  |
| TC-112       | Diesel    | Reciprocating | 1500  |

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

#### D.3.1 Particulate Matter Limitations Except Lake County [326 IAC 6.5-1-2(a)]

Pursuant to 326 IAC 6.5-1-2(a) (Particulate Matter Limitations Except Lake County), particulate (PM) emissions from each of the Test Cells TC-107, TC-109, TC-111 and TC-112 shall not exceed three hundredths (0.03) grains per dry standard cubic foot of exhaust air.

#### D.3.2 PSD Minor Limit [326 IAC 2-2]

Pursuant to 326 IAC 2-2 (Prevention of Significant Deterioration (PSD) Requirements), the following conditions shall apply:

- (a) Combined NO<sub>x</sub> emissions from diesel fuel fired reciprocating engines utilized in Test Cells TC-107, TC-109, TC-111 and TC-112 shall be limited to less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (b) The combined input of diesel fuel to reciprocating engines utilized in Test Cells TC-107, TC-109, TC-111 and TC-112 shall be less than 182,481 gallons per twelve (12) consecutive month period with compliance determined at the end of each month. For the purposes of determining compliance, each gallon of diesel fuel burned in reciprocating engines that are equal to or less than 600 horsepower shall be equivalent to one and thirty seven hundredths (1.37) gallons of diesel fuel burned in reciprocating engines that are greater than 600 horsepower.

Compliance with the above limits shall render 326 IAC 2-2 (Prevention of Significant Deterioration) not applicable.

#### D.3.3 Preventive Maintenance Plan [326 IAC 2-7-5(12)]

A Preventive Maintenance Plan is required for Test Cells TC-107, TC-109, TC-111 and TC-112. Section B - Preventive Maintenance Plan contains the Permittee's obligation with regard to the preventive maintenance plan required by this condition.

## Compliance Determination Requirements

### D.3.4 Emission Factors and Performance Testing

- (a) The Permittee shall use the following NOx emissions factors in conjunction with the actual throughput of diesel fuel fired in reciprocating engines utilized in Test Cells TC-107, TC-109, TC-111, TC-112 to determine compliance with emissions limitation in Condition D.3.2:

| Reciprocating Engine Size (horsepower) | NOx emissions factor                              |
|--|---|
| 600 or less                            | 0.6042 pounds per gallon of diesel fuel combusted |
| greater than 600                       | 0.4384 pounds per gallon of diesel fuel combusted |

- (b) Monthly NOx emissions shall be determined by the following equation:
- $$\text{NOx emissions (tons)} = (0.6042 \text{ lbs/gal} \times \text{gal throughput for engines 600 hp or less} + 0.4384 \text{ lbs/gal} \times \text{gal throughput for engines greater than 600 hp}) / 2,000 \text{ lbs NOx per ton NOx}$$
- (c) Pursuant to IC 13-15-7-1, IC 13-15-7-2, 326 IC 2-1.1-9(2) and 326 IAC 2-1.1-11 the IDEM, OAQ reserves the authority to require the Permittee to conduct performance tests to verify the emissions factors of this permit.
- (d) After issuance of this permit, if the performance test results indicate a discrepancy between the emission factors and the actual emissions rate observed during the test, the Permittee shall inform IDEM, OAQ, Permits Branch of such variation no later than 90 days of the submission of performance test report to IDEM.
- (e) Pursuant to IC 13-15-7-1, IC 13-15-7-2 and 326 IC 2-1.1-9(2), the IDEM, OAQ may re-evaluate the permit conditions and emissions factors. IDEM, OAQ may, at its discretion, use the authority under IC 13-15-7-2, IC 13-15-7-2 and/or 326 IAC 2-1.1-9(2) to re-open and revise the permit to more closely reflect the actual performance test results using permit amendment or modification procedures.

## Record Keeping and Reporting Requirement [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

### D.3.5 Record Keeping Requirements

- (a) To document the compliance status with Condition D.3.2 and Condition D.3.4, the Permittee shall:
- (1) Maintain monthly records of the diesel fuel throughput in Test Cells TC-107, TC-109, TC-111, TC-112 for engines 600 horsepower or less and maintain monthly records of diesel fuel throughput in Test Cells TC-107, TC-109, TC-111, TC-112 for engines greater than 600 horsepower.
  - (2) Maintain records of NOx emissions on a monthly basis using the emissions factors in Condition D.3.4 in conjunction with monthly diesel fuel throughput in Test Cells TC-107, TC-109, TC-111, TC-112 to calculate combined NOx emissions from Test Cells TC-107, TC-109, TC-111, TC-112. Records necessary to demonstrate the compliance status shall be available not later than thirty (30) days of the end of each compliance period.

- (b) Section C - General Record Keeping Requirements contains the Permittee's obligation with regard to the records required to be maintained by this condition.

#### D.3.6 Reporting Requirements

---

A quarterly summary of the information to document the compliance status with Condition D.3.2 and Condition D.3.4 shall be submitted a quarterly summary of the information to document the compliance status with Condition D.3.2 and Condition D.3.4 shall be submitted not later than thirty (30) days after the end of the calendar quarter being reported. The report submitted by the Permittee does require the certification a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).

## SECTION D.4

## FACILITY OPERATION CONDITIONS

### Facility Description [326 IAC 2-7-5(14)]

- (e) Emission unit PTS14 consists of the following five (5) transmission test stands, identified as test stand O-1, O-2, O-24, O-25 and O-31. Test stands O-1, O-2, O-24, O-25 and O-31 were constructed in 1978, 1979, 1986, 1986, and 1984 respectively. The emissions from test stands O-1, O-2, O-24, O-25 and O-31 are exhausted out stacks 14041, 14038, 14024, 14023, and 14045, respectively.

| Test Cell ID | Fuel Type | Engine Type   | Estimated Maximum Engine Size in Horsepower |
|--------------|-----------|---------------|---|
| O-1          | Diesel    | Reciprocating | 2400  |
| O-2          | Diesel    | Reciprocating | 2400  |
| O-24         | Diesel    | Reciprocating | 600   |
| O-25         | Diesel    | Reciprocating | 600   |
| O-31         | Diesel    | Reciprocating | 2400  |

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

#### D.4.1 Particulate Matter Limitations Except Lake County [326 IAC 6.5-1-2(a)]

Pursuant to 326 IAC 6.5-1-2(a) (Particulate Matter Limitations Except Lake County), particulate (PM) emissions from each of the Test Stands O-1, O-2, O-24, O-25 and O-31 shall not exceed three hundredths (0.03) grains per dry standard cubic foot of exhaust air.

#### D.4.2 PSD Minor Limit [326 IAC 2-2]

In order to render the requirements of 326 IAC 2-2 (Prevention of Significant Deterioration (PSD) Requirements) not applicable to Test Stands O-1, O-2, O-24, O-25 and O-31, the following conditions shall apply:

- (a) Combined NO<sub>x</sub> emissions from diesel fuel fired reciprocating engines utilized in Test Stands O-1 and O-2 shall be limited to less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (b) The combined input of diesel fuel to reciprocating engines utilized in Test Stands O-1 and O-2 shall be less than 182,481 gallons per twelve (12) consecutive month period with compliance determined at the end of each month. For the purposes of determining compliance, each gallon of diesel fuel burned in reciprocating engines that are equal to or less than 600 horsepower shall be equivalent to one and thirty seven hundredths (1.37) gallons of diesel fuel burned in reciprocating engines that are greater than 600 horsepower.
- (c) Combined NO<sub>x</sub> emissions from diesel fuel fired reciprocating engines utilized in Test Stands O-24 and O-25 shall be limited to less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (d) The combined input of diesel fuel to reciprocating engines utilized in Test Stands O-24 and O-25 shall be less than 182,481 gallons per twelve (12) consecutive month period

with compliance determined at the end of each month. For the purposes of determining compliance, each gallon of diesel fuel burned in reciprocating engines that are equal to or less than 600 horsepower shall be equivalent to one and thirty seven hundredths (1.37) gallons of diesel fuel burned in reciprocating engines that are greater than 600 horsepower.

- (e) NOx emissions from diesel fuel fired reciprocating engines utilized in Test Stand O-31 shall be limited to less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (f) The input of diesel fuel to reciprocating engines utilized in Test Stand O-31 shall be less than 182,481 gallons per twelve (12) consecutive month period with compliance determined at the end of each month. For the purposes of determining compliance, each gallon of diesel fuel burned in reciprocating engines that are equal to or less than 600 horsepower shall be equivalent to one and thirty seven hundredths (1.37) gallons of diesel fuel burned in reciprocating engines that are greater than 600 horsepower.

#### D.4.3 Preventive Maintenance Plan [326 IAC 2-7-5(12)]

A Preventive Maintenance Plan is required for Test Stands O-1, O-2, O-24, O-25 and O-31. Section B - Preventive Maintenance Plan contains the Permittee's obligation with regard to the preventive maintenance plan required by this condition.

### Compliance Determination Requirements

#### D.4.4 Emission Factors and Performance Testing

- (a) The Permittee shall use the following NOx emissions factors in conjunction with the actual throughput of diesel fuel fired in reciprocating engines utilized in Test Stands O-1, O-2, O-24, O-25 and O-31 to determine compliance with emissions limitation in Condition D.4.2:

| Reciprocating Engine Size (horsepower) | NOx emissions factor                              |
|--|---|
| 600 or less                            | 0.6042 pounds per gallon of diesel fuel combusted |
| greater than 600                       | 0.4384 pounds per gallon of diesel fuel combusted |

- (b) Monthly NOx emissions shall be determined by the following equation:  
  

$$\text{NOx emissions (tons)} = (0.6042 \text{ lbs/gal} \times \text{gal throughput for engines 600 hp or less} + 0.4384 \text{ lbs/gal} \times \text{gal throughput for engines greater than 600 hp}) / 2,000 \text{ lbs NOx per ton NOx}$$
- (c) Pursuant to IC 13-15-7-1, IC 13-15-7-2, 326 IC 2-1.1-9(2) and 326 IAC 2-1.1-11 the IDEM, OAQ reserves the authority to require the Permittee to conduct performance tests to verify the emissions factors of this permit.
- (d) After issuance of this permit, if the performance test results indicate a discrepancy between the emission factors and the actual emissions rate observed during the test, the Permittee shall inform IDEM, OAQ, Permits Branch of such variation no later than 90 days of the submission of performance test report to IDEM.
- (e) Pursuant to IC 13-15-7-1, IC 13-15-7-2 and 326 IC 2-1.1-9(2), the IDEM, OAQ may re-evaluate the permit conditions and emissions factors. IDEM, OAQ may, at its discretion, use the authority under IC 13-15-7-2, IC 13-15-7-2 and/or 326 IAC 2-1.1-9(2) to re-open

and revise the permit to more closely reflect the actual performance test results using permit amendment or modification procedures.

### **Record Keeping and Reporting Requirement [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

#### **D.4.5 Record Keeping Requirements**

---

- (a) To document the compliance status with Condition D.4.2(b) and Condition D.4.4, for Test Stands O-1 and O-2, maintain monthly records of the diesel fuel throughput for engines 600 horsepower or less and maintain monthly records of diesel fuel throughput for engines greater than 600 horsepower. Maintain records of the combined NOx emissions on a monthly basis using the emissions factors in Condition D.4.4 in conjunction with combined monthly diesel fuel throughput in Test Stands O-1 and O-2 to calculate NOx emissions from Test Stand O-1 and O-2. Records necessary to demonstrate compliance shall be available no later than thirty (30) days of the end of each compliance period.
- (b) To document the compliance status with Condition D.4.2(d), for Test Stands O-24 and O-25, maintain monthly records of the diesel fuel throughput for engines 600 horsepower or less and maintain monthly records of diesel fuel throughput for engines greater than 600 horsepower. Maintain records of the combined NOx emissions on a monthly basis using the emissions factors in Condition D.4.4 in conjunction with combined monthly diesel fuel throughput in Test Stands O-24 and O-25 to calculate NOx emissions from Test Stand O-24 and O-25. Records necessary to demonstrate compliance shall be available no later than thirty (30) days of the end of each compliance period.
- (c) To document the compliance status with Condition D.4.2(f), for Test Stand O-31, maintain monthly records of the diesel fuel throughput for engines 600 horsepower or less and maintain monthly records of diesel fuel throughput for engines greater than 600 horsepower. Maintain records of the NOx emissions on a monthly basis using the emissions factors in Condition D.4.4 in conjunction with monthly diesel fuel throughput in Test Stand O-31 to calculate emissions from Test Stand O-31. Records necessary to demonstrate compliance shall be available no later than thirty (30) days after the end of each compliance period.
- (d) Section C - General Record Keeping Requirements contains the Permittee's obligation with regard to the records required to be maintained by this condition.

#### **D.4.6 Reporting Requirements**

---

A quarterly summary of the information to document the compliance status with Condition D.4.2 and Condition D.4.4 shall be submitted not later than thirty (30) days after the end of the calendar quarter being reported. Section C - General Reporting contains the Permittee's obligation with regard to the reporting required by this condition. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).

## SECTION D.5 FACILITY OPERATION CONDITIONS

### Facility Description [326 IAC 2-7-5(14)]

- (f) Cold solvent degreasing using mineral spirits identified as emission unit CSD. Emissions are in to the building. Each degreasing unit was installed prior to 1977. [326 IAC 8-3-2][326 IAC 8-3-8]

#### Specifically Regulated Insignificant Activities

- (i) Cleaners and solvents characterized as having a vapor pressure equal to or less than: two (2.0) kilo Pascals (fifteen (15) millimeters of mercury or three-tenths (0.3) pound per square inch) measured at thirty-eight (38) degrees Centigrade (one hundred (100) degrees Fahrenheit); or seven-tenths (0.7) kilo Pascal (five (5) millimeters of mercury or one-tenth (0.1) pound per square inch) measured at twenty (20) degrees Centigrade (sixty-eight (68) degrees Fahrenheit); the use of which, for all cleaners and solvents combined, does not exceed one hundred forty-five (145) gallons per twelve (12) months, including:

One (1) cold solvent degreasing unit using mineral spirits identified as emission unit CSD-1, approved in 2012 for construction, exhausting inside. [326 IAC 8-3-2] [326 IAC 8-3-8]

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

#### D.5.1 Volatile Organic Compounds (VOC) [326 IAC 8-3-2] [326 IAC 8-3-5]

- (a) Pursuant to 326 IAC 8-3-2 (Cold Cleaner Degreaser Control Equipment and Operating Requirements), for cold cleaning degreasers constructed after January 1, 1980, the Permittee shall ensure the following control equipment and operating requirements are met:
- (1) Equip the degreaser with a cover.
  - (2) Equip the degreaser with a device for draining cleaned parts.
  - (3) Close the degreaser cover whenever parts are not being handled in the degreaser.
  - (4) Drain cleaned parts for at least fifteen (15) seconds or until dripping ceases;
  - (5) Provide a permanent, conspicuous label that lists the operating requirements; in subdivisions (3), (4), (6), and (7).
  - (6) Store waste solvent only in closed containers.
  - (7) Prohibit the disposal or transfer of waste solvent in such a manner that could allow greater than twenty percent (20%) of the waste solvent (by weight) to evaporate into the atmosphere.
- (b) Pursuant to 326 IAC 8-3-2 (Cold Cleaner Degreaser Control Equipment and Operating Requirements), for cold cleaning degreasers without remote solvent reservoirs constructed after July 1, 1990, the Permittee shall ensure the following additional control equipment and operating requirements are met:

- (1) Equip the degreaser with one (1) of the following control devices if the solvent is heated to a temperature of greater than forty-eight and nine-tenths (48.9) degrees Celsius (one hundred twenty (120) degrees Fahrenheit):
  - (A) A freeboard that attains a freeboard ratio of seventy-five hundredths (0.75) or greater.
  - (B) A water cover when solvent used is insoluble in, and heavier than, water.
  - (C) A refrigerated chiller.
  - (D) Carbon adsorption.
  - (E) An alternative system of demonstrated equivalent or better control as those outlined in clauses (A) through (D) that is approved by the department. An alternative system shall be submitted to the U.S. EPA as a SIP revision.
- (2) Ensure the degreaser cover is designed so that it can be easily operated with one (1) hand if the solvent is agitated or heated.
- (3) If used, solvent spray:
  - (A) must be a solid, fluid stream; and
  - (B) shall be applied at a pressure that does not cause excessive splashing.

#### **D.5.2 Volatile Organic Compounds (VOC) [326 IAC 8-3-8]**

---

Pursuant to 326 IAC 8-3-8 (Material Requirements for Cold Cleaner Degreasers), on and after January 1, 2015, the Permittee shall not operate a cold cleaner degreaser with a solvent that has a VOC composite partial vapor pressure than exceeds one (1) millimeter of mercury (nineteen-thousandths (0.019) pound per square inch) measured at twenty (20) degrees Celsius (sixty-eight (68) degrees Fahrenheit).

### **Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

#### **D.5.3 Record Keeping Requirements**

---

- (a) Pursuant to 326 IAC 8-3-8(c)(2), on and after January 1, 2015, the following records shall be maintained for each purchase of cold cleaner degreaser solvent:
  - (1) The name and address of the solvent supplier.
  - (2) The date of purchase (or invoice/bill dates of contract servicer indicating service date).
  - (3) The type of solvent purchased.
  - (4) The total volume of the solvent purchased.
  - (5) The true vapor pressure of the solvent measured in millimeters of mercury at twenty (20) degrees Celsius (sixty-eight (68) degrees Fahrenheit).
- (b) Section C - General Record Keeping Requirements of this permit contains the Permittee's obligations with regard to the records required by this condition.



## SECTION D.6 FACILITY OPERATION CONDITIONS

### Facility Description [326 IAC 2-7-5(14)]

- (g) Transmission Test Cell 702, identified as Emission Unit ID ETC702, consisting of one (1) reciprocating engine firing diesel fuel, with an estimated maximum engine size of 4000 hp, and exhausting at Stack/ Vent IDs PTE062 and PTE062A. This emission unit can accommodate engines of greater than 600 horsepower. Constructed in 2002.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

#### D.6.1 Particulate Matter Limitations Except Lake County [326 IAC 6.5-1-2(a)]

Pursuant to 326 IAC 6.5-1-2(a) (Particulate Matter Limitations Except Lake County), particulate (PM) emissions from Emission Unit ID ETC702 shall not exceed three hundredths (0.03) grains per dry standard cubic foot of exhaust air.

#### D.6.2 PSD Minor Limit [326 IAC 2-2] [Significant Source Modification 097-15550-00310]

Pursuant to 326 IAC 2-2 (Prevention of Significant Deterioration (PSD) Requirements), the following conditions shall apply:

- (a) NO<sub>x</sub> emissions from diesel fuel fired reciprocating engines utilized in Test Cell 702 shall be limited to less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (b) The input of diesel fuel to Test Cell 702 shall be less than 173,516 gallons per twelve (12) consecutive month period with compliance determined at the end of each month. For the purposes of determining compliance, each gallon of diesel fuel burned in reciprocating engines that are equal to or less than 600 horsepower shall be equivalent to one and thirty seven hundredths (1.37) gallons of diesel fuel burned in reciprocating engines that are greater than 600 horsepower.

Compliance with the above limits shall render 326 IAC 2-2 (Prevention of Significant Deterioration) not applicable.

#### D.6.3 Preventive Maintenance Plan [326 IAC 2-7-5(12)]

A Preventive Maintenance Plan is required for Test Cell 702. Section B - Preventive Maintenance Plan contains the Permittee's obligation with regard to the preventive maintenance plan required by this condition.

### Compliance Determination Requirements

#### D.6.4 Emission Factors and Performance Testing

- (a) The Permittee shall use the following NO<sub>x</sub> emissions factors in conjunction with the actual throughput of diesel fuel fired in reciprocating engines utilized in Test Cell 702 to determine compliance with emissions limitation in Condition D.6.2:

| Reciprocating Engine Size (horsepower) | NO <sub>x</sub> emissions factor                  |
|--|---|
| 600 or less                            | 0.6042 pounds per gallon of diesel fuel combusted |
| greater than 600                       | 0.4384 pounds per gallon of diesel fuel combusted |

- (b) Monthly NOx emissions shall be determined by the following equation:
- $$\text{NOx emissions (tons)} = (0.6042 \text{ lbs/gal} \times \text{gal throughput for engines 600 hp or less} + 0.4384 \text{ lbs/gal} \times \text{gal throughput for engines greater than 600 hp}) / 2,000 \text{ lbs NOx per ton NOx}$$
- (c) Pursuant to IC 13-15-7-1, IC 13-15-7-2, 326 IC 2-1.1-9(2) and 326 IAC 2-1.1-11 the IDEM, OAQ reserves the authority to require the Permittee to conduct performance tests to verify the emissions factors of this permit.
- (d) After issuance of this permit, if the performance test results indicate a discrepancy between the emission factors and the actual emissions rate observed during the test, the Permittee shall inform IDEM, OAQ, Permits Branch of such variation no later than 90 days of the submission of performance test report to IDEM.
- (e) Pursuant to IC 13-15-7-1, IC 13-15-7-2 and 326 IC 2-1.1-9(2), the IDEM, OAQ may re-evaluate the permit conditions and emissions factors. IDEM, OAQ may, at its discretion, use the authority under IC 13-15-7-2, IC 13-15-7-2 and/or 326 IAC 2-1.1-9(2) to re-open and revise the permit to more closely reflect the actual performance test results using permit amendment or modification procedures.

**Record Keeping and Reporting Requirement [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

**D.6.5 Record Keeping Requirements**

---

- (a) To document the compliance status with Condition D.6.2 and Condition D.6.4, the Permittee shall:
- (1) Maintain monthly records of the diesel fuel throughput in Test Cell 702 for engines 600 horsepower or less and maintain monthly records of diesel fuel throughput in Test Cell 702 for engines greater than 600 horsepower.
  - (2) Maintain records of NOx emissions on a monthly basis using the emissions factors in Condition D.6.4 in conjunction with monthly diesel fuel throughput in Test Cell 702 to calculate NOx emissions from Test Cell 702. Records necessary to demonstrate compliance shall be available no later than thirty (30) days of the end of each compliance period.
- (b) Section C - General Record Keeping Requirements contains the Permittee's obligation with regard to the records required to be maintained by this condition.

**D.6.6 Reporting Requirements**

---

A quarterly summary of the information to document the compliance status with Condition D.6.2 and D.6.4 shall be submitted not later than thirty (30) days after the end of the quarter being reported. Section C - General Reporting contains the Permittee's obligation with regard to the reporting required by this condition. The report submitted by the Permittee does require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).

## SECTION D.7

## FACILITY OPERATION CONDITIONS

### Facility Description [326 IAC 2-7-5(14)]

- (h) One (1) natural gas-fired boiler, identified as Emission Unit ID BLR6, constructed in 2011, with a maximum heat input of 99 million Btu per hour, equipped with low-NO<sub>x</sub> burners and flue gas recirculation.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

#### D.7.1 Particulate Emission Limitations for Sources of Indirect Heating [326 IAC 6-2-4]

Pursuant to 326 IAC 6-2-4 (Particulate Emission Limitations for Sources of Indirect Heating), particulate emissions from Boiler BLR6 shall be limited to less than 0.24 pounds per MMBtu heat input.

The limit was calculated using the following equation:

$$Pt = 1.09 / Q^{0.26}$$

Where

Pt = Pounds of particulate matter emitted per million Btu (lb/MMBtu) heat input; and

Q = Total source maximum heat input capacity in MMBtu/hr (Q equals 363.97 MMBtu/hr)

#### D.7.2 Preventive Maintenance Plan [326 IAC 2-7-5(12)]

A Preventive Maintenance Plan is required for Emission Unit ID BLR6 and any control devices. Section B - Preventive Maintenance Plan contains the Permittee's obligation with regard to the preventive maintenance plan required by this condition.

## SECTION D.8

## FACILITY OPERATION CONDITIONS

### Specifically Regulated Insignificant Activities

#### Facility Description [326 IAC 2-7-5(14)]

- (a) Natural gas-fired combustion sources with heat input equal to or less than ten million (10,000,000) Btu per hour. [326 IAC 6.5-1-2]
- (b) Emergency diesel generators not exceeding 1600 horsepower. [326 IAC 6.5-1-2(a)]
- (c) Emergency Stationary fire pumps. [326 IAC 6.5-1-2(a)]
- (d) Grinding and machining operations controlled with fabric filters, scrubbers, mist collectors, wet collectors and electrostatic precipitators with a design grain loading of less than or equal to 0.03 grains per actual cubic foot and a gas flow rate less than or equal to 4000 actual cubic feet per minute, including the following: deburring; buffing; polishing; abrasive blasting; pneumatic conveying; and woodworking operations. [326 IAC 6.5-1-2(a)]
  - (1) Shot Blast controlled with fabric filters. [326 IAC 6.5-1-2(a)]
- (e) Heat Treating [326 IAC 6.5-1-2(a)]
- (f) Activities or categories of activities with individual HAP emissions not previously identified. Any unit emitting greater than 1 pound per day but less than 5 pounds per day or 1 ton per year of a single HAP.
  - (1) Production welding - manganese [326 IAC 6.5-1-2(a)]

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

#### D.8.1 Particulate Matter Limitations Except Lake County [326 IAC 6.5-1-2(a)]

Pursuant to 326 IAC 6.5-1-2(a) (Particulate Matter Limitations Except Lake County), particulate (PM) emissions from the natural gas-fired combustion sources with heat input equal to or less than ten million (10,000,000) Btu per hour, emergency diesel generators, emergency stationary fire pumps, grinding and machining operations, shot blast, heat treating operations and production welding each shall not exceed three hundredths (0.03) grains per dry standard cubic foot of exhaust air.

### Compliance Determination Requirements

#### D.8.2 Particulate Control

In order to comply with D.8.1, the fabric filters for particulate control shall be in operation and control emissions from shot blasting at all times that the shot blasting units are in operation.

## SECTION D.9

## FACILITY OPERATION CONDITIONS

### Facility Description [326 IAC 2-7-5(14)]

- (j) Transmission Test Cell 55, identified as ETC55, permitted in 2013, consisting of two reciprocating diesel-fired engines, with an estimated maximum engine size of 4,000 hp each, exhausting to Stacks/Vents PTE93 and PTE94.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

#### D.9.1 Particulate Matter Limitations Except Lake County [326 IAC 6.5-1-2(a)]

Pursuant to 326 IAC 6.5-1-2(a) (Particulate Matter Limitations Except Lake County), particulate (PM) emissions from ETC55 shall not exceed three hundredths (0.03) grains per dry standard cubic foot of exhaust air.

#### D.9.2 PSD Minor Limit [326 IAC 2-2]

In order to render the requirements of 326 IAC 2-2 not applicable to ETC55, the Permittee shall comply with the following:

- (a) NO<sub>x</sub> emissions from diesel fuel fired reciprocating engines utilized in ETC55 shall be less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.
- (b) CO emissions from diesel fuel fired reciprocating engines utilized in ETC55 shall be less than one-hundred (100) tons per twelve (12) consecutive month period with compliance determined at the end of each month.

Compliance with these limits shall render 326 IAC 2-2 (Prevention of Significant Deterioration) not applicable to ETC55.

#### D.9.3 Nonattainment NSR Minor Limit [326 IAC 2-1.1-5]

In order to render the requirements of 326 IAC 2-1.1-5 not applicable to ETC55, the Permittee shall comply with the following:

SO<sub>2</sub> emissions from diesel fuel fired reciprocating engines utilized in ETC55 shall be less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.

Compliance with this limit shall render 326 IAC 2-1.1-5 (Nonattainment NSR) not applicable to ETC55.

#### D.9.4 Sulfur Dioxide (SO<sub>2</sub>) [326 IAC 7-1.1-1]

Pursuant to 326 IAC 7-1.1-2 (SO<sub>2</sub> Emissions Limitations), Sulfur Dioxide (SO<sub>2</sub>) emissions from ETC55 shall not exceed five tenths (0.5) pounds per million Btu heat input.

#### D.9.5 Preventive Maintenance Plan [326 IAC 2-7-5(12)]

A Preventive Maintenance Plan is required for ETC55. Section B - Preventive Maintenance Plan contains the Permittee's obligation with regard to the preventive maintenance plan required by this condition.

## Compliance Determination Requirements

### D.9.6 NOx Emissions Determination

---

To comply with the NOx emissions limit in Condition D.9.2(a), the following equation shall be used:

$$\text{NOx} = [(FU \times D \times EF / FCR)_{\text{Engine 1}} + (FU \times D \times EF / FCR)_{\text{Engine 2}}] \times 1 \text{ ton} / 2,000 \text{ lb}$$

Where:

NOx = NOx emissions (ton/month)

FU = Fuel Usage (gal/month)

D = Density of fuel (lb/gal)

EF = NOx Emission Factor (lb/hp-hr) (For each engine type used, the emission factor shall be the emission limitation from the applicable federal engine emission standards.)

FCR = Fuel Consumption Rate (lb fuel/hp-hr)

### D.9.7 CO Emissions Determination

---

To comply with the CO emissions limit in Condition D.9.2(b), the following equation shall be used:

$$\text{CO} = [(FU \times D \times EF / FCR)_{\text{Engine 1}} + (FU \times D \times EF / FCR)_{\text{Engine 2}}] \times 1 \text{ ton} / 2,000 \text{ lb}$$

Where:

CO = CO emissions (ton/month)

FU = Fuel Usage (gal/month)

D = Density of fuel (lb/gal)

EF = CO Emission Factor (lb/hp-hr) (For each engine type used, the emission factor shall be the emission limitation from the applicable federal engine emission standards.)

FCR = Fuel Consumption Rate (lb fuel/hp-hr)

### D.9.8 SO<sub>2</sub> Emissions Determination

---

To comply with the SO<sub>2</sub> emissions limit in Condition D.9.3, the following equation shall be used:

$$\text{SO}_2 = [(FU \times D \times EF / FCR)_{\text{Engine 1}} + (FU \times D \times EF / FCR)_{\text{Engine 2}}] \times 1 \text{ ton} / 2,000 \text{ lb}$$

Where:

SO<sub>2</sub> = SO<sub>2</sub> emissions (ton/month)

FU = Fuel Usage (gal/month)

D = Density of fuel (lb/gal)

EF = SO<sub>2</sub> Emission Factor (0.00405 lb SO<sub>2</sub>/hp-hr) (from AP-42, Table 3.4-1)

FCR = Fuel Consumption Rate (lb fuel/hp-hr)

### D.9.9 Sulfur Dioxide Emissions and Sulfur Content

---

Compliance with Condition D.9.4 shall be determined utilizing one of the following options:

- (a) Pursuant to 326 IAC 3-7-4, the Permittee shall demonstrate that the sulfur dioxide emissions do not exceed five-tenths (0.5) pounds per million Btu heat input by:
  - (1) Providing vendor analysis of fuel delivered, if accompanied by a certification; or
  - (2) Analyzing the oil sample to determine the sulfur content of the oil via the procedures in 40 CFR 60, Appendix A, Method 19.
    - (A) Oil samples may be collected from the fuel tank immediately after the fuel tank is filled and before any oil is combusted; and

- (B) If a partially empty fuel tank is refilled, a new sample and analysis would be required upon filling; or
- (b) Compliance may also be determined by conducting a stack test for sulfur dioxide emissions, using 40 CFR 60, Appendix A, Method 6 in accordance with the procedures in 326 IAC 3-6.

A determination of noncompliance pursuant to either of the methods specified in (a) or (b) above shall not be refuted by evidence of compliance pursuant to the other method.

### **Record Keeping and Reporting Requirement [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

#### **D.9.10 Record Keeping Requirements**

---

- (a) To document the compliance status with Condition D.9.2, the Permittee shall:
  - (1) Maintain monthly records of the diesel fuel throughput, fuel density, fuel consumption rate, and the emission factors for NO<sub>x</sub> and CO for Engine 1 and Engine 2 in Test Cell ETC55.
  - (2) Maintain records of NO<sub>x</sub> emissions on a monthly basis using the equation in Condition D.9.6.
  - (3) Maintain records of CO emissions on a monthly basis using the equation in Condition D.9.7.
- (b) To document the compliance status with Condition D.9.3, the Permittee shall:
  - (1) Maintain monthly records of the diesel fuel throughput, fuel density, fuel consumption rate, and the emission factor for SO<sub>2</sub> for Engine 1 and Engine 2 in Test Cell ETC55.
  - (2) Maintain records of SO<sub>2</sub> emissions on a monthly basis using the equation in Condition D.9.8.
- (c) To document the compliance status with Condition D.9.4, the Permittee shall maintain records in accordance with (1) through (6) below:
  - (1) Calendar dates covered in the compliance determination period;
  - (2) Actual fuel oil usage since last compliance determination period and equivalent sulfur dioxide emissions;
  - (3) A certification, signed by the owner or operator which is not necessarily the responsible official, that the records of the fuel supplier certifications represent all of the fuel combusted during the period; and

If the fuel supplier certification is used to demonstrate compliance the following, as a minimum, shall be maintained:

  - (4) Fuel supplier certifications.
  - (5) The name of the fuel supplier; and
  - (6) A statement from the fuel supplier that certifies the sulfur content of the fuel oil.

- (d) Section C - General Record Keeping Requirements contains the Permittee's obligation with regard to the records required to be maintained by this condition.

#### D.9.11 Reporting Requirements

---

Quarterly summaries of the information to document the compliance status with Condition D.9.2, D.9.3, D.9.6, D.9.7, and D.9.8 shall be submitted using the reporting forms located at the end of this permit, or their equivalent, not later than thirty (30) days after the end of the quarter being reported. Section C - General Reporting contains the Permittee's obligation with regard to the reporting required by this condition. The reports submitted by the Permittee do require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).



**SECTION E.1 New Source Performance Standards [326 IAC 2-7-5(1)] [326 IAC 12-1]  
[40 CFR 60, Subpart Dc]**

**Facility Description [326 IAC 2-7-5(14)]:**

- (h) One (1) natural gas-fired boiler, identified as Emission Unit ID BLR6, constructed in 2011, with a maximum heat input of 99 million Btu per hour, equipped with low-NOx burners and flue gas recirculation.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

**E.1.1 General Provision Relating to New Source Performance Standards [326 IAC 12]  
[40 CFR 60, Subpart A]**

- (a) Pursuant to 40 CFR 60.1, the Permittee shall comply with the provisions of 40 CFR Part 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to Emission Unit ID BLR6 as described in this section except when otherwise specified in 40 CFR Part 60, Subpart Dc.
- (b) Pursuant to 40 CFR 60.10, the Permittee shall submit all required notifications and reports to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

**E.1.2 Standard of Performance for Small Industrial-Commercial Institutional Steam Generating Units  
[326 IAC 12] [40 CFR 60, Subpart Dc]**

Pursuant to 40 CFR 60 Subpart Dc (included as Attachment A of this permit), the Permittee shall comply with the provisions of Standard of Performance for Small Industrial-Commercial Institutional Steam Generating Units for the Steam Boiler, identified as BLR6, as specified as follows:

- (1) 40 CFR 60.40c(a), (b);  
(2) 40 CFR 60.41c;  
(3) 40 CFR 60.48c(a), (g), (i); and  
(4) 40 CFR 60.7

**SECTION E.2 New Source Performance Standards [326 IAC 2-7-5(1)] [326 IAC 12-1]  
[40 CFR 60, Subpart III]**

**Facility Description [326 IAC 2-7-5(14)]:**

- (a) Emergency diesel generators not exceeding 1600 horsepower. [326 IAC 6.5-1-2]
  - (1) one (1) 1490-hp diesel emergency generator located in the Powerhouse courtyard.
- (j) Transmission Test Cell 55, identified as ETC55, approved in 2013 for construction, consisting of two reciprocating diesel-fired engines, with an estimated maximum engine size of 4,000 hp each, exhausting to Stacks/Vents PTE93 and PTE94.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

**E.2.1 General Provisions Relating to National Emission Standards for Hazardous Air Pollutants under 40 CFR Part 60 [326 IAC 12-1] [40 CFR Part 60, Subpart A]**

- (a) Pursuant to 40 CFR 60.1, the Permittee shall comply with the provisions of 40 CFR Part 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the units as described in this section except when otherwise specified in 40 CFR Part 60, Subpart III.
- (b) Pursuant to 40 CFR 60.10, the Permittee shall submit all required notifications and reports to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue,  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

**E.2.2 Standard of Performance for Stationary Compression Ignition Internal Combustion Engines [326 IAC 12] [40 CFR 60, Subpart III]**

Pursuant to 40 CFR 60 Subpart III (included as Attachment B of this permit), the Permittee shall comply with the provisions of Standard of Performance for Stationary Compression Ignition Internal Combustion Engines for the diesel emergency generator as specified as follows:

- (1) 40 CFR 60.4205(b)
- (2) 40 CFR 60.4206
- (3) 40 CFR 60.4207(b)
- (4) 40 CFR 60.4209(a)
- (5) 40 CFR 60.4211(a), (c), (e)
- (6) 40 CFR 60.4214(b)

**E.2.3 Standard of Performance for Stationary Compression Ignition Internal Combustion Engines [326 IAC 12] [40 CFR 60, Subpart III]**

Pursuant to 40 CFR 60 Subpart III (included as Attachment B of this permit), the Permittee shall comply with the provisions of Standard of Performance for Stationary Compression Ignition Internal Combustion Engines for ETC55, as specified as follows:

- (1) 40 CFR 60.4200
- (2) 40 CFR 60.4201
- (3) 40 CFR 60.4204(a), (b) and (e)
- (4) 40 CFR 60.4206

- (5) 40 CFR 60.4207(a), (b) and (e)
- (6) 40 CFR 60.4208(a), (e), (h) and (i)
- (7) 40 CFR 60.4211(a), (b), (c), (d), (e) and (g)
- (8) 40 CFR 60.4214(a)
- (9) 40 CFR 60.4218
- (10) 40 CFR 60.4219

**SECTION E.3 National Emission Standards for Hazardous Air Pollutants [326 IAC 2-7-5(1)]  
[326 IAC 20-1] [40 CFR 63, Subpart CCCCCC]**

Facility Description [326 IAC 2-7-5(14)]:

- (a) A gasoline fuel transfer and dispensing operation handling less than or equal to one thousand three hundred (1,300) gallons per day, such and filling storage tanks having a storage capacity equal to or less than ten thousand five hundred (10,500) gallons. Such storage tanks may be in a fixed location or on mobile equipment.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

**E.3.1 General Provision Relating National Emission Standards for Hazardous Air Pollutants  
[326 IAC 20] [40 CFR 63, Subpart A]**

- (a) Pursuant to 40 CFR Part 63.11110, the Permittee shall comply with the provisions of 40 CFR Part 63, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 20-1, apply to gas dispensing as described in this section except when otherwise specified in 40 CFR Part 63, Subpart CCCCCC.
- (b) Pursuant to 40 CFR 60.10, the Permittee shall submit all required notifications and reports to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue,  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

**E.3.2 Standard National Emission Standards for Hazardous Air Pollutants for Gasoline Dispensing  
Facilities [326 IAC 20] [40 CFR Part 63.11110, Subpart CCCCCC]**

Pursuant to 40 CFR 63 Subpart CCCCCC (included as Attachment C of this permit), the Permittee shall comply with the provisions of National Emission Standards for Hazardous Air Pollutants for Gasoline Dispensing Facilities as specified as follows:

- (1) 40 CFR 63.11113(b), and  
(2) 40 CFR 63.11116.

**SECTION E.4 National Emission Standards for Hazardous Air Pollutants [326 IAC 2-7-5(1)]  
[326 IAC 20-1] [40 CFR 63, Subpart WWWWWW]**

Facility Description [326 IAC 2-7-5(14)]:

(2) The following tanks involved in plating operations:

(A) One manganese phosphate tank (Dept. 1492 tank F3)

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

**E.4.1 General Provision Relating to National Emission Standards for Hazardous Air Pollutants  
[326 IAC 20] [40 CFR 63, Subpart A]**

(a) Pursuant to 40 CFR 63, the Permittee shall comply with the provisions of 40 CFR Part 63, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 20-1, apply to a plating and polishing facility as described in this section except when otherwise specified in 40 CFR Part 63 Subpart WWWWWW.

(b) Pursuant to 40 CFR 63.10, the Permittee shall submit all required notifications and reports to:

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue,  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

**E.4.2 National Emission Standards for Hazardous Air Pollutants for Plating and Polishing Operations  
[326 IAC 20] [40 CFR 63, Subpart WWWWWW]**

Pursuant to 40 CFR Part 63.11504, Subpart WWWWWW (included as Attachment D of this permit), the Permittee shall comply with the provisions of National Emission Standards for Hazardous Air Pollutants for Plating and Polishing Operations, identified as a plating operation, as follows:

- (1) 40 CFR 63.11507(a);
- (2) 40 CFR 63.11507(g);
- (3) 40 CFR 63.11508(a), (b), (c)(1) and (2), (d)(1)-(8); and
- (4) 40 CFR 63.11509(a)(1)-(3), (b), (c)(1), (c)(2)(i), (c)(7), (d), (e) and (f).

## SECTION E.5

## FACILITY OPERATION CONDITIONS

### Facility Description [326 IAC 2-7-5(14)]

(c) Emission Unit ETC consists of the following development transmission test cells:

| Test Cell ID | Fuel Type | Engine Type                  | Estimated Maximum Engine Size in Horsepower     |
|--------------|-----------|------------------------------|---|
| 701          | Diesel    | Reciprocating or Gas Turbine | 4000  |
| 705          | Diesel    | Reciprocating or Gas Turbine | 2400 for reciprocating;<br>4000 for gas turbine |

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

*This section only applies at times when a turbine engine is installed in the test cell and a test cell exemption does not apply.*

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

#### E.5.1 General Provisions Relating to New Source Performance Standards (NSPS) [40 CFR 60, Subpart A] [326 IAC 12]

The provisions of 40 CFR 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to Test Cell 701 and Test Cell 705 (of Emission Unit ETC) except when otherwise specified in 40 CFR 60, Subpart KKKK.

#### E.5.2 Stationary Combustion Turbines NSPS Requirements [40 CFR 60, Subpart KKKK] [326 IAC 12]

Pursuant to 40 CFR 60 Subpart KKKK, the Permittee shall comply with the provisions of 40 CFR 60 Subpart KKKK, which are incorporated as 326 IAC 12-1 for Test Cell 701 and Test Cell 705 (of Emission Unit ETC), as specified as follows:

- (1) 40 CFR 60.4305
- (2) 40 CFR 60.4315
- (3) 40 CFR 60.4320(a)
- (4) 40 CFR 60.4325
- (5) 40 CFR 60.4330(a)
- (6) 40 CFR 60.4333
- (7) 40 CFR 60.4375
- (8) 40 CFR 60.4395
- (9) 40 CFR 60.4420

## SECTION E.6

## FACILITY OPERATION CONDITIONS

### Facility Description [326 IAC 2-7-5(14)]:

- (j) Transmission Test Cell 55, identified as ETC55, permitted in 2013, consisting of two reciprocating diesel-fired engines, with an estimated maximum engine size of 4,000 hp each, exhausting to Stacks/Vents PTE93 and PTE94.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

#### E.6.1 General Provisions Relating to National Emission Standards for Hazardous Air Pollutants (NESHAP) [326 IAC 20-82] [40 CFR 63, Subpart A]

The provisions of 40 CFR 63, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 20-82, apply to ETC55 except when otherwise specified in 40 CFR 63, Subpart ZZZZ.

#### E.6.2 Stationary Reciprocating Internal Combustion Engines NESHAP [326 IAC 20-82] [40 CFR 63, Subpart ZZZZ]

Pursuant to 40 CFR 63 Subpart ZZZZ, the Permittee shall comply with the provisions of 40 CFR 63 Subpart ZZZZ, which are incorporated as 326 IAC 20-82 for ETC55, as specified as follows:

##### When using new engines

- (1) 40 CFR 63.6580
- (2) 40 CFR 63.6585(a), (c), (e)
- (3) 40 CFR 63.6590(a)(2)(iii) and (c)(1)
- (4) 40 CFR 63.6595(a)(7)
- (5) 40 CFR 63.6665
- (6) 40 CFR 63.6670
- (7) 40 CFR 63.6675

##### When using existing engines

- (1) 40 CFR 63.6580
- (2) 40 CFR 63.6585(a), (c), (e)
- (3) 40 CFR 63.6590(a)(1)(iii) and (iv)
- (4) 40 CFR 63.6595(a)(1), (b), and (c)
- (5) 40 CFR 63.6603(a)
- (6) 40 CFR 63.6604(a)
- (7) 40 CFR 63.6605
- (8) 40 CFR 63.6612
- (9) 40 CFR 63.6615
- (10) 40 CFR 63.6620(a), (d), (e), (f), (g), (h), and (i)
- (11) 40 CFR 63.6625(e)(4), (g), (h), (i)
- (12) 40 CFR 63.6630(a), (b), and (c)
- (13) 40 CFR 63.6635
- (14) 40 CFR 63.6640(a), (b), and (e)
- (15) 40 CFR 63.6645(a)(2), (a)(5), (g), and (h)
- (16) 40 CFR 63.6650
- (17) 40 CFR 63.6655
- (18) 40 CFR 63.6660
- (19) 40 CFR 63.6665
- (20) 40 CFR 63.6670
- (21) 40 CFR 63.6675

- (22) Table 2b
- (23) Table 2d (item 1), (item 2), and (item 3)
- (24) Table 3 (item 4)
- (25) Table 4 (items 1 and 3)
- (26) Table 5 (items 1, 2, 3, 4, 5, 6, 11 and 12)
- (27) Table 6 (items 3, 9, 10, and 11)
- (28) Table 7 (item 1)
- (29) Table 8



## SECTION E.7

## ORDER OF THE COMMISSIONER

### Facility Description [326 IAC 2-7-5(14)]

- (c) Engineering development transmission test cell 704 at Emission Unit ETC.

| Test Cell ID | Fuel Type | Engine Type   | Estimated Maximum Engine Size in Horsepower |
|--------------|-----------|---------------|---|
| 704          | Diesel    | Reciprocating | 2400  |

- (e) Emission unit PTS14, consisting of the following transmission test stands, identified as test stand O-1, O-2, and O-31. Test stands O-1, O-2, and O-31 were constructed in 1978, 1979, and 1984 respectively. The emissions from test stands O-1, O-2, and O-31 are exhausted out stacks 14041, 14038, and 14045, respectively.

| Test Cell ID | Fuel Type | Engine Type   | Estimated Maximum Engine Size in Horsepower |
|--------------|-----------|---------------|---|
| O-1          | Diesel    | Reciprocating | 2400  |
| O-2          | Diesel    | Reciprocating | 2400  |
| O-31         | Diesel    | Reciprocating | 2400  |

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### E.7.1 Agency Determination and Order of the Commissioner

- (a) Allison Transmission shall submit a status report within fifteen (15) days of completion of the following milestones indicating the actual dates of completion:
- (1) The date of delivery of the oxidation catalyst system to the Main Campus Building.
  - (2) The date of completion of installation of the oxidation catalyst system at the Main Campus Building.
  - (3) The date of completion of final quality assurance and control testing of the oxidation catalyst system.
  - (4) The date of startup of the oxidation catalyst system.
- (b) Allison Transmission shall comply with the standards set forth in 40 CFR 63, Subpart ZZZZ no later than May 3, 2014.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
PART 70 OPERATING PERMIT  
CERTIFICATION**

Source Name: Allison Transmission, Inc. - Speedway Main Campus  
Source Address: One Allison Way, Mail Code: M-29, Indianapolis Indiana 46222  
Part 70 Permit No.: T097-27011-00310

**This certification shall be included when submitting monitoring, testing reports/results or other documents as required by this permit.**

Please check what document is being certified:

- ☐ Annual Compliance Certification Letter
- ☐ Test Result (specify) \_\_\_\_\_.
- ☐ Report (specify) \_\_\_\_\_.
- ☐ Notification (specify) \_\_\_\_\_.
- ☐ Affidavit (specify) \_\_\_\_\_.
- ☐ Other (specify) \_\_\_\_\_.

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Signature:

Printed Name:

Title/Position:

Phone:

Date:

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH  
100 North Senate Avenue  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251  
Phone: (317) 233-0178  
Fax: (317) 233-6865**

**PART 70 OPERATING PERMIT  
EMERGENCY OCCURRENCE REPORT**

Source Name: Allison Transmission, Inc. - Speedway Main Campus  
Source Address: One Allison Way, Mail Code: M-29, Indianapolis Indiana 46222  
Part 70 Permit No.: T097-27011-00310

**This form consists of 2 pages**

**Page 1 of 2**

- ☐ This is an emergency as defined in 326 IAC 2-7-1(12)
- The Permittee must notify the Office of Air Quality (OAQ), within four (4) daytime business hours (1-800-451-6027 or 317-233-0178, ask for Compliance Section); and
  - The Permittee must submit notice in writing or by facsimile within two (2) working days (Facsimile Number: 317-233-6865), and follow the other requirements of 326 IAC 2-7-16.

If any of the following are not applicable, mark N/A

|   |
|---|
| Facility/Equipment/Operation:                       |
| Control Equipment:                                  |
| Permit Condition or Operation Limitation in Permit: |
| Description of the Emergency:                       |
| Describe the cause of the Emergency:                |

If any of the following are not applicable, mark N/A

Page 2 of 2

|   |
|---|
| Date/Time Emergency started:  |
| Date/Time Emergency was corrected:  |
| Was the facility being properly operated at the time of the emergency?    Y    N  |
| Type of Pollutants Emitted: TSP, PM-10, SO <sub>2</sub> , VOC, NO <sub>x</sub> , CO, Pb, other:   |
| Estimated amount of pollutant(s) emitted during emergency:  |
| Describe the steps taken to mitigate the problem:   |
| Describe the corrective actions/response steps taken:   |
| Describe the measures taken to minimize emissions:  |
| If applicable, describe the reasons why continued operation of the facilities are necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw materials of substantial economic value: |

Form Completed by: \_\_\_\_\_

Title / Position: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
Compliance and Enforcement Branch

Part 70 Usage Report  
(Submit Report Quarterly)

Source Name: Allison Transmission, Inc. - Speedway Main Campus  
Source Address: One Allison Way, Mail Code: M-29, Indianapolis Indiana 46222  
Part 70 Permit No.: T097-27011-00310  
Facility: BLR 4 and BLR 5  
Parameter: Filterable PM emissions  
Limit: 39.3 tons per twelve (12) consecutive month period with compliance determined at the end of each month.

Quarter: \_\_\_\_\_ Year: \_\_\_\_\_

| Month | Type of Fuel | Amount combusted this month | Amount combusted in the previous 11 months | Filterable PM Emission Factor | Monthly Filterable PM Emissions (tons/month) | Twelve month sum of filterable PM Emissions (tons/12 months) |
|-------|--------------|-----------------------------|--|-------------------------------|--|--|
|       | Natural Gas  |                             |  |                               |  |  |
|       | Natural Gas  |                             |  |                               |  |  |
|       | Natural Gas  |                             |  |                               |  |  |

☐ No deviation occurred in this quarter.

☐ Deviation/s occurred in this quarter.

Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_

Title / Position: \_\_\_\_\_

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
 OFFICE OF AIR QUALITY  
 Compliance and Enforcement Branch**

**Part 70 Usage Report  
 (Submit Report Quarterly)**

Source Name: Allison Transmission, Inc. - Speedway Main Campus  
 Source Address: One Allison Way, Mail Code: M-29, Indianapolis Indiana 46222  
 Part 70 Permit No.: T097-27011-00310  
 Facility: Emission Unit ETC Test Cell 39N  
 Parameter: Diesel fuel usage; limit the potential to emit NOx in Test Cell 39N to less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.  
 Limit: The input of diesel fuel to reciprocating engines utilized in Test Cell Stand 39N shall be less than 182,481 gallons per twelve (12) consecutive month period with compliance determined at the end of each month. For the purposes of determining compliance, each gallon of diesel fuel burned in reciprocating engines that are equal to or less than 600 horsepower shall be equivalent to one and thirty seven hundredths (1.37) gallons of diesel fuel burned in reciprocating engines that are greater than 600 horsepower.

Quarter: \_\_\_\_\_ Year: \_\_\_\_\_

|       | Column 1                                    |   |                               |                      | Column 2                                    |   |                               |                      | Column 1 + Column 2                         |   |                               |                      |
|-------|---|---|-------------------------------|----------------------|---|---|-------------------------------|----------------------|---|---|-------------------------------|----------------------|
|       | This Month                                  |   |                               |                      | Previous 11 Months                          |   |                               |                      | 12 Month Total                              |   |                               |                      |
|       | Diesel fuel usage in engines > 600 hp (gal) | Equivalent gallons in engines ≤ 600 hp (gal x 1.37) | Total Diesel fuel usage (gal) | NOx emissions (tons) | Diesel fuel usage in engines > 600 hp (gal) | Equivalent gallons in engines ≤ 600 hp (gal x 1.37) | Total Diesel fuel usage (gal) | NOx emissions (tons) | Diesel fuel usage in engines > 600 hp (gal) | Equivalent gallons in engines ≤ 600 hp (gal x 1.37) | Total Diesel fuel usage (gal) | NOx emissions (tons) |
| Month |   |   |                               |                      |   |   |                               |                      |   |   |                               |                      |
| Month |   |   |                               |                      |   |   |                               |                      |   |   |                               |                      |
| Month |   |   |                               |                      |   |   |                               |                      |   |   |                               |                      |

☐ No deviation occurred in this quarter.

☐ Deviation/s occurred in this quarter.

Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_  
 Title / Position: \_\_\_\_\_  
 Signature: \_\_\_\_\_  
 Date: \_\_\_\_\_  
 Phone: \_\_\_\_\_

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
 OFFICE OF AIR QUALITY  
 Compliance and Enforcement Branch**

**Part 70 Usage Report  
 (Submit Report Quarterly)**

Source Name: Allison Transmission, Inc. - Speedway Main Campus  
 Source Address: One Allison Way, Mail Code: M-29, Indianapolis Indiana 46222  
 Part 70 Permit No.: T097-27011-00310  
 Facility: Emission Unit DTC (TC-107, TC-109, TC-111 and TC-112)  
 Parameter: Combined diesel fuel usage; limit the combined potential to emit NOx in Test Cells TC-107, TC-109, TC-111 and TC-112 to less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.  
 Limit: The combined input of diesel fuel to reciprocating engines utilized in Test Cells TC-107, TC-109, TC-111 and TC-112 shall be less than 182,481 gallons per twelve (12) consecutive month period with compliance determined at the end of each month. For the purposes of determining compliance, each gallon of diesel fuel burned in reciprocating engines that are equal to or less than 600 horsepower shall be equivalent to one and thirty seven hundredths (1.37) gallons of diesel fuel burned in reciprocating engines that are greater than 600 horsepower.

Quarter: \_\_\_\_\_ Year: \_\_\_\_\_

|       | Column 1                                    |   |                               |                      | Column 2                                    |   |                               |                      | Column 1 + Column 2                         |   |                               |                      |
|-------|---|---|-------------------------------|----------------------|---|---|-------------------------------|----------------------|---|---|-------------------------------|----------------------|
|       | This Month                                  |   |                               |                      | Previous 11 Months                          |   |                               |                      | 12 Month Total                              |   |                               |                      |
|       | Diesel fuel usage in engines > 600 hp (gal) | Equivalent gallons in engines ≤ 600 hp (gal x 1.37) | Total Diesel fuel usage (gal) | NOx emissions (tons) | Diesel fuel usage in engines > 600 hp (gal) | Equivalent gallons in engines ≤ 600 hp (gal x 1.37) | Total Diesel fuel usage (gal) | NOx emissions (tons) | Diesel fuel usage in engines > 600 hp (gal) | Equivalent gallons in engines ≤ 600 hp (gal x 1.37) | Total Diesel fuel usage (gal) | NOx emissions (tons) |
| Month |   |   |                               |                      |   |   |                               |                      |   |   |                               |                      |
| Month |   |   |                               |                      |   |   |                               |                      |   |   |                               |                      |
| Month |   |   |                               |                      |   |   |                               |                      |   |   |                               |                      |

☐ No deviation occurred in this quarter.

☐ Deviation/s occurred in this quarter.

Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_  
 Title / Position: \_\_\_\_\_  
 Signature: \_\_\_\_\_  
 Date: \_\_\_\_\_  
 Phone: \_\_\_\_\_

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
 OFFICE OF AIR QUALITY  
 Compliance and Enforcement Branch**

**Part 70 Usage Report  
 (Submit Report Quarterly)**

Source Name: Allison Transmission, Inc. - Speedway Main Campus  
 Source Address: One Allison Way, Mail Code: M-29, Indianapolis Indiana 46222  
 Part 70 Permit No.: T097-27011-00310  
 Facility: Emission Unit PTS14 (Test Stands O-1 and O-2 only)  
 Parameter: Combined diesel fuel usage; limit the combined potential to emit NOx in Test Stands O-1 and O-2 to less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.  
 Limit: The combined input of diesel fuel to reciprocating engines utilized in Test Stands O-1 and O-2 shall be less than 182,481 gallons per twelve (12) consecutive month period with compliance determined at the end of each month. For the purposes of determining compliance, each gallon of diesel fuel burned in reciprocating engines that are equal to or less than 600 horsepower shall be equivalent to one and thirty seven hundredths (1.37) gallons of diesel fuel burned in reciprocating engines that are greater than 600 horsepower.

Quarter: \_\_\_\_\_ Year: \_\_\_\_\_

|       | Column 1                                    |   |                               |                      | Column 2                                    |   |                               |                      | Column 1 + Column 2                         |   |                               |                      |
|-------|---|---|-------------------------------|----------------------|---|---|-------------------------------|----------------------|---|---|-------------------------------|----------------------|
|       | This Month                                  |   |                               |                      | Previous 11 Months                          |   |                               |                      | 12 Month Total                              |   |                               |                      |
|       | Diesel fuel usage in engines > 600 hp (gal) | Equivalent gallons in engines ≤ 600 hp (gal x 1.37) | Total Diesel fuel usage (gal) | NOx emissions (tons) | Diesel fuel usage in engines > 600 hp (gal) | Equivalent gallons in engines ≤ 600 hp (gal x 1.37) | Total Diesel fuel usage (gal) | NOx emissions (tons) | Diesel fuel usage in engines > 600 hp (gal) | Equivalent gallons in engines ≤ 600 hp (gal x 1.37) | Total Diesel fuel usage (gal) | NOx emissions (tons) |
| Month |   |   |                               |                      |   |   |                               |                      |   |   |                               |                      |
| Month |   |   |                               |                      |   |   |                               |                      |   |   |                               |                      |
| Month |   |   |                               |                      |   |   |                               |                      |   |   |                               |                      |

☐ No deviation occurred in this quarter.

☐ Deviation/s occurred in this quarter.

Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_  
 Title / Position: \_\_\_\_\_  
 Signature: \_\_\_\_\_  
 Date: \_\_\_\_\_  
 Phone: \_\_\_\_\_



**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
 OFFICE OF AIR QUALITY  
 Compliance and Enforcement Branch**

**Part 70 Usage Report  
 (Submit Report Quarterly)**

Source Name: Allison Transmission, Inc. - Speedway Main Campus  
 Source Address: One Allison Way, Mail Code: M-29, Indianapolis Indiana 46222  
 Part 70 Permit No.: T097-27011-00310  
 Facility: Emission Unit PTS14 (Test Stands O-24 and O-25 only)  
 Parameter: Combined diesel fuel usage; limit the combined potential to emit NOx in Test Stands O-24 and O-25 to less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.  
 Limit: The combined input of diesel fuel to reciprocating engines utilized in Test Stands O-24 and O-25 shall be less than 182,481 gallons per twelve (12) consecutive month period with compliance determined at the end of each month. For the purposes of determining compliance, each gallon of diesel fuel burned in reciprocating engines that are equal to or less than 600 horsepower shall be equivalent to one and thirty seven hundredths (1.37) gallons of diesel fuel burned in reciprocating engines that are greater than 600 horsepower.

Quarter: \_\_\_\_\_ Year: \_\_\_\_\_

|       | Column 1                                    |   |                               |                      | Column 2                                    |   |                               |                      | Column 1 + Column 2                         |   |                               |                      |
|-------|---|---|-------------------------------|----------------------|---|---|-------------------------------|----------------------|---|---|-------------------------------|----------------------|
|       | This Month                                  |   |                               |                      | Previous 11 Months                          |   |                               |                      | 12 Month Total                              |   |                               |                      |
|       | Diesel fuel usage in engines > 600 hp (gal) | Equivalent gallons in engines ≤ 600 hp (gal x 1.37) | Total Diesel fuel usage (gal) | NOx emissions (tons) | Diesel fuel usage in engines > 600 hp (gal) | Equivalent gallons in engines ≤ 600 hp (gal x 1.37) | Total Diesel fuel usage (gal) | NOx emissions (tons) | Diesel fuel usage in engines > 600 hp (gal) | Equivalent gallons in engines ≤ 600 hp (gal x 1.37) | Total Diesel fuel usage (gal) | NOx emissions (tons) |
| Month |   |   |                               |                      |   |   |                               |                      |   |   |                               |                      |
| Month |   |   |                               |                      |   |   |                               |                      |   |   |                               |                      |
| Month |   |   |                               |                      |   |   |                               |                      |   |   |                               |                      |

☐ No deviation occurred in this quarter.

☐ Deviation/s occurred in this quarter.

Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_  
 Title / Position: \_\_\_\_\_  
 Signature: \_\_\_\_\_  
 Date: \_\_\_\_\_  
 Phone: \_\_\_\_\_

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
 OFFICE OF AIR QUALITY  
 Compliance and Enforcement Branch**

**Part 70 Usage Report  
 (Submit Report Quarterly)**

Source Name: Allison Transmission, Inc. - Speedway Main Campus  
 Source Address: One Allison Way, Mail Code: M-29, Indianapolis Indiana 46222  
 Part 70 Permit No.: T097-27011-00310  
 Facility: Emission Unit PTS14 (Test Stand O-31)  
 Parameter: Diesel fuel usage; limit the potential to emit NOx in Test Stand O-31 to less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.

Limit: The input of diesel fuel to reciprocating engines utilized in Test Stand O-31 shall be less than 182,481 gallons per twelve (12) consecutive month period with compliance determined at the end of each month. For the purposes of determining compliance, each gallon of diesel fuel burned in reciprocating engines that are equal to or less than 600 horsepower shall be equivalent to one and thirty seven hundredths (1.37) gallons of diesel fuel burned in reciprocating engines that are greater than 600 horsepower.

Quarter: \_\_\_\_\_ Year: \_\_\_\_\_

|       | Column 1                                    |   |                               |                      | Column 2                                    |   |                               |                      | Column 1 + Column 2                         |   |                               |                      |
|-------|---|---|-------------------------------|----------------------|---|---|-------------------------------|----------------------|---|---|-------------------------------|----------------------|
|       | This Month                                  |   |                               |                      | Previous 11 Months                          |   |                               |                      | 12 Month Total                              |   |                               |                      |
|       | Diesel fuel usage in engines > 600 hp (gal) | Equivalent gallons in engines ≤ 600 hp (gal x 1.37) | Total Diesel fuel usage (gal) | NOx emissions (tons) | Diesel fuel usage in engines > 600 hp (gal) | Equivalent gallons in engines ≤ 600 hp (gal x 1.37) | Total Diesel fuel usage (gal) | NOx emissions (tons) | Diesel fuel usage in engines > 600 hp (gal) | Equivalent gallons in engines ≤ 600 hp (gal x 1.37) | Total Diesel fuel usage (gal) | NOx emissions (tons) |
| Month |   |   |                               |                      |   |   |                               |                      |   |   |                               |                      |
| Month |   |   |                               |                      |   |   |                               |                      |   |   |                               |                      |
| Month |   |   |                               |                      |   |   |                               |                      |   |   |                               |                      |

☐ No deviation occurred in this quarter.

☐ Deviation/s occurred in this quarter.

Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_  
 Title / Position: \_\_\_\_\_  
 Signature: \_\_\_\_\_  
 Date: \_\_\_\_\_  
 Phone: \_\_\_\_\_

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
 OFFICE OF AIR QUALITY  
 Compliance and Enforcement Branch**

**Part 70 Usage Report  
 (Submit Report Quarterly)**

Source Name: Allison Transmission, Inc. - Speedway Main Campus  
 Source Address: One Allison Way, Mail Code: M-29, Indianapolis Indiana 46222  
 Part 70 Permit No.: T097-27011-00310  
 Facility: Emission Unit ETC702 (Test Cell 702)  
 Parameter: Diesel fuel usage; limit the potential to emit NOx in Test Cell 702 to less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.  
 Limit: The input of diesel fuel to reciprocating engines utilized in Test Cell 702 shall be less than 173,516 gallons per twelve (12) consecutive month period with compliance determined at the end of each month. For the purposes of determining compliance, each gallon of diesel fuel burned in reciprocating engines that are equal to or less than 600 horsepower shall be equivalent to one and thirty seven hundredths (1.37) gallons of diesel fuel burned in reciprocating engines that are greater than 600 horsepower.

Quarter: \_\_\_\_\_ Year: \_\_\_\_\_

|       | Column 1                                    |   |                               |                      | Column 2                                    |   |                               |                      | Column 1 + Column 2                         |   |                               |                      |
|-------|---|---|-------------------------------|----------------------|---|---|-------------------------------|----------------------|---|---|-------------------------------|----------------------|
|       | This Month                                  |   |                               |                      | Previous 11 Months                          |   |                               |                      | 12 Month Total                              |   |                               |                      |
|       | Diesel fuel usage in engines > 600 hp (gal) | Equivalent gallons in engines ≤ 600 hp (gal x 1.37) | Total Diesel fuel usage (gal) | NOx emissions (tons) | Diesel fuel usage in engines > 600 hp (gal) | Equivalent gallons in engines ≤ 600 hp (gal x 1.37) | Total Diesel fuel usage (gal) | NOx emissions (tons) | Diesel fuel usage in engines > 600 hp (gal) | Equivalent gallons in engines ≤ 600 hp (gal x 1.37) | Total Diesel fuel usage (gal) | NOx emissions (tons) |
| Month |   |   |                               |                      |   |   |                               |                      |   |   |                               |                      |
| Month |   |   |                               |                      |   |   |                               |                      |   |   |                               |                      |
| Month |   |   |                               |                      |   |   |                               |                      |   |   |                               |                      |

☐ No deviation occurred in this quarter.

☐ Deviation/s occurred in this quarter.

Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_  
 Title / Position: \_\_\_\_\_  
 Signature: \_\_\_\_\_  
 Date: \_\_\_\_\_  
 Phone: \_\_\_\_\_

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT**  
**OFFICE OF AIR QUALITY**  
**Compliance and Enforcement Branch**

**Part 70 Quarterly Report**

Source Name: Allison Transmission, Inc. - Speedway Main Campus  
Source Address: One Allison Way, Mail Code: M-29, Indianapolis Indiana 46222  
Part 70 Permit No.: T097-27011-00310  
Facility: Emission Unit ETC55  
Parameter: NOx Emissions  
Limit: NOx emissions from diesel fuel fired reciprocating engines utilized in ETC55 shall be less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.

The following equation shall be used to determine compliance:

$$\text{NOx} = [(FU \times D \times EF / FCR)_{\text{Engine 1}} + (FU \times D \times EF / FCR)_{\text{Engine 2}}] \times 1 \text{ ton} / 2,000 \text{ lb}$$

Where:

NOx = NOx emissions (ton/month)

FU = Fuel Usage (gal/month)

D = Density of fuel (lb/gal)

EF = NOx Emission Factor (lb/hp-hr) (For each engine type used, the emission factor shall be the emission limitation from the applicable federal engine emission standards.)

FCR = Fuel Consumption Rate (lb fuel/hp-hr)

Quarter: \_\_\_\_\_ Year: \_\_\_\_\_

| Month | Column 1   | Column 2           | Column 1 + Column 2 |
|-------|------------|--------------------|---------------------|
|       | This Month | Previous 11 Months | 12 Month Total      |
|       |            |                    |                     |
|       |            |                    |                     |
|       |            |                    |                     |

☐ No deviation occurred in this quarter.

☐ Deviation/s occurred in this quarter.

Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_  
Title / Position: \_\_\_\_\_  
Signature: \_\_\_\_\_  
Date: \_\_\_\_\_  
Phone: \_\_\_\_\_

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT**  
**OFFICE OF AIR QUALITY**  
**Compliance and Enforcement Branch**

**Part 70 Quarterly Report**

Source Name: Allison Transmission, Inc. - Speedway Main Campus  
Source Address: One Allison Way, Mail Code: M-29, Indianapolis Indiana 46222  
Part 70 Permit No.: T097-27011-00310  
Facility: Emission Unit ETC55  
Parameter: CO Emissions  
Limit: CO emissions from diesel fuel fired reciprocating engines utilized in ETC55 shall be less than one-hundred (100) tons per twelve (12) consecutive month period with compliance determined at the end of each month.

The following equation shall be used to determine compliance:

$$CO = [(FU \times D \times EF / FCR)_{\text{Engine 1}} + (FU \times D \times EF / FCR)_{\text{Engine 2}}] \times 1 \text{ ton} / 2,000 \text{ lb}$$

Where:

CO = CO emissions (ton/month)

FU = Fuel Usage (gal/month)

D = Density of fuel (lb/gal)

EF = CO Emission Factor (lb/hp-hr) (For each engine type used, the emission factor shall be the emission limitation from the applicable federal engine emission standards.)

FCR = Fuel Consumption Rate (lb fuel/hp-hr)

Quarter: \_\_\_\_\_ Year: \_\_\_\_\_

| Month | Column 1   | Column 2           | Column 1 + Column 2 |
|-------|------------|--------------------|---------------------|
|       | This Month | Previous 11 Months | 12 Month Total      |
|       |            |                    |                     |
|       |            |                    |                     |
|       |            |                    |                     |

☐ No deviation occurred in this quarter.

☐ Deviation/s occurred in this quarter.

Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_  
Title / Position: \_\_\_\_\_  
Signature: \_\_\_\_\_  
Date: \_\_\_\_\_  
Phone: \_\_\_\_\_

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
 OFFICE OF AIR QUALITY  
 Compliance and Enforcement Branch**

**Part 70 Quarterly Report**

Source Name: Allison Transmission, Inc. - Speedway Main Campus  
 Source Address: One Allison Way, Mail Code: M-29, Indianapolis Indiana 46222  
 Part 70 Permit No.: T097-27011-00310  
 Facility: Emission Unit ETC55  
 Parameter: SO<sub>2</sub> Emissions  
 Limit: SO<sub>2</sub> emissions from diesel fuel fired reciprocating engines utilized in ETC55 shall be less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.

The following equation shall be used to determine compliance:

$$SO_2 = [(FU \times D \times EF / FCR)_{\text{Engine 1}} + (FU \times D \times EF / FCR)_{\text{Engine 2}}] \times 1 \text{ ton} / 2,000 \text{ lb}$$

Where:

SO<sub>2</sub> = SO<sub>2</sub> emissions (ton/month)

FU = Fuel Usage (gal/month)

D = Density of fuel (lb/gal)

EF = SO<sub>2</sub> Emission Factor (0.00405 lb SO<sub>2</sub>/hp-hr) (from AP-42, Table 3.4-1)

FCR = Fuel Consumption Rate (lb fuel/hp-hr)

Quarter: \_\_\_\_\_ Year: \_\_\_\_\_

| Month | Column 1   | Column 2           | Column 1 + Column 2 |
|-------|------------|--------------------|---------------------|
|       | This Month | Previous 11 Months | 12 Month Total      |
|       |            |                    |                     |
|       |            |                    |                     |
|       |            |                    |                     |

☐ No deviation occurred in this quarter.

☐ Deviation/s occurred in this quarter.

Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_  
 Title / Position: \_\_\_\_\_  
 Signature: \_\_\_\_\_  
 Date: \_\_\_\_\_  
 Phone: \_\_\_\_\_

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH  
PART 70 OPERATING PERMIT  
QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT**

Source Name: Allison Transmission, Inc. - Speedway Main Campus  
Source Address: One Allison Way, Mail Code: M-29, Indianapolis Indiana 46222  
Part 70 Permit No.: T097-27011-00310

Months: \_\_\_\_\_ to \_\_\_\_\_ Year: \_\_\_\_\_

Page 1 of 2

This report shall be submitted quarterly based on a calendar year. Proper notice submittal under Section B – Emergency Provisions satisfies the reporting requirements of paragraph (a) of Section C – General Reporting. Any deviation from the requirements of this permit, the date(s) of each deviation, the probable cause of the deviation, and the response steps taken must be reported. A deviation required to be reported pursuant to an applicable requirement that exists independent of the permit, shall be reported according to the schedule stated in the applicable requirement and does not need to be included in this report. Additional pages may be attached if necessary. If no deviations occurred, please specify in the box marked "No deviations occurred this reporting period".

☐ NO DEVIATIONS OCCURRED THIS REPORTING PERIOD.

☐ THE FOLLOWING DEVIATIONS OCCURRED THIS REPORTING PERIOD

**Permit Requirement** (specify permit condition #)

**Date of Deviation:**

**Duration of Deviation:**

**Number of Deviations:**

**Probable Cause of Deviation:**

**Response Steps Taken:**

**Permit Requirement** (specify permit condition #)

**Date of Deviation:**

**Duration of Deviation:**

**Number of Deviations:**

**Probable Cause of Deviation:**

**Response Steps Taken:**

|  |                               |
|--|-------------------------------|
| <b>Permit Requirement (specify permit condition #)</b> |                               |
| <b>Date of Deviation:</b>                              | <b>Duration of Deviation:</b> |
| <b>Number of Deviations:</b>                           |                               |
| <b>Probable Cause of Deviation:</b>                    |                               |
| <b>Response Steps Taken:</b>                           |                               |
| <b>Permit Requirement (specify permit condition #)</b> |                               |
| <b>Date of Deviation:</b>                              | <b>Duration of Deviation:</b> |
| <b>Number of Deviations:</b>                           |                               |
| <b>Probable Cause of Deviation:</b>                    |                               |
| <b>Response Steps Taken:</b>                           |                               |
| <b>Permit Requirement (specify permit condition #)</b> |                               |
| <b>Date of Deviation:</b>                              | <b>Duration of Deviation:</b> |
| <b>Number of Deviations:</b>                           |                               |
| <b>Probable Cause of Deviation:</b>                    |                               |
| <b>Response Steps Taken:</b>                           |                               |

Form Completed by: \_\_\_\_\_

Title / Position: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_



## Attachment A

### Title 40: Protection of Environment

#### PART 60— STANDARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES

##### Subpart Dc—Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units

**Source:** 72 FR 32759, June 13, 2007, unless otherwise noted.

##### **§ 60.40c Applicability and delegation of authority.**

(a) Except as provided in paragraphs (d), (e), (f), and (g) of this section, the affected facility to which this subpart applies is each steam generating unit for which construction, modification, or reconstruction is commenced after June 9, 1989 and that has a maximum design heat input capacity of 29 megawatts (MW) (100 million British thermal units per hour (MMBtu/h)) or less, but greater than or equal to 2.9 MW (10 MMBtu/h).

(b) In delegating implementation and enforcement authority to a State under section 111(c) of the Clean Air Act, §60.48c(a)(4) shall be retained by the Administrator and not transferred to a State.

(c) Steam generating units that meet the applicability requirements in paragraph (a) of this section are not subject to the sulfur dioxide (SO<sub>2</sub>) or particulate matter (PM) emission limits, performance testing requirements, or monitoring requirements under this subpart (§§60.42c, 60.43c, 60.44c, 60.45c, 60.46c, or 60.47c) during periods of combustion research, as defined in §60.41c.

(d) Any temporary change to an existing steam generating unit for the purpose of conducting combustion research is not considered a modification under §60.14.

(e) Affected facilities ( *i.e.* heat recovery steam generators and fuel heaters) that are associated with stationary combustion turbines and meet the applicability requirements of subpart KKKK of this part are not subject to this subpart. This subpart will continue to apply to all other heat recovery steam generators, fuel heaters, and other affected facilities that are capable of combusting more than or equal to 2.9 MW (10 MMBtu/h) heat input of fossil fuel but less than or equal to 29 MW (100 MMBtu/h) heat input of fossil fuel. If the heat recovery steam generator, fuel heater, or other affected facility is subject to this subpart, only emissions resulting from combustion of fuels in the steam generating unit are subject to this subpart. (The stationary combustion turbine emissions are subject to subpart GG or KKKK, as applicable, of this part.)

(f) Any affected facility that meets the applicability requirements of and is subject to subpart AAAA or subpart CCCC of this part is not subject to this subpart.

(g) Any facility that meets the applicability requirements and is subject to an EPA approved State or Federal section 111(d)/129 plan implementing subpart BBBB of this part is not subject to this subpart.

(h) Affected facilities that also meet the applicability requirements under subpart J or subpart Ja of this part are subject to the PM and NO<sub>x</sub> standards under this subpart and the SO<sub>2</sub> standards under subpart J or subpart Ja of this part, as applicable.

(i) Temporary boilers are not subject to this subpart.

[72 FR 32759, June 13, 2007, as amended at 74 FR 5090, Jan. 28, 2009; 77 FR 9461, Feb. 16, 2012]

### **§ 60.41c Definitions.**

As used in this subpart, all terms not defined herein shall have the meaning given them in the Clean Air Act and in subpart A of this part.

*Annual capacity factor* means the ratio between the actual heat input to a steam generating unit from an individual fuel or combination of fuels during a period of 12 consecutive calendar months and the potential heat input to the steam generating unit from all fuels had the steam generating unit been operated for 8,760 hours during that 12-month period at the maximum design heat input capacity. In the case of steam generating units that are rented or leased, the actual heat input shall be determined based on the combined heat input from all operations of the affected facility during a period of 12 consecutive calendar months.

*Coal* means all solid fuels classified as anthracite, bituminous, subbituminous, or lignite by the American Society of Testing and Materials in ASTM D388 (incorporated by reference, see §60.17), coal refuse, and petroleum coke. Coal-derived synthetic fuels derived from coal for the purposes of creating useful heat, including but not limited to solvent refined coal, gasified coal not meeting the definition of natural gas, coal-oil mixtures, and coal-water mixtures, are also included in this definition for the purposes of this subpart.

*Coal refuse* means any by-product of coal mining or coal cleaning operations with an ash content greater than 50 percent (by weight) and a heating value less than 13,900 kilojoules per kilogram (kJ/kg) (6,000 Btu per pound (Btu/lb) on a dry basis.

*Combined cycle system* means a system in which a separate source (such as a stationary gas turbine, internal combustion engine, or kiln) provides exhaust gas to a steam generating unit.

*Combustion research* means the experimental firing of any fuel or combination of fuels in a steam generating unit for the purpose of conducting research and development of more efficient combustion or more effective prevention or control of air pollutant emissions from combustion, provided that, during these periods of research and development, the heat generated is not used for any purpose other than preheating combustion air for use by that steam generating unit ( *i.e.* , the heat generated is released to the atmosphere without being used for space heating, process heating, driving pumps, preheating combustion air for other units, generating electricity, or any other purpose).

*Conventional technology* means wet flue gas desulfurization technology, dry flue gas desulfurization technology, atmospheric fluidized bed combustion technology, and oil hydrodesulfurization technology.

*Distillate oil* means fuel oil that complies with the specifications for fuel oil numbers 1 or 2, as defined by the American Society for Testing and Materials in ASTM D396 (incorporated by reference, see §60.17), diesel fuel oil numbers 1 or 2, as defined by the American Society for Testing and Materials in ASTM D975 (incorporated by reference, see §60.17), kerosine, as defined by the American Society of Testing and Materials in ASTM D3699 (incorporated by reference, see §60.17), biodiesel as defined by the American Society of Testing and Materials in ASTM D6751 (incorporated by reference, see §60.17), or biodiesel blends as defined by the American Society of Testing and Materials in ASTM D7467 (incorporated by reference, see §60.17).

*Dry flue gas desulfurization technology* means a SO<sub>2</sub> control system that is located between the steam generating unit and the exhaust vent or stack, and that removes sulfur oxides from the combustion gases of the steam generating unit by contacting the combustion gases with an alkaline reagent and water, whether introduced separately or as a premixed slurry or solution and forming a dry powder material. This definition includes devices where the dry powder material is subsequently converted to another form. Alkaline reagents used in dry flue gas desulfurization systems include, but are not limited to, lime and sodium compounds.

*Duct burner* means a device that combusts fuel and that is placed in the exhaust duct from another source (such as a stationary gas turbine, internal combustion engine, kiln, etc.) to allow the firing of additional fuel to heat the exhaust gases before the exhaust gases enter a steam generating unit.

*Emerging technology* means any SO<sub>2</sub> control system that is not defined as a conventional technology under this section, and for which the owner or operator of the affected facility has received approval from the Administrator to operate as an emerging technology under §60.48c(a)(4).

*Federally enforceable* means all limitations and conditions that are enforceable by the Administrator, including the requirements of 40 CFR parts 60 and 61, requirements within any applicable State implementation plan, and any permit requirements established under 40 CFR 52.21 or under 40 CFR 51.18 and 51.24.

*Fluidized bed combustion technology* means a device wherein fuel is distributed onto a bed (or series of beds) of limestone aggregate (or other sorbent materials) for combustion; and these materials are forced upward in the device by the flow of combustion air and the gaseous products of combustion. Fluidized bed combustion technology includes, but is not limited to, bubbling bed units and circulating bed units.

*Fuel pretreatment* means a process that removes a portion of the sulfur in a fuel before combustion of the fuel in a steam generating unit.

*Heat input* means heat derived from combustion of fuel in a steam generating unit and does not include the heat derived from preheated combustion air, recirculated flue gases, or exhaust gases from other sources (such as stationary gas turbines, internal combustion engines, and kilns).

*Heat transfer medium* means any material that is used to transfer heat from one point to another point.

*Maximum design heat input capacity* means the ability of a steam generating unit to combust a stated maximum amount of fuel (or combination of fuels) on a steady state basis as determined by the physical design and characteristics of the steam generating unit.

*Natural gas* means:

(1) A naturally occurring mixture of hydrocarbon and nonhydrocarbon gases found in geologic formations beneath the earth's surface, of which the principal constituent is methane; or

(2) Liquefied petroleum (LP) gas, as defined by the American Society for Testing and Materials in ASTM D1835 (incorporated by reference, see §60.17); or

(3) A mixture of hydrocarbons that maintains a gaseous state at ISO conditions. Additionally, natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 34 and 43 megajoules (MJ) per dry standard cubic meter (910 and 1,150 Btu per dry standard cubic foot).

*Noncontinental area* means the State of Hawaii, the Virgin Islands, Guam, American Samoa, the Commonwealth of Puerto Rico, or the Northern Mariana Islands.

*Oil* means crude oil or petroleum, or a liquid fuel derived from crude oil or petroleum, including distillate oil and residual oil.

*Potential sulfur dioxide emission rate* means the theoretical SO<sub>2</sub> emissions (nanograms per joule (ng/J) or lb/MMBtu heat input) that would result from combusting fuel in an uncleaned state and without using emission control systems.

*Process heater* means a device that is primarily used to heat a material to initiate or promote a chemical reaction in which the material participates as a reactant or catalyst.

*Residual oil* means crude oil, fuel oil that does not comply with the specifications under the definition of distillate oil, and all fuel oil numbers 4, 5, and 6, as defined by the American Society for Testing and Materials in ASTM D396 (incorporated by reference, see §60.17).

*Steam generating unit* means a device that combusts any fuel and produces steam or heats water or heats any heat transfer medium. This term includes any duct burner that combusts fuel and is part of a combined cycle system. This term does not include process heaters as defined in this subpart.

*Steam generating unit operating day* means a 24-hour period between 12:00 midnight and the following midnight during which any fuel is combusted at any time in the steam generating unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period.

*Temporary boiler* means a steam generating unit that combusts natural gas or distillate oil with a potential SO<sub>2</sub> emissions rate no greater than 26 ng/J (0.060 lb/MMBtu), and the unit is designed to, and is capable of, being carried or moved from one location to another by means of, for example, wheels, skids, carrying handles, dollies, trailers, or platforms. A steam generating unit is not a temporary boiler if any one of the following conditions exists:

- (1) The equipment is attached to a foundation.
- (2) The steam generating unit or a replacement remains at a location for more than 180 consecutive days. Any temporary boiler that replaces a temporary boiler at a location and performs the same or similar function will be included in calculating the consecutive time period.
- (3) The equipment is located at a seasonal facility and operates during the full annual operating period of the seasonal facility, remains at the facility for at least 2 years, and operates at that facility for at least 3 months each year.
- (4) The equipment is moved from one location to another in an attempt to circumvent the residence time requirements of this definition.

*Wet flue gas desulfurization technology* means an SO<sub>2</sub> control system that is located between the steam generating unit and the exhaust vent or stack, and that removes sulfur oxides from the combustion gases of the steam generating unit by contacting the combustion gases with an alkaline slurry or solution and forming a liquid material. This definition includes devices where the liquid material is subsequently converted to another form. Alkaline reagents used in wet flue gas desulfurization systems include, but are not limited to, lime, limestone, and sodium compounds.

*Wet scrubber system* means any emission control device that mixes an aqueous stream or slurry with the exhaust gases from a steam generating unit to control emissions of PM or SO<sub>2</sub>.

*Wood* means wood, wood residue, bark, or any derivative fuel or residue thereof, in any form, including but not limited to sawdust, sanderdust, wood chips, scraps, slabs, millings, shavings, and processed pellets made from wood or other forest residues.

[72 FR 32759, June 13, 2007, as amended at 74 FR 5090, Jan. 28, 2009; 77 FR 9461, Feb. 16, 2012]

**§ 60.42c Standard for sulfur dioxide (SO<sub>2</sub>).**

(a) Except as provided in paragraphs (b), (c), and (e) of this section, on and after the date on which the performance test is completed or required to be completed under §60.8, whichever date comes first, the owner or operator of an affected facility that combusts only coal shall neither: cause to be discharged into the atmosphere from the affected facility any gases that contain SO<sub>2</sub> in excess of 87 ng/J (0.20 lb/MMBtu) heat input or 10 percent (0.10) of the potential SO<sub>2</sub> emission rate (90 percent reduction), nor cause to be discharged into the atmosphere from the affected facility any gases that contain SO<sub>2</sub> in excess of 520 ng/J (1.2 lb/MMBtu) heat input. If coal is combusted with other fuels, the affected facility shall neither: cause to be discharged into the atmosphere from the affected facility any gases that contain SO<sub>2</sub> in excess of 87 ng/J (0.20 lb/MMBtu) heat input or 10 percent (0.10) of the potential SO<sub>2</sub> emission rate (90 percent reduction), nor cause to be discharged into the atmosphere from the affected facility any gases that contain SO<sub>2</sub> in excess of the emission limit is determined pursuant to paragraph (e)(2) of this section.

(b) Except as provided in paragraphs (c) and (e) of this section, on and after the date on which the performance test is completed or required to be completed under §60.8, whichever date comes first, the owner or operator of an affected facility that:

(1) Combusts only coal refuse alone in a fluidized bed combustion steam generating unit shall neither:

(i) Cause to be discharged into the atmosphere from that affected facility any gases that contain SO<sub>2</sub> in excess of 87 ng/J (0.20 lb/MMBtu) heat input or 20 percent (0.20) of the potential SO<sub>2</sub> emission rate (80 percent reduction); nor

(ii) Cause to be discharged into the atmosphere from that affected facility any gases that contain SO<sub>2</sub> in excess of 520 ng/J (1.2 lb/MMBtu) heat input. If coal is fired with coal refuse, the affected facility subject to paragraph (a) of this section. If oil or any other fuel (except coal) is fired with coal refuse, the affected facility is subject to the 87 ng/J (0.20 lb/MMBtu) heat input SO<sub>2</sub> emissions limit or the 90 percent SO<sub>2</sub> reduction requirement specified in paragraph (a) of this section and the emission limit is determined pursuant to paragraph (e)(2) of this section.

(2) Combusts only coal and that uses an emerging technology for the control of SO<sub>2</sub> emissions shall neither:

(i) Cause to be discharged into the atmosphere from that affected facility any gases that contain SO<sub>2</sub> in excess of 50 percent (0.50) of the potential SO<sub>2</sub> emission rate (50 percent reduction); nor

(ii) Cause to be discharged into the atmosphere from that affected facility any gases that contain SO<sub>2</sub> in excess of 260 ng/J (0.60 lb/MMBtu) heat input. If coal is combusted with other fuels, the affected facility is subject to the 50 percent SO<sub>2</sub> reduction requirement specified in this paragraph and the emission limit determined pursuant to paragraph (e)(2) of this section.

(c) On and after the date on which the initial performance test is completed or required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that combusts coal, alone or in combination with any other fuel, and is listed in paragraphs (c)(1), (2), (3), or (4) of this section shall cause to be discharged into the atmosphere from that affected facility any gases that contain SO<sub>2</sub> in excess of the emission limit determined pursuant to paragraph (e)(2) of this section. Percent reduction requirements are not applicable to affected facilities under paragraphs (c)(1), (2), (3), or (4).

(1) Affected facilities that have a heat input capacity of 22 MW (75 MMBtu/h) or less;

(2) Affected facilities that have an annual capacity for coal of 55 percent (0.55) or less and are subject to a federally enforceable requirement limiting operation of the affected facility to an annual capacity factor for coal of 55 percent (0.55) or less.

(3) Affected facilities located in a noncontinental area; or

(4) Affected facilities that combust coal in a duct burner as part of a combined cycle system where 30 percent (0.30) or less of the heat entering the steam generating unit is from combustion of coal in the duct burner and 70 percent (0.70) or more of the heat entering the steam generating unit is from exhaust gases entering the duct burner.

(d) On and after the date on which the initial performance test is completed or required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that combusts oil shall cause to be discharged into the atmosphere from that affected facility any gases that contain SO<sub>2</sub> in excess of 215 ng/J (0.50 lb/MMBtu) heat input from oil; or, as an alternative, no owner or operator of an affected facility that combusts oil shall combust oil in the affected facility that contains greater than 0.5 weight percent sulfur. The percent reduction requirements are not applicable to affected facilities under this paragraph.

(e) On and after the date on which the initial performance test is completed or required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that combusts coal, oil, or coal and oil with any other fuel shall cause to be discharged into the atmosphere from that affected facility any gases that contain SO<sub>2</sub> in excess of the following:

(1) The percent of potential SO<sub>2</sub> emission rate or numerical SO<sub>2</sub> emission rate required under paragraph (a) or (b)(2) of this section, as applicable, for any affected facility that

(i) Combusts coal in combination with any other fuel;

(ii) Has a heat input capacity greater than 22 MW (75 MMBtu/h); and

(iii) Has an annual capacity factor for coal greater than 55 percent (0.55); and

(2) The emission limit determined according to the following formula for any affected facility that combusts coal, oil, or coal and oil with any other fuel:

$$E_s = \frac{(K_a H_a + K_b H_b + K_c H_c)}{(H_a + H_b + H_c)}$$

Where:

E<sub>s</sub>= SO<sub>2</sub> emission limit, expressed in ng/J or lb/MMBtu heat input;

K<sub>a</sub>= 520 ng/J (1.2 lb/MMBtu);

K<sub>b</sub>= 260 ng/J (0.60 lb/MMBtu);

K<sub>c</sub>= 215 ng/J (0.50 lb/MMBtu);

H<sub>a</sub>= Heat input from the combustion of coal, except coal combusted in an affected facility subject to paragraph (b)(2) of this section, in Joules (J) [MMBtu];

H<sub>b</sub>= Heat input from the combustion of coal in an affected facility subject to paragraph (b)(2) of this section, in J (MMBtu); and

$H_c$  = Heat input from the combustion of oil, in J (MMBtu).

(f) Reduction in the potential  $SO_2$  emission rate through fuel pretreatment is not credited toward the percent reduction requirement under paragraph (b)(2) of this section unless:

(1) Fuel pretreatment results in a 50 percent (0.50) or greater reduction in the potential  $SO_2$  emission rate; and

(2) Emissions from the pretreated fuel (without either combustion or post-combustion  $SO_2$  control) are equal to or less than the emission limits specified under paragraph (b)(2) of this section.

(g) Except as provided in paragraph (h) of this section, compliance with the percent reduction requirements, fuel oil sulfur limits, and emission limits of this section shall be determined on a 30-day rolling average basis.

(h) For affected facilities listed under paragraphs (h)(1), (2), (3), or (4) of this section, compliance with the emission limits or fuel oil sulfur limits under this section may be determined based on a certification from the fuel supplier, as described under §60.48c(f), as applicable.

(1) Distillate oil-fired affected facilities with heat input capacities between 2.9 and 29 MW (10 and 100 MMBtu/hr).

(2) Residual oil-fired affected facilities with heat input capacities between 2.9 and 8.7 MW (10 and 30 MMBtu/hr).

(3) Coal-fired affected facilities with heat input capacities between 2.9 and 8.7 MW (10 and 30 MMBtu/h).

(4) Other fuels-fired affected facilities with heat input capacities between 2.9 and 8.7 MW (10 and 30 MMBtu/h).

(i) The  $SO_2$  emission limits, fuel oil sulfur limits, and percent reduction requirements under this section apply at all times, including periods of startup, shutdown, and malfunction.

(j) For affected facilities located in noncontinental areas and affected facilities complying with the percent reduction standard, only the heat input supplied to the affected facility from the combustion of coal and oil is counted under this section. No credit is provided for the heat input to the affected facility from wood or other fuels or for heat derived from exhaust gases from other sources, such as stationary gas turbines, internal combustion engines, and kilns.

[72 FR 32759, June 13, 2007, as amended at 74 FR 5090, Jan. 28, 2009; 77 FR 9462, Feb. 16, 2012]

#### **§ 60.43c Standard for particulate matter (PM).**

(a) On and after the date on which the initial performance test is completed or required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that commenced construction, reconstruction, or modification on or before February 28, 2005, that combusts coal or combusts mixtures of coal with other fuels and has a heat input capacity of 8.7 MW (30 MMBtu/h) or greater, shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of the following emission limits:

(1) 22 ng/J (0.051 lb/MMBtu) heat input if the affected facility combusts only coal, or combusts coal with other fuels and has an annual capacity factor for the other fuels of 10 percent (0.10) or less.

(2) 43 ng/J (0.10 lb/MMBtu) heat input if the affected facility combusts coal with other fuels, has an annual capacity factor for the other fuels greater than 10 percent (0.10), and is subject to a federally enforceable requirement limiting operation of the affected facility to an annual capacity factor greater than 10 percent (0.10) for fuels other than coal.

(b) On and after the date on which the initial performance test is completed or required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that commenced construction, reconstruction, or modification on or before February 28, 2005, that combusts wood or combusts mixtures of wood with other fuels (except coal) and has a heat input capacity of 8.7 MW (30 MMBtu/h) or greater, shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of the following emissions limits:

(1) 43 ng/J (0.10 lb/MMBtu) heat input if the affected facility has an annual capacity factor for wood greater than 30 percent (0.30); or

(2) 130 ng/J (0.30 lb/MMBtu) heat input if the affected facility has an annual capacity factor for wood of 30 percent (0.30) or less and is subject to a federally enforceable requirement limiting operation of the affected facility to an annual capacity factor for wood of 30 percent (0.30) or less.

(c) On and after the date on which the initial performance test is completed or required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that combusts coal, wood, or oil and has a heat input capacity of 8.7 MW (30 MMBtu/h) or greater shall cause to be discharged into the atmosphere from that affected facility any gases that exhibit greater than 20 percent opacity (6-minute average), except for one 6-minute period per hour of not more than 27 percent opacity. Owners and operators of an affected facility that elect to install, calibrate, maintain, and operate a continuous emissions monitoring system (CEMS) for measuring PM emissions according to the requirements of this subpart and are subject to a federally enforceable PM limit of 0.030 lb/MMBtu or less are exempt from the opacity standard specified in this paragraph (c).

(d) The PM and opacity standards under this section apply at all times, except during periods of startup, shutdown, or malfunction.

(e)(1) On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that commences construction, reconstruction, or modification after February 28, 2005, and that combusts coal, oil, wood, a mixture of these fuels, or a mixture of these fuels with any other fuels and has a heat input capacity of 8.7 MW (30 MMBtu/h) or greater shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of 13 ng/J (0.030 lb/MMBtu) heat input, except as provided in paragraphs (e)(2), (e)(3), and (e)(4) of this section.

(2) As an alternative to meeting the requirements of paragraph (e)(1) of this section, the owner or operator of an affected facility for which modification commenced after February 28, 2005, may elect to meet the requirements of this paragraph. On and after the date on which the initial performance test is completed or required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that commences modification after February 28, 2005 shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of both:

(i) 22 ng/J (0.051 lb/MMBtu) heat input derived from the combustion of coal, oil, wood, a mixture of these fuels, or a mixture of these fuels with any other fuels; and

(ii) 0.2 percent of the combustion concentration (99.8 percent reduction) when combusting coal, oil, wood, a mixture of these fuels, or a mixture of these fuels with any other fuels.



(3) On and after the date on which the initial performance test is completed or is required to be completed under §60.8, whichever date comes first, no owner or operator of an affected facility that commences modification after February 28, 2005, and that combusts over 30 percent wood (by heat input) on an annual basis and has a heat input capacity of 8.7 MW (30 MMBtu/h) or greater shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of 43 ng/J (0.10 lb/MMBtu) heat input.

(4) An owner or operator of an affected facility that commences construction, reconstruction, or modification after February 28, 2005, and that combusts only oil that contains no more than 0.50 weight percent sulfur or a mixture of 0.50 weight percent sulfur oil with other fuels not subject to a PM standard under §60.43c and not using a post-combustion technology (except a wet scrubber) to reduce PM or SO<sub>2</sub> emissions is not subject to the PM limit in this section.

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009; 77 FR 9462, Feb. 16, 2012]

#### **§ 60.44c Compliance and performance test methods and procedures for sulfur dioxide.**

(a) Except as provided in paragraphs (g) and (h) of this section and §60.8(b), performance tests required under §60.8 shall be conducted following the procedures specified in paragraphs (b), (c), (d), (e), and (f) of this section, as applicable. Section 60.8(f) does not apply to this section. The 30-day notice required in §60.8(d) applies only to the initial performance test unless otherwise specified by the Administrator.

(b) The initial performance test required under §60.8 shall be conducted over 30 consecutive operating days of the steam generating unit. Compliance with the percent reduction requirements and SO<sub>2</sub> emission limits under §60.42c shall be determined using a 30-day average. The first operating day included in the initial performance test shall be scheduled within 30 days after achieving the maximum production rate at which the affected facility will be operated, but not later than 180 days after the initial startup of the facility. The steam generating unit load during the 30-day period does not have to be the maximum design heat input capacity, but must be representative of future operating conditions.

(c) After the initial performance test required under paragraph (b) of this section and §60.8, compliance with the percent reduction requirements and SO<sub>2</sub> emission limits under §60.42c is based on the average percent reduction and the average SO<sub>2</sub> emission rates for 30 consecutive steam generating unit operating days. A separate performance test is completed at the end of each steam generating unit operating day, and a new 30-day average percent reduction and SO<sub>2</sub> emission rate are calculated to show compliance with the standard.

(d) If only coal, only oil, or a mixture of coal and oil is combusted in an affected facility, the procedures in Method 19 of appendix A of this part are used to determine the hourly SO<sub>2</sub> emission rate ( $E_{ho}$ ) and the 30-day average SO<sub>2</sub> emission rate ( $E_{ao}$ ). The hourly averages used to compute the 30-day averages are obtained from the CEMS. Method 19 of appendix A of this part shall be used to calculate  $E_{ao}$  when using daily fuel sampling or Method 6B of appendix A of this part.

(e) If coal, oil, or coal and oil are combusted with other fuels:

(1) An adjusted  $E_{ho}$  ( $E_{hoO}$ ) is used in Equation 19–19 of Method 19 of appendix A of this part to compute the adjusted  $E_{ao}$  ( $E_{aoO}$ ). The  $E_{hoO}$  is computed using the following formula:

$$E_{hoO} = \frac{E_{ho} - E_w(1 - X_1)}{X_1}$$

Where:

$E_{ho0}$  = Adjusted  $E_{ho}$ , ng/J (lb/MMBtu);

$E_{ho}$  = Hourly  $SO_2$  emission rate, ng/J (lb/MMBtu);

$E_w$  =  $SO_2$  concentration in fuels other than coal and oil combusted in the affected facility, as determined by fuel sampling and analysis procedures in Method 9 of appendix A of this part, ng/J (lb/MMBtu). The value  $E_w$  for each fuel lot is used for each hourly average during the time that the lot is being combusted. The owner or operator does not have to measure  $E_w$  if the owner or operator elects to assume  $E_w = 0$ .

$X_k$  = Fraction of the total heat input from fuel combustion derived from coal and oil, as determined by applicable procedures in Method 19 of appendix A of this part.

(2) The owner or operator of an affected facility that qualifies under the provisions of §60.42c(c) or (d) (where percent reduction is not required) does not have to measure the parameters  $E_w$  or  $X_k$  if the owner or operator of the affected facility elects to measure emission rates of the coal or oil using the fuel sampling and analysis procedures under Method 19 of appendix A of this part.

(f) Affected facilities subject to the percent reduction requirements under §60.42c(a) or (b) shall determine compliance with the  $SO_2$  emission limits under §60.42c pursuant to paragraphs (d) or (e) of this section, and shall determine compliance with the percent reduction requirements using the following procedures:

(1) If only coal is combusted, the percent of potential  $SO_2$  emission rate is computed using the following formula:

$$\%P_s = 100 \left( 1 - \frac{\%R_g}{100} \right) \left( 1 - \frac{\%R_f}{100} \right)$$

Where:

$\%P_s$  = Potential  $SO_2$  emission rate, in percent;

$\%R_g$  =  $SO_2$  removal efficiency of the control device as determined by Method 19 of appendix A of this part, in percent; and

$\%R_f$  =  $SO_2$  removal efficiency of fuel pretreatment as determined by Method 19 of appendix A of this part, in percent.

(2) If coal, oil, or coal and oil are combusted with other fuels, the same procedures required in paragraph (f)(1) of this section are used, except as provided for in the following:

(i) To compute the  $\%P_s$ , an adjusted  $\%R_g$  ( $\%R_{g0}$ ) is computed from  $E_{ao0}$  from paragraph (e)(1) of this section and an adjusted average  $SO_2$  inlet rate ( $E_{ai0}$ ) using the following formula:

$$\%R_{g0} = 100 \left( 1 - \frac{E_{w0}}{E_{ai0}} \right)$$

Where:

$\%R_{g0}$  = Adjusted  $\%R_g$ , in percent;

$E_{ao} = \text{Adjusted } E_{ao}, \text{ ng/J (lb/MMBtu); and}$

$E_{ai} = \text{Adjusted average SO}_2\text{inlet rate, ng/J (lb/MMBtu).}$

(ii) To compute  $E_{ai}$ , an adjusted hourly  $\text{SO}_2$ inlet rate ( $E_{hi}$ ) is used. The  $E_{hi}$  is computed using the following formula:

$$E_{ai} = \frac{E_m - E_w(1 - X_k)}{X_k}$$

Where:

$E_{hi} = \text{Adjusted } E_{hi}, \text{ ng/J (lb/MMBtu);}$

$E_{hi} = \text{Hourly SO}_2\text{inlet rate, ng/J (lb/MMBtu);}$

$E_w = \text{SO}_2\text{concentration in fuels other than coal and oil combusted in the affected facility, as determined by fuel sampling and analysis procedures in Method 19 of appendix A of this part, ng/J (lb/MMBtu). The value } E_w\text{ for each fuel lot is used for each hourly average during the time that the lot is being combusted. The owner or operator does not have to measure } E_w\text{ if the owner or operator elects to assume } E_w = 0; \text{ and}$

$X_k = \text{Fraction of the total heat input from fuel combustion derived from coal and oil, as determined by applicable procedures in Method 19 of appendix A of this part.}$

(g) For oil-fired affected facilities where the owner or operator seeks to demonstrate compliance with the fuel oil sulfur limits under §60.42c based on shipment fuel sampling, the initial performance test shall consist of sampling and analyzing the oil in the initial tank of oil to be fired in the steam generating unit to demonstrate that the oil contains 0.5 weight percent sulfur or less. Thereafter, the owner or operator of the affected facility shall sample the oil in the fuel tank after each new shipment of oil is received, as described under §60.46c(d)(2).

(h) For affected facilities subject to §60.42c(h)(1), (2), or (3) where the owner or operator seeks to demonstrate compliance with the  $\text{SO}_2$  standards based on fuel supplier certification, the performance test shall consist of the certification from the fuel supplier, as described in §60.48c(f), as applicable.

(i) The owner or operator of an affected facility seeking to demonstrate compliance with the  $\text{SO}_2$  standards under §60.42c(c)(2) shall demonstrate the maximum design heat input capacity of the steam generating unit by operating the steam generating unit at this capacity for 24 hours. This demonstration shall be made during the initial performance test, and a subsequent demonstration may be requested at any other time. If the demonstrated 24-hour average firing rate for the affected facility is less than the maximum design heat input capacity stated by the manufacturer of the affected facility, the demonstrated 24-hour average firing rate shall be used to determine the annual capacity factor for the affected facility; otherwise, the maximum design heat input capacity provided by the manufacturer shall be used.

(j) The owner or operator of an affected facility shall use all valid  $\text{SO}_2$  emissions data in calculating  $\%P_s$  and  $E_{ho}$  under paragraphs (d), (e), or (f) of this section, as applicable, whether or not the minimum emissions data requirements under §60.46c(f) are achieved. All valid emissions data, including valid data collected during periods of startup, shutdown, and malfunction, shall be used in calculating  $\%P_s$  or  $E_{ho}$  pursuant to paragraphs (d), (e), or (f) of this section, as applicable.

**§ 60.45c Compliance and performance test methods and procedures for particulate matter.**

(a) The owner or operator of an affected facility subject to the PM and/or opacity standards under §60.43c shall conduct an initial performance test as required under §60.8, and shall conduct subsequent performance tests as requested by the Administrator, to determine compliance with the standards using the following procedures and reference methods, except as specified in paragraph (c) of this section.

(1) Method 1 of appendix A of this part shall be used to select the sampling site and the number of traverse sampling points.

(2) Method 3A or 3B of appendix A–2 of this part shall be used for gas analysis when applying Method 5 or 5B of appendix A–3 of this part or 17 of appendix A–6 of this part.

(3) Method 5, 5B, or 17 of appendix A of this part shall be used to measure the concentration of PM as follows:

(i) Method 5 of appendix A of this part may be used only at affected facilities without wet scrubber systems.

(ii) Method 17 of appendix A of this part may be used at affected facilities with or without wet scrubber systems provided the stack gas temperature does not exceed a temperature of 160 °C (320 °F). The procedures of Sections 8.1 and 11.1 of Method 5B of appendix A of this part may be used in Method 17 of appendix A of this part only if Method 17 of appendix A of this part is used in conjunction with a wet scrubber system. Method 17 of appendix A of this part shall not be used in conjunction with a wet scrubber system if the effluent is saturated or laden with water droplets.

(iii) Method 5B of appendix A of this part may be used in conjunction with a wet scrubber system.

(4) The sampling time for each run shall be at least 120 minutes and the minimum sampling volume shall be 1.7 dry standard cubic meters (dscm) [60 dry standard cubic feet (dscf)] except that smaller sampling times or volumes may be approved by the Administrator when necessitated by process variables or other factors.

(5) For Method 5 or 5B of appendix A of this part, the temperature of the sample gas in the probe and filter holder shall be monitored and maintained at 160 ±14 °C (320±25 °F).

(6) For determination of PM emissions, an oxygen (O<sub>2</sub>) or carbon dioxide (CO<sub>2</sub>) measurement shall be obtained simultaneously with each run of Method 5, 5B, or 17 of appendix A of this part by traversing the duct at the same sampling location.

(7) For each run using Method 5, 5B, or 17 of appendix A of this part, the emission rates expressed in ng/J (lb/MMBtu) heat input shall be determined using:

(i) The O<sub>2</sub> or CO<sub>2</sub> measurements and PM measurements obtained under this section, (ii) The dry basis F factor, and

(iii) The dry basis emission rate calculation procedure contained in Method 19 of appendix A of this part.

(8) Method 9 of appendix A–4 of this part shall be used for determining the opacity of stack emissions.

(b) The owner or operator of an affected facility seeking to demonstrate compliance with the PM standards under §60.43c(b)(2) shall demonstrate the maximum design heat input capacity of the steam generating unit by operating the steam generating unit at this capacity for 24 hours. This demonstration

shall be made during the initial performance test, and a subsequent demonstration may be requested at any other time. If the demonstrated 24-hour average firing rate for the affected facility is less than the maximum design heat input capacity stated by the manufacturer of the affected facility, the demonstrated 24-hour average firing rate shall be used to determine the annual capacity factor for the affected facility; otherwise, the maximum design heat input capacity provided by the manufacturer shall be used.

(c) In place of PM testing with Method 5 or 5B of appendix A-3 of this part or Method 17 of appendix A-6 of this part, an owner or operator may elect to install, calibrate, maintain, and operate a CEMS for monitoring PM emissions discharged to the atmosphere and record the output of the system. The owner or operator of an affected facility who elects to continuously monitor PM emissions instead of conducting performance testing using Method 5 or 5B of appendix A-3 of this part or Method 17 of appendix A-6 of this part shall install, calibrate, maintain, and operate a CEMS and shall comply with the requirements specified in paragraphs (c)(1) through (c)(14) of this section.

(1) Notify the Administrator 1 month before starting use of the system.

(2) Notify the Administrator 1 month before stopping use of the system.

(3) The monitor shall be installed, evaluated, and operated in accordance with §60.13 of subpart A of this part.

(4) The initial performance evaluation shall be completed no later than 180 days after the date of initial startup of the affected facility, as specified under §60.8 of subpart A of this part or within 180 days of notification to the Administrator of use of CEMS if the owner or operator was previously determining compliance by Method 5, 5B, or 17 of appendix A of this part performance tests, whichever is later.

(5) The owner or operator of an affected facility shall conduct an initial performance test for PM emissions as required under §60.8 of subpart A of this part. Compliance with the PM emission limit shall be determined by using the CEMS specified in paragraph (d) of this section to measure PM and calculating a 24-hour block arithmetic average emission concentration using EPA Reference Method 19 of appendix A of this part, section 4.1.

(6) Compliance with the PM emission limit shall be determined based on the 24-hour daily (block) average of the hourly arithmetic average emission concentrations using CEMS outlet data.

(7) At a minimum, valid CEMS hourly averages shall be obtained as specified in paragraph (c)(7)(i) of this section for 75 percent of the total operating hours per 30-day rolling average.

(i) At least two data points per hour shall be used to calculate each 1-hour arithmetic average.

(ii) [Reserved]

(8) The 1-hour arithmetic averages required under paragraph (c)(7) of this section shall be expressed in ng/J or lb/MMBtu heat input and shall be used to calculate the boiler operating day daily arithmetic average emission concentrations. The 1-hour arithmetic averages shall be calculated using the data points required under §60.13(e)(2) of subpart A of this part.

(9) All valid CEMS data shall be used in calculating average emission concentrations even if the minimum CEMS data requirements of paragraph (c)(7) of this section are not met.

(10) The CEMS shall be operated according to Performance Specification 11 in appendix B of this part.

(11) During the correlation testing runs of the CEMS required by Performance Specification 11 in appendix B of this part, PM and O<sub>2</sub>(or CO<sub>2</sub>) data shall be collected concurrently (or within a 30- to 60-minute period) by both the continuous emission monitors and performance tests conducted using the following test methods.

(i) For PM, Method 5 or 5B of appendix A-3 of this part or Method 17 of appendix A-6 of this part shall be used; and

(ii) For O<sub>2</sub> (or CO<sub>2</sub>), Method 3A or 3B of appendix A-2 of this part, as applicable shall be used.

(12) Quarterly accuracy determinations and daily calibration drift tests shall be performed in accordance with procedure 2 in appendix F of this part. Relative Response Audit's must be performed annually and Response Correlation Audits must be performed every 3 years.

(13) When PM emissions data are not obtained because of CEMS breakdowns, repairs, calibration checks, and zero and span adjustments, emissions data shall be obtained by using other monitoring systems as approved by the Administrator or EPA Reference Method 19 of appendix A of this part to provide, as necessary, valid emissions data for a minimum of 75 percent of total operating hours on a 30-day rolling average.

(14) As of January 1, 2012, and within 90 days after the date of completing each performance test, as defined in §60.8, conducted to demonstrate compliance with this subpart, you must submit relative accuracy test audit ( *i.e.*, reference method) data and performance test ( *i.e.*, compliance test) data, except opacity data, electronically to EPA's Central Data Exchange (CDX) by using the Electronic Reporting Tool (ERT) (see [http://www.epa.gov/ttn/chief/ert/ert\\_tool.html/](http://www.epa.gov/ttn/chief/ert/ert_tool.html/)) or other compatible electronic spreadsheet. Only data collected using test methods compatible with ERT are subject to this requirement to be submitted electronically into EPA's WebFIRE database.

(d) The owner or operator of an affected facility seeking to demonstrate compliance under §60.43c(e)(4) shall follow the applicable procedures under §60.48c(f). For residual oil-fired affected facilities, fuel supplier certifications are only allowed for facilities with heat input capacities between 2.9 and 8.7 MW (10 to 30 MMBtu/h).

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009; 76 FR 3523, Jan. 20, 2011; 77 FR 9463, Feb. 16, 2012]

#### **§ 60.46c Emission monitoring for sulfur dioxide.**

(a) Except as provided in paragraphs (d) and (e) of this section, the owner or operator of an affected facility subject to the SO<sub>2</sub>emission limits under §60.42c shall install, calibrate, maintain, and operate a CEMS for measuring SO<sub>2</sub>concentrations and either O<sub>2</sub>or CO<sub>2</sub>concentrations at the outlet of the SO<sub>2</sub>control device (or the outlet of the steam generating unit if no SO<sub>2</sub>control device is used), and shall record the output of the system. The owner or operator of an affected facility subject to the percent reduction requirements under §60.42c shall measure SO<sub>2</sub>concentrations and either O<sub>2</sub>or CO<sub>2</sub>concentrations at both the inlet and outlet of the SO<sub>2</sub>control device.

(b) The 1-hour average SO<sub>2</sub>emission rates measured by a CEMS shall be expressed in ng/J or lb/MMBtu heat input and shall be used to calculate the average emission rates under §60.42c. Each 1-hour average SO<sub>2</sub>emission rate must be based on at least 30 minutes of operation, and shall be calculated using the data points required under §60.13(h)(2). Hourly SO<sub>2</sub>emission rates are not calculated if the affected facility is operated less than 30 minutes in a 1-hour period and are not counted toward determination of a steam generating unit operating day.

(c) The procedures under §60.13 shall be followed for installation, evaluation, and operation of the CEMS.

(1) All CEMS shall be operated in accordance with the applicable procedures under Performance Specifications 1, 2, and 3 of appendix B of this part.

(2) Quarterly accuracy determinations and daily calibration drift tests shall be performed in accordance with Procedure 1 of appendix F of this part.

(3) For affected facilities subject to the percent reduction requirements under §60.42c, the span value of the SO<sub>2</sub>CEMS at the inlet to the SO<sub>2</sub>control device shall be 125 percent of the maximum estimated hourly potential SO<sub>2</sub>emission rate of the fuel combusted, and the span value of the SO<sub>2</sub>CEMS at the outlet from the SO<sub>2</sub>control device shall be 50 percent of the maximum estimated hourly potential SO<sub>2</sub>emission rate of the fuel combusted.

(4) For affected facilities that are not subject to the percent reduction requirements of §60.42c, the span value of the SO<sub>2</sub>CEMS at the outlet from the SO<sub>2</sub>control device (or outlet of the steam generating unit if no SO<sub>2</sub>control device is used) shall be 125 percent of the maximum estimated hourly potential SO<sub>2</sub>emission rate of the fuel combusted.

(d) As an alternative to operating a CEMS at the inlet to the SO<sub>2</sub>control device (or outlet of the steam generating unit if no SO<sub>2</sub>control device is used) as required under paragraph (a) of this section, an owner or operator may elect to determine the average SO<sub>2</sub>emission rate by sampling the fuel prior to combustion. As an alternative to operating a CEMS at the outlet from the SO<sub>2</sub>control device (or outlet of the steam generating unit if no SO<sub>2</sub>control device is used) as required under paragraph (a) of this section, an owner or operator may elect to determine the average SO<sub>2</sub>emission rate by using Method 6B of appendix A of this part. Fuel sampling shall be conducted pursuant to either paragraph (d)(1) or (d)(2) of this section. Method 6B of appendix A of this part shall be conducted pursuant to paragraph (d)(3) of this section.

(1) For affected facilities combusting coal or oil, coal or oil samples shall be collected daily in an as-fired condition at the inlet to the steam generating unit and analyzed for sulfur content and heat content according the Method 19 of appendix A of this part. Method 19 of appendix A of this part provides procedures for converting these measurements into the format to be used in calculating the average SO<sub>2</sub>input rate.

(2) As an alternative fuel sampling procedure for affected facilities combusting oil, oil samples may be collected from the fuel tank for each steam generating unit immediately after the fuel tank is filled and before any oil is combusted. The owner or operator of the affected facility shall analyze the oil sample to determine the sulfur content of the oil. If a partially empty fuel tank is refilled, a new sample and analysis of the fuel in the tank would be required upon filling. Results of the fuel analysis taken after each new shipment of oil is received shall be used as the daily value when calculating the 30-day rolling average until the next shipment is received. If the fuel analysis shows that the sulfur content in the fuel tank is greater than 0.5 weight percent sulfur, the owner or operator shall ensure that the sulfur content of subsequent oil shipments is low enough to cause the 30-day rolling average sulfur content to be 0.5 weight percent sulfur or less.

(3) Method 6B of appendix A of this part may be used in lieu of CEMS to measure SO<sub>2</sub>at the inlet or outlet of the SO<sub>2</sub>control system. An initial stratification test is required to verify the adequacy of the Method 6B of appendix A of this part sampling location. The stratification test shall consist of three paired runs of a suitable SO<sub>2</sub>and CO<sub>2</sub>measurement train operated at the candidate location and a second similar train operated according to the procedures in §3.2 and the applicable procedures in section 7 of Performance Specification 2 of appendix B of this part. Method 6B of appendix A of this part, Method 6A of appendix A of this part, or a combination of Methods 6 and 3 of appendix A of this part or Methods 6C and 3A of appendix A of this part are suitable measurement techniques. If Method 6B of appendix A of this part is

used for the second train, sampling time and timer operation may be adjusted for the stratification test as long as an adequate sample volume is collected; however, both sampling trains are to be operated similarly. For the location to be adequate for Method 6B of appendix A of this part 24-hour tests, the mean of the absolute difference between the three paired runs must be less than 10 percent (0.10).

(e) The monitoring requirements of paragraphs (a) and (d) of this section shall not apply to affected facilities subject to §60.42c(h) (1), (2), or (3) where the owner or operator of the affected facility seeks to demonstrate compliance with the SO<sub>2</sub> standards based on fuel supplier certification, as described under §60.48c(f), as applicable.

(f) The owner or operator of an affected facility operating a CEMS pursuant to paragraph (a) of this section, or conducting as-fired fuel sampling pursuant to paragraph (d)(1) of this section, shall obtain emission data for at least 75 percent of the operating hours in at least 22 out of 30 successive steam generating unit operating days. If this minimum data requirement is not met with a single monitoring system, the owner or operator of the affected facility shall supplement the emission data with data collected with other monitoring systems as approved by the Administrator.

#### **§ 60.47c Emission monitoring for particulate matter.**

(a) Except as provided in paragraphs (c), (d), (e), and (f) of this section, the owner or operator of an affected facility combusting coal, oil, or wood that is subject to the opacity standards under §60.43c shall install, calibrate, maintain, and operate a continuous opacity monitoring system (COMS) for measuring the opacity of the emissions discharged to the atmosphere and record the output of the system. The owner or operator of an affected facility subject to an opacity standard in §60.43c(c) that is not required to use a COMS due to paragraphs (c), (d), (e), or (f) of this section that elects not to use a COMS shall conduct a performance test using Method 9 of appendix A-4 of this part and the procedures in §60.11 to demonstrate compliance with the applicable limit in §60.43c by April 29, 2011, within 45 days of stopping use of an existing COMS, or within 180 days after initial startup of the facility, whichever is later, and shall comply with either paragraphs (a)(1), (a)(2), or (a)(3) of this section. The observation period for Method 9 of appendix A-4 of this part performance tests may be reduced from 3 hours to 60 minutes if all 6-minute averages are less than 10 percent and all individual 15-second observations are less than or equal to 20 percent during the initial 60 minutes of observation.

(1) Except as provided in paragraph (a)(2) and (a)(3) of this section, the owner or operator shall conduct subsequent Method 9 of appendix A-4 of this part performance tests using the procedures in paragraph (a) of this section according to the applicable schedule in paragraphs (a)(1)(i) through (a)(1)(iv) of this section, as determined by the most recent Method 9 of appendix A-4 of this part performance test results.

(i) If no visible emissions are observed, a subsequent Method 9 of appendix A-4 of this part performance test must be completed within 12 calendar months from the date that the most recent performance test was conducted or within 45 days of the next day that fuel with an opacity standard is combusted, whichever is later;

(ii) If visible emissions are observed but the maximum 6-minute average opacity is less than or equal to 5 percent, a subsequent Method 9 of appendix A-4 of this part performance test must be completed within 6 calendar months from the date that the most recent performance test was conducted or within 45 days of the next day that fuel with an opacity standard is combusted, whichever is later;

(iii) If the maximum 6-minute average opacity is greater than 5 percent but less than or equal to 10 percent, a subsequent Method 9 of appendix A-4 of this part performance test must be completed within 3 calendar months from the date that the most recent performance test was conducted or within 45 days of the next day that fuel with an opacity standard is combusted, whichever is later; or



(iv) If the maximum 6-minute average opacity is greater than 10 percent, a subsequent Method 9 of appendix A-4 of this part performance test must be completed within 45 calendar days from the date that the most recent performance test was conducted.

(2) If the maximum 6-minute opacity is less than 10 percent during the most recent Method 9 of appendix A-4 of this part performance test, the owner or operator may, as an alternative to performing subsequent Method 9 of appendix A-4 of this part performance tests, elect to perform subsequent monitoring using Method 22 of appendix A-7 of this part according to the procedures specified in paragraphs (a)(2)(i) and (ii) of this section.

(i) The owner or operator shall conduct 10 minute observations (during normal operation) each operating day the affected facility fires fuel for which an opacity standard is applicable using Method 22 of appendix A-7 of this part and demonstrate that the sum of the occurrences of any visible emissions is not in excess of 5 percent of the observation period ( *i.e.* , 30 seconds per 10 minute period). If the sum of the occurrence of any visible emissions is greater than 30 seconds during the initial 10 minute observation, immediately conduct a 30 minute observation. If the sum of the occurrence of visible emissions is greater than 5 percent of the observation period ( *i.e.*, 90 seconds per 30 minute period), the owner or operator shall either document and adjust the operation of the facility and demonstrate within 24 hours that the sum of the occurrence of visible emissions is equal to or less than 5 percent during a 30 minute observation ( *i.e.*, 90 seconds) or conduct a new Method 9 of appendix A-4 of this part performance test using the procedures in paragraph (a) of this section within 45 calendar days according to the requirements in §60.45c(a)(8).

(ii) If no visible emissions are observed for 10 operating days during which an opacity standard is applicable, observations can be reduced to once every 7 operating days during which an opacity standard is applicable. If any visible emissions are observed, daily observations shall be resumed.

(3) If the maximum 6-minute opacity is less than 10 percent during the most recent Method 9 of appendix A-4 of this part performance test, the owner or operator may, as an alternative to performing subsequent Method 9 of appendix A-4 performance tests, elect to perform subsequent monitoring using a digital opacity compliance system according to a site-specific monitoring plan approved by the Administrator. The observations shall be similar, but not necessarily identical, to the requirements in paragraph (a)(2) of this section. For reference purposes in preparing the monitoring plan, see OAQPS "Determination of Visible Emission Opacity from Stationary Sources Using Computer-Based Photographic Analysis Systems." This document is available from the U.S. Environmental Protection Agency (U.S. EPA); Office of Air Quality and Planning Standards; Sector Policies and Programs Division; Measurement Policy Group (D243-02), Research Triangle Park, NC 27711. This document is also available on the Technology Transfer Network (TTN) under Emission Measurement Center Preliminary Methods.

(b) All COMS shall be operated in accordance with the applicable procedures under Performance Specification 1 of appendix B of this part. The span value of the opacity COMS shall be between 60 and 80 percent.

(c) Owners and operators of an affected facilities that burn only distillate oil that contains no more than 0.5 weight percent sulfur and/or liquid or gaseous fuels with potential sulfur dioxide emission rates of 26 ng/J (0.060 lb/MMBtu) heat input or less and that do not use a post-combustion technology to reduce SO<sub>2</sub> or PM emissions and that are subject to an opacity standard in §60.43c(c) are not required to operate a COMS if they follow the applicable procedures in §60.48c(f).

(d) Owners or operators complying with the PM emission limit by using a PM CEMS must calibrate, maintain, operate, and record the output of the system for PM emissions discharged to the atmosphere as specified in §60.45c(c). The CEMS specified in paragraph §60.45c(c) shall be operated and data recorded during all periods of operation of the affected facility except for CEMS breakdowns and repairs. Data is recorded during calibration checks, and zero and span adjustments.

(e) Owners and operators of an affected facility that is subject to an opacity standard in §60.43c(c) and that does not use post-combustion technology (except a wet scrubber) for reducing PM, SO<sub>2</sub>, or carbon monoxide (CO) emissions, burns only gaseous fuels or fuel oils that contain less than or equal to 0.5 weight percent sulfur, and is operated such that emissions of CO discharged to the atmosphere from the affected facility are maintained at levels less than or equal to 0.15 lb/MMBtu on a boiler operating day average basis is not required to operate a COMS. Owners and operators of affected facilities electing to comply with this paragraph must demonstrate compliance according to the procedures specified in paragraphs (e)(1) through (4) of this section; or

(1) You must monitor CO emissions using a CEMS according to the procedures specified in paragraphs (e)(1)(i) through (iv) of this section.

(i) The CO CEMS must be installed, certified, maintained, and operated according to the provisions in §60.58b(i)(3) of subpart Eb of this part.

(ii) Each 1-hour CO emissions average is calculated using the data points generated by the CO CEMS expressed in parts per million by volume corrected to 3 percent oxygen (dry basis).

(iii) At a minimum, valid 1-hour CO emissions averages must be obtained for at least 90 percent of the operating hours on a 30-day rolling average basis. The 1-hour averages are calculated using the data points required in §60.13(h)(2).

(iv) Quarterly accuracy determinations and daily calibration drift tests for the CO CEMS must be performed in accordance with procedure 1 in appendix F of this part.

(2) You must calculate the 1-hour average CO emissions levels for each steam generating unit operating day by multiplying the average hourly CO output concentration measured by the CO CEMS times the corresponding average hourly flue gas flow rate and divided by the corresponding average hourly heat input to the affected source. The 24-hour average CO emission level is determined by calculating the arithmetic average of the hourly CO emission levels computed for each steam generating unit operating day.

(3) You must evaluate the preceding 24-hour average CO emission level each steam generating unit operating day excluding periods of affected source startup, shutdown, or malfunction. If the 24-hour average CO emission level is greater than 0.15 lb/MMBtu, you must initiate investigation of the relevant equipment and control systems within 24 hours of the first discovery of the high emission incident and, take the appropriate corrective action as soon as practicable to adjust control settings or repair equipment to reduce the 24-hour average CO emission level to 0.15 lb/MMBtu or less.

(4) You must record the CO measurements and calculations performed according to paragraph (e) of this section and any corrective actions taken. The record of corrective action taken must include the date and time during which the 24-hour average CO emission level was greater than 0.15 lb/MMBtu, and the date, time, and description of the corrective action.

(f) An owner or operator of an affected facility that is subject to an opacity standard in §60.43c(c) is not required to operate a COMS provided that the affected facility meets the conditions in either paragraphs (f)(1), (2), or (3) of this section.

(1) The affected facility uses a fabric filter (baghouse) as the primary PM control device and, the owner or operator operates a bag leak detection system to monitor the performance of the fabric filter according to the requirements in section §60.48Da of this part.

(2) The affected facility uses an ESP as the primary PM control device, and the owner or operator uses an ESP predictive model to monitor the performance of the ESP developed in accordance and operated according to the requirements in section §60.48Da of this part.

(3) The affected facility burns only gaseous fuels and/or fuel oils that contain no greater than 0.5 weight percent sulfur, and the owner or operator operates the unit according to a written site-specific monitoring plan approved by the permitting authority. This monitoring plan must include procedures and criteria for establishing and monitoring specific parameters for the affected facility indicative of compliance with the opacity standard. For testing performed as part of this site-specific monitoring plan, the permitting authority may require as an alternative to the notification and reporting requirements specified in §§60.8 and 60.11 that the owner or operator submit any deviations with the excess emissions report required under §60.48c(c).

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009; 76 FR 3523, Jan. 20, 2011; 77 FR 9463, Feb. 16, 2012]

#### **§ 60.48c Reporting and recordkeeping requirements.**

(a) The owner or operator of each affected facility shall submit notification of the date of construction or reconstruction and actual startup, as provided by §60.7 of this part. This notification shall include:

(1) The design heat input capacity of the affected facility and identification of fuels to be combusted in the affected facility.

(2) If applicable, a copy of any federally enforceable requirement that limits the annual capacity factor for any fuel or mixture of fuels under §60.42c, or §60.43c.

(3) The annual capacity factor at which the owner or operator anticipates operating the affected facility based on all fuels fired and based on each individual fuel fired.

(4) Notification if an emerging technology will be used for controlling SO<sub>2</sub> emissions. The Administrator will examine the description of the control device and will determine whether the technology qualifies as an emerging technology. In making this determination, the Administrator may require the owner or operator of the affected facility to submit additional information concerning the control device. The affected facility is subject to the provisions of §60.42c(a) or (b)(1), unless and until this determination is made by the Administrator.

(b) The owner or operator of each affected facility subject to the SO<sub>2</sub> emission limits of §60.42c, or the PM or opacity limits of §60.43c, shall submit to the Administrator the performance test data from the initial and any subsequent performance tests and, if applicable, the performance evaluation of the CEMS and/or COMS using the applicable performance specifications in appendix B of this part.

(c) In addition to the applicable requirements in §60.7, the owner or operator of an affected facility subject to the opacity limits in §60.43c(c) shall submit excess emission reports for any excess emissions from the affected facility that occur during the reporting period and maintain records according to the requirements specified in paragraphs (c)(1) through (3) of this section, as applicable to the visible emissions monitoring method used.

(1) For each performance test conducted using Method 9 of appendix A-4 of this part, the owner or operator shall keep the records including the information specified in paragraphs (c)(1)(i) through (iii) of this section.

(i) Dates and time intervals of all opacity observation periods;

(ii) Name, affiliation, and copy of current visible emission reading certification for each visible emission observer participating in the performance test; and

(iii) Copies of all visible emission observer opacity field data sheets;

(2) For each performance test conducted using Method 22 of appendix A-4 of this part, the owner or operator shall keep the records including the information specified in paragraphs (c)(2)(i) through (iv) of this section.

(i) Dates and time intervals of all visible emissions observation periods;

(ii) Name and affiliation for each visible emission observer participating in the performance test;

(iii) Copies of all visible emission observer opacity field data sheets; and

(iv) Documentation of any adjustments made and the time the adjustments were completed to the affected facility operation by the owner or operator to demonstrate compliance with the applicable monitoring requirements.

(3) For each digital opacity compliance system, the owner or operator shall maintain records and submit reports according to the requirements specified in the site-specific monitoring plan approved by the Administrator

(d) The owner or operator of each affected facility subject to the SO<sub>2</sub> emission limits, fuel oil sulfur limits, or percent reduction requirements under §60.42c shall submit reports to the Administrator.

(e) The owner or operator of each affected facility subject to the SO<sub>2</sub> emission limits, fuel oil sulfur limits, or percent reduction requirements under §60.42c shall keep records and submit reports as required under paragraph (d) of this section, including the following information, as applicable.

(1) Calendar dates covered in the reporting period.

(2) Each 30-day average SO<sub>2</sub> emission rate (ng/J or lb/MMBtu), or 30-day average sulfur content (weight percent), calculated during the reporting period, ending with the last 30-day period; reasons for any noncompliance with the emission standards; and a description of corrective actions taken.

(3) Each 30-day average percent of potential SO<sub>2</sub> emission rate calculated during the reporting period, ending with the last 30-day period; reasons for any noncompliance with the emission standards; and a description of the corrective actions taken.

(4) Identification of any steam generating unit operating days for which SO<sub>2</sub> or diluent (O<sub>2</sub> or CO<sub>2</sub>) data have not been obtained by an approved method for at least 75 percent of the operating hours; justification for not obtaining sufficient data; and a description of corrective actions taken.

(5) Identification of any times when emissions data have been excluded from the calculation of average emission rates; justification for excluding data; and a description of corrective actions taken if data have been excluded for periods other than those during which coal or oil were not combusted in the steam generating unit.

(6) Identification of the F factor used in calculations, method of determination, and type of fuel combusted.

(7) Identification of whether averages have been obtained based on CEMS rather than manual sampling methods.

(8) If a CEMS is used, identification of any times when the pollutant concentration exceeded the full span of the CEMS.

(9) If a CEMS is used, description of any modifications to the CEMS that could affect the ability of the CEMS to comply with Performance Specifications 2 or 3 of appendix B of this part.

(10) If a CEMS is used, results of daily CEMS drift tests and quarterly accuracy assessments as required under appendix F, Procedure 1 of this part.

(11) If fuel supplier certification is used to demonstrate compliance, records of fuel supplier certification as described under paragraph (f)(1), (2), (3), or (4) of this section, as applicable. In addition to records of fuel supplier certifications, the report shall include a certified statement signed by the owner or operator of the affected facility that the records of fuel supplier certifications submitted represent all of the fuel combusted during the reporting period.

(f) Fuel supplier certification shall include the following information:

(1) For distillate oil:

(i) The name of the oil supplier;

(ii) A statement from the oil supplier that the oil complies with the specifications under the definition of distillate oil in §60.41c; and

(iii) The sulfur content or maximum sulfur content of the oil.

(2) For residual oil:

(i) The name of the oil supplier;

(ii) The location of the oil when the sample was drawn for analysis to determine the sulfur content of the oil, specifically including whether the oil was sampled as delivered to the affected facility, or whether the sample was drawn from oil in storage at the oil supplier's or oil refiner's facility, or other location;

(iii) The sulfur content of the oil from which the shipment came (or of the shipment itself); and

(iv) The method used to determine the sulfur content of the oil.

(3) For coal:

(i) The name of the coal supplier;

(ii) The location of the coal when the sample was collected for analysis to determine the properties of the coal, specifically including whether the coal was sampled as delivered to the affected facility or whether the sample was collected from coal in storage at the mine, at a coal preparation plant, at a coal supplier's facility, or at another location. The certification shall include the name of the coal mine (and coal seam), coal storage facility, or coal preparation plant (where the sample was collected);

(iii) The results of the analysis of the coal from which the shipment came (or of the shipment itself) including the sulfur content, moisture content, ash content, and heat content; and

(iv) The methods used to determine the properties of the coal.

(4) For other fuels:

(i) The name of the supplier of the fuel;

(ii) The potential sulfur emissions rate or maximum potential sulfur emissions rate of the fuel in ng/J heat input; and

(iii) The method used to determine the potential sulfur emissions rate of the fuel.

(g)(1) Except as provided under paragraphs (g)(2) and (g)(3) of this section, the owner or operator of each affected facility shall record and maintain records of the amount of each fuel combusted during each operating day.

(2) As an alternative to meeting the requirements of paragraph (g)(1) of this section, the owner or operator of an affected facility that combusts only natural gas, wood, fuels using fuel certification in §60.48c(f) to demonstrate compliance with the SO<sub>2</sub> standard, fuels not subject to an emissions standard (excluding opacity), or a mixture of these fuels may elect to record and maintain records of the amount of each fuel combusted during each calendar month.

(3) As an alternative to meeting the requirements of paragraph (g)(1) of this section, the owner or operator of an affected facility or multiple affected facilities located on a contiguous property unit where the only fuels combusted in any steam generating unit (including steam generating units not subject to this subpart) at that property are natural gas, wood, distillate oil meeting the most current requirements in §60.42C to use fuel certification to demonstrate compliance with the SO<sub>2</sub> standard, and/or fuels, excluding coal and residual oil, not subject to an emissions standard (excluding opacity) may elect to record and maintain records of the total amount of each steam generating unit fuel delivered to that property during each calendar month.

(h) The owner or operator of each affected facility subject to a federally enforceable requirement limiting the annual capacity factor for any fuel or mixture of fuels under §60.42c or §60.43c shall calculate the annual capacity factor individually for each fuel combusted. The annual capacity factor is determined on a 12-month rolling average basis with a new annual capacity factor calculated at the end of the calendar month.

(i) All records required under this section shall be maintained by the owner or operator of the affected facility for a period of two years following the date of such record.

(j) The reporting period for the reports required under this subpart is each six-month period. All reports shall be submitted to the Administrator and shall be postmarked by the 30th day following the end of the reporting period.

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009]

## **Attachment B**

### **Title 40: Protection of Environment**

#### **PART 60— STANDARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES**

##### **Subpart III—Standards of Performance for Stationary Compression Ignition Internal Combustion Engines**

**Source:** 71 FR 39172, July 11, 2006, unless otherwise noted.

##### **What This Subpart Covers**

###### **§ 60.4200 Am I subject to this subpart?**

(a) The provisions of this subpart are applicable to manufacturers, owners, and operators of stationary compression ignition (CI) internal combustion engines (ICE) and other persons as specified in paragraphs (a)(1) through (4) of this section. For the purposes of this subpart, the date that construction commences is the date the engine is ordered by the owner or operator.

(1) Manufacturers of stationary CI ICE with a displacement of less than 30 liters per cylinder where the model year is:

(i) 2007 or later, for engines that are not fire pump engines;

(ii) The model year listed in Table 3 to this subpart or later model year, for fire pump engines.

(2) Owners and operators of stationary CI ICE that commence construction after July 11, 2005, where the stationary CI ICE are:

(i) Manufactured after April 1, 2006, and are not fire pump engines, or

(ii) Manufactured as a certified National Fire Protection Association (NFPA) fire pump engine after July 1, 2006.

(3) Owners and operators of any stationary CI ICE that are modified or reconstructed after July 11, 2005 and any person that modifies or reconstructs any stationary CI ICE after July 11, 2005.

(4) The provisions of §60.4208 of this subpart are applicable to all owners and operators of stationary CI ICE that commence construction after July 11, 2005.

(b) The provisions of this subpart are not applicable to stationary CI ICE being tested at a stationary CI ICE test cell/stand.

(c) If you are an owner or operator of an area source subject to this subpart, you are exempt from the obligation to obtain a permit under 40 CFR part 70 or 40 CFR part 71, provided you are not required to obtain a permit under 40 CFR 70.3(a) or 40 CFR 71.3(a) for a reason other than your status as an area source under this subpart. Notwithstanding the previous sentence, you must continue to comply with the provisions of this subpart applicable to area sources.

(d) Stationary CI ICE may be eligible for exemption from the requirements of this subpart as described in 40 CFR part 1068, subpart C (or the exemptions described in 40 CFR part 89, subpart J and 40 CFR part 94, subpart J, for engines that would need to be certified to standards in those parts), except that owners and operators, as well as manufacturers, may be eligible to request an exemption for national security.

(e) Owners and operators of facilities with CI ICE that are acting as temporary replacement units and that are located at a stationary source for less than 1 year and that have been properly certified as meeting

the standards that would be applicable to such engine under the appropriate nonroad engine provisions, are not required to meet any other provisions under this subpart with regard to such engines.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37967, June 28, 2011]

## **Emission Standards for Manufacturers**

### **§ 60.4201 What emission standards must I meet for non-emergency engines if I am a stationary CI internal combustion engine manufacturer?**

(a) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later non-emergency stationary CI ICE with a maximum engine power less than or equal to 2,237 kilowatt (KW) (3,000 horsepower (HP)) and a displacement of less than 10 liters per cylinder to the certification emission standards for new nonroad CI engines in 40 CFR 89.112, 40 CFR 89.113, 40 CFR 1039.101, 40 CFR 1039.102, 40 CFR 1039.104, 40 CFR 1039.105, 40 CFR 1039.107, and 40 CFR 1039.115, as applicable, for all pollutants, for the same model year and maximum engine power.

(b) Stationary CI internal combustion engine manufacturers must certify their 2007 through 2010 model year non-emergency stationary CI ICE with a maximum engine power greater than 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder to the emission standards in table 1 to this subpart, for all pollutants, for the same maximum engine power.

(c) Stationary CI internal combustion engine manufacturers must certify their 2011 model year and later non-emergency stationary CI ICE with a maximum engine power greater than 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder to the certification emission standards for new nonroad CI engines in 40 CFR 1039.101, 40 CFR 1039.102, 40 CFR 1039.104, 40 CFR 1039.105, 40 CFR 1039.107, and 40 CFR 1039.115, as applicable, for all pollutants, for the same maximum engine power.

(d) Stationary CI internal combustion engine manufacturers must certify the following non-emergency stationary CI ICE to the certification emission standards for new marine CI engines in 40 CFR 94.8, as applicable, for all pollutants, for the same displacement and maximum engine power:

(1) Their 2007 model year through 2012 non-emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder;

(2) Their 2013 model year non-emergency stationary CI ICE with a maximum engine power greater than or equal to 3,700 KW (4,958 HP) and a displacement of greater than or equal to 10 liters per cylinder and less than 15 liters per cylinder; and

(3) Their 2013 model year non-emergency stationary CI ICE with a displacement of greater than or equal to 15 liters per cylinder and less than 30 liters per cylinder.

(e) Stationary CI internal combustion engine manufacturers must certify the following non-emergency stationary CI ICE to the certification emission standards and other requirements for new marine CI engines in 40 CFR 1042.101, 40 CFR 1042.107, 40 CFR 1042.110, 40 CFR 1042.115, 40 CFR 1042.120, and 40 CFR 1042.145, as applicable, for all pollutants, for the same displacement and maximum engine power:

(1) Their 2013 model year non-emergency stationary CI ICE with a maximum engine power less than 3,700 KW (4,958 HP) and a displacement of greater than or equal to 10 liters per cylinder and less than 15 liters per cylinder; and

(2) Their 2014 model year and later non-emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder.

(f) Notwithstanding the requirements in paragraphs (a) through (c) of this section, stationary non-emergency CI ICE identified in paragraphs (a) and (c) may be certified to the provisions of 40 CFR part



94 or, if Table 1 to 40 CFR 1042.1 identifies 40 CFR part 1042 as being applicable, 40 CFR part 1042, if the engines will be used solely in either or both of the following locations:

- (1) Areas of Alaska not accessible by the Federal Aid Highway System (FAHS); and
- (2) Marine offshore installations.

(g) Notwithstanding the requirements in paragraphs (a) through (f) of this section, stationary CI internal combustion engine manufacturers are not required to certify reconstructed engines; however manufacturers may elect to do so. The reconstructed engine must be certified to the emission standards specified in paragraphs (a) through (e) of this section that are applicable to the model year, maximum engine power, and displacement of the reconstructed stationary CI ICE.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37967, June 28, 2011]

**§ 60.4202 What emission standards must I meet for emergency engines if I am a stationary CI internal combustion engine manufacturer?**

(a) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a maximum engine power less than or equal to 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder that are not fire pump engines to the emission standards specified in paragraphs (a)(1) through (2) of this section.

(1) For engines with a maximum engine power less than 37 KW (50 HP):

(i) The certification emission standards for new nonroad CI engines for the same model year and maximum engine power in 40 CFR 89.112 and 40 CFR 89.113 for all pollutants for model year 2007 engines, and

(ii) The certification emission standards for new nonroad CI engines in 40 CFR 1039.104, 40 CFR 1039.105, 40 CFR 1039.107, 40 CFR 1039.115, and table 2 to this subpart, for 2008 model year and later engines.

(2) For engines with a maximum engine power greater than or equal to 37 KW (50 HP), the certification emission standards for new nonroad CI engines for the same model year and maximum engine power in 40 CFR 89.112 and 40 CFR 89.113 for all pollutants beginning in model year 2007.

(b) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a maximum engine power greater than 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder that are not fire pump engines to the emission standards specified in paragraphs (b)(1) through (2) of this section.

(1) For 2007 through 2010 model years, the emission standards in table 1 to this subpart, for all pollutants, for the same maximum engine power.

(2) For 2011 model year and later, the certification emission standards for new nonroad CI engines for engines of the same model year and maximum engine power in 40 CFR 89.112 and 40 CFR 89.113 for all pollutants.

(c) [Reserved]

(d) Beginning with the model years in table 3 to this subpart, stationary CI internal combustion engine manufacturers must certify their fire pump stationary CI ICE to the emission standards in table 4 to this subpart, for all pollutants, for the same model year and NFPA nameplate power.

(e) Stationary CI internal combustion engine manufacturers must certify the following emergency stationary CI ICE that are not fire pump engines to the certification emission standards for new marine CI

engines in 40 CFR 94.8, as applicable, for all pollutants, for the same displacement and maximum engine power:

(1) Their 2007 model year through 2012 emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder;

(2) Their 2013 model year and later emergency stationary CI ICE with a maximum engine power greater than or equal to 3,700 KW (4,958 HP) and a displacement of greater than or equal to 10 liters per cylinder and less than 15 liters per cylinder;

(3) Their 2013 model year emergency stationary CI ICE with a displacement of greater than or equal to 15 liters per cylinder and less than 30 liters per cylinder; and

(4) Their 2014 model year and later emergency stationary CI ICE with a maximum engine power greater than or equal to 2,000 KW (2,682 HP) and a displacement of greater than or equal to 15 liters per cylinder and less than 30 liters per cylinder.

(f) Stationary CI internal combustion engine manufacturers must certify the following emergency stationary CI ICE to the certification emission standards and other requirements applicable to Tier 3 new marine CI engines in 40 CFR 1042.101, 40 CFR 1042.107, 40 CFR 1042.115, 40 CFR 1042.120, and 40 CFR 1042.145, for all pollutants, for the same displacement and maximum engine power:

(1) Their 2013 model year and later emergency stationary CI ICE with a maximum engine power less than 3,700 KW (4,958 HP) and a displacement of greater than or equal to 10 liters per cylinder and less than 15 liters per cylinder; and

(2) Their 2014 model year and later emergency stationary CI ICE with a maximum engine power less than 2,000 KW (2,682 HP) and a displacement of greater than or equal to 15 liters per cylinder and less than 30 liters per cylinder.

(g) Notwithstanding the requirements in paragraphs (a) through (d) of this section, stationary emergency CI internal combustion engines identified in paragraphs (a) and (c) may be certified to the provisions of 40 CFR part 94 or, if Table 2 to 40 CFR 1042.101 identifies Tier 3 standards as being applicable, the requirements applicable to Tier 3 engines in 40 CFR part 1042, if the engines will be used solely in either or both of the following locations:

(1) Areas of Alaska not accessible by the FAHS; and

(2) Marine offshore installations.

(h) Notwithstanding the requirements in paragraphs (a) through (f) of this section, stationary CI internal combustion engine manufacturers are not required to certify reconstructed engines; however manufacturers may elect to do so. The reconstructed engine must be certified to the emission standards specified in paragraphs (a) through (f) of this section that are applicable to the model year, maximum engine power and displacement of the reconstructed emergency stationary CI ICE.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37968, June 28, 2011]

**§ 60.4203 How long must my engines meet the emission standards if I am a manufacturer of stationary CI internal combustion engines?**

Engines manufactured by stationary CI internal combustion engine manufacturers must meet the emission standards as required in §§60.4201 and 60.4202 during the certified emissions life of the engines.

[76 FR 37968, June 28, 2011]

## Emission Standards for Owners and Operators

### § 60.4204 What emission standards must I meet for non-emergency engines if I am an owner or operator of a stationary CI internal combustion engine?

(a) Owners and operators of pre-2007 model year non-emergency stationary CI ICE with a displacement of less than 10 liters per cylinder must comply with the emission standards in table 1 to this subpart. Owners and operators of pre-2007 model year non-emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder must comply with the emission standards in 40 CFR 94.8(a)(1).

(b) Owners and operators of 2007 model year and later non-emergency stationary CI ICE with a displacement of less than 30 liters per cylinder must comply with the emission standards for new CI engines in §60.4201 for their 2007 model year and later stationary CI ICE, as applicable.

(c) Owners and operators of non-emergency stationary CI engines with a displacement of greater than or equal to 30 liters per cylinder must meet the following requirements:

(1) For engines installed prior to January 1, 2012, limit the emissions of  $\text{NO}_x$  in the stationary CI internal combustion engine exhaust to the following:

(i) 17.0 grams per kilowatt-hour (g/KW-hr) (12.7 grams per horsepower-hr (g/HP-hr)) when maximum engine speed is less than 130 revolutions per minute (rpm);

(ii)  $45 \cdot n^{-0.2}$  g/KW-hr ( $34 \cdot n^{-0.2}$  g/HP-hr) when maximum engine speed is 130 or more but less than 2,000 rpm, where n is maximum engine speed; and

(iii) 9.8 g/KW-hr (7.3 g/HP-hr) when maximum engine speed is 2,000 rpm or more.

(2) For engines installed on or after January 1, 2012 and before January 1, 2016, limit the emissions of  $\text{NO}_x$  in the stationary CI internal combustion engine exhaust to the following:

(i) 14.4 g/KW-hr (10.7 g/HP-hr) when maximum engine speed is less than 130 rpm;

(ii)  $44 \cdot n^{-0.23}$  g/KW-hr ( $33 \cdot n^{-0.23}$  g/HP-hr) when maximum engine speed is greater than or equal to 130 but less than 2,000 rpm and where n is maximum engine speed; and

(iii) 7.7 g/KW-hr (5.7 g/HP-hr) when maximum engine speed is greater than or equal to 2,000 rpm.

(3) For engines installed on or after January 1, 2016, limit the emissions of  $\text{NO}_x$  in the stationary CI internal combustion engine exhaust to the following:

(i) 3.4 g/KW-hr (2.5 g/HP-hr) when maximum engine speed is less than 130 rpm;

(ii)  $9.0 \cdot n^{-0.20}$  g/KW-hr ( $6.7 \cdot n^{-0.20}$  g/HP-hr) where n (maximum engine speed) is 130 or more but less than 2,000 rpm; and

(iii) 2.0 g/KW-hr (1.5 g/HP-hr) where maximum engine speed is greater than or equal to 2,000 rpm.

(4) Reduce particulate matter (PM) emissions by 60 percent or more, or limit the emissions of PM in the stationary CI internal combustion engine exhaust to 0.15 g/KW-hr (0.11 g/HP-hr).

(d) Owners and operators of non-emergency stationary CI ICE with a displacement of less than 30 liters per cylinder who conduct performance tests in-use must meet the not-to-exceed (NTE) standards as indicated in §60.4212.

(e) Owners and operators of any modified or reconstructed non-emergency stationary CI ICE subject to this subpart must meet the emission standards applicable to the model year, maximum engine power, and displacement of the modified or reconstructed non-emergency stationary CI ICE that are specified in paragraphs (a) through (d) of this section.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37968, June 28, 2011]

**§ 60.4205 What emission standards must I meet for emergency engines if I am an owner or operator of a stationary CI internal combustion engine?**

(a) Owners and operators of pre-2007 model year emergency stationary CI ICE with a displacement of less than 10 liters per cylinder that are not fire pump engines must comply with the emission standards in Table 1 to this subpart. Owners and operators of pre-2007 model year emergency stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards in 40 CFR 94.8(a)(1).

(b) Owners and operators of 2007 model year and later emergency stationary CI ICE with a displacement of less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards for new nonroad CI engines in §60.4202, for all pollutants, for the same model year and maximum engine power for their 2007 model year and later emergency stationary CI ICE.

(c) Owners and operators of fire pump engines with a displacement of less than 30 liters per cylinder must comply with the emission standards in table 4 to this subpart, for all pollutants.

(d) Owners and operators of emergency stationary CI engines with a displacement of greater than or equal to 30 liters per cylinder must meet the requirements in this section.

(1) For engines installed prior to January 1, 2012, limit the emissions of  $\text{NO}_x$  in the stationary CI internal combustion engine exhaust to the following:

(i) 17.0 g/KW-hr (12.7 g/HP-hr) when maximum engine speed is less than 130 rpm;

(ii)  $45 \cdot n^{-0.2}$  g/KW-hr ( $34 \cdot n^{-0.2}$  g/HP-hr) when maximum engine speed is 130 or more but less than 2,000 rpm, where n is maximum engine speed; and

(iii) 9.8 g/kW-hr (7.3 g/HP-hr) when maximum engine speed is 2,000 rpm or more.

(2) For engines installed on or after January 1, 2012, limit the emissions of  $\text{NO}_x$  in the stationary CI internal combustion engine exhaust to the following:

(i) 14.4 g/KW-hr (10.7 g/HP-hr) when maximum engine speed is less than 130 rpm;

(ii)  $44 \cdot n^{-0.23}$  g/KW-hr ( $33 \cdot n^{-0.23}$  g/HP-hr) when maximum engine speed is greater than or equal to 130 but less than 2,000 rpm and where n is maximum engine speed; and

(iii) 7.7 g/KW-hr (5.7 g/HP-hr) when maximum engine speed is greater than or equal to 2,000 rpm.

(3) Limit the emissions of PM in the stationary CI internal combustion engine exhaust to 0.40 g/KW-hr (0.30 g/HP-hr).

(e) Owners and operators of emergency stationary CI ICE with a displacement of less than 30 liters per cylinder who conduct performance tests in-use must meet the NTE standards as indicated in §60.4212.

(f) Owners and operators of any modified or reconstructed emergency stationary CI ICE subject to this subpart must meet the emission standards applicable to the model year, maximum engine power, and displacement of the modified or reconstructed CI ICE that are specified in paragraphs (a) through (e) of this section.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37969, June 28, 2011]

**§ 60.4206 How long must I meet the emission standards if I am an owner or operator of a stationary CI internal combustion engine?**

Owners and operators of stationary CI ICE must operate and maintain stationary CI ICE that achieve the emission standards as required in §§60.4204 and 60.4205 over the entire life of the engine.

[76 FR 37969, June 28, 2011]

**Fuel Requirements for Owners and Operators**

**§ 60.4207 What fuel requirements must I meet if I am an owner or operator of a stationary CI internal combustion engine subject to this subpart?**

(a) Beginning October 1, 2007, owners and operators of stationary CI ICE subject to this subpart that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 80.510(a).

(b) Beginning October 1, 2010, owners and operators of stationary CI ICE subject to this subpart with a displacement of less than 30 liters per cylinder that use diesel fuel must purchase diesel fuel that meets the requirements of 40 CFR 80.510(b) for nonroad diesel fuel.

(c) [Reserved]

(d) Beginning June 1, 2012, owners and operators of stationary CI ICE subject to this subpart with a displacement of greater than or equal to 30 liters per cylinder are no longer subject to the requirements of paragraph (a) of this section, and must use fuel that meets a maximum per-gallon sulfur content of 1,000 parts per million (ppm).

(e) Stationary CI ICE that have a national security exemption under §60.4200(d) are also exempt from the fuel requirements in this section.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37969, June 28, 2011]

**Other Requirements for Owners and Operators**

**§ 60.4208 What is the deadline for importing or installing stationary CI ICE produced in previous model years?**

(a) After December 31, 2008, owners and operators may not install stationary CI ICE (excluding fire pump engines) that do not meet the applicable requirements for 2007 model year engines.

(b) After December 31, 2009, owners and operators may not install stationary CI ICE with a maximum engine power of less than 19 KW (25 HP) (excluding fire pump engines) that do not meet the applicable requirements for 2008 model year engines.

(c) After December 31, 2014, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power of greater than or equal to 19 KW (25 HP) and less than 56 KW (75 HP) that do not meet the applicable requirements for 2013 model year non-emergency engines.

(d) After December 31, 2013, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power of greater than or equal to 56 KW (75 HP) and less than 130 KW (175 HP) that do not meet the applicable requirements for 2012 model year non-emergency engines.

(e) After December 31, 2012, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power of greater than or equal to 130 KW (175 HP), including those above 560 KW (750 HP), that do not meet the applicable requirements for 2011 model year non-emergency engines.

(f) After December 31, 2016, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power of greater than or equal to 560 KW (750 HP) that do not meet the applicable requirements for 2015 model year non-emergency engines.

(g) After December 31, 2018, owners and operators may not install non-emergency stationary CI ICE with a maximum engine power greater than or equal to 600 KW (804 HP) and less than 2,000 KW (2,680 HP) and a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder that do not meet the applicable requirements for 2017 model year non-emergency engines.

(h) In addition to the requirements specified in §§60.4201, 60.4202, 60.4204, and 60.4205, it is prohibited to import stationary CI ICE with a displacement of less than 30 liters per cylinder that do not meet the applicable requirements specified in paragraphs (a) through (g) of this section after the dates specified in paragraphs (a) through (g) of this section.

(i) The requirements of this section do not apply to owners or operators of stationary CI ICE that have been modified, reconstructed, and do not apply to engines that were removed from one existing location and reinstalled at a new location.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37969, June 28, 2011]

**§ 60.4209 What are the monitoring requirements if I am an owner or operator of a stationary CI internal combustion engine?**

If you are an owner or operator, you must meet the monitoring requirements of this section. In addition, you must also meet the monitoring requirements specified in §60.4211.

(a) If you are an owner or operator of an emergency stationary CI internal combustion engine that does not meet the standards applicable to non-emergency engines, you must install a non-resettable hour meter prior to startup of the engine.

(b) If you are an owner or operator of a stationary CI internal combustion engine equipped with a diesel particulate filter to comply with the emission standards in §60.4204, the diesel particulate filter must be installed with a backpressure monitor that notifies the owner or operator when the high backpressure limit of the engine is approached.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37969, June 28, 2011]

**Compliance Requirements**

**§ 60.4210 What are my compliance requirements if I am a stationary CI internal combustion engine manufacturer?**

(a) Stationary CI internal combustion engine manufacturers must certify their stationary CI ICE with a displacement of less than 10 liters per cylinder to the emission standards specified in §60.4201(a) through (c) and §60.4202(a), (b) and (d) using the certification procedures required in 40 CFR part 89, subpart B, or 40 CFR part 1039, subpart C, as applicable, and must test their engines as specified in those parts. For the purposes of this subpart, engines certified to the standards in table 1 to this subpart shall be subject to the same requirements as engines certified to the standards in 40 CFR part 89. For the purposes of this subpart, engines certified to the standards in table 4 to this subpart shall be subject to the same requirements as engines certified to the standards in 40 CFR part 89, except that engines with NFPA nameplate power of less than 37 KW (50 HP) certified to model year 2011 or later standards shall be subject to the same requirements as engines certified to the standards in 40 CFR part 1039.

(b) Stationary CI internal combustion engine manufacturers must certify their stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder to the emission standards specified in §60.4201(d) and (e) and §60.4202(e) and (f) using the certification procedures required in 40 CFR part 94, subpart C, or 40 CFR part 1042, subpart C, as applicable, and must test their engines as specified in 40 CFR part 94 or 1042, as applicable.

(c) Stationary CI internal combustion engine manufacturers must meet the requirements of 40 CFR 1039.120, 1039.125, 1039.130, and 1039.135, and 40 CFR part 1068 for engines that are certified to the emission standards in 40 CFR part 1039. Stationary CI internal combustion engine manufacturers must meet the corresponding provisions of 40 CFR part 89, 40 CFR part 94 or 40 CFR part 1042 for engines that would be covered by that part if they were nonroad (including marine) engines. Labels on such engines must refer to stationary engines, rather than or in addition to nonroad or marine engines, as appropriate. Stationary CI internal combustion engine manufacturers must label their engines according to paragraphs (c)(1) through (3) of this section.

(1) Stationary CI internal combustion engines manufactured from January 1, 2006 to March 31, 2006 (January 1, 2006 to June 30, 2006 for fire pump engines), other than those that are part of certified engine families under the nonroad CI engine regulations, must be labeled according to 40 CFR 1039.20.

(2) Stationary CI internal combustion engines manufactured from April 1, 2006 to December 31, 2006 (or, for fire pump engines, July 1, 2006 to December 31 of the year preceding the year listed in table 3 to this subpart) must be labeled according to paragraphs (c)(2)(i) through (iii) of this section:

(i) Stationary CI internal combustion engines that are part of certified engine families under the nonroad regulations must meet the labeling requirements for nonroad CI engines, but do not have to meet the labeling requirements in 40 CFR 1039.20.

(ii) Stationary CI internal combustion engines that meet Tier 1 requirements (or requirements for fire pumps) under this subpart, but do not meet the requirements applicable to nonroad CI engines must be labeled according to 40 CFR 1039.20. The engine manufacturer may add language to the label clarifying that the engine meets Tier 1 requirements (or requirements for fire pumps) of this subpart.

(iii) Stationary CI internal combustion engines manufactured after April 1, 2006 that do not meet Tier 1 requirements of this subpart, or fire pumps engines manufactured after July 1, 2006 that do not meet the requirements for fire pumps under this subpart, may not be used in the U.S. If any such engines are manufactured in the U.S. after April 1, 2006 (July 1, 2006 for fire pump engines), they must be exported or must be brought into compliance with the appropriate standards prior to initial operation. The export provisions of 40 CFR 1068.230 would apply to engines for export and the manufacturers must label such engines according to 40 CFR 1068.230.

(3) Stationary CI internal combustion engines manufactured after January 1, 2007 (for fire pump engines, after January 1 of the year listed in table 3 to this subpart, as applicable) must be labeled according to paragraphs (c)(3)(i) through (iii) of this section.

(i) Stationary CI internal combustion engines that meet the requirements of this subpart and the corresponding requirements for nonroad (including marine) engines of the same model year and HP must be labeled according to the provisions in 40 CFR parts 89, 94, 1039 or 1042, as appropriate.

(ii) Stationary CI internal combustion engines that meet the requirements of this subpart, but are not certified to the standards applicable to nonroad (including marine) engines of the same model year and HP must be labeled according to the provisions in 40 CFR parts 89, 94, 1039 or 1042, as appropriate, but the words "stationary" must be included instead of "nonroad" or "marine" on the label. In addition, such engines must be labeled according to 40 CFR 1039.20.

(iii) Stationary CI internal combustion engines that do not meet the requirements of this subpart must be labeled according to 40 CFR 1068.230 and must be exported under the provisions of 40 CFR 1068.230.

(d) An engine manufacturer certifying an engine family or families to standards under this subpart that are identical to standards applicable under 40 CFR parts 89, 94, 1039 or 1042 for that model year may certify any such family that contains both nonroad (including marine) and stationary engines as a single engine family and/or may include any such family containing stationary engines in the averaging, banking and trading provisions applicable for such engines under those parts.

(e) Manufacturers of engine families discussed in paragraph (d) of this section may meet the labeling requirements referred to in paragraph (c) of this section for stationary CI ICE by either adding a separate label containing the information required in paragraph (c) of this section or by adding the words “and stationary” after the word “nonroad” or “marine,” as appropriate, to the label.

(f) Starting with the model years shown in table 5 to this subpart, stationary CI internal combustion engine manufacturers must add a permanent label stating that the engine is for stationary emergency use only to each new emergency stationary CI internal combustion engine greater than or equal to 19 KW (25 HP) that meets all the emission standards for emergency engines in §60.4202 but does not meet all the emission standards for non-emergency engines in §60.4201. The label must be added according to the labeling requirements specified in 40 CFR 1039.135(b). Engine manufacturers must specify in the owner's manual that operation of emergency engines is limited to emergency operations and required maintenance and testing.

(g) Manufacturers of fire pump engines may use the test cycle in table 6 to this subpart for testing fire pump engines and may test at the NFPA certified nameplate HP, provided that the engine is labeled as “Fire Pump Applications Only”.

(h) Engine manufacturers, including importers, may introduce into commerce uncertified engines or engines certified to earlier standards that were manufactured before the new or changed standards took effect until inventories are depleted, as long as such engines are part of normal inventory. For example, if the engine manufacturers' normal industry practice is to keep on hand a one-month supply of engines based on its projected sales, and a new tier of standards starts to apply for the 2009 model year, the engine manufacturer may manufacture engines based on the normal inventory requirements late in the 2008 model year, and sell those engines for installation. The engine manufacturer may not circumvent the provisions of §§60.4201 or 60.4202 by stockpiling engines that are built before new or changed standards take effect. Stockpiling of such engines beyond normal industry practice is a violation of this subpart.

(i) The replacement engine provisions of 40 CFR 89.1003(b)(7), 40 CFR 94.1103(b)(3), 40 CFR 94.1103(b)(4) and 40 CFR 1068.240 are applicable to stationary CI engines replacing existing equipment that is less than 15 years old.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37969, June 28, 2011]

**§ 60.4211 What are my compliance requirements if I am an owner or operator of a stationary CI internal combustion engine?**

(a) If you are an owner or operator and must comply with the emission standards specified in this subpart, you must do all of the following, except as permitted under paragraph (g) of this section:

(1) Operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's emission-related written instructions;

(2) Change only those emission-related settings that are permitted by the manufacturer; and

(3) Meet the requirements of 40 CFR parts 89, 94 and/or 1068, as they apply to you.

(b) If you are an owner or operator of a pre-2007 model year stationary CI internal combustion engine and must comply with the emission standards specified in §§60.4204(a) or 60.4205(a), or if you are an owner or operator of a CI fire pump engine that is manufactured prior to the model years in table 3 to this



subpart and must comply with the emission standards specified in §60.4205(c), you must demonstrate compliance according to one of the methods specified in paragraphs (b)(1) through (5) of this section.

(1) Purchasing an engine certified according to 40 CFR part 89 or 40 CFR part 94, as applicable, for the same model year and maximum engine power. The engine must be installed and configured according to the manufacturer's specifications.

(2) Keeping records of performance test results for each pollutant for a test conducted on a similar engine. The test must have been conducted using the same methods specified in this subpart and these methods must have been followed correctly.

(3) Keeping records of engine manufacturer data indicating compliance with the standards.

(4) Keeping records of control device vendor data indicating compliance with the standards.

(5) Conducting an initial performance test to demonstrate compliance with the emission standards according to the requirements specified in §60.4212, as applicable.

(c) If you are an owner or operator of a 2007 model year and later stationary CI internal combustion engine and must comply with the emission standards specified in §60.4204(b) or §60.4205(b), or if you are an owner or operator of a CI fire pump engine that is manufactured during or after the model year that applies to your fire pump engine power rating in table 3 to this subpart and must comply with the emission standards specified in §60.4205(c), you must comply by purchasing an engine certified to the emission standards in §60.4204(b), or §60.4205(b) or (c), as applicable, for the same model year and maximum (or in the case of fire pumps, NFPA nameplate) engine power. The engine must be installed and configured according to the manufacturer's emission-related specifications, except as permitted in paragraph (g) of this section.

(d) If you are an owner or operator and must comply with the emission standards specified in §60.4204(c) or §60.4205(d), you must demonstrate compliance according to the requirements specified in paragraphs (d)(1) through (3) of this section.

(1) Conducting an initial performance test to demonstrate initial compliance with the emission standards as specified in §60.4213.

(2) Establishing operating parameters to be monitored continuously to ensure the stationary internal combustion engine continues to meet the emission standards. The owner or operator must petition the Administrator for approval of operating parameters to be monitored continuously. The petition must include the information described in paragraphs (d)(2)(i) through (v) of this section.

(i) Identification of the specific parameters you propose to monitor continuously;

(ii) A discussion of the relationship between these parameters and NO<sub>x</sub> and PM emissions, identifying how the emissions of these pollutants change with changes in these parameters, and how limitations on these parameters will serve to limit NO<sub>x</sub> and PM emissions;

(iii) A discussion of how you will establish the upper and/or lower values for these parameters which will establish the limits on these parameters in the operating limitations;

(iv) A discussion identifying the methods and the instruments you will use to monitor these parameters, as well as the relative accuracy and precision of these methods and instruments; and

(v) A discussion identifying the frequency and methods for recalibrating the instruments you will use for monitoring these parameters.

(3) For non-emergency engines with a displacement of greater than or equal to 30 liters per cylinder, conducting annual performance tests to demonstrate continuous compliance with the emission standards as specified in §60.4213.

(e) If you are an owner or operator of a modified or reconstructed stationary CI internal combustion engine and must comply with the emission standards specified in §60.4204(e) or §60.4205(f), you must demonstrate compliance according to one of the methods specified in paragraphs (e)(1) or (2) of this section.

(1) Purchasing, or otherwise owning or operating, an engine certified to the emission standards in §60.4204(e) or §60.4205(f), as applicable.

(2) Conducting a performance test to demonstrate initial compliance with the emission standards according to the requirements specified in §60.4212 or §60.4213, as appropriate. The test must be conducted within 60 days after the engine commences operation after the modification or reconstruction.

(f) Emergency stationary ICE may be operated for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by Federal, State or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of such units is limited to 100 hours per year. There is no time limit on the use of emergency stationary ICE in emergency situations. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency ICE beyond 100 hours per year. Emergency stationary ICE may operate up to 50 hours per year in non-emergency situations, but those 50 hours are counted towards the 100 hours per year provided for maintenance and testing. The 50 hours per year for non-emergency situations cannot be used for peak shaving or to generate income for a facility to supply power to an electric grid or otherwise supply non-emergency power as part of a financial arrangement with another entity. For owners and operators of emergency engines, any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations for 50 hours per year, as permitted in this section, is prohibited.

(g) If you do not install, configure, operate, and maintain your engine and control device according to the manufacturer's emission-related written instructions, or you change emission-related settings in a way that is not permitted by the manufacturer, you must demonstrate compliance as follows:

(1) If you are an owner or operator of a stationary CI internal combustion engine with maximum engine power less than 100 HP, you must keep a maintenance plan and records of conducted maintenance to demonstrate compliance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, if you do not install and configure the engine and control device according to the manufacturer's emission-related written instructions, or you change the emission-related settings in a way that is not permitted by the manufacturer, you must conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year of such action.

(2) If you are an owner or operator of a stationary CI internal combustion engine greater than or equal to 100 HP and less than or equal to 500 HP, you must keep a maintenance plan and records of conducted maintenance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, you must conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year of startup, or within 1 year after an engine and control device is no longer installed, configured, operated, and maintained in accordance with the manufacturer's emission-related written instructions, or within 1 year after you change emission-related settings in a way that is not permitted by the manufacturer.

(3) If you are an owner or operator of a stationary CI internal combustion engine greater than 500 HP, you must keep a maintenance plan and records of conducted maintenance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, you must conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year of startup, or within 1 year after an engine and control device is no longer installed, configured, operated, and maintained in accordance with the manufacturer's emission-related written instructions, or within 1 year after you

change emission-related settings in a way that is not permitted by the manufacturer. You must conduct subsequent performance testing every 8,760 hours of engine operation or 3 years, whichever comes first, thereafter to demonstrate compliance with the applicable emission standards.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37970, June 28, 2011]

### Testing Requirements for Owners and Operators

#### **§ 60.4212 What test methods and other procedures must I use if I am an owner or operator of a stationary CI internal combustion engine with a displacement of less than 30 liters per cylinder?**

Owners and operators of stationary CI ICE with a displacement of less than 30 liters per cylinder who conduct performance tests pursuant to this subpart must do so according to paragraphs (a) through (e) of this section.

(a) The performance test must be conducted according to the in-use testing procedures in 40 CFR part 1039, subpart F, for stationary CI ICE with a displacement of less than 10 liters per cylinder, and according to 40 CFR part 1042, subpart F, for stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder.

(b) Exhaust emissions from stationary CI ICE that are complying with the emission standards for new CI engines in 40 CFR part 1039 must not exceed the not-to-exceed (NTE) standards for the same model year and maximum engine power as required in 40 CFR 1039.101(e) and 40 CFR 1039.102(g)(1), except as specified in 40 CFR 1039.104(d). This requirement starts when NTE requirements take effect for nonroad diesel engines under 40 CFR part 1039.

(c) Exhaust emissions from stationary CI ICE that are complying with the emission standards for new CI engines in 40 CFR 89.112 or 40 CFR 94.8, as applicable, must not exceed the NTE numerical requirements, rounded to the same number of decimal places as the applicable standard in 40 CFR 89.112 or 40 CFR 94.8, as applicable, determined from the following equation:

$$\text{NTE requirement for each pollutant} = (1.25) \times (\text{STD}) \quad (\text{Eq. 1})$$

Where:

STD = The standard specified for that pollutant in 40 CFR 89.112 or 40 CFR 94.8, as applicable.

Alternatively, stationary CI ICE that are complying with the emission standards for new CI engines in 40 CFR 89.112 or 40 CFR 94.8 may follow the testing procedures specified in §60.4213 of this subpart, as appropriate.

(d) Exhaust emissions from stationary CI ICE that are complying with the emission standards for pre-2007 model year engines in §60.4204(a), §60.4205(a), or §60.4205(c) must not exceed the NTE numerical requirements, rounded to the same number of decimal places as the applicable standard in §60.4204(a), §60.4205(a), or §60.4205(c), determined from the equation in paragraph (c) of this section.

Where:

STD = The standard specified for that pollutant in §60.4204(a), §60.4205(a), or §60.4205(c).

Alternatively, stationary CI ICE that are complying with the emission standards for pre-2007 model year engines in §60.4204(a), §60.4205(a), or §60.4205(c) may follow the testing procedures specified in §60.4213, as appropriate.

(e) Exhaust emissions from stationary CI ICE that are complying with the emission standards for new CI engines in 40 CFR part 1042 must not exceed the NTE standards for the same model year and maximum engine power as required in 40 CFR 1042.101(c).

[71 FR 39172, July 11, 2006, as amended at 76 FR 37971, June 28, 2011]

**§ 60.4213 What test methods and other procedures must I use if I am an owner or operator of a stationary CI internal combustion engine with a displacement of greater than or equal to 30 liters per cylinder?**

Owners and operators of stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder must conduct performance tests according to paragraphs (a) through (f) of this section.

(a) Each performance test must be conducted according to the requirements in §60.8 and under the specific conditions that this subpart specifies in table 7. The test must be conducted within 10 percent of 100 percent peak (or the highest achievable) load.

(b) You may not conduct performance tests during periods of startup, shutdown, or malfunction, as specified in §60.8(c).

(c) You must conduct three separate test runs for each performance test required in this section, as specified in §60.8(f). Each test run must last at least 1 hour.

(d) To determine compliance with the percent reduction requirement, you must follow the requirements as specified in paragraphs (d)(1) through (3) of this section.

(1) You must use Equation 2 of this section to determine compliance with the percent reduction requirement:

$$\frac{C_i - C_o}{C_i} \times 100 = R \quad (\text{Eq. 2})$$

Where:

$C_i$  = concentration of  $\text{NO}_x$  or PM at the control device inlet,

$C_o$  = concentration of  $\text{NO}_x$  or PM at the control device outlet, and

R = percent reduction of  $\text{NO}_x$  or PM emissions.

(2) You must normalize the  $\text{NO}_x$  or PM concentrations at the inlet and outlet of the control device to a dry basis and to 15 percent oxygen ( $\text{O}_2$ ) using Equation 3 of this section, or an equivalent percent carbon dioxide ( $\text{CO}_2$ ) using the procedures described in paragraph (d)(3) of this section.

$$C_{adj} = C_d \frac{5.9}{20.9 - \% \text{O}_2} \quad (\text{Eq. 3})$$

Where:

$C_{adj}$  = Calculated  $\text{NO}_x$  or PM concentration adjusted to 15 percent  $\text{O}_2$ .

$C_d$  = Measured concentration of  $\text{NO}_x$  or PM, uncorrected.

5.9 = 20.9 percent  $\text{O}_2$ –15 percent  $\text{O}_2$ , the defined  $\text{O}_2$  correction value, percent.

$\% \text{O}_2$  = Measured  $\text{O}_2$  concentration, dry basis, percent.

(3) If pollutant concentrations are to be corrected to 15 percent O<sub>2</sub> and CO<sub>2</sub> concentration is measured in lieu of O<sub>2</sub> concentration measurement, a CO<sub>2</sub> correction factor is needed. Calculate the CO<sub>2</sub> correction factor as described in paragraphs (d)(3)(i) through (iii) of this section.

(i) Calculate the fuel-specific F<sub>o</sub> value for the fuel burned during the test using values obtained from Method 19, Section 5.2, and the following equation:

$$F_o = \frac{0.209}{F_d} \quad (\text{Eq. 4})$$

Where:

F<sub>o</sub> = Fuel factor based on the ratio of O<sub>2</sub> volume to the ultimate CO<sub>2</sub> volume produced by the fuel at zero percent excess air.

0.209 = Fraction of air that is O<sub>2</sub>, percent/100.

F<sub>d</sub> = Ratio of the volume of dry effluent gas to the gross calorific value of the fuel from Method 19, dsm<sup>3</sup> / J (dscf/10<sup>6</sup> Btu).

F<sub>c</sub> = Ratio of the volume of CO<sub>2</sub> produced to the gross calorific value of the fuel from Method 19, dsm<sup>3</sup> / J (dscf/10<sup>6</sup> Btu).

(ii) Calculate the CO<sub>2</sub> correction factor for correcting measurement data to 15 percent O<sub>2</sub>, as follows:

$$X_{CO_2} = \frac{5.9}{F_o} \quad (\text{Eq. 5})$$

Where:

X<sub>CO<sub>2</sub></sub> = CO<sub>2</sub> correction factor, percent.

5.9 = 20.9 percent O<sub>2</sub> – 15 percent O<sub>2</sub>, the defined O<sub>2</sub> correction value, percent.

(iii) Calculate the NO<sub>x</sub> and PM gas concentrations adjusted to 15 percent O<sub>2</sub> using CO<sub>2</sub> as follows:

$$C_{adj} = C_d \frac{X_{CO_2}}{\%CO_2} \quad (\text{Eq. 6})$$

Where:

C<sub>adj</sub> = Calculated NO<sub>x</sub> or PM concentration adjusted to 15 percent O<sub>2</sub>.

C<sub>d</sub> = Measured concentration of NO<sub>x</sub> or PM, uncorrected.

%CO<sub>2</sub> = Measured CO<sub>2</sub> concentration, dry basis, percent.

(e) To determine compliance with the NO<sub>x</sub> mass per unit output emission limitation, convert the concentration of NO<sub>x</sub> in the engine exhaust using Equation 7 of this section:

$$ER = \frac{C_d \times 1.912 \times 10^{-3} \times Q \times T}{KW\text{-hour}} \quad (\text{Eq. 7})$$

Where:

ER = Emission rate in grams per KW-hour.

$C_d$  = Measured  $\text{NO}_x$  concentration in ppm.

$1.912 \times 10^{-3}$  = Conversion constant for ppm  $\text{NO}_x$  to grams per standard cubic meter at 25 degrees Celsius.

Q = Stack gas volumetric flow rate, in standard cubic meter per hour.

T = Time of test run, in hours.

KW-hour = Brake work of the engine, in KW-hour.

(f) To determine compliance with the PM mass per unit output emission limitation, convert the concentration of PM in the engine exhaust using Equation 8 of this section:

$$ER = \frac{C_{adj} \times Q \times T}{KW\text{-hour}} \quad (\text{Eq. 8})$$

Where:

ER = Emission rate in grams per KW-hour.

$C_{adj}$  = Calculated PM concentration in grams per standard cubic meter.

Q = Stack gas volumetric flow rate, in standard cubic meter per hour.

T = Time of test run, in hours.

KW-hour = Energy output of the engine, in KW.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37971, June 28, 2011]

## Notification, Reports, and Records for Owners and Operators

### **§ 60.4214 What are my notification, reporting, and recordkeeping requirements if I am an owner or operator of a stationary CI internal combustion engine?**

(a) Owners and operators of non-emergency stationary CI ICE that are greater than 2,237 KW (3,000 HP), or have a displacement of greater than or equal to 10 liters per cylinder, or are pre-2007 model year engines that are greater than 130 KW (175 HP) and not certified, must meet the requirements of paragraphs (a)(1) and (2) of this section.

(1) Submit an initial notification as required in §60.7(a)(1). The notification must include the information in paragraphs (a)(1)(i) through (v) of this section.

(i) Name and address of the owner or operator;

(ii) The address of the affected source;

(iii) Engine information including make, model, engine family, serial number, model year, maximum engine power, and engine displacement;

(iv) Emission control equipment; and

(v) Fuel used.

(2) Keep records of the information in paragraphs (a)(2)(i) through (iv) of this section.

(i) All notifications submitted to comply with this subpart and all documentation supporting any notification.

(ii) Maintenance conducted on the engine.

(iii) If the stationary CI internal combustion is a certified engine, documentation from the manufacturer that the engine is certified to meet the emission standards.

(iv) If the stationary CI internal combustion is not a certified engine, documentation that the engine meets the emission standards.

(b) If the stationary CI internal combustion engine is an emergency stationary internal combustion engine, the owner or operator is not required to submit an initial notification. Starting with the model years in table 5 to this subpart, if the emergency engine does not meet the standards applicable to non-emergency engines in the applicable model year, the owner or operator must keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time.

(c) If the stationary CI internal combustion engine is equipped with a diesel particulate filter, the owner or operator must keep records of any corrective action taken after the backpressure monitor has notified the owner or operator that the high backpressure limit of the engine is approached.

### Special Requirements

#### **§ 60.4215 What requirements must I meet for engines used in Guam, American Samoa, or the Commonwealth of the Northern Mariana Islands?**

(a) Stationary CI ICE with a displacement of less than 30 liters per cylinder that are used in Guam, American Samoa, or the Commonwealth of the Northern Mariana Islands are required to meet the applicable emission standards in §§60.4202 and 60.4205.

(b) Stationary CI ICE that are used in Guam, American Samoa, or the Commonwealth of the Northern Mariana Islands are not required to meet the fuel requirements in §60.4207.

(c) Stationary CI ICE with a displacement of greater than or equal to 30 liters per cylinder that are used in Guam, American Samoa, or the Commonwealth of the Northern Mariana Islands are required to meet the following emission standards:

(1) For engines installed prior to January 1, 2012, limit the emissions of  $\text{NO}_x$  in the stationary CI internal combustion engine exhaust to the following:

(i) 17.0 g/KW-hr (12.7 g/HP-hr) when maximum engine speed is less than 130 rpm;

(ii)  $45 \cdot n^{-0.2}$  g/KW-hr ( $34 \cdot n^{-0.2}$  g/HP-hr) when maximum engine speed is 130 or more but less than 2,000 rpm, where n is maximum engine speed; and

(iii) 9.8 g/KW-hr (7.3 g/HP-hr) when maximum engine speed is 2,000 rpm or more.

(2) For engines installed on or after January 1, 2012, limit the emissions of  $\text{NO}_x$  in the stationary CI internal combustion engine exhaust to the following:

(i) 14.4 g/KW-hr (10.7 g/HP-hr) when maximum engine speed is less than 130 rpm;

(ii)  $44 \cdot n^{-0.23}$  g/KW-hr ( $33 \cdot n^{-0.23}$  g/HP-hr) when maximum engine speed is greater than or equal to 130 but less than 2,000 rpm and where n is maximum engine speed; and

(iii) 7.7 g/KW-hr (5.7 g/HP-hr) when maximum engine speed is greater than or equal to 2,000 rpm.

(3) Limit the emissions of PM in the stationary CI internal combustion engine exhaust to 0.40 g/KW-hr (0.30 g/HP-hr).

[71 FR 39172, July 11, 2006, as amended at 76 FR 37971, June 28, 2011]

**§ 60.4216 What requirements must I meet for engines used in Alaska?**

(a) Prior to December 1, 2010, owners and operators of stationary CI ICE with a displacement of less than 30 liters per cylinder located in areas of Alaska not accessible by the FAHS should refer to 40 CFR part 69 to determine the diesel fuel requirements applicable to such engines.

(b) Except as indicated in paragraph (c) of this section, manufacturers, owners and operators of stationary CI ICE with a displacement of less than 10 liters per cylinder located in areas of Alaska not accessible by the FAHS may meet the requirements of this subpart by manufacturing and installing engines meeting the requirements of 40 CFR parts 94 or 1042, as appropriate, rather than the otherwise applicable requirements of 40 CFR parts 89 and 1039, as indicated in sections §60.4201(f) and 60.4202(g) of this subpart.

(c) Manufacturers, owners and operators of stationary CI ICE that are located in areas of Alaska not accessible by the FAHS may choose to meet the applicable emission standards for emergency engines in §60.4202 and §60.4205, and not those for non-emergency engines in §60.4201 and §60.4204, except that for 2014 model year and later non-emergency CI ICE, the owner or operator of any such engine that was not certified as meeting Tier 4 PM standards, must meet the applicable requirements for PM in §60.4201 and §60.4204 or install a PM emission control device that achieves PM emission reductions of 85 percent, or 60 percent for engines with a displacement of greater than or equal to 30 liters per cylinder, compared to engine-out emissions.

(d) The provisions of §60.4207 do not apply to owners and operators of pre-2014 model year stationary CI ICE subject to this subpart that are located in areas of Alaska not accessible by the FAHS.

(e) The provisions of §60.4208(a) do not apply to owners and operators of stationary CI ICE subject to this subpart that are located in areas of Alaska not accessible by the FAHS until after December 31, 2009.

(f) The provisions of this section and §60.4207 do not prevent owners and operators of stationary CI ICE subject to this subpart that are located in areas of Alaska not accessible by the FAHS from using fuels mixed with used lubricating oil, in volumes of up to 1.75 percent of the total fuel. The sulfur content of the used lubricating oil must be less than 200 parts per million. The used lubricating oil must meet the on-specification levels and properties for used oil in 40 CFR 279.11.

[76 FR 37971, June 28, 2011]

**§ 60.4217 What emission standards must I meet if I am an owner or operator of a stationary internal combustion engine using special fuels?**

Owners and operators of stationary CI ICE that do not use diesel fuel may petition the Administrator for approval of alternative emission standards, if they can demonstrate that they use a fuel that is not the fuel on which the manufacturer of the engine certified the engine and that the engine cannot meet the applicable standards required in §60.4204 or §60.4205 using such fuels and that use of such fuel is appropriate and reasonably necessary, considering cost, energy, technical feasibility, human health and environmental, and other factors, for the operation of the engine.

[76 FR 37972, June 28, 2011]



## General Provisions

### § 60.4218 What parts of the General Provisions apply to me?

Table 8 to this subpart shows which parts of the General Provisions in §§60.1 through 60.19 apply to you.

#### Definitions

### § 60.4219 What definitions apply to this subpart?

As used in this subpart, all terms not defined herein shall have the meaning given them in the CAA and in subpart A of this part.

*Certified emissions life* means the period during which the engine is designed to properly function in terms of reliability and fuel consumption, without being remanufactured, specified as a number of hours of operation or calendar years, whichever comes first. The values for certified emissions life for stationary CI ICE with a displacement of less than 10 liters per cylinder are given in 40 CFR 1039.101(g). The values for certified emissions life for stationary CI ICE with a displacement of greater than or equal to 10 liters per cylinder and less than 30 liters per cylinder are given in 40 CFR 94.9(a).

*Combustion turbine* means all equipment, including but not limited to the turbine, the fuel, air, lubrication and exhaust gas systems, control systems (except emissions control equipment), and any ancillary components and sub-components comprising any simple cycle combustion turbine, any regenerative/recuperative cycle combustion turbine, the combustion turbine portion of any cogeneration cycle combustion system, or the combustion turbine portion of any combined cycle steam/electric generating system.

*Compression ignition* means relating to a type of stationary internal combustion engine that is not a spark ignition engine.

*Date of manufacture* means one of the following things:

- (1) For freshly manufactured engines and modified engines, date of manufacture means the date the engine is originally produced.
- (2) For reconstructed engines, date of manufacture means the date the engine was originally produced, except as specified in paragraph (3) of this definition.
- (3) Reconstructed engines are assigned a new date of manufacture if the fixed capital cost of the new and refurbished components exceeds 75 percent of the fixed capital cost of a comparable entirely new facility. An engine that is produced from a previously used engine block does not retain the date of manufacture of the engine in which the engine block was previously used if the engine is produced using all new components except for the engine block. In these cases, the date of manufacture is the date of reconstruction or the date the new engine is produced.

*Diesel fuel* means any liquid obtained from the distillation of petroleum with a boiling point of approximately 150 to 360 degrees Celsius. One commonly used form is number 2 distillate oil.

*Diesel particulate filter* means an emission control technology that reduces PM emissions by trapping the particles in a flow filter substrate and periodically removes the collected particles by either physical action or by oxidizing (burning off) the particles in a process called regeneration.

*Emergency stationary internal combustion engine* means any stationary internal combustion engine whose operation is limited to emergency situations and required testing and maintenance. Examples include stationary ICE used to produce power for critical networks or equipment (including power supplied to portions of a facility) when electric power from the local utility (or the normal power source, if the facility

runs on its own power production) is interrupted, or stationary ICE used to pump water in the case of fire or flood, etc. Stationary CI ICE used to supply power to an electric grid or that supply power as part of a financial arrangement with another entity are not considered to be emergency engines.

*Engine manufacturer* means the manufacturer of the engine. See the definition of “manufacturer” in this section.

*Fire pump engine* means an emergency stationary internal combustion engine certified to NFPA requirements that is used to provide power to pump water for fire suppression or protection.

*Freshly manufactured engine* means an engine that has not been placed into service. An engine becomes freshly manufactured when it is originally produced.

*Installed* means the engine is placed and secured at the location where it is intended to be operated.

*Manufacturer* has the meaning given in section 216(1) of the Act. In general, this term includes any person who manufactures a stationary engine for sale in the United States or otherwise introduces a new stationary engine into commerce in the United States. This includes importers who import stationary engines for sale or resale.

*Maximum engine power* means maximum engine power as defined in 40 CFR 1039.801.

*Model year* means the calendar year in which an engine is manufactured (see “date of manufacture”), except as follows:

(1) Model year means the annual new model production period of the engine manufacturer in which an engine is manufactured (see “date of manufacture”), if the annual new model production period is different than the calendar year and includes January 1 of the calendar year for which the model year is named. It may not begin before January 2 of the previous calendar year and it must end by December 31 of the named calendar year.

(2) For an engine that is converted to a stationary engine after being placed into service as a nonroad or other non-stationary engine, model year means the calendar year or new model production period in which the engine was manufactured (see “date of manufacture”).

*Other internal combustion engine* means any internal combustion engine, except combustion turbines, which is not a reciprocating internal combustion engine or rotary internal combustion engine.

*Reciprocating internal combustion engine* means any internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work.

*Rotary internal combustion engine* means any internal combustion engine which uses rotary motion to convert heat energy into mechanical work.

*Spark ignition* means relating to a gasoline, natural gas, or liquefied petroleum gas fueled engine or any other type of engine with a spark plug (or other sparking device) and with operating characteristics significantly similar to the theoretical Otto combustion cycle. Spark ignition engines usually use a throttle to regulate intake air flow to control power during normal operation. Dual-fuel engines in which a liquid fuel (typically diesel fuel) is used for CI and gaseous fuel (typically natural gas) is used as the primary fuel at an annual average ratio of less than 2 parts diesel fuel to 100 parts total fuel on an energy equivalent basis are spark ignition engines.

*Stationary internal combustion engine* means any internal combustion engine, except combustion turbines, that converts heat energy into mechanical work and is not mobile. Stationary ICE differ from mobile ICE in that a stationary internal combustion engine is not a nonroad engine as defined at 40 CFR 1068.30 (excluding paragraph (2)(ii) of that definition), and is not used to propel a motor vehicle, aircraft, or a vehicle used solely for competition. Stationary ICE include reciprocating ICE, rotary ICE, and other ICE, except combustion turbines.

*Subpart* means 40 CFR part 60, subpart IIII.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37972, June 28, 2011]

**Table 1 to Subpart IIII of Part 60—Emission Standards for Stationary Pre-2007 Model Year Engines With a Displacement of <10 Liters per Cylinder and 2007–2010 Model Year Engines >2,237 KW (3,000 HP) and With a Displacement of <10 Liters per Cylinder**

[As stated in §§60.4201(b), 60.4202(b), 60.4204(a), and 60.4205(a), you must comply with the following emission standards]

| Maximum engine power       | Emission standards for stationary pre-2007 model year engines with a displacement of <10 liters per cylinder and 2007–2010 model year engines >2,237 KW (3,000 HP) and with a displacement of <10 liters per cylinder in g/KW-hr (g/HP-hr) |           |                 |            |             |
|----------------------------|--|-----------|-----------------|------------|-------------|
|                            | NMHC + NO <sub>x</sub>   | HC        | NO <sub>x</sub> | CO         | PM          |
| KW<8 (HP<11)               | 10.5 (7.8)   |           |                 | 8.0 (6.0)  | 1.0 (0.75)  |
| 8≤KW<19<br>(11≤HP<25)      | 9.5 (7.1)  |           |                 | 6.6 (4.9)  | 0.80 (0.60) |
| 19≤KW<37<br>(25≤HP<50)     | 9.5 (7.1)  |           |                 | 5.5 (4.1)  | 0.80 (0.60) |
| 37≤KW<56<br>(50≤HP<75)     |  |           | 9.2 (6.9)       |            |             |
| 56≤KW<75<br>(75≤HP<100)    |  |           | 9.2 (6.9)       |            |             |
| 75≤KW<130<br>(100≤HP<175)  |  |           | 9.2 (6.9)       |            |             |
| 130≤KW<225<br>(175≤HP<300) |  | 1.3 (1.0) | 9.2 (6.9)       | 11.4 (8.5) | 0.54 (0.40) |
| 225≤KW<450<br>(300≤HP<600) |  | 1.3 (1.0) | 9.2 (6.9)       | 11.4 (8.5) | 0.54 (0.40) |
| 450≤KW≤560<br>(600≤HP≤750) |  | 1.3 (1.0) | 9.2 (6.9)       | 11.4 (8.5) | 0.54 (0.40) |
| KW>560<br>(HP>750)         |  | 1.3 (1.0) | 9.2 (6.9)       | 11.4 (8.5) | 0.54 (0.40) |

**Table 2 to Subpart IIII of Part 60—Emission Standards for 2008 Model Year and Later Emergency Stationary CI ICE <37 KW (50 HP) With a Displacement of <10 Liters per Cylinder**

[As stated in §60.4202(a)(1), you must comply with the following emission standards]

| Engine power           | Emission standards for 2008 model year and later emergency stationary CI ICE <37 KW (50 HP) with a displacement of <10 liters per cylinder in g/KW-hr (g/HP-hr) |                        |           |             |
|------------------------|---|------------------------|-----------|-------------|
|                        | Model year(s)   | NO <sub>x</sub> + NMHC | CO        | PM          |
| KW<8 (HP<11)           | 2008+   | 7.5 (5.6)              | 8.0 (6.0) | 0.40 (0.30) |
| 8≤KW<19<br>(11≤HP<25)  | 2008+   | 7.5 (5.6)              | 6.6 (4.9) | 0.40 (0.30) |
| 19≤KW<37<br>(25≤HP<50) | 2008+   | 7.5 (5.6)              | 5.5 (4.1) | 0.30 (0.22) |

**Table 3 to Subpart IIII of Part 60—Certification Requirements for Stationary Fire Pump Engines**

**Table 3 to Subpart IIII of Part 60—Certification Requirements for Stationary Fire Pump Engines**

As stated in §60.4202(d), you must certify new stationary fire pump engines beginning with the following model years:

| Engine power               | Starting model year engine manufacturers must certify new stationary fire pump engines according to §60.4202(d) <sup>1</sup> |
|----------------------------|--|
| KW<75<br>(HP<100)          | 2011   |
| 75≤KW<130<br>(100≤HP<175)  | 2010   |
| 130≤KW≤560<br>(175≤HP≤750) | 2009   |
| KW>560<br>(HP>750)         | 2008   |

<sup>1</sup>Manufacturers of fire pump stationary CI ICE with a maximum engine power greater than or equal to 37 kW (50 HP) and less than 450 KW (600 HP) and a rated speed of greater than 2,650 revolutions per minute (rpm) are not required to certify such engines until three model years following the model year indicated in this Table 3 for engines in the applicable engine power category.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37972, June 28, 2011]

**Table 4 to Subpart IIII of Part 60—Emission Standards for Stationary Fire Pump Engines**

[As stated in §§60.4202(d) and 60.4205(c), you must comply with the following emission standards for stationary fire pump engines]

| Maximum engine power    | Model year(s)      | NMHC + NO <sub>x</sub> | CO        | PM          |
|-------------------------|--------------------|------------------------|-----------|-------------|
| KW<8 (HP<11)            | 2010 and earlier   | 10.5 (7.8)             | 8.0 (6.0) | 1.0 (0.75)  |
|                         | 2011+              | 7.5 (5.6)              |           | 0.40 (0.30) |
| 8≤KW<19 (11≤HP<25)      | 2010 and earlier   | 9.5 (7.1)              | 6.6 (4.9) | 0.80 (0.60) |
|                         | 2011+              | 7.5 (5.6)              |           | 0.40 (0.30) |
| 19≤KW<37 (25≤HP<50)     | 2010 and earlier   | 9.5 (7.1)              | 5.5 (4.1) | 0.80 (0.60) |
|                         | 2011+              | 7.5 (5.6)              |           | 0.30 (0.22) |
| 37≤KW<56 (50≤HP<75)     | 2010 and earlier   | 10.5 (7.8)             | 5.0 (3.7) | 0.80 (0.60) |
|                         | 2011+ <sup>1</sup> | 4.7 (3.5)              |           | 0.40 (0.30) |
| 56≤KW<75 (75≤HP<100)    | 2010 and earlier   | 10.5 (7.8)             | 5.0 (3.7) | 0.80 (0.60) |
|                         | 2011+ <sup>1</sup> | 4.7 (3.5)              |           | 0.40 (0.30) |
| 75≤KW<130 (100≤HP<175)  | 2009 and earlier   | 10.5 (7.8)             | 5.0 (3.7) | 0.80 (0.60) |
|                         | 2010+ <sup>2</sup> | 4.0 (3.0)              |           | 0.30 (0.22) |
| 130≤KW<225 (175≤HP<300) | 2008 and earlier   | 10.5 (7.8)             | 3.5 (2.6) | 0.54 (0.40) |
|                         | 2009+ <sup>3</sup> | 4.0 (3.0)              |           | 0.20 (0.15) |
| 225≤KW<450 (300≤HP<600) | 2008 and earlier   | 10.5 (7.8)             | 3.5 (2.6) | 0.54 (0.40) |
|                         | 2009+ <sup>3</sup> | 4.0 (3.0)              |           | 0.20 (0.15) |
| 450≤KW≤560 (600≤HP≤750) | 2008 and earlier   | 10.5 (7.8)             | 3.5 (2.6) | 0.54 (0.40) |
|                         | 2009+              | 4.0 (3.0)              |           | 0.20 (0.15) |
| KW>560 (HP>750)         | 2007 and earlier   | 10.5 (7.8)             | 3.5 (2.6) | 0.54 (0.40) |
|                         | 2008+              | 6.4 (4.8)              |           | 0.20 (0.15) |

<sup>1</sup>For model years 2011–2013, manufacturers, owners and operators of fire pump stationary CI ICE in this engine power category with a rated speed of greater than 2,650 revolutions per minute (rpm) may comply with the emission limitations for 2010 model year engines.

<sup>2</sup>For model years 2010–2012, manufacturers, owners and operators of fire pump stationary CI ICE in this engine power category with a rated speed of greater than 2,650 rpm may comply with the emission limitations for 2009 model year engines.

<sup>3</sup>In model years 2009–2011, manufacturers of fire pump stationary CI ICE in this engine power category with a rated speed of greater than 2,650 rpm may comply with the emission limitations for 2008 model year engines.

**Table 5 to Subpart IIII of Part 60—Labeling and Recordkeeping Requirements for New Stationary Emergency Engines**

[You must comply with the labeling requirements in §60.4210(f) and the recordkeeping requirements in §60.4214(b) for new emergency stationary CI ICE beginning in the following model years:]

| Engine power          | Starting model year |
|-----------------------|---------------------|
| 19≤KW<56 (25≤HP<75)   | 2013                |
| 56≤KW<130 (75≤HP<175) | 2012                |
| KW≥130 (HP≥175)       | 2011                |

**Table 6 to Subpart IIII of Part 60—Optional 3-Mode Test Cycle for Stationary Fire Pump Engines**

[As stated in §60.4210(g), manufacturers of fire pump engines may use the following test cycle for testing fire pump engines:]

| Mode No. | Engine speed <sup>1</sup> | Torque (percent) <sup>2</sup> | Weighting factors |
|----------|---------------------------|-------------------------------|-------------------|
| 1        | Rated                     | 100                           | 0.30              |
| 2        | Rated                     | 75                            | 0.50              |
| 3        | Rated                     | 50                            | 0.20              |

<sup>1</sup>Engine speed: ±2 percent of point.

<sup>2</sup>Torque: NFPA certified nameplate HP for 100 percent point. All points should be ±2 percent of engine percent load value.

**Table 7 to Subpart IIII of Part 60—Requirements for Performance Tests for Stationary CI ICE With a Displacement of ≥30 Liters per Cylinder**

[As stated in §60.4213, you must comply with the following requirements for performance tests for stationary CI ICE with a displacement of ≥30 liters per cylinder:]

| For each   | Complying with the requirement to                         | You must  | Using   | According to the following requirements   |
|--|---|---|---|---|
| 1. Stationary CI internal combustion engine with a displacement of ≥30 liters per cylinder | a. Reduce NO <sub>x</sub> emissions by 90 percent or more | i. Select the sampling port location and the number of traverse points;   | (1) Method 1 or 1A of 40 CFR part 60, appendix A      | (a) Sampling sites must be located at the inlet and outlet of the control device.   |
|  |   | ii. Measure O <sub>2</sub> at the inlet and outlet of the control device; | (2) Method 3, 3A, or 3B of 40 CFR part 60, appendix A | (b) Measurements to determine O <sub>2</sub> concentration must be made at the same time as the measurements for NO <sub>x</sub> concentration. |

| For each | Complying with the requirement to  | You must  | Using  | According to the following requirements   |
|----------|--|---|--|---|
|          |  | iii. If necessary, measure moisture content at the inlet and outlet of the control device; and,   | (3) Method 4 of 40 CFR part 60, appendix A, Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348–03 (incorporated by reference, see §60.17)  | (c) Measurements to determine moisture content must be made at the same time as the measurements for NO <sub>x</sub> concentration.                                 |
|          |  | iv. Measure NO <sub>x</sub> at the inlet and outlet of the control device   | (4) Method 7E of 40 CFR part 60, appendix A, Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348–03 (incorporated by reference, see §60.17) | (d) NO <sub>x</sub> concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs. |
|          | b. Limit the concentration of NO <sub>x</sub> in the stationary CI internal combustion engine exhaust. | i. Select the sampling port location and the number of traverse points;   | (1) Method 1 or 1A of 40 CFR part 60, appendix A   | (a) If using a control device, the sampling site must be located at the outlet of the control device.   |
|          |  | ii. Determine the O <sub>2</sub> concentration of the stationary internal combustion engine exhaust at the sampling port location; and, | (2) Method 3, 3A, or 3B of 40 CFR part 60, appendix A  | (b) Measurements to determine O <sub>2</sub> concentration must be made at the same time as the measurement for NO <sub>x</sub> concentration.                      |
|          |  | iii. If necessary, measure moisture content of the stationary internal combustion engine exhaust at the sampling port location; and,    | (3) Method 4 of 40 CFR part 60, appendix A, Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348–03 (incorporated by reference, see §60.17)  | (c) Measurements to determine moisture content must be made at the same time as the measurement for NO <sub>x</sub> concentration.                                  |
|          |  | iv. Measure NO <sub>x</sub> at the exhaust of the stationary internal combustion engine   | (4) Method 7E of 40 CFR part 60, appendix A, Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348–03 (incorporated by reference, see §60.17) | (d) NO <sub>x</sub> concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs. |
|          | c. Reduce PM emissions by 60 percent or more   | i. Select the sampling port location and the number of traverse points;   | (1) Method 1 or 1A of 40 CFR part 60, appendix A   | (a) Sampling sites must be located at the inlet and outlet of the control device.   |

| For each | Complying with the requirement to  | You must   | Using   | According to the following requirements  |
|----------|--|--|---|--|
|          |  | ii. Measure O <sub>2</sub> at the inlet and outlet of the control device;  | (2) Method 3, 3A, or 3B of 40 CFR part 60, appendix A | (b) Measurements to determine O <sub>2</sub> concentration must be made at the same time as the measurements for PM concentration.                     |
|          |  | iii. If necessary, measure moisture content at the inlet and outlet of the control device; and   | (3) Method 4 of 40 CFR part 60, appendix A            | (c) Measurements to determine and moisture content must be made at the same time as the measurements for PM concentration.                             |
|          |  | iv. Measure PM at the inlet and outlet of the control device   | (4) Method 5 of 40 CFR part 60, appendix A            | (d) PM concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs. |
|          | d. Limit the concentration of PM in the stationary CI internal combustion engine exhaust | i. Select the sampling port location and the number of traverse points;  | (1) Method 1 or 1A of 40 CFR part 60, appendix A      | (a) If using a control device, the sampling site must be located at the outlet of the control device.  |
|          |  | ii. Determine the O <sub>2</sub> concentration of the stationary internal combustion engine exhaust at the sampling port location; and | (2) Method 3, 3A, or 3B of 40 CFR part 60, appendix A | (b) Measurements to determine O <sub>2</sub> concentration must be made at the same time as the measurements for PM concentration.                     |
|          |  | iii. If necessary, measure moisture content of the stationary internal combustion engine exhaust at the sampling port location; and    | (3) Method 4 of 40 CFR part 60, appendix A            | (c) Measurements to determine moisture content must be made at the same time as the measurements for PM concentration.                                 |



| For each | Complying with the requirement to | You must   | Using                                      | According to the following requirements  |
|----------|-----------------------------------|--|--|--|
|          |                                   | iv. Measure PM at the exhaust of the stationary internal combustion engine | (4) Method 5 of 40 CFR part 60, appendix A | (d) PM concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs. |

**Table 8 to Subpart IIII of Part 60—Applicability of General Provisions to Subpart IIII**

[As stated in §60.4218, you must comply with the following applicable General Provisions:]

| General Provisions citation | Subject of citation                                    | Applies to subpart | Explanation   |
|-----------------------------|--|--------------------|---|
| §60.1                       | General applicability of the General Provisions        | Yes                |   |
| §60.2                       | Definitions  | Yes                | Additional terms defined in §60.4219.   |
| §60.3                       | Units and abbreviations                                | Yes                |   |
| §60.4                       | Address  | Yes                |   |
| §60.5                       | Determination of construction or modification          | Yes                |   |
| §60.6                       | Review of plans  | Yes                |   |
| §60.7                       | Notification and Recordkeeping                         | Yes                | Except that §60.7 only applies as specified in §60.4214(a).   |
| §60.8                       | Performance tests                                      | Yes                | Except that §60.8 only applies to stationary CI ICE with a displacement of (≥30 liters per cylinder and engines that are not certified. |
| §60.9                       | Availability of information                            | Yes                |   |
| §60.10                      | State Authority  | Yes                |   |
| §60.11                      | Compliance with standards and maintenance requirements | No                 | Requirements are specified in subpart IIII.   |
| §60.12                      | Circumvention  | Yes                |   |
| §60.13                      | Monitoring requirements                                | Yes                | Except that §60.13 only applies to stationary CI ICE with a displacement of (≥30 liters per cylinder.                                   |
| §60.14                      | Modification   | Yes                |   |
| §60.15                      | Reconstruction   | Yes                |   |
| §60.16                      | Priority list  | Yes                |   |
| §60.17                      | Incorporations by reference                            | Yes                |   |

| <b>General Provisions citation</b> | <b>Subject of citation</b>                      | <b>Applies to subpart</b> | <b>Explanation</b> |
|------------------------------------|---|---------------------------|--------------------|
| §60.18                             | General control device requirements             | No                        |                    |
| §60.19                             | General notification and reporting requirements | Yes                       |                    |

## **Attachment C**

### **Title 40: Protection of Environment**

#### **PART 63—NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS FOR SOURCE CATEGORIES**

##### **Subpart CCCCCC—National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Dispensing Facilities**

Source: 73 FR 1945, Jan. 10, 2008, unless otherwise noted.

#### **What This Subpart Covers**

##### **§ 63.11110 What is the purpose of this subpart?**

This subpart establishes national emission limitations and management practices for hazardous air pollutants (HAP) emitted from the loading of gasoline storage tanks at gasoline dispensing facilities (GDF). This subpart also establishes requirements to demonstrate compliance with the emission limitations and management practices.

##### **§ 63.11111 Am I subject to the requirements in this subpart?**

- (a) The affected source to which this subpart applies is each GDF that is located at an area source. The affected source includes each gasoline cargo tank during the delivery of product to a GDF and also includes each storage tank.
- (b) If your GDF has a monthly throughput of less than 10,000 gallons of gasoline, you must comply with the requirements in §63.11116.
- (c) If your GDF has a monthly throughput of 10,000 gallons of gasoline or more, you must comply with the requirements in §63.11117.
- (d) If your GDF has a monthly throughput of 100,000 gallons of gasoline or more, you must comply with the requirements in §63.11118.
- (e) An affected source shall, upon request by the Administrator, demonstrate that their monthly throughput is less than the 10,000-gallon or the 100,000-gallon threshold level, as applicable. For new or reconstructed affected sources, as specified in §63.11112(b) and (c), recordkeeping to document monthly throughput must begin upon startup of the affected source. For existing sources, as specified in §63.11112(d), recordkeeping to document monthly throughput must begin on January 10, 2008. For existing sources that are subject to this subpart only because they load gasoline into fuel tanks other than those in motor vehicles, as defined in §63.11132, recordkeeping to document monthly throughput must begin on January 24, 2011. Records required under this paragraph shall be kept for a period of 5 years.
- (f) If you are an owner or operator of affected sources, as defined in paragraph (a) of this section, you are not required to obtain a permit under 40 CFR part 70 or 40 CFR part 71 as a result of being subject to this subpart. However, you must still apply for and obtain a permit under 40 CFR part 70 or 40 CFR part 71 if you meet one or more of the applicability criteria found in 40 CFR 70.3(a) and (b) or 40 CFR 71.3(a) and (b).
- (g) The loading of aviation gasoline into storage tanks at airports, and the subsequent transfer of aviation gasoline within the airport, is not subject to this subpart.

(h) Monthly throughput is the total volume of gasoline loaded into, or dispensed from, all the gasoline storage tanks located at a single affected GDF. If an area source has two or more GDF at separate locations within the area source, each GDF is treated as a separate affected source.

(i) If your affected source's throughput ever exceeds an applicable throughput threshold, the affected source will remain subject to the requirements for sources above the threshold, even if the affected source throughput later falls below the applicable throughput threshold.

(j) The dispensing of gasoline from a fixed gasoline storage tank at a GDF into a portable gasoline tank for the on-site delivery and subsequent dispensing of the gasoline into the fuel tank of a motor vehicle or other gasoline-fueled engine or equipment used within the area source is only subject to §63.11116 of this subpart.

(k) For any affected source subject to the provisions of this subpart and another Federal rule, you may elect to comply only with the more stringent provisions of the applicable subparts. You must consider all provisions of the rules, including monitoring, recordkeeping, and reporting. You must identify the affected source and provisions with which you will comply in your Notification of Compliance Status required under §63.11124. You also must demonstrate in your Notification of Compliance Status that each provision with which you will comply is at least as stringent as the otherwise applicable requirements in this subpart. You are responsible for making accurate determinations concerning the more stringent provisions, and noncompliance with this rule is not excused if it is later determined that your determination was in error, and, as a result, you are violating this subpart. Compliance with this rule is your responsibility and the Notification of Compliance Status does not alter or affect that responsibility.

[73 FR 1945, Jan. 10, 2008, as amended at 76 FR 4181, Jan. 24, 2011]

#### **§ 63.11112 What parts of my affected source does this subpart cover?**

(a) The emission sources to which this subpart applies are gasoline storage tanks and associated equipment components in vapor or liquid gasoline service at new, reconstructed, or existing GDF that meet the criteria specified in §63.11111. Pressure/Vacuum vents on gasoline storage tanks and the equipment necessary to unload product from cargo tanks into the storage tanks at GDF are covered emission sources. The equipment used for the refueling of motor vehicles is not covered by this subpart.

(b) An affected source is a new affected source if you commenced construction on the affected source after November 9, 2006, and you meet the applicability criteria in §63.11111 at the time you commenced operation.

(c) An affected source is reconstructed if you meet the criteria for reconstruction as defined in §63.2.

(d) An affected source is an existing affected source if it is not new or reconstructed.

#### **§ 63.11113 When do I have to comply with this subpart?**

(a) If you have a new or reconstructed affected source, you must comply with this subpart according to paragraphs (a)(1) and (2) of this section, except as specified in paragraph (d) of this section.

(1) If you start up your affected source before January 10, 2008, you must comply with the standards in this subpart no later than January 10, 2008.

(2) If you start up your affected source after January 10, 2008, you must comply with the standards in this subpart upon startup of your affected source.

(b) If you have an existing affected source, you must comply with the standards in this subpart no later than January 10, 2011.

(c) If you have an existing affected source that becomes subject to the control requirements in this subpart because of an increase in the monthly throughput, as specified in §63.11111(c) or §63.11111(d), you must comply with the standards in this subpart no later than 3 years after the affected source becomes subject to the control requirements in this subpart.

(d) If you have a new or reconstructed affected source and you are complying with Table 1 to this subpart, you must comply according to paragraphs (d)(1) and (2) of this section.

(1) If you start up your affected source from November 9, 2006 to September 23, 2008, you must comply no later than September 23, 2008.

(2) If you start up your affected source after September 23, 2008, you must comply upon startup of your affected source.

(e) The initial compliance demonstration test required under §63.11120(a)(1) and (2) must be conducted as specified in paragraphs (e)(1) and (2) of this section.

(1) If you have a new or reconstructed affected source, you must conduct the initial compliance test upon installation of the complete vapor balance system.

(2) If you have an existing affected source, you must conduct the initial compliance test as specified in paragraphs (e)(2)(i) or (e)(2)(ii) of this section.

(i) For vapor balance systems installed on or before December 15, 2009, you must test no later than 180 days after the applicable compliance date specified in paragraphs (b) or (c) of this section.

(ii) For vapor balance systems installed after December 15, 2009, you must test upon installation of the complete vapor balance system.

(f) If your GDF is subject to the control requirements in this subpart only because it loads gasoline into fuel tanks other than those in motor vehicles, as defined in §63.11132, you must comply with the standards in this subpart as specified in paragraphs (f)(1) or (f)(2) of this section.

(1) If your GDF is an existing facility, you must comply by January 24, 2014.

(2) If your GDF is a new or reconstructed facility, you must comply by the dates specified in paragraphs (f)(2)(i) and (ii) of this section.

(i) If you start up your GDF after December 15, 2009, but before January 24, 2011, you must comply no later than January 24, 2011.

(ii) If you start up your GDF after January 24, 2011, you must comply upon startup of your GDF.

[73 FR 1945, Jan. 10, 2008, as amended at 73 FR 35944, June 25, 2008; 76 FR 4181, Jan. 24, 2011]

## **Emission Limitations and Management Practices**

### **§ 63.11115 What are my general duties to minimize emissions?**

Each owner or operator of an affected source under this subpart must comply with the requirements of paragraphs (a) and (b) of this section.

(a) You must, at all times, operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.

(b) You must keep applicable records and submit reports as specified in §63.11125(d) and §63.11126(b).

[76 FR 4182, Jan. 24, 2011]

**§ 63.11116 Requirements for facilities with monthly throughput of less than 10,000 gallons of gasoline.**

(a) You must not allow gasoline to be handled in a manner that would result in vapor releases to the atmosphere for extended periods of time. Measures to be taken include, but are not limited to, the following:

(1) Minimize gasoline spills;

(2) Clean up spills as expeditiously as practicable;

(3) Cover all open gasoline containers and all gasoline storage tank fill-pipes with a gasketed seal when not in use;

(4) Minimize gasoline sent to open waste collection systems that collect and transport gasoline to reclamation and recycling devices, such as oil/water separators.

(b) You are not required to submit notifications or reports as specified in §63.11125, §63.11126, or subpart A of this part, but you must have records available within 24 hours of a request by the Administrator to document your gasoline throughput.

(c) You must comply with the requirements of this subpart by the applicable dates specified in §63.11113.

(d) Portable gasoline containers that meet the requirements of 40 CFR part 59, subpart F, are considered acceptable for compliance with paragraph (a)(3) of this section.

[73 FR 1945, Jan. 10, 2008, as amended at 76 FR 4182, Jan. 24, 2011]

**§ 63.11117 Requirements for facilities with monthly throughput of 10,000 gallons of gasoline or more.**

(a) You must comply with the requirements in section §63.11116(a).

(b) Except as specified in paragraph (c) of this section, you must only load gasoline into storage tanks at your facility by utilizing submerged filling, as defined in §63.11132, and as specified in paragraphs (b)(1), (b)(2), or (b)(3) of this section. The applicable distances in paragraphs (b)(1) and (2) shall be measured from the point in the opening of the submerged fill pipe that is the greatest distance from the bottom of the storage tank.

(1) Submerged fill pipes installed on or before November 9, 2006, must be no more than 12 inches from the bottom of the tank.

(2) Submerged fill pipes installed after November 9, 2006, must be no more than 6 inches from the bottom of the tank.

(3) Submerged fill pipes not meeting the specifications of paragraphs (b)(1) or (b)(2) of this section are allowed if the owner or operator can demonstrate that the liquid level in the tank is always above the entire opening of the fill pipe. Documentation providing such demonstration must be made available for inspection by the Administrator's delegated representative during the course of a site visit.

(c) Gasoline storage tanks with a capacity of less than 250 gallons are not required to comply with the submerged fill requirements in paragraph (b) of this section, but must comply only with all of the requirements in §63.11116.

(d) You must have records available within 24 hours of a request by the Administrator to document your gasoline throughput.

(e) You must submit the applicable notifications as required under §63.11124(a).

(f) You must comply with the requirements of this subpart by the applicable dates contained in §63.11113.

[73 FR 1945, Jan. 10, 2008, as amended at 73 FR 12276, Mar. 7, 2008; 76 FR 4182, Jan. 24, 2011]

**§ 63.11118 Requirements for facilities with monthly throughput of 100,000 gallons of gasoline or more.**

(a) You must comply with the requirements in §§63.11116(a) and 63.11117(b).

(b) Except as provided in paragraph (c) of this section, you must meet the requirements in either paragraph (b)(1) or paragraph (b)(2) of this section.

(1) Each management practice in Table 1 to this subpart that applies to your GDF.

(2) If, prior to January 10, 2008, you satisfy the requirements in both paragraphs (b)(2)(i) and (ii) of this section, you will be deemed in compliance with this subsection.

(i) You operate a vapor balance system at your GDF that meets the requirements of either paragraph (b)(2)(i)(A) or paragraph (b)(2)(i)(B) of this section.

(A) Achieves emissions reduction of at least 90 percent.

(B) Operates using management practices at least as stringent as those in Table 1 to this subpart.

(ii) Your gasoline dispensing facility is in compliance with an enforceable State, local, or tribal rule or permit that contains requirements of either paragraph (b)(2)(i)(A) or paragraph (b)(2)(i)(B) of this section.

(c) The emission sources listed in paragraphs (c)(1) through (3) of this section are not required to comply with the control requirements in paragraph (b) of this section, but must comply with the requirements in §63.11117.

- (1) Gasoline storage tanks with a capacity of less than 250 gallons that are constructed after January 10, 2008.
- (2) Gasoline storage tanks with a capacity of less than 2,000 gallons that were constructed before January 10, 2008.
- (3) Gasoline storage tanks equipped with floating roofs, or the equivalent.
- (d) Cargo tanks unloading at GDF must comply with the management practices in Table 2 to this subpart.
- (e) You must comply with the applicable testing requirements contained in §63.11120.
- (f) You must submit the applicable notifications as required under §63.11124.
- (g) You must keep records and submit reports as specified in §§63.11125 and 63.11126.
- (h) You must comply with the requirements of this subpart by the applicable dates contained in §63.11113.

[73 FR 1945, Jan. 10, 2008, as amended at 73 FR 12276, Mar. 7, 2008]

## **Testing and Monitoring Requirements**

### **§ 63.11120 What testing and monitoring requirements must I meet?**

(a) Each owner or operator, at the time of installation, as specified in §63.11113(e), of a vapor balance system required under §63.11118(b)(1), and every 3 years thereafter, must comply with the requirements in paragraphs (a)(1) and (2) of this section.

(1) You must demonstrate compliance with the leak rate and cracking pressure requirements, specified in item 1(g) of Table 1 to this subpart, for pressure-vacuum vent valves installed on your gasoline storage tanks using the test methods identified in paragraph (a)(1)(i) or paragraph (a)(1)(ii) of this section.

(i) California Air Resources Board Vapor Recovery Test Procedure TP-201.1E,—Leak Rate and Cracking Pressure of Pressure/Vacuum Vent Valves, adopted October 8, 2003 (incorporated by reference, see §63.14).

(ii) Use alternative test methods and procedures in accordance with the alternative test method requirements in §63.7(f).

(2) You must demonstrate compliance with the static pressure performance requirement specified in item 1(h) of Table 1 to this subpart for your vapor balance system by conducting a static pressure test on your gasoline storage tanks using the test methods identified in paragraphs (a)(2)(i), (a)(2)(ii), or (a)(2)(iii) of this section.

(i) California Air Resources Board Vapor Recovery Test Procedure TP-201.3,—Determination of 2-Inch WC Static Pressure Performance of Vapor Recovery Systems of Dispensing Facilities, adopted April 12, 1996, and amended March 17, 1999 (incorporated by reference, see §63.14).

(ii) Use alternative test methods and procedures in accordance with the alternative test method requirements in §63.7(f).



(iii) Bay Area Air Quality Management District Source Test Procedure ST-30—Static Pressure Integrity Test—Underground Storage Tanks, adopted November 30, 1983, and amended December 21, 1994 (incorporated by reference, see §63.14).

(b) Each owner or operator choosing, under the provisions of §63.6(g), to use a vapor balance system other than that described in Table 1 to this subpart must demonstrate to the Administrator or delegated authority under paragraph §63.11131(a) of this subpart, the equivalency of their vapor balance system to that described in Table 1 to this subpart using the procedures specified in paragraphs (b)(1) through (3) of this section.

(1) You must demonstrate initial compliance by conducting an initial performance test on the vapor balance system to demonstrate that the vapor balance system achieves 95 percent reduction using the California Air Resources Board Vapor Recovery Test Procedure TP-201.1,—Volumetric Efficiency for Phase I Vapor Recovery Systems, adopted April 12, 1996, and amended February 1, 2001, and October 8, 2003, (incorporated by reference, see §63.14).

(2) You must, during the initial performance test required under paragraph (b)(1) of this section, determine and document alternative acceptable values for the leak rate and cracking pressure requirements specified in item 1(g) of Table 1 to this subpart and for the static pressure performance requirement in item 1(h) of Table 1 to this subpart.

(3) You must comply with the testing requirements specified in paragraph (a) of this section.

(c) Conduct of performance tests. Performance tests conducted for this subpart shall be conducted under such conditions as the Administrator specifies to the owner or operator based on representative performance ( *i.e.*, performance based on normal operating conditions) of the affected source. Upon request, the owner or operator shall make available to the Administrator such records as may be necessary to determine the conditions of performance tests.

(d) Owners and operators of gasoline cargo tanks subject to the provisions of Table 2 to this subpart must conduct annual certification testing according to the vapor tightness testing requirements found in §63.11092(f).

[73 FR 1945, Jan. 10, 2008, as amended at 76 FR 4182, Jan. 24, 2011]

## **Notifications, Records, and Reports**

### **§ 63.11124 What notifications must I submit and when?**

(a) Each owner or operator subject to the control requirements in §63.11117 must comply with paragraphs (a)(1) through (3) of this section.

(1) You must submit an Initial Notification that you are subject to this subpart by May 9, 2008, or at the time you become subject to the control requirements in §63.11117, unless you meet the requirements in paragraph (a)(3) of this section. If your affected source is subject to the control requirements in §63.11117 only because it loads gasoline into fuel tanks other than those in motor vehicles, as defined in §63.11132, you must submit the Initial Notification by May 24, 2011. The Initial Notification must contain the information specified in paragraphs (a)(1)(i) through (iii) of this section. The notification must be submitted to the applicable EPA Regional Office and delegated State authority as specified in §63.13.

(i) The name and address of the owner and the operator.

(ii) The address (*i.e.*, physical location) of the GDF.

(iii) A statement that the notification is being submitted in response to this subpart and identifying the requirements in paragraphs (a) through (c) of §63.11117 that apply to you.

(2) You must submit a Notification of Compliance Status to the applicable EPA Regional Office and the delegated State authority, as specified in §63.13, within 60 days of the applicable compliance date specified in §63.11113, unless you meet the requirements in paragraph (a)(3) of this section. The Notification of Compliance Status must be signed by a responsible official who must certify its accuracy, must indicate whether the source has complied with the requirements of this subpart, and must indicate whether the facilities' monthly throughput is calculated based on the volume of gasoline loaded into all storage tanks or on the volume of gasoline dispensed from all storage tanks. If your facility is in compliance with the requirements of this subpart at the time the Initial Notification required under paragraph (a)(1) of this section is due, the Notification of Compliance Status may be submitted in lieu of the Initial Notification provided it contains the information required under paragraph (a)(1) of this section.

(3) If, prior to January 10, 2008, you are operating in compliance with an enforceable State, local, or tribal rule or permit that requires submerged fill as specified in §63.11117(b), you are not required to submit an Initial Notification or a Notification of Compliance Status under paragraph (a)(1) or paragraph (a)(2) of this section.

(b) Each owner or operator subject to the control requirements in §63.11118 must comply with paragraphs (b)(1) through (5) of this section.

(1) You must submit an Initial Notification that you are subject to this subpart by May 9, 2008, or at the time you become subject to the control requirements in §63.11118. If your affected source is subject to the control requirements in §63.11118 only because it loads gasoline into fuel tanks other than those in motor vehicles, as defined in §63.11132, you must submit the Initial Notification by May 24, 2011. The Initial Notification must contain the information specified in paragraphs (b)(1)(i) through (iii) of this section. The notification must be submitted to the applicable EPA Regional Office and delegated State authority as specified in §63.13.

(i) The name and address of the owner and the operator.

(ii) The address (i.e., physical location) of the GDF.

(iii) A statement that the notification is being submitted in response to this subpart and identifying the requirements in paragraphs (a) through (c) of §63.11118 that apply to you.

(2) You must submit a Notification of Compliance Status to the applicable EPA Regional Office and the delegated State authority, as specified in §63.13, in accordance with the schedule specified in §63.9(h). The Notification of Compliance Status must be signed by a responsible official who must certify its accuracy, must indicate whether the source has complied with the requirements of this subpart, and must indicate whether the facility's throughput is determined based on the volume of gasoline loaded into all storage tanks or on the volume of gasoline dispensed from all storage tanks. If your facility is in compliance with the requirements of this subpart at the time the Initial Notification required under paragraph (b)(1) of this section is due, the Notification of Compliance Status may be submitted in lieu of the Initial Notification provided it contains the information required under paragraph (b)(1) of this section.

(3) If, prior to January 10, 2008, you satisfy the requirements in both paragraphs (b)(3)(i) and (ii) of this section, you are not required to submit an Initial Notification or a Notification of Compliance Status under paragraph (b)(1) or paragraph (b)(2) of this subsection.

(i) You operate a vapor balance system at your gasoline dispensing facility that meets the requirements of either paragraphs (b)(3)(i)(A) or (b)(3)(i)(B) of this section.

(A) Achieves emissions reduction of at least 90 percent.

(B) Operates using management practices at least as stringent as those in Table 1 to this subpart.

(ii) Your gasoline dispensing facility is in compliance with an enforceable State, local, or tribal rule or permit that contains requirements of either paragraphs (b)(3)(i)(A) or (b)(3)(i)(B) of this section.

(4) You must submit a Notification of Performance Test, as specified in §63.9(e), prior to initiating testing required by §63.11120(a) and (b).

(5) You must submit additional notifications specified in §63.9, as applicable.

[73 FR 1945, Jan. 10, 2008, as amended at 73 FR 12276, Mar. 7, 2008; 76 FR 4182, Jan. 24, 2011]

### **§ 63.11125 What are my recordkeeping requirements?**

(a) Each owner or operator subject to the management practices in §63.11118 must keep records of all tests performed under §63.11120(a) and (b).

(b) Records required under paragraph (a) of this section shall be kept for a period of 5 years and shall be made available for inspection by the Administrator's delegated representatives during the course of a site visit.

(c) Each owner or operator of a gasoline cargo tank subject to the management practices in Table 2 to this subpart must keep records documenting vapor tightness testing for a period of 5 years. Documentation must include each of the items specified in §63.11094(b)(2)(i) through (viii). Records of vapor tightness testing must be retained as specified in either paragraph (c)(1) or paragraph (c)(2) of this section.

(1) The owner or operator must keep all vapor tightness testing records with the cargo tank.

(2) As an alternative to keeping all records with the cargo tank, the owner or operator may comply with the requirements of paragraphs (c)(2)(i) and (ii) of this section.

(i) The owner or operator may keep records of only the most recent vapor tightness test with the cargo tank, and keep records for the previous 4 years at their office or another central location.

(ii) Vapor tightness testing records that are kept at a location other than with the cargo tank must be instantly available ( e.g., via e-mail or facsimile) to the Administrator's delegated representative during the course of a site visit or within a mutually agreeable time frame. Such records must be an exact duplicate image of the original paper copy record with certifying signatures.

(d) Each owner or operator of an affected source under this subpart shall keep records as specified in paragraphs (d)(1) and (2) of this section.

(1) Records of the occurrence and duration of each malfunction of operation ( i.e., process equipment) or the air pollution control and monitoring equipment.

(2) Records of actions taken during periods of malfunction to minimize emissions in accordance with §63.11115(a), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation.

[73 FR 1945, Jan. 10, 2008, as amended at 76 FR 4183, Jan. 24, 2011]

**§ 63.11126 What are my reporting requirements?**

(a) Each owner or operator subject to the management practices in §63.11118 shall report to the Administrator the results of all volumetric efficiency tests required under §63.11120(b). Reports submitted under this paragraph must be submitted within 180 days of the completion of the performance testing.

(b) Each owner or operator of an affected source under this subpart shall report, by March 15 of each year, the number, duration, and a brief description of each type of malfunction which occurred during the previous calendar year and which caused or may have caused any applicable emission limitation to be exceeded. The report must also include a description of actions taken by an owner or operator during a malfunction of an affected source to minimize emissions in accordance with §63.11115(a), including actions taken to correct a malfunction. No report is necessary for a calendar year in which no malfunctions occurred.

[76 FR 4183, Jan. 24, 2011]

**Other Requirements and Information**

**§ 63.11130 What parts of the General Provisions apply to me?**

Table 3 to this subpart shows which parts of the General Provisions apply to you.

**§ 63.11131 Who implements and enforces this subpart?**

(a) This subpart can be implemented and enforced by the U.S. EPA or a delegated authority such as the applicable State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to a State, local, or tribal agency, then that agency, in addition to the U.S. EPA, has the authority to implement and enforce this subpart. Contact the applicable U.S. EPA Regional Office to find out if implementation and enforcement of this subpart is delegated to a State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under subpart E of this part, the authorities contained in paragraph (c) of this section are retained by the Administrator of U.S. EPA and cannot be transferred to the State, local, or tribal agency.

(c) The authorities that cannot be delegated to State, local, or tribal agencies are as specified in paragraphs (c)(1) through (3) of this section.

(1) Approval of alternatives to the requirements in §§63.11116 through 63.11118 and 63.11120.

(2) Approval of major alternatives to test methods under §63.7(e)(2)(ii) and (f), as defined in §63.90, and as required in this subpart.

(3) Approval of major alternatives to recordkeeping and reporting under §63.10(f), as defined in §63.90, and as required in this subpart.

**§ 63.11132 What definitions apply to this subpart?**

As used in this subpart, all terms not defined herein shall have the meaning given them in the Clean Air Act (CAA), or in subparts A and BBBBBB of this part. For purposes of this subpart, definitions in this section supersede definitions in other parts or subparts.

*Dual-point vapor balance system* means a type of vapor balance system in which the storage tank is equipped with an entry port for a gasoline fill pipe and a separate exit port for a vapor connection.

*Gasoline* means any petroleum distillate or petroleum distillate/alcohol blend having a Reid vapor pressure of 27.6 kilopascals or greater, which is used as a fuel for internal combustion engines.

*Gasoline cargo tank* means a delivery tank truck or railcar which is loading or unloading gasoline, or which has loaded or unloaded gasoline on the immediately previous load.

*Gasoline dispensing facility (GDF)* means any stationary facility which dispenses gasoline into the fuel tank of a motor vehicle, motor vehicle engine, nonroad vehicle, or nonroad engine, including a nonroad vehicle or nonroad engine used solely for competition. These facilities include, but are not limited to, facilities that dispense gasoline into on- and off-road, street, or highway motor vehicles, lawn equipment, boats, test engines, landscaping equipment, generators, pumps, and other gasoline-fueled engines and equipment.

*Monthly throughput* means the total volume of gasoline that is loaded into, or dispensed from, all gasoline storage tanks at each GDF during a month. Monthly throughput is calculated by summing the volume of gasoline loaded into, or dispensed from, all gasoline storage tanks at each GDF during the current day, plus the total volume of gasoline loaded into, or dispensed from, all gasoline storage tanks at each GDF during the previous 364 days, and then dividing that sum by 12.

*Motor vehicle* means any self-propelled vehicle designed for transporting persons or property on a street or highway.

*Nonroad engine* means an internal combustion engine (including the fuel system) that is not used in a motor vehicle or a vehicle used solely for competition, or that is not subject to standards promulgated under section 7411 of this title or section 7521 of this title.

*Nonroad vehicle* means a vehicle that is powered by a nonroad engine, and that is not a motor vehicle or a vehicle used solely for competition.

*Submerged filling* means, for the purposes of this subpart, the filling of a gasoline storage tank through a submerged fill pipe whose discharge is no more than the applicable distance specified in §63.11117(b) from the bottom of the tank. Bottom filling of gasoline storage tanks is included in this definition.

*Vapor balance system* means a combination of pipes and hoses that create a closed system between the vapor spaces of an unloading gasoline cargo tank and a receiving storage tank such that vapors displaced from the storage tank are transferred to the gasoline cargo tank being unloaded.

*Vapor-tight* means equipment that allows no loss of vapors. Compliance with vapor-tight requirements can be determined by checking to ensure that the concentration at a potential leak source is not equal to or greater than 100 percent of the Lower Explosive Limit when measured with a combustible gas detector, calibrated with propane, at a distance of 1 inch from the source.

*Vapor-tight gasoline cargo tank* means a gasoline cargo tank which has demonstrated within the 12 preceding months that it meets the annual certification test requirements in §63.11092(f) of this part.

[73 FR 1945, Jan. 10, 2008, as amended at 76 FR 4183, Jan. 24, 2011]

**Table 1 to Subpart CCCCCC of Part 63—Applicability Criteria and Management Practices for Gasoline Dispensing Facilities With Monthly Throughput of 100,000 Gallons of Gasoline or More<sup>1</sup>**

| If you own or operate   | Then you must  |
|---|--|
| 1. A new, reconstructed, or existing GDF subject to §63.11118   | Install and operate a vapor balance system on your gasoline storage tanks that meets the design criteria in paragraphs (a) through (h).  |
|   | (a) All vapor connections and lines on the storage tank shall be equipped with closures that seal upon disconnect.   |
|   | (b) The vapor line from the gasoline storage tank to the gasoline cargo tank shall be vapor-tight, as defined in §63.11132.  |
|   | (c) The vapor balance system shall be designed such that the pressure in the tank truck does not exceed 18 inches water pressure or 5.9 inches water vacuum during product transfer.   |
|   | (d) The vapor recovery and product adaptors, and the method of connection with the delivery elbow, shall be designed so as to prevent the over-tightening or loosening of fittings during normal delivery operations.  |
|   | (e) If a gauge well separate from the fill tube is used, it shall be provided with a submerged drop tube that extends the same distance from the bottom of the storage tank as specified in §63.11117(b).  |
|   | (f) Liquid fill connections for all systems shall be equipped with vapor-tight caps.   |
|   | (g) Pressure/vacuum (PV) vent valves shall be installed on the storage tank vent pipes. The pressure specifications for PV vent valves shall be: a positive pressure setting of 2.5 to 6.0 inches of water and a negative pressure setting of 6.0 to 10.0 inches of water. The total leak rate of all PV vent valves at an affected facility, including connections, shall not exceed 0.17 cubic foot per hour at a pressure of 2.0 inches of water and 0.63 cubic foot per hour at a vacuum of 4 inches of water. |
|   | (h) The vapor balance system shall be capable of meeting the static pressure performance requirement of the following equation:  |
|   | $P_f = 2e^{-500.887/v}$  |
|   | Where:   |
|   | $P_f$ = Minimum allowable final pressure, inches of water.   |
|   | $v$ = Total ullage affected by the test, gallons.  |
|   | $e$ = Dimensionless constant equal to approximately 2.718.   |
|   | $2$ = The initial pressure, inches water.  |
| 2. A new or reconstructed GDF, or any storage tank(s) constructed after November 9, 2006, at an existing affected facility subject to §63.11118 | Equip your gasoline storage tanks with a dual-point vapor balance system, as defined in §63.11132, and comply with the requirements of item 1 in this Table.   |

<sup>1</sup>The management practices specified in this Table are not applicable if you are complying with the requirements in §63.11118(b)(2), except that if you are complying with the requirements in §63.11118(b)(2)(i)(B), you must operate using management practices at least as stringent as those listed in this Table.

[73 FR 1945, Jan. 10, 2008, as amended at 73 FR 35944, June 25, 2008; 76 FR 4184, Jan. 24, 2011]

**Table 2 to Subpart CCCCCC of Part 63—Applicability Criteria and Management Practices for Gasoline Cargo Tanks Unloading at Gasoline Dispensing Facilities With Monthly Throughput of 100,000 Gallons of Gasoline or More**

| <b>If you own or operate</b> | <b>Then you must</b>  |
|------------------------------|---|
| A gasoline cargo tank        | Not unload gasoline into a storage tank at a GDF subject to the control requirements in this subpart unless the following conditions are met:   |
|                              | (i) All hoses in the vapor balance system are properly connected,   |
|                              | (ii) The adapters or couplers that attach to the vapor line on the storage tank have closures that seal upon disconnect,  |
|                              | (iii) All vapor return hoses, couplers, and adapters used in the gasoline delivery are vapor-tight,   |
|                              | (iv) All tank truck vapor return equipment is compatible in size and forms a vapor-tight connection with the vapor balance equipment on the GDF storage tank, and   |
|                              | (v) All hatches on the tank truck are closed and securely fastened.   |
|                              | (vi) The filling of storage tanks at GDF shall be limited to unloading from vapor-tight gasoline cargo tanks. Documentation that the cargo tank has met the specifications of EPA Method 27 shall be carried with the cargo tank, as specified in §63.11125(c). |

[73 FR 1945, Jan. 10, 2008, as amended at 76 FR 4184, Jan. 24, 2011]

**Table 3 to Subpart CCCCCC of Part 63—Applicability of General Provisions**

| <b>Citation</b> | <b>Subject</b> | <b>Brief description</b>  | <b>Applies to subpart CCCCCC</b>   |
|-----------------|----------------|---|--|
| §63.1           | Applicability  | Initial applicability determination; applicability after standard established; permit requirements; extensions, notifications | Yes, specific requirements given in §63.11111.   |
| §63.1(c)(2)     | Title V Permit | Requirements for obtaining a title V permit from the applicable permitting authority  | Yes, §63.11111(f) of subpart CCCCCC exempts identified area sources from the obligation to obtain title V operating permits. |

| <b>Citation</b> | <b>Subject</b>  | <b>Brief description</b>  | <b>Applies to subpart CCCCCC</b>  |
|-----------------|---|---|---|
| §63.2           | Definitions   | Definitions for part 63 standards   | Yes, additional definitions in §63.11132.   |
| §63.3           | Units and Abbreviations   | Units and abbreviations for part 63 standards   | Yes.  |
| §63.4           | Prohibited Activities and Circumvention                                   | Prohibited activities; Circumvention, severability  | Yes.  |
| §63.5           | Construction/Reconstruction   | Applicability; applications; approvals  | Yes, except that these notifications are not required for facilities subject to §63.11116 |
| §63.6(a)        | Compliance with Standards/Operation & Maintenance—Applicability           | General Provisions apply unless compliance extension; General Provisions apply to area sources that become major  | Yes.  |
| §63.6(b)(1)–(4) | Compliance Dates for New and Reconstructed Sources                        | Standards apply at effective date; 3 years after effective date; upon startup; 10 years after construction or reconstruction commences for CAA section 112(f)   | Yes.  |
| §63.6(b)(5)     | Notification  | Must notify if commenced construction or reconstruction after proposal  | Yes.  |
| §63.6(b)(6)     | [Reserved]  |   |   |
| §63.6(b)(7)     | Compliance Dates for New and Reconstructed Area Sources That Become Major | Area sources that become major must comply with major source standards immediately upon becoming major, regardless of whether required to comply when they were an area source                            | No.   |
| §63.6(c)(1)–(2) | Compliance Dates for Existing Sources                                     | Comply according to date in this subpart, which must be no later than 3 years after effective date; for CAA section 112(f) standards, comply within 90 days of effective date unless compliance extension | No, §63.11113 specifies the compliance dates.   |
| §63.6(c)(3)–(4) | [Reserved]  |   |   |
| §63.6(c)(5)     | Compliance Dates for Existing Area Sources That Become Major              | Area sources That become major must comply with major source standards by date indicated in this subpart or by equivalent time period (e.g., 3 years)   | No.   |



| <b>Citation</b>           | <b>Subject</b>   | <b>Brief description</b>  | <b>Applies to subpart CCCCCC</b>                |
|---------------------------|--|---|---|
| §63.6(d)                  | [Reserved]   |   |   |
| 63.6(e)(1)(i)             | General duty to minimize emissions                                       | Operate to minimize emissions at all times; information Administrator will use to determine if operation and maintenance requirements were met.                                 | No. See §63.11115 for general duty requirement. |
| 63.6(e)(1)(ii)            | Requirement to correct malfunctions ASAP                                 | Owner or operator must correct malfunctions as soon as possible.  | No.   |
| §63.6(e)(2)               | [Reserved]   |   |   |
| §63.6(e)(3)               | Startup, Shutdown, and Malfunction (SSM) Plan                            | Requirement for SSM plan; content of SSM plan; actions during SSM   | No.   |
| §63.6(f)(1)               | Compliance Except During SSM   | You must comply with emission standards at all times except during SSM  | No.   |
| §63.6(f)(2)–(3)           | Methods for Determining Compliance                                       | Compliance based on performance test, operation and maintenance plans, records, inspection  | Yes.  |
| §63.6(g)(1)–(3)           | Alternative Standard   | Procedures for getting an alternative standard  | Yes.  |
| §63.6(h)(1)               | Compliance with Opacity/Visible Emission (VE) Standards                  | You must comply with opacity/VE standards at all times except during SSM  | No.   |
| §63.6(h)(2)(i)            | Determining Compliance with Opacity/VE Standards                         | If standard does not State test method, use EPA Method 9 for opacity in appendix A of part 60 of this chapter and EPA Method 22 for VE in appendix A of part 60 of this chapter | No.   |
| §63.6(h)(2)(ii)           | [Reserved]   |   |   |
| §63.6(h)(2)(iii)          | Using Previous Tests To Demonstrate Compliance With Opacity/VE Standards | Criteria for when previous opacity/VE testing can be used to show compliance with this subpart  | No.   |
| §63.6(h)(3)               | [Reserved]   |   |   |
| §63.6(h)(4)               | Notification of Opacity/VE Observation Date                              | Must notify Administrator of anticipated date of observation  | No.   |
| §63.6(h)(5)(i), (iii)–(v) | Conducting Opacity/VE Observations                                       | Dates and schedule for conducting opacity/VE observations   | No.   |
| §63.6(h)(5)(ii)           | Opacity Test Duration and Averaging Times                                | Must have at least 3 hours of observation with 30 6-minute averages   | No.   |
| §63.6(h)(6)               | Records of Conditions During Opacity/VE Observations                     | Must keep records available and allow Administrator to inspect  | No.   |

| <b>Citation</b>  | <b>Subject</b>   | <b>Brief description</b>   | <b>Applies to subpart CCCCCC</b> |
|------------------|--|--|----------------------------------|
| §63.6(h)(7)(i)   | Report Continuous Opacity Monitoring System (COMS) Monitoring Data From Performance Test | Must submit COMS data with other performance test data   | No.                              |
| §63.6(h)(7)(ii)  | Using COMS Instead of EPA Method 9   | Can submit COMS data instead of EPA Method 9 results even if rule requires EPA Method 9 in appendix A of part 60 of this chapter, but must notify Administrator before performance test  | No.                              |
| §63.6(h)(7)(iii) | Averaging Time for COMS During Performance Test  | To determine compliance, must reduce COMS data to 6-minute averages  | No.                              |
| §63.6(h)(7)(iv)  | COMS Requirements  | Owner/operator must demonstrate that COMS performance evaluations are conducted according to §63.8(e); COMS are properly maintained and operated according to §63.8(c) and data quality as §63.8(d)  | No.                              |
| §63.6(h)(7)(v)   | Determining Compliance with Opacity/VE Standards   | COMS is probable but not conclusive evidence of compliance with opacity standard, even if EPA Method 9 observation shows otherwise. Requirements for COMS to be probable evidence-proper maintenance, meeting Performance Specification 1 in appendix B of part 60 of this chapter, and data have not been altered | No.                              |
| §63.6(h)(8)      | Determining Compliance with Opacity/VE Standards   | Administrator will use all COMS, EPA Method 9 (in appendix A of part 60 of this chapter), and EPA Method 22 (in appendix A of part 60 of this chapter) results, as well as information about operation and maintenance to determine compliance   | No.                              |
| §63.6(h)(9)      | Adjusted Opacity Standard  | Procedures for Administrator to adjust an opacity standard   | No.                              |
| §63.6(i)(1)–(14) | Compliance Extension   | Procedures and criteria for Administrator to grant compliance extension  | Yes.                             |
| §63.6(j)         | Presidential Compliance Exemption  | President may exempt any source from requirement to comply with this subpart   | Yes.                             |

| <b>Citation</b> | <b>Subject</b>                              | <b>Brief description</b>   | <b>Applies to subpart CCCCCC</b>  |
|-----------------|---|--|---|
| §63.7(a)(2)     | Performance Test Dates                      | Dates for conducting initial performance testing; must conduct 180 days after compliance date  | Yes.  |
| §63.7(a)(3)     | CAA Section 114 Authority                   | Administrator may require a performance test under CAA section 114 at any time   | Yes.  |
| §63.7(b)(1)     | Notification of Performance Test            | Must notify Administrator 60 days before the test  | Yes.  |
| §63.7(b)(2)     | Notification of Re-scheduling               | If have to reschedule performance test, must notify Administrator of rescheduled date as soon as practicable and without delay   | Yes.  |
| §63.7(c)        | Quality Assurance (QA)/Test Plan            | Requirement to submit site-specific test plan 60 days before the test or on date Administrator agrees with; test plan approval procedures; performance audit requirements; internal and external QA procedures for testing | Yes.  |
| §63.7(d)        | Testing Facilities                          | Requirements for testing facilities  | Yes.  |
| 63.7(e)(1)      | Conditions for Conducting Performance Tests | Performance test must be conducted under representative conditions   | No, §63.11120(c) specifies conditions for conducting performance tests. |
| §63.7(e)(2)     | Conditions for Conducting Performance Tests | Must conduct according to this subpart and EPA test methods unless Administrator approves alternative  | Yes.  |
| §63.7(e)(3)     | Test Run Duration                           | Must have three test runs of at least 1 hour each; compliance is based on arithmetic mean of three runs; conditions when data from an additional test run can be used  | Yes.  |
| §63.7(f)        | Alternative Test Method                     | Procedures by which Administrator can grant approval to use an intermediate or major change, or alternative to a test method   | Yes.  |
| §63.7(g)        | Performance Test Data Analysis              | Must include raw data in performance test report; must submit performance test data 60 days after end of test with the Notification of Compliance Status; keep data for 5 years  | Yes.  |

| <b>Citation</b>      | <b>Subject</b>   | <b>Brief description</b>   | <b>Applies to subpart CCCCCC</b> |
|----------------------|--|--|----------------------------------|
| §63.7(h)             | Waiver of Tests  | Procedures for Administrator to waive performance test   | Yes.                             |
| §63.8(a)(1)          | Applicability of Monitoring Requirements                         | Subject to all monitoring requirements in standard   | Yes.                             |
| §63.8(a)(2)          | Performance Specifications                                       | Performance Specifications in appendix B of 40 CFR part 60 apply   | Yes.                             |
| §63.8(a)(3)          | [Reserved]   |  |                                  |
| §63.8(a)(4)          | Monitoring of Flares   | Monitoring requirements for flares in §63.11 apply   | Yes.                             |
| §63.8(b)(1)          | Monitoring   | Must conduct monitoring according to standard unless Administrator approves alternative  | Yes.                             |
| §63.8(b)(2)–(3)      | Multiple Effluents and Multiple Monitoring Systems               | Specific requirements for installing monitoring systems; must install on each affected source or after combined with another affected source before it is released to the atmosphere provided the monitoring is sufficient to demonstrate compliance with the standard; if more than one monitoring system on an emission point, must report all monitoring system results, unless one monitoring system is a backup | No.                              |
| §63.8(c)(1)          | Monitoring System Operation and Maintenance                      | Maintain monitoring system in a manner consistent with good air pollution control practices  | No.                              |
| §63.8(c)(1)(i)–(iii) | Operation and Maintenance of Continuous Monitoring Systems (CMS) | Must maintain and operate each CMS as specified in §63.6(e)(1); must keep parts for routine repairs readily available; must develop a written SSM plan for CMS, as specified in §63.6(e)(3)  | No.                              |
| §63.8(c)(2)–(8)      | CMS Requirements   | Must install to get representative emission or parameter measurements; must verify operational status before or at performance test  | No.                              |
| §63.8(d)             | CMS Quality Control  | Requirements for CMS quality control, including calibration, etc.; must keep quality control plan on record for 5 years; keep old versions for 5 years after revisions   | No.                              |
| §63.8(e)             | CMS Performance Evaluation                                       | Notification, performance evaluation test plan, reports  | No.                              |

| <b>Citation</b>          | <b>Subject</b>  | <b>Brief description</b>  | <b>Applies to subpart CCCCCC</b>              |
|--------------------------|---|---|---|
| §63.8(f)(1)–(5)          | Alternative Monitoring Method                                   | Procedures for Administrator to approve alternative monitoring  | No.   |
| §63.8(f)(6)              | Alternative to Relative Accuracy Test                           | Procedures for Administrator to approve alternative relative accuracy tests for continuous emissions monitoring system (CEMS)   | No.   |
| §63.8(g)                 | Data Reduction  | COMS 6-minute averages calculated over at least 36 evenly spaced data points; CEMS 1 hour averages computed over at least 4 equally spaced data points; data that cannot be used in average                       | No.   |
| §63.9(a)                 | Notification Requirements                                       | Applicability and State delegation  | Yes.  |
| §63.9(b)(1)–(2), (4)–(5) | Initial Notifications   | Submit notification within 120 days after effective date; notification of intent to construct/reconstruct, notification of commencement of construction/reconstruction, notification of startup; contents of each | Yes.  |
| §63.9(c)                 | Request for Compliance Extension                                | Can request if cannot comply by date or if installed best available control technology or lowest achievable emission rate   | Yes.  |
| §63.9(d)                 | Notification of Special Compliance Requirements for New Sources | For sources that commence construction between proposal and promulgation and want to comply 3 years after effective date  | Yes.  |
| §63.9(e)                 | Notification of Performance Test                                | Notify Administrator 60 days prior  | Yes.  |
| §63.9(f)                 | Notification of VE/Opacity Test                                 | Notify Administrator 30 days prior  | No.   |
| §63.9(g)                 | Additional Notifications when Using CMS                         | Notification of performance evaluation; notification about use of COMS data; notification that exceeded criterion for relative accuracy alternative   | Yes, however, there are no opacity standards. |
| §63.9(h)(1)–(6)          | Notification of Compliance Status                               | Contents due 60 days after end of performance test or other compliance demonstration, except for opacity/VE, which are due 30 days after; when to submit to Federal vs. State authority                           | Yes, however, there are no opacity standards. |
| §63.9(i)                 | Adjustment of Submittal Deadlines                               | Procedures for Administrator to approve change when notifications must be submitted   | Yes.  |

| <b>Citation</b>       | <b>Subject</b>                     | <b>Brief description</b>  | <b>Applies to subpart CCCCCC</b>  |
|-----------------------|------------------------------------|---|---|
| §63.9(j)              | Change in Previous Information     | Must submit within 15 days after the change   | Yes.  |
| §63.10(a)             | Recordkeeping/Reporting            | Applies to all, unless compliance extension; when to submit to Federal vs. State authority; procedures for owners of more than one source | Yes.  |
| §63.10(b)(1)          | Recordkeeping/Reporting            | General requirements; keep all records readily available; keep for 5 years  | Yes.  |
| §63.10(b)(2)(i)       | Records related to SSM             | Recordkeeping of occurrence and duration of startups and shutdowns  | No.   |
| §63.10(b)(2)(ii)      | Records related to SSM             | Recordkeeping of malfunctions   | No. See §63.11125(d) for recordkeeping of (1) occurrence and duration and (2) actions taken during malfunction. |
| §63.10(b)(2)(iii)     | Maintenance records                | Recordkeeping of maintenance on air pollution control and monitoring equipment  | Yes.  |
| §63.10(b)(2)(iv)      | Records Related to SSM             | Actions taken to minimize emissions during SSM  | No.   |
| §63.10(b)(2)(v)       | Records Related to SSM             | Actions taken to minimize emissions during SSM  | No.   |
| §63.10(b)(2)(vi)–(xi) | CMS Records                        | Malfunctions, inoperative, out-of-control periods   | No.   |
| §63.10(b)(2)(xii)     | Records                            | Records when under waiver   | Yes.  |
| §63.10(b)(2)(xiii)    | Records                            | Records when using alternative to relative accuracy test  | Yes.  |
| §63.10(b)(2)(xiv)     | Records                            | All documentation supporting Initial Notification and Notification of Compliance Status   | Yes.  |
| §63.10(b)(3)          | Records                            | Applicability determinations  | Yes.  |
| §63.10(c)             | Records                            | Additional records for CMS  | No.   |
| §63.10(d)(1)          | General Reporting Requirements     | Requirement to report   | Yes.  |
| §63.10(d)(2)          | Report of Performance Test Results | When to submit to Federal or State authority  | Yes.  |

| <b>Citation</b>       | <b>Subject</b>                       | <b>Brief description</b>   | <b>Applies to subpart CCCCCC</b>                                    |
|-----------------------|--------------------------------------|--|---|
| §63.10(d)(3)          | Reporting Opacity or VE Observations | What to report and when  | No.   |
| §63.10(d)(4)          | Progress Reports                     | Must submit progress reports on schedule if under compliance extension   | Yes.  |
| §63.10(d)(5)          | SSM Reports                          | Contents and submission  | No. See §63.11126(b) for malfunction reporting requirements.        |
| §63.10(e)(1)–(2)      | Additional CMS Reports               | Must report results for each CEMS on a unit; written copy of CMS performance evaluation; two-three copies of COMS performance evaluation   | No.   |
| §63.10(e)(3)(i)–(iii) | Reports                              | Schedule for reporting excess emissions  | No.   |
| §63.10(e)(3)(iv)–(v)  | Excess Emissions Reports             | Requirement to revert to quarterly submission if there is an excess emissions and parameter monitor exceedances (now defined as deviations); provision to request semiannual reporting after compliance for 1 year; submit report by 30th day following end of quarter or calendar half; if there has not been an exceedance or excess emissions (now defined as deviations), report contents in a statement that there have been no deviations; must submit report containing all of the information in §§63.8(c)(7)–(8) and 63.10(c)(5)–(13) | No.   |
| §63.10(e)(3)(iv)–(v)  | Excess Emissions Reports             | Requirement to revert to quarterly submission if there is an excess emissions and parameter monitor exceedances (now defined as deviations); provision to request semiannual reporting after compliance for 1 year; submit report by 30th day following end of quarter or calendar half; if there has not been an exceedance or excess emissions (now defined as deviations), report contents in a statement that there have been no deviations; must submit report containing all of the information in §§63.8(c)(7)–(8) and 63.10(c)(5)–(13) | No, §63.11130(K) specifies excess emission events for this subpart. |

| <b>Citation</b>         | <b>Subject</b>                             | <b>Brief description</b>  | <b>Applies to subpart CCCCCC</b> |
|-------------------------|--|---|----------------------------------|
| §63.10(e)(3)(vi)–(viii) | Excess Emissions Report and Summary Report | Requirements for reporting excess emissions for CMS; requires all of the information in §§63.10(c)(5)–(13) and 63.8(c)(7)–(8) | No.                              |
| §63.10(e)(4)            | Reporting COMS Data                        | Must submit COMS data with performance test data  | No.                              |
| §63.10(f)               | Waiver for Recordkeeping/Reporting         | Procedures for Administrator to waive   | Yes.                             |
| §63.11(b)               | Flares                                     | Requirements for flares   | No.                              |
| §63.12                  | Delegation                                 | State authority to enforce standards  | Yes.                             |
| §63.13                  | Addresses                                  | Addresses where reports, notifications, and requests are sent   | Yes.                             |
| §63.14                  | Incorporations by Reference                | Test methods incorporated by reference  | Yes.                             |
| §63.15                  | Availability of Information                | Public and confidential information   | Yes.                             |

[73 FR 1945, Jan. 10, 2008, as amended at 76 FR 4184, Jan. 24, 2011]



## **Attachment D**

### **Title 40: Protection of Environment**

#### **PART 63—NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS FOR SOURCE CATEGORIES**

##### **Subpart WWWWWW—National Emission Standards for Hazardous Air Pollutants: Area Source Standards for Plating and Polishing Operations**

Source: 73 FR 37741, July 1, 2008, unless otherwise noted.

#### **Applicability and Compliance Dates**

##### **§ 63.11504 Am I subject to this subpart?**

(a) You are subject to this subpart if you own or operate a plating and polishing facility that is an area source of hazardous air pollutant (HAP) emissions and meets the criteria specified in paragraphs (a)(1) through (3) of this section.

(1) A plating and polishing facility is a plant site that is engaged in one or more of the processes listed in paragraphs (a)(1)(i) through (vi) of this section.

(i) Electroplating other than chromium electroplating (i.e., non-chromium electroplating).

(ii) Electroless or non-electrolytic plating.

(iii) Other non-electrolytic metal coating processes, such as chromate conversion coating, nickel acetate sealing, sodium dichromate sealing, and manganese phosphate coating; and thermal spraying.

(iv) Dry mechanical polishing of finished metals and formed products after plating or thermal spraying.

(v) Electroforming.

(vi) Electropolishing.

(2) A plating or polishing facility is an area source of HAP emissions, where an area source is any stationary source or group of stationary sources within a contiguous area under common control that does not have the potential to emit any single HAP at a rate of 9.07 megagrams per year (Mg/yr) (10 tons per year (tpy)) or more and any combination of HAP at a rate of 22.68 Mg/yr (25 tpy) or more.

(3) Your plating and polishing facility uses or has emissions of compounds of one or more plating and polishing metal HAP, which means any compound of any of the following metals: cadmium, chromium, lead, manganese, and nickel, as defined in §63.11511, "What definitions apply to this subpart?" With the exception of lead, plating and polishing metal HAP also include any of these metals in the elemental form.

(b) [Reserved]

[73 FR 37741, July 1, 2008, as amended at 76 FR 57919, Sept. 19, 2011]

##### **§ 63.11505 What parts of my plant does this subpart cover?**

(a) This subpart applies to each new or existing affected source, as specified in paragraphs (a)(1) through (3) of this section, at all times. A new source is defined in §63.11511, "What definitions apply to this subpart?"

(1) Each tank that contains one or more of the plating and polishing metal HAP, as defined in §63.11511, "What definitions apply to this subpart?", and is used for non-chromium electroplating; electroforming; electropolishing; electroless plating or other non-electrolytic metal coating operations, such as chromate conversion coating, nickel acetate sealing, sodium dichromate sealing, and manganese phosphate coating.

(2) Each thermal spraying operation that applies one or more of the plating and polishing metal HAP, as defined in §63.11511, "What definitions apply to this subpart?"

(3) Each dry mechanical polishing operation that emits one or more of the plating and polishing metal HAP, as defined in §63.11511, "What definitions apply to this subpart?"

(b) An affected source is existing if you commenced construction or reconstruction of the affected source on or before March 14, 2008.

(c) An affected source is new if you commenced construction or reconstruction of the affected source after March 14, 2008.

(d) This subpart does not apply to any of the process units or operations described in paragraphs (d)(1) through (6) of this section.

(1) Process units that are subject to the requirements of 40 CFR part 63, subpart N (National Emission Standards for Chromium Emissions from Hard and Decorative Chromium Electroplating and Chromium Anodizing Tanks).

(2) Research and development process units, as defined in §63.11511, "What definitions apply to this subpart?"

(3) Process units that are used strictly for educational purposes.

(4) Plating, polishing, coating, or thermal spraying conducted to repair surfaces or equipment.

(5) Dry mechanical polishing conducted to restore the original finish to a surface.

(6) Any plating or polishing process that uses process materials that contain cadmium, chromium, lead, or nickel (as the metal) in amounts less than 0.1 percent by weight, or that contain manganese in amounts less than 1.0 percent by weight (as the metal), as used. Information used to determine the amount of plating and polishing metal HAP in materials used in the plating or polishing process may include information reported on the Material Safety Data Sheet for the material, but is not required. For plating or polishing tanks, the HAP content may be determined from the final bath contents "as used" to plate or to polish.

(e) You are exempt from the obligation to obtain a permit under 40 CFR part 70 or 40 CFR part 71, "Title V," provided you are not otherwise required to obtain a permit under 40 CFR 70.3(a) or 40 CFR 71.3(a) for a reason other than your status as an area source under this subpart. Notwithstanding the previous sentence, you must continue to comply with the provisions of this subpart applicable to area sources.

[73 FR 37741, July 1, 2008, as amended at 76 FR 57919, Sept. 19, 2011]

### **§ 63.11506 What are my compliance dates?**

- (a) If you own or operate an existing affected source, you must achieve compliance with the applicable provisions of this subpart no later than July 1, 2010.
- (b) If you own or operate a new affected source for which the initial startup date is on or before July 1, 2008, you must achieve compliance with the provisions of this subpart no later than July 1, 2008.
- (c) If you own or operate a new affected source for which the initial startup date is after July 1, 2008, you must achieve compliance with the provisions of this subpart upon initial startup of your affected source.

### **Standards and Compliance Requirements**

### **§ 63.11507 What are my standards and management practices?**

(a) If you own or operate an affected new or existing non-cyanide electroplating, electroforming, or electropolishing tank (hereafter referred to as an "electrolytic" process tank, as defined in §63.11511, "What definitions apply to this subpart?") that contains one or more of the plating and polishing metal HAP and operates at a pH of less than 12, you must comply with the requirements in paragraph (a)(1), (2), or (3) of this section, and implement the applicable management practices in paragraph (g) of this section, as practicable.

(1) You must use a wetting agent/fume suppressant in the bath of the affected tank, as defined in §63.11511, "What definitions apply to this subpart?" and according to paragraphs (a)(1)(i) through (iii) of this section.

(i) You must initially add the wetting agent/fume suppressant in the amounts recommended by the manufacturer for the specific type of electrolytic process.

(ii) You must add wetting agent/fume suppressant in proportion to the other bath chemistry ingredients that are added to replenish the bath, as in the original make-up of the bath, or in proportions such that the bath contents are returned to that of the original make-up of the bath.

(iii) If a wetting agent/fume suppressant is included in the electrolytic process bath chemicals used in the affected tank according to the manufacturer's instructions, it is not necessary to add additional wetting agent/fume suppressants to the tank to comply with this rule.

(2) You must capture and exhaust emissions from the affected tank to any one of the following emission control devices: composite mesh pad, packed bed scrubber, or mesh pad mist eliminator, according to paragraphs (a)(2)(i) and (ii) of this section.

(i) You must operate all capture and control devices according to the manufacturer's specifications and operating instructions.

(ii) You must keep the manufacturer's specifications and operating instructions at the facility at all times in a location where they can be easily accessed by the operators.

(3) You must cover the tank surface according to paragraph (a)(3)(i) or (ii) of this section.

(i) For batch electrolytic process tanks, as defined in §63.11511, "What definitions apply to this subpart?", you must use a tank cover, as defined in §63.11511, over all of the effective surface area of the tank for at least 95 percent of the electrolytic process operating time.

(ii) For continuous electrolytic process tanks, as defined in §63.11511, “What definitions apply to this subpart?”, you must cover at least 75 percent of the surface of the tank, as defined in §63.11511, whenever the electrolytic process tank is in operation.

(b) If you own or operate an affected new or existing “flash” or short-term electroplating tank, as defined in §63.11511, “What definitions apply to this subpart?”, that uses or emits one or more of the plating and polishing metal HAP, you must comply with the requirements specified in paragraph (b)(1) or (b)(2), and implement the applicable management practices in paragraph (g) of this section, as practicable.

(1) You must limit short-term or “flash” electroplating to no more than 1 cumulative hour per day or 3 cumulative minutes per hour of plating time.

(2) You must use a tank cover, as defined in §63.11511, “What definitions apply to this subpart?”, for at least 95 percent of the plating time.

(c) If you own or operate an affected new or existing process tank that is used both for short-term electroplating and for electrolytic processing of longer duration (i.e., processing that does not meet the definition of short-term or flash electroplating) and contains one or more of the plating and polishing metal HAP, you must meet the requirements specified in paragraph (a) or (b) of this section, whichever apply to the process operation, and implement the applicable management practices in paragraph (g) of this section, as practicable.

(d) If you own or operate an affected new or existing electroplating tank that uses cyanide in the plating bath, operates at pH greater than or equal to 12, and contains one or more of the plating and polishing metal HAP, you must comply with the requirements in paragraphs (d)(1) and (2) of this section:

(1) You must measure and record the pH of the bath upon startup of the bath, as defined in §63.11511, “What definitions apply to this subpart?” No additional pH measurements are required.

(2) You must implement the applicable management practices in paragraph (g) of this section, as practicable.

(e) If you own or operate an affected new or existing dry mechanical polishing machine that emits one or more of the plating and polishing metal HAP, you must operate a capture system that captures particulate matter (PM) emissions from the dry mechanical polishing process and transports the emissions to a cartridge, fabric, or high efficiency particulate air (HEPA) filter, according to paragraphs (e)(1) and (2) of this section.

(1) You must operate all capture and control devices according to the manufacturer's specifications and operating instructions.

(2) You must keep the manufacturer's specifications and operating instructions at the facility at all times in a location where they can be easily accessed by the operators.

(f) If you own or operate an affected thermal spraying operation that applies one or more of the plating and polishing metal HAP, you must meet the applicable requirements specified in paragraphs (f)(1) through (3) of this section, and the applicable management practices in paragraph (g) of this section.

(1) For existing permanent thermal spraying operations, you must operate a capture system that collects PM emissions from the thermal spraying process and transports the emissions to a water curtain, fabric filter, cartridge, or HEPA filter, according to paragraphs (f)(1)(i) and (ii) of this section.

(2) For new permanent thermal spraying operations, you must operate a capture system that collects PM emissions from the thermal spraying process and transports the emissions to a fabric, cartridge, or HEPA filter, according to paragraphs (f)(2)(i) and (ii) of this section.

(3) For temporary thermal spraying operations, as defined in §63.11511 "What definitions apply to this subpart?", you must meet the applicable requirements specified in paragraphs (f)(3)(i) and (ii) of this section.

(i) You must document the amount of time the thermal spraying occurs each day, and where it is conducted.

(ii) You must implement the applicable management practices specified in paragraph (g) of this section, as practicable.

(g) If you own or operate an affected new or existing plating and polishing process unit that contains, applies, or emits one or more of the plating and polishing metal HAP, you must implement the applicable management practices in paragraphs (g)(1) through (12) of this section, as practicable.

(1) Minimize bath agitation when removing any parts processed in the tank, as practicable except when necessary to meet part quality requirements.

(2) Maximize the draining of bath solution back into the tank, as practicable, by extending drip time when removing parts from the tank; using drain boards (also known as drip shields); or withdrawing parts slowly from the tank, as practicable.

(3) Optimize the design of barrels, racks, and parts to minimize dragout of bath solution (such as by using slotted barrels and tilted racks, or by designing parts with flow-through holes to allow the tank solution to drip back into the tank), as practicable.

(4) Use tank covers, if already owned and available at the facility, whenever practicable.

(5) Minimize or reduce heating of process tanks, as practicable (e.g., when doing so would not interrupt production or adversely affect part quality).

(6) Perform regular repair, maintenance, and preventive maintenance of racks, barrels, and other equipment associated with affected sources, as practicable.

(7) Minimize bath contamination, such as through the prevention or quick recovery of dropped parts, use of distilled/de-ionized water, water filtration, pre-cleaning of parts to be plated, and thorough rinsing of pre-treated parts to be plated, as practicable.

(8) Maintain quality control of chemicals, and chemical and other bath ingredient concentrations in the tanks, as practicable.

(9) Perform general good housekeeping, such as regular sweeping or vacuuming, if needed, and periodic washdowns, as practicable.

(10) Minimize spills and overflow of tanks, as practicable.

(11) Use squeegee rolls in continuous or reel-to-reel plating tanks, as practicable.

(12) Perform regular inspections to identify leaks and other opportunities for pollution prevention.

[73 FR 37741, July 1, 2008, as amended at 76 FR 57920, Sept. 19, 2011]

**§ 63.11508 What are my compliance requirements?**

(a) If you own or operate an affected source, you must submit a Notification of Compliance Status in accordance with §63.11509(b) of "What are my notification, reporting, and recordkeeping requirements?"

(b) You must be in compliance with the applicable management practices and equipment standards in this subpart at all times.

(c) To demonstrate initial compliance, you must satisfy the requirements specified in paragraphs (c)(1) through (11) of this section.

(1) If you own or operate an affected electroplating, electroforming, or electropolishing tank that contains one or more of the plating and polishing metal HAP and is subject to the requirements in §63.11507(a), "What are my standards and management practices?", and you use a wetting agent/fume suppressant to comply with this subpart, you must demonstrate initial compliance according to paragraphs (c)(1)(i) through (iv) of this section.

(i) You must add wetting agent/fume suppressant to the bath of each affected tank according to manufacturer's specifications and instructions.

(ii) You must state in your Notification of Compliance Status that you add wetting agent/fume suppressant to the bath according to manufacturer's specifications and instructions.

(iii) You must implement the applicable management practices specified in §63.11507(g), "What are my standards and management practices?", as practicable.

(iv) You must state in your Notification of Compliance Status that you have implemented the applicable management practices specified in §63.11507(g), "What are my standards and management practices?", as practicable.

(2) If you own or operate an affected electroplating, electroforming, or electropolishing tank that contains one or more of the plating and polishing metal HAP and is subject to the requirements in §63.11507(a), "What are my standards and management practices?", and you use a control system, as defined in §63.11511, "What definitions apply to this subpart?", to comply with this subpart, you must demonstrate initial compliance according to paragraphs (c)(2)(i) through (v) of this section.

(i) You must install a control system designed to capture emissions from the affected tank and exhaust them to a composite mesh pad, packed bed scrubber, or mesh pad mist eliminator.

(ii) You must state in your Notification of Compliance Status that you have installed the control system according to the manufacturer's specifications and instructions.

(iii) You must implement the applicable management practices specified in §63.11507(g), "What are my standards and management practices?", as practicable.

(iv) You must state in your Notification of Compliance Status that you have implemented the applicable management practices specified in §63.11507(g), "What are my standards and management practices?", as practicable.

(v) You must follow the manufacturer's specifications and operating instructions for the control systems at all times.

(3) If you own or operate an affected batch electrolytic process tank, as defined in §63.11511, "What definitions apply to this subpart?" that contains one or more of the plating and polishing metal HAP and which is subject to the requirements in §63.11507(a), "What are my standards and management practices?" and you use a tank cover, as defined in §63.11511, to comply with §11507(a), (b) or (c) of this subpart, you must demonstrate initial compliance according to paragraphs (c)(3)(i) through (iv) of this section.

(i) You must install a tank cover on the affected tank.

(ii) You must state in your Notification of Compliance Status that you operate the tank with the cover in place at least 95 percent of the electrolytic process operating time.

(iii) You must implement the applicable management practices specified in §63.11507(g), "What are my standards and management practices?", as practicable.

(iv) You must state in your Notification of Compliance Status that you have implemented the applicable management practices specified in §63.11507(g), "What are my standards and management practices?", as practicable.

(4) If you own or operate an affected continuous electrolytic process tank, as defined in §63.11511, "What definitions apply to this subpart?" that contains one or more of the plating and polishing metal HAP and is subject to the requirements in §63.11507(a), "What are my standards and management practices?" and you cover the tank surface to comply with §11507(a), (b) or (c) of this subpart, you must demonstrate initial compliance according to paragraphs (c)(4)(i) through (iv) of this section.

(i) You must cover at least 75 percent of the surface area of the affected tank.

(ii) You must state in your Notification of Compliance Status that you operate the tank with the surface cover in place whenever the continuous electrolytic process is in operation.

(iii) You must implement the applicable management practices specified in §63.11507(g), "What are my standards and management practices?", as practicable.

(iv) You must state in your Notification of Compliance Status that you have implemented the applicable management practices specified in §63.11507(g), "What are my standards and management practices?", as practicable.

(5) If you own or operate an affected flash or short-term electroplating tank that contains one or more of the plating and polishing metal HAP and is subject to the requirements in §63.11507(b), "What are my standards and management practices?" and you comply with §11507(a), (b) or (c) of this subpart by limiting the plating time of the affected tank, you must demonstrate initial compliance according to paragraphs (c)(5)(i) through (iii) of this section.

(i) You must state in your Notification of Compliance Status that you limit short-term or flash electroplating to no more than 1 cumulative hour per day, or 3 cumulative minutes per hour of plating time.

(ii) You must implement the applicable management practices specified in §63.11507(g), "What are my standards and management practices?", as practicable.

(iii) You must state in your Notification of Compliance Status that you have implemented the applicable management practices specified in §63.11507(g), "What are my standards and management practices?", as practicable.

(6) If you own or operate an affected flash or short-term electroplating tank that contains one or more of the plating and polishing metal HAP and is subject to the requirements in §63.11507(b), "What are my standards and management practices?" and you comply with §11507(a), (b) or (c) of this subpart by operating the affected tank with a cover, you must demonstrate initial compliance according to paragraphs (c)(6)(i) through (iv) of this section.

(i) You must install a tank cover on the affected tank.

(ii) You must state in your Notification of Compliance Status that you operate the tank with the cover in place at least 95 percent of the plating time.

(iii) You must implement the applicable management practices specified in §63.11507(g), "What are my standards and management practices?", as practicable.

(iv) You must state in your Notification of Compliance Status that you have implemented the applicable management practices specified in §63.11507(g), "What are my standards and management practices?", as practicable.

(7) If you own or operate an affected tank that contains one or more of the plating and polishing metal HAP, uses cyanide in the bath, and is subject to the management practices specified in §63.11507(d), "What are my standards and management practices?", you must demonstrate initial compliance according to paragraphs (c)(7)(i) through (iii) of this section.

(i) You must report in your Notification of Compliance Status the pH of the bath solution that was measured at startup, as defined in §63.11511, according to the requirements of §63.11507(d)(1).

(ii) You must implement the applicable management practices specified in §63.11507(g), "What are my standards and management practices?", as practicable.

(iii) You must state in your Notification of Compliance Status that you have implemented the applicable management practices specified in §63.11490(g), "What are my standards and management practices?", as practicable.

(8) If you own or operate an affected dry mechanical polishing operation that emits one or more of the plating and polishing metal HAP and is subject to the requirements in §63.11507(e), "What are my standards and management practices?", you must demonstrate initial compliance according to paragraphs (c)(8)(i) through (iii) of this section.

(i) You must install a control system that is designed to capture PM emissions from the polishing operation and exhaust them to a cartridge, fabric, or HEPA filter.

(ii) You must state in your Notification of Compliance Status that you have installed the control system according to the manufacturer's specifications and instructions.

(iii) You must keep the manufacturer's operating instructions at the facility at all times in a location where they can be easily accessed by the operators.

(9) If you own or operate an existing affected permanent thermal spraying operation that applies one or more of the plating and polishing metal HAP and is subject to the requirements in §63.11507(f)(1), "What



are my standards and management practices?”, you must demonstrate initial compliance according to paragraphs (c)(9)(i) through (iii) of this section.

(i) You must install a control system that is designed to capture PM emissions from the thermal spraying operation and exhaust them to a water curtain, or a cartridge, fabric, or HEPA filter.

(ii) You must state in your Notification of Compliance Status that you have installed and are operating the control system according to the manufacturer's specifications and instructions.

(iii) You must keep the manufacturer's operating instructions at the facility at all times in a location where they can be easily accessed by the operators.

(10) If you own or operate a new affected permanent thermal spraying operation that applies one or more of the plating and polishing metal HAP and is subject to the requirements in §63.11507(f)(2), “What are my standards and management practices?”, you must demonstrate initial compliance according to paragraphs (c)(10)(i) through (iii) of this section.

(i) You must install and operate a control system that is designed to capture PM emissions from the thermal spraying operation and exhaust them to a cartridge, fabric, or HEPA filter.

(ii) You must state in your Notification of Compliance Status that you have installed and operate the control system according to the manufacturer's specifications and instructions.

(iii) You must keep the manufacturer's operating instructions at the facility at all times in a location where they can be easily accessed by the operators.

(11) If you own or operate an affected temporary thermal spraying operation that applies one or more of the plating and polishing metal HAP and is subject to the requirements in §63.11507(f)(3), “What are my standards and management practices?”, you must demonstrate initial compliance according to paragraphs (c)(11)(i) and (ii) of this section.

(i) You must implement the applicable management practices specified in §63.11507(g), “What are my standards and management practices?”, as practicable.

(ii) You must state in your Notification of Compliance Status that you have implemented the applicable management practices specified in §63.11507(g), “What are my standards and management practices?”, as practicable.

(d) To demonstrate continuous compliance with the applicable management practices and equipment standards specified in this subpart, you must satisfy the requirements specified in paragraphs (d)(1) through (8) of this section.

(1) You must always operate and maintain your affected source, including air pollution control equipment.

(2) You must prepare an annual compliance certification according to the requirements specified in §63.11509(c), “Notification, Reporting, and Recordkeeping,” and keep it in a readily-accessible location for inspector review.

(3) If you own or operate an affected electroplating, electroforming, or electropolishing tank that contains one or more of the plating and polishing metal HAP and is subject to the requirements in §63.11507(a), “What are my standards and management practices?”, and you use a wetting agent/fume suppressant to comply with this subpart, you must demonstrate continuous compliance according to paragraphs (d)(3)(i) through (iii) of this section.

(i) You must record that you have added the wetting agent/fume suppressant to the tank bath in the original make-up of the tank.

(ii) For tanks where the wetting agent/fume suppressant is a separate ingredient from the other tank additives, you must demonstrate continuous compliance according to paragraphs (d)(3)(ii) (A) and (B) this section.

(A) You must add wetting agent/fume suppressant in proportion to the other bath chemistry ingredients that are added to replenish the tank bath, as in the original make-up of the tank; or in proportion such that the bath is brought back to the original make-up of the tank.

(B) You must record each addition of wetting agent/fume suppressant to the tank bath.

(iii) You must state in your annual compliance certification that you have added wetting agent/fume suppressant to the bath according to the manufacturer's specifications and instructions.

(4) If you own or operate an affected electroplating, electroforming, or electropolishing tank that contains one or more of the plating and polishing metal HAP and is subject to the requirements in §63.11507(a), "What are my standards and management practices?", and you use a control system to comply with this subpart; an affected dry mechanical polishing operation that is subject to §63.11507(e); or an affected thermal spraying operation that is subject to §63.11507(f)(1) or (2), you must demonstrate continuous compliance according to paragraphs (d)(4)(i) through (v) of this section.

(i) You must operate and maintain the control system according to the manufacturer's specifications and instructions.

(ii) Following any malfunction or failure of the capture or control devices to operate properly, you must take immediate corrective action to return the equipment to normal operation according to the manufacturer's specifications and operating instructions.

(iii) You must state in your annual certification that you have operated and maintained the control system according to the manufacturer's specifications and instructions.

(iv) You must record the results of all control system inspections, deviations from proper operation, and any corrective action taken.

(v) You must keep the manufacturer's operating instructions at the facility at all times in a location where they can be easily accessed by the operators.

(5) If you own or operate an affected flash or short-term electroplating tank that contains one or more of the plating and polishing metal HAP and is subject to the requirements in §63.11507(b), "What are my standards and management practices?" and you comply with §11507(a), (b) or (c) of this subpart by limiting the plating time for the affected tank, you must demonstrate continuous compliance according to paragraphs (d)(5)(i) through (iii) of this section.

(i) You must limit short-term or flash electroplating to no more than 1 cumulative hour per day or 3 cumulative minutes per hour of plating time.

(ii) You must record the times that the affected tank is operated each day.

(iii) You must state in your annual compliance certification that you have limited short-term or flash electroplating to no more than 1 cumulative hour per day or 3 cumulative minutes per hour of plating time.

(6) If you own or operate an affected batch electrolytic process tank that contains one or more of the plating and polishing metal HAP and is subject to the requirements of §63.11507(a), "What are my standards and management practices?" or a flash or short-term electroplating tank that contains one or more of the plating and polishing metal HAP and is subject to the requirements in §63.11507(b), and you comply with §11507(a), (b) or (c) of this section by operating the affected tank with a cover, you must demonstrate continuous compliance according to paragraphs (d)(6)(i) through (iii) of this section.

(i) You must operate the tank with the cover in place at least 95 percent of the electrolytic process operating time.

(ii) You must record the times that the tank is operated and the times that the tank is covered on a daily basis.

(iii) You must state in your annual certification that you have operated the tank with the cover in place at least 95 percent of the electrolytic process time.

(7) If you own or operate an affected continuous electrolytic process tank that contains one or more of the plating and polishing metal HAP and is subject to the requirements in §63.11507(a), "What are my standards and management practices?" and you comply with §11507(a), (b) or (c) of this subpart by operating the affected tank with a cover, you must demonstrate continuous compliance according to paragraphs (d)(7)(i) and (ii) of this section.

(i) You must operate the tank with at least 75 percent of the surface covered during all periods of electrolytic process operation.

(ii) You must state in your annual certification that you have operated the tank with 75 percent of the surface covered during all periods of electrolytic process operation.

(8) If you own or operate an affected tank or other operation that is subject to the management practices specified in §63.11507(g), "What are my standards and management practices?", you must demonstrate continuous compliance according to paragraphs (d)(8)(i) and (ii) of this section.

(i) You must implement the applicable management practices during all times that the affected tank or process is in operation.

(ii) You must state in your annual compliance certification that you have implemented the applicable management practices, as practicable.

[73 FR 37741, July 1, 2008, as amended at 76 FR 57920, Sept. 19, 2011]

#### **§ 63.11509 What are my notification, reporting, and recordkeeping requirements?**

(a) If you own or operate an affected source, as defined in §63.11505(a), "What parts of my plant does this subpart cover?", you must submit an Initial Notification in accordance with paragraphs (a)(1) through (4) of this section by the dates specified.

(1) The Initial Notification must include the information specified in §63.9(b)(2)(i) through (iv) of the General Provisions of this part.

(2) The Initial Notification must include a description of the compliance method (e.g., use of wetting agent/fume suppressant) for each affected source.

(3) If you start up your affected source on or before July 1, 2008, you must submit an Initial Notification not later than 120 calendar days after July 1, 2008.

(4) If you startup your new affected source after July 1, 2008, you must submit an Initial Notification when you become subject to this subpart.

(b) If you own or operate an affected source, you must submit a Notification of Compliance Status in accordance with paragraphs (b)(1) through (3) of this section.

(1) The Notification of Compliance Status must be submitted before the close of business on the compliance date specified in §63.11506, "What are my compliance dates?"

(2) The Notification of Compliance Status must include the items specified in paragraphs (b)(2)(i) through (iv) of this section.

(i) List of affected sources and the plating and polishing metal HAP used in, or emitted by, those sources.

(ii) Methods used to comply with the applicable management practices and equipment standards.

(iii) Description of the capture and emission control systems used to comply with the applicable equipment standards.

(iv) Statement by the owner or operator of the affected source as to whether the source is in compliance with the applicable standards or other requirements.

(3) If a facility makes a change to any items in (b)(2)(i), iii, and (iv) of this section that does not result in a deviation, an amended Notification of Compliance Status should be submitted within 30 days of the change.

(c) If you own or operate an affected source, you must prepare an annual certification of compliance report according to paragraphs (c)(1) through (7) of this section. These reports do not need to be submitted unless a deviation from the requirements of this subpart has occurred during the reporting year, in which case, the annual compliance report must be submitted along with the deviation report.

(1) If you own or operate an affected electroplating, electroforming, or electropolishing tank that is subject to the requirements in §63.11507(a)(1), "What are my standards and management practices?", you must state in your annual compliance certification that you have added wetting agent/fume suppressant to the bath according to the manufacturer's specifications and instructions.

(2) If you own or operate any one of the affected sources listed in paragraphs (c)(2)(i) through (iii) of this section, you must state in your annual certification that you have operated and maintained the control system according to the manufacturer's specifications and instructions.

(i) Electroplating, electroforming, or electropolishing tank that is subject to the requirements in §63.11507(a), "What are my standards and management practices?", and you use a control system to comply with this subpart;

(ii) Dry mechanical polishing operation that is subject to §63.11507(e); or

(iii) Permanent thermal spraying operation that is subject to §63.11507(f)(1) or (2).

(3) If you own or operate an affected flash or short-term electroplating tank that is subject to the requirements in §63.11507(b), "What are my standards and management practices?" and you comply with §11507(a), (b) or (c) of this subpart by limiting the plating time of the affected tank, you must state in your annual compliance certification that you have limited short-term or flash electroplating to no more than 1 cumulative hour per day or 3 cumulative minutes per hour of plating time.

(4) If you own or operate an affected batch electrolytic process tank that is subject to the requirements of §63.11507(a) or a flash or short-term electroplating tank that is subject to the requirements in §63.11507(b), "What are my standards and management practices?" and you comply with §11507(a), (b) or (c) of this subpart by operating the affected tank with a cover, you must state in your annual certification that you have operated the tank with the cover in place at least 95 percent of the electrolytic process time.

(5) If you own or operate an affected continuous electrolytic process tank that is subject to the requirements of §63.11507(a), "What are my standards and management practices?" and you comply with §11507(a), (b) or (c) of this subpart by operating the affected tank with a cover, you must state in your annual certification that you have covered at least 75 percent of the surface area of the tank during all periods of electrolytic process operation.

(6) If you own or operate an affected tank or other affected plating and polishing operation that is subject to the management practices specified in §63.11507(g), "What are my standards and management practices?" you must state in your annual compliance certification that you have implemented the applicable management practices, as practicable.

(7) Each annual compliance report must be prepared no later than January 31 of the year immediately following the reporting period and kept in a readily-accessible location for inspector review. If a deviation has occurred during the year, each annual compliance report must be submitted along with the deviation report, and postmarked or delivered no later than January 31 of the year immediately following the reporting period.

(d) If you own or operate an affected source, and any deviations from the compliance requirements specified in this subpart occurred during the year, you must report the deviations, along with the corrective action taken, and submit this report to the delegated authority.

(e) You must keep the records specified in paragraphs (e)(1) through (3) of this section.

(1) A copy of any Initial Notification and Notification of Compliance Status that you submitted and all documentation supporting those notifications.

(2) The records specified in §63.10(b)(2)(i) through (iii) and (xiv) of the General Provisions of this part.

(3) The records required to show continuous compliance with each management practice and equipment standard that applies to you, as specified in §63.11508(d), "What are my compliance requirements?"

(f) You must keep each record for a minimum of 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record. You must keep each record onsite for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to §63.10(b)(1) of the General Provisions to part 63. You may keep the records offsite for the remaining 3 years.

[73 FR 37741, July 1, 2008, as amended at 76 FR 57920, Sept. 19, 2011]

## **Other Requirements and Information**

**§ 63.11510 What General Provisions apply to this subpart?**

If you own or operate a new or existing affected source, you must comply with the requirements of the General Provisions (40 CFR part 63, subpart A) according to Table 1 of this subpart.

### **§ 63.11511 What definitions apply to this subpart?**

Terms used in this subpart are defined in this section.

*Batch electrolytic process tank* means a tank used for an electrolytic process in which a part or group of parts, typically mounted on racks or placed in barrels, is placed in the tank and immersed in an electrolytic process solution as a single unit (i.e., as a batch) for a predetermined period of time, during which none of the parts are removed from the tank and no other parts are added to the tank, and after which the part or parts are removed from the tank as a unit.

*Bath* means the liquid contents of a tank, as defined in this section, which is used for electroplating, electroforming, electropolishing, or other metal coating processes at a plating and polishing facility.

*Bench-scale* means any operation that is small enough to be performed on a bench, table, or similar structure so that the equipment is not directly contacting the floor.

*Capture system* means the collection of components used to capture gases and fumes released from one or more emissions points and then convey the captured gas stream to a control device, as part of a complete control system. A capture system may include, but is not limited to, the following components as applicable to a given capture system design: duct intake devices, hoods, enclosures, ductwork, dampers, manifolds, plenums, and fans.

*Cartridge filter* means a type of control device that uses perforated metal cartridges containing a pleated paper or non-woven fibrous filter media to remove PM from a gas stream by sieving and other mechanisms. Cartridge filters can be designed with single use cartridges, which are removed and disposed after reaching capacity, or continuous use cartridges, which typically are cleaned by means of a pulse-jet mechanism.

*Composite mesh pad* means a type of control device similar to a mesh pad mist eliminator except that the device is designed with multiple pads in series that are woven with layers of material with varying fiber diameters, which produce a coalescing effect on the droplets or PM that impinge upon the pads.

*Continuous electrolytic process tank* means a tank that uses an electrolytic process and in which a continuous metal strip or other type of continuous substrate is fed into and removed from the tank continuously. This process is also called reel-to-reel electrolytic plating.

*Control device* means equipment that is part of a control system that collects and/or reduces the quantity of a pollutant that is emitted to the air. The control device receives emissions that are transported from the process by the capture system.

*Control system* means the combination of a capture system and a control device. The capture system is designed to collect and transport air emissions from the affected source to the control device. The overall control efficiency of any control system is a combination of the ability of the system to capture the air emissions (i.e., the capture efficiency) and the control device efficiency. Consequently, it is important to achieve good capture to ensure good overall control efficiency. Capture devices that are known to provide high capture efficiencies include hoods, enclosures, or any other duct intake devices with ductwork, dampers, manifolds, plenums, or fans.

*Conversion coatings* are coatings that form a hard metal finish on an object when the object is submerged in a tank bath or solution that contains the conversion coatings. Conversion coatings for the purposes of this rule include coatings composed of chromium, as well as the other plating and polishing metal HAP, where no electrical current is used.

*Cyanide plating* means plating processes performed in tanks that use cyanide as a major bath ingredient and that operate at pH of 12 or more, and use or emit any of the plating and polishing metal HAP, as defined in this section. Electroplating and electroforming are performed with or without cyanide. The cyanide in the bath works to dissolve the HAP metal added as a cyanide compound (e.g., cadmium cyanide) and creates free cyanide in solution, which helps to corrode the anode. These tanks are self-regulating to a pH of 12 due to the caustic nature of the cyanide bath chemistry. The cyanide in the bath is a major bath constituent and not an additive; however, the self-regulating chemistry of the bath causes the bath to act as if wetting agents/fume suppressants are being used and to ensure an optimum plating process. All cyanide plating baths at pH greater than or equal to 12 have cyanide-metal complexes in solution. The metal HAP to be plated is not emitted because it is either bound in the metal-cyanide complex or reduced at the cathode to elemental metal, and plated onto the immersed parts. Cyanide baths are not intentionally operated at pH less 12 since unfavorable plating conditions would occur in the tank, among other negative effects.

*Deviation* means any instance in which an affected source or an owner or operator of such an affected source:

- (1) Fails to meet any requirement or obligation established by this rule including, but not limited to, any equipment standard (including emissions and operating limits), management practice, or operation and maintenance requirement;
- (2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this rule and that is included in the operating permit for any affected facility required to obtain such a permit; or
- (3) Fails to meet any equipment standard (including emission and operating limits), management standard, or operation and maintenance requirement in this rule during startup, shutdown, or malfunction.

*Dry mechanical polishing* means a process used for removing defects from and smoothing the surface of finished metals and formed products after plating or thermal spraying with any of the plating and polishing metal HAP, as defined in this section, using automatic or manually-operated machines that have hard-faced abrasive wheels or belts and where no liquids or fluids are used to trap the removed metal particles. The affected process does not include polishing with use of pastes, liquids, lubricants, or any other added materials.

*Electroforming* means an electrolytic process using or emitting any of the plating and polishing metal HAP, as defined in this section, that is used for fabricating metal parts. This process is essentially the same as electroplating except that the plated substrate (mandrel) is removed, leaving only the metal plate. In electroforming, the metal plate is self-supporting and generally thicker than in electroplating.

*Electroless plating* means a non-electrolytic process that uses or emits any of the plating and polishing metal HAP, as defined in this section, in which metallic ions in a plating bath or solution are reduced to form a metal coating at the surface of a catalytic substrate without the use of external electrical energy. Electroless plating is also called non-electrolytic plating. Examples include, but are not limited to, chromate conversion coating, nickel acetate sealing, sodium dichromate sealing, and manganese phosphate coating.

*Electrolytic plating processes* means electroplating and electroforming that use or emit any of the plating and polishing metal HAP, as defined in this section, where metallic ions in a plating bath or solution are reduced to form a metal coating on the surface of parts and products using electrical energy.

*Electroplating* means an electrolytic process that uses or emits any of the plating and polishing metal HAP, as defined in this section, in which metal ions in solution are reduced onto the surface of the work piece (the cathode) via an electrical current. The metal ions in the solution are usually replenished by the



dissolution of metal from solid metal anodes fabricated of the same metal being plated, or by direct replenishment of the solution with metal salts or oxides; electroplating is also called electrolytic plating.

*Electropolishing* means an electrolytic process performed in a tank after plating that uses or emits any of the plating and polishing metal HAP, as defined in this section, in which a work piece is attached to an anode immersed in a bath, and the metal substrate is dissolved electrolytically, thereby removing the surface contaminant; electropolishing is also called electrolytic polishing. For the purposes of this subpart, electropolishing does not include bench-scale operations.

*Fabric filter* means a type of control device used for collecting PM by filtering a process exhaust stream through a filter or filter media. A fabric filter is also known as a baghouse.

*Filters*, for the purposes of this part, include cartridge, fabric, or HEPA filters, as defined in this section.

*Flash electroplating* means an electrolytic process performed in a tank that uses or emits any of the plating and polishing metal HAP, as defined in this section, and that is used no more than 3 cumulative minutes per hour or no more than 1 cumulative hour per day.

*General Provisions of this part (40 CFR part 63, subpart A)* means the section of the Code of Federal Regulations (CFR) that addresses air pollution rules that apply to all HAP sources addressed in part 63, which includes the National Emission Standards for Hazardous Air Pollutants (NESHAP).

*HAP* means hazardous air pollutant as defined from the list of 188 chemicals and compounds specified in the CAA Amendments of 1990; HAP are also called "air toxics." The five plating and polishing metal HAP, as defined in this section, are on this list of 188 chemicals.

*High efficiency particulate air (HEPA) filter* means a type of control device that uses a filter composed of a mat of randomly arranged fibers and is designed to remove at least 99.97 percent of airborne particles that are 0.3 micrometers or larger in diameter.

*Maintenance* is any process at a plating and polishing facility that is performed to keep the process equipment or the facility operating properly and is not performed on items to be sold as products.

*Major facility for HAP* is any facility that emits greater than 10 tpy of any HAP, or that emits a combined total of all HAP of over 25 tpy, where the HAP used to determine the total facility emissions are not restricted to only plating and polishing metal HAP or from only plating and polishing operations.

*Mesh pad mist eliminator* means a type of control device, consisting of layers of interlocked filaments densely packed between two supporting grids that remove liquid droplets and PM from the gas stream through inertial impaction and direct interception.

*Metal coating operation* means any process performed either in a tank that contains liquids or as part of a thermal spraying operation, that applies one or more plating and polishing metal HAP, as defined in this section, to the surface of parts and products used in manufacturing. These processes include but are not limited to: non-chromium electroplating; electroforming; electropolishing; non-electrolytic metal coating processes, such as chromate conversion coating, electroless nickel plating, nickel acetate sealing, sodium dichromate sealing, and manganese phosphate coating; and thermal or flame spraying.

*Metal HAP content of material used in plating and polishing* is the HAP content as determined from an analysis or engineering estimate of the HAP contents of the tank bath or solution, in the case of plating, metal coating, or electropolishing; or the HAP content of the metal coating being applied in the case of thermal spraying. Safety data sheet (SDS) information may be used in lieu of testing or engineering estimates but is not required to be used.

*New source* means any affected source for which you commenced construction or reconstruction after March 14, 2008.

*Non-cyanide electrolytic plating and electropolishing processes* means electroplating, electroforming, and electropolishing that uses or emits any of the plating and polishing metal HAP, as defined in this section, performed without cyanide in the tank. These processes do not use cyanide in the tank and operate at pH values less than 12. These processes use electricity and add or remove metals such as metal HAP from parts and products used in manufacturing. Both electroplating and electroforming can be performed with cyanide as well.

*Non-electrolytic plating* means a process that uses or emits any of the plating and polishing metal HAP, as defined in this section, in which metallic ions in a plating bath or solution are reduced to form a metal coating at the surface of a catalytic substrate without the use of external electrical energy. Non-electrolytic plating is also called electroless plating. Examples include chromate conversion coating, nickel acetate sealing, electroless nickel plating, sodium dichromate sealing, and manganese phosphate coating.

*Packed-bed scrubber* means a type of control device that includes a single or double packed bed that contains packing media on which PM and droplets impinge and are removed from the gas stream. The packed-bed section of the scrubber is followed by a mist eliminator to remove any water entrained from the packed-bed section.

*Plating and polishing facility* means a facility engaged in one or more of the following processes that uses or emits any of the plating and polishing metal HAP, as defined in this section: electroplating processes other than chromium electroplating ( *i.e.*, non-chromium electroplating); electroless plating; other non-electrolytic metal coating processes performed in a tank, such as chromate conversion coating, nickel acetate sealing, sodium dichromate sealing, and manganese phosphate coating; thermal spraying; and the dry mechanical polishing of finished metals and formed products after plating or thermal spraying. Plating is performed in a tank or thermally sprayed so that a metal coating is irreversibly applied to an object. Plating and polishing does not include any bench-scale processes.

*Plating and polishing metal HAP* means any compound of any of the following metals: cadmium, chromium, lead, manganese, and nickel, or any of these metals in the elemental form, with the exception of lead. Any material that does not contain cadmium, chromium, lead, or nickel in amounts greater than or equal to 0.1 percent by weight (as the metal), and does not contain manganese in amounts greater than or equal to 1.0 percent by weight (as the metal), as reported on the Material Safety Data Sheet for the material, is not considered to be a plating and polishing metal HAP.

*Plating and polishing process tanks* means any tank in which a process is performed at an affected plating and polishing facility that uses or has the potential to emit any of the plating and polishing metal HAP, as defined in this section. The processes performed in plating and polishing tanks include the following: electroplating processes other than chromium electroplating ( *i.e.*, non-chromium electroplating) performed in a tank; electroless plating; and non-electrolytic metal coating processes, such as chromate conversion coating, nickel acetate sealing, sodium dichromate sealing, and manganese phosphate coating; and electropolishing. This term does not include tanks containing solutions that are used to clean, rinse or wash parts prior to placing the parts in a plating and polishing process tank, or subsequent to removing the parts from a plating and polishing process tank. This term also does not include any bench-scale operations.

*PM* means solid or particulate matter that is emitted into the air.

*Repair* means any process used to return a finished object or tool back to its original function or shape.

*Research and development process unit* means any process unit that is used for conducting research and development for new processes and products and is not used to manufacture products for commercial sale, except in a *de minimis* manner.

*Short-term plating* means an electroplating process that uses or emits any of the plating and polishing metal HAP, as defined in this section, and that is used no more than 3 cumulative minutes per hour or 1 hour cumulative per day.

*Startup of the tank bath* is when the components or relative proportions of the various components in the bath have been altered from the most recent operating period. Startup of the bath does not include events where only the tank's heating or agitation and other mechanical operations are turned back on after being turned off for a period of time.

*Tank cover* for batch process units means a solid structure made of an impervious material that is designed to cover the entire open surface of a tank or process unit that is used for plating or other metal coating processes.

*Tank cover* for continuous process units, means a solid structure or combination of structures, made of an impervious material that is designed to cover at least 75 percent of the open surface of the tank or process unit that is used for continuous plating or other continuous metal coating processes.

*Temporary thermal spraying* means a thermal spraying operation that uses or emits any of the plating and polishing metal HAP, as defined in this section, and that lasts no more than 1 hour in duration during any one day and is conducted in situ. Thermal spraying that is conducted in a dedicated thermal spray booth or structure is not considered to be temporary thermal spraying.

*Thermal spraying* (also referred to as metal spraying or flame spraying) is a process that uses or emits any of the plating and polishing metal HAP, as defined in this section, in which a metallic coating is applied by projecting heated, molten, or semi-molten metal particles onto a substrate. Commonly-used thermal spraying methods include high velocity oxy-fuel (HVOF) spraying, flame spraying, electric arc spraying, plasma arc spraying, and detonation gun spraying. This operation does not include spray painting at ambient temperatures.

*Water curtain* means a type of control device that draws the exhaust stream through a continuous curtain of moving water to scrub out suspended PM.

*Wetting agent/fume suppressant* means any chemical agent that reduces or suppresses fumes or mists from a plating and polishing tank by reducing the surface tension of the tank bath.

[73 FR 37741, July 1, 2008, as amended at 76 FR 57921, Sept. 19, 2011]

#### **§ 63.11512 Who implements and enforces this subpart?**

(a) This subpart can be implemented and enforced by EPA or a delegated authority such as your State, local, or tribal agency. If the EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency, in addition to EPA, has the authority to implement and enforce this subpart. You should contact your EPA Regional Office to find out if implementation and enforcement of this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under 40 CFR part 63, subpart E, the authorities contained in paragraph (c) of this section are retained by the EPA Administrator and are not transferred to the State, local, or tribal agency.

(c) The authorities that cannot be delegated to State, local, or tribal agencies are specified in paragraphs (c)(1) through (5) of this section.

(1) Approval of an alternative non-opacity emissions standard under 40 CFR 63.6(g), of the General Provisions of this part.

(2) Approval of an alternative opacity emissions standard under §63.6(h)(9), of the General Provisions of this part.

(3) Approval of a major change to test methods under §63.7(e)(2)(ii) and (f), of the General Provisions of this part. A “major change to test method” is defined in §63.90.

(4) Approval of a major change to monitoring under §63.8(f), of the General Provisions of this part. A “major change to monitoring” is defined in §63.90.

(5) Approval of a major change to recordkeeping and reporting under §63.10(f), of the General Provisions of this part. A “major change to recordkeeping/reporting” is defined in §63.90.

#### **§ 63.11513 [Reserved]**

#### **Table 1 to Subpart WWWWWW of Part 63—Applicability of General Provisions to Plating and Polishing Area Sources**

As required in §63.11510, “What General Provisions apply to this subpart?”, you must meet each requirement in the following table that applies to you.

| <b>Citation</b>   | <b>Subject</b>  |
|---|---|
| 63.1 <sup>1</sup>   | Applicability.  |
| 63.2  | Definitions.  |
| 63.3  | Units and abbreviations.  |
| 63.4  | Prohibited activities.  |
| 63.6(a), (b)(1)–(b)(5), (c)(1), (c)(2), (c)(5), and (j)       | Compliance with standards and maintenance requirements.                     |
| 63.10(a), (b)(1), (b)(2)(i)–(iii), (xiv), (b)(3), (d)(1), (f) | Recordkeeping and reporting.  |
| 63.12   | State authority and delegations.  |
| 63.13   | Addresses of State air pollution control agencies and EPA regional offices. |
| 63.14   | Incorporation by reference.   |
| 63.15   | Availability of information and confidentiality.                            |

<sup>1</sup>Section 63.11505(e), “What parts of my plant does this subpart cover?”, exempts affected sources from the obligation to obtain title V operating permits.

## **Attachment E**

### **Title 40: Protection of Environment**

#### **PART 60 — STANDARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES**

##### **Subpart KKKK—Standards of Performance for Stationary Combustion Turbines**

SOURCE: 71 FR 38497, July 6, 2006, unless otherwise noted.

##### **Introduction**

##### **§ 60.4300 What is the purpose of this subpart?**

This subpart establishes emission standards and compliance schedules for the control of emissions from stationary combustion turbines that commenced construction, modification or reconstruction after February 18, 2005.

##### **Applicability**

##### **§ 60.4305 Does this subpart apply to my stationary combustion turbine?**

(a) If you are the owner or operator of a stationary combustion turbine with a heat input at peak load equal to or greater than 10.7 gigajoules (10 MMBtu) per hour, based on the higher heating value of the fuel, which commenced construction, modification, or reconstruction after February 18, 2005, your turbine is subject to this subpart. Only heat input to the combustion turbine should be included when determining whether or not this subpart is applicable to your turbine. Any additional heat input to associated heat recovery steam generators (HRSG) or duct burners should not be included when determining your peak heat input. However, this subpart does apply to emissions from any associated HRSG and duct burners.

(b) Stationary combustion turbines regulated under this subpart are exempt from the requirements of subpart GG of this part. Heat recovery steam generators and duct burners regulated under this subpart are exempted from the requirements of subparts Da, Db, and Dc of this part.

##### **§ 60.4310 What types of operations are exempt from these standards of performance?**

(a) Emergency combustion turbines, as defined in § 60.4420(i), are exempt from the nitrogen oxides (NO<sub>x</sub>) emission limits in § 60.4320.

(b) Stationary combustion turbines engaged by manufacturers in research and development of equipment for both combustion turbine emission control techniques and combustion turbine efficiency improvements are exempt from the NO<sub>x</sub> emission limits in § 60.4320 on a case-by-case basis as determined by the Administrator.

(c) Stationary combustion turbines at integrated gasification combined cycle electric utility steam generating units that are subject to subpart Da of this part are exempt from this subpart.

(d) Combustion turbine test cells/stands are exempt from this subpart.

## **Emission Limits**

### **§ 60.4315 What pollutants are regulated by this subpart?**

The pollutants regulated by this subpart are nitrogen oxide ( $\text{NO}_x$ ) and sulfur dioxide ( $\text{SO}_2$ ).

### **§ 60.4320 What emission limits must I meet for nitrogen oxides ( $\text{NO}_x$ )?**

(a) You must meet the emission limits for  $\text{NO}_x$  specified in Table 1 to this subpart.

(b) If you have two or more turbines that are connected to a single generator, each turbine must meet the emission limits for  $\text{NO}_x$ .

### **§ 60.4325 What emission limits must I meet for $\text{NO}_x$ if my turbine burns both natural gas and distillate oil (or some other combination of fuels)?**

You must meet the emission limits specified in Table 1 to this subpart. If your total heat input is greater than or equal to 50 percent natural gas, you must meet the corresponding limit for a natural gas-fired turbine when you are burning that fuel. Similarly, when your total heat input is greater than 50 percent distillate oil and fuels other than natural gas, you must meet the corresponding limit for distillate oil and fuels other than natural gas for the duration of the time that you burn that particular fuel.

### **§ 60.4330 What emission limits must I meet for sulfur dioxide ( $\text{SO}_2$ )?**

(a) If your turbine is located in a continental area, you must comply with either paragraph (a)(1), (a)(2), or (a)(3) of this section. If your turbine is located in Alaska, you do not have to comply with the requirements in paragraph (a) of this section until January 1, 2008.

(1) You must not cause to be discharged into the atmosphere from the subject stationary combustion turbine any gases which contain  $\text{SO}_2$  in excess of 110 nanograms per Joule (ng/J) (0.90 pounds per megawatt-hour (lb/MWh)) gross output;

(2) You must not burn in the subject stationary combustion turbine any fuel which contains total potential sulfur emissions in excess of 26 ng  $\text{SO}_2$  /J (0.060 lb  $\text{SO}_2$  /MMBtu) heat input. If your turbine simultaneously fires multiple fuels, each fuel must meet this requirement; or

(3) For each stationary combustion turbine burning at least 50 percent biogas on a calendar month basis, as determined based on total heat input, you must not cause to be discharged into the atmosphere from the affected source any gases that contain  $\text{SO}_2$  in excess of 65 ng  $\text{SO}_2$  /J (0.15 lb  $\text{SO}_2$  /MMBtu) heat input.

(b) If your turbine is located in a noncontinental area or a continental area that the Administrator determines does not have access to natural gas and that the removal of sulfur compounds would cause more environmental harm than benefit, you must comply with one or the other of the following conditions:

(1) You must not cause to be discharged into the atmosphere from the subject stationary combustion turbine any gases which contain  $\text{SO}_2$  in excess of 780 ng/J (6.2 lb/MWh) gross output, or

(2) You must not burn in the subject stationary combustion turbine any fuel which contains total sulfur with potential sulfur emissions in excess of 180 ng  $\text{SO}_2$  /J (0.42 lb  $\text{SO}_2$  /MMBtu) heat input. If your turbine simultaneously fires multiple fuels, each fuel must meet this requirement.

## **General Compliance Requirements**

### **§ 60.4333 What are my general requirements for complying with this subpart?**

(a) You must operate and maintain your stationary combustion turbine, air pollution control equipment, and monitoring equipment in a manner consistent with good air pollution control practices for minimizing emissions at all times including during startup, shutdown, and malfunction.

(b) When an affected unit with heat recovery utilizes a common steam header with one or more combustion turbines, the owner or operator shall either:

(1) Determine compliance with the applicable NO<sub>x</sub> emissions limits by measuring the emissions combined with the emissions from the other unit(s) utilizing the common heat recovery unit; or

(2) Develop, demonstrate, and provide information satisfactory to the Administrator on methods for apportioning the combined gross energy output from the heat recovery unit for each of the affected combustion turbines. The Administrator may approve such demonstrated substitute methods for apportioning the combined gross energy output measured at the steam turbine whenever the demonstration ensures accurate estimation of emissions related under this part.

## **Monitoring**

### **§ 60.4335 How do I demonstrate compliance for NO<sub>x</sub> if I use water or steam injection?**

(a) If you are using water or steam injection to control NO<sub>x</sub> emissions, you must install, calibrate, maintain and operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water or steam to fuel being fired in the turbine when burning a fuel that requires water or steam injection for compliance.

(b) Alternatively, you may use continuous emission monitoring, as follows:

(1) Install, certify, maintain, and operate a continuous emission monitoring system (CEMS) consisting of a NO<sub>x</sub> monitor and a diluent gas (oxygen (O<sub>2</sub>) or carbon dioxide (CO<sub>2</sub>)) monitor, to determine the hourly NO<sub>x</sub> emission rate in parts per million (ppm) or pounds per million British thermal units (lb/MMBtu); and

(2) For units complying with the output-based standard, install, calibrate, maintain, and operate a fuel flow meter (or flow meters) to continuously measure the heat input to the affected unit; and

(3) For units complying with the output-based standard, install, calibrate, maintain, and operate a watt meter (or meters) to continuously measure the gross electrical output of the unit in megawatt-hours; and

(4) For combined heat and power units complying with the output-based standard, install, calibrate, maintain, and operate meters for useful recovered energy flow rate, temperature, and pressure, to continuously measure the total thermal energy output in British thermal units per hour (Btu/h).

### **§ 60.4340 How do I demonstrate continuous compliance for NO<sub>x</sub> if I do not use water or steam injection?**

(a) If you are not using water or steam injection to control NO<sub>x</sub> emissions, you must perform annual performance tests in accordance with § 60.4400 to demonstrate continuous compliance. If the NO<sub>x</sub> emission result from the performance test is less than or equal to 75 percent of the NO<sub>x</sub> emission limit for the turbine, you may reduce the frequency of subsequent performance tests to once every 2 years (no more than 26 calendar months following the previous performance test). If the results of any subsequent

performance test exceed 75 percent of the NO<sub>x</sub> emission limit for the turbine, you must resume annual performance tests.

(b) As an alternative, you may install, calibrate, maintain and operate one of the following continuous monitoring systems:

(1) Continuous emission monitoring as described in §§ 60.4335(b) and 60.4345, or

(2) Continuous parameter monitoring as follows:

(i) For a diffusion flame turbine without add-on selective catalytic reduction (SCR) controls, you must define parameters indicative of the unit's NO<sub>x</sub> formation characteristics, and you must monitor these parameters continuously.

(ii) For any lean premix stationary combustion turbine, you must continuously monitor the appropriate parameters to determine whether the unit is operating in low-NO<sub>x</sub> mode.

(iii) For any turbine that uses SCR to reduce NO<sub>x</sub> emissions, you must continuously monitor appropriate parameters to verify the proper operation of the emission controls.

(iv) For affected units that are also regulated under part 75 of this chapter, with state approval you can monitor the NO<sub>x</sub> emission rate using the methodology in appendix E to part 75 of this chapter, or the low mass emissions methodology in § 75.19, the requirements of this paragraph (b) may be met by performing the parametric monitoring described in section 2.3 of part 75 appendix E or in § 75.19(c)(1)(iv)(H).

**§ 60.4345 What are the requirements for the continuous emission monitoring system equipment, if I choose to use this option?**

If the option to use a NO<sub>x</sub> CEMS is chosen:

(a) Each NO<sub>x</sub> diluent CEMS must be installed and certified according to Performance Specification 2 (PS 2) in appendix B to this part, except the 7-day calibration drift is based on unit operating days, not calendar days. With state approval, Procedure 1 in appendix F to this part is not required. Alternatively, a NO<sub>x</sub> diluent CEMS that is installed and certified according to appendix A of part 75 of this chapter is acceptable for use under this subpart. The relative accuracy test audit (RATA) of the CEMS shall be performed on a lb/MMBtu basis.

(b) As specified in § 60.13(e)(2), during each full unit operating hour, both the NO<sub>x</sub> monitor and the diluent monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained with each monitor for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required for each monitor to validate the NO<sub>x</sub> emission rate for the hour.

(c) Each fuel flowmeter shall be installed, calibrated, maintained, and operated according to the manufacturer's instructions. Alternatively, with state approval, fuel flowmeters that meet the installation, certification, and quality assurance requirements of appendix D to part 75 of this chapter are acceptable for use under this subpart.

(d) Each watt meter, steam flow meter, and each pressure or temperature measurement device shall be installed, calibrated, maintained, and operated according to manufacturer's instructions.



(e) The owner or operator shall develop and keep on-site a quality assurance (QA) plan for all of the continuous monitoring equipment described in paragraphs (a), (c), and (d) of this section. For the CEMS and fuel flow meters, the owner or operator may, with state approval, satisfy the requirements of this paragraph by implementing the QA program and plan described in section 1 of appendix B to part 75 of this chapter.

**§ 60.4350 How do I use data from the continuous emission monitoring equipment to identify excess emissions?**

For purposes of identifying excess emissions:

(a) All CEMS data must be reduced to hourly averages as specified in § 60.13(h).

(b) For each unit operating hour in which a valid hourly average, as described in § 60.4345(b), is obtained for both NO<sub>x</sub> and diluent monitors, the data acquisition and handling system must calculate and record the hourly NO<sub>x</sub> emission rate in units of ppm or lb/MMBtu, using the appropriate equation from method 19 in appendix A of this part. For any hour in which the hourly average O<sub>2</sub> concentration exceeds 19.0 percent O<sub>2</sub> (or the hourly average CO<sub>2</sub> concentration is less than 1.0 percent CO<sub>2</sub>), a diluent cap value of 19.0 percent O<sub>2</sub> or 1.0 percent CO<sub>2</sub> (as applicable) may be used in the emission calculations.

(c) Correction of measured NO<sub>x</sub> concentrations to 15 percent O<sub>2</sub> is not allowed.

(d) If you have installed and certified a NO<sub>x</sub> diluent CEMS to meet the requirements of part 75 of this chapter, states can approve that only quality assured data from the CEMS shall be used to identify excess emissions under this subpart. Periods where the missing data substitution procedures in subpart D of part 75 are applied are to be reported as monitor downtime in the excess emissions and monitoring performance report required under § 60.7(c).

(e) All required fuel flow rate, steam flow rate, temperature, pressure, and megawatt data must be reduced to hourly averages.

(f) Calculate the hourly average NO<sub>x</sub> emission rates, in units of the emission standards under § 60.4320, using either ppm for units complying with the concentration limit or the following equation for units complying with the output based standard:

(1) For simple-cycle operation:

$$E = \frac{(\text{NO}_x)_h * (\text{HI})_h}{P} \quad (\text{Eq. 1})$$

Where:

E = hourly NO<sub>x</sub> emission rate, in lb/MWh,

(NO<sub>x</sub>)<sub>h</sub> = hourly NO<sub>x</sub> emission rate, in lb/MMBtu,

(HI)<sub>h</sub> = hourly heat input rate to the unit, in MMBtu/h, measured using the fuel flowmeter(s), e.g., calculated using Equation D-15a in appendix D to part 75 of this chapter, and

P = gross energy output of the combustion turbine in MW.

(2) For combined-cycle and combined heat and power complying with the output-based standard, use Equation 1 of this subpart, except that the gross energy output is calculated as the sum of the total

electrical and mechanical energy generated by the combustion turbine, the additional electrical or mechanical energy (if any) generated by the steam turbine following the heat recovery steam generator, and 100 percent of the total useful thermal energy output that is not used to generate additional electricity or mechanical output, expressed in equivalent MW, as in the following equations:

$$P = (Pe)_t + (Pe)_c + Ps + Po \quad (\text{Eq. 2})$$

Where:

P = gross energy output of the stationary combustion turbine system in MW.

$(Pe)_t$  = electrical or mechanical energy output of the combustion turbine in MW,

$(Pe)_c$  = electrical or mechanical energy output (if any) of the steam turbine in MW, and

$$Ps = \frac{Q * H}{3.413 \times 10^6 \text{ Btu/MWh}} \quad (\text{Eq. 3})$$

Where:

Ps = useful thermal energy of the steam, measured relative to ISO conditions, not used to generate additional electric or mechanical output, in MW,

Q = measured steam flow rate in lb/h,

H = enthalpy of the steam at measured temperature and pressure relative to ISO conditions, in Btu/lb, and  $3.413 \times 10^6$  = conversion from Btu/h to MW.

Po = other useful heat recovery, measured relative to ISO conditions, not used for steam generation or performance enhancement of the combustion turbine.

(3) For mechanical drive applications complying with the output-based standard, use the following equation:

$$E = \frac{(NO_x)_m}{BL * AL} \quad (\text{Eq. 4})$$

Where:

E = NO<sub>x</sub> emission rate in lb/MWh,

$(NO_x)_m$  = NO<sub>x</sub> emission rate in lb/h,

BL = manufacturer's base load rating of turbine, in MW, and

AL = actual load as a percentage of the base load.

(g) For simple cycle units without heat recovery, use the calculated hourly average emission rates from paragraph (f) of this section to assess excess emissions on a 4-hour rolling average basis, as described in § 60.4380(b)(1).

(h) For combined cycle and combined heat and power units with heat recovery, use the calculated hourly average emission rates from paragraph (f) of this section to assess excess emissions on a 30 unit operating day rolling average basis, as described in § 60.4380(b)(1).

**§ 60.4355 How do I establish and document a proper parameter monitoring plan?**

(a) The steam or water to fuel ratio or other parameters that are continuously monitored as described in §§ 60.4335 and 60.4340 must be monitored during the performance test required under § 60.8, to establish acceptable values and ranges. You may supplement the performance test data with engineering analyses, design specifications, manufacturer's recommendations and other relevant information to define the acceptable parametric ranges more precisely. You must develop and keep on-site a parameter monitoring plan which explains the procedures used to document proper operation of the NO<sub>x</sub> emission controls. The plan must:

(1) Include the indicators to be monitored and show there is a significant relationship to emissions and proper operation of the NO<sub>x</sub> emission controls,

(2) Pick ranges (or designated conditions) of the indicators, or describe the process by which such range (or designated condition) will be established,

(3) Explain the process you will use to make certain that you obtain data that are representative of the emissions or parameters being monitored (such as detector location, installation specification if applicable),

(4) Describe quality assurance and control practices that are adequate to ensure the continuing validity of the data,

(5) Describe the frequency of monitoring and the data collection procedures which you will use (e.g., you are using a computerized data acquisition over a number of discrete data points with the average (or maximum value) being used for purposes of determining whether an exceedance has occurred), and

(6) Submit justification for the proposed elements of the monitoring. If a proposed performance specification differs from manufacturer recommendation, you must explain the reasons for the differences. You must submit the data supporting the justification, but you may refer to generally available sources of information used to support the justification. You may rely on engineering assessments and other data, provided you demonstrate factors which assure compliance or explain why performance testing is unnecessary to establish indicator ranges. When establishing indicator ranges, you may choose to simplify the process by treating the parameters as if they were correlated. Using this assumption, testing can be divided into two cases:

(i) All indicators are significant only on one end of range (e.g., for a thermal incinerator controlling volatile organic compounds (VOC) it is only important to insure a minimum temperature, not a maximum). In this case, you may conduct your study so that each parameter is at the significant limit of its range while you conduct your emissions testing. If the emissions tests show that the source is in compliance at the significant limit of each parameter, then as long as each parameter is within its limit, you are presumed to be in compliance.

(ii) Some or all indicators are significant on both ends of the range. In this case, you may conduct your study so that each parameter that is significant at both ends of its range assumes its extreme values in all possible combinations of the extreme values (either single or double) of all of the other parameters. For example, if there were only two parameters, A and B, and A had a range of values while B had only a minimum value, the combinations would be A high with B minimum and A low with B minimum. If both A and B had a range, the combinations would be A high and B high, A low and B low, A high and B low, A low and B high. For the case of four parameters all having a range, there are 16 possible combinations.

(b) For affected units that are also subject to part 75 of this chapter and that have state approval to use the low mass emissions methodology in § 75.19 or the NO<sub>x</sub> emission measurement methodology in appendix E to part 75, you may meet the requirements of this paragraph by developing and keeping on-

site (or at a central location for unmanned facilities) a QA plan, as described in § 75.19(e)(5) or in section 2.3 of appendix E to part 75 of this chapter and section 1.3.6 of appendix B to part 75 of this chapter.

**§ 60.4360 How do I determine the total sulfur content of the turbine's combustion fuel?**

You must monitor the total sulfur content of the fuel being fired in the turbine, except as provided in § 60.4365. The sulfur content of the fuel must be determined using total sulfur methods described in § 60.4415. Alternatively, if the total sulfur content of the gaseous fuel during the most recent performance test was less than half the applicable limit, ASTM D4084, D4810, D5504, or D6228, or Gas Processors Association Standard 2377 (all of which are incorporated by reference, see § 60.17), which measure the major sulfur compounds, may be used.

**§ 60.4365 How can I be exempted from monitoring the total sulfur content of the fuel?**

You may elect not to monitor the total sulfur content of the fuel combusted in the turbine, if the fuel is demonstrated not to exceed potential sulfur emissions of 26 ng SO<sub>2</sub> /J (0.060 lb SO<sub>2</sub> /MMBtu) heat input for units located in continental areas and 180 ng SO<sub>2</sub> /J (0.42 lb SO<sub>2</sub> /MMBtu) heat input for units located in noncontinental areas or a continental area that the Administrator determines does not have access to natural gas and that the removal of sulfur compounds would cause more environmental harm than benefit. You must use one of the following sources of information to make the required demonstration:

(a) The fuel quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the fuel, specifying that the maximum total sulfur content for oil use in continental areas is 0.05 weight percent (500 ppmw) or less and 0.4 weight percent (4,000 ppmw) or less for noncontinental areas, the total sulfur content for natural gas use in continental areas is 20 grains of sulfur or less per 100 standard cubic feet and 140 grains of sulfur or less per 100 standard cubic feet for noncontinental areas, has potential sulfur emissions of less than less than 26 ng SO<sub>2</sub> /J (0.060 lb SO<sub>2</sub> /MMBtu) heat input for continental areas and has potential sulfur emissions of less than less than 180 ng SO<sub>2</sub> /J (0.42 lb SO<sub>2</sub> /MMBtu) heat input for noncontinental areas; or

(b) Representative fuel sampling data which show that the sulfur content of the fuel does not exceed 26 ng SO<sub>2</sub> /J (0.060 lb SO<sub>2</sub> /MMBtu) heat input for continental areas or 180 ng SO<sub>2</sub> /J (0.42 lb SO<sub>2</sub> /MMBtu) heat input for noncontinental areas. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of appendix D to part 75 of this chapter is required.

**§ 60.4370 How often must I determine the sulfur content of the fuel?**

The frequency of determining the sulfur content of the fuel must be as follows:

(a) Fuel oil. For fuel oil, use one of the total sulfur sampling options and the associated sampling frequency described in sections 2.2.3, 2.2.4.1, 2.2.4.2, and 2.2.4.3 of appendix D to part 75 of this chapter ( i.e. , flow proportional sampling, daily sampling, sampling from the unit's storage tank after each addition of fuel to the tank, or sampling each delivery prior to combining it with fuel oil already in the intended storage tank).

(b) Gaseous fuel. If you elect not to demonstrate sulfur content using options in § 60.4365, and the fuel is supplied without intermediate bulk storage, the sulfur content value of the gaseous fuel must be determined and recorded once per unit operating day.

(c) Custom schedules. Notwithstanding the requirements of paragraph (b) of this section, operators or fuel vendors may develop custom schedules for determination of the total sulfur content of gaseous fuels, based on the design and operation of the affected facility and the characteristics of the fuel supply. Except as provided in paragraphs (c)(1) and (c)(2) of this section, custom schedules shall be

substantiated with data and shall be approved by the Administrator before they can be used to comply with the standard in § 60.4330.

(1) The two custom sulfur monitoring schedules set forth in paragraphs (c)(1)(i) through (iv) and in paragraph (c)(2) of this section are acceptable, without prior Administrative approval:

(i) The owner or operator shall obtain daily total sulfur content measurements for 30 consecutive unit operating days, using the applicable methods specified in this subpart. Based on the results of the 30 daily samples, the required frequency for subsequent monitoring of the fuel's total sulfur content shall be as specified in paragraph (c)(1)(ii), (iii), or (iv) of this section, as applicable.

(ii) If none of the 30 daily measurements of the fuel's total sulfur content exceeds half the applicable standard, subsequent sulfur content monitoring may be performed at 12-month intervals. If any of the samples taken at 12-month intervals has a total sulfur content greater than half but less than the applicable limit, follow the procedures in paragraph (c)(1)(iii) of this section. If any measurement exceeds the applicable limit, follow the procedures in paragraph (c)(1)(iv) of this section.

(iii) If at least one of the 30 daily measurements of the fuel's total sulfur content is greater than half but less than the applicable limit, but none exceeds the applicable limit, then:

(A) Collect and analyze a sample every 30 days for 3 months. If any sulfur content measurement exceeds the applicable limit, follow the procedures in paragraph (c)(1)(iv) of this section. Otherwise, follow the procedures in paragraph (c)(1)(iii)(B) of this section.

(B) Begin monitoring at 6-month intervals for 12 months. If any sulfur content measurement exceeds the applicable limit, follow the procedures in paragraph (c)(1)(iv) of this section. Otherwise, follow the procedures in paragraph (c)(1)(iii)(C) of this section.

(C) Begin monitoring at 12-month intervals. If any sulfur content measurement exceeds the applicable limit, follow the procedures in paragraph (c)(1)(iv) of this section. Otherwise, continue to monitor at this frequency.

(iv) If a sulfur content measurement exceeds the applicable limit, immediately begin daily monitoring according to paragraph (c)(1)(i) of this section. Daily monitoring shall continue until 30 consecutive daily samples, each having a sulfur content no greater than the applicable limit, are obtained. At that point, the applicable procedures of paragraph (c)(1)(ii) or (iii) of this section shall be followed.

(2) The owner or operator may use the data collected from the 720-hour sulfur sampling demonstration described in section 2.3.6 of appendix D to part 75 of this chapter to determine a custom sulfur sampling schedule, as follows:

(i) If the maximum fuel sulfur content obtained from the 720 hourly samples does not exceed 20 grains/100 scf, no additional monitoring of the sulfur content of the gas is required, for the purposes of this subpart.

(ii) If the maximum fuel sulfur content obtained from any of the 720 hourly samples exceeds 20 grains/100 scf, but none of the sulfur content values (when converted to weight percent sulfur) exceeds half the applicable limit, then the minimum required sampling frequency shall be one sample at 12 month intervals.

(iii) If any sample result exceeds half the applicable limit, but none exceeds the applicable limit, follow the provisions of paragraph (c)(1)(iii) of this section.

(iv) If the sulfur content of any of the 720 hourly samples exceeds the applicable limit, follow the provisions of paragraph (c)(1)(iv) of this section.

## **Reporting**

### **§ 60.4375 What reports must I submit?**

(a) For each affected unit required to continuously monitor parameters or emissions, or to periodically determine the fuel sulfur content under this subpart, you must submit reports of excess emissions and monitor downtime, in accordance with § 60.7(c). Excess emissions must be reported for all periods of unit operation, including start-up, shutdown, and malfunction.

(b) For each affected unit that performs annual performance tests in accordance with § 60.4340(a), you must submit a written report of the results of each performance test before the close of business on the 60th day following the completion of the performance test.

### **§ 60.4380 How are excess emissions and monitor downtime defined for NO<sub>x</sub> ?**

For the purpose of reports required under § 60.7(c), periods of excess emissions and monitor downtime that must be reported are defined as follows:

(a) For turbines using water or steam to fuel ratio monitoring:

(1) An excess emission is any unit operating hour for which the 4-hour rolling average steam or water to fuel ratio, as measured by the continuous monitoring system, falls below the acceptable steam or water to fuel ratio needed to demonstrate compliance with § 60.4320, as established during the performance test required in § 60.8. Any unit operating hour in which no water or steam is injected into the turbine when a fuel is being burned that requires water or steam injection for NO<sub>x</sub> control will also be considered an excess emission.

(2) A period of monitor downtime is any unit operating hour in which water or steam is injected into the turbine, but the essential parametric data needed to determine the steam or water to fuel ratio are unavailable or invalid.

(3) Each report must include the average steam or water to fuel ratio, average fuel consumption, and the combustion turbine load during each excess emission.

(b) For turbines using continuous emission monitoring, as described in §§ 60.4335(b) and 60.4345:

(1) An excess emissions is any unit operating period in which the 4-hour or 30-day rolling average NO<sub>x</sub> emission rate exceeds the applicable emission limit in § 60.4320. For the purposes of this subpart, a "4-hour rolling average NO<sub>x</sub> emission rate" is the arithmetic average of the average NO<sub>x</sub> emission rate in ppm or ng/J (lb/MWh) measured by the continuous emission monitoring equipment for a given hour and the three unit operating hour average NO<sub>x</sub> emission rates immediately preceding that unit operating hour. Calculate the rolling average if a valid NO<sub>x</sub> emission rate is obtained for at least 3 of the 4 hours. For the purposes of this subpart, a "30-day rolling average NO<sub>x</sub> emission rate" is the arithmetic average of all hourly NO<sub>x</sub> emission data in ppm or ng/J (lb/MWh) measured by the continuous emission monitoring equipment for a given day and the twenty-nine unit operating days immediately preceding that unit operating day. A new 30-day average is calculated each unit operating day as the average of all hourly NO<sub>x</sub> emissions rates for the preceding 30 unit operating days if a valid NO<sub>x</sub> emission rate is obtained for at least 75 percent of all operating hours.

(2) A period of monitor downtime is any unit operating hour in which the data for any of the following parameters are either missing or invalid: NO<sub>x</sub> concentration, CO<sub>2</sub> or O<sub>2</sub> concentration, fuel flow rate, steam flow rate, steam temperature, steam pressure, or megawatts. The steam flow rate, steam temperature, and steam pressure are only required if you will use this information for compliance purposes.

(3) For operating periods during which multiple emissions standards apply, the applicable standard is the average of the applicable standards during each hour. For hours with multiple emissions standards, the applicable limit for that hour is determined based on the condition that corresponded to the highest emissions standard.

(c) For turbines required to monitor combustion parameters or parameters that document proper operation of the NO<sub>x</sub> emission controls:

(1) An excess emission is a 4-hour rolling unit operating hour average in which any monitored parameter does not achieve the target value or is outside the acceptable range defined in the parameter monitoring plan for the unit.

(2) A period of monitor downtime is a unit operating hour in which any of the required parametric data are either not recorded or are invalid.

#### **§ 60.4385 How are excess emissions and monitoring downtime defined for SO<sub>2</sub> ?**

If you choose the option to monitor the sulfur content of the fuel, excess emissions and monitoring downtime are defined as follows:

(a) For samples of gaseous fuel and for oil samples obtained using daily sampling, flow proportional sampling, or sampling from the unit's storage tank, an excess emission occurs each unit operating hour included in the period beginning on the date and hour of any sample for which the sulfur content of the fuel being fired in the combustion turbine exceeds the applicable limit and ending on the date and hour that a subsequent sample is taken that demonstrates compliance with the sulfur limit.

(b) If the option to sample each delivery of fuel oil has been selected, you must immediately switch to one of the other oil sampling options (i.e., daily sampling, flow proportional sampling, or sampling from the unit's storage tank) if the sulfur content of a delivery exceeds 0.05 weight percent. You must continue to use one of the other sampling options until all of the oil from the delivery has been combusted, and you must evaluate excess emissions according to paragraph (a) of this section. When all of the fuel from the delivery has been burned, you may resume using the as-delivered sampling option.

(c) A period of monitor downtime begins when a required sample is not taken by its due date. A period of monitor downtime also begins on the date and hour of a required sample, if invalid results are obtained. The period of monitor downtime ends on the date and hour of the next valid sample.

#### **§ 60.4390 What are my reporting requirements if I operate an emergency combustion turbine or a research and development turbine?**

(a) If you operate an emergency combustion turbine, you are exempt from the NO<sub>x</sub> limit and must submit an initial report to the Administrator stating your case.

(b) Combustion turbines engaged by manufacturers in research and development of equipment for both combustion turbine emission control techniques and combustion turbine efficiency improvements may be exempted from the NO<sub>x</sub> limit on a case-by-case basis as determined by the Administrator. You must petition for the exemption.

### § 60.4395 When must I submit my reports?

All reports required under § 60.7(c) must be postmarked by the 30th day following the end of each 6-month period.

### Performance Tests

### § 60.4400 How do I conduct the initial and subsequent performance tests, regarding NO<sub>x</sub> ?

(a) You must conduct an initial performance test, as required in § 60.8. Subsequent NO<sub>x</sub> performance tests shall be conducted on an annual basis (no more than 14 calendar months following the previous performance test).

(1) There are two general methodologies that you may use to conduct the performance tests. For each test run:

(i) Measure the NO<sub>x</sub> concentration (in parts per million (ppm)), using EPA Method 7E or EPA Method 20 in appendix A of this part. For units complying with the output based standard, concurrently measure the stack gas flow rate, using EPA Methods 1 and 2 in appendix A of this part, and measure and record the electrical and thermal output from the unit. Then, use the following equation to calculate the NO<sub>x</sub> emission rate:

$$E = \frac{1.194 \times 10^{-7} * (NO_x)_c * Q_{std}}{P} \quad (\text{Eq. 5})$$

Where:

E = NO<sub>x</sub> emission rate, in lb/MWh

$1.194 \times 10^{-7}$  = conversion constant, in lb/dscf-ppm

(NO<sub>x</sub>)<sub>c</sub> = average NO<sub>x</sub> concentration for the run, in ppm

Q<sub>std</sub> = stack gas volumetric flow rate, in dscf/hr

P = gross electrical and mechanical energy output of the combustion turbine, in MW (for simple-cycle operation), for combined-cycle operation, the sum of all electrical and mechanical output from the combustion and steam turbines, or, for combined heat and power operation, the sum of all electrical and mechanical output from the combustion and steam turbines plus all useful recovered thermal output not used for additional electric or mechanical generation, in MW, calculated according to § 60.4350(f)(2); or

(ii) Measure the NO<sub>x</sub> and diluent gas concentrations, using either EPA Methods 7E and 3A, or EPA Method 20 in appendix A of this part. Concurrently measure the heat input to the unit, using a fuel flowmeter (or flowmeters), and measure the electrical and thermal output of the unit. Use EPA Method 19 in appendix A of this part to calculate the NO<sub>x</sub> emission rate in lb/MMBtu. Then, use Equations 1 and, if necessary, 2 and 3 in § 60.4350(f) to calculate the NO<sub>x</sub> emission rate in lb/MWh.

(2) Sampling traverse points for NO<sub>x</sub> and (if applicable) diluent gas are to be selected following EPA Method 20 or EPA Method 1 (non-particulate procedures), and sampled for equal time intervals. The sampling must be performed with a traversing single-hole probe, or, if feasible, with a stationary multi-hole probe that samples each of the points sequentially. Alternatively, a multi-hole probe designed and documented to sample equal volumes from each hole may be used to sample simultaneously at the required points.



(3) Notwithstanding paragraph (a)(2) of this section, you may test at fewer points than are specified in EPA Method 1 or EPA Method 20 in appendix A of this part if the following conditions are met:

(i) You may perform a stratification test for NO<sub>x</sub> and diluent pursuant to

(A) [Reserved], or

(B) The procedures specified in section 6.5.6.1(a) through (e) of appendix A of part 75 of this chapter.

(ii) Once the stratification sampling is completed, you may use the following alternative sample point selection criteria for the performance test:

(A) If each of the individual traverse point NO<sub>x</sub> concentrations is within  $\pm 10$  percent of the mean concentration for all traverse points, or the individual traverse point diluent concentrations differs by no more than  $\pm 5$  ppm or  $\pm 0.5$  percent CO<sub>2</sub> (or O<sub>2</sub>) from the mean for all traverse points, then you may use three points (located either 16.7, 50.0 and 83.3 percent of the way across the stack or duct, or, for circular stacks or ducts greater than 2.4 meters (7.8 feet) in diameter, at 0.4, 1.2, and 2.0 meters from the wall). The three points must be located along the measurement line that exhibited the highest average NO<sub>x</sub> concentration during the stratification test; or

(B) For turbines with a NO<sub>x</sub> standard greater than 15 ppm @ 15% O<sub>2</sub>, you may sample at a single point, located at least 1 meter from the stack wall or at the stack centroid if each of the individual traverse point NO<sub>x</sub> concentrations is within  $\pm 5$  percent of the mean concentration for all traverse points, or the individual traverse point diluent concentrations differs by no more than  $\pm 3$  ppm or  $\pm 0.3$  percent CO<sub>2</sub> (or O<sub>2</sub>) from the mean for all traverse points; or

(C) For turbines with a NO<sub>x</sub> standard less than or equal to 15 ppm @ 15% O<sub>2</sub>, you may sample at a single point, located at least 1 meter from the stack wall or at the stack centroid if each of the individual traverse point NO<sub>x</sub> concentrations is within  $\pm 2.5$  percent of the mean concentration for all traverse points, or the individual traverse point diluent concentrations differs by no more than  $\pm 1$  ppm or  $\pm 0.15$  percent CO<sub>2</sub> (or O<sub>2</sub>) from the mean for all traverse points.

(b) The performance test must be done at any load condition within plus or minus 25 percent of 100 percent of peak load. You may perform testing at the highest achievable load point, if at least 75 percent of peak load cannot be achieved in practice. You must conduct three separate test runs for each performance test. The minimum time per run is 20 minutes.

(1) If the stationary combustion turbine combusts both oil and gas as primary or backup fuels, separate performance testing is required for each fuel.

(2) For a combined cycle and CHP turbine systems with supplemental heat (duct burner), you must measure the total NO<sub>x</sub> emissions after the duct burner rather than directly after the turbine. The duct burner must be in operation during the performance test.

(3) If water or steam injection is used to control NO<sub>x</sub> with no additional post-combustion NO<sub>x</sub> control and you choose to monitor the steam or water to fuel ratio in accordance with § 60.4335, then that monitoring system must be operated concurrently with each EPA Method 20 or EPA Method 7E run and must be used to determine the fuel consumption and the steam or water to fuel ratio necessary to comply with the applicable § 60.4320 NO<sub>x</sub> emission limit.

(4) Compliance with the applicable emission limit in § 60.4320 must be demonstrated at each tested load level. Compliance is achieved if the three-run arithmetic average NO<sub>x</sub> emission rate at each tested level meets the applicable emission limit in § 60.4320.

(5) If you elect to install a CEMS, the performance evaluation of the CEMS may either be conducted separately or (as described in § 60.4405) as part of the initial performance test of the affected unit.

(6) The ambient temperature must be greater than 0 °F during the performance test.

**§ 60.4405 How do I perform the initial performance test if I have chosen to install a NO<sub>x</sub> -diluent CEMS?**

If you elect to install and certify a NO<sub>x</sub> -diluent CEMS under § 60.4345, then the initial performance test required under § 60.8 may be performed in the following alternative manner:

(a) Perform a minimum of nine RATA reference method runs, with a minimum time per run of 21 minutes, at a single load level, within plus or minus 25 percent of 100 percent of peak load. The ambient temperature must be greater than 0 °F during the RATA runs.

(b) For each RATA run, concurrently measure the heat input to the unit using a fuel flow meter (or flow meters) and measure the electrical and thermal output from the unit.

(c) Use the test data both to demonstrate compliance with the applicable NO<sub>x</sub> emission limit under § 60.4320 and to provide the required reference method data for the RATA of the CEMS described under § 60.4335.

(d) Compliance with the applicable emission limit in § 60.4320 is achieved if the arithmetic average of all of the NO<sub>x</sub> emission rates for the RATA runs, expressed in units of ppm or lb/MWh, does not exceed the emission limit.

**§ 60.4410 How do I establish a valid parameter range if I have chosen to continuously monitor parameters?**

If you have chosen to monitor combustion parameters or parameters indicative of proper operation of NO<sub>x</sub> emission controls in accordance with § 60.4340, the appropriate parameters must be continuously monitored and recorded during each run of the initial performance test, to establish acceptable operating ranges, for purposes of the parameter monitoring plan for the affected unit, as specified in § 60.4355.

**§ 60.4415 How do I conduct the initial and subsequent performance tests for sulfur?**

(a) You must conduct an initial performance test, as required in § 60.8. Subsequent SO<sub>2</sub> performance tests shall be conducted on an annual basis (no more than 14 calendar months following the previous performance test). There are three methodologies that you may use to conduct the performance tests.

(1) If you choose to periodically determine the sulfur content of the fuel combusted in the turbine, a representative fuel sample would be collected following ASTM D5287 (incorporated by reference, see § 60.17) for natural gas or ASTM D4177 (incorporated by reference, see § 60.17) for oil. Alternatively, for oil, you may follow the procedures for manual pipeline sampling in section 14 of ASTM D4057 (incorporated by reference, see § 60.17). The fuel analyses of this section may be performed either by you, a service contractor retained by you, the fuel vendor, or any other qualified agency. Analyze the samples for the total sulfur content of the fuel using:

(i) For liquid fuels, ASTM D129, or alternatively D1266, D1552, D2622, D4294, or D5453 (all of which are incorporated by reference, see § 60.17); or

(ii) For gaseous fuels, ASTM D1072, or alternatively D3246, D4084, D4468, D4810, D6228, D6667, or Gas Processors Association Standard 2377 (all of which are incorporated by reference, see § 60.17).

(2) Measure the SO<sub>2</sub> concentration (in parts per million (ppm)), using EPA Methods 6, 6C, 8, or 20 in appendix A of this part. In addition, the American Society of Mechanical Engineers (ASME) standard, ASME PTC 19-10-1981-Part 10, "Flue and Exhaust Gas Analyses," manual methods for sulfur dioxide (incorporated by reference, see § 60.17) can be used instead of EPA Methods 6 or 20. For units complying with the output based standard, concurrently measure the stack gas flow rate, using EPA Methods 1 and 2 in appendix A of this part, and measure and record the electrical and thermal output from the unit. Then use the following equation to calculate the SO<sub>2</sub> emission rate:

$$E = \frac{1.664 \times 10^{-7} * (SO_2)_c * Q_{std}}{P} \quad (\text{Eq. 6})$$

Where:

E = SO<sub>2</sub> emission rate, in lb/MWh

$1.664 \times 10^{-7}$  = conversion constant, in lb/dscf-ppm

(SO<sub>2</sub>)<sub>c</sub> = average SO<sub>2</sub> concentration for the run, in ppm

Q<sub>std</sub> = stack gas volumetric flow rate, in dscf/hr

P = gross electrical and mechanical energy output of the combustion turbine, in MW (for simple-cycle operation), for combined-cycle operation, the sum of all electrical and mechanical output from the combustion and steam turbines, or, for combined heat and power operation, the sum of all electrical and mechanical output from the combustion and steam turbines plus all useful recovered thermal output not used for additional electric or mechanical generation, in MW, calculated according to § 60.4350(f)(2); or

(3) Measure the SO<sub>2</sub> and diluent gas concentrations, using either EPA Methods 6, 6C, or 8 and 3A, or 20 in appendix A of this part. In addition, you may use the manual methods for sulfur dioxide ASME PTC 19-10-1981-Part 10 (incorporated by reference, see § 60.17). Concurrently measure the heat input to the unit, using a fuel flowmeter (or flowmeters), and measure the electrical and thermal output of the unit. Use EPA Method 19 in appendix A of this part to calculate the SO<sub>2</sub> emission rate in lb/MMBtu. Then, use Equations 1 and, if necessary, 2 and 3 in § 60.4350(f) to calculate the SO<sub>2</sub> emission rate in lb/MWh.

(b) [Reserved]

## Definitions

### § 60.4420 What definitions apply to this subpart?

As used in this subpart, all terms not defined herein will have the meaning given them in the Clean Air Act and in subpart A (General Provisions) of this part.

Biogas means gas produced by the anaerobic digestion or fermentation of organic matter including manure, sewage sludge, municipal solid waste, biodegradable waste, or any other biodegradable feedstock, under anaerobic conditions. Biogas is comprised primarily of methane and CO<sub>2</sub>.

Combined cycle combustion turbine means any stationary combustion turbine which recovers heat from the combustion turbine exhaust gases to generate steam that is only used to create additional power output in a steam turbine.

Combined heat and power combustion turbine means any stationary combustion turbine which recovers heat from the exhaust gases to heat water or another medium, generate steam for useful purposes other than additional electric generation, or directly uses the heat in the exhaust gases for a useful purpose.

Combustion turbine model means a group of combustion turbines having the same nominal air flow, combustor inlet pressure, combustor inlet temperature, firing temperature, turbine inlet temperature and turbine inlet pressure.

Combustion turbine test cell/stand means any apparatus used for testing uninstalled stationary or uninstalled mobile (motive) combustion turbines.

Diffusion flame stationary combustion turbine means any stationary combustion turbine where fuel and air are injected at the combustor and are mixed only by diffusion prior to ignition.

Duct burner means a device that combusts fuel and that is placed in the exhaust duct from another source, such as a stationary combustion turbine, internal combustion engine, kiln, etc., to allow the firing of additional fuel to heat the exhaust gases before the exhaust gases enter a heat recovery steam generating unit.

Efficiency means the combustion turbine manufacturer's rated heat rate at peak load in terms of heat input per unit of power output—based on the higher heating value of the fuel.

Emergency combustion turbine means any stationary combustion turbine which operates in an emergency situation. Examples include stationary combustion turbines used to produce power for critical networks or equipment, including power supplied to portions of a facility, when electric power from the local utility is interrupted, or stationary combustion turbines used to pump water in the case of fire or flood, etc. Emergency stationary combustion turbines do not include stationary combustion turbines used as peaking units at electric utilities or stationary combustion turbines at industrial facilities that typically operate at low capacity factors. Emergency combustion turbines may be operated for the purpose of maintenance checks and readiness testing, provided that the tests are required by the manufacturer, the vendor, or the insurance company associated with the turbine. Required testing of such units should be minimized, but there is no time limit on the use of emergency combustion turbines.

Excess emissions means a specified averaging period over which either (1) the NO<sub>x</sub> emissions are higher than the applicable emission limit in § 60.4320; (2) the total sulfur content of the fuel being combusted in the affected facility exceeds the limit specified in § 60.4330; or (3) the recorded value of a particular monitored parameter is outside the acceptable range specified in the parameter monitoring plan for the affected unit.

Gross useful output means the gross useful work performed by the stationary combustion turbine system. For units using the mechanical energy directly or generating only electricity, the gross useful work performed is the gross electrical or mechanical output from the turbine/generator set. For combined heat and power units, the gross useful work performed is the gross electrical or mechanical output plus the useful thermal output (i.e., thermal energy delivered to a process).

Heat recovery steam generating unit means a unit where the hot exhaust gases from the combustion turbine are routed in order to extract heat from the gases and generate steam, for use in a steam turbine or other device that utilizes steam. Heat recovery steam generating units can be used with or without duct burners.

Integrated gasification combined cycle electric utility steam generating unit means a coal-fired electric utility steam generating unit that burns a synthetic gas derived from coal in a combined-cycle gas turbine. No solid coal is directly burned in the unit during operation.

ISO conditions means 288 Kelvin, 60 percent relative humidity and 101.3 kilopascals pressure.

Lean premix stationary combustion turbine means any stationary combustion turbine where the air and fuel are thoroughly mixed to form a lean mixture before delivery to the combustor. Mixing may occur before or in the combustion chamber. A lean premixed turbine may operate in diffusion flame mode during operating conditions such as startup and shutdown, extreme ambient temperature, or low or transient load.

Natural gas means a naturally occurring fluid mixture of hydrocarbons (e.g., methane, ethane, or propane) produced in geological formations beneath the Earth's surface that maintains a gaseous state at standard atmospheric temperature and pressure under ordinary conditions. Additionally, natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 950 and 1,100 British thermal units (Btu) per standard cubic foot. Natural gas does not include the following gaseous fuels: landfill gas, digester gas, refinery gas, sour gas, blast furnace gas, coal-derived gas, producer gas, coke oven gas, or any gaseous fuel produced in a process which might result in highly variable sulfur content or heating value.

Noncontinental area means the State of Hawaii, the Virgin Islands, Guam, American Samoa, the Commonwealth of Puerto Rico, the Northern Mariana Islands, or offshore platforms.

Peak load means 100 percent of the manufacturer's design capacity of the combustion turbine at ISO conditions.

Regenerative cycle combustion turbine means any stationary combustion turbine which recovers heat from the combustion turbine exhaust gases to preheat the inlet combustion air to the combustion turbine.

Simple cycle combustion turbine means any stationary combustion turbine which does not recover heat from the combustion turbine exhaust gases to preheat the inlet combustion air to the combustion turbine, or which does not recover heat from the combustion turbine exhaust gases for purposes other than enhancing the performance of the combustion turbine itself.

Stationary combustion turbine means all equipment, including but not limited to the turbine, the fuel, air, lubrication and exhaust gas systems, control systems (except emissions control equipment), heat recovery system, and any ancillary components and sub-components comprising any simple cycle stationary combustion turbine, any regenerative/recuperative cycle stationary combustion turbine, any combined cycle combustion turbine, and any combined heat and power combustion turbine based system. Stationary means that the combustion turbine is not self propelled or intended to be propelled while performing its function. It may, however, be mounted on a vehicle for portability.

Unit operating day means a 24-hour period between 12 midnight and the following midnight during which any fuel is combusted at any time in the unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period.

Unit operating hour means a clock hour during which any fuel is combusted in the affected unit. If the unit combusts fuel for the entire clock hour, it is considered to be a full unit operating hour. If the unit combusts fuel for only part of the clock hour, it is considered to be a partial unit operating hour.

Useful thermal output means the thermal energy made available for use in any industrial or commercial process, or used in any heating or cooling application, i.e., total thermal energy made available for processes and applications other than electrical or mechanical generation. Thermal output for this subpart means the energy in recovered thermal output measured against the energy in the thermal output at 15 degrees Celsius and 101.325 kilopascals of pressure.

[71 FR 38497, July 6, 2006, as amended at 74 FR 11861, Mar. 20, 2009]

**Table 1 to Subpart KKKK of Part 60—Nitrogen Oxide Emission Limits for New Stationary Combustion Turbines**

| <b>Combustion turbine type</b>   | <b>Combustion turbine heat input at peak load (HHV)</b> | <b>NO<sub>x</sub> emission standard</b>   |
|--|---|---|
| New turbine firing natural gas, electric generating  | ≤ 50 MMBtu/h  | 42 ppm at 15 percent O <sub>2</sub> or 290 ng/J of useful output (2.3 lb/MWh).    |
| New turbine firing natural gas, mechanical drive   | ≤ 50 MMBtu/h  | 100 ppm at 15 percent O <sub>2</sub> or 690 ng/J of useful output (5.5 lb/MWh).   |
| New turbine firing natural gas   | > 50 MMBtu/h and ≤ 850 MMBtu/h                          | 25 ppm at 15 percent O <sub>2</sub> or 150 ng/J of useful output (1.2 lb/MWh).    |
| New, modified, or reconstructed turbine firing natural gas   | > 850 MMBtu/h   | 15 ppm at 15 percent O <sub>2</sub> or 54 ng/J of useful output (0.43 lb/MWh)     |
| New turbine firing fuels other than natural gas, electric generating   | ≤ 50 MMBtu/h  | 96 ppm at 15 percent O <sub>2</sub> or 700 ng/J of useful output (5.5 lb/MWh).    |
| New turbine firing fuels other than natural gas, mechanical drive  | ≤ 50 MMBtu/h  | 150 ppm at 15 percent O <sub>2</sub> or 1,100 ng/J of useful output (8.7 lb/MWh). |
| New turbine firing fuels other than natural gas  | > 50 MMBtu/h and ≤ 850 MMBtu/h                          | 74 ppm at 15 percent O <sub>2</sub> or 460 ng/J of useful output (3.6 lb/MWh).    |
| New, modified, or reconstructed turbine firing fuels other than natural gas  | > 850 MMBtu/h   | 42 ppm at 15 percent O <sub>2</sub> or 160 ng/J of useful output (1.3 lb/MWh).    |
| Modified or reconstructed turbine  | ≤ 50 MMBtu/h  | 150 ppm at 15 percent O <sub>2</sub> or 1,100 ng/J of useful output (8.7 lb/MWh). |
| Modified or reconstructed turbine firing natural gas   | > 50 MMBtu/h and ≤ 850 MMBtu/h                          | 42 ppm at 15 percent O <sub>2</sub> or 250 ng/J of useful output (2.0 lb/MWh).    |
| Modified or reconstructed turbine firing fuels other than natural gas  | > 50 MMBtu/h and ≤ 850 MMBtu/h                          | 96 ppm at 15 percent O <sub>2</sub> or 590 ng/J of useful output (4.7 lb/MWh).    |
| Turbines located north of the Arctic Circle (latitude 66.5 degrees north), turbines operating at less than 75 percent of peak load, modified and reconstructed offshore turbines, and turbine operating at temperatures less than 0 °F | ≤ 30 MW output  | 150 ppm at 15 percent O <sub>2</sub> or 1,100 ng/J of useful output (8.7 lb/MWh). |

|  |                |   |
|--|----------------|---|
| Turbines located north of the Arctic Circle (latitude 66.5 degrees north), turbines operating at less than 75 percent of peak load, modified and reconstructed offshore turbines, and turbine operating at temperatures less than 0 °F | > 30 MW output | 96 ppm at 15 percent O <sub>2</sub> or 590 ng/J of useful output (4.7 lb/MWh).  |
| Heat recovery units operating independent of the combustion turbine  | All sizes      | 54 ppm at 15 percent O <sub>2</sub> or 110 ng/J of useful output (0.86 lb/MWh). |

## **Attachment F**

### **Title 40: Protection of Environment**

#### **PART 63—NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS FOR SOURCE CATEGORIES**

##### **Subpart ZZZZ—National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines**

SOURCE: 69 FR 33506, June 15, 2004, unless otherwise noted.

#### **What This Subpart Covers**

##### **§ 63.6580 What is the purpose of subpart ZZZZ?**

Subpart ZZZZ establishes national emission limitations and operating limitations for hazardous air pollutants (HAP) emitted from stationary reciprocating internal combustion engines (RICE) located at major and area sources of HAP emissions. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emission limitations and operating limitations.

[73 FR 3603, Jan. 18, 2008]

##### **§ 63.6585 Am I subject to this subpart?**

You are subject to this subpart if you own or operate a stationary RICE at a major or area source of HAP emissions, except if the stationary RICE is being tested at a stationary RICE test cell/stand.

(a) A stationary RICE is any internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work and which is not mobile. Stationary RICE differ from mobile RICE in that a stationary RICE is not a non-road engine as defined at 40 CFR 1068.30, and is not used to propel a motor vehicle or a vehicle used solely for competition.

(b) A major source of HAP emissions is a plant site that emits or has the potential to emit any single HAP at a rate of 10 tons (9.07 megagrams) or more per year or any combination of HAP at a rate of 25 tons (22.68 megagrams) or more per year, except that for oil and gas production facilities, a major source of HAP emissions is determined for each surface site.

(c) An area source of HAP emissions is a source that is not a major source.

(d) If you are an owner or operator of an area source subject to this subpart, your status as an entity subject to a standard or other requirements under this subpart does not subject you to the obligation to obtain a permit under 40 CFR part 70 or 71, provided you are not required to obtain a permit under 40 CFR 70.3(a) or 40 CFR 71.3(a) for a reason other than your status as an area source under this subpart. Notwithstanding the previous sentence, you must continue to comply with the provisions of this subpart as applicable.

(e) If you are an owner or operator of a stationary RICE used for national security purposes, you may be eligible to request an exemption from the requirements of this subpart as described in 40 CFR part 1068, subpart C.



(f) The emergency stationary RICE listed in paragraphs (f)(1) through (3) of this section are not subject to this subpart. The stationary RICE must meet the definition of an emergency stationary RICE in § 63.6675, which includes operating according to the provisions specified in § 63.6640(f).

(1) Existing residential emergency stationary RICE located at an area source of HAP emissions that do not operate or are not contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in § 63.6640(f)(2)(ii) and (iii) and that do not operate for the purpose specified in § 63.6640(f)(4)(ii).

(2) Existing commercial emergency stationary RICE located at an area source of HAP emissions that do not operate or are not contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in § 63.6640(f)(2)(ii) and (iii) and that do not operate for the purpose specified in § 63.6640(f)(4)(ii).

(3) Existing institutional emergency stationary RICE located at an area source of HAP emissions that do not operate or are not contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in § 63.6640(f)(2)(ii) and (iii) and that do not operate for the purpose specified in § 63.6640(f)(4)(ii).

[69 FR 33506, June 15, 2004, as amended at 73 FR 3603, Jan. 18, 2008; 78 FR 6700, Jan. 30, 2013]

#### **§ 63.6590 What parts of my plant does this subpart cover?**

This subpart applies to each affected source.

(a) *Affected source.* An affected source is any existing, new, or reconstructed stationary RICE located at a major or area source of HAP emissions, excluding stationary RICE being tested at a stationary RICE test cell/stand.

##### **(1) Existing stationary RICE.**

(i) For stationary RICE with a site rating of more than 500 brake horsepower (HP) located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before December 19, 2002.

(ii) For stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.

(iii) For stationary RICE located at an area source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.

(iv) A change in ownership of an existing stationary RICE does not make that stationary RICE a new or reconstructed stationary RICE.

(2) *New stationary RICE.* (i) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions is new if you commenced construction of the stationary RICE on or after December 19, 2002.

(ii) A stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.

(iii) A stationary RICE located at an area source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.

(3) *Reconstructed stationary RICE.* (i) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions is reconstructed if you meet the definition of reconstruction in § 63.2 and reconstruction is commenced on or after December 19, 2002.

(ii) A stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions is reconstructed if you meet the definition of reconstruction in § 63.2 and reconstruction is commenced on or after June 12, 2006.

(iii) A stationary RICE located at an area source of HAP emissions is reconstructed if you meet the definition of reconstruction in § 63.2 and reconstruction is commenced on or after June 12, 2006.

(b) *Stationary RICE subject to limited requirements.* (1) An affected source which meets either of the criteria in paragraphs (b)(1)(i) through (ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of § 63.6645(f).

(i) The stationary RICE is a new or reconstructed emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions that does not operate or is not contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in § 63.6640(f)(2)(ii) and (iii).

(ii) The stationary RICE is a new or reconstructed limited use stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.

(2) A new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis must meet the initial notification requirements of § 63.6645(f) and the requirements of §§ 63.6625(c), 63.6650(g), and 63.6655(c). These stationary RICE do not have to meet the emission limitations and operating limitations of this subpart.

(3) The following stationary RICE do not have to meet the requirements of this subpart and of subpart A of this part, including initial notification requirements:

(i) Existing spark ignition 2 stroke lean burn (2SLB) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;

(ii) Existing spark ignition 4 stroke lean burn (4SLB) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;

(iii) Existing emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions that does not operate or is not contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in § 63.6640(f)(2)(ii) and (iii).

(iv) Existing limited use stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions;

(v) Existing stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis;

(c) *Stationary RICE subject to Regulations under 40 CFR Part 60.* An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines. No further requirements apply for such engines under this part.

- (1) A new or reconstructed stationary RICE located at an area source;
- (2) A new or reconstructed 2SLB stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;
- (3) A new or reconstructed 4SLB stationary RICE with a site rating of less than 250 brake HP located at a major source of HAP emissions;
- (4) A new or reconstructed spark ignition 4 stroke rich burn (4SRB) stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;
- (5) A new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis;
- (6) A new or reconstructed emergency or limited use stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;
- (7) A new or reconstructed compression ignition (CI) stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008; 75 FR 9674, Mar. 3, 2010; 75 FR 37733, June 30, 2010; 75 FR 51588, Aug. 20, 2010; 78 FR 6700, Jan. 30, 2013]

**§ 63.6595 When do I have to comply with this subpart?**

(a) *Affected sources.* (1) If you have an existing stationary RICE, excluding existing non-emergency CI stationary RICE, with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the applicable emission limitations, operating limitations and other requirements no later than June 15, 2007. If you have an existing non-emergency CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, an existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or an existing stationary CI RICE located at an area source of HAP emissions, you must comply with the applicable emission limitations, operating limitations, and other requirements no later than May 3, 2013. If you have an existing stationary SI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or an existing stationary SI RICE located at an area source of HAP emissions, you must comply with the applicable emission limitations, operating limitations, and other requirements no later than October 19, 2013.

(2) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions before August 16, 2004, you must comply with the applicable emission limitations and operating limitations in this subpart no later than August 16, 2004.

(3) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions after August 16, 2004, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(4) If you start up your new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions before January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart no later than January 18, 2008.

(5) If you start up your new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions after January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(6) If you start up your new or reconstructed stationary RICE located at an area source of HAP emissions before January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart no later than January 18, 2008.

(7) If you start up your new or reconstructed stationary RICE located at an area source of HAP emissions after January 18, 2008, you must comply with the applicable emission limitations and operating limitations in this subpart upon startup of your affected source.

(b) *Area sources that become major sources.* If you have an area source that increases its emissions or its potential to emit such that it becomes a major source of HAP, the compliance dates in paragraphs (b)(1) and (2) of this section apply to you.

(1) Any stationary RICE for which construction or reconstruction is commenced after the date when your area source becomes a major source of HAP must be in compliance with this subpart upon startup of your affected source.

(2) Any stationary RICE for which construction or reconstruction is commenced before your area source becomes a major source of HAP must be in compliance with the provisions of this subpart that are applicable to RICE located at major sources within 3 years after your area source becomes a major source of HAP.

(c) If you own or operate an affected source, you must meet the applicable notification requirements in § 63.6645 and in 40 CFR part 63, subpart A.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008; 75 FR 9675, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010; 78 FR 6701, Jan. 30, 2013]

## **Emission and Operating Limitations**

### **§ 63.6600 What emission limitations and operating limitations must I meet if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?**

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in § 63.6620 and Table 4 to this subpart.

(a) If you own or operate an existing, new, or reconstructed spark ignition 4SRB stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 1a to this subpart and the operating limitations in Table 1b to this subpart which apply to you.

(b) If you own or operate a new or reconstructed 2SLB stationary RICE with a site rating of more than 500 brake HP located at major source of HAP emissions, a new or reconstructed 4SLB stationary RICE with a

site rating of more than 500 brake HP located at major source of HAP emissions, or a new or reconstructed CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 2a to this subpart and the operating limitations in Table 2b to this subpart which apply to you.

(c) If you own or operate any of the following stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the emission limitations in Tables 1a, 2a, 2c, and 2d to this subpart or operating limitations in Tables 1b and 2b to this subpart: an existing 2SLB stationary RICE; an existing 4SLB stationary RICE; a stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis; an emergency stationary RICE; or a limited use stationary RICE.

(d) If you own or operate an existing non-emergency stationary CI RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations in Table 2c to this subpart and the operating limitations in Table 2b to this subpart which apply to you.

[73 FR 3605, Jan. 18, 2008, as amended at 75 FR 9675, Mar. 3, 2010]

**§ 63.6601 What emission limitations must I meet if I own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 brake HP and less than or equal to 500 brake HP located at a major source of HAP emissions?**

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in § 63.6620 and Table 4 to this subpart. If you own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at major source of HAP emissions manufactured on or after January 1, 2008, you must comply with the emission limitations in Table 2a to this subpart and the operating limitations in Table 2b to this subpart which apply to you.

[73 FR 3605, Jan. 18, 2008, as amended at 75 FR 9675, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010]

**§ 63.6602 What emission limitations and other requirements must I meet if I own or operate an existing stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions?**

If you own or operate an existing stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions, you must comply with the emission limitations and other requirements in Table 2c to this subpart which apply to you. Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in § 63.6620 and Table 4 to this subpart.

[78 FR 6701, Jan. 30, 2013]

**§ 63.6603 What emission limitations, operating limitations, and other requirements must I meet if I own or operate an existing stationary RICE located at an area source of HAP emissions?**

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in § 63.6620 and Table 4 to this subpart.

(a) If you own or operate an existing stationary RICE located at an area source of HAP emissions, you must comply with the requirements in Table 2d to this subpart and the operating limitations in Table 2b to this subpart that apply to you.

(b) If you own or operate an existing stationary non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP that meets either paragraph (b)(1) or (2) of this section, you do not have to meet the numerical CO emission limitations specified in Table 2d of this subpart. Existing stationary non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP that meet either paragraph (b)(1) or (2) of this section must meet the management practices that are shown for stationary non-emergency CI RICE with a site rating of less than or equal to 300 HP in Table 2d of this subpart.

(1) The area source is located in an area of Alaska that is not accessible by the Federal Aid Highway System (FAHS).

(2) The stationary RICE is located at an area source that meets paragraphs (b)(2)(i), (ii), and (iii) of this section.

(i) The only connection to the FAHS is through the Alaska Marine Highway System (AMHS), or the stationary RICE operation is within an isolated grid in Alaska that is not connected to the statewide electrical grid referred to as the Alaska Railbelt Grid.

(ii) At least 10 percent of the power generated by the stationary RICE on an annual basis is used for residential purposes.

(iii) The generating capacity of the area source is less than 12 megawatts, or the stationary RICE is used exclusively for backup power for renewable energy.

(c) If you own or operate an existing stationary non-emergency CI RICE with a site rating of more than 300 HP located on an offshore vessel that is an area source of HAP and is a nonroad vehicle that is an Outer Continental Shelf (OCS) source as defined in 40 CFR 55.2, you do not have to meet the numerical CO emission limitations specified in Table 2d of this subpart. You must meet all of the following management practices:

(1) Change oil every 1,000 hours of operation or annually, whichever comes first. Sources have the option to utilize an oil analysis program as described in § 63.6625(i) in order to extend the specified oil change requirement.

(2) Inspect and clean air filters every 750 hours of operation or annually, whichever comes first, and replace as necessary.

(3) Inspect fuel filters and belts, if installed, every 750 hours of operation or annually, whichever comes first, and replace as necessary.

(4) Inspect all flexible hoses every 1,000 hours of operation or annually, whichever comes first, and replace as necessary.

(d) If you own or operate an existing non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP emissions that is certified to the Tier 1 or Tier 2 emission standards in Table 1 of 40 CFR 89.112 and that is subject to an enforceable state or local standard that requires the engine to be replaced no later than June 1, 2018, you may until January 1, 2015, or 12 years after the installation date of the engine (whichever is later), but not later than June 1, 2018, choose to comply with the management practices that are shown for stationary non-emergency CI RICE with a site rating of less than or equal to 300 HP in Table 2d of this subpart instead of the applicable emission limitations in Table 2d, operating limitations in Table 2b, and crankcase ventilation system requirements in § 63.6625(g). You must comply with the emission limitations in Table 2d and operating limitations in Table 2b that apply for non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP

emissions by January 1, 2015, or 12 years after the installation date of the engine (whichever is later), but not later than June 1, 2018. You must also comply with the crankcase ventilation system requirements in § 63.6625(g) by January 1, 2015, or 12 years after the installation date of the engine (whichever is later), but not later than June 1, 2018.

(e) If you own or operate an existing non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP emissions that is certified to the Tier 3 (Tier 2 for engines above 560 kilowatt (kW)) emission standards in Table 1 of 40 CFR 89.112, you may comply with the requirements under this part by meeting the requirements for Tier 3 engines (Tier 2 for engines above 560 kW) in 40 CFR part 60 subpart IIII instead of the emission limitations and other requirements that would otherwise apply under this part for existing non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP emissions.

(f) An existing non-emergency SI 4SLB and 4SRB stationary RICE with a site rating of more than 500 HP located at area sources of HAP must meet the definition of remote stationary RICE in § 63.6675 on the initial compliance date for the engine, October 19, 2013, in order to be considered a remote stationary RICE under this subpart. Owners and operators of existing non-emergency SI 4SLB and 4SRB stationary RICE with a site rating of more than 500 HP located at area sources of HAP that meet the definition of remote stationary RICE in § 63.6675 of this subpart as of October 19, 2013 must evaluate the status of their stationary RICE every 12 months. Owners and operators must keep records of the initial and annual evaluation of the status of the engine. If the evaluation indicates that the stationary RICE no longer meets the definition of remote stationary RICE in § 63.6675 of this subpart, the owner or operator must comply with all of the requirements for existing non-emergency SI 4SLB and 4SRB stationary RICE with a site rating of more than 500 HP located at area sources of HAP that are not remote stationary RICE within 1 year of the evaluation.

[75 FR 9675, Mar. 3, 2010, as amended at 75 FR 51589, Aug. 20, 2010; 76 FR 12866, Mar. 9, 2011; 78 FR 6701, Jan. 30, 2013]

#### **§ 63.6604 What fuel requirements must I meet if I own or operate a stationary CI RICE?**

(a) If you own or operate an existing non-emergency, non-black start CI stationary RICE with a site rating of more than 300 brake HP with a displacement of less than 30 liters per cylinder that uses diesel fuel, you must use diesel fuel that meets the requirements in 40 CFR 80.510(b) for nonroad diesel fuel.

(b) Beginning January 1, 2015, if you own or operate an existing emergency CI stationary RICE with a site rating of more than 100 brake HP and a displacement of less than 30 liters per cylinder that uses diesel fuel and operates or is contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in § 63.6640(f)(2)(ii) and (iii) or that operates for the purpose specified in § 63.6640(f)(4)(ii), you must use diesel fuel that meets the requirements in 40 CFR 80.510(b) for nonroad diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to January 1, 2015, may be used until depleted.

(c) Beginning January 1, 2015, if you own or operate a new emergency CI stationary RICE with a site rating of more than 500 brake HP and a displacement of less than 30 liters per cylinder located at a major source of HAP that uses diesel fuel and operates or is contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in § 63.6640(f)(2)(ii) and (iii), you must use diesel fuel that meets the requirements in 40 CFR 80.510(b) for nonroad diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to January 1, 2015, may be used until depleted.

(d) Existing CI stationary RICE located in Guam, American Samoa, the Commonwealth of the Northern Mariana Islands, at area sources in areas of Alaska that meet either § 63.6603(b)(1) or § 63.6603(b)(2), or are on offshore vessels that meet § 63.6603(c) are exempt from the requirements of this section.

[78 FR 6702, Jan. 30, 2013]

### **General Compliance Requirements**

#### **§ 63.6605 What are my general requirements for complying with this subpart?**

(a) You must be in compliance with the emission limitations, operating limitations, and other requirements in this subpart that apply to you at all times.

(b) At all times you must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.

[75 FR 9675, Mar. 3, 2010, as amended at 78 FR 6702, Jan. 30, 2013]

### **Testing and Initial Compliance Requirements**

#### **§ 63.6610 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?**

If you own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions you are subject to the requirements of this section.

(a) You must conduct the initial performance test or other initial compliance demonstrations in Table 4 to this subpart that apply to you within 180 days after the compliance date that is specified for your stationary RICE in § 63.6595 and according to the provisions in § 63.7(a)(2).

(b) If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004 and own or operate stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must demonstrate initial compliance with either the proposed emission limitations or the promulgated emission limitations no later than February 10, 2005 or no later than 180 days after startup of the source, whichever is later, according to § 63.7(a)(2)(ix).

(c) If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004 and own or operate stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, and you chose to comply with the proposed emission limitations when demonstrating initial compliance, you must conduct a second performance test to demonstrate compliance with the promulgated emission limitations by December 13, 2007 or after startup of the source, whichever is later, according to § 63.7(a)(2)(ix).

(d) An owner or operator is not required to conduct an initial performance test on units for which a performance test has been previously conducted, but the test must meet all of the conditions described in paragraphs (d)(1) through (5) of this section.

(1) The test must have been conducted using the same methods specified in this subpart, and these methods must have been followed correctly.



- (2) The test must not be older than 2 years.
- (3) The test must be reviewed and accepted by the Administrator.
- (4) Either no process or equipment changes must have been made since the test was performed, or the owner or operator must be able to demonstrate that the results of the performance test, with or without adjustments, reliably demonstrate compliance despite process or equipment changes.
- (5) The test must be conducted at any load condition within plus or minus 10 percent of 100 percent load.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3605, Jan. 18, 2008]

**§ 63.6611 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a new or reconstructed 4SLB SI stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions?**

If you own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions, you must conduct an initial performance test within 240 days after the compliance date that is specified for your stationary RICE in § 63.6595 and according to the provisions specified in Table 4 to this subpart, as appropriate.

[73 FR 3605, Jan. 18, 2008, as amended at 75 FR 51589, Aug. 20, 2010]

**§ 63.6612 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate an existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing stationary RICE located at an area source of HAP emissions?**

If you own or operate an existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing stationary RICE located at an area source of HAP emissions you are subject to the requirements of this section.

(a) You must conduct any initial performance test or other initial compliance demonstration according to Tables 4 and 5 to this subpart that apply to you within 180 days after the compliance date that is specified for your stationary RICE in § 63.6595 and according to the provisions in § 63.7(a)(2).

(b) An owner or operator is not required to conduct an initial performance test on a unit for which a performance test has been previously conducted, but the test must meet all of the conditions described in paragraphs (b)(1) through (4) of this section.

(1) The test must have been conducted using the same methods specified in this subpart, and these methods must have been followed correctly.

(2) The test must not be older than 2 years.

(3) The test must be reviewed and accepted by the Administrator.

(4) Either no process or equipment changes must have been made since the test was performed, or the owner or operator must be able to demonstrate that the results of the performance test, with or without adjustments, reliably demonstrate compliance despite process or equipment changes.

[75 FR 9676, Mar. 3, 2010, as amended at 75 FR 51589, Aug. 20, 2010]

**§ 63.6615 When must I conduct subsequent performance tests?**

If you must comply with the emission limitations and operating limitations, you must conduct subsequent performance tests as specified in Table 3 of this subpart.

**§ 63.6620 What performance tests and other procedures must I use?**

(a) You must conduct each performance test in Tables 3 and 4 of this subpart that applies to you.

(b) Each performance test must be conducted according to the requirements that this subpart specifies in Table 4 to this subpart. If you own or operate a non-operational stationary RICE that is subject to performance testing, you do not need to start up the engine solely to conduct the performance test. Owners and operators of a non-operational engine can conduct the performance test when the engine is started up again. The test must be conducted at any load condition within plus or minus 10 percent of 100 percent load for the stationary RICE listed in paragraphs (b)(1) through (4) of this section.

(1) Non-emergency 4SRB stationary RICE with a site rating of greater than 500 brake HP located at a major source of HAP emissions.

(2) New non-emergency 4SLB stationary RICE with a site rating of greater than or equal to 250 brake HP located at a major source of HAP emissions.

(3) New non-emergency 2SLB stationary RICE with a site rating of greater than 500 brake HP located at a major source of HAP emissions.

(4) New non-emergency CI stationary RICE with a site rating of greater than 500 brake HP located at a major source of HAP emissions.

(c) [Reserved]

(d) You must conduct three separate test runs for each performance test required in this section, as specified in § 63.7(e)(3). Each test run must last at least 1 hour, unless otherwise specified in this subpart.

(e)(1) You must use Equation 1 of this section to determine compliance with the percent reduction requirement:

$$\frac{C_i - C_o}{C_i} \times 100 = R \quad (\text{Eq. 1})$$

Where:

$C_i$  = concentration of carbon monoxide (CO), total hydrocarbons (THC), or formaldehyde at the control device inlet,

$C_o$  = concentration of CO, THC, or formaldehyde at the control device outlet, and

R = percent reduction of CO, THC, or formaldehyde emissions.

(2) You must normalize the CO, THC, or formaldehyde concentrations at the inlet and outlet of the control device to a dry basis and to 15 percent oxygen, or an equivalent percent carbon dioxide (CO<sub>2</sub>). If

pollutant concentrations are to be corrected to 15 percent oxygen and CO<sub>2</sub> concentration is measured in lieu of oxygen concentration measurement, a CO<sub>2</sub> correction factor is needed. Calculate the CO<sub>2</sub> correction factor as described in paragraphs (e)(2)(i) through (iii) of this section.

(i) Calculate the fuel-specific F<sub>o</sub> value for the fuel burned during the test using values obtained from Method 19, Section 5.2, and the following equation:

$$F_o = \frac{0.209 F_d}{F_c} \quad (\text{Eq. 2})$$

Where:

F<sub>o</sub> = Fuel factor based on the ratio of oxygen volume to the ultimate CO<sub>2</sub> volume produced by the fuel at zero percent excess air.

0.209 = Fraction of air that is oxygen, percent/100.

F<sub>d</sub> = Ratio of the volume of dry effluent gas to the gross calorific value of the fuel from Method 19, dsm<sup>3</sup> /J (dscf/10<sup>6</sup> Btu).

F<sub>c</sub> = Ratio of the volume of CO<sub>2</sub> produced to the gross calorific value of the fuel from Method 19, dsm<sup>3</sup> /J (dscf/10<sup>6</sup> Btu)

(ii) Calculate the CO<sub>2</sub> correction factor for correcting measurement data to 15 percent O<sub>2</sub> , as follows:

$$X_{CO_2} = \frac{5.9}{F_o} \quad (\text{Eq. 3})$$

Where:

X<sub>CO<sub>2</sub></sub> = CO<sub>2</sub> correction factor, percent.

5.9 = 20.9 percent O<sub>2</sub> —15 percent O<sub>2</sub> , the defined O<sub>2</sub> correction value, percent.

(iii) Calculate the CO, THC, and formaldehyde gas concentrations adjusted to 15 percent O<sub>2</sub> using CO<sub>2</sub> as follows:

$$C_{adj} = C_d \frac{X_{CO_2}}{\%CO_2} \quad (\text{Eq. 4})$$

Where:

C<sub>adj</sub> = Calculated concentration of CO, THC, or formaldehyde adjusted to 15 percent O<sub>2</sub>.

C<sub>d</sub> = Measured concentration of CO, THC, or formaldehyde, uncorrected.

X<sub>CO<sub>2</sub></sub> = CO<sub>2</sub> correction factor, percent.

%CO<sub>2</sub> = Measured CO<sub>2</sub> concentration measured, dry basis, percent.

(f) If you comply with the emission limitation to reduce CO and you are not using an oxidation catalyst, if you comply with the emission limitation to reduce formaldehyde and you are not using NSCR, or if you comply with the emission limitation to limit the concentration of formaldehyde in the stationary RICE exhaust and you are not using an oxidation catalyst or NSCR, you must petition the Administrator for operating limitations to be established during the initial performance test and continuously monitored thereafter; or for approval of no operating limitations. You must not conduct the initial performance test until after the petition has been approved by the Administrator.

(g) If you petition the Administrator for approval of operating limitations, your petition must include the information described in paragraphs (g)(1) through (5) of this section.

(1) Identification of the specific parameters you propose to use as operating limitations;

(2) A discussion of the relationship between these parameters and HAP emissions, identifying how HAP emissions change with changes in these parameters, and how limitations on these parameters will serve to limit HAP emissions;

(3) A discussion of how you will establish the upper and/or lower values for these parameters which will establish the limits on these parameters in the operating limitations;

(4) A discussion identifying the methods you will use to measure and the instruments you will use to monitor these parameters, as well as the relative accuracy and precision of these methods and instruments; and

(5) A discussion identifying the frequency and methods for recalibrating the instruments you will use for monitoring these parameters.

(h) If you petition the Administrator for approval of no operating limitations, your petition must include the information described in paragraphs (h)(1) through (7) of this section.

(1) Identification of the parameters associated with operation of the stationary RICE and any emission control device which could change intentionally ( e.g., operator adjustment, automatic controller adjustment, etc.) or unintentionally ( e.g., wear and tear, error, etc.) on a routine basis or over time;

(2) A discussion of the relationship, if any, between changes in the parameters and changes in HAP emissions;

(3) For the parameters which could change in such a way as to increase HAP emissions, a discussion of whether establishing limitations on the parameters would serve to limit HAP emissions;

(4) For the parameters which could change in such a way as to increase HAP emissions, a discussion of how you could establish upper and/or lower values for the parameters which would establish limits on the parameters in operating limitations;

(5) For the parameters, a discussion identifying the methods you could use to measure them and the instruments you could use to monitor them, as well as the relative accuracy and precision of the methods and instruments;

(6) For the parameters, a discussion identifying the frequency and methods for recalibrating the instruments you could use to monitor them; and

(7) A discussion of why, from your point of view, it is infeasible or unreasonable to adopt the parameters as operating limitations.

(i) The engine percent load during a performance test must be determined by documenting the calculations, assumptions, and measurement devices used to measure or estimate the percent load in a specific application. A written report of the average percent load determination must be included in the notification of compliance status. The following information must be included in the written report: the engine model number, the engine manufacturer, the year of purchase, the manufacturer's site-rated brake horsepower, the ambient temperature, pressure, and humidity during the performance test, and all assumptions that were made to estimate or calculate percent load during the performance test must be

clearly explained. If measurement devices such as flow meters, kilowatt meters, beta analyzers, stain gauges, etc. are used, the model number of the measurement device, and an estimate of its accurate in percentage of true value must be provided.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9676, Mar. 3, 2010; 78 FR 6702, Jan. 30, 2013]

**§ 63.6625 What are my monitoring, installation, collection, operation, and maintenance requirements?**

(a) If you elect to install a CEMS as specified in Table 5 of this subpart, you must install, operate, and maintain a CEMS to monitor CO and either O<sub>2</sub> or CO<sub>2</sub> according to the requirements in paragraphs (a)(1) through (4) of this section. If you are meeting a requirement to reduce CO emissions, the CEMS must be installed at both the inlet and outlet of the control device. If you are meeting a requirement to limit the concentration of CO, the CEMS must be installed at the outlet of the control device.

(1) Each CEMS must be installed, operated, and maintained according to the applicable performance specifications of 40 CFR part 60, appendix B.

(2) You must conduct an initial performance evaluation and an annual relative accuracy test audit (RATA) of each CEMS according to the requirements in § 63.8 and according to the applicable performance specifications of 40 CFR part 60, appendix B as well as daily and periodic data quality checks in accordance with 40 CFR part 60, appendix F, procedure 1.

(3) As specified in § 63.8(c)(4)(ii), each CEMS must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period. You must have at least two data points, with each representing a different 15-minute period, to have a valid hour of data.

(4) The CEMS data must be reduced as specified in § 63.8(g)(2) and recorded in parts per million or parts per billion (as appropriate for the applicable limitation) at 15 percent oxygen or the equivalent CO<sub>2</sub> concentration.

(b) If you are required to install a continuous parameter monitoring system (CPMS) as specified in Table 5 of this subpart, you must install, operate, and maintain each CPMS according to the requirements in paragraphs (b)(1) through (6) of this section. For an affected source that is complying with the emission limitations and operating limitations on March 9, 2011, the requirements in paragraph (b) of this section are applicable September 6, 2011.

(1) You must prepare a site-specific monitoring plan that addresses the monitoring system design, data collection, and the quality assurance and quality control elements outlined in paragraphs (b)(1)(i) through (v) of this section and in § 63.8(d). As specified in § 63.8(f)(4), you may request approval of monitoring system quality assurance and quality control procedures alternative to those specified in paragraphs (b)(1) through (5) of this section in your site-specific monitoring plan.

(i) The performance criteria and design specifications for the monitoring system equipment, including the sample interface, detector signal analyzer, and data acquisition and calculations;

(ii) Sampling interface ( e.g., thermocouple) location such that the monitoring system will provide representative measurements;

(iii) Equipment performance evaluations, system accuracy audits, or other audit procedures;

(iv) Ongoing operation and maintenance procedures in accordance with provisions in § 63.8(c)(1)(ii) and (c)(3); and

(v) Ongoing reporting and recordkeeping procedures in accordance with provisions in § 63.10(c), (e)(1), and (e)(2)(i).

(2) You must install, operate, and maintain each CPMS in continuous operation according to the procedures in your site-specific monitoring plan.

(3) The CPMS must collect data at least once every 15 minutes (see also § 63.6635).

(4) For a CPMS for measuring temperature range, the temperature sensor must have a minimum tolerance of 2.8 degrees Celsius (5 degrees Fahrenheit) or 1 percent of the measurement range, whichever is larger.

(5) You must conduct the CPMS equipment performance evaluation, system accuracy audits, or other audit procedures specified in your site-specific monitoring plan at least annually.

(6) You must conduct a performance evaluation of each CPMS in accordance with your site-specific monitoring plan.

(c) If you are operating a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must monitor and record your fuel usage daily with separate fuel meters to measure the volumetric flow rate of each fuel. In addition, you must operate your stationary RICE in a manner which reasonably minimizes HAP emissions.

(d) If you are operating a new or reconstructed emergency 4SLB stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions, you must install a non-resettable hour meter prior to the startup of the engine.

(e) If you own or operate any of the following stationary RICE, you must operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission-related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions:

(1) An existing stationary RICE with a site rating of less than 100 HP located at a major source of HAP emissions;

(2) An existing emergency or black start stationary RICE with a site rating of less than or equal to 500 HP located at a major source of HAP emissions;

(3) An existing emergency or black start stationary RICE located at an area source of HAP emissions;

(4) An existing non-emergency, non-black start stationary CI RICE with a site rating less than or equal to 300 HP located at an area source of HAP emissions;

(5) An existing non-emergency, non-black start 2SLB stationary RICE located at an area source of HAP emissions;

(6) An existing non-emergency, non-black start stationary RICE located at an area source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis.

(7) An existing non-emergency, non-black start 4SLB stationary RICE with a site rating less than or equal to 500 HP located at an area source of HAP emissions;

(8) An existing non-emergency, non-black start 4SRB stationary RICE with a site rating less than or equal to 500 HP located at an area source of HAP emissions;

(9) An existing, non-emergency, non-black start 4SLB stationary RICE with a site rating greater than 500 HP located at an area source of HAP emissions that is operated 24 hours or less per calendar year; and

(10) An existing, non-emergency, non-black start 4SRB stationary RICE with a site rating greater than 500 HP located at an area source of HAP emissions that is operated 24 hours or less per calendar year.

(f) If you own or operate an existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing emergency stationary RICE located at an area source of HAP emissions, you must install a non-resettable hour meter if one is not already installed.

(g) If you own or operate an existing non-emergency, non-black start CI engine greater than or equal to 300 HP that is not equipped with a closed crankcase ventilation system, you must comply with either paragraph (g)(1) or paragraph (2) of this section. Owners and operators must follow the manufacturer's specified maintenance requirements for operating and maintaining the open or closed crankcase ventilation systems and replacing the crankcase filters, or can request the Administrator to approve different maintenance requirements that are as protective as manufacturer requirements. Existing CI engines located at area sources in areas of Alaska that meet either § 63.6603(b)(1) or § 63.6603(b)(2) do not have to meet the requirements of this paragraph (g). Existing CI engines located on offshore vessels that meet § 63.6603(c) do not have to meet the requirements of this paragraph (g).

(1) Install a closed crankcase ventilation system that prevents crankcase emissions from being emitted to the atmosphere, or

(2) Install an open crankcase filtration emission control system that reduces emissions from the crankcase by filtering the exhaust stream to remove oil mist, particulates and metals.

(h) If you operate a new, reconstructed, or existing stationary engine, you must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup in Tables 1a, 2a, 2c, and 2d to this subpart apply.

(i) If you own or operate a stationary CI engine that is subject to the work, operation or management practices in items 1 or 2 of Table 2c to this subpart or in items 1 or 4 of Table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.

(j) If you own or operate a stationary SI engine that is subject to the work, operation or management practices in items 6, 7, or 8 of Table 2c to this subpart or in items 5, 6, 7, 9, or 11 of Table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Acid Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Acid Number increases by more than 3.0 milligrams of potassium hydroxide (KOH) per gram from Total Acid Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3606, Jan. 18, 2008; 75 FR 9676, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010; 76 FR 12866, Mar. 9, 2011; 78 FR 6703, Jan. 30, 2013]

**§ 63.6630 How do I demonstrate initial compliance with the emission limitations, operating limitations, and other requirements?**

(a) You must demonstrate initial compliance with each emission limitation, operating limitation, and other requirement that applies to you according to Table 5 of this subpart.

(b) During the initial performance test, you must establish each operating limitation in Tables 1b and 2b of this subpart that applies to you.

(c) You must submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in § 63.6645.

(d) Non-emergency 4SRB stationary RICE complying with the requirement to reduce formaldehyde emissions by 76 percent or more can demonstrate initial compliance with the formaldehyde emission limit by testing for THC instead of formaldehyde. The testing must be conducted according to the requirements in Table 4 of this subpart. The average reduction of emissions of THC determined from the performance test must be equal to or greater than 30 percent.

(e) The initial compliance demonstration required for existing non-emergency 4SLB and 4SRB stationary RICE with a site rating of more than 500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year must be conducted according to the following requirements:

(1) The compliance demonstration must consist of at least three test runs.

(2) Each test run must be of at least 15 minute duration, except that each test conducted using the method in appendix A to this subpart must consist of at least one measurement cycle and include at least 2 minutes of test data phase measurement.

(3) If you are demonstrating compliance with the CO concentration or CO percent reduction requirement, you must measure CO emissions using one of the CO measurement methods specified in Table 4 of this subpart, or using appendix A to this subpart.



(4) If you are demonstrating compliance with the THC percent reduction requirement, you must measure THC emissions using Method 25A, reported as propane, of 40 CFR part 60, appendix A.

(5) You must measure O<sub>2</sub> using one of the O<sub>2</sub> measurement methods specified in Table 4 of this subpart. Measurements to determine O<sub>2</sub> concentration must be made at the same time as the measurements for CO or THC concentration.

(6) If you are demonstrating compliance with the CO or THC percent reduction requirement, you must measure CO or THC emissions and O<sub>2</sub> emissions simultaneously at the inlet and outlet of the control device.

[69 FR 33506, June 15, 2004, as amended at 78 FR 6704, Jan. 30, 2013]

### **Continuous Compliance Requirements**

#### **§ 63.6635 How do I monitor and collect data to demonstrate continuous compliance?**

(a) If you must comply with emission and operating limitations, you must monitor and collect data according to this section.

(b) Except for monitor malfunctions, associated repairs, required performance evaluations, and required quality assurance or control activities, you must monitor continuously at all times that the stationary RICE is operating. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions.

(c) You may not use data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities in data averages and calculations used to report emission or operating levels. You must, however, use all the valid data collected during all other periods.

[69 FR 33506, June 15, 2004, as amended at 76 FR 12867, Mar. 9, 2011]

#### **§ 63.6640 How do I demonstrate continuous compliance with the emission limitations, operating limitations, and other requirements?**

(a) You must demonstrate continuous compliance with each emission limitation, operating limitation, and other requirements in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply to you according to methods specified in Table 6 to this subpart.

(b) You must report each instance in which you did not meet each emission limitation or operating limitation in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply to you. These instances are deviations from the emission and operating limitations in this subpart. These deviations must be reported according to the requirements in § 63.6650. If you change your catalyst, you must reestablish the values of the operating parameters measured during the initial performance test. When you reestablish the values of your operating parameters, you must also conduct a performance test to demonstrate that you are meeting the required emission limitation applicable to your stationary RICE.

(c) The annual compliance demonstration required for existing non-emergency 4SLB and 4SRB stationary RICE with a site rating of more than 500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year must be conducted according to the following requirements:

(1) The compliance demonstration must consist of at least one test run.

(2) Each test run must be of at least 15 minute duration, except that each test conducted using the method in appendix A to this subpart must consist of at least one measurement cycle and include at least 2 minutes of test data phase measurement.

(3) If you are demonstrating compliance with the CO concentration or CO percent reduction requirement, you must measure CO emissions using one of the CO measurement methods specified in Table 4 of this subpart, or using appendix A to this subpart.

(4) If you are demonstrating compliance with the THC percent reduction requirement, you must measure THC emissions using Method 25A, reported as propane, of 40 CFR part 60, appendix A.

(5) You must measure O<sub>2</sub> using one of the O<sub>2</sub> measurement methods specified in Table 4 of this subpart. Measurements to determine O<sub>2</sub> concentration must be made at the same time as the measurements for CO or THC concentration.

(6) If you are demonstrating compliance with the CO or THC percent reduction requirement, you must measure CO or THC emissions and O<sub>2</sub> emissions simultaneously at the inlet and outlet of the control device.

(7) If the results of the annual compliance demonstration show that the emissions exceed the levels specified in Table 6 of this subpart, the stationary RICE must be shut down as soon as safely possible, and appropriate corrective action must be taken (e.g., repairs, catalyst cleaning, catalyst replacement). The stationary RICE must be retested within 7 days of being restarted and the emissions must meet the levels specified in Table 6 of this subpart. If the retest shows that the emissions continue to exceed the specified levels, the stationary RICE must again be shut down as soon as safely possible, and the stationary RICE may not operate, except for purposes of startup and testing, until the owner/operator demonstrates through testing that the emissions do not exceed the levels specified in Table 6 of this subpart.

(d) For new, reconstructed, and rebuilt stationary RICE, deviations from the emission or operating limitations that occur during the first 200 hours of operation from engine startup (engine burn-in period) are not violations. Rebuilt stationary RICE means a stationary RICE that has been rebuilt as that term is defined in 40 CFR 94.11(a).

(e) You must also report each instance in which you did not meet the requirements in Table 8 to this subpart that apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing emergency stationary RICE, an existing limited use stationary RICE, or an existing stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart, except for the initial notification requirements: a new or reconstructed stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new or reconstructed emergency stationary RICE, or a new or reconstructed limited use stationary RICE.

(f) If you own or operate an emergency stationary RICE, you must operate the emergency stationary RICE according to the requirements in paragraphs (f)(1) through (4) of this section. In order for the engine to be considered an emergency stationary RICE under this subpart, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency

situations for 50 hours per year, as described in paragraphs (f)(1) through (4) of this section, is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1) through (4) of this section, the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines.

(1) There is no time limit on the use of emergency stationary RICE in emergency situations.

(2) You may operate your emergency stationary RICE for any combination of the purposes specified in paragraphs (f)(2)(i) through (iii) of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraphs (f)(3) and (4) of this section counts as part of the 100 hours per calendar year allowed by this paragraph (f)(2).

(i) Emergency stationary RICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency RICE beyond 100 hours per calendar year.

(ii) Emergency stationary RICE may be operated for emergency demand response for periods in which the Reliability Coordinator under the North American Electric Reliability Corporation (NERC) Reliability Standard EOP-002-3, Capacity and Energy Emergencies (incorporated by reference, see § 63.14), or other authorized entity as determined by the Reliability Coordinator, has declared an Energy Emergency Alert Level 2 as defined in the NERC Reliability Standard EOP-002-3.

(iii) Emergency stationary RICE may be operated for periods where there is a deviation of voltage or frequency of 5 percent or greater below standard voltage or frequency.

(3) Emergency stationary RICE located at major sources of HAP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing and emergency demand response provided in paragraph (f)(2) of this section. The 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

(4) Emergency stationary RICE located at area sources of HAP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing and emergency demand response provided in paragraph (f)(2) of this section. Except as provided in paragraphs (f)(4)(i) and (ii) of this section, the 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

(i) Prior to May 3, 2014, the 50 hours per year for non-emergency situations can be used for peak shaving or non-emergency demand response to generate income for a facility, or to otherwise supply power as part of a financial arrangement with another entity if the engine is operated as part of a peak shaving (load management program) with the local distribution system operator and the power is provided only to the facility itself or to support the local distribution system.

(ii) The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:

(A) The engine is dispatched by the local balancing authority or local transmission and distribution system operator.

(B) The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.

(C) The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.

(D) The power is provided only to the facility itself or to support the local transmission and distribution system.

(E) The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine owner or operator.

[69 FR 33506, June 15, 2004, as amended at 71 FR 20467, Apr. 20, 2006; 73 FR 3606, Jan. 18, 2008; 75 FR 9676, Mar. 3, 2010; 75 FR 51591, Aug. 20, 2010; 78 FR 6704, Jan. 30, 2013]

## **Notifications, Reports, and Records**

### **§ 63.6645 What notifications must I submit and when?**

(a) You must submit all of the notifications in §§ 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), 63.9(b) through (e), and (g) and (h) that apply to you by the dates specified if you own or operate any of the following;

(1) An existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions.

(2) An existing stationary RICE located at an area source of HAP emissions.

(3) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.

(4) A new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 HP located at a major source of HAP emissions.

(5) This requirement does not apply if you own or operate an existing stationary RICE less than 100 HP, an existing stationary emergency RICE, or an existing stationary RICE that is not subject to any numerical emission standards.

(b) As specified in § 63.9(b)(2), if you start up your stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions before the effective date of this subpart, you must submit an Initial Notification not later than December 13, 2004.

(c) If you start up your new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions on or after August 16, 2004, you must submit an Initial Notification not later than 120 days after you become subject to this subpart.

(d) As specified in § 63.9(b)(2), if you start up your stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions before the effective date of this subpart

and you are required to submit an initial notification, you must submit an Initial Notification not later than July 16, 2008.

(e) If you start up your new or reconstructed stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions on or after March 18, 2008 and you are required to submit an initial notification, you must submit an Initial Notification not later than 120 days after you become subject to this subpart.

(f) If you are required to submit an Initial Notification but are otherwise not affected by the requirements of this subpart, in accordance with § 63.6590(b), your notification should include the information in § 63.9(b)(2)(i) through (v), and a statement that your stationary RICE has no additional requirements and explain the basis of the exclusion (for example, that it operates exclusively as an emergency stationary RICE if it has a site rating of more than 500 brake HP located at a major source of HAP emissions).

(g) If you are required to conduct a performance test, you must submit a Notification of Intent to conduct a performance test at least 60 days before the performance test is scheduled to begin as required in § 63.7(b)(1).

(h) If you are required to conduct a performance test or other initial compliance demonstration as specified in Tables 4 and 5 to this subpart, you must submit a Notification of Compliance Status according to § 63.9(h)(2)(ii).

(1) For each initial compliance demonstration required in Table 5 to this subpart that does not include a performance test, you must submit the Notification of Compliance Status before the close of business on the 30th day following the completion of the initial compliance demonstration.

(2) For each initial compliance demonstration required in Table 5 to this subpart that includes a performance test conducted according to the requirements in Table 3 to this subpart, you must submit the Notification of Compliance Status, including the performance test results, before the close of business on the 60th day following the completion of the performance test according to § 63.10(d)(2).

(i) If you own or operate an existing non-emergency CI RICE with a site rating of more than 300 HP located at an area source of HAP emissions that is certified to the Tier 1 or Tier 2 emission standards in Table 1 of 40 CFR 89.112 and subject to an enforceable state or local standard requiring engine replacement and you intend to meet management practices rather than emission limits, as specified in § 63.6603(d), you must submit a notification by March 3, 2013, stating that you intend to use the provision in § 63.6603(d) and identifying the state or local regulation that the engine is subject to.

[73 FR 3606, Jan. 18, 2008, as amended at 75 FR 9677, Mar. 3, 2010; 75 FR 51591, Aug. 20, 2010; 78 FR 6705, Jan. 30, 2013]

#### **§ 63.6650 What reports must I submit and when?**

(a) You must submit each report in Table 7 of this subpart that applies to you.

(b) Unless the Administrator has approved a different schedule for submission of reports under § 63.10(a), you must submit each report by the date in Table 7 of this subpart and according to the requirements in paragraphs (b)(1) through (b)(9) of this section.

(1) For semiannual Compliance reports, the first Compliance report must cover the period beginning on the compliance date that is specified for your affected source in § 63.6595 and ending on June 30 or December 31, whichever date is the first date following the end of the first calendar half after the compliance date that is specified for your source in § 63.6595.

(2) For semiannual Compliance reports, the first Compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date follows the end of the first calendar half after the compliance date that is specified for your affected source in § 63.6595.

(3) For semiannual Compliance reports, each subsequent Compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31.

(4) For semiannual Compliance reports, each subsequent Compliance report must be postmarked or delivered no later than July 31 or January 31, whichever date is the first date following the end of the semiannual reporting period.

(5) For each stationary RICE that is subject to permitting regulations pursuant to 40 CFR part 70 or 71, and if the permitting authority has established dates for submitting semiannual reports pursuant to 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6 (a)(3)(iii)(A), you may submit the first and subsequent Compliance reports according to the dates the permitting authority has established instead of according to the dates in paragraphs (b)(1) through (b)(4) of this section.

(6) For annual Compliance reports, the first Compliance report must cover the period beginning on the compliance date that is specified for your affected source in § 63.6595 and ending on December 31.

(7) For annual Compliance reports, the first Compliance report must be postmarked or delivered no later than January 31 following the end of the first calendar year after the compliance date that is specified for your affected source in § 63.6595.

(8) For annual Compliance reports, each subsequent Compliance report must cover the annual reporting period from January 1 through December 31.

(9) For annual Compliance reports, each subsequent Compliance report must be postmarked or delivered no later than January 31.

(c) The Compliance report must contain the information in paragraphs (c)(1) through (6) of this section.

(1) Company name and address.

(2) Statement by a responsible official, with that official's name, title, and signature, certifying the accuracy of the content of the report.

(3) Date of report and beginning and ending dates of the reporting period.

(4) If you had a malfunction during the reporting period, the compliance report must include the number, duration, and a brief description for each type of malfunction which occurred during the reporting period and which caused or may have caused any applicable emission limitation to be exceeded. The report must also include a description of actions taken by an owner or operator during a malfunction of an affected source to minimize emissions in accordance with § 63.6605(b), including actions taken to correct a malfunction.

(5) If there are no deviations from any emission or operating limitations that apply to you, a statement that there were no deviations from the emission or operating limitations during the reporting period.

(6) If there were no periods during which the continuous monitoring system (CMS), including CEMS and CPMS, was out-of-control, as specified in § 63.8(c)(7), a statement that there were no periods during which the CMS was out-of-control during the reporting period.

(d) For each deviation from an emission or operating limitation that occurs for a stationary RICE where you are not using a CMS to comply with the emission or operating limitations in this subpart, the Compliance report must contain the information in paragraphs (c)(1) through (4) of this section and the information in paragraphs (d)(1) and (2) of this section.

(1) The total operating time of the stationary RICE at which the deviation occurred during the reporting period.

(2) Information on the number, duration, and cause of deviations (including unknown cause, if applicable), as applicable, and the corrective action taken.

(e) For each deviation from an emission or operating limitation occurring for a stationary RICE where you are using a CMS to comply with the emission and operating limitations in this subpart, you must include information in paragraphs (c)(1) through (4) and (e)(1) through (12) of this section.

(1) The date and time that each malfunction started and stopped.

(2) The date, time, and duration that each CMS was inoperative, except for zero (low-level) and high-level checks.

(3) The date, time, and duration that each CMS was out-of-control, including the information in § 63.8(c)(8).

(4) The date and time that each deviation started and stopped, and whether each deviation occurred during a period of malfunction or during another period.

(5) A summary of the total duration of the deviation during the reporting period, and the total duration as a percent of the total source operating time during that reporting period.

(6) A breakdown of the total duration of the deviations during the reporting period into those that are due to control equipment problems, process problems, other known causes, and other unknown causes.

(7) A summary of the total duration of CMS downtime during the reporting period, and the total duration of CMS downtime as a percent of the total operating time of the stationary RICE at which the CMS downtime occurred during that reporting period.

(8) An identification of each parameter and pollutant (CO or formaldehyde) that was monitored at the stationary RICE.

(9) A brief description of the stationary RICE.

(10) A brief description of the CMS.

(11) The date of the latest CMS certification or audit.

(12) A description of any changes in CMS, processes, or controls since the last reporting period.

(f) Each affected source that has obtained a title V operating permit pursuant to 40 CFR part 70 or 71 must report all deviations as defined in this subpart in the semiannual monitoring report required by 40 CFR 70.6 (a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If an affected source submits a Compliance report pursuant to Table 7 of this subpart along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the Compliance report includes all required

information concerning deviations from any emission or operating limitation in this subpart, submission of the Compliance report shall be deemed to satisfy any obligation to report the same deviations in the semiannual monitoring report. However, submission of a Compliance report shall not otherwise affect any obligation the affected source may have to report deviations from permit requirements to the permit authority.

(g) If you are operating as a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must submit an annual report according to Table 7 of this subpart by the date specified unless the Administrator has approved a different schedule, according to the information described in paragraphs (b)(1) through (b)(5) of this section. You must report the data specified in (g)(1) through (g)(3) of this section.

(1) Fuel flow rate of each fuel and the heating values that were used in your calculations. You must also demonstrate that the percentage of heat input provided by landfill gas or digester gas is equivalent to 10 percent or more of the total fuel consumption on an annual basis.

(2) The operating limits provided in your federally enforceable permit, and any deviations from these limits.

(3) Any problems or errors suspected with the meters.

(h) If you own or operate an emergency stationary RICE with a site rating of more than 100 brake HP that operates or is contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in § 63.6640(f)(2)(ii) and (iii) or that operates for the purpose specified in § 63.6640(f)(4)(ii), you must submit an annual report according to the requirements in paragraphs (h)(1) through (3) of this section.

(1) The report must contain the following information:

(i) Company name and address where the engine is located.

(ii) Date of the report and beginning and ending dates of the reporting period.

(iii) Engine site rating and model year.

(iv) Latitude and longitude of the engine in decimal degrees reported to the fifth decimal place.

(v) Hours operated for the purposes specified in § 63.6640(f)(2)(ii) and (iii), including the date, start time, and end time for engine operation for the purposes specified in § 63.6640(f)(2)(ii) and (iii).

(vi) Number of hours the engine is contractually obligated to be available for the purposes specified in § 63.6640(f)(2)(ii) and (iii).

(vii) Hours spent for operation for the purpose specified in § 63.6640(f)(4)(ii), including the date, start time, and end time for engine operation for the purposes specified in § 63.6640(f)(4)(ii). The report must also identify the entity that dispatched the engine and the situation that necessitated the dispatch of the engine.

(viii) If there were no deviations from the fuel requirements in § 63.6604 that apply to the engine (if any), a statement that there were no deviations from the fuel requirements during the reporting period.

(ix) If there were deviations from the fuel requirements in § 63.6604 that apply to the engine (if any), information on the number, duration, and cause of deviations, and the corrective action taken.



(2) The first annual report must cover the calendar year 2015 and must be submitted no later than March 31, 2016. Subsequent annual reports for each calendar year must be submitted no later than March 31 of the following calendar year.

(3) The annual report must be submitted electronically using the subpart specific reporting form in the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data Exchange (CDX) ( [www.epa.gov/cdx](http://www.epa.gov/cdx) ). However, if the reporting form specific to this subpart is not available in CEDRI at the time that the report is due, the written report must be submitted to the Administrator at the appropriate address listed in § 63.13.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9677, Mar. 3, 2010; 78 FR 6705, Jan. 30, 2013]

#### **§ 63.6655 What records must I keep?**

(a) If you must comply with the emission and operating limitations, you must keep the records described in paragraphs (a)(1) through (a)(5), (b)(1) through (b)(3) and (c) of this section.

(1) A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted, according to the requirement in § 63.10(b)(2)(xiv).

(2) Records of the occurrence and duration of each malfunction of operation ( *i.e.*, process equipment) or the air pollution control and monitoring equipment.

(3) Records of performance tests and performance evaluations as required in § 63.10(b)(2)(viii).

(4) Records of all required maintenance performed on the air pollution control and monitoring equipment.

(5) Records of actions taken during periods of malfunction to minimize emissions in accordance with § 63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation.

(b) For each CEMS or CPMS, you must keep the records listed in paragraphs (b)(1) through (3) of this section.

(1) Records described in § 63.10(b)(2)(vi) through (xi).

(2) Previous ( *i.e.*, superseded) versions of the performance evaluation plan as required in § 63.8(d)(3).

(3) Requests for alternatives to the relative accuracy test for CEMS or CPMS as required in § 63.8(f)(6)(i), if applicable.

(c) If you are operating a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must keep the records of your daily fuel usage monitors.

(d) You must keep the records required in Table 6 of this subpart to show continuous compliance with each emission or operating limitation that applies to you.

(e) You must keep records of the maintenance conducted on the stationary RICE in order to demonstrate that you operated and maintained the stationary RICE and after-treatment control device (if any) according to your own maintenance plan if you own or operate any of the following stationary RICE;

(1) An existing stationary RICE with a site rating of less than 100 brake HP located at a major source of HAP emissions.

(2) An existing stationary emergency RICE.

(3) An existing stationary RICE located at an area source of HAP emissions subject to management practices as shown in Table 2d to this subpart.

(f) If you own or operate any of the stationary RICE in paragraphs (f)(1) through (2) of this section, you must keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. The owner or operator must document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for non-emergency operation. If the engine is used for the purposes specified in § 63.6640(f)(2)(ii) or (iii) or § 63.6640(f)(4)(ii), the owner or operator must keep records of the notification of the emergency situation, and the date, start time, and end time of engine operation for these purposes.

(1) An existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions that does not meet the standards applicable to non-emergency engines.

(2) An existing emergency stationary RICE located at an area source of HAP emissions that does not meet the standards applicable to non-emergency engines.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9678, Mar. 3, 2010; 75 FR 51592, Aug. 20, 2010; 78 FR 6706, Jan. 30, 2013]

#### **§ 63.6660 In what form and how long must I keep my records?**

(a) Your records must be in a form suitable and readily available for expeditious review according to § 63.10(b)(1).

(b) As specified in § 63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record readily accessible in hard copy or electronic form for at least 5 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to § 63.10(b)(1).

[69 FR 33506, June 15, 2004, as amended at 75 FR 9678, Mar. 3, 2010]

#### **Other Requirements and Information**

#### **§ 63.6665 What parts of the General Provisions apply to me?**

Table 8 to this subpart shows which parts of the General Provisions in §§ 63.1 through 63.15 apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with any of the requirements of the General Provisions specified in Table 8: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing stationary RICE that combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, an existing emergency

stationary RICE, or an existing limited use stationary RICE. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in the General Provisions specified in Table 8 except for the initial notification requirements: A new stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new emergency stationary RICE, or a new limited use stationary RICE.

[75 FR 9678, Mar. 3, 2010]

#### **§ 63.6670 Who implements and enforces this subpart?**

(a) This subpart is implemented and enforced by the U.S. EPA, or a delegated authority such as your State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency (as well as the U.S. EPA) has the authority to implement and enforce this subpart. You should contact your U.S. EPA Regional Office to find out whether this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under 40 CFR part 63, subpart E, the authorities contained in paragraph (c) of this section are retained by the Administrator of the U.S. EPA and are not transferred to the State, local, or tribal agency.

(c) The authorities that will not be delegated to State, local, or tribal agencies are:

(1) Approval of alternatives to the non-opacity emission limitations and operating limitations in § 63.6600 under § 63.6(g).

(2) Approval of major alternatives to test methods under § 63.7(e)(2)(ii) and (f) and as defined in § 63.90.

(3) Approval of major alternatives to monitoring under § 63.8(f) and as defined in § 63.90.

(4) Approval of major alternatives to recordkeeping and reporting under § 63.10(f) and as defined in § 63.90.

(5) Approval of a performance test which was conducted prior to the effective date of the rule, as specified in § 63.6610(b).

#### **§ 63.6675 What definitions apply to this subpart?**

Terms used in this subpart are defined in the Clean Air Act (CAA); in 40 CFR 63.2, the General Provisions of this part; and in this section as follows:

*Alaska Railbelt Grid* means the service areas of the six regulated public utilities that extend from Fairbanks to Anchorage and the Kenai Peninsula. These utilities are Golden Valley Electric Association; Chugach Electric Association; Matanuska Electric Association; Homer Electric Association; Anchorage Municipal Light & Power; and the City of Seward Electric System.

*Area source* means any stationary source of HAP that is not a major source as defined in part 63.

*Associated equipment* as used in this subpart and as referred to in section 112(n)(4) of the CAA, means equipment associated with an oil or natural gas exploration or production well, and includes all equipment from the well bore to the point of custody transfer, except glycol dehydration units, storage vessels with potential for flash emissions, combustion turbines, and stationary RICE.

*Backup power for renewable energy* means an engine that provides backup power to a facility that generates electricity from renewable energy resources, as that term is defined in Alaska Statute 42.45.045(l)(5) (incorporated by reference, see § 63.14).

*Black start engine* means an engine whose only purpose is to start up a combustion turbine.

*CAA* means the Clean Air Act (42 U.S.C. 7401 *et seq.*, as amended by Public Law 101-549, 104 Stat. 2399).

*Commercial emergency stationary RICE* means an emergency stationary RICE used in commercial establishments such as office buildings, hotels, stores, telecommunications facilities, restaurants, financial institutions such as banks, doctor's offices, and sports and performing arts facilities.

*Compression ignition* means relating to a type of stationary internal combustion engine that is not a spark ignition engine.

*Custody transfer* means the transfer of hydrocarbon liquids or natural gas: After processing and/or treatment in the producing operations, or from storage vessels or automatic transfer facilities or other such equipment, including product loading racks, to pipelines or any other forms of transportation. For the purposes of this subpart, the point at which such liquids or natural gas enters a natural gas processing plant is a point of custody transfer.

*Deviation* means any instance in which an affected source subject to this subpart, or an owner or operator of such a source:

- (1) Fails to meet any requirement or obligation established by this subpart, including but not limited to any emission limitation or operating limitation;
- (2) Fails to meet any term or condition that is adopted to implement an applicable requirement in this subpart and that is included in the operating permit for any affected source required to obtain such a permit; or
- (3) Fails to meet any emission limitation or operating limitation in this subpart during malfunction, regardless of whether or not such failure is permitted by this subpart.
- (4) Fails to satisfy the general duty to minimize emissions established by § 63.6(e)(1)(i).

*Diesel engine* means any stationary RICE in which a high boiling point liquid fuel injected into the combustion chamber ignites when the air charge has been compressed to a temperature sufficiently high for auto-ignition. This process is also known as compression ignition.

*Diesel fuel* means any liquid obtained from the distillation of petroleum with a boiling point of approximately 150 to 360 degrees Celsius. One commonly used form is fuel oil number 2. Diesel fuel also includes any non-distillate fuel with comparable physical and chemical properties ( e.g. biodiesel) that is suitable for use in compression ignition engines.

*Digester gas* means any gaseous by-product of wastewater treatment typically formed through the anaerobic decomposition of organic waste materials and composed principally of methane and CO<sub>2</sub>.

*Dual-fuel engine* means any stationary RICE in which a liquid fuel (typically diesel fuel) is used for compression ignition and gaseous fuel (typically natural gas) is used as the primary fuel.

*Emergency stationary RICE* means any stationary reciprocating internal combustion engine that meets all of the criteria in paragraphs (1) through (3) of this definition. All emergency stationary RICE must comply with the requirements specified in § 63.6640(f) in order to be considered emergency stationary RICE. If the engine does not comply with the requirements specified in § 63.6640(f), then it is not considered to be an emergency stationary RICE under this subpart.

(1) The stationary RICE is operated to provide electrical power or mechanical work during an emergency situation. Examples include stationary RICE used to produce power for critical networks or equipment (including power supplied to portions of a facility) when electric power from the local utility (or the normal power source, if the facility runs on its own power production) is interrupted, or stationary RICE used to pump water in the case of fire or flood, etc.

(2) The stationary RICE is operated under limited circumstances for situations not included in paragraph (1) of this definition, as specified in § 63.6640(f).

(3) The stationary RICE operates as part of a financial arrangement with another entity in situations not included in paragraph (1) of this definition only as allowed in § 63.6640(f)(2)(ii) or (iii) and § 63.6640(f)(4)(i) or (ii).

*Engine startup* means the time from initial start until applied load and engine and associated equipment reaches steady state or normal operation. For stationary engine with catalytic controls, engine startup means the time from initial start until applied load and engine and associated equipment, including the catalyst, reaches steady state or normal operation.

*Four-stroke engine* means any type of engine which completes the power cycle in two crankshaft revolutions, with intake and compression strokes in the first revolution and power and exhaust strokes in the second revolution.

*Gaseous fuel* means a material used for combustion which is in the gaseous state at standard atmospheric temperature and pressure conditions.

*Gasoline* means any fuel sold in any State for use in motor vehicles and motor vehicle engines, or nonroad or stationary engines, and commonly or commercially known or sold as gasoline.

*Glycol dehydration unit* means a device in which a liquid glycol (including, but not limited to, ethylene glycol, diethylene glycol, or triethylene glycol) absorbent directly contacts a natural gas stream and absorbs water in a contact tower or absorption column (absorber). The glycol contacts and absorbs water vapor and other gas stream constituents from the natural gas and becomes "rich" glycol. This glycol is then regenerated in the glycol dehydration unit reboiler. The "lean" glycol is then recycled.

*Hazardous air pollutants (HAP)* means any air pollutants listed in or pursuant to section 112(b) of the CAA.

*Institutional emergency stationary RICE* means an emergency stationary RICE used in institutional establishments such as medical centers, nursing homes, research centers, institutions of higher education, correctional facilities, elementary and secondary schools, libraries, religious establishments, police stations, and fire stations.

*ISO standard day conditions* means 288 degrees Kelvin (15 degrees Celsius), 60 percent relative humidity and 101.3 kilopascals pressure.

*Landfill gas* means a gaseous by-product of the land application of municipal refuse typically formed through the anaerobic decomposition of waste materials and composed principally of methane and CO<sub>2</sub>.

*Lean burn engine* means any two-stroke or four-stroke spark ignited engine that does not meet the definition of a rich burn engine.

*Limited use stationary RICE* means any stationary RICE that operates less than 100 hours per year.

*Liquefied petroleum gas* means any liquefied hydrocarbon gas obtained as a by-product in petroleum refining of natural gas production.

*Liquid fuel* means any fuel in liquid form at standard temperature and pressure, including but not limited to diesel, residual/crude oil, kerosene/naphtha (jet fuel), and gasoline.

*Major Source*, as used in this subpart, shall have the same meaning as in § 63.2, except that:

(1) Emissions from any oil or gas exploration or production well (with its associated equipment (as defined in this section)) and emissions from any pipeline compressor station or pump station shall not be aggregated with emissions from other similar units, to determine whether such emission points or stations are major sources, even when emission points are in a contiguous area or under common control;

(2) For oil and gas production facilities, emissions from processes, operations, or equipment that are not part of the same oil and gas production facility, as defined in § 63.1271 of subpart HHH of this part, shall not be aggregated;

(3) For production field facilities, only HAP emissions from glycol dehydration units, storage vessel with the potential for flash emissions, combustion turbines and reciprocating internal combustion engines shall be aggregated for a major source determination; and

(4) Emissions from processes, operations, and equipment that are not part of the same natural gas transmission and storage facility, as defined in § 63.1271 of subpart HHH of this part, shall not be aggregated.

*Malfunction* means any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner which causes, or has the potential to cause, the emission limitations in an applicable standard to be exceeded. Failures that are caused in part by poor maintenance or careless operation are not malfunctions.

*Natural gas* means a naturally occurring mixture of hydrocarbon and non-hydrocarbon gases found in geologic formations beneath the Earth's surface, of which the principal constituent is methane. Natural gas may be field or pipeline quality.

*Non-selective catalytic reduction (NSCR)* means an add-on catalytic nitrogen oxides (NO<sub>x</sub>) control device for rich burn engines that, in a two-step reaction, promotes the conversion of excess oxygen, NO<sub>x</sub>, CO, and volatile organic compounds (VOC) into CO<sub>2</sub>, nitrogen, and water.

*Oil and gas production facility* as used in this subpart means any grouping of equipment where hydrocarbon liquids are processed, upgraded (i.e., remove impurities or other constituents to meet contract specifications), or stored prior to the point of custody transfer; or where natural gas is processed, upgraded, or stored prior to entering the natural gas transmission and storage source category. For purposes of a major source determination, facility (including a building, structure, or installation) means oil and natural gas production and processing equipment that is located within the boundaries of an individual surface site as defined in this section. Equipment that is part of a facility will typically be located within close proximity to other equipment located at the same facility. Pieces of production equipment or groupings of equipment located on different oil and gas leases, mineral fee tracts, lease tracts, subsurface or surface unit areas, surface fee tracts, surface lease tracts, or separate surface sites,

whether or not connected by a road, waterway, power line or pipeline, shall not be considered part of the same facility. Examples of facilities in the oil and natural gas production source category include, but are not limited to, well sites, satellite tank batteries, central tank batteries, a compressor station that transports natural gas to a natural gas processing plant, and natural gas processing plants.

*Oxidation catalyst* means an add-on catalytic control device that controls CO and VOC by oxidation.

*Peaking unit or engine* means any standby engine intended for use during periods of high demand that are not emergencies.

*Percent load* means the fractional power of an engine compared to its maximum manufacturer's design capacity at engine site conditions. Percent load may range between 0 percent to above 100 percent.

*Potential to emit* means the maximum capacity of a stationary source to emit a pollutant under its physical and operational design. Any physical or operational limitation on the capacity of the stationary source to emit a pollutant, including air pollution control equipment and restrictions on hours of operation or on the type or amount of material combusted, stored, or processed, shall be treated as part of its design if the limitation or the effect it would have on emissions is federally enforceable. For oil and natural gas production facilities subject to subpart HH of this part, the potential to emit provisions in § 63.760(a) may be used. For natural gas transmission and storage facilities subject to subpart HHH of this part, the maximum annual facility gas throughput for storage facilities may be determined according to § 63.1270(a)(1) and the maximum annual throughput for transmission facilities may be determined according to § 63.1270(a)(2).

*Production field facility* means those oil and gas production facilities located prior to the point of custody transfer.

*Production well* means any hole drilled in the earth from which crude oil, condensate, or field natural gas is extracted.

*Propane* means a colorless gas derived from petroleum and natural gas, with the molecular structure C<sub>3</sub>H<sub>8</sub>.

*Remote stationary RICE* means stationary RICE meeting any of the following criteria:

(1) Stationary RICE located in an offshore area that is beyond the line of ordinary low water along that portion of the coast of the United States that is in direct contact with the open seas and beyond the line marking the seaward limit of inland waters.

(2) Stationary RICE located on a pipeline segment that meets both of the criteria in paragraphs (2)(i) and (ii) of this definition.

(i) A pipeline segment with 10 or fewer buildings intended for human occupancy and no buildings with four or more stories within 220 yards (200 meters) on either side of the centerline of any continuous 1-mile (1.6 kilometers) length of pipeline. Each separate dwelling unit in a multiple dwelling unit building is counted as a separate building intended for human occupancy.

(ii) The pipeline segment does not lie within 100 yards (91 meters) of either a building or a small, well-defined outside area (such as a playground, recreation area, outdoor theater, or other place of public assembly) that is occupied by 20 or more persons on at least 5 days a week for 10 weeks in any 12-month period. The days and weeks need not be consecutive. The building or area is considered occupied for a full day if it is occupied for any portion of the day.

(iii) For purposes of this paragraph (2), the term pipeline segment means all parts of those physical facilities through which gas moves in transportation, including but not limited to pipe, valves, and other appurtenance attached to pipe, compressor units, metering stations, regulator stations, delivery stations, holders, and fabricated assemblies. Stationary RICE located within 50 yards (46 meters) of the pipeline segment providing power for equipment on a pipeline segment are part of the pipeline segment. Transportation of gas means the gathering, transmission, or distribution of gas by pipeline, or the storage of gas. A building is intended for human occupancy if its primary use is for a purpose involving the presence of humans.

(3) Stationary RICE that are not located on gas pipelines and that have 5 or fewer buildings intended for human occupancy and no buildings with four or more stories within a 0.25 mile radius around the engine. A building is intended for human occupancy if its primary use is for a purpose involving the presence of humans.

*Residential emergency stationary RICE* means an emergency stationary RICE used in residential establishments such as homes or apartment buildings.

*Responsible official* means responsible official as defined in 40 CFR 70.2.

*Rich burn engine* means any four-stroke spark ignited engine where the manufacturer's recommended operating air/fuel ratio divided by the stoichiometric air/fuel ratio at full load conditions is less than or equal to 1.1. Engines originally manufactured as rich burn engines, but modified prior to December 19, 2002 with passive emission control technology for NO<sub>x</sub> (such as pre-combustion chambers) will be considered lean burn engines. Also, existing engines where there are no manufacturer's recommendations regarding air/fuel ratio will be considered a rich burn engine if the excess oxygen content of the exhaust at full load conditions is less than or equal to 2 percent.

*Site-rated HP* means the maximum manufacturer's design capacity at engine site conditions.

*Spark ignition* means relating to either: A gasoline-fueled engine; or any other type of engine with a spark plug (or other sparking device) and with operating characteristics significantly similar to the theoretical Otto combustion cycle. Spark ignition engines usually use a throttle to regulate intake air flow to control power during normal operation. Dual-fuel engines in which a liquid fuel (typically diesel fuel) is used for CI and gaseous fuel (typically natural gas) is used as the primary fuel at an annual average ratio of less than 2 parts diesel fuel to 100 parts total fuel on an energy equivalent basis are spark ignition engines.

*Stationary reciprocating internal combustion engine (RICE)* means any reciprocating internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work and which is not mobile. Stationary RICE differ from mobile RICE in that a stationary RICE is not a non-road engine as defined at 40 CFR 1068.30, and is not used to propel a motor vehicle or a vehicle used solely for competition.

*Stationary RICE test cell/stand* means an engine test cell/stand, as defined in subpart P of this part, that tests stationary RICE.

*Stoichiometric* means the theoretical air-to-fuel ratio required for complete combustion.

*Storage vessel with the potential for flash emissions* means any storage vessel that contains a hydrocarbon liquid with a stock tank gas-to-oil ratio equal to or greater than 0.31 cubic meters per liter and an American Petroleum Institute gravity equal to or greater than 40 degrees and an actual annual average hydrocarbon liquid throughput equal to or greater than 79,500 liters per day. Flash emissions occur when dissolved hydrocarbons in the fluid evolve from solution when the fluid pressure is reduced.



*Subpart* means 40 CFR part 63, subpart ZZZZ.

*Surface site* means any combination of one or more graded pad sites, gravel pad sites, foundations, platforms, or the immediate physical location upon which equipment is physically affixed.

*Two-stroke engine* means a type of engine which completes the power cycle in single crankshaft revolution by combining the intake and compression operations into one stroke and the power and exhaust operations into a second stroke. This system requires auxiliary scavenging and inherently runs lean of stoichiometric.

[69 FR 33506, June 15, 2004, as amended at 71 FR 20467, Apr. 20, 2006; 73 FR 3607, Jan. 18, 2008; 75 FR 9679, Mar. 3, 2010; 75 FR 51592, Aug. 20, 2010; 76 FR 12867, Mar. 9, 2011; 78 FR 6706, Jan. 30, 2013]

**Table 1a to Subpart ZZZZ of Part 63—Emission Limitations for Existing, New, and Reconstructed Spark Ignition, 4SRB Stationary RICE > 500 HP Located at a Major Source of HAP Emissions**

As stated in §§ 63.6600 and 63.6640, you must comply with the following emission limitations at 100 percent load plus or minus 10 percent for existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions:

| For each . . .          | You must meet the following emission limitation, except during periods of startup . . .   | During periods of startup you must . . .  |
|-------------------------|---|---|
| 1. 4SRB stationary RICE | a. Reduce formaldehyde emissions by 76 percent or more. If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004, you may reduce formaldehyde emissions by 75 percent or more until June 15, 2007 or | Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. <sup>1</sup> |
|                         | b. Limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O <sub>2</sub>   |   |

<sup>1</sup>Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

[75 FR 9679, Mar. 3, 2010, as amended at 75 FR 51592, Aug. 20, 2010]

**Table 1b to Subpart ZZZZ of Part 63—Operating Limitations for Existing, New, and Reconstructed SI 4SRB Stationary RICE >500 HP Located at a Major Source of HAP Emissions**

As stated in §§ 63.6600, 63.6603, 63.6630 and 63.6640, you must comply with the following operating limitations for existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions:

**TABLE 1B TO SUBPART ZZZZ OF PART 63—OPERATING LIMITATIONS FOR EXISTING, NEW, AND RECONSTRUCTED SI 4SRB STATIONARY RICE >500 HP LOCATED AT A MAJOR SOURCE OF HAP EMISSIONS**

| <b>For each . . .</b>  | <b>You must meet the following operating limitation, except during periods of startup . . .</b>   |
|--|---|
| 1. existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions complying with the requirement to reduce formaldehyde emissions by 76 percent or more (or by 75 percent or more, if applicable) and using NSCR; or existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O <sub>2</sub> and using NSCR; | a. maintain your catalyst so that the pressure drop across the catalyst does not change by more than 2 inches of water at 100 percent load plus or minus 10 percent from the pressure drop across the catalyst measured during the initial performance test; and<br>b. maintain the temperature of your stationary RICE exhaust so that the catalyst inlet temperature is greater than or equal to 750 °F and less than or equal to 1250 °F. <sup>1</sup> |
| 2. existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions complying with the requirement to reduce formaldehyde emissions by 76 percent or more (or by 75 percent or more, if applicable) and not using NSCR; or  | Comply with any operating limitations approved by the Administrator.  |
| existing, new and reconstructed 4SRB stationary RICE >500 HP located at a major source of HAP emissions complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust to 350 ppbvd or less at 15 percent O <sub>2</sub> and not using NSCR.   |   |

<sup>1</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.8(f) for a different temperature range.

**Table 2a to Subpart ZZZZ of Part 63—Emission Limitations for New and Reconstructed 2SLB and Compression Ignition Stationary RICE >500 HP and New and Reconstructed 4SLB Stationary RICE ≥250 HP Located at a Major Source of HAP Emissions**

As stated in §§ 63.6600 and 63.6640, you must comply with the following emission limitations for new and reconstructed lean burn and new and reconstructed compression ignition stationary RICE at 100 percent load plus or minus 10 percent:

| For each . . .          | You must meet the following emission limitation, except during periods of startup . . .  | During periods of startup you must . . .  |
|-------------------------|--|---|
| 1. 2SLB stationary RICE | a. Reduce CO emissions by 58 percent or more; or<br>b. Limit concentration of formaldehyde in the stationary RICE exhaust to 12 ppmvd or less at 15 percent O <sub>2</sub> . If you commenced construction or reconstruction between December 19, 2002 and June 15, 2004, you may limit concentration of formaldehyde to 17 ppmvd or less at 15 percent O <sub>2</sub> until June 15, 2007 | Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. <sup>1</sup> |
| 2. 4SLB stationary RICE | a. Reduce CO emissions by 93 percent or more; or   |   |
|                         | b. Limit concentration of formaldehyde in the stationary RICE exhaust to 14 ppmvd or less at 15 percent O <sub>2</sub>   |   |
| 3. CI stationary RICE   | a. Reduce CO emissions by 70 percent or more; or   |   |
|                         | b. Limit concentration of formaldehyde in the stationary RICE exhaust to 580 ppbvd or less at 15 percent O <sub>2</sub>  |   |

<sup>1</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

**Table 2b to Subpart ZZZZ of Part 63—Operating Limitations for New and Reconstructed 2SLB and CI Stationary RICE >500 HP Located at a Major Source of HAP Emissions, New and Reconstructed 4SLB Stationary RICE ≥250 HP Located at a Major Source of HAP Emissions, Existing CI Stationary RICE >500 HP**

As stated in §§ 63.6600, 63.6601, 63.6603, 63.6630, and 63.6640, you must comply with the following operating limitations for new and reconstructed 2SLB and CI stationary RICE >500 HP located at a major source of HAP emissions; new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions; and existing CI stationary RICE >500 HP:

**TABLE 2B TO SUBPART ZZZZ OF PART 63—OPERATING LIMITATIONS FOR NEW AND RECONSTRUCTED 2SLB AND CI STATIONARY RICE >500 HP LOCATED AT A MAJOR SOURCE OF HAP EMISSIONS, NEW AND RECONSTRUCTED 4SLB STATIONARY RICE ≥250 HP LOCATED AT A MAJOR SOURCE OF HAP EMISSIONS, EXISTING CI STATIONARY RICE >500 HP**

| <b>For each . . .</b>  | <b>You must meet the following operating limitation, except during periods of startup . . .</b>  |
|--|--|
| 1. New and reconstructed 2SLB and CI stationary RICE >500 HP located at a major source of HAP emissions and new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions complying with the requirement to reduce CO emissions and using an oxidation catalyst; and<br>New and reconstructed 2SLB and CI stationary RICE >500 HP located at a major source of HAP emissions and new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust and using an oxidation catalyst. | a. maintain your catalyst so that the pressure drop across the catalyst does not change by more than 2 inches of water at 100 percent load plus or minus 10 percent from the pressure drop across the catalyst that was measured during the initial performance test; and<br>b. maintain the temperature of your stationary RICE exhaust so that the catalyst inlet temperature is greater than or equal to 450 °F and less than or equal to 1350 °F. <sup>1</sup> |
| 2. Existing CI stationary RICE >500 HP complying with the requirement to limit or reduce the concentration of CO in the stationary RICE exhaust and using an oxidation catalyst  | a. maintain your catalyst so that the pressure drop across the catalyst does not change by more than 2 inches of water from the pressure drop across the catalyst that was measured during the initial performance test; and<br>b. maintain the temperature of your stationary RICE exhaust so that the catalyst inlet temperature is greater than or equal to 450 °F and less than or equal to 1350 °F. <sup>1</sup>  |
| 3. New and reconstructed 2SLB and CI stationary RICE >500 HP located at a major source of HAP emissions and new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions complying with the requirement to reduce CO emissions and not using an oxidation catalyst; and   | Comply with any operating limitations approved by the Administrator.   |

| For each . . .   | You must meet the following operating limitation, except during periods of startup . . . |
|--|--|
| New and reconstructed 2SLB and CI stationary RICE >500 HP located at a major source of HAP emissions and new and reconstructed 4SLB stationary RICE ≥250 HP located at a major source of HAP emissions complying with the requirement to limit the concentration of formaldehyde in the stationary RICE exhaust and not using an oxidation catalyst; and |  |
| existing CI stationary RICE >500 HP complying with the requirement to limit or reduce the concentration of CO in the stationary RICE exhaust and not using an oxidation catalyst.  |  |

<sup>1</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.8(f) for a different temperature range.

[78 FR 6707, Jan. 30, 2013]

**Table 2c to Subpart ZZZZ of Part 63—Requirements for Existing Compression Ignition Stationary RICE Located at a Major Source of HAP Emissions and Existing Spark Ignition Stationary RICE ≤500 HP Located at a Major Source of HAP Emissions**

As stated in §§ 63.6600, 63.6602, and 63.6640, you must comply with the following requirements for existing compression ignition stationary RICE located at a major source of HAP emissions and existing spark ignition stationary RICE ≤500 HP located at a major source of HAP emissions:

**TABLE 2C TO SUBPART ZZZZ OF PART 63—REQUIREMENTS FOR EXISTING COMPRESSION IGNITION STATIONARY RICE LOCATED AT A MAJOR SOURCE OF HAP EMISSIONS AND EXISTING SPARK IGNITION STATIONARY RICE ≤500 HP LOCATED AT A MAJOR SOURCE OF HAP EMISSIONS**

| <b>For each . . .</b>   | <b>You must meet the following requirement, except during periods of startup . . .</b>  | <b>During periods of startup you must . . .</b>   |
|---|---|---|
| 1. Emergency stationary CI RICE and black start stationary CI RICE <sup>1</sup> | a. Change oil and filter every 500 hours of operation or annually, whichever comes first. <sup>2</sup><br>b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary;<br>c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>   | Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. <sup>3</sup> |
| 2. Non-Emergency, non-black start stationary CI RICE <100 HP                    | a. Change oil and filter every 1,000 hours of operation or annually, whichever comes first. <sup>2</sup><br>b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary;<br>c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup> |   |
| 3. Non-Emergency, non-black start CI stationary RICE 100≤HP≤300 HP              | Limit concentration of CO in the stationary RICE exhaust to 230 ppmvd or less at 15 percent O <sub>2</sub> .  |   |

| <b>For each . . .</b>  | <b>You must meet the following requirement, except during periods of startup . . .</b>  | <b>During periods of startup you must . . .</b> |
|--|---|---|
| 4. Non-Emergency, non-black start CI stationary RICE 300>HP≤500.” is corrected to read “4. Non-Emergency, non-black start CI stationary RICE 300<HP≤500. | a. Limit concentration of CO in the stationary RICE exhaust to 49 ppmvd or less at 15 percent O <sub>2</sub> ; or<br>b. Reduce CO emissions by 70 percent or more.  |   |
| 5. Non-Emergency, non-black start stationary CI RICE >500 HP   | a. Limit concentration of CO in the stationary RICE exhaust to 23 ppmvd or less at 15 percent O <sub>2</sub> ; or<br>b. Reduce CO emissions by 70 percent or more.  |   |
| 6. Emergency stationary SI RICE and black start stationary SI RICE. <sup>1</sup>   | a. Change oil and filter every 500 hours of operation or annually, whichever comes first; <sup>2</sup><br>b. Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first, and replace as necessary;<br>c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup> |   |
| 7. Non-Emergency, non-black start stationary SI RICE <100 HP that are not 2SLB stationary RICE   | a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first; <sup>2</sup><br>b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first, and replace as necessary;   |   |
|  | c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>  |   |

| <b>For each . . .</b>   | <b>You must meet the following requirement, except during periods of startup . . .</b>  | <b>During periods of startup you must . . .</b> |
|---|---|---|
| 8. Non-Emergency, non-black start 2SLB stationary SI RICE <100 HP   | a. Change oil and filter every 4,320 hours of operation or annually, whichever comes first; <sup>2</sup><br>b. Inspect spark plugs every 4,320 hours of operation or annually, whichever comes first, and replace as necessary; |   |
|   | c. Inspect all hoses and belts every 4,320 hours of operation or annually, whichever comes first, and replace as necessary. <sup>3</sup>  |   |
| 9. Non-emergency, non-black start 2SLB stationary RICE 100≤HP≤500   | Limit concentration of CO in the stationary RICE exhaust to 225 ppmvd or less at 15 percent O <sub>2</sub> .  |   |
| 10. Non-emergency, non-black start 4SLB stationary RICE 100≤HP≤500  | Limit concentration of CO in the stationary RICE exhaust to 47 ppmvd or less at 15 percent O <sub>2</sub> .   |   |
| 11. Non-emergency, non-black start 4SRB stationary RICE 100≤HP≤500  | Limit concentration of formaldehyde in the stationary RICE exhaust to 10.3 ppmvd or less at 15 percent O <sub>2</sub> .   |   |
| 12. Non-emergency, non-black start stationary RICE 100≤HP≤500 which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis | Limit concentration of CO in the stationary RICE exhaust to 177 ppmvd or less at 15 percent O <sub>2</sub> .  |   |

<sup>1</sup> If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the work practice requirements on the schedule required in Table 2c of this subpart, or if performing the work practice on the required schedule would otherwise pose an unacceptable risk under federal, state, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under federal, state, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under federal, state, or local law has abated. Sources must report any failure to perform the work practice on the schedule required and the federal, state or local law under which the risk was deemed unacceptable.

<sup>2</sup> Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in Table 2c of this subpart.



<sup>3</sup> Sources can petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices.

[78 FR 6708, Jan. 30, 2013, as amended at 78 FR 14457, Mar. 6, 2013]

**Table 2d to Subpart ZZZZ of Part 63—Requirements for Existing Stationary RICE Located at Area Sources of HAP Emissions**

As stated in §§ 63.6603 and 63.6640, you must comply with the following requirements for existing stationary RICE located at area sources of HAP emissions:

**TABLE 2D TO SUBPART ZZZZ OF PART 63—REQUIREMENTS FOR EXISTING STATIONARY RICE LOCATED AT AREA SOURCES OF HAP EMISSIONS**

| <b>For each . . .</b>   | <b>You must meet the following requirement, except during periods of startup . . .</b>   | <b>During periods of startup you must . . .</b>  |
|---|--|--|
| 1. Non-Emergency, non-black start CI stationary RICE ≤300 HP    | a. Change oil and filter every 1,000 hours of operation or annually, whichever comes first; <sup>1</sup><br>b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary;<br>c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. | Minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply. |
| 2. Non-Emergency, non-black start CI stationary RICE 300<HP≤500 | a. Limit concentration of CO in the stationary RICE exhaust to 49 ppmvd at 15 percent O <sub>2</sub> ; or  |  |
|   | b. Reduce CO emissions by 70 percent or more.  |  |
| 3. Non-Emergency, non-black start CI stationary RICE >500 HP    | a. Limit concentration of CO in the stationary RICE exhaust to 23 ppmvd at 15 percent O <sub>2</sub> ; or  |  |
|   | b. Reduce CO emissions by 70 percent or more.  |  |

| For each . . .  | You must meet the following requirement, except during periods of startup . . .  | During periods of startup you must . . . |
|---|--|--|
| 4. Emergency stationary CI RICE and black start stationary CI RICE. <sup>2</sup>  | a. Change oil and filter every 500 hours of operation or annually, whichever comes first; <sup>1</sup>   |  |
|   | b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; and  |  |
|   | c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.  |  |
| 5. Emergency stationary SI RICE; black start stationary SI RICE; non-emergency, non-black start 4SLB stationary RICE >500 HP that operate 24 hours or less per calendar year; non-emergency, non-black start 4SRB stationary RICE >500 HP that operate 24 hours or less per calendar year. <sup>2</sup> | a. Change oil and filter every 500 hours of operation or annually, whichever comes first; <sup>1</sup><br>b. Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; and<br>c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. |  |
| 6. Non-emergency, non-black start 2SLB stationary RICE  | a. Change oil and filter every 4,320 hours of operation or annually, whichever comes first; <sup>1</sup>   |  |
|   | b. Inspect spark plugs every 4,320 hours of operation or annually, whichever comes first, and replace as necessary; and  |  |

| For each . . .   | You must meet the following requirement, except during periods of startup . . .   | During periods of startup you must . . . |
|--|---|--|
|  | c. Inspect all hoses and belts every 4,320 hours of operation or annually, whichever comes first, and replace as necessary. |  |
| 7. Non-emergency, non-black start 4SLB stationary RICE ≤500 HP   | a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first; <sup>1</sup>                    |  |
|  | b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first, and replace as necessary; and     |  |
|  | c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary. |  |
| 8. Non-emergency, non-black start 4SLB remote stationary RICE >500 HP  | a. Change oil and filter every 2,160 hours of operation or annually, whichever comes first; <sup>1</sup>                    |  |
|  | b. Inspect spark plugs every 2,160 hours of operation or annually, whichever comes first, and replace as necessary; and     |  |
|  | c. Inspect all hoses and belts every 2,160 hours of operation or annually, whichever comes first, and replace as necessary. |  |
| 9. Non-emergency, non-black start 4SLB stationary RICE >500 HP that are not remote stationary RICE and that operate more than 24 hours per calendar year | Install an oxidation catalyst to reduce HAP emissions from the stationary RICE.   |  |

| For each . . .   | You must meet the following requirement, except during periods of startup . . .   | During periods of startup you must . . . |
|--|---|--|
| 10. Non-emergency, non-black start 4SRB stationary RICE ≤500 HP  | a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first; <sup>1</sup>  |  |
|  | b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first, and replace as necessary; and   |  |
|  | c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary.   |  |
| 11. Non-emergency, non-black start 4SRB remote stationary RICE >500 HP   | a. Change oil and filter every 2,160 hours of operation or annually, whichever comes first; <sup>1</sup>  |  |
|  | b. Inspect spark plugs every 2,160 hours of operation or annually, whichever comes first, and replace as necessary; and   |  |
|  | c. Inspect all hoses and belts every 2,160 hours of operation or annually, whichever comes first, and replace as necessary.   |  |
| 12. Non-emergency, non-black start 4SRB stationary RICE >500 HP that are not remote stationary RICE and that operate more than 24 hours per calendar year              | Install NSCR to reduce HAP emissions from the stationary RICE.  |  |
| 13. Non-emergency, non-black start stationary RICE which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis | a. Change oil and filter every 1,440 hours of operation or annually, whichever comes first; <sup>1</sup><br>b. Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first, and replace as necessary; and |  |

| <b>For each . . .</b> | <b>You must meet the following requirement, except during periods of startup . . .</b>                                      | <b>During periods of startup you must . . .</b> |
|-----------------------|---|---|
|                       | c. Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary. |   |

<sup>1</sup> Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in Table 2d of this subpart.

<sup>2</sup> If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in Table 2d of this subpart, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under federal, state, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under federal, state, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under federal, state, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the federal, state or local law under which the risk was deemed unacceptable.

[78 FR 6709, Jan. 30, 2013]

**Table 3 to Subpart ZZZZ of Part 63—Subsequent Performance Tests**

As stated in §§ 63.6615 and 63.6620, you must comply with the following subsequent performance test requirements:

**TABLE 3 TO SUBPART ZZZZ OF PART 63—SUBSEQUENT PERFORMANCE TESTS**

| <b>For each . . .</b>   | <b>Complying with the requirement to . . .</b>                         | <b>You must . . .</b>   |
|---|--|---|
| 1. New or reconstructed 2SLB stationary RICE >500 HP located at major sources; new or reconstructed 4SLB stationary RICE ≥250 HP located at major sources; and new or reconstructed CI stationary RICE >500 HP located at major sources | Reduce CO emissions and not using a CEMS                               | Conduct subsequent performance tests semiannually. <sup>1</sup>                           |
| 2. 4SRB stationary RICE ≥5,000 HP located at major sources  | Reduce formaldehyde emissions  | Conduct subsequent performance tests semiannually. <sup>1</sup>                           |
| 3. Stationary RICE >500 HP located at major sources and new or reconstructed 4SLB stationary RICE 250≤HP≤500 located at major sources   | Limit the concentration of formaldehyde in the stationary RICE exhaust | Conduct subsequent performance tests semiannually. <sup>1</sup>                           |
| 4. Existing non-emergency, non-black start CI stationary RICE >500 HP that are not limited use stationary RICE  | Limit or reduce CO emissions and not using a CEMS                      | Conduct subsequent performance tests every 8,760 hours or 3 years, whichever comes first. |
| 5. Existing non-emergency, non-black start CI stationary RICE >500 HP that are limited use stationary RICE  | Limit or reduce CO emissions and not using a CEMS                      | Conduct subsequent performance tests every 8,760 hours or 5 years, whichever comes first. |

<sup>1</sup> After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

[78 FR 6711, Jan. 30, 2013]

**Table 4 to Subpart ZZZZ of Part 63—Requirements for Performance Tests**

As stated in §§ 63.6610, 63.6611, 63.6612, 63.6620, and 63.6640, you must comply with the following requirements for performance tests for stationary RICE:

**TABLE 4 TO SUBPART ZZZZ OF PART 63. REQUIREMENTS FOR PERFORMANCE TESTS**

| For each . . .                        | Complying with the requirement to . . . | You must . . .  | Using . . .   | According to the following requirements . . .  |
|---------------------------------------|---|---|---|--|
| 1. 2SLB, 4SLB, and CI stationary RICE | a. reduce CO emissions                  | i. Measure the O <sub>2</sub> at the inlet and outlet of the control device; and  | (1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A, or ASTM Method D6522-00 (Reapproved 2005). <sup>a c</sup>   | (a) Measurements to determine O <sub>2</sub> must be made at the same time as the measurements for CO concentration.   |
|                                       |   | ii. Measure the CO at the inlet and the outlet of the control device  | (1) ASTM D6522-00 (Reapproved 2005) <sup>a b c</sup> or Method 10 of 40 CFR part 60, appendix A   | (a) The CO concentration must be at 15 percent O <sub>2</sub> , dry basis.   |
| 2. 4SRB stationary RICE               | a. reduce formaldehyde emissions        | i. Select the sampling port location and the number of traverse points; and   | (1) Method 1 or 1A of 40 CFR part 60, appendix A § 63.7(d)(1)(i)  | (a) sampling sites must be located at the inlet and outlet of the control device.  |
|                                       |   | ii. Measure O <sub>2</sub> at the inlet and outlet of the control device; and   | (1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A, or ASTM Method D6522-00 (Reapproved 2005). <sup>a</sup>   | (a) measurements to determine O <sub>2</sub> concentration must be made at the same time as the measurements for formaldehyde or THC concentration.              |
|                                       |   | iii. Measure moisture content at the inlet and outlet of the control device; and  | (1) Method 4 of 40 CFR part 60, appendix A, or Test Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348-03. <sup>a</sup>   | (a) measurements to determine moisture content must be made at the same time and location as the measurements for formaldehyde or THC concentration.             |
|                                       |   | iv. If demonstrating compliance with the formaldehyde percent reduction requirement, measure formaldehyde at the inlet and the outlet of the control device | (1) Method 320 or 323 of 40 CFR part 63, appendix A; or ASTM D6348-03, <sup>a</sup> provided in ASTM D6348-03 Annex A5 (Analyte Spiking Technique), the percent R must be greater than or equal to 70 and less than or equal to 130 | (a) formaldehyde concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs. |

| For each . . .     | Complying with the requirement to . . .   | You must . . .   | Using . . .   | According to the following requirements . . .  |
|--------------------|---|--|---|--|
|                    |   | v. If demonstrating compliance with the THC percent reduction requirement, measure THC at the inlet and the outlet of the control device | (1) Method 25A, reported as propane, of 40 CFR part 60, appendix A  | (a) THC concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs.          |
| 3. Stationary RICE | a. limit the concentration of formaldehyde or CO in the stationary RICE exhaust | i. Select the sampling port location and the number of traverse points; and  | (1) Method 1 or 1A of 40 CFR part 60, appendix A § 63.7(d)(1)(i)  | (a) if using a control device, the sampling site must be located at the outlet of the control device.  |
|                    |   | ii. Determine the O <sub>2</sub> concentration of the stationary RICE exhaust at the sampling port location; and                         | (1) Method 3 or 3A or 3B of 40 CFR part 60, appendix A, or ASTM Method D6522-00 (Reapproved 2005). <sup>a</sup>   | (a) measurements to determine O <sub>2</sub> concentration must be made at the same time and location as the measurements for formaldehyde or CO concentration.  |
|                    |   | iii. Measure moisture content of the stationary RICE exhaust at the sampling port location; and  | (1) Method 4 of 40 CFR part 60, appendix A, or Test Method 320 of 40 CFR part 63, appendix A, or ASTM D 6348-03. <sup>a</sup>   | (a) measurements to determine moisture content must be made at the same time and location as the measurements for formaldehyde or CO concentration.              |
|                    |   | iv. Measure formaldehyde at the exhaust of the stationary RICE; or   | (1) Method 320 or 323 of 40 CFR part 63, appendix A; or ASTM D6348-03, <sup>a</sup> provided in ASTM D6348-03 Annex A5 (Analyte Spiking Technique), the percent R must be greater than or equal to 70 and less than or equal to 130 | (a) Formaldehyde concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs. |
|                    |   | v. measure CO at the exhaust of the stationary RICE.   | (1) Method 10 of 40 CFR part 60, appendix A, ASTM Method D6522-00 (2005), <sup>a</sup> Method 320 of 40 CFR part 63, appendix A, or ASTM D6348-03. <sup>a</sup>   | (a) CO concentration must be at 15 percent O <sub>2</sub> , dry basis. Results of this test consist of the average of the three 1-hour or longer runs.           |



<sup>a</sup> Incorporated by reference, see 40 CFR 63.14. You may also obtain copies from University Microfilms International, 300 North Zeeb Road, Ann Arbor, MI 48106.

<sup>b</sup> You may also use Method 320 of 40 CFR part 63, appendix A, or ASTM D6348-03.

<sup>c</sup> ASTM-D6522-00 (2005) may be used to test both CI and SI stationary RICE.

[78 FR 6711, Jan. 30, 2013]

**Table 5 to Subpart ZZZZ of Part 63—Initial Compliance With Emission Limitations, Operating Limitations, and Other Requirements**

As stated in §§ 63.6612, 63.6625 and 63.6630, you must initially comply with the emission and operating limitations as required by the following:

**TABLE 5 TO SUBPART ZZZZ OF PART 63—INITIAL COMPLIANCE WITH EMISSION LIMITATIONS, OPERATING LIMITATIONS, AND OTHER REQUIREMENTS**

| For each . . .   | Complying with the requirement to . . .                                      | You have demonstrated initial compliance if . . .  |
|--|--|--|
| 1. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP located at an area source of HAP | a. Reduce CO emissions and using oxidation catalyst, and using a CPMS        | i. The average reduction of emissions of CO determined from the initial performance test achieves the required CO percent reduction; and<br>ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b); and<br>iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test. |
| 2. Non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP located at an area source of HAP   | a. Limit the concentration of CO, using oxidation catalyst, and using a CPMS | i. The average CO concentration determined from the initial performance test is less than or equal to the CO emission limitation; and  |
|  |  | ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b); and  |
|  |  | iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.  |

| For each . . .   | Complying with the requirement to . . .                            | You have demonstrated initial compliance if . . .  |
|--|--|--|
| 3. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE $\geq$ 250 HP located at a major source of HAP, non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP located at an area source of HAP | a. Reduce CO emissions and not using oxidation catalyst            | i. The average reduction of emissions of CO determined from the initial performance test achieves the required CO percent reduction; and<br>ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in § 63.6625(b); and<br>iii. You have recorded the approved operating parameters (if any) during the initial performance test. |
| 4. Non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP located at an area source of HAP   | a. Limit the concentration of CO, and not using oxidation catalyst | i. The average CO concentration determined from the initial performance test is less than or equal to the CO emission limitation; and<br>ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in § 63.6625(b); and  |
|  |  | iii. You have recorded the approved operating parameters (if any) during the initial performance test.   |
| 5. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE $\geq$ 250 HP located at a major source of HAP, non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP located at an area source of HAP | a. Reduce CO emissions, and using a CEMS                           | i. You have installed a CEMS to continuously monitor CO and either O <sub>2</sub> or CO <sub>2</sub> at both the inlet and outlet of the oxidation catalyst according to the requirements in § 63.6625(a); and<br>ii. You have conducted a performance evaluation of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B; and  |
|  |  | iii. The average reduction of CO calculated using § 63.6620 equals or exceeds the required percent reduction. The initial test comprises the first 4-hour period after successful validation of the CEMS. Compliance is based on the average percent reduction achieved during the 4-hour period.  |
| 6. Non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP located at an area source of HAP   | a. Limit the concentration of CO, and using a CEMS                 | i. You have installed a CEMS to continuously monitor CO and either O <sub>2</sub> or CO <sub>2</sub> at the outlet of the oxidation catalyst according to the requirements in § 63.6625(a); and  |

| For each . . .   | Complying with the requirement to . . .             | You have demonstrated initial compliance if . . .   |
|--|---|---|
|  |   | ii. You have conducted a performance evaluation of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B; and   |
|  |   | iii. The average concentration of CO calculated using § 63.6620 is less than or equal to the CO emission limitation. The initial test comprises the first 4-hour period after successful validation of the CEMS. Compliance is based on the average concentration measured during the 4-hour period.              |
| 7. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP | a. Reduce formaldehyde emissions and using NSCR     | i. The average reduction of emissions of formaldehyde determined from the initial performance test is equal to or greater than the required formaldehyde percent reduction, or the average reduction of emissions of THC determined from the initial performance test is equal to or greater than 30 percent; and |
|  |   | ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b); and   |
|  |   | iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.   |
| 8. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP | a. Reduce formaldehyde emissions and not using NSCR | i. The average reduction of emissions of formaldehyde determined from the initial performance test is equal to or greater than the required formaldehyde percent reduction or the average reduction of emissions of THC determined from the initial performance test is equal to or greater than 30 percent; and  |
|  |   | ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in § 63.6625(b); and  |
|  |   | iii. You have recorded the approved operating parameters (if any) during the initial performance test.  |

| For each . . .  | Complying with the requirement to . . .  | You have demonstrated initial compliance if . . .  |
|---|--|--|
| 9. New or reconstructed non-emergency stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE $250 \leq \text{HP} \leq 500$ located at a major source of HAP, and existing non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP  | a. Limit the concentration of formaldehyde in the stationary RICE exhaust and using oxidation catalyst or NSCR     | i. The average formaldehyde concentration, corrected to 15 percent $\text{O}_2$ , dry basis, from the three test runs is less than or equal to the formaldehyde emission limitation; and<br>ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b); and                                  |
|   |  | iii. You have recorded the catalyst pressure drop and catalyst inlet temperature during the initial performance test.  |
| 10. New or reconstructed non-emergency stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE $250 \leq \text{HP} \leq 500$ located at a major source of HAP, and existing non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP | a. Limit the concentration of formaldehyde in the stationary RICE exhaust and not using oxidation catalyst or NSCR | i. The average formaldehyde concentration, corrected to 15 percent $\text{O}_2$ , dry basis, from the three test runs is less than or equal to the formaldehyde emission limitation; and<br>ii. You have installed a CPMS to continuously monitor operating parameters approved by the Administrator (if any) according to the requirements in § 63.6625(b); and |
|   |  | iii. You have recorded the approved operating parameters (if any) during the initial performance test.   |
| 11. Existing non-emergency stationary RICE $100 \leq \text{HP} \leq 500$ located at a major source of HAP, and existing non-emergency stationary CI RICE $300 < \text{HP} \leq 500$ located at an area source of HAP  | a. Reduce CO emissions   | i. The average reduction of emissions of CO or formaldehyde, as applicable determined from the initial performance test is equal to or greater than the required CO or formaldehyde, as applicable, percent reduction.   |
| 12. Existing non-emergency stationary RICE $100 \leq \text{HP} \leq 500$ located at a major source of HAP, and existing non-emergency stationary CI RICE $300 < \text{HP} \leq 500$ located at an area source of HAP  | a. Limit the concentration of formaldehyde or CO in the stationary RICE exhaust                                    | i. The average formaldehyde or CO concentration, as applicable, corrected to 15 percent $\text{O}_2$ , dry basis, from the three test runs is less than or equal to the formaldehyde or CO emission limitation, as applicable.   |
| 13. Existing non-emergency 4SLB stationary RICE >500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year   | a. Install an oxidation catalyst   | i. You have conducted an initial compliance demonstration as specified in § 63.6630(e) to show that the average reduction of emissions of CO is 93 percent or more, or the average CO concentration is less than or equal to 47 ppmvd at 15 percent $\text{O}_2$ ;   |

| For each . . .  | Complying with the requirement to . . . | You have demonstrated initial compliance if . . .  |
|---|---|--|
|   |   | ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b), or you have installed equipment to automatically shut down the engine if the catalyst inlet temperature exceeds 1350 °F.   |
| 14. Existing non-emergency 4SRB stationary RICE >500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year | a. Install NSCR                         | i. You have conducted an initial compliance demonstration as specified in § 63.6630(e) to show that the average reduction of emissions of CO is 75 percent or more, the average CO concentration is less than or equal to 270 ppmvd at 15 percent O <sub>2</sub> , or the average reduction of emissions of THC is 30 percent or more; |
|   |   | ii. You have installed a CPMS to continuously monitor catalyst inlet temperature according to the requirements in § 63.6625(b), or you have installed equipment to automatically shut down the engine if the catalyst inlet temperature exceeds 1250 °F.   |

[78 FR 6712, Jan. 30, 2013]

**Table 6 to Subpart ZZZZ of Part 63—Continuous Compliance With Emission Limitations, and Other Requirements**

As stated in § 63.6640, you must continuously comply with the emissions and operating limitations and work or management practices as required by the following:

**TABLE 6 TO SUBPART ZZZZ OF PART 63—CONTINUOUS COMPLIANCE WITH EMISSION LIMITATIONS, AND OTHER REQUIREMENTS**

| For each . . .  | Complying with the requirement to . . .                                      | You must demonstrate continuous compliance by . . .  |
|---|--|--|
| 1. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, and new or reconstructed non-emergency CI stationary RICE >500 HP located at a major source of HAP | a. Reduce CO emissions and using an oxidation catalyst, and using a CPMS     | i. Conducting semiannual performance tests for CO to demonstrate that the required CO percent reduction is achieved <sup>a</sup> ; and<br>ii. Collecting the catalyst inlet temperature data according to § 63.6625(b); and<br>iii. Reducing these data to 4-hour rolling averages; and            |
|   |  | iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and   |
|   |  | v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.   |
| 2. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, and new or reconstructed non-emergency CI stationary RICE >500 HP located at a major source of HAP | a. Reduce CO emissions and not using an oxidation catalyst, and using a CPMS | i. Conducting semiannual performance tests for CO to demonstrate that the required CO percent reduction is achieved <sup>a</sup> ; and<br>ii. Collecting the approved operating parameter (if any) data according to § 63.6625(b); and<br>iii. Reducing these data to 4-hour rolling averages; and |
|   |  | iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.   |

| For each . . .   | Complying with the requirement to . . .  | You must demonstrate continuous compliance by . . .  |
|--|--|--|
| 3. New or reconstructed non-emergency 2SLB stationary RICE >500 HP located at a major source of HAP, new or reconstructed non-emergency 4SLB stationary RICE ≥250 HP located at a major source of HAP, new or reconstructed non-emergency stationary CI RICE >500 HP located at a major source of HAP, and existing non-emergency stationary CI RICE >500 HP | a. Reduce CO emissions or limit the concentration of CO in the stationary RICE exhaust, and using a CEMS | i. Collecting the monitoring data according to § 63.6625(a), reducing the measurements to 1-hour averages, calculating the percent reduction or concentration of CO emissions according to § 63.6620; and<br>ii. Demonstrating that the catalyst achieves the required percent reduction of CO emissions over the 4-hour averaging period, or that the emission remain at or below the CO concentration limit; and |
|  |  | iii. Conducting an annual RATA of your CEMS using PS 3 and 4A of 40 CFR part 60, appendix B, as well as daily and periodic data quality checks in accordance with 40 CFR part 60, appendix F, procedure 1.   |
| 4. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP   | a. Reduce formaldehyde emissions and using NSCR  | i. Collecting the catalyst inlet temperature data according to § 63.6625(b); and   |
|  |  | ii. Reducing these data to 4-hour rolling averages; and  |
|  |  | iii. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and  |
|  |  | iv. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.  |
| 5. Non-emergency 4SRB stationary RICE >500 HP located at a major source of HAP   | a. Reduce formaldehyde emissions and not using NSCR  | i. Collecting the approved operating parameter (if any) data according to § 63.6625(b); and  |
|  |  | ii. Reducing these data to 4-hour rolling averages; and  |
|  |  | iii. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.  |

| For each . . .  | Complying with the requirement to . . .  | You must demonstrate continuous compliance by . . .  |
|---|--|--|
| 6. Non-emergency 4SRB stationary RICE with a brake HP $\geq 5,000$ located at a major source of HAP   | a. Reduce formaldehyde emissions   | Conducting semiannual performance tests for formaldehyde to demonstrate that the required formaldehyde percent reduction is achieved, or to demonstrate that the average reduction of emissions of THC determined from the performance test is equal to or greater than 30 percent. <sup>a</sup> |
| 7. New or reconstructed non-emergency stationary RICE >500 HP located at a major source of HAP and new or reconstructed non-emergency 4SLB stationary RICE $250 \leq \text{HP} \leq 500$ located at a major source of HAP | a. Limit the concentration of formaldehyde in the stationary RICE exhaust and using oxidation catalyst or NSCR     | i. Conducting semiannual performance tests for formaldehyde to demonstrate that your emissions remain at or below the formaldehyde concentration limit <sup>a</sup> ; and<br>ii. Collecting the catalyst inlet temperature data according to § 63.6625(b); and                                   |
|   |  | iii. Reducing these data to 4-hour rolling averages; and   |
|   |  | iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and   |
|   |  | v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.   |
| 8. New or reconstructed non-emergency stationary RICE >500 HP located at a major source of HAP and new or reconstructed non-emergency 4SLB stationary RICE $250 \leq \text{HP} \leq 500$ located at a major source of HAP | a. Limit the concentration of formaldehyde in the stationary RICE exhaust and not using oxidation catalyst or NSCR | i. Conducting semiannual performance tests for formaldehyde to demonstrate that your emissions remain at or below the formaldehyde concentration limit <sup>a</sup> ; and<br>ii. Collecting the approved operating parameter (if any) data according to § 63.6625(b); and                        |
|   |  | iii. Reducing these data to 4-hour rolling averages; and   |
|   |  | iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.   |



| For each . . .  | Complying with the requirement to . . .  | You must demonstrate continuous compliance by . . .   |
|---|--|---|
| <p>9. Existing emergency and black start stationary RICE ≤500 HP located at a major source of HAP, existing non-emergency stationary RICE &lt;100 HP located at a major source of HAP, existing emergency and black start stationary RICE located at an area source of HAP, existing non-emergency stationary CI RICE ≤300 HP located at an area source of HAP, existing non-emergency 2SLB stationary RICE located at an area source of HAP, existing non-emergency stationary SI RICE located at an area source of HAP which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, existing non-emergency 4SLB and 4SRB stationary RICE ≤500 HP located at an area source of HAP, existing non-emergency 4SLB and 4SRB stationary RICE &gt;500 HP located at an area source of HAP that operate 24 hours or less per calendar year, and existing non-emergency 4SLB and 4SRB stationary RICE &gt;500 HP located at an area source of HAP that are remote stationary RICE</p> | <p>a. Work or Management practices</p>   | <p>i. Operating and maintaining the stationary RICE according to the manufacturer's emission-related operation and maintenance instructions; or<br/>ii. Develop and follow your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.</p> |
| <p>10. Existing stationary CI RICE &gt;500 HP that are not limited use stationary RICE</p>  | <p>a. Reduce CO emissions, or limit the concentration of CO in the stationary RICE exhaust, and using oxidation catalyst</p> | <p>i. Conducting performance tests every 8,760 hours or 3 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and</p>  |
|   |  | <p>ii. Collecting the catalyst inlet temperature data according to § 63.6625(b); and</p>  |
|   |  | <p>iii. Reducing these data to 4-hour rolling averages; and</p>   |
|   |  | <p>iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and</p>   |

| For each . . .   | Complying with the requirement to . . .   | You must demonstrate continuous compliance by . . .   |
|--|---|---|
|  |   | v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.  |
| 11. Existing stationary CI RICE >500 HP that are not limited use stationary RICE | a. Reduce CO emissions, or limit the concentration of CO in the stationary RICE exhaust, and not using oxidation catalyst | i. Conducting performance tests every 8,760 hours or 3 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and |
|  |   | ii. Collecting the approved operating parameter (if any) data according to § 63.6625(b); and  |
|  |   | iii. Reducing these data to 4-hour rolling averages; and  |
|  |   | iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.  |
| 12. Existing limited use CI stationary RICE >500 HP                              | a. Reduce CO emissions or limit the concentration of CO in the stationary RICE exhaust, and using an oxidation catalyst   | i. Conducting performance tests every 8,760 hours or 5 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and |
|  |   | ii. Collecting the catalyst inlet temperature data according to § 63.6625(b); and   |
|  |   | iii. Reducing these data to 4-hour rolling averages; and  |
|  |   | iv. Maintaining the 4-hour rolling averages within the operating limitations for the catalyst inlet temperature; and  |

| For each . . .  | Complying with the requirement to . . .   | You must demonstrate continuous compliance by . . .   |
|---|---|---|
|   |   | v. Measuring the pressure drop across the catalyst once per month and demonstrating that the pressure drop across the catalyst is within the operating limitation established during the performance test.  |
| 13. Existing limited use CI stationary RICE >500 HP   | a. Reduce CO emissions or limit the concentration of CO in the stationary RICE exhaust, and not using an oxidation catalyst | i. Conducting performance tests every 8,760 hours or 5 years, whichever comes first, for CO or formaldehyde, as appropriate, to demonstrate that the required CO or formaldehyde, as appropriate, percent reduction is achieved or that your emissions remain at or below the CO or formaldehyde concentration limit; and   |
|   |   | ii. Collecting the approved operating parameter (if any) data according to § 63.6625(b); and  |
|   |   | iii. Reducing these data to 4-hour rolling averages; and  |
|   |   | iv. Maintaining the 4-hour rolling averages within the operating limitations for the operating parameters established during the performance test.  |
| 14. Existing non-emergency 4SLB stationary RICE >500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year | a. Install an oxidation catalyst  | i. Conducting annual compliance demonstrations as specified in § 63.6640(c) to show that the average reduction of emissions of CO is 93 percent or more, or the average CO concentration is less than or equal to 47 ppmvd at 15 percent O <sub>2</sub> ; and either<br>ii. Collecting the catalyst inlet temperature data according to § 63.6625(b), reducing these data to 4-hour rolling averages; and maintaining the 4-hour rolling averages within the limitation of greater than 450 °F and less than or equal to 1350 °F for the catalyst inlet temperature; or<br>iii. Immediately shutting down the engine if the catalyst inlet temperature exceeds 1350 °F. |

| For each . . .  | Complying with the requirement to . . . | You must demonstrate continuous compliance by . . .   |
|---|---|---|
| 15. Existing non-emergency 4SRB stationary RICE >500 HP located at an area source of HAP that are not remote stationary RICE and that are operated more than 24 hours per calendar year | a. Install NSCR                         | i. Conducting annual compliance demonstrations as specified in § 63.6640(c) to show that the average reduction of emissions of CO is 75 percent or more, the average CO concentration is less than or equal to 270 ppmvd at 15 percent O <sub>2</sub> , or the average reduction of emissions of THC is 30 percent or more; and either<br>ii. Collecting the catalyst inlet temperature data according to § 63.6625(b), reducing these data to 4-hour rolling averages; and maintaining the 4-hour rolling averages within the limitation of greater than or equal to 750 °F and less than or equal to 1250 °F for the catalyst inlet temperature; or<br>iii. Immediately shutting down the engine if the catalyst inlet temperature exceeds 1250 °F. |

<sup>a</sup> After you have demonstrated compliance for two consecutive tests, you may reduce the frequency of subsequent performance tests to annually. If the results of any subsequent annual performance test indicate the stationary RICE is not in compliance with the CO or formaldehyde emission limitation, or you deviate from any of your operating limitations, you must resume semiannual performance tests.

[78 FR 6715, Jan. 30, 2013]

**Table 7 to Subpart ZZZZ of Part 63—Requirements for Reports**

As stated in § 63.6650, you must comply with the following requirements for reports:

**TABLE 7 TO SUBPART ZZZZ OF PART 63—REQUIREMENTS FOR REPORTS**

| <b>For each . . .</b>  | <b>You must submit a . . .</b> | <b>The report must contain . . .</b>  | <b>You must submit the report . . .</b>   |
|--|--------------------------------|---|---|
| 1. Existing non-emergency, non-black start stationary RICE $100 \leq \text{HP} \leq 500$ located at a major source of HAP; existing non-emergency, non-black start stationary CI RICE $>500$ HP located at a major source of HAP; existing non-emergency 4SRB stationary RICE $>500$ HP located at a major source of HAP; existing non-emergency, non-black start stationary CI RICE $>300$ HP located at an area source of HAP; new or reconstructed non-emergency stationary RICE $>500$ HP located at a major source of HAP; and new or reconstructed non-emergency 4SLB stationary RICE $250 \leq \text{HP} \leq 500$ located at a major source of HAP | Compliance report              | a. If there are no deviations from any emission limitations or operating limitations that apply to you, a statement that there were no deviations from the emission limitations or operating limitations during the reporting period. If there were no periods during which the CMS, including CEMS and CPMS, was out-of-control, as specified in § 63.8(c)(7), a statement that there were not periods during which the CMS was out-of-control during the reporting period; or | i. Semiannually according to the requirements in § 63.6650(b)(1)-(5) for engines that are not limited use stationary RICE subject to numerical emission limitations; and<br>ii. Annually according to the requirements in § 63.6650(b)(6)-(9) for engines that are limited use stationary RICE subject to numerical emission limitations. |
|  |                                | b. If you had a deviation from any emission limitation or operating limitation during the reporting period, the information in § 63.6650(d). If there were periods during which the CMS, including CEMS and CPMS, was out-of-control, as specified in § 63.8(c)(7), the information in § 63.6650(e); or   | i. Semiannually according to the requirements in § 63.6650(b).  |
|  |                                | c. If you had a malfunction during the reporting period, the information in § 63.6650(c)(4).  | i. Semiannually according to the requirements in § 63.6650(b).  |
| 2. New or reconstructed non-emergency stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis   | Report                         | a. The fuel flow rate of each fuel and the heating values that were used in your calculations, and you must demonstrate that the percentage of heat input provided by landfill gas or digester gas, is equivalent to 10 percent or more of the gross heat input on an annual basis; and   | i. Annually, according to the requirements in § 63.6650.  |

| <b>For each . . .</b>  | <b>You must submit a . . .</b> | <b>The report must contain . . .</b>   | <b>You must submit the report . . .</b>                               |
|--|--------------------------------|--|---|
|  |                                | b. The operating limits provided in your federally enforceable permit, and any deviations from these limits; and | i. See item 2.a.i.  |
|  |                                | c. Any problems or errors suspected with the meters.   | i. See item 2.a.i.  |
| 3. Existing non-emergency, non-black start 4SLB and 4SRB stationary RICE >500 HP located at an area source of HAP that are not remote stationary RICE and that operate more than 24 hours per calendar year  | Compliance report              | a. The results of the annual compliance demonstration, if conducted during the reporting period.                 | i. Semiannually according to the requirements in § 63.6650(b)(1)-(5). |
| 4. Emergency stationary RICE that operate or are contractually obligated to be available for more than 15 hours per year for the purposes specified in § 63.6640(f)(2)(ii) and (iii) or that operate for the purposes specified in § 63.6640(f)(4)(ii) | Report                         | a. The information in § 63.6650(h)(1)  | i. annually according to the requirements in § 63.6650(h)(2)-(3).     |

[78 FR 6719, Jan. 30, 2013]

**Table 8 to Subpart ZZZZ of Part 63—Applicability of General Provisions to Subpart ZZZZ.**

As stated in § 63.6665, you must comply with the following applicable general provisions.

| <b>General provisions citation</b> | <b>Subject of citation</b>  | <b>Applies to subpart</b> | <b>Explanation</b>   |
|------------------------------------|---|---------------------------|--|
| § 63.1                             | General applicability of the General Provisions                                   | Yes.                      |  |
| § 63.2                             | Definitions   | Yes                       | Additional terms defined in § 63.6675.                               |
| § 63.3                             | Units and abbreviations   | Yes.                      |  |
| § 63.4                             | Prohibited activities and circumvention   | Yes.                      |  |
| § 63.5                             | Construction and reconstruction   | Yes.                      |  |
| § 63.6(a)                          | Applicability   | Yes.                      |  |
| § 63.6(b)(1)-(4)                   | Compliance dates for new and reconstructed sources                                | Yes.                      |  |
| § 63.6(b)(5)                       | Notification  | Yes.                      |  |
| § 63.6(b)(6)                       | [Reserved]  |                           |  |
| § 63.6(b)(7)                       | Compliance dates for new and reconstructed area sources that become major sources | Yes.                      |  |
| § 63.6(c)(1)-(2)                   | Compliance dates for existing sources   | Yes.                      |  |
| § 63.6(c)(3)-(4)                   | [Reserved]  |                           |  |
| § 63.6(c)(5)                       | Compliance dates for existing area sources that become major sources              | Yes.                      |  |
| § 63.6(d)                          | [Reserved]  |                           |  |
| § 63.6(e)                          | Operation and maintenance   | No.                       |  |
| § 63.6(f)(1)                       | Applicability of standards  | No.                       |  |
| § 63.6(f)(2)                       | Methods for determining compliance  | Yes.                      |  |
| § 63.6(f)(3)                       | Finding of compliance   | Yes.                      |  |
| § 63.6(g)(1)-(3)                   | Use of alternate standard   | Yes.                      |  |
| § 63.6(h)                          | Opacity and visible emission standards  | No                        | Subpart ZZZZ does not contain opacity or visible emission standards. |
| § 63.6(i)                          | Compliance extension procedures and criteria                                      | Yes.                      |  |

| <b>General provisions citation</b> | <b>Subject of citation</b>   | <b>Applies to subpart</b> | <b>Explanation</b>  |
|------------------------------------|--|---------------------------|---|
| § 63.6(j)                          | Presidential compliance exemption                                    | Yes.                      |   |
| § 63.7(a)(1)-(2)                   | Performance test dates   | Yes                       | Subpart ZZZZ contains performance test dates at §§ 63.6610, 63.6611, and 63.6612. |
| § 63.7(a)(3)                       | CAA section 114 authority  | Yes.                      |   |
| § 63.7(b)(1)                       | Notification of performance test                                     | Yes                       | Except that § 63.7(b)(1) only applies as specified in § 63.6645.                  |
| § 63.7(b)(2)                       | Notification of rescheduling   | Yes                       | Except that § 63.7(b)(2) only applies as specified in § 63.6645.                  |
| § 63.7(c)                          | Quality assurance/test plan  | Yes                       | Except that § 63.7(c) only applies as specified in § 63.6645.                     |
| § 63.7(d)                          | Testing facilities   | Yes.                      |   |
| § 63.7(e)(1)                       | Conditions for conducting performance tests                          | No.                       | Subpart ZZZZ specifies conditions for conducting performance tests at § 63.6620.  |
| § 63.7(e)(2)                       | Conduct of performance tests and reduction of data                   | Yes                       | Subpart ZZZZ specifies test methods at § 63.6620.                                 |
| § 63.7(e)(3)                       | Test run duration  | Yes.                      |   |
| § 63.7(e)(4)                       | Administrator may require other testing under section 114 of the CAA | Yes.                      |   |
| § 63.7(f)                          | Alternative test method provisions                                   | Yes.                      |   |
| § 63.7(g)                          | Performance test data analysis, recordkeeping, and reporting         | Yes.                      |   |
| § 63.7(h)                          | Waiver of tests  | Yes.                      |   |
| § 63.8(a)(1)                       | Applicability of monitoring requirements                             | Yes                       | Subpart ZZZZ contains specific requirements for monitoring at § 63.6625.          |
| § 63.8(a)(2)                       | Performance specifications   | Yes.                      |   |
| § 63.8(a)(3)                       | [Reserved]   |                           |   |
| § 63.8(a)(4)                       | Monitoring for control devices                                       | No.                       |   |
| § 63.8(b)(1)                       | Monitoring   | Yes.                      |   |
| § 63.8(b)(2)-(3)                   | Multiple effluents and multiple monitoring systems                   | Yes.                      |   |



| <b>General provisions citation</b> | <b>Subject of citation</b>                                      | <b>Applies to subpart</b>                                     | <b>Explanation</b>  |
|------------------------------------|---|---|---|
| § 63.8(c)(1)                       | Monitoring system operation and maintenance                     | Yes.  |   |
| § 63.8(c)(1)(i)                    | Routine and predictable SSM                                     | No  |   |
| § 63.8(c)(1)(ii)                   | SSM not in Startup Shutdown Malfunction Plan                    | Yes.  |   |
| § 63.8(c)(1)(iii)                  | Compliance with operation and maintenance requirements          | No  |   |
| § 63.8(c)(2)-(3)                   | Monitoring system installation                                  | Yes.  |   |
| § 63.8(c)(4)                       | Continuous monitoring system (CMS) requirements                 | Yes   | Except that subpart ZZZZ does not require Continuous Opacity Monitoring System (COMS).  |
| § 63.8(c)(5)                       | COMS minimum procedures   | No  | Subpart ZZZZ does not require COMS.   |
| § 63.8(c)(6)-(8)                   | CMS requirements  | Yes   | Except that subpart ZZZZ does not require COMS.   |
| § 63.8(d)                          | CMS quality control   | Yes.  |   |
| § 63.8(e)                          | CMS performance evaluation                                      | Yes   | Except for § 63.8(e)(5)(ii), which applies to COMS.   |
|                                    |   | Except that § 63.8(e) only applies as specified in § 63.6645. |   |
| § 63.8(f)(1)-(5)                   | Alternative monitoring method                                   | Yes   | Except that § 63.8(f)(4) only applies as specified in § 63.6645.  |
| § 63.8(f)(6)                       | Alternative to relative accuracy test                           | Yes   | Except that § 63.8(f)(6) only applies as specified in § 63.6645.  |
| § 63.8(g)                          | Data reduction  | Yes   | Except that provisions for COMS are not applicable. Averaging periods for demonstrating compliance are specified at §§ 63.6635 and 63.6640. |
| § 63.9(a)                          | Applicability and State delegation of notification requirements | Yes.  |   |
| § 63.9(b)(1)-(5)                   | Initial notifications   | Yes   | Except that § 63.9(b)(3) is reserved.   |

| <b>General provisions citation</b> | <b>Subject of citation</b>                                      | <b>Applies to subpart</b>                                     | <b>Explanation</b>  |
|------------------------------------|---|---|---|
|                                    |   | Except that § 63.9(b) only applies as specified in § 63.6645. |   |
| § 63.9(c)                          | Request for compliance extension                                | Yes   | Except that § 63.9(c) only applies as specified in § 63.6645.   |
| § 63.9(d)                          | Notification of special compliance requirements for new sources | Yes   | Except that § 63.9(d) only applies as specified in § 63.6645.   |
| § 63.9(e)                          | Notification of performance test                                | Yes   | Except that § 63.9(e) only applies as specified in § 63.6645.   |
| § 63.9(f)                          | Notification of visible emission (VE)/opacity test              | No  | Subpart ZZZZ does not contain opacity or VE standards.  |
| § 63.9(g)(1)                       | Notification of performance evaluation                          | Yes   | Except that § 63.9(g) only applies as specified in § 63.6645.   |
| § 63.9(g)(2)                       | Notification of use of COMS data                                | No  | Subpart ZZZZ does not contain opacity or VE standards.  |
| § 63.9(g)(3)                       | Notification that criterion for alternative to RATA is exceeded | Yes   | If alternative is in use.   |
|                                    |   | Except that § 63.9(g) only applies as specified in § 63.6645. |   |
| § 63.9(h)(1)-(6)                   | Notification of compliance status                               | Yes   | Except that notifications for sources using a CEMS are due 30 days after completion of performance evaluations. § 63.9(h)(4) is reserved. |
|                                    |   |   | Except that § 63.9(h) only applies as specified in § 63.6645.   |
| § 63.9(i)                          | Adjustment of submittal deadlines                               | Yes.  |   |
| § 63.9(j)                          | Change in previous information                                  | Yes.  |   |
| § 63.10(a)                         | Administrative provisions for recordkeeping/reporting           | Yes.  |   |
| § 63.10(b)(1)                      | Record retention  | Yes   | Except that the most recent 2 years of data do not have to be retained on site.   |
| § 63.10(b)(2)(i)-(v)               | Records related to SSM  | No.   |   |

| <b>General provisions citation</b> | <b>Subject of citation</b>                        | <b>Applies to subpart</b> | <b>Explanation</b>                                     |
|------------------------------------|---|---------------------------|--|
| § 63.10(b)(2)(vi)-(xi)             | Records   | Yes.                      |  |
| § 63.10(b)(2)(xii)                 | Record when under waiver                          | Yes.                      |  |
| § 63.10(b)(2)(xiii)                | Records when using alternative to RATA            | Yes                       | For CO standard if using RATA alternative.             |
| § 63.10(b)(2)(xiv)                 | Records of supporting documentation               | Yes.                      |  |
| § 63.10(b)(3)                      | Records of applicability determination            | Yes.                      |  |
| § 63.10(c)                         | Additional records for sources using CEMS         | Yes                       | Except that § 63.10(c)(2)-(4) and (9) are reserved.    |
| § 63.10(d)(1)                      | General reporting requirements                    | Yes.                      |  |
| § 63.10(d)(2)                      | Report of performance test results                | Yes.                      |  |
| § 63.10(d)(3)                      | Reporting opacity or VE observations              | No                        | Subpart ZZZZ does not contain opacity or VE standards. |
| § 63.10(d)(4)                      | Progress reports                                  | Yes.                      |  |
| § 63.10(d)(5)                      | Startup, shutdown, and malfunction reports        | No.                       |  |
| § 63.10(e)(1) and (2)(i)           | Additional CMS Reports                            | Yes.                      |  |
| § 63.10(e)(2)(ii)                  | COMS-related report                               | No                        | Subpart ZZZZ does not require COMS.                    |
| § 63.10(e)(3)                      | Excess emission and parameter exceedances reports | Yes.                      | Except that § 63.10(e)(3)(i) (C) is reserved.          |
| § 63.10(e)(4)                      | Reporting COMS data                               | No                        | Subpart ZZZZ does not require COMS.                    |
| § 63.10(f)                         | Waiver for recordkeeping/reporting                | Yes.                      |  |
| § 63.11                            | Flares  | No.                       |  |
| § 63.12                            | State authority and delegations                   | Yes.                      |  |
| § 63.13                            | Addresses   | Yes.                      |  |
| § 63.14                            | Incorporation by reference                        | Yes.                      |  |
| § 63.15                            | Availability of information                       | Yes.                      |  |

[75 FR 9688, Mar. 3, 2010, as amended at 78 FR 6720, Jan. 30, 2013]

## **Appendix A—Protocol for Using an Electrochemical Analyzer to Determine Oxygen and Carbon Monoxide Concentrations From Certain Engines**

### **1.0 SCOPE AND APPLICATION. WHAT IS THIS PROTOCOL?**

This protocol is a procedure for using portable electrochemical (EC) cells for measuring carbon monoxide (CO) and oxygen (O<sub>2</sub>) concentrations in controlled and uncontrolled emissions from existing stationary 4-stroke lean burn and 4-stroke rich burn reciprocating internal combustion engines as specified in the applicable rule.

#### *1.1 Analytes. What does this protocol determine?*

This protocol measures the engine exhaust gas concentrations of carbon monoxide (CO) and oxygen (O<sub>2</sub>).

| <b>Analyte</b>           | <b>CAS No.</b> | <b>Sensitivity</b>   |
|--------------------------|----------------|--|
| Carbon monoxide (CO)     | 630-08-0       | Minimum detectable limit should be 2 percent of the nominal range or 1 ppm, whichever is less restrictive. |
| Oxygen (O <sub>2</sub> ) | 7782-44-7      |  |

#### *1.2 Applicability. When is this protocol acceptable?*

This protocol is applicable to 40 CFR part 63, subpart ZZZZ. Because of inherent cross sensitivities of EC cells, you must not apply this protocol to other emissions sources without specific instruction to that effect.

#### *1.3 Data Quality Objectives. How good must my collected data be?*

Refer to Section 13 to verify and document acceptable analyzer performance.

#### *1.4 Range. What is the targeted analytical range for this protocol?*

The measurement system and EC cell design(s) conforming to this protocol will determine the analytical range for each gas component. The nominal ranges are defined by choosing up-scale calibration gas concentrations near the maximum anticipated flue gas concentrations for CO and O<sub>2</sub>, or no more than twice the permitted CO level.

#### *1.5 Sensitivity. What minimum detectable limit will this protocol yield for a particular gas component?*

The minimum detectable limit depends on the nominal range and resolution of the specific EC cell used, and the signal to noise ratio of the measurement system. The minimum detectable limit should be 2 percent of the nominal range or 1 ppm, whichever is less restrictive.

### **2.0 SUMMARY OF PROTOCOL**

In this protocol, a gas sample is extracted from an engine exhaust system and then conveyed to a portable EC analyzer for measurement of CO and O<sub>2</sub> gas concentrations. This method provides measurement system performance specifications and sampling protocols to ensure reliable data. You may use additions to, or modifications of vendor supplied measurement systems (e.g., heated or unheated sample lines, thermocouples, flow meters, selective gas scrubbers, etc.) to meet the design

specifications of this protocol. Do not make changes to the measurement system from the as-verified configuration (Section 3.12).

### 3.0 DEFINITIONS

**3.1 Measurement System.** The total equipment required for the measurement of CO and O<sub>2</sub> concentrations. The measurement system consists of the following major subsystems:

**3.1.1 Data Recorder.** A strip chart recorder, computer or digital recorder for logging measurement data from the analyzer output. You may record measurement data from the digital data display manually or electronically.

**3.1.2 Electrochemical (EC) Cell.** A device, similar to a fuel cell, used to sense the presence of a specific analyte and generate an electrical current output proportional to the analyte concentration.

**3.1.3 Interference Gas Scrubber.** A device used to remove or neutralize chemical compounds that may interfere with the selective operation of an EC cell.

**3.1.4 Moisture Removal System.** Any device used to reduce the concentration of moisture in the sample stream so as to protect the EC cells from the damaging effects of condensation and to minimize errors in measurements caused by the scrubbing of soluble gases.

**3.1.5 Sample Interface.** The portion of the system used for one or more of the following: sample acquisition; sample transport; sample conditioning or protection of the EC cell from any degrading effects of the engine exhaust effluent; removal of particulate matter and condensed moisture.

**3.2 Nominal Range.** The range of analyte concentrations over which each EC cell is operated (normally 25 percent to 150 percent of up-scale calibration gas value). Several nominal ranges can be used for any given cell so long as the calibration and repeatability checks for that range remain within specifications.

**3.3 Calibration Gas.** A vendor certified concentration of a specific analyte in an appropriate balance gas.

**3.4 Zero Calibration Error.** The analyte concentration output exhibited by the EC cell in response to zero-level calibration gas.

**3.5 Up-Scale Calibration Error.** The mean of the difference between the analyte concentration exhibited by the EC cell and the certified concentration of the up-scale calibration gas.

**3.6 Interference Check.** A procedure for quantifying analytical interference from components in the engine exhaust gas other than the targeted analytes.

**3.7 Repeatability Check.** A protocol for demonstrating that an EC cell operated over a given nominal analyte concentration range provides a stable and consistent response and is not significantly affected by repeated exposure to that gas.

**3.8 Sample Flow Rate.** The flow rate of the gas sample as it passes through the EC cell. In some situations, EC cells can experience drift with changes in flow rate. The flow rate must be monitored and documented during all phases of a sampling run.

**3.9 Sampling Run.** A timed three-phase event whereby an EC cell's response rises and plateaus in a sample conditioning phase, remains relatively constant during a measurement data phase, then declines during a refresh phase. The sample conditioning phase exposes the EC cell to the gas sample for a length of time sufficient to reach a constant response. The measurement data phase is the time interval

during which gas sample measurements can be made that meet the acceptance criteria of this protocol. The refresh phase then purges the EC cells with CO-free air. The refresh phase replenishes requisite O<sub>2</sub> and moisture in the electrolyte reserve and provides a mechanism to de-gas or desorb any interference gas scrubbers or filters so as to enable a stable CO EC cell response. There are four primary types of sampling runs: pre-sampling calibrations; stack gas sampling; post-sampling calibration checks; and measurement system repeatability checks. Stack gas sampling runs can be chained together for extended evaluations, providing all other procedural specifications are met.

*3.10 Sampling Day.* A time not to exceed twelve hours from the time of the pre-sampling calibration to the post-sampling calibration check. During this time, stack gas sampling runs can be repeated without repeated recalibrations, providing all other sampling specifications have been met.

*3.11 Pre-Sampling Calibration/Post-Sampling Calibration Check.* The protocols executed at the beginning and end of each sampling day to bracket measurement readings with controlled performance checks.

*3.12 Performance-Established Configuration.* The EC cell and sampling system configuration that existed at the time that it initially met the performance requirements of this protocol.

#### 4.0 INTERFERENCES.

When present in sufficient concentrations, NO and NO<sub>2</sub> are two gas species that have been reported to interfere with CO concentration measurements. In the likelihood of this occurrence, it is the protocol user's responsibility to employ and properly maintain an appropriate CO EC cell filter or scrubber for removal of these gases, as described in Section 6.2.12.

#### 5.0 SAFETY. [RESERVED]

#### 6.0 EQUIPMENT AND SUPPLIES.

##### *6.1 What equipment do I need for the measurement system?*

The system must maintain the gas sample at conditions that will prevent moisture condensation in the sample transport lines, both before and as the sample gas contacts the EC cells. The essential components of the measurement system are described below.

##### *6.2 Measurement System Components.*

*6.2.1 Sample Probe.* A single extraction-point probe constructed of glass, stainless steel or other non-reactive material, and of length sufficient to reach any designated sampling point. The sample probe must be designed to prevent plugging due to condensation or particulate matter.

*6.2.2 Sample Line.* Non-reactive tubing to transport the effluent from the sample probe to the EC cell.

*6.2.3 Calibration Assembly (optional).* A three-way valve assembly or equivalent to introduce calibration gases at ambient pressure at the exit end of the sample probe during calibration checks. The assembly must be designed such that only stack gas or calibration gas flows in the sample line and all gases flow through any gas path filters.

*6.2.4 Particulate Filter (optional).* Filters before the inlet of the EC cell to prevent accumulation of particulate material in the measurement system and extend the useful life of the components. All filters must be fabricated of materials that are non-reactive to the gas mixtures being sampled.

**6.2.5 Sample Pump.** A leak-free pump to provide undiluted sample gas to the system at a flow rate sufficient to minimize the response time of the measurement system. If located upstream of the EC cells, the pump must be constructed of a material that is non-reactive to the gas mixtures being sampled.

**6.2.8 Sample Flow Rate Monitoring.** An adjustable rotameter or equivalent device used to adjust and maintain the sample flow rate through the analyzer as prescribed.

**6.2.9 Sample Gas Manifold (optional).** A manifold to divert a portion of the sample gas stream to the analyzer and the remainder to a by-pass discharge vent. The sample gas manifold may also include provisions for introducing calibration gases directly to the analyzer. The manifold must be constructed of a material that is non-reactive to the gas mixtures being sampled.

**6.2.10 EC cell.** A device containing one or more EC cells to determine the CO and O<sub>2</sub> concentrations in the sample gas stream. The EC cell(s) must meet the applicable performance specifications of Section 13 of this protocol.

**6.2.11 Data Recorder.** A strip chart recorder, computer or digital recorder to make a record of analyzer output data. The data recorder resolution (i.e., readability) must be no greater than 1 ppm for CO; 0.1 percent for O<sub>2</sub>; and one degree (either °C or °F) for temperature. Alternatively, you may use a digital or analog meter having the same resolution to observe and manually record the analyzer responses.

**6.2.12 Interference Gas Filter or Scrubber.** A device to remove interfering compounds upstream of the CO EC cell. Specific interference gas filters or scrubbers used in the performance-established configuration of the analyzer must continue to be used. Such a filter or scrubber must have a means to determine when the removal agent is exhausted. Periodically replace or replenish it in accordance with the manufacturer's recommendations.

## 7.0 REAGENTS AND STANDARDS. WHAT CALIBRATION GASES ARE NEEDED?

**7.1 Calibration Gases.** CO calibration gases for the EC cell must be CO in nitrogen or CO in a mixture of nitrogen and O<sub>2</sub>. Use CO calibration gases with labeled concentration values certified by the manufacturer to be within ± 5 percent of the label value. Dry ambient air (20.9 percent O<sub>2</sub>) is acceptable for calibration of the O<sub>2</sub> cell. If needed, any lower percentage O<sub>2</sub> calibration gas must be a mixture of O<sub>2</sub> in nitrogen.

**7.1.1 Up-Scale CO Calibration Gas Concentration.** Choose one or more up-scale gas concentrations such that the average of the stack gas measurements for each stack gas sampling run are between 25 and 150 percent of those concentrations. Alternatively, choose an up-scale gas that does not exceed twice the concentration of the applicable outlet standard. If a measured gas value exceeds 150 percent of the up-scale CO calibration gas value at any time during the stack gas sampling run, the run must be discarded and repeated.

### 7.1.2 Up-Scale O<sub>2</sub> Calibration Gas Concentration.

Select an O<sub>2</sub> gas concentration such that the difference between the gas concentration and the average stack gas measurement or reading for each sample run is less than 15 percent O<sub>2</sub>. When the average exhaust gas O<sub>2</sub> readings are above 6 percent, you may use dry ambient air (20.9 percent O<sub>2</sub>) for the up-scale O<sub>2</sub> calibration gas.

**7.1.3 Zero Gas.** Use an inert gas that contains less than 0.25 percent of the up-scale CO calibration gas concentration. You may use dry air that is free from ambient CO and other combustion gas products (e.g., CO<sub>2</sub>).

## 8.0 SAMPLE COLLECTION AND ANALYSIS

### 8.1 Selection of Sampling Sites.

**8.1.1 Control Device Inlet.** Select a sampling site sufficiently downstream of the engine so that the combustion gases should be well mixed. Use a single sampling extraction point near the center of the duct (e.g., within the 10 percent centroidal area), unless instructed otherwise.

**8.1.2 Exhaust Gas Outlet.** Select a sampling site located at least two stack diameters downstream of any disturbance (e.g., turbocharger exhaust, crossover junction or recirculation take-off) and at least one-half stack diameter upstream of the gas discharge to the atmosphere. Use a single sampling extraction point near the center of the duct (e.g., within the 10 percent centroidal area), unless instructed otherwise.

**8.2 Stack Gas Collection and Analysis.** Prior to the first stack gas sampling run, conduct that the pre-sampling calibration in accordance with Section 10.1. Use Figure 1 to record all data. Zero the analyzer with zero gas. Confirm and record that the scrubber media color is correct and not exhausted. Then position the probe at the sampling point and begin the sampling run at the same flow rate used during the up-scale calibration. Record the start time. Record all EC cell output responses and the flow rate during the "sample conditioning phase" once per minute until constant readings are obtained. Then begin the "measurement data phase" and record readings every 15 seconds for at least two minutes (or eight readings), or as otherwise required to achieve two continuous minutes of data that meet the specification given in Section 13.1. Finally, perform the "refresh phase" by introducing dry air, free from CO and other combustion gases, until several minute-to-minute readings of consistent value have been obtained. For each run use the "measurement data phase" readings to calculate the average stack gas CO and O<sub>2</sub> concentrations.

**8.3 EC Cell Rate.** Maintain the EC cell sample flow rate so that it does not vary by more than  $\pm 10$  percent throughout the pre-sampling calibration, stack gas sampling and post-sampling calibration check. Alternatively, the EC cell sample flow rate can be maintained within a tolerance range that does not affect the gas concentration readings by more than  $\pm 3$  percent, as instructed by the EC cell manufacturer.

## 9.0 QUALITY CONTROL (RESERVED)

## 10.0 CALIBRATION AND STANDARDIZATION

**10.1 Pre-Sampling Calibration.** Conduct the following protocol once for each nominal range to be used on each EC cell before performing a stack gas sampling run on each field sampling day. Repeat the calibration if you replace an EC cell before completing all of the sampling runs. There is no prescribed order for calibration of the EC cells; however, each cell must complete the measurement data phase during calibration. Assemble the measurement system by following the manufacturer's recommended protocols including for preparing and preconditioning the EC cell. Assure the measurement system has no leaks and verify the gas scrubbing agent is not depleted. Use Figure 1 to record all data.

**10.1.1 Zero Calibration.** For both the O<sub>2</sub> and CO cells, introduce zero gas to the measurement system (e.g., at the calibration assembly) and record the concentration reading every minute until readings are constant for at least two consecutive minutes. Include the time and sample flow rate. Repeat the steps in this section at least once to verify the zero calibration for each component gas.

**10.1.2 Zero Calibration Tolerance.** For each zero gas introduction, the zero level output must be less than or equal to  $\pm 3$  percent of the up-scale gas value or  $\pm 1$  ppm, whichever is less restrictive, for the CO channel and less than or equal to  $\pm 0.3$  percent O<sub>2</sub> for the O<sub>2</sub> channel.



**10.1.3 Up-Scale Calibration.** Individually introduce each calibration gas to the measurement system (e.g., at the calibration assembly) and record the start time. Record all EC cell output responses and the flow rate during this “sample conditioning phase” once per minute until readings are constant for at least two minutes. Then begin the “measurement data phase” and record readings every 15 seconds for a total of two minutes, or as otherwise required. Finally, perform the “refresh phase” by introducing dry air, free from CO and other combustion gases, until readings are constant for at least two consecutive minutes. Then repeat the steps in this section at least once to verify the calibration for each component gas. Introduce all gases to flow through the entire sample handling system (i.e., at the exit end of the sampling probe or the calibration assembly).

**10.1.4 Up-Scale Calibration Error.** The mean of the difference of the “measurement data phase” readings from the reported standard gas value must be less than or equal to  $\pm 5$  percent or  $\pm 1$  ppm for CO or  $\pm 0.5$  percent O<sub>2</sub>, whichever is less restrictive, respectively. The maximum allowable deviation from the mean measured value of any single “measurement data phase” reading must be less than or equal to  $\pm 2$  percent or  $\pm 1$  ppm for CO or  $\pm 0.5$  percent O<sub>2</sub>, whichever is less restrictive, respectively.

**10.2 Post-Sampling Calibration Check.** Conduct a stack gas post-sampling calibration check after the stack gas sampling run or set of runs and within 12 hours of the initial calibration. Conduct up-scale and zero calibration checks using the protocol in Section 10.1. Make no changes to the sampling system or EC cell calibration until all post-sampling calibration checks have been recorded. If either the zero or up-scale calibration error exceeds the respective specification in Sections 10.1.2 and 10.1.4 then all measurement data collected since the previous successful calibrations are invalid and re-calibration and re-sampling are required. If the sampling system is disassembled or the EC cell calibration is adjusted, repeat the calibration check before conducting the next analyzer sampling run.

## 11.0 ANALYTICAL PROCEDURE

The analytical procedure is fully discussed in Section 8.

## 12.0 CALCULATIONS AND DATA ANALYSIS

Determine the CO and O<sub>2</sub> concentrations for each stack gas sampling run by calculating the mean gas concentrations of the data recorded during the “measurement data phase”.

## 13.0 PROTOCOL PERFORMANCE

Use the following protocols to verify consistent analyzer performance during each field sampling day.

**13.1 Measurement Data Phase Performance Check.** Calculate the mean of the readings from the “measurement data phase”. The maximum allowable deviation from the mean for each of the individual readings is  $\pm 2$  percent, or  $\pm 1$  ppm, whichever is less restrictive. Record the mean value and maximum deviation for each gas monitored. Data must conform to Section 10.1.4. The EC cell flow rate must conform to the specification in Section 8.3.

*Example: A measurement data phase is invalid if the maximum deviation of any single reading comprising that mean is greater than  $\pm 2$  percent or  $\pm 1$  ppm (the default criteria). For example, if the mean = 30 ppm, single readings of below 29 ppm and above 31 ppm are disallowed ).*

**13.2 Interference Check.** Before the initial use of the EC cell and interference gas scrubber in the field, and semi-annually thereafter, challenge the interference gas scrubber with NO and NO<sub>2</sub> gas standards that are generally recognized as representative of diesel-fueled engine NO and NO<sub>2</sub> emission values. Record the responses displayed by the CO EC cell and other pertinent data on Figure 1 or a similar form.

**13.2.1 Interference Response.** The combined NO and NO<sub>2</sub> interference response should be less than or equal to  $\pm 5$  percent of the up-scale CO calibration gas concentration.

**13.3 Repeatability Check.** Conduct the following check once for each nominal range that is to be used on the CO EC cell within 5 days prior to each field sampling program. If a field sampling program lasts longer than 5 days, repeat this check every 5 days. Immediately repeat the check if the EC cell is replaced or if the EC cell is exposed to gas concentrations greater than 150 percent of the highest up-scale gas concentration.

**13.3.1 Repeatability Check Procedure.** Perform a complete EC cell sampling run (all three phases) by introducing the CO calibration gas to the measurement system and record the response. Follow Section 10.1.3. Use Figure 1 to record all data. Repeat the run three times for a total of four complete runs. During the four repeatability check runs, do not adjust the system except where necessary to achieve the correct calibration gas flow rate at the analyzer.

**13.3.2 Repeatability Check Calculations.** Determine the highest and lowest average "measurement data phase" CO concentrations from the four repeatability check runs and record the results on Figure 1 or a similar form. The absolute value of the difference between the maximum and minimum average values recorded must not vary more than  $\pm 3$  percent or  $\pm 1$  ppm of the up-scale gas value, whichever is less restrictive.

#### 14.0 POLLUTION PREVENTION (RESERVED)

#### 15.0 WASTE MANAGEMENT (RESERVED)

#### 16.0 ALTERNATIVE PROCEDURES (RESERVED)

#### 17.0 REFERENCES

- (1) "Development of an Electrochemical Cell Emission Analyzer Test Protocol", Topical Report, Phil Juneau, Emission Monitoring, Inc., July 1997.
- (2) "Determination of Nitrogen Oxides, Carbon Monoxide, and Oxygen Emissions from Natural Gas-Fired Engines, Boilers, and Process Heaters Using Portable Analyzers", EMC Conditional Test Protocol 30 (CTM-30), Gas Research Institute Protocol GRI-96/0008, Revision 7, October 13, 1997.
- (3) "ICAC Test Protocol for Periodic Monitoring", EMC Conditional Test Protocol 34 (CTM-034), The Institute of Clean Air Companies, September 8, 1999.
- (4) "Code of Federal Regulations", Protection of Environment, 40 CFR, Part 60, Appendix A, Methods 1-4; 10.

|  |                        |                  |                        |                     |
|--|------------------------|------------------|------------------------|---------------------|
|  |                        |                  |                        |                     |
| Facility_____ Engine I.D._____ Date_____ |                        |                  |                        |                     |
| Run Type:                                | ( )                    | ( )              | ( )                    | ( )                 |
| (X)                                      | Pre-Sample Calibration | Stack Gas Sample | Post-Sample Cal. Check | Repeatability Check |

[illegible]

|   |  |  |  |  |  |  |  |  |  |  |  |
|---|--|--|--|--|--|--|--|--|--|--|--|
| " |  |  |  |  |  |  |  |  |  |  |  |
| " |  |  |  |  |  |  |  |  |  |  |  |

[78 FR 6721, Jan. 30, 2013]

## Technical Support Document (TSD) for a Part 70 Significant Source Modification and Significant Permit Modification

### Source Description and Location

|                                      |   |
|--------------------------------------|---|
| Source Name:                         | Allison Transmission, Inc. - Speedway Main Campus |
| Source Location:                     | One Allison Way, Indianapolis, IN 46222           |
| County:                              | Marion  |
| SIC Code:                            | 3714 (motor vehicle parts and accessories)        |
| Operation Permit No.:                | T 097-27011-00310                                 |
| Operation Permit Issuance Date:      | March 23, 2010                                    |
| Significant Source Modification No.: | 097-33211-00310                                   |
| Significant Permit Modification No.: | 097-33236-00310                                   |
| Permit Reviewer:                     | Heath Hartley                                     |

### Source Definition

This Source Definition from the Part 70 Operating Permit was incorporated into this permit as follows:

This transmission manufacturing and testing plant consists of three (3) plants:

- (a) Plant 3 is located at 4700 West 10<sup>th</sup> Street, Indianapolis, IN 46222;
- (b) Plants 12 and 14 are both located at 901 Grande Avenue, Indianapolis, IN 46222

Since the three (3) plants are located on contiguous or adjacent properties, belong to the same industrial grouping and are under common control of the same entity, they will be considered one (1) source, effective from the date of issuance of this Part 70 permit.

### Existing Approvals

The source was issued Part 70 Operating Permit No. T 097-27011-00310 on March 23, 2010. The source has since received the following approvals:

- (a) Administrative Amendment No. 097-29691-00310, issued on December 9, 2010; and
- (b) Minor Source Modification No. 097-30495-00310, issued on June 9, 2011.
- (c) Significant Permit Modification No. 097-30499-00310, issued on August 4, 2011.
- (d) Significant Permit Modification No. 097-31784-00310, issued on August 17, 2012.

### County Attainment Status

The source is located in Marion County.

| Pollutant  | Designation  |
|--|--|
| SO <sub>2</sub>  | Better than national standards.  |
| CO   | Attainment effective February 18, 2000, for the part of the city of Indianapolis bounded by 11 <sup>th</sup> Street on the north; Capitol Avenue on the west; Georgia Street on the south; and Delaware Street on the east. Unclassifiable or attainment effective November 15, 1990, for the remainder of Indianapolis and Marion County.   |
| O <sub>3</sub>   | Attainment effective November 8, 2007, for the 8-hour ozone standard. <sup>1</sup>   |
| PM <sub>10</sub>   | Unclassifiable effective November 15, 1990.  |
| PM <sub>2.5</sub>  | Basic nonattainment designation effective federally April 5, 2005, for PM <sub>2.5</sub> .   |
| NO <sub>2</sub>  | Cannot be classified or better than national standards.  |
| Pb   | Attainment effective July 10, 2000, for the part of Franklin Township bounded by Thompson Road on the south; Emerson Avenue on the west; Five Points Road on the east; and Troy Avenue on the north. Attainment effective July 10, 2000, for the part of Wayne Township bounded by Rockville Road on the north; Girls School Road on the east; Washington Street on the south; and Bridgeport Road on the west. The remainder of the county is not designated. |
| <sup>1</sup> Attainment effective October 18, 2000, for the 1-hour ozone standard for the Indianapolis area, including Marion County, and is a maintenance area for the 1-hour ozone National Ambient Air Quality Standards (NAAQS) for purposes of 40 CFR 51, Subpart X*. The 1-hour designation was revoked effective June 15, 2005. |  |

- (a) **Ozone Standards**  
 Volatile organic compounds (VOC) and Nitrogen Oxides (NO<sub>x</sub>) are regulated under the Clean Air Act (CAA) for the purposes of attaining and maintaining the National Ambient Air Quality Standards (NAAQS) for ozone. Therefore, VOC and NO<sub>x</sub> emissions are considered when evaluating the rule applicability relating to ozone. Marion County has been designated as attainment or unclassifiable for ozone. Therefore, VOC and NO<sub>x</sub> emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2.
- (b) **PM<sub>2.5</sub>**  
 Marion County has been classified as nonattainment for PM<sub>2.5</sub> in 70 FR 943 dated January 5, 2005. On May 8, 2008, U.S. EPA promulgated specific New Source Review rules for PM<sub>2.5</sub> emissions. These rules became effective on July 15, 2008. Therefore, direct PM<sub>2.5</sub>, SO<sub>2</sub> and NO<sub>x</sub> emissions were reviewed pursuant to the requirements of Nonattainment New Source Review, 326 IAC 2-1.1-5. See the State Rule Applicability – Entire Source section.
- (c) **Other Criteria Pollutants**  
 Marion County has been classified as attainment or unclassifiable in Indiana for SO<sub>2</sub>, CO, PM<sub>10</sub>, NO<sub>2</sub> and Pb. Therefore, these emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2.

### Fugitive Emissions

Since this source has nested fossil fuel boilers (or combinations thereof) totaling more than two hundred fifty (250) million Btu per hour heat input, the boilers are considered one of the twenty-eight (28) listed source categories, as specified in 326 IAC 2-2, 326 IAC 2-3, or 326 IAC 2-7, within a non-listed source. Therefore, fugitive emissions from the nested boilers are counted toward the determination of PSD, Emission Offset, and Part 70 Permit applicability.

### Source Status

The table below summarizes the potential to emit of the entire source, prior to the proposed modification, after consideration of all enforceable limits established in the effective permits:

| Pollutant         | Emissions (ton/yr) |
|-------------------|--------------------|
| PM                | 158.4              |
| PM <sub>10</sub>  | 152.4              |
| PM <sub>2.5</sub> | 152.4              |
| SO <sub>2</sub>   | 761.9              |
| VOC               | 212.1              |
| CO                | 1398.3             |
| NO <sub>x</sub>   | 4985.4             |
| GHGs              | 487,717            |
| Worst Single HAP  | <10                |
| Total HAPs        | <25                |

- (a) This existing source is a major stationary source, under PSD (326 IAC 2-2), because a regulated pollutant is emitted at a rate of 100 tons per year or more, and it is one of the twenty-eight (28) listed source categories, as specified in 326 IAC 2-2-1(ff)(1).
- (b) This existing source is a major stationary source, under nonattainment new source review rules (326 IAC 2-1.1-5) since direct PM<sub>2.5</sub> and/or SO<sub>2</sub> is emitted at a rate of 100 tons per year or more.
- (c) GHGs are greater than one hundred thousand (>100,000) tons of CO<sub>2</sub> equivalent emissions (CO<sub>2</sub>e) per year.
- (d) This existing source is not a major source of HAPs, as defined in 40 CFR 63.2, because HAPs emissions are less than ten (10) tons per year for any single HAP and less than twenty-five (25) tons per year of a combination of HAPs. Therefore, this source is an area source under Section 112 of the Clean Air Act (CAA).
- (e) These emissions are based upon Part 70 Operating Permit No. T097-27011-00310, SPM 097-30499-00310 and SPM 097-31784-00310 with minor corrections to fuel combustion emission factors used.

### Description of Proposed Modification

The Office of Air Quality (OAQ) has reviewed a modification application, submitted by Allison Transmission, Inc. - Speedway Main Campus on May 15, 2013, relating to the addition of two diesel-fired engines (maximum 4,000 hp) to Test Cell 55. The following is a list of the proposed emission units:

- (a) Transmission Test Cell 55, identified as ETC55, approved in 2013 for construction, consisting of two reciprocating diesel-fired engines, with an estimated maximum engine size of 4,000 hp each, exhausting to Stacks/Vents PTE93 and PTE94.

As part of the modification, IDEM OAQ has made the following additional changes:

- Calculations have been included and updated for all emission units to reflect current units and fuel types and to make minor corrections to fuel combustion emission factors used.
  - As part of the modification, IDEM OAQ has revised HAPs calculations for BLR4, BLR5, ETC, ETC702.
  - As part of the modification, IDEM OAQ has included Greenhouse Gas emissions.
- The Source has determined that the requirements of Subpart 40 CFR 60, Subpart KKKK Combustion Turbines, are applicable to Test Cell 701 and Test Cell 705 (of Emission Unit ETC).

### Enforcement Issues

There are no pending enforcement actions related to this modification.

### Emission Calculations

See Appendix A of this Technical Support Document for detailed emission calculations.

### Permit Level Determination – Part 70

Pursuant to 326 IAC 2-1.1-1(16), Potential to Emit is defined as “the maximum capacity of a stationary source or emission unit to emit any air pollutant under its physical and operational design. Any physical or operational limitation on the capacity of a source to emit an air pollutant, including air pollution control equipment and restrictions on hours of operation or type or amount of material combusted, stored, or processed shall be treated as part of its design if the limitation is enforceable by the U. S. EPA, IDEM, or the appropriate local air pollution control agency.”

The following table is used to determine the appropriate permit level under 326 IAC 2-7-10.5. This table reflects the PTE before controls of the modification. Control equipment is not considered federally enforceable until it has been required in a federally enforceable permit.

| Increase in PTE Before Controls of the Modification |                            |
|---|----------------------------|
| Pollutant   | Potential To Emit (ton/yr) |
| PM  | 12.3                       |
| PM <sub>10</sub>                                    | 7.0                        |
| PM <sub>2.5</sub>                                   | 7.0                        |
| SO <sub>2</sub>                                     | 70.9                       |
| VOC   | 12.4                       |
| CO  | 100.8                      |
| NO <sub>x</sub>                                     | 420.5                      |
| Benzene   | 0.09                       |
| Total HAPs  | 0.19                       |

Appendix A of this TSD reflects the unrestricted potential emissions of the modification.

This source modification is subject to 326 IAC 2-7-10.5(g)(4) since PTE of NO<sub>x</sub> and SO<sub>2</sub> are greater than 25 tons per year each and the PTE of CO is greater than 100 tons per year. Additionally, the modification will be incorporated into the Part 70 Operating Permit through a significant permit modification issued pursuant to 326 IAC 2-7-12(d), because the modification incorporates applicable portions of the New Source Performance Standards for Stationary Compression Ignition Internal Combustion Engines (40 CFR 60, Subpart IIII) and National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (40 CFR 63, Subpart ZZZZ) under Title I of the Clean Air Act (CAA).

### Permit Level Determination – PSD or Nonattainment NSR

The table below summarizes the potential to emit, reflecting all limits, of the emission units. Any control equipment is considered federally enforceable only after issuance of this Part 70 source/permit modification, and only to the extent that the effect of the control equipment is made practically enforceable in the permit.



| Process / Emission Unit   | Limited Potential to Emit of Modification (ton/yr) |                  |                     |                      |      |       |                     |                          |         |            |
|---|--|------------------|---------------------|----------------------|------|-------|---------------------|--------------------------|---------|------------|
|   | PM   | PM <sub>10</sub> | PM <sub>2.5</sub> * | SO <sub>2</sub> **** | VOC  | CO*** | NO <sub>x</sub> *** | GHGs**                   | Benzene | Total HAPs |
| ETC55   | 12.3   | 7.0              | 7.0                 | < 40                 | 12.4 | < 100 | < 40                | 20,397                   | 0.09    | 0.19       |
| PSD Significant Level   | 25   | 15               | NA                  | NA                   | 40   | 100   | 40                  | 75,000 CO <sub>2</sub> e | NA      | NA         |
| Nonattainment NSR Significant Level   | NA   | NA               | 10                  | 40                   | NA   | NA    | NA                  | NA                       | NA      | NA         |
| *PM <sub>2.5</sub> listed is direct PM <sub>2.5</sub> .<br>**The 100,000 CO <sub>2</sub> e threshold represents the Title V and PSD subject to regulation thresholds for GHGs in order to determine whether a source's emissions are a regulated NSR pollutant under Title V and PSD.<br>*** NO <sub>x</sub> and CO limited such that 326 IAC 2-2 does not apply<br>**** SO <sub>2</sub> limited such that 326 IAC 2-1.1-5 does not apply |  |                  |                     |                      |      |       |                     |                          |         |            |

- (a) This modification to an existing major stationary source is not major because the emissions increase is less than the PSD significant levels. Therefore, pursuant to 326 IAC 2-2, the PSD requirements do not apply.
- (b) In order to render the requirements of 326 IAC 2-2 not applicable to ETC55, the Permittee shall comply with the following:
- (1) NO<sub>x</sub> emissions from diesel fuel fired reciprocating engines utilized in Test Cell ETC55 shall be less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.
  - (2) CO emissions from diesel fuel fired reciprocating engines utilized in ETC55 shall be less than one-hundred (100) tons per twelve (12) consecutive month period with compliance determined at the end of each month.
- Compliance with these limits will limit the potential to emit from this modification to less than forty (40) tons of NO<sub>x</sub> and less than one-hundred (100) tons of CO per twelve (12) consecutive month period and will render the requirements of 326 IAC 2-2 not applicable to ETC55.
- (c) In order to render the requirements of 326 IAC 2-1.1-5 not applicable to ETC55, the Permittee shall comply with the following:
- (1) SO<sub>2</sub> emissions from diesel fuel fired reciprocating engines utilized in ETC55 shall be less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.

Compliance with this limit will limit the potential to emit from this modification to less than forty (40) tons of SO<sub>2</sub> per twelve (12) consecutive month period and shall render 326 IAC 2-1.1-5 (Nonattainment NSR) not applicable to ETC55.

| Potential to Emit of the Entire Source After Modification (tons/year)                               |                           |                           |                       |  |                             |                           |                             |                              |  |
|---|---------------------------|---------------------------|-----------------------|--|-----------------------------|---------------------------|-----------------------------|------------------------------|--|
| Process/<br>Emission Unit   | PM                        | PM <sub>10</sub>          | PM <sub>2.5</sub>     | SO <sub>2</sub>  | NO <sub>x</sub>             | VOC                       | CO                          | GHGs                         | HAPs<br>(single/<br>total)               |
| BLR 4   | 0.6                       | 2.4                       | 2.4                   | 1.88 lbs/MMBtu &<br>135.2 pounds per<br>hour <sup>(b)</sup> ;<br>592.2 tons per year<br>0.2                                    | 31.5                        | 1.7                       | 26.5                        | 38,074                       | 1.32 /<br>1.38                           |
| BLR 5   | 0.8                       | 3.2                       | 3.2                   | 1.88 lbs/MMBtu &<br>180.3 pounds per<br>hour <sup>(b)</sup> ;<br>789.7 tons per year<br>0.3                                    | 42.0                        | 2.3                       | 35.3                        | 50,765                       |  |
| BLR 6   | 0.8                       | <del>3.2</del><br>3.3     | <del>3.2</del><br>3.3 | 0.3  | <del>13.6</del><br>13.9     | 2.4                       | <del>35.7</del><br>36.4     | 52,141                       | 0.76 single<br>0.80 total<br>0.78 / 0.82 |
| Emission Unit ID ETC 24<br>engineering<br>development<br>transmission test cells<br>(including 39N) | <del>144.1</del><br>146.9 | <del>136.9</del><br>135.8 | 135.8                 | 0.5 lbs/MMBtu for<br>701, 704, 705,<br>706S, 707, 709,<br>711, 32N, 38N &<br>50 <sup>(b)</sup> ; 730.1<br>737.4 <sup>(a)</sup> | <del>4660.3</del><br>4700.3 | <del>208.0</del><br>195.3 | <del>2567.3</del><br>1251.5 | 253,327                      | 4.3 / 6.7<br>1.19 / 2.41                 |
| Emission Unit ID ETC<br>(only test cell 39N)  | <del>2.8</del><br>1.2     | <del>2.8</del><br>0.7     | 0.7                   | 0.5 lbs/MMBtu <sup>(b)</sup> ;<br>2.6<br>6.3   | < 40 <sup>(b)</sup>         | <del>3.3</del><br>1.1     | <del>8.6</del><br>10.6      | included<br>above            | included<br>above                        |
| DTC   | 2.8                       | 2.8                       | 2.8                   | 2.6  | < 40 <sup>(b)</sup>         | 3.3                       | 8.6                         | 30,460                       | 0.17 /<br><del>0.1</del> 0.71            |
| Emission Unit ID PTS14<br>transmission test stands<br>O-1 and O-2                                   | 1.3                       | 0.7                       | 0.7                   | 6.3  | < 40 <sup>(b)</sup>         | 1.1                       | 10.6                        | 42,644                       | 0.01 / 0.02                              |
| Emission Unit ID PTS14<br>transmission test stands<br>O-24 and O-25                                 | 2.8                       | 2.8                       | 2.8                   | 2.6  | < 40 <sup>(b)</sup>         | 3.3                       | 8.6                         |                              | 0.01 / 0.01                              |
| Emission Unit ID PTS14<br>transmission test stand<br>O-31   | 1.3                       | 0.7                       | 0.7                   | 6.3  | < 40 <sup>(b)</sup>         | 1.1                       | 10.6                        |                              | 0.01 / 0.02                              |
| ETC702  | 1.2                       | 0.7                       | 0.7                   | 6.0  | < 40 <sup>(b)</sup>         | 1.1                       | 10.1                        | 20,307                       | 0.10 / 0.19                              |
| Cold solvent degreasing<br>using mineral spirits  | 0                         | 0                         | 0                     | 0  | 0                           | <del>22.0</del><br>0.5    | 0                           | 0                            | 0  |
| ETC55 <sup>(c), (d)</sup>   | 12.3                      | 7.0                       | 7.0                   | < 40   | < 40                        | 12.4                      | < 100                       | 20,397                       | 0.10 / 0.19                              |
| Total   | <del>198.6</del><br>170.7 | <del>177.4</del><br>159.5 | 159.5                 | <del>3429</del><br>801.8   | <del>5170.1</del><br>5025.3 | <del>251.5</del><br>224.4 | <del>2707.6</del><br>1498.2 | 508,114                      | <10 single<br><25 total                  |
| PSD Major Source<br>Threshold   | 100                       | 100                       | NA                    | NA   | 100                         | 100                       | 100                         | 100,000<br>CO <sub>2</sub> e | NA                                       |
| Nonattainment NSR<br>Major Source Threshold   | NA                        | NA                        | 100                   | 100  | NA                          | NA                        | NA                          | 100,000<br>CO <sub>2</sub> e | NA                                       |

(a) Pursuant to 326 IAC 7-1.1-2

(b) Limited such that 326 IAC 2-2 does not apply

(c) NOx and CO limited such that 326 IAC 2-2 does not apply

(d) SO2 limited such that 326 IAC 2-1.1-5 does not apply

The table below summarizes the potential to emit of the entire source after issuance of this revision, reflecting all limits, of the emission units. Any control equipment is considered federally enforceable only after issuance of this permit, and only to the extent that the effect of the control equipment is made practically enforceable in the permit. (Note: the table below was generated from the above table, with bold text un-bolded and strikethrough text deleted)

| Potential to Emit of the Entire Source After Modification (tons/year)  |              |                  |                   |                      |                     |              |               |                              |   |
|--|--------------|------------------|-------------------|----------------------|---------------------|--------------|---------------|------------------------------|---|
| Process/<br>Emission Unit  | PM           | PM <sub>10</sub> | PM <sub>2.5</sub> | SO <sub>2</sub>      | NO <sub>x</sub>     | VOC          | CO            | GHGs                         | HAPs<br>(Single/<br>Total)                |
| BLR 4  | 0.6          | 2.4              | 2.4               | 0.2                  | 31.5                | 1.7          | 26.5          | 38,074                       | 1.32 /                                    |
| BLR 5  | 0.8          | 3.2              | 3.2               | 0.3                  | 42.0                | 2.3          | 35.3          | 50,765                       | 1.38                                      |
| BLR 6  | 0.8          | 3.3              | 3.3               | 0.3                  | 13.9                | 2.4          | 36.4          | 52,141                       | 0.78 /<br>0.82                            |
| ETC<br>(including 39N)   | 146.9        | 135.8            | 135.8             | 737.4 <sup>(a)</sup> | 4700.3              | 195.3        | 1251.5        | 253,327                      | 1.19 /<br>2.41                            |
| ETC<br>(only test cell 39N)  | 1.2          | 0.7              | 0.7               | 6.3                  | < 40 <sup>(b)</sup> | 1.1          | 10.6          | included<br>above            | included<br>above                         |
| DTC  | 2.8          | 2.8              | 2.8               | 2.6                  | < 40 <sup>(b)</sup> | 3.3          | 8.6           | 30,460                       | 0.17 /<br>0.71                            |
| PTS14: O-1 and O-2   | 1.3          | 0.7              | 0.7               | 6.3                  | < 40 <sup>(b)</sup> | 1.1          | 10.6          | 42,644                       | 0.01 /<br>0.02                            |
| PTS14: O-24 and O-25   | 2.8          | 2.8              | 2.8               | 2.6                  | < 40 <sup>(b)</sup> | 3.3          | 8.6           |                              | 0.01 /<br>0.01                            |
| PTS14: O-31  | 1.3          | 0.7              | 0.7               | 6.3                  | < 40 <sup>(b)</sup> | 1.1          | 10.6          |                              | 0.01 /<br>0.02                            |
| ETC702   | 1.2          | 0.7              | 0.7               | 6.0                  | < 40 <sup>(b)</sup> | 1.1          | 10.1          | 20,307                       | 0.10 /<br>0.19                            |
| Cold solvent degreasing<br>using mineral spirits   | 0            | 0                | 0                 | 0                    | 0                   | 0.5          | 0             | 0                            | 0   |
| ETC55 <sup>(c), (d)</sup>  | 12.3         | 7.0              | 7.0               | < 40                 | < 40                | 12.4         | < 100         | 20,397                       | 0.10 /<br>0.19                            |
| <b>Total</b>   | <b>170.7</b> | <b>159.5</b>     | <b>159.5</b>      | <b>801.8</b>         | <b>5025.3</b>       | <b>224.4</b> | <b>1498.2</b> | <b>508,114</b>               | <b>&lt;10<br/>single<br/>&lt;25 total</b> |
| PSD Major Source<br>Threshold  | 100          | 100              | NA                | NA                   | 100                 | 100          | 100           | 100,000<br>CO <sub>2</sub> e | NA  |
| Nonattainment NSR<br>Major Source Threshold  | NA           | NA               | 100               | 100                  | NA                  | NA           | NA            | 100,000<br>CO <sub>2</sub> e | NA  |
| (a) Pursuant to 326 IAC 7-1.1-2<br>(b) Limited such that 326 IAC 2-2 does not apply<br>(c) NO <sub>x</sub> and CO limited such that 326 IAC 2-2 does not apply<br>(d) SO <sub>2</sub> limited such that 326 IAC 2-1.1-5 does not apply |              |                  |                   |                      |                     |              |               |                              |   |

### Federal Rule Applicability Determination

The following federal rules are applicable to the source due to this modification:

#### **NSPS:**

- (a) ETC55 is subject to the New Source Performance Standards for Stationary Compression Ignition Internal Combustion Engines (40 CFR 60, Subpart IIII), which is incorporated by reference as 326 IAC 12, because it contains a new engine manufactured after 2006.

ETC55 is subject to the following portions of Subpart 40 CFR 60, Subpart IIII:

- (1) 40 CFR 60.4200

- (2) 40 CFR 60.4201
- (3) 40 CFR 60.4204(a), (b) and (e)
- (4) 40 CFR 60.4206
- (5) 40 CFR 60.4207(a), (b) and (e)
- (6) 40 CFR 60.4208(a), (e), (h) and (i)
- (7) 40 CFR 60.4211(a), (b), (c), (d), (e) and (g)
- (8) 40 CFR 60.4214(a)
- (9) 40 CFR 60.4218
- (10) 40 CFR 60.4219

- (b) Test Cell 701 and Test Cell 705 (of Emission Unit ETC) are subject to the New Source Performance Standards for Stationary Combustion Turbines (40 CFR 60, Subpart KKKK), which is incorporated by reference as 326 IAC 12, because they are gas turbines with a heat input at peak load greater than 10 MMBtu/hr, and the engines at this test cell have commenced construction, modification or reconstruction after February 18, 2005. This is a Title I change.

Test Cell 701 and Test Cell 705 (of Emission Unit ETC) are subject to the following portions of Subpart 40 CFR 60, Subpart KKKK:

- (1) 40 CFR 60.4305
- (2) 40 CFR 60.4315
- (3) 40 CFR 60.4320(a)
- (4) 40 CFR 60.4325
- (5) 40 CFR 60.4330(a)
- (6) 40 CFR 60.4333
- (7) 40 CFR 60.4375
- (8) 40 CFR 60.4395
- (9) 40 CFR 60.4420

**NESHAP:**

- (c) ETC55 is subject to the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (40 CFR 63, Subpart ZZZZ), which is incorporated by reference as 326 IAC 20-82, because this test cell will test diesel-fired engines at an Area Source of HAPs. The engines used at ETC55 may be changed, therefore these engines may be considered new or existing (as determined by 40 CFR 63, Subpart ZZZZ) .

When using new engines

ETC55 is subject to the following portions of Subpart 40 CFR 63, Subpart ZZZZ:

- (1) 40 CFR 63.6580
- (2) 40 CFR 63.6585(a), (c), (e)
- (3) 40 CFR 63.6590(a)(2)(iii) and (c)(1)
- (4) 40 CFR 63.6595(a)(7)
- (5) 40 CFR 63.6665
- (6) 40 CFR 63.6670
- (7) 40 CFR 63.6675

Pursuant to 40 CFR 63.6665, the diesel-fired engines at ETC55 do not have to meet the requirements of 40 CFR 63, Subpart A (General Provisions), since it is considered a new stationary RICE located at an area source of HAP emissions.

When using existing engines

ETC55 is subject to the following portions of Subpart 40 CFR 63, Subpart ZZZZ:

- (1) 40 CFR 63.6580
- (2) 40 CFR 63.6585(a), (c), (e)
- (3) 40 CFR 63.6590(a)(1)(iii) and (iv)
- (4) 40 CFR 63.6595(a)(1), (b), and (c)
- (5) 40 CFR 63.6603(a)

- (6) 40 CFR 63.6604(a)
- (7) 40 CFR 63.6605
- (8) 40 CFR 63.6612
- (9) 40 CFR 63.6615
- (10) 40 CFR 63.6620(a), (d), (e), (f), (g), (h), and (i)
- (11) 40 CFR 63.6625(e)(4), (g), (h), (i)
- (12) 40 CFR 63.6630(a), (b), and (c)
- (13) 40 CFR 63.6635
- (14) 40 CFR 63.6640(a), (b), and (e)
- (15) 40 CFR 63.6645(a)(2), (a)(5), (g), and (h)
- (16) 40 CFR 63.6650
- (17) 40 CFR 63.6655
- (18) 40 CFR 63.6660
- (19) 40 CFR 63.6665
- (20) 40 CFR 63.6670
- (21) 40 CFR 63.6675
- (22) Table 2b
- (23) Table 2d (item 1), (item 2), and (item 3)
- (24) Table 3 (item 4)
- (25) Table 4 (items 1 and 3)
- (26) Table 5 (items 1, 2, 3, 4, 5, 6, 11 and 12)
- (27) Table 6 (items 3, 9, 10, and 11)
- (28) Table 7 (item 1)
- (29) Table 8

Note: Existing non-emergency compression ignition (CI) stationary RICE that have a site rating less than or equal to 300 brake horsepower (HP) and are located at an area source of HAP are not subject to numerical CO or formaldehyde emission limitations, but are only subject to work and management practices under Table 2d and Table 6.

The requirements of 40 CFR 63 Subpart A – General Provisions, which are incorporated as 326 IAC 20-1-1, apply to the facility described in this section except when otherwise specified in 40 CFR 63 Subpart ZZZZ.

- (d) Pursuant to 40 CFR 64.2, Compliance Assurance Monitoring (CAM) is applicable to new or modified emission units that involve a pollutant-specific emission unit and meet the following criteria:
- (1) has a potential to emit before controls equal to or greater than the Part 70 major source threshold for the pollutant involved;
  - (2) is subject to an emission limitation or standard for that pollutant; and
  - (3) uses a control device, as defined in 40 CFR 64.1, to comply with that emission limitation or standard.

The requirements of 40 CFR Part 64, CAM are not applicable to ETC55 as part of this modification. ETC55 has PTE greater than major source thresholds, has an emission limit, but does not use a control device to comply with the emission limit.

|   |
|---|
| <b>State Rule Applicability Determination</b> |
|---|

The following state rules are applicable to the source due to the modification:

**326 IAC 2-1.1-5 (Nonattainment New Source Review)**

Nonattainment New Source Review applicability is discussed under the Permit Level Determination – PSD and Emission Offset section.

### **326 IAC 2-2 and 2-3 (PSD and Emission Offset)**

PSD and Emission Offset applicability is discussed under the Permit Level Determination – PSD and Emission Offset section.

### **326 IAC 2-4.1 (Major Sources of Hazardous Air Pollutants (HAP))**

The operation of ETC55 will emit less than ten (10) tons per year for a single HAP and less than twenty-five (25) tons per year for a combination of HAPs. Therefore, 326 IAC 2-4.1 does not apply.

### **326 IAC 6.5-1 (Particulate Matter Limitations Except Lake County)**

The Permittee is located in Marion county and has the potential to emit of greater than one-hundred (100) tons per year of particulate matter (PM). Therefore, pursuant to 326 IAC 6.5-1-2(a) (Particulate Matter Limitations Except Lake County), particulate (PM) emissions from ETC55 shall not exceed three hundredths (0.03) grains per dry standard cubic foot of exhaust air.

### **326 IAC 7-1.1-1 (Sulfur Dioxide (SO<sub>2</sub>))**

ETC55 has the potential to emit of greater than twenty-five (25) tons per year of SO<sub>2</sub>. Therefore, pursuant to 326 IAC 7-1.1-2 (SO<sub>2</sub> Emissions Limitations), Sulfur Dioxide (SO<sub>2</sub>) emissions from ETC55 shall not exceed five tenths (0.5) pounds per million Btu heat input.

|   |
|---|
| <b>Compliance Determination and Monitoring Requirements</b> |
|---|

Permits issued under 326 IAC 2-7 are required to ensure that sources can demonstrate compliance with all applicable state and federal rules on a continuous basis. All state and federal rules contain compliance provisions; however, these provisions do not always fulfill the requirement for a continuous demonstration. When this occurs, IDEM, OAQ, in conjunction with the source, must develop specific conditions to satisfy 326 IAC 2-7-5. As a result, Compliance Determination Requirements are included in the permit. The Compliance Determination Requirements in Section D of the permit are those conditions that are found directly within state and federal rules and the violation of which serves as grounds for enforcement action.

If the Compliance Determination Requirements are not sufficient to demonstrate continuous compliance, they will be supplemented with Compliance Monitoring Requirements, also in Section D of the permit. Unlike Compliance Determination Requirements, failure to meet Compliance Monitoring conditions would serve as a trigger for corrective actions and not grounds for enforcement action. However, a violation in relation to a compliance monitoring condition will arise through a source's failure to take the appropriate corrective actions within a specific time period.

Test Cell ETC55 includes two engines; however these engines may be changed. Therefore record keeping shall be maintained to include each engine type, emission factor, fuel usage, fuel density, fuel consumption rate, etc. for each engine used in order to determine compliance with applicable emission limitations.

Since the engines used at ETC55 will be certified to applicable federal engine emission standards, no further stack testing is required at this time.

See the Proposed Changes section of the TSD for any changes to the Compliance Determination and Compliance Monitoring Requirements of the permit.

### Proposed Changes

The changes listed below have been made to Part 70 Operating Permit Renewal No. T 097-27011-00310. Deleted language appears as ~~strikethroughs~~ and new language appears in **bold**:

**Change 1:** The Permittee has added ETC55.

A.3 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)]  
[326 IAC 2-7-5(14)]

This stationary source consists of the following emission units and pollution control devices:  
.....

- (j) **Transmission Test Cell 55, identified as ETC55, approved in 2013 for construction, consisting of two reciprocating diesel-fired engines, with an estimated maximum engine size of 4,000 hp each, exhausting to Stacks/Vents PTE93 and PTE94.**  
.....

#### SECTION D.9

#### FACILITY OPERATION CONDITIONS

##### Facility Description [326 IAC 2-7-5(14)]

- (j) **Transmission Test Cell 55, identified as ETC55, approved in 2013 for construction, consisting of two reciprocating diesel-fired engines, with an estimated maximum engine size of 4,000 hp each, exhausting to Stacks/Vents PTE93 and PTE94.**

**(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)**

##### Emission Limitations and Standards [326 IAC 2-7-5(1)]

###### D.9.1 Particulate Matter Limitations Except Lake County [326 IAC 6.5-1-2(a)]

Pursuant to 326 IAC 6.5-1-2(a) (Particulate Matter Limitations Except Lake County), particulate (PM) emissions from ETC55 shall not exceed three hundredths (0.03) grains per dry standard cubic foot of exhaust air.

###### D.9.2 PSD Minor Limit [326 IAC 2-2]

In order to render the requirements of 326 IAC 2-2 not applicable to ETC55, the Permittee shall comply with the following:

- (a) **NO<sub>x</sub> emissions from diesel fuel fired reciprocating engines utilized in ETC55 shall be less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.**
- (b) **CO emissions from diesel fuel fired reciprocating engines utilized in ETC55 shall be less than one-hundred (100) tons per twelve (12) consecutive month period with compliance determined at the end of each month.**

**Compliance with these limits shall render 326 IAC 2-2 (Prevention of Significant Deterioration) not applicable to ETC55.**

###### D.9.3 Nonattainment NSR Minor Limit [326 IAC 2-1.1-5]

In order to render the requirements of 326 IAC 2-1.1-5 not applicable to ETC55, the Permittee shall comply with the following:

**SO<sub>2</sub> emissions from diesel fuel fired reciprocating engines utilized in ETC55 shall be less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.**

Compliance with this limit shall render 326 IAC 2-1.1-5 (Nonattainment NSR) not applicable to ETC55.

**D.9.4 Sulfur Dioxide (SO<sub>2</sub>) [326 IAC 7-1.1-1]**

Pursuant to 326 IAC 7-1.1-2 (SO<sub>2</sub> Emissions Limitations), Sulfur Dioxide (SO<sub>2</sub>) emissions from ETC55 shall not exceed five tenths (0.5) pounds per million Btu heat input.

**D.9.5 Preventive Maintenance Plan [326 IAC 2-7-5(12)]**

A Preventive Maintenance Plan is required for ETC55. Section B - Preventive Maintenance Plan contains the Permittee's obligation with regard to the preventive maintenance plan required by this condition.

**Compliance Determination Requirements**

**D.9.6 NO<sub>x</sub> Emissions Determination**

To comply with the NO<sub>x</sub> emissions limit in Condition D.9.2(a), the following equation shall be used:

$$\text{NO}_x = [(FU \times D \times EF / FCR)_{\text{Engine 1}} + (FU \times D \times EF / FCR)_{\text{Engine 2}}] \times 1 \text{ ton} / 2000 \text{ lb}$$

Where:

NO<sub>x</sub> = NO<sub>x</sub> emissions (ton/month)

FU = Fuel Usage (gal/month)

D = Density of fuel (lb/gal)

EF = NO<sub>x</sub> Emission Factor (lb/hp-hr) (For each engine type used, the emission factor shall be the emission limitation from the applicable federal engine emission standards.)

FCR = Fuel Consumption Rate (lb fuel/hp-hr)

**D.9.7 CO Emissions Determination**

To comply with the CO emissions limit in Condition D.9.2(b), the following equation shall be used:

$$\text{CO} = [(FU \times D \times EF / FCR)_{\text{Engine 1}} + (FU \times D \times EF / FCR)_{\text{Engine 2}}] \times 1 \text{ ton} / 2000 \text{ lb}$$

Where:

CO = CO emissions (ton/month)

FU = Fuel Usage (gal/month)

D = Density of fuel (lb/gal)

EF = CO Emission Factor (lb/hp-hr) (For each engine type used, the emission factor shall be the emission limitation from the applicable federal engine emission standards.)

FCR = Fuel Consumption Rate (lb fuel/hp-hr)

**D.9.8 SO<sub>2</sub> Emissions Determination**

To comply with the SO<sub>2</sub> emissions limit in Condition D.9.3, the following equation shall be used:

$$\text{SO}_2 = [(FU \times D \times EF / FCR)_{\text{Engine 1}} + (FU \times D \times EF / FCR)_{\text{Engine 2}}] \times 1 \text{ ton} / 2000 \text{ lb}$$

Where:

SO<sub>2</sub> = SO<sub>2</sub> emissions (ton/month)

FU = Fuel Usage (gal/month)

D = Density of fuel (lb/gal)

EF = SO<sub>2</sub> Emission Factor (0.00405 lb SO<sub>2</sub>/hp-hr) (from AP-42, Table 3.4-1)

FCR = Fuel Consumption Rate (lb fuel/hp-hr)

**D.9.9 Sulfur Dioxide Emissions and Sulfur Content**

Compliance with Condition D.9.4 shall be determined utilizing one of the following options:



- (a) Pursuant to 326 IAC 3-7-4, the Permittee shall demonstrate that the sulfur dioxide emissions do not exceed five-tenths (0.5) pounds per million Btu heat input by:**
  - (1) Providing vendor analysis of fuel delivered, if accompanied by a certification; or**
  - (2) Analyzing the oil sample to determine the sulfur content of the oil via the procedures in 40 CFR 60, Appendix A, Method 19.**
    - (A) Oil samples may be collected from the fuel tank immediately after the fuel tank is filled and before any oil is combusted; and**
    - (B) If a partially empty fuel tank is refilled, a new sample and analysis would be required upon filling; or**
- (b) Compliance may also be determined by conducting a stack test for sulfur dioxide emissions, using 40 CFR 60, Appendix A, Method 6 in accordance with the procedures in 326 IAC 3-6.**

A determination of noncompliance pursuant to either of the methods specified in (a) or (b) above shall not be refuted by evidence of compliance pursuant to the other method.

#### **Record Keeping and Reporting Requirement [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

##### **D.9.10 Record Keeping Requirements**

---

- (a) To document the compliance status with Condition D.9.2, the Permittee shall:**
  - (1) Maintain monthly records of the diesel fuel throughput, fuel density, fuel consumption rate, and the emission factors for NO<sub>x</sub> and CO for Engine 1 and Engine 2 in Test Cell ETC55.**
  - (2) Maintain records of NO<sub>x</sub> emissions on a monthly basis using the equation in Condition D.9.6.**
  - (3) Maintain records of CO emissions on a monthly basis using the equation in Condition D.9.7.**
- (b) To document the compliance status with Condition D.9.3, the Permittee shall:**
  - (1) Maintain monthly records of the diesel fuel throughput, fuel density, fuel consumption rate, and the emission factor for SO<sub>2</sub> for Engine 1 and Engine 2 in Test Cell ETC55.**
  - (2) Maintain records of SO<sub>2</sub> emissions on a monthly basis using the equation in Condition D.9.8.**
- (c) To document the compliance status with Condition D.9.4, the Permittee shall maintain records in accordance with (1) through (6) below:**
  - (1) Calendar dates covered in the compliance determination period;**
  - (2) Actual fuel oil usage since last compliance determination period and equivalent sulfur dioxide emissions;**
  - (3) A certification, signed by the owner or operator which is not necessarily the responsible official, that the records of the fuel supplier certifications represent all of the fuel combusted during the period; and**

**If the fuel supplier certification is used to demonstrate compliance the following, as a minimum, shall be maintained:**

- (4) Fuel supplier certifications.**
  - (5) The name of the fuel supplier; and**
  - (6) A statement from the fuel supplier that certifies the sulfur content of the fuel oil.**
- (d) Section C - General Record Keeping Requirements contains the Permittee's obligation with regard to the records required to be maintained by this condition.**

#### **D.9.11 Reporting Requirements**

**A quarterly summary of the information to document the compliance status with Condition D.9.2, D.9.3, D.9.6, D.9.7, and D.9.8 shall be submitted using the reporting forms located at the end of this permit, or their equivalent, not later than thirty (30) days after the end of the quarter being reported. Section C - General Reporting contains the Permittee's obligation with regard to the reporting required by this condition. The reports submitted by the Permittee do require a certification that meets the requirements of 326 IAC 2-7-6(1) by a "responsible official" as defined by 326 IAC 2-7-1(35).**

.....

#### **SECTION E.2 New Source Performance Standards [326 IAC 2-7-5(1)] [326 IAC 12-1] [40 CFR 60, Subpart III]**

##### **Facility Description [326 IAC 2-7-5(14)]:**

- (a) Emergency diesel generators not exceeding 1600 horsepower. [326 IAC 6.5-1-2]**
  - (1) one (1) 1490-hp diesel emergency generator located in the Powerhouse courtyard.**
- (j) Transmission Test Cell 55, identified as ETC55, approved in 2013 for construction, consisting of two reciprocating diesel-fired engines, with an estimated maximum engine size of 4,000 hp each, exhausting to Stacks/Vents PTE93 and PTE94.**

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

#### **E.2.1 General Provisions Relating to National Emission Standards for Hazardous Air Pollutants under 40 CFR Part 60 [326 IAC 12-1] [40 CFR Part 60, Subpart A]**

- (a) Pursuant to 40 CFR 60.1, the Permittee shall comply with the provisions of 40 CFR Part 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to the ~~diesel emergency generator~~ **units** as described in this section except when otherwise specified in 40 CFR Part 60, Subpart III.**
- (b) Pursuant to 40 CFR 60.10, the Permittee shall submit all required notifications and reports to:**

Indiana Department of Environmental Management  
Compliance and Enforcement Branch, Office of Air Quality  
100 North Senate Avenue,  
MC 61-53 IGCN 1003  
Indianapolis, Indiana 46204-2251

**E.2.2 Standard of Performance for Stationary Compression Ignition Internal Combustion Engines**  
**[326 IAC 12] [40 CFR 60, Subpart IIII]**

Pursuant to 40 CFR 60 Subpart IIII (included as Attachment B of this permit), the Permittee shall comply with the provisions of Standard of Performance for Stationary Compression Ignition Internal Combustion Engines for the ~~Steam Boiler, identified as diesel emergency generator~~, as specified as follows:

**E.2.3 Standard of Performance for Stationary Compression Ignition Internal Combustion Engines**  
**[326 IAC 12] [40 CFR 60, Subpart IIII]**

Pursuant to 40 CFR 60 Subpart IIII (included as Attachment B of this permit), the Permittee shall comply with the provisions of Standard of Performance for Stationary Compression Ignition Internal Combustion Engines for ETC55, as specified as follows:

- (1) 40 CFR 60.4200
- (2) 40 CFR 60.4201
- (3) 40 CFR 60.4204(a), (b) and (e)
- (4) 40 CFR 60.4206
- (5) 40 CFR 60.4207(a), (b) and (e)
- (6) 40 CFR 60.4208(a), (e), (h) and (i)
- (7) 40 CFR 60.4211(a), (b), (c), (d), (e) and (g)
- (8) 40 CFR 60.4214(a)
- (9) 40 CFR 60.4218
- (10) 40 CFR 60.4219

.....  
**SECTION E.6 FACILITY OPERATION CONDITIONS**

**Facility Description [326 IAC 2-7-5(14)]:**

- (j) Transmission Test Cell 55, identified as ETC55, permitted in 2013, consisting of two reciprocating diesel-fired engines, with an estimated maximum engine size of 4,000 hp each, exhausting to Stacks/Vents PTE93 and PTE94.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

**Emission Limitations and Standards [326 IAC 2-7-5(1)]**

**E.6.1 General Provisions Relating to National Emission Standards for Hazardous Air Pollutants (NESHAP) [326 IAC 20-82] [40 CFR 63, Subpart A]**

The provisions of 40 CFR 63, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 20-82, apply to ETC55 except when otherwise specified in 40 CFR 63, Subpart ZZZZ.

**E.6.2 Stationary Reciprocating Internal Combustion Engines NESHAP [326 IAC 20-82] [40 CFR 63, Subpart ZZZZ]**

Pursuant to 40 CFR 63 Subpart ZZZZ, the Permittee shall comply with the provisions of 40 CFR 63 Subpart ZZZZ, which are incorporated as 326 IAC 20-82 for ETC55, as specified as follows:

**When using new engines**

- (1) 40 CFR 63.6580
- (2) 40 CFR 63.6585(a), (c), (e)
- (3) 40 CFR 63.6590(a)(2)(iii) and (c)(1)
- (4) 40 CFR 63.6595(a)(7)
- (5) 40 CFR 63.6665
- (6) 40 CFR 63.6670

**(7) 40 CFR 63.6675**

**When using existing engines**

- (1) 40 CFR 63.6580**
- (2) 40 CFR 63.6585(a), (c), (e)**
- (3) 40 CFR 63.6590(a)(1)(iii) and (iv)**
- (4) 40 CFR 63.6595(a)(1), (b), and (c)**
- (5) 40 CFR 63.6603(a)**
- (6) 40 CFR 63.6604(a)**
- (7) 40 CFR 63.6605**
- (8) 40 CFR 63.6612**
- (9) 40 CFR 63.6615**
- (10) 40 CFR 63.6620(a), (d), (e), (f), (g), (h), and (i)**
- (11) 40 CFR 63.6625(e)(4), (g), (h), (i)**
- (12) 40 CFR 63.6630(a), (b), and (c)**
- (13) 40 CFR 63.6635**
- (14) 40 CFR 63.6640(a), (b), and (e)**
- (15) 40 CFR 63.6645(a)(2), (a)(5), (g), and (h)**
- (16) 40 CFR 63.6650**
- (17) 40 CFR 63.6655**
- (18) 40 CFR 63.6660**
- (19) 40 CFR 63.6665**
- (20) 40 CFR 63.6670**
- (21) 40 CFR 63.6675**
- (22) Table 2b**
- (23) Table 2d (item 1), (item 2), and (item 3)**
- (24) Table 3 (item 4)**
- (25) Table 4 (items 1 and 3)**
- (26) Table 5 (items 1, 2, 3, 4, 5, 6, 11 and 12)**
- (27) Table 6 (items 3, 9, 10, and 11)**
- (28) Table 7 (item 1)**
- (29) Table 8**

.....

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
Compliance and Enforcement Branch**

**Part 70 Quarterly Report**

**Source Name:** Allison Transmission, Inc. - Speedway Main Campus  
**Source Address:** One Allison Way, Mail Code: M-29, Indianapolis Indiana 46222  
**Part 70 Permit No.:** T097-27011-00310  
**Facility:** Emission Unit ETC55  
**Parameter:** NOx Emissions  
**Limit:** NOx emissions from diesel fuel fired reciprocating engines utilized in ETC55 shall be less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.

The following equation shall be used to determine compliance:

$$\text{NOx} = [(FU \times D \times EF / FCR)_{\text{Engine 1}} + (FU \times D \times EF / FCR)_{\text{Engine 2}}] \times 1 \text{ ton} / 2,000 \text{ lb}$$

Where:

NOx = NOx emissions (ton/month)

FU = Fuel Usage (gal/month)

D = Density of fuel (lb/gal)

EF = NOx Emission Factor (lb/hp-hr) (For each engine type used, the emission factor shall be the emission limitation from the applicable federal engine emission standards.)

FCR = Fuel Consumption Rate (lb fuel/hp-hr)

Quarter: \_\_\_\_\_ Year: \_\_\_\_\_

| Month | Column 1   | Column 2           | Column 1 +<br>Column 2 |
|-------|------------|--------------------|------------------------|
|       | This Month | Previous 11 Months | 12 Month Total         |
|       |            |                    |                        |
|       |            |                    |                        |
|       |            |                    |                        |

☐ No deviation occurred in this quarter.

☐ Deviation/s occurred in this quarter.

Deviation has been reported on: \_\_\_\_\_

Submitted by: \_\_\_\_\_

Title / Position: \_\_\_\_\_

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

.....

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
Compliance and Enforcement Branch**

**Part 70 Quarterly Report**

**Source Name:** Allison Transmission, Inc. - Speedway Main Campus  
**Source Address:** One Allison Way, Mail Code: M-29, Indianapolis Indiana 46222  
**Part 70 Permit No.:** T097-27011-00310  
**Facility:** Emission Unit ETC55  
**Parameter:** CO Emissions  
**Limit:** CO emissions from diesel fuel fired reciprocating engines utilized in ETC55 shall be less than one-hundred (100) tons per twelve (12) consecutive month period with compliance determined at the end of each month

The following equation shall be used to determine compliance:

$$CO = [(FU \times D \times EF / FCR)_{\text{Engine 1}} + (FU \times D \times EF / FCR)_{\text{Engine 2}}] \times 1 \text{ ton} / 2,000 \text{ lb}$$

Where:

CO = CO emissions (ton/month)

FU = Fuel Usage (gal/month)

D = Density of fuel (lb/gal)

EF = CO Emission Factor (lb/hp-hr) (For each engine type used, the emission factor shall be the emission limitation from the applicable federal engine emission standards.)

FCR = Fuel Consumption Rate (lb fuel/hp-hr)

Quarter: \_\_\_\_\_ Year: \_\_\_\_\_

| Month | Column 1   | Column 2           | Column 1 + Column 2 |
|-------|------------|--------------------|---------------------|
|       | This Month | Previous 11 Months | 12 Month Total      |
|       |            |                    |                     |
|       |            |                    |                     |
|       |            |                    |                     |

☐ No deviation occurred in this quarter.

☐ Deviation/s occurred in this quarter.

Deviation has been reported on: \_\_\_\_\_

**Submitted by:** \_\_\_\_\_

**Title / Position:** \_\_\_\_\_

**Signature:** \_\_\_\_\_

**Date:** \_\_\_\_\_

**Phone:** \_\_\_\_\_

.....

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
Compliance and Enforcement Branch**

**Part 70 Quarterly Report**

**Source Name:** Allison Transmission, Inc. - Speedway Main Campus  
**Source Address:** One Allison Way, Mail Code: M-29, Indianapolis Indiana 46222  
**Part 70 Permit No.:** T097-27011-00310  
**Facility:** Emission Unit ETC55  
**Parameter:** SO<sub>2</sub> Emissions  
**Limit:** SO<sub>2</sub> emissions from diesel fuel fired reciprocating engines utilized in ETC55 shall be less than forty (40) tons per twelve (12) consecutive month period with compliance determined at the end of each month.

The following equation shall be used to determine compliance:

$$SO_2 = [(FU \times D \times EF / FCR)_{\text{Engine 1}} + (FU \times D \times EF / FCR)_{\text{Engine 2}}] \times 1 \text{ ton} / 2000 \text{ lb}$$

Where:

SO<sub>2</sub> = SO<sub>2</sub> emissions (ton/month)

FU = Fuel Usage (gal/month)

D = Density of fuel (lb/gal)

EF = SO<sub>2</sub> Emission Factor (0.00405 lb SO<sub>2</sub>/hp-hr) (from AP-42, Table 3.4-1)

FCR = Fuel Consumption Rate (lb fuel/hp-hr)

Quarter: \_\_\_\_\_ Year: \_\_\_\_\_

| Month | Column 1   | Column 2           | Column 1 + Column 2 |
|-------|------------|--------------------|---------------------|
|       | This Month | Previous 11 Months | 12 Month Total      |
|       |            |                    |                     |
|       |            |                    |                     |
|       |            |                    |                     |

☐ No deviation occurred in this quarter.

☐ Deviation/s occurred in this quarter.

Deviation has been reported on: \_\_\_\_\_

**Submitted by:** \_\_\_\_\_

**Title / Position:** \_\_\_\_\_

**Signature:** \_\_\_\_\_

**Date:** \_\_\_\_\_

**Phone:** \_\_\_\_\_

.....

**Change 2:** The Permittee has completed an applicability determination that the 40 CFR 60, Subpart IIII and 40 CFR 63, Subpart ZZZZ are not exempt because test cell transmissions are being tested instead of test cell engines. Also, the Permittee does operate a gas turbine with heat input at peak load greater than 10 MMBtu/hr and therefore should be subject to 40 CFR 60, Subpart KKKK.

B.12 Permit Shield [326 IAC 2-7-15] [326 IAC 2-7-20] [326 IAC 2-7-12]

---

.....

- (b) In addition to the nonapplicability determinations set forth in Sections D of this permit, the IDEM, OAQ has made the following determinations regarding this source:

.....

- (6) ~~The requirements of the New Source Performance Standard for Stationary Compression Ignition Internal Combustion Engines (CI ICE), 326 IAC 12 and 40 CFR 60.4200, Subpart IIII, are not included in the permit for the stationary CI ICE test cell/stand because the provisions of this subpart are not applicable to stationary CI ICE being tested at a stationary CI ICE test cell/stand. The July 11, 2006 Federal Register also states that engines used at test cells/stands are exempt.~~ **Reserved**

- (7) The requirements of the New Source Performance Standard for Stationary Spark Ignition Internal Combustion Engines, 326 IAC 12 and 40 CFR 60.4230, Subpart JJJJ are not included in the permit because ~~the regulation does not apply to stationary SI ICE being tested at an engine test cell/stand~~ **there are no spark ignition internal combustion engines in operation at the facility.**

- (8) ~~The requirements of the New Source Performance Standard for Stationary Combustion Turbines, 326 IAC 12 and 40 CFR 60.4300, Subpart KKKK are not included in the permit because the source does not operate stationary gas turbines with a heat input at peak load greater than 10 MMBtu/hr that were constructed, reconstructed or modification after February 18, 2005.~~ **Reserved**

.....

- (11) ~~The requirements of the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Stationary Reciprocating Internal Combustion Engines, 326 IAC 20, 40 CFR 63.6580, Subpart ZZZZ are not included in the permit because the provisions of the subpart do not apply to engines being tested at a test cell/stand.~~ **Reserved**

.....



**Change 3:** The Agency Determination and Order of the Commissioner has been added to the permit.

## **SECTION E.7 Order of the Commissioner**

### **Facility Description [326 IAC 2-7-5(14)]**

**(c) Engineering development transmission test cell 704 at Emission Unit ETC.**

| Test Cell ID | Fuel Type | Engine Type   | Estimated Maximum Engine Size in Horsepower |
|--------------|-----------|---------------|---|
| 704          | Diesel    | Reciprocating | 2400  |

**(e) Emission unit PTS14, consisting of the following transmission test stands, identified as test stand O-1, O-2, and O-31. Test stands O-1, O-2, and O-31 were constructed in 1978, 1979, and 1984 respectively. The emissions from test stands O-1, O-2, and O-31 are exhausted out stacks 14041, 14038, and 14045, respectively.**

| Test Cell ID | Fuel Type | Engine Type   | Estimated Maximum Engine Size in Horsepower |
|--------------|-----------|---------------|---|
| O-1          | Diesel    | Reciprocating | 2400  |
| O-2          | Diesel    | Reciprocating | 2400  |
| O-31         | Diesel    | Reciprocating | 2400  |

**(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)**

### **E.7.1 Agency Determination and Order of the Commissioner**

- (a) Allison Transmission shall submit a status report within fifteen (15) days of completion of the following milestones indicating the actual dates of completion:**
- (1) The date of delivery of the oxidation catalyst system to the Main Campus Building.**
  - (2) The date of completion of installation of the oxidation catalyst system at the Main Campus Building.**
  - (3) The date of completion of final quality assurance and control testing of the oxidation catalyst system.**
  - (4) The date of startup of the oxidation catalyst system.**
- (b) Allison Transmission shall comply with the standards set forth in 40 CFR 63, Subpart ZZZZ no later than May 3, 2014.**

**Change 4:** The requirements of 40 CFR 60, Subpart KKKK have been added to existing units.

## SECTION E.5 FACILITY OPERATION CONDITIONS

### Facility Description [326 IAC 2-7-5(14)]

(c) Emission Unit ETC consists of the following development transmission test cells:

| Test Cell ID | Fuel Type | Engine Type                  | Estimated Maximum Engine Size in Horsepower  |
|--------------|-----------|------------------------------|--|
| 701          | Diesel    | Reciprocating or Gas Turbine | 4000   |
| 705          | Diesel    | Reciprocating or Gas Turbine | 2400 for reciprocating; 4000 for gas turbine |

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

*This section only applies at times when a turbine engine is installed in the test cell and a test cell exemption does not apply.*

### Emission Limitations and Standards [326 IAC 2-7-5(1)]

#### E.5.1 General Provisions Relating to New Source Performance Standards (NSPS) [40 CFR 60, Subpart A] [326 IAC 12]

The provisions of 40 CFR 60, Subpart A - General Provisions, which are incorporated by reference in 326 IAC 12-1, apply to Test Cell 701 and Test Cell 705 (of Emission Unit ETC) except when otherwise specified in 40 CFR 60, Subpart KKKK.

#### E.5.2 Stationary Combustion Turbines NSPS Requirements [40 CFR 60, Subpart KKKK] [326 IAC 12]

Pursuant to 40 CFR 60 Subpart KKKK, the Permittee shall comply with the provisions of 40 CFR 60 Subpart KKKK, which are incorporated as 326 IAC 12-1 for Test Cell 701 and Test Cell 705 (of Emission Unit ETC), as specified as follows:

- (1) 40 CFR 60.4305
- (2) 40 CFR 60.4315
- (3) 40 CFR 60.4320(a)
- (4) 40 CFR 60.4325
- (5) 40 CFR 60.4330(a)
- (6) 40 CFR 60.4333
- (7) 40 CFR 60.4375
- (8) 40 CFR 60.4395
- (9) 40 CFR 60.4420

.....

### Other Changes

The changes listed below have been made to Part 70 Operating Permit Renewal No. T 097-27011-00310. Deleted language appears as ~~strike throughs~~ and new language appears in **bold**:

**Change No. 1** On November 3, 2011, the Indiana Air Pollution Control Board issued a revision to 326 IAC 2. The revision resulted in a change to the rule site of the “responsible official” definition. The rule site for responsible official has changed from 326 IAC 2-7-1(34) to 326 IAC 2-7-1(35).

**Change No. 2** The Organic Solvent Degreasing Operations (326 IAC 8-3-2 and 326 IAC 8-3-8) rules have been updated. 326 IAC 8-3-5 has been repealed.

A.3 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)]  
[326 IAC 2-7-5(14)]

This stationary source consists of the following emission units and pollution control devices:

- (f) Cold solvent degreasing using mineral spirits identified as emission unit CSD. Emissions are vented inside the building. Each degreasing unit was installed prior to 1977.  
**[326 IAC 8-3-2] [326 IAC 8-3-8]**

.....

A.4 Specifically Regulated Insignificant Activities  
[326 IAC 2-7-1(21)][326 IAC 2-7-4(c)][326 IAC 2-7-5(14)]

This stationary source also includes the following insignificant activities which are specifically regulated, as defined in 326 IAC 2-7-1(21):

- (i) Cleaners and solvents characterized as having a vapor pressure equal to or less than: two (2.0) kilo Pascals (fifteen (15) millimeters of mercury or three-tenths (0.3) pound per square inch) measured at thirty-eight (38) degrees Centigrade (one hundred (100) degrees Fahrenheit); or seven-tenths (0.7) kilo Pascal (five (5) millimeters of mercury or one-tenth (0.1) pound per square inch) measured at twenty (20) degrees Centigrade (sixty-eight (68) degrees Fahrenheit); the use of which, for all cleaners and solvents combined, does not exceed one hundred forty-five (145) gallons per twelve (12) months, including:

One (1) cold solvent degreasing unit using mineral spirits identified as emission unit CSD-1, approved in 2012 for construction, exhausting inside. [326 IAC 8-3-2] ~~[326 IAC 8-3-5]~~  
**[326 IAC 8-3-8]**

.....

SECTION D.5

FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(14)]

- (f) Cold solvent degreasing using mineral spirits identified as emission unit CSD. Emissions are in to the building. Each degreasing unit was installed prior to 1977. **[326 IAC 8-3-2][326 IAC 8-3-8]**

Specifically Regulated Insignificant Activities

- (i) Cleaners and solvents characterized as having a vapor pressure equal to or less than: two (2.0) kilo Pascals (fifteen (15) millimeters of mercury or three-tenths (0.3) pound per square inch) measured at thirty-eight (38) degrees Centigrade (one hundred (100) degrees Fahrenheit); or seven-tenths (0.7) kilo Pascal (five (5) millimeters of mercury or one-tenth (0.1) pound per square inch) measured at twenty (20) degrees Centigrade (sixty-eight (68) degrees Fahrenheit); the use of which, for all cleaners and solvents combined, does not exceed one hundred forty-five (145) gallons per twelve (12) months, including:

One (1) cold solvent degreasing unit using mineral spirits identified as emission unit CSD-1, approved in 2012 for construction, exhausting inside. [326 IAC 8-3-2] ~~[326 IAC 8-3-5]~~ **[326 IAC 8-3-8]**

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.5.1 Volatile Organic Compounds (VOC) [326 IAC 8-3-2]

~~Pursuant to 326 IAC 8-3-2 (Organic Solvent Degreasing Operations: Cold Cleaner Operation), for cold cleaning operations existing as of January 1, 1980 located in Marion County, the Permittee shall:~~

**(a) Pursuant to 326 IAC 8-3-2 (Cold Cleaner Degreaser Control Equipment and Operating Requirements), for cold cleaning degreasers constructed after January 1, 1980, the Permittee shall ensure the following control equipment and operating requirements are met:**

- (1) Equip the ~~cleaner~~ degreaser with a cover.**
- (2) Equip the ~~cleaner~~ degreaser with a ~~facility~~ device for draining cleaned parts.**
- (3) Close the degreaser cover whenever parts are not being handled in the ~~cleaner~~; degreaser.**
- (4) Drain cleaned parts for at least fifteen (15) seconds or until dripping ceases;**
- (5) Provide a permanent, conspicuous label summarizing that lists the operationing requirements; in subdivisions (3), (4), (6), and (7).**
- (6) Store waste solvent only in ~~covered~~ closed containers. and not dispose**
- (7) Prohibit the disposal or transfer of waste solvent or transfer it to another party, in such a manner that could allow greater than twenty percent (20%) of the waste solvent (by weight) ~~can~~ to evaporate into the atmosphere.**

**(b) Pursuant to 326 IAC 8-3-2 (Cold Cleaner Degreaser Control Equipment and Operating Requirements), for cold cleaning degreasers without remote solvent reservoirs constructed after July 1, 1990, the Permittee shall ensure the following additional control equipment and operating requirements are met:**

- (1) Equip the degreaser with one (1) of the following control devices if the solvent is heated to a temperature of greater than forty-eight and nine-tenths (48.9) degrees Celsius (one hundred twenty (120) degrees Fahrenheit):**
  - (A) A freeboard that attains a freeboard ratio of seventy-five hundredths (0.75) or greater.**
  - (B) A water cover when solvent used is insoluble in, and heavier than, water.**
  - (C) A refrigerated chiller.**
  - (D) Carbon adsorption.**
  - (E) An alternative system of demonstrated equivalent or better control as those outlined in clauses (A) through (D) that is approved by the department. An alternative system shall be submitted to the U.S. EPA as a SIP revision.**
- (2) Ensure the degreaser cover is designed so that it can be easily operated with one (1) hand if the solvent is agitated or heated.**
- (3) If used, solvent spray:**

**(A) must be a solid, fluid stream; and**

**(B) shall be applied at a pressure that does not cause excessive splashing.**

~~(b) Pursuant to 326 IAC 8-3-5(a) (Cold Cleaner Degreaser Operation and Control), for cold cleaner degreaser operations without remote solvent reservoirs constructed after July 1, 1990, the Permittee shall ensure that the following control equipment requirements are met:~~

~~(1) Equip the degreaser with a cover. The cover must be designed so that it can be easily operated with one (1) hand if:~~

~~(A) The solvent volatility is greater than two (2) kiloPascals (fifteen (15) millimeters of mercury or three-tenths (0.3) pounds per square inch) measured at thirty-eight degrees Celsius (38°C) (one hundred degrees Fahrenheit (100°F));~~

~~(B) The solvent is agitated; or~~

~~(C) The solvent is heated.~~

~~(2) Equip the degreaser with a facility for draining cleaned articles. If the solvent volatility is greater than four and three-tenths (4.3) kiloPascals (thirty-two (32) millimeters of mercury) or six-tenths (0.6) pounds per square inch) measured at thirty-eight degrees Celsius (38°C) (one hundred degrees Fahrenheit (100°F)), then the drainage facility must be internal such that articles are enclosed under the cover while draining. The drainage facility may be external for applications where an internal type cannot fit into the cleaning system.~~

~~(3) Provide a permanent, conspicuous label which lists the operating requirements outlined in subsection (b).~~

~~(4) The solvent spray, if used, must be a solid, fluid stream and shall be applied at a pressure which does not cause excessive splashing.~~

~~(5) Equip the degreaser with one (1) of the following control devices if the solvent volatility is greater than four and three-tenths (4.3) kiloPascals (thirty-two (32) millimeters of mercury) or six-tenths (0.6) pounds per square inch) measured at thirty-eight degrees Celsius (38°C) (one hundred degrees Fahrenheit (100°F)), or if the solvent is heated to a temperature greater than forty-eight and nine-tenths degrees Celsius (48.9°C) (one hundred twenty degrees Fahrenheit (120°F)):~~

~~(A) A freeboard that attains a freeboard ratio of seventy-five hundredths (0.75) or greater.~~

~~(B) A water cover when solvent is used is insoluble in water and heavier than water.~~

~~(C) Other systems of demonstrated equivalent control such as a refrigerated chiller or carbon adsorption. Such systems shall be submitted to the U.S. EPA as a SIP revision.~~

~~(c) Pursuant to 326 IAC 8-3-5(b) (Cold Cleaner Degreaser Operation and Control), the owner or operator of a cold cleaning facility construction of which commenced after July 1, 1990, shall ensure that the following operating requirements are met:~~

~~(1) Close the cover whenever articles are not being handled in the degreaser.~~

- ~~(2) Drain cleaned articles for at least fifteen (15) seconds or until dripping ceases.~~
- ~~(3) Store waste solvent only in covered containers and prohibit the disposal or transfer of waste solvent in any manner in which greater than twenty percent (20%) of the waste solvent by weight could evaporate.~~

#### **D.5.2 Volatile Organic Compounds (VOC) [326 IAC 8-3-8]**

Pursuant to 326 IAC 8-3-8 (Material Requirements for Cold Cleaner Degreasers), on and after January 1, 2015, the Permittee shall not operate a cold cleaner degreaser with a solvent that has a VOC composite partial vapor pressure than exceeds one (1) millimeter of mercury (nineteen-thousandths (0.019) pound per square inch) measured at twenty (20) degrees Celsius (sixty-eight (68) degrees Fahrenheit).

#### **Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]**

##### **D.5.3 Record Keeping Requirements**

- (a) Pursuant to 326 IAC 8-3-8(c)(2), on and after January 1, 2015, the following records shall be maintained for each purchase of cold cleaner degreaser solvent:
  - (1) The name and address of the solvent supplier.
  - (2) The date of purchase (or invoice/bill dates of contract servicer indicating service date).
  - (3) The type of solvent purchased.
  - (4) The total volume of the solvent purchased.
  - (5) The true vapor pressure of the solvent measured in millimeters of mercury at twenty (20) degrees Celsius (sixty-eight (68) degrees Fahrenheit).
- (b) Section C - General Record Keeping Requirements of this permit contains the Permittee's obligations with regard to the records required by this condition.

#### **Conclusion and Recommendation**

The construction of this proposed modification shall be subject to the conditions of the attached proposed Part 70 Significant Source Modification No. 097-33211-00310 and Significant Permit Modification 097-33236-00310. The staff recommend to the Commissioner that this Part 70 Significant Source and Significant Permit Modification be approved.

#### **IDEM Contact**

- (a) Questions regarding this proposed permit can be directed to Heath Hartley at the Indiana Department Environmental Management, Office of Air Quality, Permits Branch, 100 North Senate Avenue, MC 61-53 IGCN 1003, Indianapolis, Indiana 46204-2251 or by telephone at (317) 232-8217 or toll free at 1-800-451-6027 extension 232-8217.
- (b) A copy of the findings is available on the Internet at: <http://www.in.gov/ai/appfiles/idem-caats/>
- (c) For additional information about air permits and how the public and interested parties can participate, refer to the IDEM's Guide for Citizen Participation and Permit Guide on the Internet at: [www.idem.in.gov](http://www.idem.in.gov)

### Appendix A: Emissions Calculations Emission Summary

Company Name: Allison Transmission, Inc. - Main Speedway Campus  
 Address City IN Zip: One Allison Way, Indianapolis, IN 46222  
 Permit Number: SSM 097-33211-00310 and SPM 097-33236-00310  
 Reviewer: Heath Hartley  
 Date: 5/16/2013

#### Uncontrolled Potential Emissions

| Emission Unit          |               | PM<br>(tons/yr) | PM <sub>10</sub><br>(tons/yr) | PM <sub>2.5</sub><br>(tons/yr) | SO <sub>2</sub><br>(tons/yr) | NOx<br>(tons/yr) | VOC<br>(tons/yr) | CO<br>(tons/yr) | GHG as<br>CO <sub>2</sub> e | Total HAPs<br>(tons/yr) | Worst Single HAP<br>(Hexane) (tons/yr) |         |
|------------------------|---------------|-----------------|-------------------------------|--------------------------------|------------------------------|------------------|------------------|-----------------|-----------------------------|-------------------------|--|---------|
| New                    | ETC55         | 12.3            | 7.0                           | 7.0                            | 70.9                         | 420.5            | 12.4             | 100.8           | 20,397                      | 0.19                    | 0.09                                   | Benzene |
| Existing               | BLR4          | 0.6             | 2.4                           | 2.4                            | 0.2                          | 31.5             | 1.7              | 26.5            | 38,074                      | 1.38                    | 1.32                                   | Hexane  |
|                        | BLR5          | 0.8             | 3.2                           | 3.2                            | 0.3                          | 42.0             | 2.3              | 35.3            | 50,765                      |                         |  |         |
|                        | BLR6          | 0.8             | 3.3                           | 3.3                            | 0.3                          | 13.9             | 2.4              | 36.4            | 52,141                      |                         |  |         |
|                        | ETC           | 153.0           | 138.7                         | 138.7                          | 772.6                        | 4895.8           | 200.8            | 1303.4          | 253,327                     | 2.41                    | 1.19                                   | Benzene |
|                        | DTC           | 57.0            | 57.0                          | 57.0                           | 53.3                         | 811.3            | 66.2             | 174.8           | 30,460                      | 0.71                    | 0.17                                   | Benzene |
|                        | PTS14 O-1&O-2 | 14.7            | 8.4                           | 8.2                            | 74.3                         | 470.9            | 13.2             | 125.1           | 42,644                      | 0.23                    | 0.11                                   | Benzene |
|                        | PTS14 O-24&25 | 11.4            | 11.4                          | 11.4                           | 10.7                         | 162.3            | 13.2             | 35.0            |                             | 0.14                    | 0.03                                   | Benzene |
|                        | PTS14 O-31    | 7.4             | 4.2                           | 4.1                            | 37.2                         | 235.5            | 6.6              | 62.5            |                             | 0.12                    | 0.06                                   | Benzene |
|                        | ETC702        | 12.3            | 7.0                           | 6.8                            | 61.9                         | 392.4            | 11.0             | 104.2           | 20,307                      | 0.19                    | 0.10                                   | Benzene |
| CSD                    |               | 0               | 0                             | 0                              | 0                            | 0                | 0.5              | 0               | 0                           | 0                       | 0                                      | ---     |
| Total Existing         |               | 258.0           | 235.7                         | 235.1                          | 1010.7                       | 7055.6           | 318.1            | 1903.3          | 487,717                     | 6.01                    | 2.11                                   | Hexane  |
| Source Total After Mod |               | 270.3           | 242.7                         | 242.1                          | 1081.6                       | 7476.1           | 330.4            | 2004.1          | 508,114                     | 6.19                    | 2.11                                   | Hexane  |

#### Limited Potential to Emit

| Emission Unit          |               | PM<br>(tons/yr) | PM <sub>10</sub><br>(tons/yr) | PM <sub>2.5</sub><br>(tons/yr) | SO <sub>2</sub><br>(tons/yr) | NOx<br>(tons/yr) | VOC<br>(tons/yr) | CO<br>(tons/yr) | GHG as<br>CO <sub>2</sub> e | Total HAPs<br>(tons/yr) | Worst Single HAP<br>(Hexane) (tons/yr) |         |
|------------------------|---------------|-----------------|-------------------------------|--------------------------------|------------------------------|------------------|------------------|-----------------|-----------------------------|-------------------------|--|---------|
| New                    | ETC55         | 12.3            | 7.0                           | 7.0                            | 39.9                         | 39.9             | 12.4             | 99.9            | 20,397                      | 0.19                    | 0.09                                   | Benzene |
| Existing               | BLR4          | 0.6             | 2.4                           | 2.4                            | 0.2                          | 31.5             | 1.7              | 26.5            | 38,074                      | 1.38                    | 1.32                                   | Hexane  |
|                        | BLR5          | 0.8             | 3.2                           | 3.2                            | 0.3                          | 42.0             | 2.3              | 35.3            | 50,765                      |                         |  |         |
|                        | BLR6          | 0.8             | 3.3                           | 3.3                            | 0.3                          | 13.9             | 2.4              | 36.4            | 52,141                      |                         |  |         |
|                        | ETC           | 146.9           | 135.8                         | 135.8                          | 737.4                        | 4700.3           | 195.3            | 1251.5          | 253,327                     | 2.41                    | 1.19                                   | Benzene |
|                        | DTC           | 2.8             | 2.8                           | 2.8                            | 2.6                          | 39.9             | 3.3              | 8.6             | 30,460                      | 0.71                    | 0.17                                   | Benzene |
|                        | PTS14 O-1&O-2 | 1.3             | 0.7                           | 0.7                            | 6.3                          | 39.9             | 1.1              | 10.6            | 42,644                      | 0.02                    | 0.01                                   | Benzene |
|                        | PTS14 O-24&25 | 2.8             | 2.8                           | 2.8                            | 2.6                          | 39.9             | 3.3              | 8.6             |                             | 0.01                    | 0.01                                   | Benzene |
|                        | PTS14 O-31    | 1.3             | 0.7                           | 0.7                            | 6.3                          | 39.9             | 1.1              | 10.6            |                             | 0.02                    | 0.01                                   | Benzene |
|                        | ETC702        | 1.2             | 0.7                           | 0.7                            | 6.0                          | 38.0             | 1.1              | 10.1            | 20,307                      | 0.19                    | 0.10                                   | Benzene |
| CSD                    |               | 0               | 0                             | 0                              | 0                            | 0                | 0.5              | 0               | 0                           | 0                       | 0                                      | ---     |
| Total Existing         |               | 158.4           | 152.4                         | 152.4                          | 761.9                        | 4985.4           | 212.1            | 1398.3          | 487,717                     | 5.57                    | 2.11                                   | Hexane  |
| Source Total After Mod |               | 170.7           | 159.5                         | 159.4                          | 801.8                        | 5025.3           | 224.4            | 1498.2          | 508,114                     | 5.76                    | 2.11                                   | Hexane  |

**Appendix A: Emission Calculations**  
**Large Reciprocating Internal Combustion Engines - Diesel Fuel**  
**Output Rating (>600 HP) Maximum Input Rate (>4.2 MMBtu/hr)**  
**ETC55**

Company Name: Allison Transmission, Inc. - Main Speedway Campus  
Address City IN Zip: One Allison Way, Indianapolis, IN 46222  
Permit Number: SSM 097-33211-00310 and SPM 097-33236-00310  
Reviewer: Heath Hartley  
Date: 5/16/2013

Emissions calculated from 40 CFR 89.112, Tier 2 emission standards for nonroad engines (kW > 560, model year 2006 or more recent)

|   |            |          |              |           |          |           |          |
|---|------------|----------|--------------|-----------|----------|-----------|----------|
| Output Horsepower Rating (hp)             | 4000       |          |              |           |          |           |          |
| Maximum Hours Operated per Year           | 8760       |          |              |           |          |           |          |
| Potential Throughput (hp-hr/yr)           | 35,040,000 |          |              |           |          |           |          |
|   | Pollutant  |          |              |           |          |           |          |
|   | PM         | PM10     | direct PM2.5 | SO2       | NOx      | VOC       | CO       |
| Emission Factor in g/kW-hr <sup>(1)</sup> | 0.20       | 0.20     | 0.20         | see below | 6.4      | see below | 3.5      |
| Emission Factor in g/hp-hr <sup>(1)</sup> | 0.15       | 0.15     | 0.15         |           | 4.8      |           | 2.6      |
| Emission Factor in lb/hp-hr               | 3.29E-04   | 3.29E-04 | 3.29E-04     |           | 1.05E-02 |           | 5.75E-03 |
| Potential Emission in tons/yr             | 5.8        | 5.8      | 5.8          |           | 184.3    |           | 100.8    |

**Emissions calculated based AP-42 Emission Factors**

|  |            |          |               |                       |                         |          |          |
|--|------------|----------|---------------|-----------------------|-------------------------|----------|----------|
| Output Horsepower Rating (hp)              | 4000       |          |               |                       |                         |          |          |
| Maximum Hours Operated per Year            | 8760       |          |               |                       |                         |          |          |
| Potential Throughput (hp-hr/yr)            | 35,040,000 |          |               |                       |                         |          |          |
| Sulfur Content (S) of Fuel (% by weight)   | 0.5        |          |               |                       |                         |          |          |
|  | Pollutant  |          |               |                       |                         |          |          |
|  | PM*        | PM10*    | direct PM2.5* | SO2                   | NOx                     | VOC      | CO       |
| Emission Factor in lb/hp-hr <sup>(2)</sup> | 7.00E-04   | 4.01E-04 | 4.01E-04      | 4.05E-03<br>(.00809S) | 2.40E-02<br>**see below | 7.05E-04 | 5.50E-03 |
| Potential Emission in tons/yr              | 12.3       | 7.0      | 7.0           | 70.9                  | 420.5                   | 12.4     | 96.4     |

\*\*NOx emission factor: uncontrolled = 0.024 lb/hp-hr, controlled by ignition timing retard = 0.013 lb/hp-hr

**Worst Case Potential to Emit**

|                               |           |       |               |      |       |      |       |
|-------------------------------|-----------|-------|---------------|------|-------|------|-------|
|                               | Pollutant |       |               |      |       |      |       |
|                               | PM*       | PM10* | direct PM2.5* | SO2  | NOx   | VOC  | CO    |
| Potential Emission in tons/yr | 12.3      | 7.0   | 7.0           | 70.9 | 420.5 | 12.4 | 100.8 |

**Hazardous Air Pollutants (HAPs)**

|                                 |           |          |          |              |              |          |                   |
|---------------------------------|-----------|----------|----------|--------------|--------------|----------|-------------------|
|                                 | Pollutant |          |          |              |              |          |                   |
|                                 | Benzene   | Toluene  | Xylene   | Formaldehyde | Acetaldehyde | Acrolein | Total PAH HAPs*** |
| Emission Factor in lb/hp-hr**** | 5.12E-06  | 1.97E-06 | 1.35E-06 | 5.52E-07     | 1.76E-07     | 5.52E-08 | 1.48E-06          |
| Potential Emission in tons/yr   | 0.09      | 0.03     | 0.02     | 0.01         | 3E-03        | 1E-03    | 0.03              |

\*\*\*PAH = Polyaromatic Hydrocarbon (PAHs are considered HAPs, since they are considered Polycyclic Organic Matter)

\*\*\*\*Emission factors in lb/hp-hr were calculated using emission factors in lb/MMBtu and a brake specific fuel consumption of 7,000 Btu / hp-hr (AP-42 Table 3.4-1).

|   |  |             |
|---|--|-------------|
| <b>Potential Emission of Total HAPs (tons/yr)</b> |  | <b>0.19</b> |
|---|--|-------------|

**Green House Gas Emissions (GHG)**

|                               |           |          |          |
|-------------------------------|-----------|----------|----------|
|                               | Pollutant |          |          |
|                               | CO2       | CH4      | N2O      |
| Emission Factor in lb/hp-hr   | 1.16E+00  | 6.35E-05 | 9.30E-06 |
| Potential Emission in tons/yr | 20,323    | 1.11     | 0.16     |

|                                       |  |        |
|---------------------------------------|--|--------|
| Summed Potential Emissions in tons/yr |  | 20,324 |
| CO2e Total in tons/yr                 |  | 20,397 |

**Methodology**

Potential Throughput (hp-hr/yr) = [Output Horsepower Rating (hp)] \* [Maximum Hours Operated per Year]

<sup>(1)</sup> Emission Factors from 40 CFR 89.112, Tier 2 emission standards for nonroad engines (kW > 560, model year 2006 or more recent)

<sup>(2)</sup> Emission Factors are from AP 42 (Supplement B 10/96) Tables 3.4-1, 3.4-2, 3.4-3, and 3.4-4.

CH4 and N2O Emission Factor from 40 CFR 98 Subpart C Table C-2.

Global Warming Potentials (GWP) from Table A-1 of 40 CFR Part 98 Subpart A.

Potential Emission (tons/yr) = [Potential Throughput (hp-hr/yr)] \* [Emission Factor (lb/hp-hr)] / [2,000 lb/ton]

CO2e (tons/yr) = CO2 Potential Emission ton/yr x CO2 GWP (1) + CH4 Potential Emission ton/yr x CH4 GWP (21) + N2O Potential Emission ton/yr x N2O GWP (310).



**Appendix A: Emission Calculations**  
**Natural Gas Combustion Only**  
**MMBtu/hr <100**  
**BLR4 through BLR5**

Company Name: Allison Transmission, Inc. - Main Speedway Campus  
Address City IN Zip: One Allison Way, Indianapolis, IN 46222  
Permit Number: SSM 097-33211-00310 and SPM 097-33236-00310  
Reviewer: Heath Hartley  
Date: 5/16/2013

Emission Unit BLR4 through BLR5

|                |      |
|----------------|------|
| MMBtu/MMcf     | 1000 |
| Sulfur Content | NA   |
| Ash Content    | NA   |

| EMISSION UNIT DESCRIPTION |                           |  |                          |                |
|---------------------------|---------------------------|--|--------------------------|----------------|
| Emission Unit I.D.        | Heat Capacity<br>MMBtu/hr |  | Heat Capacity<br>MMCF/hr | Date Installed |
| BLR4                      | 72                        |  | 0.072                    | 1953           |
| BLR5                      | 96                        |  | 0.096                    | 1963           |

|               | Pollutant |       |       |      |       |       |       |
|---------------|-----------|-------|-------|------|-------|-------|-------|
|               | PM        | PM-10 | PM2.5 | SO2  | NOx   | NMTOC | CO    |
| NG - Lbs/MMcf | 1.9       | 7.6   | 7.6   | 0.6  | 100   | 5.5   | 84    |
| BLR4          | 0.60      | 2.40  | 2.40  | 0.19 | 31.54 | 1.73  | 26.49 |
| BLR5          | 0.80      | 3.20  | 3.20  | 0.25 | 42.05 | 2.31  | 35.32 |

\*PM emission factor is filterable PM only. PM<sub>10</sub> and PM<sub>2.5</sub> emission factors are filterable and condensable PM combined.

\*\*Emission Factors for NO<sub>x</sub>: Uncontrolled = 100, Low NO<sub>x</sub> Burner = 50, Low NO<sub>x</sub> Burners/Flue gas recirculation = 32

**Methodology**

All emission factors are based on normal firing.

MMBtu = 1,000,000 Btu

MMcf = 1,000,000 Cubic Feet of Gas

Emission Factors are from AP 42, Chapter 1.4, Tables 1.4-1, 1.4-2, 1.4-3, SCC #1-02-006-02, 1-01-006-02, 1-03-006-02, and 1-03-006-03

Potential Throughput (MMcf/yr) = Heat Input Capacity (MMBtu/hr) / Heating Value (MMBtu/MMcf) x 8,760 hrs/yr

Potential Emissions (tons/yr) = Throughput (MMcf/yr) x Emission Factor (lb/MMcf) / 2,000 lb/ton

**Hazardous Air Pollutants (HAPs) Calculations**

|                               | HAPs - Organics |                 |              |         |         |                |
|-------------------------------|-----------------|-----------------|--------------|---------|---------|----------------|
|                               | Benzene         | Dichlorobenzene | Formaldehyde | Hexane  | Toluene | Total-Organics |
| Emission Factor in lb/MMcf    | 2.1E-03         | 1.2E-03         | 7.5E-02      | 1.8E+00 | 3.4E-03 |                |
| Potential Emission in tons/yr | 1.5E-03         | 8.8E-04         | 0.06         | 1.32    | 2.5E-03 | <b>1.38</b>    |

|                               | HAPs - Metals |         |          |           |         |
|-------------------------------|---------------|---------|----------|-----------|---------|
|                               | Lead          | Cadmium | Chromium | Manganese | Nickel  |
| Emission Factor in lb/MMcf    | 5.0E-04       | 1.1E-03 | 1.4E-03  | 3.8E-04   | 2.1E-03 |
| Potential Emission in tons/yr | 3.7E-04       | 8.1E-04 | 1.0E-03  | 2.8E-04   | 1.5E-03 |

**Methodology**

Emission Factors from AP-42 Tables in 1.4 (2/98)

The five highest organic and metal HAPs emission factors are provided above.

Additional HAPs emission factors are available in AP-42, Chapter 1.4.

|                   |             |
|-------------------|-------------|
| <b>Total HAPs</b> | <b>1.39</b> |
|-------------------|-------------|

**Greenhouse Gas Calculations**

|                                       | BLR4    |        |      | BLR5    |        |      |
|---------------------------------------|---------|--------|------|---------|--------|------|
|                                       | CO2     | CH4    | N2O  | CO2     | CH4    | N2O  |
| Emission Factor in lb/MMcf            | 120,000 | 2.3    | 2.2  | 120,000 | 2.3    | 2.2  |
| Potential Emission in tons/yr         | 37,843  | 0.73   | 0.69 | 50,458  | 0.97   | 0.93 |
| Summed Potential Emissions in tons/yr |         | 37,845 |      |         | 50,459 |      |
| CO2e Total in tons/yr                 |         | 38,074 |      |         | 50,765 |      |

**Methodology**

The N2O Emission Factor for uncontrolled is 2.2. The N2O Emission Factor for low Nox burner is 0.64.

Emission Factors are from AP 42, Table 1.4-2 SCC #1-02-006-02, 1-01-006-02, 1-03-006-02, and 1-03-006-03.

Global Warming Potentials (GWP) from Table A-1 of 40 CFR Part 98 Subpart A.

Emission (tons/yr) = Throughput (MMCF/yr) x Emission Factor (lb/MMCF)/2,000 lb/ton

CO2e (ton/yr) = CO2 Potential Emission ton/yr x CO2 GWP (1) + CH4 Potential Emission ton/yr x CH4 GWP (21) + N2O Potential Emission ton/yr x N2O GWP (310).

**Appendix A: Emissions Calculations**  
**Natural Gas Combustion Only**  
**MMBtu/hr <100**  
**BLR6**

Company Name: Allison Transmission, Inc. - Main Speedway Campus  
Address City IN Zip: One Allison Way, Indianapolis, IN 46222  
Permit Number: SSM 097-33211-00310 and SPM 097-33236-00310  
Reviewer: Heath Hartley  
Date: 5/16/2013

|                                 |                   |                                 |
|---------------------------------|-------------------|---------------------------------|
| Heat Input Capacity<br>MMBtu/hr | HHV<br>MMBtu/MMcf | Potential Throughput<br>MMcf/yr |
| 99.0                            | 1000              | 867.2                           |

| BLR6                           | Pollutant |                    |                     |                 |                   |      |       |
|--------------------------------|-----------|--------------------|---------------------|-----------------|-------------------|------|-------|
|                                | PM*       | PM <sub>10</sub> * | PM <sub>2.5</sub> * | SO <sub>2</sub> | NO <sub>x</sub>   | VOC  | CO    |
| Emission Factor in lb/MMcf     | 1.9       | 7.6                | 7.6                 | 0.6             | 32<br>**see below | 5.5  | 84    |
| Potential Emissions in tons/yr | 0.82      | 3.30               | 3.30                | 0.26            | 13.88             | 2.38 | 36.42 |

\*PM emission factor is filterable PM only. PM<sub>10</sub> and PM<sub>2.5</sub> emission factors are filterable and condensable PM combined.

\*\*Emission Factors for NO<sub>x</sub>: Uncontrolled = 100, Low NO<sub>x</sub> Burner = 50, Low NO<sub>x</sub> Burners/Flue gas recirculation = 32

**Methodology**

All emission factors are based on normal firing.

MMBtu = 1,000,000 Btu

MMcf = 1,000,000 Cubic Feet of Gas

Emission Factors are from AP 42, Chapter 1.4, Tables 1.4-1, 1.4-2, 1.4-3, SCC #1-02-006-02, 1-01-006-02, 1-03-006-02, and 1-03-006-03

Potential Throughput (MMcf/yr) = Heat Input Capacity (MMBtu/hr) ÷ Heating Value (MMBtu/MMcf) x 8,760 hrs/yr

Potential Emissions (tons/yr) = Throughput (MMcf/yr) x Emission Factor (lb/MMcf) ÷ 2,000 lb/ton

**Hazardous Air Pollutants (HAPs) Calculations**

|                                | HAPs - Organics |                |              |         |         |                |
|--------------------------------|-----------------|----------------|--------------|---------|---------|----------------|
|                                | Benzene         | Dichlorobenzen | Formaldehyde | Hexane  | Toluene | Total-Organics |
| Emission Factor in lb/MMcf     | 2.1E-03         | 1.2E-03        | 7.5E-02      | 1.8E+00 | 3.4E-03 |                |
| Potential Emissions in tons/yr | 9.1E-04         | 5.2E-04        | 0.03         | 0.78    | 1.5E-03 | 0.82           |

|                                | HAPs - Metals |         |          |           |         |
|--------------------------------|---------------|---------|----------|-----------|---------|
|                                | Lead          | Cadmium | Chromium | Manganese | Nickel  |
| Emission Factor in lb/MMcf     | 5.0E-04       | 1.1E-03 | 1.4E-03  | 3.8E-04   | 2.1E-03 |
| Potential Emissions in tons/yr | 2.2E-04       | 4.8E-04 | 6.1E-04  | 1.6E-04   | 9.1E-04 |

Methodology is the same as previous page.

The five highest organic and metal HAPs emission factors are provided above.

Additional HAPs emission factors are available in AP-42, Chapter 1.4.

|                   |             |
|-------------------|-------------|
| <b>Total HAPs</b> | <b>0.82</b> |
|-------------------|-------------|

**Greenhouse Gas Calculations**

|                                       | BLR6            |                 |                  |
|---------------------------------------|-----------------|-----------------|------------------|
|                                       | CO <sub>2</sub> | CH <sub>4</sub> | N <sub>2</sub> O |
| Emission Factor in lb/MMcf            | 120000          | 2.3             | 0.64             |
| Potential Emissions in tons/yr        | 52,034          | 1.00            | 0.28             |
| Summed Potential Emissions in tons/yr | 52,036          |                 |                  |
| CO <sub>2</sub> e Total in tons/yr    | 52,141          |                 |                  |

**Methodology**

The N<sub>2</sub>O Emission Factor for uncontrolled is 2.2. The N<sub>2</sub>O Emission Factor for low NO<sub>x</sub> burner is 0.64.

Emission Factors are from AP 42, Table 1.4-2 SCC #1-02-006-02, 1-01-006-02, 1-03-006-02, and 1-03-006-03.

Greenhouse Warming Potentials (GWP) from Table A-1 of 40 CFR Part 98 Subpart A.

Potential Emissions (tons/yr) = Throughput (MMcf/yr) x Emission Factor (lb/MMcf) ÷ 2,000 lb/ton

CO<sub>2</sub>e (ton/yr) = CO<sub>2</sub> Potential Emission ton/yr x CO<sub>2</sub> GWP (1) + CH<sub>4</sub> Potential Emission ton/yr x CH<sub>4</sub> GWP (21) + N<sub>2</sub>O Potential Emission ton/yr x N<sub>2</sub>O GWP (310)

**Appendix A: Emission Calculations**  
**Large Reciprocating Internal Combustion Engines - Diesel Fuel**  
**Output Rating (>600 HP) Maximum Input Rate (>4.2 MMBtu/hr)**  
**ETC (at maximum horsepower of 4000 hp)**

Company Name: Allison Transmission, Inc. - Main Speedway Campus  
Address City IN Zip: One Allison Way, Indianapolis, IN 46222  
Permit Number: SSM 097-33211-00310 and SPM 097-33236-00310  
Reviewer: Heath Hartley  
Date: 5/16/2013

|                |        |                    |
|----------------|--------|--------------------|
| Emission Unit  | ETC    | Plant 3            |
| Heat Content   | 137000 | Btu/gal (diesel)   |
| Heat Content   | 130000 | Btu/gal (gasoline) |
| Sulfur Content | 0.5    |                    |

| Cell ID Number | Fuel Type          | Output (HP) | Maximum Unit Capacity (MMBtu/hr) | Maximum Unit Capacity (gal/hr) | S/V I.D. |
|----------------|--------------------|-------------|----------------------------------|--------------------------------|----------|
| 701            | Diesel/Gas Turbine | 4000        | 28.0                             | 204.4                          | PTE057   |
| 704            | Diesel             | 2400        | 16.8                             | 122.6                          | PTE065   |
| 705            | Diesel/Gas Turbine | 2400        | 16.8                             | 122.6                          | PTE067   |
| 706S           | Diesel             | 4000        | 28.0                             | 204.4                          | PTE069   |
| 707            | Diesel             | 2400        | 16.8                             | 122.6                          | PTE071   |
| 709            | Diesel             | 2400        | 16.8                             | 122.6                          | PTE075   |
| 710            | Diesel             | 1500        | 10.5                             | 76.6                           | PTE077   |
| 711            | Diesel             | 2400        | 16.8                             | 122.6                          | PTE079   |
| 712            | Diesel             | 1500        | 10.5                             | 76.6                           | PTE080   |
| 32N            | Diesel             | 2400        | 16.8                             | 122.6                          | PTE008   |
| 32S            | Diesel             | 1500        | 10.5                             | 76.6                           | PTE006   |
| 38N            | Diesel             | 4000        | 28.0                             | 204.4                          | PTE011   |
| 39N            | Diesel             | 2400        | 16.8                             | 122.6                          | PTE018   |
| 39S            | Diesel             | 1500        | 10.5                             | 76.6                           | PTE020   |
| 40N            | Diesel             | 1500        | 10.5                             | 76.6                           | PTE013   |
| 40S            | Diesel             | 1500        | 10.5                             | 76.6                           | PTE014   |
| 41N            | Diesel             | 1200        | 8.4                              | 61.3                           | PTE023   |
| 41S            | Diesel             | 1200        | 8.4                              | 61.3                           | PTE021   |
| 48N            | Diesel             | 1200        | 8.4                              | 61.3                           | PTE040   |
| 48S            | Diesel             | 1200        | 8.4                              | 61.3                           | PTE041   |
| 49N            | Diesel             | 1500        | 10.5                             | 76.6                           | PTE086   |
| 49S            | Diesel             | 1500        | 10.5                             | 76.6                           | PTE087   |
| 50             | Diesel             | 2400        | 16.8                             | 122.6                          | PTE093   |
| 51N            | Diesel             | 1200        | 8.4                              | 61.3                           | PTE084   |
| 51S            | Gasoline or Diesel | 700         | 4.9                              | 35.8                           | PTE082   |
| <b>Totals</b>  |                    |             | <b>349.3</b>                     | <b>2549.64</b>                 |          |

**Green House Gas Emissions (GHG)**

|                               | Pollutant |          |          |
|-------------------------------|-----------|----------|----------|
|                               | CO2       | CH4      | N2O      |
| Emission Factor in lb/MMBtu   | 1.65E+02  | 8.10E-03 | 1.32E-03 |
| Potential Emission in tons/yr | 252,439   | 12.39    | 2.02     |

|  |                |
|--|----------------|
| <b>Summed Potential Emissions in tons/yr</b> | <b>252,454</b> |
| <b>CO2e Total in tons/yr</b>                 | <b>253,327</b> |

Potential Throughput (MMBtu/yr) = [Heat Input Capacity (MMBtu/hr)] \* [Maximum Hours Operated per Year]

Potential Emission (tons/yr) = [Potential Throughput (MMBtu/yr)] \* [Emission Factor (lb/MMBtu)] / [2,000 lb/ton]

CO2e (tons/yr) = CO2 Potential Emission ton/yr x CO2 GWP (1) + CH4 Potential Emission ton/yr x CH4 GWP (21) + N2O Potential Emission ton/yr x N2O GWP (310).

**Appendix A: Emission Calculations**  
**Large Reciprocating Internal Combustion Engines - Diesel Fuel**  
**Output Rating (>600 HP) Maximum Input Rate (>4.2 MMBtu/hr)**  
**ETC (at maximum horsepower of 4000 hp)**

Company Name: Allison Transmission, Inc. - Main Speedway Campus  
Address City IN Zip: One Allison Way, Indianapolis, IN 46222  
Permit Number: SSM 097-33211-00310 and SPM 097-33236-00310  
Reviewer: Heath Hartley  
Date: 5/16/2013

| POTENTIAL EMISSIONS - MAX HP CONFIGURATION |               |               |              |              |             |             |               |               |               |               |             |
|--|---------------|---------------|--------------|--------------|-------------|-------------|---------------|---------------|---------------|---------------|-------------|
| Pollutant                                  | NOx           | CO            | SOx          | PM           | PM-10       | PM-2.5      | TOC           | Combined HAP  | Formaldehyde  | Benzene       |             |
| Factor (Diesel)                            | 3.2           | 0.85          | 0.505        | 0.1          | 0.0573      | 0.0556      | 0.09          | 1.57E-03      | 7.89E-05      | 7.76E-04      |             |
| Factor (Gasoline)                          | 1.63          | 0.99          | 0.084        | 0.1          | 0.1         | 0.1         | 3.03          | Not Available | Not Available | Not Available |             |
| Factor (Diesel Turbine)                    | 0.88          | 0.0033        | 0.505        | 0.0043       | 0.0072      | 0.0072      | 0.00041       | 1.29E-03      | 2.80E-04      | 5.50E-05      |             |
| Units                                      | lbs/MMBtu     | lbs/MMBtu     | lbs/MMBtu    | lbs/MMBtu    | lbs/MMBtu   | lbs/MMBtu   | lbs/MMBtu     | lbs/MMBtu     | lbs/MMBtu     | lbs/MMBtu     |             |
|  | 0.438 lb/gal  | 0.116 lb/gal  |              |              |             |             | 0.0137 lb/gal |               |               |               |             |
| Cell No.                                   | NOx           | CO            | SOx          | PM           | PM-10       | PM-2.5      | TOC           | Combined HAP  | Formaldehyde  | Benzene       | limited SO2 |
| 701  | 392.4         | 104.2         | 61.9         | 12.3         | 7.0         | 6.8         | 11.0          | 0.19          | 0.010         | 0.095         | 61.3        |
| 704  | 235.5         | 62.5          | 37.2         | 7.4          | 4.2         | 4.1         | 6.6           | 0.12          | 0.006         | 0.057         | 36.8        |
| 705  | 235.5         | 62.5          | 37.2         | 7.4          | 4.2         | 4.1         | 6.6           | 0.12          | 0.006         | 0.057         | 36.8        |
| 706S                                       | 392.4         | 104.2         | 61.9         | 12.3         | 7.0         | 6.8         | 11.0          | 0.19          | 0.010         | 0.095         | 61.3        |
| 707  | 235.5         | 62.5          | 37.2         | 7.4          | 4.2         | 4.1         | 6.6           | 0.12          | 0.006         | 0.057         | 36.8        |
| 709  | 235.5         | 62.5          | 37.2         | 7.4          | 4.2         | 4.1         | 6.6           | 0.12          | 0.006         | 0.057         | 36.8        |
| 710  | 147.2         | 39.1          | 23.2         | 4.6          | 2.6         | 2.6         | 4.1           | 0.07          | 0.004         | 0.036         |             |
| 711  | 235.5         | 62.5          | 37.2         | 7.4          | 4.2         | 4.1         | 6.6           | 0.12          | 0.006         | 0.057         | 36.8        |
| 712  | 147.2         | 39.1          | 23.2         | 4.6          | 2.6         | 2.6         | 4.1           | 0.07          | 0.004         | 0.036         |             |
| 32N  | 235.5         | 62.5          | 37.2         | 7.4          | 4.2         | 4.1         | 6.6           | 0.12          | 0.006         | 0.057         | 36.8        |
| 32S  | 147.2         | 39.1          | 23.2         | 4.6          | 2.6         | 2.6         | 4.1           | 0.07          | 0.004         | 0.036         |             |
| 38N  | 392.4         | 104.2         | 61.9         | 12.3         | 7.0         | 6.8         | 11.0          | 0.19          | 0.010         | 0.095         | 61.3        |
| 39N  | 235.5         | 62.5          | 37.2         | 7.4          | 4.2         | 4.1         | 6.6           | 0.12          | 0.006         | 0.057         | 6.3         |
| 39S  | 147.2         | 39.1          | 23.2         | 4.6          | 2.6         | 2.6         | 4.1           | 0.07          | 0.004         | 0.036         |             |
| 40N  | 147.2         | 39.1          | 23.2         | 4.6          | 2.6         | 2.6         | 4.1           | 0.07          | 0.004         | 0.036         |             |
| 40S  | 147.2         | 39.1          | 23.2         | 4.6          | 2.6         | 2.6         | 4.1           | 0.07          | 0.004         | 0.036         |             |
| 41N  | 117.7         | 31.3          | 18.6         | 3.7          | 2.1         | 2.0         | 3.3           | 0.06          | 0.003         | 0.029         |             |
| 41S  | 117.7         | 31.3          | 18.6         | 3.7          | 2.1         | 2.0         | 3.3           | 0.06          | 0.003         | 0.029         |             |
| 48N  | 117.7         | 31.3          | 18.6         | 3.7          | 2.1         | 2.0         | 3.3           | 0.06          | 0.003         | 0.029         |             |
| 48S  | 117.7         | 31.3          | 18.6         | 3.7          | 2.1         | 2.0         | 3.3           | 0.06          | 0.003         | 0.029         |             |
| 49N  | 147.2         | 39.1          | 23.2         | 4.6          | 2.6         | 2.6         | 4.1           | 0.07          | 0.004         | 0.036         |             |
| 49S  | 147.2         | 39.1          | 23.2         | 4.6          | 2.6         | 2.6         | 4.1           | 0.07          | 0.004         | 0.036         |             |
| 50   | 235.5         | 62.5          | 37.2         | 7.4          | 4.2         | 4.1         | 6.6           | 0.12          | 0.006         | 0.057         | 36.8        |
| 51N  | 117.7         | 31.3          | 18.6         | 3.7          | 2.1         | 2.0         | 3.3           | 0.06          | 0.003         | 0.029         |             |
| 51S  | 68.7          | 18.2          | 10.8         | 2.1          | 1.2         | 1.2         | 1.9           | 0.03          | 0.002         | 0.017         |             |
| 51S (gasoline)                             | 35.0          | 21.2          | 1.8          | 2.1          | 2.1         | 2.1         | 65.0          | 0.0           | 0.000         | 0.000         |             |
| 701&705 (turbines)                         | 107.9         | 0.4           | 61.9         | 0.5          | 0.9         | 0.9         | 0.1           | 0.2           | 0.034         | 0.007         |             |
| <b>Total</b>                               | <b>4895.8</b> | <b>1303.4</b> | <b>772.6</b> | <b>153.0</b> | <b>88.6</b> | <b>86.0</b> | <b>200.8</b>  | <b>2.41</b>   | <b>0.12</b>   | <b>1.19</b>   |             |
| PTE w/39N limited                          | 4700.3        | 1251.5        | 737.4        | 146.9        | 85.1        | 82.6        | 195.3         | 2.31          | 0.12          | 1.14          |             |
| 39N Limited                                | < 40          | 10.6          | 6.31         | 1.25         | 0.72        | 0.69        | 1.12          | 0.02          | 0.00          | 0.01          |             |

**APPLICABLE EMISSIONS LIMITATIONS**

| Pollutant          | Test Cell                   | Regulation       | Limit   |
|--------------------|-----------------------------|------------------|---|
| PM                 | All Cells                   | 326 IAC 6-1-2(a) | 0.03 gr/dscf  |
| SO2                | <b>All Cells in Italics</b> | 326 IAC 7-1.1-2  | 0.5 lbs/MMBtu or 0.5% Sulfur (Test Cell 39N fuel use limits restrict SO2 < 25tpy) |
| NOx                | 39N                         | 326 IAC 2-2      | <40 tpy such that 326 IAC 2-2 will not apply                                      |
| Limited Throughput |                             | 326 IAC 2-2      | 182,481 gal/yr  |

**Methodology**

Emission Factors for Diesel Engines greater than 600 HP, (AP-42 Section 3.4 (10/96)); NOx emission factor (uncontrolled) = 3.2 lb/MMBtu

Emission Factors for Gasoline Engines from AP-42 Table 3.3-1 (10/96). CO EF corrected 3/24/09.

Emission Factors for Diesel Turbines from AP-42 Table 3.1 (4/00).

PTE (ton/yr) = Max Capacity (MMBtu/hr) x Emission Factor (lb/MMBtu) x 8760 hr/yr x 1 ton / 2000 lb

Limited Emissions (ton/yr) = Limited Throughput (gal/yr) x Emission Factor (lb/MMBtu) x Heat Content (MMBtu/gal) x 1 ton/2000 lb

**Appendix A: Emission Calculations**  
**Reciprocating Internal Combustion Engines - Diesel Fuel**  
**Output Rating (600 HP and less) Maximum Input Rate (4.2 MMBtu/hr and less)**  
**ETC (at 600 hp)**

Company Name: Allison Transmission, Inc. - Main Speedway Campus  
Address City IN Zip: One Allison Way, Indianapolis, IN 46222  
Permit Number: SSM 097-33211-00310 and SPM 097-33236-00310  
Reviewer: Heath Hartley  
Date: 5/16/2013

|                |        |                    |
|----------------|--------|--------------------|
| Emission Unit  | ETC    | Plant 3            |
| Heat Content   | 137000 | Btu/gal (diesel)   |
| Heat Content   | 130000 | Btu/gal (gasoline) |
| Sulfur Content | 0.5    |                    |

| Cell ID Number | Fuel Type          | Output (HP) | Maximum Unit Capacity (MMBtu/hr) | Maximum Unit Capacity (gal/hr) | S/V I.D. |
|----------------|--------------------|-------------|----------------------------------|--------------------------------|----------|
| 701            | Diesel/Gas Turbine | 600         | 4.2                              | 30.7                           | PTE057   |
| 704            | Diesel             | 600         | 4.2                              | 30.7                           | PTE065   |
| 705            | Diesel/Gas Turbine | 600         | 4.2                              | 30.7                           | PTE067   |
| 706S           | Diesel             | 600         | 4.2                              | 30.7                           | PTE069   |
| 707            | Diesel             | 600         | 4.2                              | 30.7                           | PTE071   |
| 709            | Diesel             | 600         | 4.2                              | 30.7                           | PTE075   |
| 710            | Diesel             | 600         | 4.2                              | 30.7                           | PTE077   |
| 711            | Diesel             | 600         | 4.2                              | 30.7                           | PTE079   |
| 712            | Diesel             | 600         | 4.2                              | 30.7                           | PTE080   |
| 32N            | Diesel             | 600         | 4.2                              | 30.7                           | PTE008   |
| 32S            | Diesel             | 600         | 4.2                              | 30.7                           | PTE006   |
| 38N            | Diesel             | 600         | 4.2                              | 30.7                           | PTE011   |
| 39N            | Diesel             | 600         | 4.2                              | 30.7                           | PTE018   |
| 39S            | Diesel             | 600         | 4.2                              | 30.7                           | PTE020   |
| 40N            | Diesel             | 600         | 4.2                              | 30.7                           | PTE013   |
| 40S            | Diesel             | 600         | 4.2                              | 30.7                           | PTE014   |
| 41N            | Diesel             | 600         | 4.2                              | 30.7                           | PTE023   |
| 41S            | Diesel             | 600         | 4.2                              | 30.7                           | PTE021   |
| 48N            | Diesel             | 600         | 4.2                              | 30.7                           | PTE040   |
| 48S            | Diesel             | 600         | 4.2                              | 30.7                           | PTE041   |
| 49N            | Diesel             | 600         | 4.2                              | 30.7                           | PTE086   |
| 49S            | Diesel             | 600         | 4.2                              | 30.7                           | PTE087   |
| 50             | Diesel             | 600         | 4.2                              | 30.7                           | PTE093   |
| 51N            | Diesel             | 600         | 4.2                              | 30.7                           | PTE084   |
| 51S            | Gasoline or Diesel | 600         | 4.2                              | 30.7                           | PTE082   |
| <b>Totals</b>  |                    |             | <b>105.0</b>                     | <b>766.42</b>                  |          |

**Green House Gas Emissions (GHG)**

|                               | Pollutant |          |          |
|-------------------------------|-----------|----------|----------|
|                               | CO2       | CH4      | N2O      |
| Emission Factor in lb/MMBtu   | 1.64E+02  | 6.61E-03 | 1.32E-03 |
| Potential Emission in tons/yr | 75,424    | 3.04     | 0.61     |

|  |               |
|--|---------------|
| <b>Summed Potential Emissions in tons/yr</b> | <b>75,427</b> |
| <b>CO2e Total in tons/yr</b>                 | <b>75,676</b> |

Potential Throughput (MMBtu/yr) = [Heat Input Capacity (MMBtu/hr)] \* [Maximum Hours Operated per Year]

Potential Emission (tons/yr) = [Potential Throughput (MMBtu/yr)] \* [Emission Factor (lb/MMBtu)] / [2,000 lb/ton]

CO2e (tons/yr) = CO2 Potential Emission ton/yr x CO2 GWP (1) + CH4 Potential Emission ton/yr x CH4 GWP (21) + N2O Potential Emission ton/yr x N2O GWP (310).

**Appendix A: Emission Calculations**  
**Reciprocating Internal Combustion Engines - Diesel Fuel**  
**Output Rating (600 HP and less) Maximum Input Rate (4.2 MMBtu/hr and less)**  
**ETC (at 600 hp)**

Company Name: Allison Transmission, Inc. - Main Speedway Campus  
Address City IN Zip: One Allison Way, Indianapolis, IN 46222  
Permit Number: SSM 097-33211-00310 and SPM 097-33236-00310  
Reviewer: Heath Hartley  
Date: 5/16/2013

**POTENTIAL EMISSIONS - MAX HP CONFIGURATION**

| Pollutant               | NOx           | CO           | SOx          | PM           | PM-10        | PM-2.5       | TOC           | Combined HAP  | Formaldehyde  | Benzene       |             |
|-------------------------|---------------|--------------|--------------|--------------|--------------|--------------|---------------|---------------|---------------|---------------|-------------|
| Factor (Diesel)         | 4.41          | 0.95         | 0.29         | 0.31         | 0.31         | 0.31         | 0.36          | 3.87E-03      | 1.18E-03      | 9.33E-04      |             |
| Factor (Gasoline)       | 1.63          | 0.99         | 0.084        | 0.1          | 0.1          | 0.1          | 3.03          | Not Available | Not Available | Not Available |             |
| Factor (Diesel Turbine) | 0.88          | 0.0033       | 0.505        | 0.0043       | 0.0072       | 0.0072       | 0.00041       | 1.29E-03      | 2.80E-04      | 5.50E-05      |             |
| Units                   | lbs/MMBtu     | lbs/MMBtu    | lbs/MMBtu    | lbs/MMBtu    | lbs/MMBtu    | lbs/MMBtu    | lbs/MMBtu     | lbs/MMBtu     | lbs/MMBtu     | lbs/MMBtu     |             |
|                         | 0.438 lb/gal  | 0.116 lb/gal |              |              |              |              | 0.0137 lb/gal |               |               |               |             |
| Cell No.                | NOx           | CO           | SOx          | PM           | PM-10        | PM-2.5       | TOC           | Combined HAP  | Formaldehyde  | Benzene       | limited SO2 |
| 701                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         | 9.2         |
| 704                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         | 9.2         |
| 705                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         | 9.2         |
| 706S                    | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         | 9.2         |
| 707                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         | 9.2         |
| 709                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         | 9.2         |
| 710                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         |             |
| 711                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         | 9.2         |
| 712                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         |             |
| 32N                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         | 9.2         |
| 32S                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         |             |
| 38N                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         | 9.2         |
| 39N                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         | 2.6         |
| 39S                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         |             |
| 40N                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         |             |
| 40S                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         |             |
| 41N                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         |             |
| 41S                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         |             |
| 48N                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         |             |
| 48S                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         |             |
| 49N                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         |             |
| 49S                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         |             |
| 50                      | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         | 9.2         |
| 51N                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         |             |
| 51S                     | 81.1          | 17.5         | 5.3          | 5.7          | 5.7          | 5.7          | 6.6           | 0.07          | 0.022         | 0.017         |             |
| 51S (gasoline)          | 30.0          | 18.2         | 1.5          | 1.8          | 1.8          | 1.8          | 55.7          | 0.0           | 0.000         | 0.000         |             |
| 701&705 (turbines)      | 16.2          | 0.1          | 9.3          | 0.1          | 0.1          | 0.1          | 0.0           | 0.0           | 0.005         | 0.001         |             |
| <b>Total</b>            | <b>2028.2</b> | <b>437.6</b> | <b>133.4</b> | <b>142.6</b> | <b>138.7</b> | <b>138.7</b> | <b>214.7</b>  | <b>1.78</b>   | <b>0.54</b>   | <b>0.43</b>   |             |
| PTE w/39N limited       | 1987.0        | 428.8        | 169.3        | 135.8        | 135.8        | 135.8        | 211.3         | 1.75          | 0.53          | 0.42          |             |
| 39N Limited             | < 40          | 11.9         | 2.6          | 3.9          | 3.9          | 3.9          | 4.5           | 0.05          | 0.01          | 0.01          |             |

**APPLICABLE EMISSIONS LIMITATIONS**

| Pollutant          | Test Cell                   | Regulation       | Limit   |
|--------------------|-----------------------------|------------------|---|
| PM                 | All Cells                   | 326 IAC 6-1-2(a) | 0.03 gr/dscf  |
| SO2                | <b>All Cells in Italics</b> | 326 IAC 7-1.1-2  | 0.5 lbs/MMBtu or 0.5% Sulfur (Test Cell 39N fuel use limits restrict SO2 < 25tpy) |
| NOx                | 39N                         | 326 IAC 2-2      | <40 tpy such that 326 IAC 2-2 will not apply                                      |
| Limited Throughput |                             | 326 IAC 2-2      | 182,481 gal/yr  |

**Methodology**

Emission Factors for Diesel Engines 600 HP and less, (AP-42 Section 3.3 (10/96))

Emission Factors for Gasoline Engines from AP-42 Table 3.3-1 (10/96). CO EF corrected 3/24/09.

Emission Factors for Diesel Turbines from AP-42 Table 3.1 (4/00).

PTE (ton/yr) = Max Capacity (MMBtu/hr) x Emission Factor (lb/MMBtu) x 8760 hr/yr x 1 ton / 2000 lb

Limited Emissions (ton/yr) = Limited Throughput (gal/yr) x Emission Factor (lb/MMBtu) x Heat Content (MMBtu/gal) x 1 ton/2000 lb

**Appendix A: Emission Calculations**  
**Reciprocating Internal Combustion Engines - Diesel Fuel**  
**DTC**

Company Name: Allison Transmission, Inc. - Main Speedway Campus  
Address City IN Zip: One Allison Way, Indianapolis, IN 46222  
Permit Number: SSM 097-33211-00310 and SPM 097-33236-00310  
Reviewer: Heath Hartley  
Date: 5/16/2013

Engines tested in the DTC test cells may vary in size (from less than 600 hp to a maximum of 1500 hp). Therefore, potential to emit calculations were performed using the worst case AP42 emission factors diesel engines 600 HP and less (AP-42 Section 3.3 (10/96)) were used.

|                |                |
|----------------|----------------|
| Emission Unit  | DTC            |
| Plant          | 3              |
| Heat Content   | 137000 Btu/gal |
| Sulfur Content | 0.5            |

| EMISSION UNIT DESCRIPTION |              |             |                                |                                  |              |          |                |
|---------------------------|--------------|-------------|--------------------------------|----------------------------------|--------------|----------|----------------|
| Cell ID Number            | Model Number | Output (HP) | Maximum Unit Capacity (gal/hr) | Maximum Unit Capacity (MMBtu/hr) | Type of Fuel | S/V I.D. | Date Installed |
| TC-107                    | DT446C       | 1500        | 15                             | 10.50                            | Diesel       | PTE045   | 1985           |
| TC-109                    | 6V-53T       | 1500        | 12                             | 10.50                            | Diesel       | PTE043   | 1985           |
| TC-111                    | DT466        | 1500        | 15                             | 10.50                            | Diesel       | PTE049   | 1985           |
| TC-112                    | N-14E        | 1500        | 24                             | 10.50                            | Diesel       | PTE050   | 1985           |
| <b>Total</b>              |              |             |                                | <b>42.00</b>                     |              |          |                |

| POTENTIAL EMISSIONS |              |              |              |              |                          |              |               |              |              |             |
|---------------------|--------------|--------------|--------------|--------------|--------------------------|--------------|---------------|--------------|--------------|-------------|
| Pollutant           | PM           | PM-10        | PM-2.5       | SOx          | NOx                      | TOC          | CO            | Combined HAP | Formaldehyde | Benzene     |
| Factor (Diesel)     | 0.31         | 0.31         | 0.31         | 0.29         | 4.41                     | 0.36         | 0.95          | 3.87E-03     | 1.18E-03     | 9.33E-04    |
| Units               | lbs/MMBtu    | lbs/MMBtu    | lbs/MMBtu    | lbs/MMBtu    | lbs/MMBtu (604.2 #/kgal) | lbs/MMBtu    | lbs/MMBtu     | lbs/MMBtu    | lbs/MMBtu    | lbs/MMBtu   |
| Cell No.            | PM           | PM-10        | PM-2.5       | SOx          | NOx                      | TOC          | CO            | Combined HAP | Formaldehyde | Benzene     |
| TC-107              | 14.26        | 14.26        | 14.26        | 13.34        | 202.82                   | 16.56        | 43.69         | 0.18         | 0.054        | 0.04        |
| TC-109              | 14.26        | 14.26        | 14.26        | 13.34        | 202.82                   | 16.56        | 43.69         | 0.18         | 0.054        | 0.04        |
| TC-111              | 14.26        | 14.26        | 14.26        | 13.34        | 202.82                   | 16.56        | 43.69         | 0.18         | 0.054        | 0.04        |
| TC-112              | 14.26        | 14.26        | 14.26        | 13.34        | 202.82                   | 16.56        | 43.69         | 0.18         | 0.054        | 0.04        |
| <b>Total</b>        | <b>57.03</b> | <b>57.03</b> | <b>57.03</b> | <b>53.35</b> | <b>811.26</b>            | <b>66.23</b> | <b>174.76</b> | <b>0.71</b>  | <b>0.217</b> | <b>0.17</b> |

Emission Factors for Diesel Engines 600 HP and less, (AP-42 Section 3.3 (10/96))

PTE (ton/yr) = Max Capacity (MMBtu/hr) x Emission Factor (lb/MMBtu) x 8760 hr/yr x 1 ton / 2000 lb

| APPLICABLE EMISSIONS LIMITATIONS |           |                               |              |
|----------------------------------|-----------|-------------------------------|--------------|
| Pollutant                        | Test Cell | Regulation                    | Limit        |
| PM                               | All Cells | 326 IAC 6-1-2(a)              | 0.03 gr/dscf |
| SO2                              | All Cells | none because SO2 PTE < 25 tpy |              |
| NOx                              | All Cells | 326 IAC 2-2                   | < 40 tons/yr |

**Test cells TC-107,109,111, and 112**

Limitation required to make 326 IAC 2-2 (PSD) not applicable:

(39.9 tons x 2000 lbs/ton)/(4.41 lbs/MMBtu x 0.137 MMBtu/gal) = 132,400.00 Gal./12 month

or

(39.9 tons x 2000 lbs/ton) / (0.031 lbs/Hp-Hr) = 2,580,645 Hp-Hr

4.41 lbs/MMBtu x 0.137 MMBtu/gal x 1000 gal = 604.2 lbs NOx/1000 gal

| Total Emissions @ limited throughput |      |       |        |      |       |          |      |              |              |         |
|--------------------------------------|------|-------|--------|------|-------|----------|------|--------------|--------------|---------|
| Pollutant                            | PM   | PM-10 | PM-2.5 | SOx  | NOx   | TOC (NM) | CO   | Combined HAP | Formaldehyde | Benzene |
| Total                                | 2.81 | 2.81  | 2.81   | 2.63 | 39.90 | 3.26     | 8.62 | 0.04         | 0.011        | 0.008   |

Limited Emissions (ton/yr) = Limited Throughput (gal/yr) x Emission Factor (lb/MMBtu) x Heat Content (MMBtu/gal) x 1 ton/2000 lb

| Test Cell    | Air Flow Rate (cfm) | Equivalent PM (lb/hr) |
|--------------|---------------------|-----------------------|
| TC-107       | 1193                | 0.31                  |
| TC-109       | 4543                | 1.17                  |
| TC-111       | 4360                | 1.12                  |
| TC-112       | 7047                | 1.81                  |
| <b>Total</b> | <b>4.41</b>         | <b>19.3</b>           |

where equivalent PM pound per hour emission rate = 0.03 gr/dscf x ft<sup>3</sup>/min x 60 min/hr x pound/7000 grains

**Green House Gas Emissions (GHG)**

|                               | Pollutant |          |          |
|-------------------------------|-----------|----------|----------|
|                               | CO2       | CH4      | N2O      |
| Emission Factor in lb/MMBtu   | 1.65E+02  | 8.10E-03 | 1.32E-03 |
| Potential Emission in tons/yr | 30,353    | 1.49     | 0.24     |

|  |               |
|--|---------------|
| <b>Summed Potential Emissions in tons/yr</b> | <b>30,355</b> |
| <b>CO2e Total in tons/yr</b>                 | <b>30,460</b> |

Potential Throughput (MMBtu/yr) = [Heat Input Capacity (MMBtu/hr)] \* [Maximum Hours Operated per Year]

Potential Emission (tons/yr) = [Potential Throughput (MMBtu/yr)] \* [Emission Factor (lb/MMBtu)] / [2,000 lb/ton]

CO2e (tons/yr) = CO2 Potential Emission ton/yr x CO2 GWP (1) + CH4 Potential Emission ton/yr x CH4 GWP (21) + N2O

Potential Emission ton/yr x N2O GWP (310).





**Appendix A: Emission Calculations**  
**Internal Combustion Engines - Diesel Fuel**  
**Diesel Fired Reciprocating Engine (>600 HP)**  
**Emission Unit ID ETC 702**

Company Name: Allison Transmission, Inc. - Main Speedway Campus  
Address City IN Zip: One Allison Way, Indianapolis, IN 46222  
Permit Number: SSM 097-33211-00310 and SPM 097-33236-00310  
Reviewer: Heath Hartley  
Date: 5/16/2013

**A. Emissions calculated based on heat input capacity (MMBtu/hr)**

|                          |                                |                     |
|--------------------------|--------------------------------|---------------------|
| Heat Input Capacity (hp) | Heat Input Capacity (MMBtu/hr) | Weight % Sulfur (S) |
| 4000                     | 28                             | 0.5                 |

|                               | Pollutant |        |        |                  |                    |      |       |              |          |
|-------------------------------|-----------|--------|--------|------------------|--------------------|------|-------|--------------|----------|
|                               | PM        | PM10   | PM2.5  | SO <sub>2</sub>  | NO <sub>x</sub>    | VOC  | CO    | Combined HAP | Benzene  |
| Emission Factor in lb/MMBtu   | 0.1       | 0.0573 | 0.0556 | 0.505<br>(1.01S) | 3.2<br>**see below | 0.09 | 0.85  | 1.57E-03     | 7.76E-04 |
| Potential Emission in tons/yr | 12.26     | 7.03   | 6.82   | 61.9             | 392.4              | 11.0 | 104.2 | 0.19         | 0.10     |

\*\*NO<sub>x</sub> emissions: uncontrolled = 3.2 lb/MMBtu, controlled with ignition timing retard = 1.9 lb/MMBtu  
Emfacs from AP-42 Tables 3.4-1 & 3.4-2 (10/96)

**B. Emissions calculated based on conversion of AP-42 emfac to lbs/1000 gal**

|                                |                               |                      |                     |
|--------------------------------|-------------------------------|----------------------|---------------------|
| Heat Input Capacity (MMBtu/hr) | Potential Throughput (gal/yr) | Heat Input (Btu/gal) | Weight % Sulfur (S) |
| 28                             | 1790365                       | 137000               | 0.5                 |

|                                | Pollutant |      |       |                 |                 |      |       |              |         |
|--------------------------------|-----------|------|-------|-----------------|-----------------|------|-------|--------------|---------|
|                                | PM        | PM10 | PM2.5 | SO <sub>2</sub> | NO <sub>x</sub> | VOC  | CO    | Combined HAP | Benzene |
| Emission Factor in lb/1000 gal | 13.70     | 7.85 | 7.62  | 69.2            | 438.4           | 12.3 | 116.5 | 0.22         | 0.11    |
| Potential Emission in tons/yr  | 12.26     | 7.03 | 6.82  | 61.9            | 392.4           | 11.0 | 104.2 | 0.19         | 0.10    |

**C. Emissions calculated based on limiting fuel throughput**

Limited fuel throughput **173516** gallons/year

|                                | Pollutant |      |       |                 |                 |      |       |              |         |
|--------------------------------|-----------|------|-------|-----------------|-----------------|------|-------|--------------|---------|
|                                | PM        | PM10 | PM2.5 | SO <sub>2</sub> | NO <sub>x</sub> | VOC  | CO    | Combined HAP | Benzene |
| Emission Factor in lb/1000 gal | 13.7      | 7.9  | 7.6   | 69.2            | 438.4           | 12.3 | 116.5 | 0.22         | 0.11    |
| Limited Emissions in tons/yr   | 1.19      | 0.68 | 0.66  | 6.00            | 38.03           | 1.07 | 10.10 | 0.02         | 0.01    |

**Methodology**

Potential Throughput: (Heat input capacity (MMBtu/hr) / heat input content (Btu/gal)) x 8760

Emission Factors are from AP 42 (Supplement B 10/96) Table 3.4-1 and Table 3.4-2

Emission (tons/yr) = [Heat input rate (MMBtu/hr) x Emission Factor (lb/MMBtu)] \* 8760 hr/yr / (2,000 lb/ton)

| Test Cell | Air Flow Rate (cfm) | Equivalent PM (lb/hr) | Equivalent PM (tons/yr) |
|-----------|---------------------|-----------------------|-------------------------|
| ETC702    | 1100                | 0.3                   | 1.2                     |

where equivalent PM pound per hour emission rate = 0.03 gr/dscf x ft<sup>3</sup>/min x 60 min/hr x pound/7000 grains

**Green House Gas Emissions (GHG)**

|                               | Pollutant       |                 |                  |
|-------------------------------|-----------------|-----------------|------------------|
|                               | CO <sub>2</sub> | CH <sub>4</sub> | N <sub>2</sub> O |
| Emission Factor in lb/MMBtu   | 1.65E+02        | 8.10E-03        | 1.32E-03         |
| Potential Emission in tons/yr | 20,236          | 0.99            | 0.16             |

|  |               |
|--|---------------|
| <b>Summed Potential Emissions in tons/yr</b> | <b>20,237</b> |
| <b>CO<sub>2</sub>e Total in tons/yr</b>      | <b>20,307</b> |

Potential Throughput (MMBtu/yr) = [Heat Input Capacity (MMBtu/hr)] \* [Maximum Hours Operated per Year]

Potential Emission (tons/yr) = [Potential Throughput (MMBtu/yr)] \* [Emission Factor (lb/MMBtu)] / [2,000 lb/ton]

CO<sub>2</sub>e (tons/yr) = CO<sub>2</sub> Potential Emission ton/yr x CO<sub>2</sub> GWP (1) + CH<sub>4</sub> Potential Emission ton/yr x CH<sub>4</sub> GWP (21) + N<sub>2</sub>O Potential Emission ton/yr x N<sub>2</sub>O GWP (310).

**Appendix A: Emissions Calculations**  
**Degreaser CSD-1**

Company Name: Allison Transmission, Inc. - Main Speedway Campus  
 Address City IN Zip: One Allison Way, Indianapolis, IN 46222  
 Permit Number: SSM 097-33211-00310 and SPM 097-33236-00310  
 Reviewer: Heath Hartley  
 Date: 5/16/2013

The solvent used in the degreaser has a density of 6.59 lb/gal that has been conservatively assumed to contain 100% VOC.

In order to claim the degreaser as an insignificant activity under the listing in 326 IAC 2-7-1(21)(J)(vi)(DD), the source shall use solvents "the use of which, for all cleaners and solvents combined, does not exceed one hundred forty-five (145) gallons per twelve (12) months".

**Uncontrolled Potential Emissions**

6.59 lb/gal x 100 % VOC x 145 gal/yr ÷ 2000 lb/ton = 0.48 tons VOC per year



## INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

100 N. Senate Avenue • Indianapolis, IN 46204  
(800) 451-6027 • (317) 232-8603 • [www.idem.IN.gov](http://www.idem.IN.gov)

**Michael R. Pence**  
*Governor*

**Thomas W. Easterly**  
*Commissioner*

### SENT VIA U.S. MAIL: CONFIRMED DELIVERY AND SIGNATURE REQUESTED

TO: Matthew Littell  
Allison Transmission, Inc. - Speedway Main Campus  
1 Allison Way  
Indianapolis, IN 46222-3271

DATE: August 22, 2013

FROM: Matt Stuckey, Branch Chief  
Permits Branch  
Office of Air Quality

SUBJECT: Final Decision  
Title V - Significant Permit Modification  
097 - 33236 - 00310

Enclosed is the final decision and supporting materials for the air permit application referenced above. Please note that this packet contains the original, signed, permit documents.

The final decision is being sent to you because our records indicate that you are the contact person for this application. However, if you are not the appropriate person within your company to receive this document, please forward it to the correct person.

A copy of the final decision and supporting materials has also been sent via standard mail to:  
David Parish, VP - Ops  
OAQ Permits Branch Interested Parties List

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178, or toll-free at 1-800-451-6027 (ext. 3-0178), and ask to speak to the permit reviewer who prepared the permit. If you think you have received this document in error, please contact Joanne Smiddie-Brush of my staff at 1-800-451-6027 (ext 3-0185), or via e-mail at [jbrush@idem.IN.gov](mailto:jbrush@idem.IN.gov).

Final Applicant Cover letter.dot 6/13/2013



## INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

100 N. Senate Avenue • Indianapolis, IN 46204  
(800) 451-6027 • (317) 232-8603 • [www.idem.IN.gov](http://www.idem.IN.gov)

Michael R. Pence  
Governor

Thomas W. Easterly  
Commissioner

August 22, 2013

TO: Speedway Public Library 5633 W 25th St Speedway IN

From: Matthew Stuckey, Branch Chief  
Permits Branch  
Office of Air Quality

Subject: **Important Information for Display Regarding a Final Determination**

**Applicant Name: Allison Transmission, Inc. - Speedway Main Campus**  
**Permit Number: 097 - 33236 - 00310**

You previously received information to make available to the public during the public comment period of a draft permit. Enclosed is a copy of the final decision and supporting materials for the same project. Please place the enclosed information along with the information you previously received. To ensure that your patrons have ample opportunity to review the enclosed permit, **we ask that you retain this document for at least 60 days.**

The applicant is responsible for placing a copy of the application in your library. If the permit application is not on file, or if you have any questions concerning this public review process, please contact Joanne Smiddie-Brush, OAQ Permits Administration Section at 1-800-451-6027, extension 3-0185.

Enclosures  
Final Library.dot 6/13/2013



## INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

100 N. Senate Avenue • Indianapolis, IN 46204  
(800) 451-6027 • (317) 232-8603 • [www.idem.IN.gov](http://www.idem.IN.gov)

**Michael R. Pence**  
Governor

**Thomas W. Easterly**  
Commissioner

TO: Interested Parties / Applicant

DATE: August 22, 2013

RE: Allison Transmission, Inc. - Speedway Main Campus / 097 - 33236 - 00310

FROM: Matthew Stuckey, Branch Chief  
Permits Branch  
Office of Air Quality

In order to conserve paper and reduce postage costs, IDEM's Office of Air Quality is now sending many permit decisions on CDs in Adobe PDF format. The enclosed CD contains information regarding the company named above.

This permit is also available on the IDEM website at:  
<http://www.in.gov/ai/appfiles/idem-caats/>


If you would like to request a paper copy of the permit document, please contact IDEM's central file room at:

Indiana Government Center North, Room 1201  
100 North Senate Avenue, MC 50-07  
Indianapolis, IN 46204  
Phone: 1-800-451-6027 (ext. 4-0965)  
Fax (317) 232-8659

**Please Note:** *If you feel you have received this information in error, or would like to be removed from the Air Permits mailing list, please contact Patricia Pear with the Air Permits Administration Section at 1-800-451-6027, ext. 3-6875 or via e-mail at [PPEAR@IDEM.IN.GOV](mailto:PPEAR@IDEM.IN.GOV).*

Enclosures  
CD Memo.dot 6/13/2013

# Mail Code 61-53

|                            |   |   |  |  |
|----------------------------|---|---|--|--|
| IDEM Staff                 | LPOGOST 8/22/2013<br>Allison Transmission, Inc. - Speedway Main Campus 097 - 33236 - 00310 /final)  |   | AFFIX STAMP<br>HERE IF<br>USED AS<br>CERTIFICATE<br>OF MAILING |  |
| Name and address of Sender |  Indiana Department of Environmental Management<br>Office of Air Quality – Permits Branch<br>100 N. Senate<br>Indianapolis, IN 46204 | Type of Mail:<br><br><b>CERTIFICATE OF MAILING ONLY</b> |  |  |

| Line | Article Number | Name, Address, Street and Post Office Address  | Postage | Handling Charges | Act. Value (If Registered) | Insured Value | Due Send if COD | R.R. Fee | S.D. Fee | S.H. Fee | Rest. Del. Fee |
|------|----------------|--|---------|------------------|----------------------------|---------------|-----------------|----------|----------|----------|----------------|
|      |                |  |         |                  |                            |               |                 |          |          |          | Remarks        |
| 1    |                | Matthew Littell Allison Transmission, Inc. - Speedway Main Campus 1 Allison Way Indianapolis IN 46222-3271 (Source CAATS) Via confirmed delivery |         |                  |                            |               |                 |          |          |          |                |
| 2    |                | David Parish VP - Ops Allison Transmission, Inc. - Speedway Main Campus 1 Allison Way Indianapolis IN 46222-3271 (RO CAATS)                      |         |                  |                            |               |                 |          |          |          |                |
| 3    |                | Marion County Health Department 3838 N, Rural St Indianapolis IN 46205-2930 (Health Department)  |         |                  |                            |               |                 |          |          |          |                |
| 4    |                | Indianapolis City Council and Mayors Office 200 East Washington Street, Room E Indianapolis IN 46204 (Local Official)                            |         |                  |                            |               |                 |          |          |          |                |
| 5    |                | Marion County Commissioners 200 E. Washington St. City County Bldg., Suite 801 Indianapolis IN 46204 (Local Official)                            |         |                  |                            |               |                 |          |          |          |                |
| 6    |                | Speedway Public Library 5633 W 25th St Speedway IN 46224-3899 (Library)  |         |                  |                            |               |                 |          |          |          |                |
| 7    |                | Matt Mosier Office of Sustainability 1200 S Madison Ave #200 Indianapolis IN 46225 (Local Official)  |         |                  |                            |               |                 |          |          |          |                |
| 8    |                |  |         |                  |                            |               |                 |          |          |          |                |
| 9    |                |  |         |                  |                            |               |                 |          |          |          |                |
| 10   |                |  |         |                  |                            |               |                 |          |          |          |                |
| 11   |                |  |         |                  |                            |               |                 |          |          |          |                |
| 12   |                |  |         |                  |                            |               |                 |          |          |          |                |
| 13   |                |  |         |                  |                            |               |                 |          |          |          |                |
| 14   |                |  |         |                  |                            |               |                 |          |          |          |                |
| 15   |                |  |         |                  |                            |               |                 |          |          |          |                |

|   |  |  |  |
|---|--|--|--|
| Total number of pieces Listed by Sender | Total number of Pieces Received at Post Office | Postmaster, Per (Name of Receiving employee) | The full declaration of value is required on all domestic and international registered mail. The maximum indemnity payable for the reconstruction of nonnegotiable documents under Express Mail document reconstructing insurance is \$50,000 per piece subject to a limit of \$50, 000 per occurrence. The maximum indemnity payable on Express mil merchandise insurance is \$500. The maximum indemnity payable is \$25,000 for registered mail, sent with optional postal insurance. See <b>Domestic Mail Manual R900, S913, and S921</b> for limitations of coverage on inured and COD mail. See <b>International Mail Manual</b> for limitations o coverage on international mail. Special handling charges apply only to Standard Mail (A) and Standard Mail (B) parcels. |
|---|--|--|--|