



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

100 N. Senate Avenue • Indianapolis, IN 46204
(800) 451-6027 • (317) 232-8603 • www.idem.IN.gov

Michael R. Pence
Governor

Thomas W. Easterly
Commissioner

To: Interested Parties
Date: February 27, 2015
From: Matthew Stuckey, Chief
Permits Branch
Office of Air Quality
Source Name: Plumrose USA Inc
Permit Level: Registration
Permit Number: 039-35017-00352
Source Location: 24402 CR 45 Elkhart, Indiana
Type of Action Taken: Initial Permit

Notice of Decision: Approval - Registration

Please be advised that on behalf of the Commissioner of the Department of Environmental Management, I have issued a decision regarding the matter referenced above.

The final decision is available on the IDEM website at: <http://www.in.gov/apps/idem/caats/>
To view the document, select Search option 3, then enter permit 35017.

If you would like to request a paper copy of the permit document, please contact IDEM's central file room:

Indiana Government Center North, Room 1201
100 North Senate Avenue, MC 50-07
Indianapolis, IN 46204
Phone: 1-800-451-6027 (ext. 4-0965)
Fax (317) 232-8659

Pursuant to IC 4-21.5-3-4(d) this order is effective when it is served. When served by U.S. mail, the order is effective three (3) calendar days from the mailing of this notice pursuant to IC 4-21.5-3-2(e).

(continues on next page)

If you wish to challenge this decision, IC 4-21.5-3-7 requires that you file a petition for administrative review. This petition may include a request for stay of effectiveness and must be submitted to the Office of Environmental Adjudication, 100 North Senate Avenue, Government Center North, Suite N 501E, Indianapolis, IN 46204, **within eighteen (18) calendar days of the mailing of this notice**. The filing of a petition for administrative review is complete on the earliest of the following dates that apply to the filing:

- (1) the date the document is delivered to the Office of Environmental Adjudication (OEA);
- (2) the date of the postmark on the envelope containing the document, if the document is mailed to OEA by U.S. mail; or
- (3) The date on which the document is deposited with a private carrier, as shown by receipt issued by the carrier, if the document is sent to the OEA by private carrier.

The petition must include facts demonstrating that you are either the applicant, a person aggrieved or adversely affected by the decision or otherwise entitled to review by law. Please identify the permit, decision, or other order for which you seek review by permit number, name of the applicant, location, date of this notice and all of the following:

- (1) the name and address of the person making the request;
- (2) the interest of the person making the request;
- (3) identification of any persons represented by the person making the request;
- (4) the reasons, with particularity, for the request;
- (5) the issues, with particularity, proposed for considerations at any hearing; and
- (6) identification of the terms and conditions which, in the judgment of the person making the request, would be appropriate in the case in question to satisfy the requirements of the law governing documents of the type issued by the Commissioner.

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178. Callers from within Indiana may call toll-free at 1-800-451-6027, ext. 3-0178.



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

100 N. Senate Avenue • Indianapolis, IN 46204

(800) 451-6027 • (317) 232-8603 • www.idem.IN.gov

Michael R. Pence
Governor

Thomas W. Easterly
Commissioner

REGISTRATION OFFICE OF AIR QUALITY

**Plumrose USA, Inc.
24401 County Road 45
Elkhart, Indiana 46516**

Pursuant to 326 IAC 2-5.1 (Construction of New Sources: Registrations) and 326 IAC 2-5.5 (Registrations), (herein known as the Registrant) is hereby authorized to construct and operate subject to the conditions contained herein, the source described in Section A (Source Summary) of this registration.

Registration No. R039-35017-00352	
Issued by:  Jason R. Krawczyk, Section Chief Permits Branch Office of Air Quality	Issuance Date: February 27, 2015

SECTION A

SOURCE SUMMARY

This registration is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Quality (OAQ). The information describing the source contained in conditions A.1 and A.2 is descriptive information and does not constitute enforceable conditions. However, the Registrant should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Registrant to obtain additional permits pursuant to 326 IAC 2.

A.1 General Information

The Registrant owns and operates a stationary meat packaging and processing operation.

Source Address:	24401 County Road 45, Elkhart, Indiana 46516
General Source Phone Number:	574-296-3190
SIC Code:	2011 (Meat Packing Plants)
County Location:	Elkhart County
Source Location Status:	Attainment for all criteria pollutants
Source Status:	Registration

A.2 Emission Units and Pollution Control Equipment Summary

This stationary source consists of the following emission units and pollution control devices:

- (a) One (1) batch Vector smokehouse, identified as SH-1 constructed in 1989, with a maximum meat throughput 1.5 tons per hour exhausting to stack S-1.
- (b) One (1) batch Enviropack smokehouse, identified as SH-2, constructed in 2002, with a maximum meat throughput of 2.0 tons per hour exhausting to two stacks S-2 and S-5.
- (c) One (1) batch Alkar smokehouse, identified as SH-3, constructed in 1977, with a maximum meat throughput 0.75 tons per hour exhausting to stack S-3.
- (d) One (1) batch Alkar smokehouse, identified as SH-4, constructed in 1977, with a maximum meat throughput 0.75 tons per hour exhausting to stack S-4.
- (e) One (1) liquid smoke operation, constructed in 2011, with a maximum meat throughput of 5 tons per hour, which can be utilized in any of the four (4) existing smokehouses and exhausts through the five associated stacks (S-1 through S-5).
- (f) One (1) parts cleaner, identified as Parts Cleaner, constructed prior to 2001, used only with wipe cleaning activities, such as using a rag containing halogenated solvent or a spray cleaner containing halogenated solvent.
- (g) One (1) natural gas-fired boiler, identified as Boiler 1, constructed in 1972, with a maximum capacity of 13.8 MMBtu/hr, exhausting outdoors.
- (h) One (1) natural gas-fired boiler, identified as Boiler 2, constructed in 2012, with a maximum capacity of 10.5 MMBtu/hr, exhausting outdoors.

Under 40 CFR 60, Subpart Dc, Boiler 2 is considered an affected facility.
- (i) One (1) natural gas-fired air makeup unit, Identified as Air Makeup 1, constructed in 2007, with a maximum capacity of 0.275 MMBtu/hr, exhausting outdoors.
- (j) One (1) clothes dryer, identified as Clothes Dryer, constructed in 2013, with a maximum capacity of 0.165 MMBtu/hr, exhausting outdoors.
- (k) Paved and Unpaved Roadways.

SECTION B GENERAL CONDITIONS

B.1 Definitions [326 IAC 2-1.1-1]

Terms in this registration shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, the applicable definitions found in the statutes or regulations (IC 13-11, 326 IAC 1-2 and 326 IAC 2-1.1-1) shall prevail.

B.2 Effective Date of Registration [IC 13-15-5-3]

Pursuant to IC 13-15-5-3, this registration is effective immediately, unless a petition for stay of effectiveness is filed and granted according to IC 13-15-6-3, and may be revoked or modified in accordance with the provisions of IC 13-15-7-1.

B.3 Registration Revocation [326 IAC 2-1.1-9]

Pursuant to 326 IAC 2-1.1-9 (Revocation), this registration to operate may be revoked for any of the following causes:

- (a) Violation of any conditions of this registration.
- (b) Failure to disclose all the relevant facts, or misrepresentation in obtaining this registration.
- (c) Changes in regulatory requirements that mandate either a temporary or permanent reduction of discharge of contaminants. However, the amendment of appropriate sections of this registration shall not require revocation of this registration.
- (d) For any cause which establishes in the judgment of IDEM the fact that continuance of this registration is not consistent with purposes of this article.

B.4 Prior Permits Superseded [326 IAC 2-1.1-9.5]

- (a) All terms and conditions of permits established prior to Registration No. R039-35017-00352 and issued pursuant to permitting programs approved into the state implementation plan have been either:
 - (1) incorporated as originally stated,
 - (2) revised, or
 - (3) deleted.
- (b) All previous registrations and permits are superseded by this registration.

B.5 Annual Notification [326 IAC 2-5.1-2(f)(3)] [326 IAC 2-5.5-4(a)(3)]

Pursuant to 326 IAC 2-5.1-2(f)(3) and 326 IAC 2-5.5-4(a)(3):

- (a) An annual notification shall be submitted by an authorized individual to the Office of Air Quality stating whether or not the source is in operation and in compliance with the terms and conditions contained in this registration.
- (b) The annual notice shall be submitted in the format attached no later than March 1 of each year to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, IN 46204-2251

- (c) The notification shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAQ on or before the date it is due.

B.6 Source Modification Requirement [326 IAC 2-5.5-6(a)]

Pursuant to 326 IAC 2-5.5-6(a), an application or notification shall be submitted in accordance with 326 IAC 2 to the Office of Air Quality (OAQ) if the source proposes to construct new emission units, modify existing emission units, or otherwise modify the source.

B.7 Registrations [326 IAC 2-5.1-2(i)]

Pursuant to 326 IAC 2-5.1-2(i), this registration does not limit the source's potential to emit.

B.8 Preventive Maintenance Plan [326 IAC 1-6-3]

(a) If required by specific condition(s) in Section D of this registration, the Registrant shall prepare and maintain Preventive Maintenance Plans (PMPs) no later than ninety (90) days after issuance of this registration or ninety (90) days after initial start-up, whichever is later, including the following information on each facility:

- (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;
- (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions; and
- (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

If, due to circumstances beyond the Registrant's control, the PMPs cannot be prepared and maintained within the above time frame, the Registrant may extend the date an additional ninety (90) days provided the Registrant notifies:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

The Registrant shall implement the PMPs.

- (b) A copy of the PMPs shall be submitted to IDEM, OAQ upon request and within a reasonable time, and shall be subject to review and approval by IDEM, OAQ. IDEM, OAQ may require the Registrant to revise its PMPs whenever lack of proper maintenance causes or is the primary contributor to an exceedance of any limitation on emissions.
- (c) To the extent the Registrant is required by 40 CFR Part 60 or 40 CFR Part 63 to have an Operation Maintenance, and Monitoring (OMM) Plan for a unit, such OMM Plan is deemed to satisfy the PMP requirements of 326 IAC 1-6-3 for that unit.

SECTION C

SOURCE OPERATION CONDITIONS

Entire Source

Emission Limitations and Standards [326 IAC 2-5.1-2(g)] [326 IAC 2-5.5-4(b)]

C.1 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-1 (Applicability) and 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this registration:

- (a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

C.2 Fugitive Dust Emissions [326 IAC 6-4]

The Registrant shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions).

SECTION D.1

OPERATION CONDITIONS

Emission Unit Description [326 IAC 2-5.1-2(f)(2)] [326 IAC 2-5.5-4(a)(2)]:

- (a) One (1) batch Vector smokehouse, identified as SH-1 constructed in 1989, with a maximum meat throughput 1.5 tons per hour exhausting to stack S-1.
- (b) One (1) batch Enviropack smokehouse, identified as SH-2, constructed in 2002, with a maximum meat throughput of 2.0 tons per hour exhausting to two stacks S-2 and S-5.
- (c) One (1) batch Alkar smokehouse, identified as SH-3, constructed in 1977, with a maximum meat throughput 0.75 tons per hour exhausting to stack S-3.
- (d) One (1) batch Alkar smokehouse, identified as SH-4, constructed in 1977, with a maximum meat throughput 0.75 tons per hour exhausting to stack S-4.

(The information describing the process contained in this emissions unit description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-5.1-2(f)(1)] [326 IAC 2-5.5-4(a)(1)]

D.1.1 Particulate Emission Limitations [326 IAC 6-3-2]

Pursuant to 326 IAC 6-3-2, the particulate matter (PM) from the smokehouses identified as SMH-1 through SMH-4 shall not exceed the particulate emission limits as contained in the table below:

Emission Unit	Process Weight Rate (tons/hr)	326 IAC 6-3-2 Limit (lbs/hr)
Smokehouse SH-1	1.5	5.38
Smokehouse SH-2	2.0	6.52
Smokehouse SH-3	0.75	3.38
Smokehouse SH-4	0.75	3.38

The pound per hour limitations were calculated with the following equation:

Interpolation of the data for the process weight rate up to sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 4.10 P^{0.67} \quad \text{where } E = \text{rate of emission in pounds per hour and} \\ P = \text{process weight rate in tons per hour}$$

D.1.2 Preventive Maintenance Plan [326 IAC 1-6-3]

A Preventive Maintenance Plan is required for these facilities and any associated control devices. Section B - Preventive Maintenance Plan contains the Registrant's obligation with regard to the preventive maintenance plan required by this condition.

SECTION D.2

OPERATION CONDITIONS

Emission Unit Description [326 IAC 2-5.1-2(f)(2)] [326 IAC 2-5.5-4(a)(2)]:

- (g) One (1) natural gas-fired boiler, identified as Boiler 1, constructed in 1972, with a maximum capacity of 13.8 MMBtu/hr, exhausting indoors.
- (h) One (1) natural gas-fired boiler, identified as Boiler 2, constructed in 2012, with a maximum capacity of 10.5 MMBtu/hr, exhausting indoors.

Under 40 CFR 60, Subpart Dc, this unit is considered an affected facility.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-5.1-2(f)(1)] [326 IAC 2-5.5-4(a)(1)]

D.2.1 Particulate Emission Limitations for Sources of Indirect Heating [326 IAC 6-2-3]

Pursuant to 326 IAC 6-2-1(b), particulate emissions from the 13.8 MMBtu/hr boiler (Boiler 1) shall not exceed 0.8 pounds of particulate matter per million British thermal units heat input.

D.2.2 Particulate Emission Limitations for Sources of Indirect Heating [326 IAC 6-2-4]

Pursuant to 326 IAC 6-2-4, particulate emissions from the 10.5 MMBtu/hr boiler (Boiler 2) shall be limited to 0.48 pounds per MMBtu heat input.

SECTION E.1

OPERATION CONDITIONS

Emission Unit Description [326 IAC 2-5.1-2(f)(2)] [326 IAC 2-5.5-4(a)(2)]:

- (h) One (1) natural gas-fired boiler, identified as Boiler 2, constructed in 2012, with a maximum capacity of 10.5 MMBtu/hr, exhausting outdoors.

Under 40 CFR 60, Subpart Dc, this unit is considered an affected facility.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

New Source Performance Standards (NSPS) Requirements

E.1.1 General Provisions Relating to New Source Performance Standards (NSPS) for for Small Industrial-Commercial-Institutional Steam Generating Units [40 CFR Part 60, Subpart A] [326 IAC 12-1]

- (a) Pursuant to 40 CFR 60.40c, the Registrant shall comply with the provisions of 40 CFR Part 60, Subpart A – General Provisions, which are incorporated by reference as 326 IAC 12-1, except as otherwise specified in 40 CFR 60, Subpart Dc.

- (b) Pursuant to 40 CFR 60.10, the Permittee shall submit all required notifications and reports to:

Indiana Department of Environmental Management
Compliance and Enforcement Branch, Office of Air Quality
100 North Senate Avenue
MC 61-53 IGCN 1003
Indianapolis, Indiana 46204-2251

E.1.2 New Source Performance Standards (NSPS) for for Small Industrial-Commercial-Institutional Steam Generating Units [40 CFR Part 60, Subpart Dc] [326 IAC 12-1]

The Registrant, which operates Boiler 2, shall comply with the following provisions of 40 CFR Part 60, Subpart Dc (included as Attachment A of this registration):

- (1) 40 CFR 60.40c
- (2) 40 CFR 60.41c
- (3) 40 CFR 60.48c (a)
- (4) 40 CFR 60.48c (g)
- (5) 40 CFR 60.48c (i)

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
COMPLIANCE AND ENFORCEMENT BRANCH**

**REGISTRATION
ANNUAL NOTIFICATION**

This form should be used to comply with the notification requirements under 326 IAC 2-5.1-2(f)(3) and 326 IAC 2-5.5-4(a)(3).

Company Name:	Plumrose USA, Inc.
Address:	24401 County Road 45
City:	Elkhart, Indiana 46516
Phone Number:	574-295-8190
Registration No.:	R039-35017-00352

I hereby certify that Plumrose USA, Inc. is:

- still in operation.
- no longer in operation.
- in compliance with the requirements of Registration No. R039-35017-00352.
- not in compliance with the requirements of Registration No. R039-35017-00352.

I hereby certify that Plumrose USA, Inc. is:

Authorized Individual (typed):
Title:
Signature:
Phone Number:
Date:

If there are any conditions or requirements for which the source is not in compliance, provide a narrative description of how the source did or will achieve compliance and the date compliance was, or will be achieved.

Noncompliance:

Attachment A

Registration No: R039-35017-00352

[Downloaded from the eCFR on May 13, 2013]

Electronic Code of Federal Regulations

Title 40: Protection of Environment

PART 60—STANDARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES

Subpart Dc—Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units

Source: 72 FR 32759, June 13, 2007, unless otherwise noted.

§ 60.40c Applicability and delegation of authority.

(a) Except as provided in paragraphs (d), (e), (f), and (g) of this section, the affected facility to which this subpart applies is each steam generating unit for which construction, modification, or reconstruction is commenced after June 9, 1989 and that has a maximum design heat input capacity of 29 megawatts (MW) (100 million British thermal units per hour (MMBtu/h)) or less, but greater than or equal to 2.9 MW (10 MMBtu/h).

(b) In delegating implementation and enforcement authority to a State under section 111(c) of the Clean Air Act, § 60.48c(a)(4) shall be retained by the Administrator and not transferred to a State.

(c) Steam generating units that meet the applicability requirements in paragraph (a) of this section are not subject to the sulfur dioxide (SO₂) or particulate matter (PM) emission limits, performance testing requirements, or monitoring requirements under this subpart (§§ 60.42c, 60.43c, 60.44c, 60.45c, 60.46c, or 60.47c) during periods of combustion research, as defined in § 60.41c.

(d) Any temporary change to an existing steam generating unit for the purpose of conducting combustion research is not considered a modification under § 60.14.

(e) Affected facilities (*i.e.* heat recovery steam generators and fuel heaters) that are associated with stationary combustion turbines and meet the applicability requirements of subpart KKKK of this part are not subject to this subpart. This subpart will continue to apply to all other heat recovery steam generators, fuel heaters, and other affected facilities that are capable of combusting more than or equal to 2.9 MW (10 MMBtu/h) heat input of fossil fuel but less than or equal to 29 MW (100 MMBtu/h) heat input of fossil fuel. If the heat recovery steam generator, fuel heater, or other affected facility is subject to this subpart, only emissions resulting from combustion of fuels in the steam generating unit are subject to this subpart. (The stationary combustion turbine emissions are subject to subpart GG or KKKK, as applicable, of this part.)

(f) Any affected facility that meets the applicability requirements of and is subject to subpart AAAA or subpart CCCC of this part is not subject to this subpart.

(g) Any facility that meets the applicability requirements and is subject to an EPA approved State or Federal section 111(d)/129 plan implementing subpart BBBB of this part is not subject to this subpart.

(h) Affected facilities that also meet the applicability requirements under subpart J or subpart Ja of this part are subject to the PM and NO_x standards under this subpart and the SO₂ standards under subpart J or subpart Ja of this part, as applicable.

(i) Temporary boilers are not subject to this subpart.

[72 FR 32759, June 13, 2007, as amended at 74 FR 5090, Jan. 28, 2009; 77 FR 9461, Feb. 16, 2012]

§ 60.41c Definitions.

As used in this subpart, all terms not defined herein shall have the meaning given them in the Clean Air Act and in subpart A of this part.

Annual capacity factor means the ratio between the actual heat input to a steam generating unit from an individual fuel or combination of fuels during a period of 12 consecutive calendar months and the potential heat input to the steam generating unit from all fuels had the steam generating unit been operated for 8,760 hours during that 12-month period at the maximum design heat input capacity. In the case of steam generating units that are rented or leased, the actual heat input shall be determined based on the combined heat input from all operations of the affected facility during a period of 12 consecutive calendar months.

Coal means all solid fuels classified as anthracite, bituminous, subbituminous, or lignite by the American Society of Testing and Materials in ASTM D388 (incorporated by reference, see § 60.17), coal refuse, and petroleum coke. Coal-derived synthetic fuels derived from coal for the purposes of creating useful heat, including but not limited to solvent refined coal, gasified coal not meeting the definition of natural gas, coal-oil mixtures, and coal-water mixtures, are also included in this definition for the purposes of this subpart.

Coal refuse means any by-product of coal mining or coal cleaning operations with an ash content greater than 50 percent (by weight) and a heating value less than 13,900 kilojoules per kilogram (kJ/kg) (6,000 Btu per pound (Btu/lb) on a dry basis.

Combined cycle system means a system in which a separate source (such as a stationary gas turbine, internal combustion engine, or kiln) provides exhaust gas to a steam generating unit.

Combustion research means the experimental firing of any fuel or combination of fuels in a steam generating unit for the purpose of conducting research and development of more efficient combustion or more effective prevention or control of air pollutant emissions from combustion, provided that, during these periods of research and development, the heat generated is not used for any purpose other than preheating combustion air for use by that steam generating unit (*i.e.* , the heat generated is released to the atmosphere without being used for space heating, process heating, driving pumps, preheating combustion air for other units, generating electricity, or any other purpose).

Conventional technology means wet flue gas desulfurization technology, dry flue gas desulfurization technology, atmospheric fluidized bed combustion technology, and oil hydrodesulfurization technology.

Distillate oil means fuel oil that complies with the specifications for fuel oil numbers 1 or 2, as defined by the American Society for Testing and Materials in ASTM D396 (incorporated by reference, see § 60.17), diesel fuel oil numbers 1 or 2, as defined by the American Society for Testing and Materials in ASTM D975 (incorporated by reference, see § 60.17), kerosine, as defined by the American Society of Testing and Materials in ASTM D3699 (incorporated by reference, see § 60.17), biodiesel as defined by the American Society of Testing and Materials in ASTM D6751 (incorporated by reference, see § 60.17), or biodiesel blends as defined by the American Society of Testing and Materials in ASTM D7467 (incorporated by reference, see § 60.17).

Dry flue gas desulfurization technology means a SO₂ control system that is located between the steam generating unit and the exhaust vent or stack, and that removes sulfur oxides from the combustion gases of the steam generating unit by contacting the combustion gases with an alkaline reagent and water, whether introduced separately or as a premixed slurry or solution and forming a dry powder material. This definition includes devices where the dry powder material is subsequently converted to another form. Alkaline reagents used in dry flue gas desulfurization systems include, but are not limited to, lime and sodium compounds.

Duct burner means a device that combusts fuel and that is placed in the exhaust duct from another source (such as a stationary gas turbine, internal combustion engine, kiln, etc.) to allow the firing of additional fuel to heat the exhaust gases before the exhaust gases enter a steam generating unit.

Emerging technology means any SO₂ control system that is not defined as a conventional technology under this section, and for which the owner or operator of the affected facility has received approval from the Administrator to operate as an emerging technology under § 60.48c(a)(4).

Federally enforceable means all limitations and conditions that are enforceable by the Administrator, including the requirements of 40 CFR parts 60 and 61, requirements within any applicable State implementation plan, and any permit requirements established under 40 CFR 52.21 or under 40 CFR 51.18 and 51.24.

Fluidized bed combustion technology means a device wherein fuel is distributed onto a bed (or series of beds) of limestone aggregate (or other sorbent materials) for combustion; and these materials are forced upward in the device by the flow of combustion air and the gaseous products of combustion. Fluidized bed combustion technology includes, but is not limited to, bubbling bed units and circulating bed units.

Fuel pretreatment means a process that removes a portion of the sulfur in a fuel before combustion of the fuel in a steam generating unit.

Heat input means heat derived from combustion of fuel in a steam generating unit and does not include the heat derived from preheated combustion air, recirculated flue gases, or exhaust gases from other sources (such as stationary gas turbines, internal combustion engines, and kilns).

Heat transfer medium means any material that is used to transfer heat from one point to another point.

Maximum design heat input capacity means the ability of a steam generating unit to combust a stated maximum amount of fuel (or combination of fuels) on a steady state basis as determined by the physical design and characteristics of the steam generating unit.

Natural gas means:

- (1) A naturally occurring mixture of hydrocarbon and nonhydrocarbon gases found in geologic formations beneath the earth's surface, of which the principal constituent is methane; or
- (2) Liquefied petroleum (LP) gas, as defined by the American Society for Testing and Materials in ASTM D1835 (incorporated by reference, see § 60.17); or
- (3) A mixture of hydrocarbons that maintains a gaseous state at ISO conditions. Additionally, natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 34 and 43 megajoules (MJ) per dry standard cubic meter (910 and 1,150 Btu per dry standard cubic foot).

Noncontinental area means the State of Hawaii, the Virgin Islands, Guam, American Samoa, the Commonwealth of Puerto Rico, or the Northern Mariana Islands.

Oil means crude oil or petroleum, or a liquid fuel derived from crude oil or petroleum, including distillate oil and residual oil.

Potential sulfur dioxide emission rate means the theoretical SO₂ emissions (nanograms per joule (ng/J) or lb/MMBtu heat input) that would result from combusting fuel in an uncleaned state and without using emission control systems.

Process heater means a device that is primarily used to heat a material to initiate or promote a chemical reaction in which the material participates as a reactant or catalyst.

Residual oil means crude oil, fuel oil that does not comply with the specifications under the definition of distillate oil, and all fuel oil numbers 4, 5, and 6, as defined by the American Society for Testing and Materials in ASTM D396 (incorporated by reference, see § 60.17).

Steam generating unit means a device that combusts any fuel and produces steam or heats water or heats any heat transfer medium. This term includes any duct burner that combusts fuel and is part of a combined cycle system. This term does not include process heaters as defined in this subpart.

Steam generating unit operating day means a 24-hour period between 12:00 midnight and the following midnight during which any fuel is combusted at any time in the steam generating unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period.

Temporary boiler means a steam generating unit that combusts natural gas or distillate oil with a potential SO₂ emissions rate no greater than 26 ng/J (0.060 lb/MMBtu), and the unit is designed to, and is capable of, being carried or moved from one location to another by means of, for example, wheels, skids, carrying handles, dollies, trailers, or platforms. A steam generating unit is not a temporary boiler if any one of the following conditions exists:

- (1) The equipment is attached to a foundation.
- (2) The steam generating unit or a replacement remains at a location for more than 180 consecutive days. Any temporary boiler that replaces a temporary boiler at a location and performs the same or similar function will be included in calculating the consecutive time period.
- (3) The equipment is located at a seasonal facility and operates during the full annual operating period of the seasonal facility, remains at the facility for at least 2 years, and operates at that facility for at least 3 months each year.
- (4) The equipment is moved from one location to another in an attempt to circumvent the residence time requirements of this definition.

Wet flue gas desulfurization technology means an SO₂ control system that is located between the steam generating unit and the exhaust vent or stack, and that removes sulfur oxides from the combustion gases of the steam generating unit by contacting the combustion gases with an alkaline slurry or solution and forming a liquid material. This definition includes devices where the liquid material is subsequently converted to another form. Alkaline reagents used in wet flue gas desulfurization systems include, but are not limited to, lime, limestone, and sodium compounds.

Wet scrubber system means any emission control device that mixes an aqueous stream or slurry with the exhaust gases from a steam generating unit to control emissions of PM or SO₂.

Wood means wood, wood residue, bark, or any derivative fuel or residue thereof, in any form, including but not limited to sawdust, sanderdust, wood chips, scraps, slabs, millings, shavings, and processed pellets made from wood or other forest residues.

[72 FR 32759, June 13, 2007, as amended at 74 FR 5090, Jan. 28, 2009; 77 FR 9461, Feb. 16, 2012]

§ 60.42c Standard for sulfur dioxide (SO₂).

(a) Except as provided in paragraphs (b), (c), and (e) of this section, on and after the date on which the performance test is completed or required to be completed under § 60.8, whichever date comes first, the owner or operator of an affected facility that combusts only coal shall neither: cause to be discharged into the atmosphere from the affected facility any gases that contain SO₂ in excess of 87 ng/J (0.20 lb/MMBtu) heat input or 10 percent (0.10) of the potential SO₂ emission rate (90 percent reduction), nor cause to be discharged into the atmosphere from the affected facility any gases that contain SO₂ in excess of 520 ng/J (1.2 lb/MMBtu) heat input. If coal is combusted with other fuels, the affected facility shall neither: cause to be discharged into the atmosphere from the affected facility any gases that contain SO₂ in excess of 87 ng/J (0.20 lb/MMBtu) heat input or 10 percent (0.10) of the potential SO₂ emission rate (90 percent reduction), nor cause to be discharged into the atmosphere from the affected facility any gases that contain SO₂ in excess of the emission limit is determined pursuant to paragraph (e)(2) of this section.

(b) Except as provided in paragraphs (c) and (e) of this section, on and after the date on which the performance test is completed or required to be completed under § 60.8, whichever date comes first, the owner or operator of an affected facility that:

(1) Combusts only coal refuse alone in a fluidized bed combustion steam generating unit shall neither:

(i) Cause to be discharged into the atmosphere from that affected facility any gases that contain SO₂ in excess of 87 ng/J (0.20 lb/MMBtu) heat input or 20 percent (0.20) of the potential SO₂ emission rate (80 percent reduction); nor

(ii) Cause to be discharged into the atmosphere from that affected facility any gases that contain SO₂ in excess of 520 ng/J (1.2 lb/MMBtu) heat input. If coal is fired with coal refuse, the affected facility subject to paragraph (a) of this section. If oil or any other fuel (except coal) is fired with coal refuse, the affected facility is subject to the 87 ng/J (0.20 lb/MMBtu) heat input SO₂ emissions limit or the 90 percent SO₂ reduction requirement specified in paragraph (a) of this section and the emission limit is determined pursuant to paragraph (e)(2) of this section.

(2) Combusts only coal and that uses an emerging technology for the control of SO₂ emissions shall neither:

(i) Cause to be discharged into the atmosphere from that affected facility any gases that contain SO₂ in excess of 50 percent (0.50) of the potential SO₂ emission rate (50 percent reduction); nor

(ii) Cause to be discharged into the atmosphere from that affected facility any gases that contain SO₂ in excess of 260 ng/J (0.60 lb/MMBtu) heat input. If coal is combusted with other fuels, the affected facility is subject to the 50 percent SO₂ reduction requirement specified in this paragraph and the emission limit determined pursuant to paragraph (e)(2) of this section.

(c) On and after the date on which the initial performance test is completed or required to be completed under § 60.8, whichever date comes first, no owner or operator of an affected facility that combusts coal, alone or in combination with any other fuel, and is listed in paragraphs (c)(1), (2), (3), or (4) of this section shall cause to be discharged into the atmosphere from that affected facility any gases that contain SO₂ in excess of the emission limit determined pursuant to paragraph (e)(2) of this section. Percent reduction requirements are not applicable to affected facilities under paragraphs (c)(1), (2), (3), or (4).

(1) Affected facilities that have a heat input capacity of 22 MW (75 MMBtu/h) or less;

(2) Affected facilities that have an annual capacity for coal of 55 percent (0.55) or less and are subject to a federally enforceable requirement limiting operation of the affected facility to an annual capacity factor for coal of 55 percent (0.55) or less.

(3) Affected facilities located in a noncontinental area; or

(4) Affected facilities that combust coal in a duct burner as part of a combined cycle system where 30 percent (0.30) or less of the heat entering the steam generating unit is from combustion of coal in the duct burner and 70 percent (0.70) or more of the heat entering the steam generating unit is from exhaust gases entering the duct burner.

(d) On and after the date on which the initial performance test is completed or required to be completed under § 60.8, whichever date comes first, no owner or operator of an affected facility that combusts oil shall cause to be discharged into the atmosphere from that affected facility any gases that contain SO₂ in excess of 215 ng/J (0.50 lb/MMBtu) heat input from oil; or, as an alternative, no owner or operator of an affected facility that combusts oil shall combust oil in the affected facility that contains greater than 0.5 weight percent sulfur. The percent reduction requirements are not applicable to affected facilities under this paragraph.

(e) On and after the date on which the initial performance test is completed or required to be completed under § 60.8, whichever date comes first, no owner or operator of an affected facility that combusts coal, oil, or coal and oil with any other fuel shall cause to be discharged into the atmosphere from that affected facility any gases that contain SO₂ in excess of the following:

(1) The percent of potential SO₂ emission rate or numerical SO₂ emission rate required under paragraph (a) or (b)(2) of this section, as applicable, for any affected facility that

(i) Combusts coal in combination with any other fuel;

(ii) Has a heat input capacity greater than 22 MW (75 MMBtu/h); and

(iii) Has an annual capacity factor for coal greater than 55 percent (0.55); and

(2) The emission limit determined according to the following formula for any affected facility that combusts coal, oil, or coal and oil with any other fuel:

$$E_s = \frac{(K_a H_a + K_b H_b + K_c H_c)}{(H_a + H_b + H_c)}$$

Where:

E_s = SO₂ emission limit, expressed in ng/J or lb/MMBtu heat input;

K_a = 520 ng/J (1.2 lb/MMBtu);

K_b = 260 ng/J (0.60 lb/MMBtu);

K_c = 215 ng/J (0.50 lb/MMBtu);

H_a = Heat input from the combustion of coal, except coal combusted in an affected facility subject to paragraph (b)(2) of this section, in Joules (J) [MMBtu];

H_b = Heat input from the combustion of coal in an affected facility subject to paragraph (b)(2) of this section, in J (MMBtu); and

H_c = Heat input from the combustion of oil, in J (MMBtu).

(f) Reduction in the potential SO₂ emission rate through fuel pretreatment is not credited toward the percent reduction requirement under paragraph (b)(2) of this section unless:

(1) Fuel pretreatment results in a 50 percent (0.50) or greater reduction in the potential SO₂ emission rate; and

(2) Emissions from the pretreated fuel (without either combustion or post-combustion SO₂ control) are equal to or less than the emission limits specified under paragraph (b)(2) of this section.

(g) Except as provided in paragraph (h) of this section, compliance with the percent reduction requirements, fuel oil sulfur limits, and emission limits of this section shall be determined on a 30-day rolling average basis.

(h) For affected facilities listed under paragraphs (h)(1), (2), (3), or (4) of this section, compliance with the emission limits or fuel oil sulfur limits under this section may be determined based on a certification from the fuel supplier, as described under § 60.48c(f), as applicable.

(1) Distillate oil-fired affected facilities with heat input capacities between 2.9 and 29 MW (10 and 100 MMBtu/hr).

(2) Residual oil-fired affected facilities with heat input capacities between 2.9 and 8.7 MW (10 and 30 MMBtu/hr).

(3) Coal-fired affected facilities with heat input capacities between 2.9 and 8.7 MW (10 and 30 MMBtu/h).

(4) Other fuels-fired affected facilities with heat input capacities between 2.9 and 8.7 MW (10 and 30 MMBtu/h).

(i) The SO₂ emission limits, fuel oil sulfur limits, and percent reduction requirements under this section apply at all times, including periods of startup, shutdown, and malfunction.

(j) For affected facilities located in noncontinental areas and affected facilities complying with the percent reduction standard, only the heat input supplied to the affected facility from the combustion of coal and oil is counted under this section. No credit is provided for the heat input to the affected facility from wood or other fuels or for heat derived from exhaust gases from other sources, such as stationary gas turbines, internal combustion engines, and kilns.

[72 FR 32759, June 13, 2007, as amended at 74 FR 5090, Jan. 28, 2009; 77 FR 9462, Feb. 16, 2012]

§ 60.43c Standard for particulate matter (PM).

(a) On and after the date on which the initial performance test is completed or required to be completed under § 60.8, whichever date comes first, no owner or operator of an affected facility that commenced construction, reconstruction, or modification on or before February 28, 2005, that combusts coal or combusts mixtures of coal with other fuels and has a heat input capacity of 8.7 MW (30 MMBtu/h) or greater, shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of the following emission limits:

(1) 22 ng/J (0.051 lb/MMBtu) heat input if the affected facility combusts only coal, or combusts coal with other fuels and has an annual capacity factor for the other fuels of 10 percent (0.10) or less.

(2) 43 ng/J (0.10 lb/MMBtu) heat input if the affected facility combusts coal with other fuels, has an annual capacity factor for the other fuels greater than 10 percent (0.10), and is subject to a federally enforceable requirement limiting operation of the affected facility to an annual capacity factor greater than 10 percent (0.10) for fuels other than coal.

(b) On and after the date on which the initial performance test is completed or required to be completed under § 60.8, whichever date comes first, no owner or operator of an affected facility that commenced construction, reconstruction, or modification on or before February 28, 2005, that combusts wood or combusts mixtures of wood with other fuels (except coal) and has a heat input capacity of 8.7 MW (30 MMBtu/h) or greater, shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of the following emissions limits:

(1) 43 ng/J (0.10 lb/MMBtu) heat input if the affected facility has an annual capacity factor for wood greater than 30 percent (0.30); or

(2) 130 ng/J (0.30 lb/MMBtu) heat input if the affected facility has an annual capacity factor for wood of 30 percent (0.30) or less and is subject to a federally enforceable requirement limiting operation of the affected facility to an annual capacity factor for wood of 30 percent (0.30) or less.

(c) On and after the date on which the initial performance test is completed or required to be completed under § 60.8, whichever date comes first, no owner or operator of an affected facility that combusts coal, wood, or oil and has a heat input capacity of 8.7 MW (30 MMBtu/h) or greater shall cause to be discharged into the atmosphere from that affected facility any gases that exhibit greater than 20 percent opacity (6-minute average), except for one 6-minute period per hour of not more than 27 percent opacity. Owners and operators of an affected facility that elect to install, calibrate, maintain, and operate a continuous emissions monitoring system (CEMS) for measuring PM emissions according to the requirements of this subpart and are subject to a federally enforceable PM limit of 0.030 lb/MMBtu or less are exempt from the opacity standard specified in this paragraph (c).

(d) The PM and opacity standards under this section apply at all times, except during periods of startup, shutdown, or malfunction.

(e)(1) On and after the date on which the initial performance test is completed or is required to be completed under § 60.8, whichever date comes first, no owner or operator of an affected facility that commences construction, reconstruction, or modification after February 28, 2005, and that combusts coal, oil, wood, a mixture of these fuels, or a mixture of these fuels with any other fuels and has a heat input capacity of 8.7 MW (30 MMBtu/h) or greater shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of 13 ng/J (0.030 lb/MMBtu) heat input, except as provided in paragraphs (e)(2), (e)(3), and (e)(4) of this section.

(2) As an alternative to meeting the requirements of paragraph (e)(1) of this section, the owner or operator of an affected facility for which modification commenced after February 28, 2005, may elect to meet the requirements of this paragraph. On and after the date on which the initial performance test is completed or required to be completed under § 60.8, whichever date comes first, no owner or operator of an affected facility that commences modification

after February 28, 2005 shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of both:

(i) 22 ng/J (0.051 lb/MMBtu) heat input derived from the combustion of coal, oil, wood, a mixture of these fuels, or a mixture of these fuels with any other fuels; and

(ii) 0.2 percent of the combustion concentration (99.8 percent reduction) when combusting coal, oil, wood, a mixture of these fuels, or a mixture of these fuels with any other fuels.

(3) On and after the date on which the initial performance test is completed or is required to be completed under § 60.8, whichever date comes first, no owner or operator of an affected facility that commences modification after February 28, 2005, and that combusts over 30 percent wood (by heat input) on an annual basis and has a heat input capacity of 8.7 MW (30 MMBtu/h) or greater shall cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of 43 ng/J (0.10 lb/MMBtu) heat input.

(4) An owner or operator of an affected facility that commences construction, reconstruction, or modification after February 28, 2005, and that combusts only oil that contains no more than 0.50 weight percent sulfur or a mixture of 0.50 weight percent sulfur oil with other fuels not subject to a PM standard under § 60.43c and not using a post-combustion technology (except a wet scrubber) to reduce PM or SO₂ emissions is not subject to the PM limit in this section.

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009; 77 FR 9462, Feb. 16, 2012]

§ 60.44c Compliance and performance test methods and procedures for sulfur dioxide.

(a) Except as provided in paragraphs (g) and (h) of this section and § 60.8(b), performance tests required under § 60.8 shall be conducted following the procedures specified in paragraphs (b), (c), (d), (e), and (f) of this section, as applicable. Section 60.8(f) does not apply to this section. The 30-day notice required in § 60.8(d) applies only to the initial performance test unless otherwise specified by the Administrator.

(b) The initial performance test required under § 60.8 shall be conducted over 30 consecutive operating days of the steam generating unit. Compliance with the percent reduction requirements and SO₂ emission limits under § 60.42c shall be determined using a 30-day average. The first operating day included in the initial performance test shall be scheduled within 30 days after achieving the maximum production rate at which the affected facility will be operated, but not later than 180 days after the initial startup of the facility. The steam generating unit load during the 30-day period does not have to be the maximum design heat input capacity, but must be representative of future operating conditions.

(c) After the initial performance test required under paragraph (b) of this section and § 60.8, compliance with the percent reduction requirements and SO₂ emission limits under § 60.42c is based on the average percent reduction and the average SO₂ emission rates for 30 consecutive steam generating unit operating days. A separate performance test is completed at the end of each steam generating unit operating day, and a new 30-day average percent reduction and SO₂ emission rate are calculated to show compliance with the standard.

(d) If only coal, only oil, or a mixture of coal and oil is combusted in an affected facility, the procedures in Method 19 of appendix A of this part are used to determine the hourly SO₂ emission rate (E_{ho}) and the 30-day average SO₂ emission rate (E_{ao}). The hourly averages used to compute the 30-day averages are obtained from the CEMS. Method 19 of appendix A of this part shall be used to calculate E_{ao} when using daily fuel sampling or Method 6B of appendix A of this part.

(e) If coal, oil, or coal and oil are combusted with other fuels:

(1) An adjusted E_{ho} ($E_{ho o}$) is used in Equation 19-19 of Method 19 of appendix A of this part to compute the adjusted E_{ao} ($E_{ao o}$). The $E_{ho o}$ is computed using the following formula:

$$E_{ho o} = \frac{E_w - E_w(1 - X_1)}{X_1}$$

Where:

$E_{ho\ o}$ = Adjusted E_{ho} , ng/J (lb/MMBtu);

E_{ho} = Hourly SO_2 emission rate, ng/J (lb/MMBtu);

E_w = SO_2 concentration in fuels other than coal and oil combusted in the affected facility, as determined by fuel sampling and analysis procedures in Method 9 of appendix A of this part, ng/J (lb/MMBtu). The value E_w for each fuel lot is used for each hourly average during the time that the lot is being combusted. The owner or operator does not have to measure E_w if the owner or operator elects to assume $E_w = 0$.

X_k = Fraction of the total heat input from fuel combustion derived from coal and oil, as determined by applicable procedures in Method 19 of appendix A of this part.

(2) The owner or operator of an affected facility that qualifies under the provisions of § 60.42c(c) or (d) (where percent reduction is not required) does not have to measure the parameters E_w or X_k if the owner or operator of the affected facility elects to measure emission rates of the coal or oil using the fuel sampling and analysis procedures under Method 19 of appendix A of this part.

(f) Affected facilities subject to the percent reduction requirements under § 60.42c(a) or (b) shall determine compliance with the SO_2 emission limits under § 60.42c pursuant to paragraphs (d) or (e) of this section, and shall determine compliance with the percent reduction requirements using the following procedures:

(1) If only coal is combusted, the percent of potential SO_2 emission rate is computed using the following formula:

$$\%P_f = 100 \left(1 - \frac{\%R_g}{100} \right) \left(1 - \frac{\%R_f}{100} \right)$$

Where:

$\%P_s$ = Potential SO_2 emission rate, in percent;

$\%R_g$ = SO_2 removal efficiency of the control device as determined by Method 19 of appendix A of this part, in percent; and

$\%R_f$ = SO_2 removal efficiency of fuel pretreatment as determined by Method 19 of appendix A of this part, in percent.

(2) If coal, oil, or coal and oil are combusted with other fuels, the same procedures required in paragraph (f)(1) of this section are used, except as provided for in the following:

(i) To compute the $\%P_s$, an adjusted $\%R_g$ ($\%R_{g\ o}$) is computed from $E_{ao\ o}$ from paragraph (e)(1) of this section and an adjusted average SO_2 inlet rate ($E_{ai\ o}$) using the following formula:

$$\%R_{g\ o} = 100 \left(1 - \frac{E_{ao\ o}}{E_{ai\ o}} \right)$$

Where:

$\%R_{g\ o}$ = Adjusted $\%R_g$, in percent;

$E_{ao\ o}$ = Adjusted E_{ao} , ng/J (lb/MMBtu); and

$E_{ai\ o}$ = Adjusted average SO_2 inlet rate, ng/J (lb/MMBtu).

(ii) To compute E_{ai} , an adjusted hourly SO_2 inlet rate (E_{hi}) is used. The E_{hi} is computed using the following formula:

$$E_{ai} = \frac{E_{hi} - E_w(1 - X_k)}{X_k}$$

Where:

E_{hi} = Adjusted E_{hi} , ng/J (lb/MMBtu);

E_{hi} = Hourly SO_2 inlet rate, ng/J (lb/MMBtu);

E_w = SO_2 concentration in fuels other than coal and oil combusted in the affected facility, as determined by fuel sampling and analysis procedures in Method 19 of appendix A of this part, ng/J (lb/MMBtu). The value E_w for each fuel lot is used for each hourly average during the time that the lot is being combusted. The owner or operator does not have to measure E_w if the owner or operator elects to assume $E_w = 0$; and

X_k = Fraction of the total heat input from fuel combustion derived from coal and oil, as determined by applicable procedures in Method 19 of appendix A of this part.

(g) For oil-fired affected facilities where the owner or operator seeks to demonstrate compliance with the fuel oil sulfur limits under § 60.42c based on shipment fuel sampling, the initial performance test shall consist of sampling and analyzing the oil in the initial tank of oil to be fired in the steam generating unit to demonstrate that the oil contains 0.5 weight percent sulfur or less. Thereafter, the owner or operator of the affected facility shall sample the oil in the fuel tank after each new shipment of oil is received, as described under § 60.46c(d)(2).

(h) For affected facilities subject to § 60.42c(h)(1), (2), or (3) where the owner or operator seeks to demonstrate compliance with the SO_2 standards based on fuel supplier certification, the performance test shall consist of the certification from the fuel supplier, as described in § 60.48c(f), as applicable.

(i) The owner or operator of an affected facility seeking to demonstrate compliance with the SO_2 standards under § 60.42c(c)(2) shall demonstrate the maximum design heat input capacity of the steam generating unit by operating the steam generating unit at this capacity for 24 hours. This demonstration shall be made during the initial performance test, and a subsequent demonstration may be requested at any other time. If the demonstrated 24-hour average firing rate for the affected facility is less than the maximum design heat input capacity stated by the manufacturer of the affected facility, the demonstrated 24-hour average firing rate shall be used to determine the annual capacity factor for the affected facility; otherwise, the maximum design heat input capacity provided by the manufacturer shall be used.

(j) The owner or operator of an affected facility shall use all valid SO_2 emissions data in calculating $\%P_s$ and E_{ho} under paragraphs (d), (e), or (f) of this section, as applicable, whether or not the minimum emissions data requirements under § 60.46c(f) are achieved. All valid emissions data, including valid data collected during periods of startup, shutdown, and malfunction, shall be used in calculating $\%P_s$ or E_{ho} pursuant to paragraphs (d), (e), or (f) of this section, as applicable.

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009]

§ 60.45c Compliance and performance test methods and procedures for particulate matter.

(a) The owner or operator of an affected facility subject to the PM and/or opacity standards under § 60.43c shall conduct an initial performance test as required under § 60.8, and shall conduct subsequent performance tests as requested by the Administrator, to determine compliance with the standards using the following procedures and reference methods, except as specified in paragraph (c) of this section.

(1) Method 1 of appendix A of this part shall be used to select the sampling site and the number of traverse sampling points.

(2) Method 3A or 3B of appendix A-2 of this part shall be used for gas analysis when applying Method 5 or 5B of appendix A-3 of this part or 17 of appendix A-6 of this part.

(3) Method 5, 5B, or 17 of appendix A of this part shall be used to measure the concentration of PM as follows:

(i) Method 5 of appendix A of this part may be used only at affected facilities without wet scrubber systems.

(ii) Method 17 of appendix A of this part may be used at affected facilities with or without wet scrubber systems provided the stack gas temperature does not exceed a temperature of 160 °C (320 °F). The procedures of Sections 8.1 and 11.1 of Method 5B of appendix A of this part may be used in Method 17 of appendix A of this part only if Method 17 of appendix A of this part is used in conjunction with a wet scrubber system. Method 17 of appendix A of this part shall not be used in conjunction with a wet scrubber system if the effluent is saturated or laden with water droplets.

(iii) Method 5B of appendix A of this part may be used in conjunction with a wet scrubber system.

(4) The sampling time for each run shall be at least 120 minutes and the minimum sampling volume shall be 1.7 dry standard cubic meters (dscm) [60 dry standard cubic feet (dscf)] except that smaller sampling times or volumes may be approved by the Administrator when necessitated by process variables or other factors.

(5) For Method 5 or 5B of appendix A of this part, the temperature of the sample gas in the probe and filter holder shall be monitored and maintained at 160 ±14 °C (320±25 °F).

(6) For determination of PM emissions, an oxygen (O₂) or carbon dioxide (CO₂) measurement shall be obtained simultaneously with each run of Method 5, 5B, or 17 of appendix A of this part by traversing the duct at the same sampling location.

(7) For each run using Method 5, 5B, or 17 of appendix A of this part, the emission rates expressed in ng/J (lb/MMBtu) heat input shall be determined using:

(i) The O₂ or CO₂ measurements and PM measurements obtained under this section, (ii) The dry basis F factor, and

(iii) The dry basis emission rate calculation procedure contained in Method 19 of appendix A of this part.

(8) Method 9 of appendix A-4 of this part shall be used for determining the opacity of stack emissions.

(b) The owner or operator of an affected facility seeking to demonstrate compliance with the PM standards under § 60.43c(b)(2) shall demonstrate the maximum design heat input capacity of the steam generating unit by operating the steam generating unit at this capacity for 24 hours. This demonstration shall be made during the initial performance test, and a subsequent demonstration may be requested at any other time. If the demonstrated 24-hour average firing rate for the affected facility is less than the maximum design heat input capacity stated by the manufacturer of the affected facility, the demonstrated 24-hour average firing rate shall be used to determine the annual capacity factor for the affected facility; otherwise, the maximum design heat input capacity provided by the manufacturer shall be used.

(c) In place of PM testing with Method 5 or 5B of appendix A-3 of this part or Method 17 of appendix A-6 of this part, an owner or operator may elect to install, calibrate, maintain, and operate a CEMS for monitoring PM emissions discharged to the atmosphere and record the output of the system. The owner or operator of an affected facility who elects to continuously monitor PM emissions instead of conducting performance testing using Method 5 or 5B of appendix A-3 of this part or Method 17 of appendix A-6 of this part shall install, calibrate, maintain, and operate a CEMS and shall comply with the requirements specified in paragraphs (c)(1) through (c)(14) of this section.

(1) Notify the Administrator 1 month before starting use of the system.

(2) Notify the Administrator 1 month before stopping use of the system.

- (3) The monitor shall be installed, evaluated, and operated in accordance with § 60.13 of subpart A of this part.
- (4) The initial performance evaluation shall be completed no later than 180 days after the date of initial startup of the affected facility, as specified under § 60.8 of subpart A of this part or within 180 days of notification to the Administrator of use of CEMS if the owner or operator was previously determining compliance by Method 5, 5B, or 17 of appendix A of this part performance tests, whichever is later.
- (5) The owner or operator of an affected facility shall conduct an initial performance test for PM emissions as required under § 60.8 of subpart A of this part. Compliance with the PM emission limit shall be determined by using the CEMS specified in paragraph (d) of this section to measure PM and calculating a 24-hour block arithmetic average emission concentration using EPA Reference Method 19 of appendix A of this part, section 4.1.
- (6) Compliance with the PM emission limit shall be determined based on the 24-hour daily (block) average of the hourly arithmetic average emission concentrations using CEMS outlet data.
- (7) At a minimum, valid CEMS hourly averages shall be obtained as specified in paragraph (c)(7)(i) of this section for 75 percent of the total operating hours per 30-day rolling average.
- (i) At least two data points per hour shall be used to calculate each 1-hour arithmetic average.
- (ii) [Reserved]
- (8) The 1-hour arithmetic averages required under paragraph (c)(7) of this section shall be expressed in ng/J or lb/MMBtu heat input and shall be used to calculate the boiler operating day daily arithmetic average emission concentrations. The 1-hour arithmetic averages shall be calculated using the data points required under § 60.13(e)(2) of subpart A of this part.
- (9) All valid CEMS data shall be used in calculating average emission concentrations even if the minimum CEMS data requirements of paragraph (c)(7) of this section are not met.
- (10) The CEMS shall be operated according to Performance Specification 11 in appendix B of this part.
- (11) During the correlation testing runs of the CEMS required by Performance Specification 11 in appendix B of this part, PM and O₂ (or CO₂) data shall be collected concurrently (or within a 30- to 60-minute period) by both the continuous emission monitors and performance tests conducted using the following test methods.
- (i) For PM, Method 5 or 5B of appendix A-3 of this part or Method 17 of appendix A-6 of this part shall be used; and
- (ii) For O₂ (or CO₂), Method 3A or 3B of appendix A-2 of this part, as applicable shall be used.
- (12) Quarterly accuracy determinations and daily calibration drift tests shall be performed in accordance with procedure 2 in appendix F of this part. Relative Response Audit's must be performed annually and Response Correlation Audits must be performed every 3 years.
- (13) When PM emissions data are not obtained because of CEMS breakdowns, repairs, calibration checks, and zero and span adjustments, emissions data shall be obtained by using other monitoring systems as approved by the Administrator or EPA Reference Method 19 of appendix A of this part to provide, as necessary, valid emissions data for a minimum of 75 percent of total operating hours on a 30-day rolling average.
- (14) As of January 1, 2012, and within 90 days after the date of completing each performance test, as defined in § 60.8, conducted to demonstrate compliance with this subpart, you must submit relative accuracy test audit (*i.e.*, reference method) data and performance test (*i.e.*, compliance test) data, except opacity data, electronically to EPA's Central Data Exchange (CDX) by using the Electronic Reporting Tool (ERT) (see http://www.epa.gov/ttn/chief/ert/ert_tool.html/) or other compatible electronic spreadsheet. Only data collected using test methods compatible with ERT are subject to this requirement to be submitted electronically into EPA's WebFIRE database.

(d) The owner or operator of an affected facility seeking to demonstrate compliance under § 60.43c(e)(4) shall follow the applicable procedures under § 60.48c(f). For residual oil-fired affected facilities, fuel supplier certifications are only allowed for facilities with heat input capacities between 2.9 and 8.7 MW (10 to 30 MMBtu/h).

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009; 76 FR 3523, Jan. 20, 2011; 77 FR 9463, Feb. 16, 2012]

§ 60.46c Emission monitoring for sulfur dioxide.

(a) Except as provided in paragraphs (d) and (e) of this section, the owner or operator of an affected facility subject to the SO₂ emission limits under § 60.42c shall install, calibrate, maintain, and operate a CEMS for measuring SO₂ concentrations and either O₂ or CO₂ concentrations at the outlet of the SO₂ control device (or the outlet of the steam generating unit if no SO₂ control device is used), and shall record the output of the system. The owner or operator of an affected facility subject to the percent reduction requirements under § 60.42c shall measure SO₂ concentrations and either O₂ or CO₂ concentrations at both the inlet and outlet of the SO₂ control device.

(b) The 1-hour average SO₂ emission rates measured by a CEMS shall be expressed in ng/J or lb/MMBtu heat input and shall be used to calculate the average emission rates under § 60.42c. Each 1-hour average SO₂ emission rate must be based on at least 30 minutes of operation, and shall be calculated using the data points required under § 60.13(h)(2). Hourly SO₂ emission rates are not calculated if the affected facility is operated less than 30 minutes in a 1-hour period and are not counted toward determination of a steam generating unit operating day.

(c) The procedures under § 60.13 shall be followed for installation, evaluation, and operation of the CEMS.

(1) All CEMS shall be operated in accordance with the applicable procedures under Performance Specifications 1, 2, and 3 of appendix B of this part.

(2) Quarterly accuracy determinations and daily calibration drift tests shall be performed in accordance with Procedure 1 of appendix F of this part.

(3) For affected facilities subject to the percent reduction requirements under § 60.42c, the span value of the SO₂ CEMS at the inlet to the SO₂ control device shall be 125 percent of the maximum estimated hourly potential SO₂ emission rate of the fuel combusted, and the span value of the SO₂ CEMS at the outlet from the SO₂ control device shall be 50 percent of the maximum estimated hourly potential SO₂ emission rate of the fuel combusted.

(4) For affected facilities that are not subject to the percent reduction requirements of § 60.42c, the span value of the SO₂ CEMS at the outlet from the SO₂ control device (or outlet of the steam generating unit if no SO₂ control device is used) shall be 125 percent of the maximum estimated hourly potential SO₂ emission rate of the fuel combusted.

(d) As an alternative to operating a CEMS at the inlet to the SO₂ control device (or outlet of the steam generating unit if no SO₂ control device is used) as required under paragraph (a) of this section, an owner or operator may elect to determine the average SO₂ emission rate by sampling the fuel prior to combustion. As an alternative to operating a CEMS at the outlet from the SO₂ control device (or outlet of the steam generating unit if no SO₂ control device is used) as required under paragraph (a) of this section, an owner or operator may elect to determine the average SO₂ emission rate by using Method 6B of appendix A of this part. Fuel sampling shall be conducted pursuant to either paragraph (d)(1) or (d)(2) of this section. Method 6B of appendix A of this part shall be conducted pursuant to paragraph (d)(3) of this section.

(1) For affected facilities combusting coal or oil, coal or oil samples shall be collected daily in an as-fired condition at the inlet to the steam generating unit and analyzed for sulfur content and heat content according to the Method 19 of appendix A of this part. Method 19 of appendix A of this part provides procedures for converting these measurements into the format to be used in calculating the average SO₂ input rate.

(2) As an alternative fuel sampling procedure for affected facilities combusting oil, oil samples may be collected from the fuel tank for each steam generating unit immediately after the fuel tank is filled and before any oil is combusted. The owner or operator of the affected facility shall analyze the oil sample to determine the sulfur content of the oil. If a partially empty fuel tank is refilled, a new sample and analysis of the fuel in the tank would be required upon filling. Results of the fuel analysis taken after each new shipment of oil is received shall be used as the daily value when

calculating the 30-day rolling average until the next shipment is received. If the fuel analysis shows that the sulfur content in the fuel tank is greater than 0.5 weight percent sulfur, the owner or operator shall ensure that the sulfur content of subsequent oil shipments is low enough to cause the 30-day rolling average sulfur content to be 0.5 weight percent sulfur or less.

(3) Method 6B of appendix A of this part may be used in lieu of CEMS to measure SO₂ at the inlet or outlet of the SO₂ control system. An initial stratification test is required to verify the adequacy of the Method 6B of appendix A of this part sampling location. The stratification test shall consist of three paired runs of a suitable SO₂ and CO₂ measurement train operated at the candidate location and a second similar train operated according to the procedures in § 3.2 and the applicable procedures in section 7 of Performance Specification 2 of appendix B of this part. Method 6B of appendix A of this part, Method 6A of appendix A of this part, or a combination of Methods 6 and 3 of appendix A of this part or Methods 6C and 3A of appendix A of this part are suitable measurement techniques. If Method 6B of appendix A of this part is used for the second train, sampling time and timer operation may be adjusted for the stratification test as long as an adequate sample volume is collected; however, both sampling trains are to be operated similarly. For the location to be adequate for Method 6B of appendix A of this part 24-hour tests, the mean of the absolute difference between the three paired runs must be less than 10 percent (0.10).

(e) The monitoring requirements of paragraphs (a) and (d) of this section shall not apply to affected facilities subject to § 60.42c(h) (1), (2), or (3) where the owner or operator of the affected facility seeks to demonstrate compliance with the SO₂ standards based on fuel supplier certification, as described under § 60.48c(f), as applicable.

(f) The owner or operator of an affected facility operating a CEMS pursuant to paragraph (a) of this section, or conducting as-fired fuel sampling pursuant to paragraph (d)(1) of this section, shall obtain emission data for at least 75 percent of the operating hours in at least 22 out of 30 successive steam generating unit operating days. If this minimum data requirement is not met with a single monitoring system, the owner or operator of the affected facility shall supplement the emission data with data collected with other monitoring systems as approved by the Administrator.

§ 60.47c Emission monitoring for particulate matter.

(a) Except as provided in paragraphs (c), (d), (e), and (f) of this section, the owner or operator of an affected facility combusting coal, oil, or wood that is subject to the opacity standards under § 60.43c shall install, calibrate, maintain, and operate a continuous opacity monitoring system (COMS) for measuring the opacity of the emissions discharged to the atmosphere and record the output of the system. The owner or operator of an affected facility subject to an opacity standard in § 60.43c(c) that is not required to use a COMS due to paragraphs (c), (d), (e), or (f) of this section that elects not to use a COMS shall conduct a performance test using Method 9 of appendix A-4 of this part and the procedures in § 60.11 to demonstrate compliance with the applicable limit in § 60.43c by April 29, 2011, within 45 days of stopping use of an existing COMS, or within 180 days after initial startup of the facility, whichever is later, and shall comply with either paragraphs (a)(1), (a)(2), or (a)(3) of this section. The observation period for Method 9 of appendix A-4 of this part performance tests may be reduced from 3 hours to 60 minutes if all 6-minute averages are less than 10 percent and all individual 15-second observations are less than or equal to 20 percent during the initial 60 minutes of observation.

(1) Except as provided in paragraph (a)(2) and (a)(3) of this section, the owner or operator shall conduct subsequent Method 9 of appendix A-4 of this part performance tests using the procedures in paragraph (a) of this section according to the applicable schedule in paragraphs (a)(1)(i) through (a)(1)(iv) of this section, as determined by the most recent Method 9 of appendix A-4 of this part performance test results.

(i) If no visible emissions are observed, a subsequent Method 9 of appendix A-4 of this part performance test must be completed within 12 calendar months from the date that the most recent performance test was conducted or within 45 days of the next day that fuel with an opacity standard is combusted, whichever is later;

(ii) If visible emissions are observed but the maximum 6-minute average opacity is less than or equal to 5 percent, a subsequent Method 9 of appendix A-4 of this part performance test must be completed within 6 calendar months from the date that the most recent performance test was conducted or within 45 days of the next day that fuel with an opacity standard is combusted, whichever is later;

(iii) If the maximum 6-minute average opacity is greater than 5 percent but less than or equal to 10 percent, a subsequent Method 9 of appendix A-4 of this part performance test must be completed within 3 calendar months from

the date that the most recent performance test was conducted or within 45 days of the next day that fuel with an opacity standard is combusted, whichever is later; or

(iv) If the maximum 6-minute average opacity is greater than 10 percent, a subsequent Method 9 of appendix A-4 of this part performance test must be completed within 45 calendar days from the date that the most recent performance test was conducted.

(2) If the maximum 6-minute opacity is less than 10 percent during the most recent Method 9 of appendix A-4 of this part performance test, the owner or operator may, as an alternative to performing subsequent Method 9 of appendix A-4 of this part performance tests, elect to perform subsequent monitoring using Method 22 of appendix A-7 of this part according to the procedures specified in paragraphs (a)(2)(i) and (ii) of this section.

(i) The owner or operator shall conduct 10 minute observations (during normal operation) each operating day the affected facility fires fuel for which an opacity standard is applicable using Method 22 of appendix A-7 of this part and demonstrate that the sum of the occurrences of any visible emissions is not in excess of 5 percent of the observation period (*i.e.* , 30 seconds per 10 minute period). If the sum of the occurrence of any visible emissions is greater than 30 seconds during the initial 10 minute observation, immediately conduct a 30 minute observation. If the sum of the occurrence of visible emissions is greater than 5 percent of the observation period (*i.e.*, 90 seconds per 30 minute period), the owner or operator shall either document and adjust the operation of the facility and demonstrate within 24 hours that the sum of the occurrence of visible emissions is equal to or less than 5 percent during a 30 minute observation (*i.e.*, 90 seconds) or conduct a new Method 9 of appendix A-4 of this part performance test using the procedures in paragraph (a) of this section within 45 calendar days according to the requirements in § 60.45c(a)(8).

(ii) If no visible emissions are observed for 10 operating days during which an opacity standard is applicable, observations can be reduced to once every 7 operating days during which an opacity standard is applicable. If any visible emissions are observed, daily observations shall be resumed.

(3) If the maximum 6-minute opacity is less than 10 percent during the most recent Method 9 of appendix A-4 of this part performance test, the owner or operator may, as an alternative to performing subsequent Method 9 of appendix A-4 performance tests, elect to perform subsequent monitoring using a digital opacity compliance system according to a site-specific monitoring plan approved by the Administrator. The observations shall be similar, but not necessarily identical, to the requirements in paragraph (a)(2) of this section. For reference purposes in preparing the monitoring plan, see OAQPS "Determination of Visible Emission Opacity from Stationary Sources Using Computer-Based Photographic Analysis Systems." This document is available from the U.S. Environmental Protection Agency (U.S. EPA); Office of Air Quality and Planning Standards; Sector Policies and Programs Division; Measurement Policy Group (D243-02), Research Triangle Park, NC 27711. This document is also available on the Technology Transfer Network (TTN) under Emission Measurement Center Preliminary Methods.

(b) All COMS shall be operated in accordance with the applicable procedures under Performance Specification 1 of appendix B of this part. The span value of the opacity COMS shall be between 60 and 80 percent.

(c) Owners and operators of an affected facilities that burn only distillate oil that contains no more than 0.5 weight percent sulfur and/or liquid or gaseous fuels with potential sulfur dioxide emission rates of 26 ng/J (0.060 lb/MMBtu) heat input or less and that do not use a post-combustion technology to reduce SO₂ or PM emissions and that are subject to an opacity standard in § 60.43c(c) are not required to operate a COMS if they follow the applicable procedures in § 60.48c(f).

(d) Owners or operators complying with the PM emission limit by using a PM CEMS must calibrate, maintain, operate, and record the output of the system for PM emissions discharged to the atmosphere as specified in § 60.45c(c). The CEMS specified in paragraph § 60.45c(c) shall be operated and data recorded during all periods of operation of the affected facility except for CEMS breakdowns and repairs. Data is recorded during calibration checks, and zero and span adjustments.

(e) Owners and operators of an affected facility that is subject to an opacity standard in § 60.43c(c) and that does not use post-combustion technology (except a wet scrubber) for reducing PM, SO₂ , or carbon monoxide (CO) emissions, burns only gaseous fuels or fuel oils that contain less than or equal to 0.5 weight percent sulfur, and is operated such that emissions of CO discharged to the atmosphere from the affected facility are maintained at levels less than or equal to 0.15 lb/MMBtu on a boiler operating day average basis is not required to operate a COMS.

Owners and operators of affected facilities electing to comply with this paragraph must demonstrate compliance according to the procedures specified in paragraphs (e)(1) through (4) of this section; or

(1) You must monitor CO emissions using a CEMS according to the procedures specified in paragraphs (e)(1)(i) through (iv) of this section.

(i) The CO CEMS must be installed, certified, maintained, and operated according to the provisions in § 60.58b(i)(3) of subpart Eb of this part.

(ii) Each 1-hour CO emissions average is calculated using the data points generated by the CO CEMS expressed in parts per million by volume corrected to 3 percent oxygen (dry basis).

(iii) At a minimum, valid 1-hour CO emissions averages must be obtained for at least 90 percent of the operating hours on a 30-day rolling average basis. The 1-hour averages are calculated using the data points required in § 60.13(h)(2).

(iv) Quarterly accuracy determinations and daily calibration drift tests for the CO CEMS must be performed in accordance with procedure 1 in appendix F of this part.

(2) You must calculate the 1-hour average CO emissions levels for each steam generating unit operating day by multiplying the average hourly CO output concentration measured by the CO CEMS times the corresponding average hourly flue gas flow rate and divided by the corresponding average hourly heat input to the affected source. The 24-hour average CO emission level is determined by calculating the arithmetic average of the hourly CO emission levels computed for each steam generating unit operating day.

(3) You must evaluate the preceding 24-hour average CO emission level each steam generating unit operating day excluding periods of affected source startup, shutdown, or malfunction. If the 24-hour average CO emission level is greater than 0.15 lb/MMBtu, you must initiate investigation of the relevant equipment and control systems within 24 hours of the first discovery of the high emission incident and, take the appropriate corrective action as soon as practicable to adjust control settings or repair equipment to reduce the 24-hour average CO emission level to 0.15 lb/MMBtu or less.

(4) You must record the CO measurements and calculations performed according to paragraph (e) of this section and any corrective actions taken. The record of corrective action taken must include the date and time during which the 24-hour average CO emission level was greater than 0.15 lb/MMBtu, and the date, time, and description of the corrective action.

(f) An owner or operator of an affected facility that is subject to an opacity standard in § 60.43c(c) is not required to operate a COMS provided that the affected facility meets the conditions in either paragraphs (f)(1), (2), or (3) of this section.

(1) The affected facility uses a fabric filter (baghouse) as the primary PM control device and, the owner or operator operates a bag leak detection system to monitor the performance of the fabric filter according to the requirements in section § 60.48Da of this part.

(2) The affected facility uses an ESP as the primary PM control device, and the owner or operator uses an ESP predictive model to monitor the performance of the ESP developed in accordance and operated according to the requirements in section § 60.48Da of this part.

(3) The affected facility burns only gaseous fuels and/or fuel oils that contain no greater than 0.5 weight percent sulfur, and the owner or operator operates the unit according to a written site-specific monitoring plan approved by the permitting authority. This monitoring plan must include procedures and criteria for establishing and monitoring specific parameters for the affected facility indicative of compliance with the opacity standard. For testing performed as part of this site-specific monitoring plan, the permitting authority may require as an alternative to the notification and reporting requirements specified in §§ 60.8 and 60.11 that the owner or operator submit any deviations with the excess emissions report required under § 60.48c(c).

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009; 76 FR 3523, Jan. 20, 2011; 77 FR 9463, Feb. 16, 2012]

§ 60.48c Reporting and recordkeeping requirements.

(a) The owner or operator of each affected facility shall submit notification of the date of construction or reconstruction and actual startup, as provided by § 60.7 of this part. This notification shall include:

(1) The design heat input capacity of the affected facility and identification of fuels to be combusted in the affected facility.

(2) If applicable, a copy of any federally enforceable requirement that limits the annual capacity factor for any fuel or mixture of fuels under § 60.42c, or § 60.43c.

(3) The annual capacity factor at which the owner or operator anticipates operating the affected facility based on all fuels fired and based on each individual fuel fired.

(4) Notification if an emerging technology will be used for controlling SO₂ emissions. The Administrator will examine the description of the control device and will determine whether the technology qualifies as an emerging technology. In making this determination, the Administrator may require the owner or operator of the affected facility to submit additional information concerning the control device. The affected facility is subject to the provisions of § 60.42c(a) or (b)(1), unless and until this determination is made by the Administrator.

(b) The owner or operator of each affected facility subject to the SO₂ emission limits of § 60.42c, or the PM or opacity limits of § 60.43c, shall submit to the Administrator the performance test data from the initial and any subsequent performance tests and, if applicable, the performance evaluation of the CEMS and/or COMS using the applicable performance specifications in appendix B of this part.

(c) In addition to the applicable requirements in § 60.7, the owner or operator of an affected facility subject to the opacity limits in § 60.43c(c) shall submit excess emission reports for any excess emissions from the affected facility that occur during the reporting period and maintain records according to the requirements specified in paragraphs (c)(1) through (3) of this section, as applicable to the visible emissions monitoring method used.

(1) For each performance test conducted using Method 9 of appendix A-4 of this part, the owner or operator shall keep the records including the information specified in paragraphs (c)(1)(i) through (iii) of this section.

(i) Dates and time intervals of all opacity observation periods;

(ii) Name, affiliation, and copy of current visible emission reading certification for each visible emission observer participating in the performance test; and

(iii) Copies of all visible emission observer opacity field data sheets;

(2) For each performance test conducted using Method 22 of appendix A-4 of this part, the owner or operator shall keep the records including the information specified in paragraphs (c)(2)(i) through (iv) of this section.

(i) Dates and time intervals of all visible emissions observation periods;

(ii) Name and affiliation for each visible emission observer participating in the performance test;

(iii) Copies of all visible emission observer opacity field data sheets; and

(iv) Documentation of any adjustments made and the time the adjustments were completed to the affected facility operation by the owner or operator to demonstrate compliance with the applicable monitoring requirements.

(3) For each digital opacity compliance system, the owner or operator shall maintain records and submit reports according to the requirements specified in the site-specific monitoring plan approved by the Administrator

(d) The owner or operator of each affected facility subject to the SO₂ emission limits, fuel oil sulfur limits, or percent reduction requirements under § 60.42c shall submit reports to the Administrator.

(e) The owner or operator of each affected facility subject to the SO₂ emission limits, fuel oil sulfur limits, or percent reduction requirements under § 60.42c shall keep records and submit reports as required under paragraph (d) of this section, including the following information, as applicable.

(1) Calendar dates covered in the reporting period.

(2) Each 30-day average SO₂ emission rate (ng/J or lb/MMBtu), or 30-day average sulfur content (weight percent), calculated during the reporting period, ending with the last 30-day period; reasons for any noncompliance with the emission standards; and a description of corrective actions taken.

(3) Each 30-day average percent of potential SO₂ emission rate calculated during the reporting period, ending with the last 30-day period; reasons for any noncompliance with the emission standards; and a description of the corrective actions taken.

(4) Identification of any steam generating unit operating days for which SO₂ or diluent (O₂ or CO₂) data have not been obtained by an approved method for at least 75 percent of the operating hours; justification for not obtaining sufficient data; and a description of corrective actions taken.

(5) Identification of any times when emissions data have been excluded from the calculation of average emission rates; justification for excluding data; and a description of corrective actions taken if data have been excluded for periods other than those during which coal or oil were not combusted in the steam generating unit.

(6) Identification of the F factor used in calculations, method of determination, and type of fuel combusted.

(7) Identification of whether averages have been obtained based on CEMS rather than manual sampling methods.

(8) If a CEMS is used, identification of any times when the pollutant concentration exceeded the full span of the CEMS.

(9) If a CEMS is used, description of any modifications to the CEMS that could affect the ability of the CEMS to comply with Performance Specifications 2 or 3 of appendix B of this part.

(10) If a CEMS is used, results of daily CEMS drift tests and quarterly accuracy assessments as required under appendix F, Procedure 1 of this part.

(11) If fuel supplier certification is used to demonstrate compliance, records of fuel supplier certification as described under paragraph (f)(1), (2), (3), or (4) of this section, as applicable. In addition to records of fuel supplier certifications, the report shall include a certified statement signed by the owner or operator of the affected facility that the records of fuel supplier certifications submitted represent all of the fuel combusted during the reporting period.

(f) Fuel supplier certification shall include the following information:

(1) For distillate oil:

(i) The name of the oil supplier;

(ii) A statement from the oil supplier that the oil complies with the specifications under the definition of distillate oil in § 60.41c; and

(iii) The sulfur content or maximum sulfur content of the oil.

(2) For residual oil:

(i) The name of the oil supplier;

(ii) The location of the oil when the sample was drawn for analysis to determine the sulfur content of the oil, specifically including whether the oil was sampled as delivered to the affected facility, or whether the sample was drawn from oil in storage at the oil supplier's or oil refiner's facility, or other location;

(iii) The sulfur content of the oil from which the shipment came (or of the shipment itself); and

(iv) The method used to determine the sulfur content of the oil.

(3) For coal:

(i) The name of the coal supplier;

(ii) The location of the coal when the sample was collected for analysis to determine the properties of the coal, specifically including whether the coal was sampled as delivered to the affected facility or whether the sample was collected from coal in storage at the mine, at a coal preparation plant, at a coal supplier's facility, or at another location. The certification shall include the name of the coal mine (and coal seam), coal storage facility, or coal preparation plant (where the sample was collected);

(iii) The results of the analysis of the coal from which the shipment came (or of the shipment itself) including the sulfur content, moisture content, ash content, and heat content; and

(iv) The methods used to determine the properties of the coal.

(4) For other fuels:

(i) The name of the supplier of the fuel;

(ii) The potential sulfur emissions rate or maximum potential sulfur emissions rate of the fuel in ng/J heat input; and

(iii) The method used to determine the potential sulfur emissions rate of the fuel.

(g)(1) Except as provided under paragraphs (g)(2) and (g)(3) of this section, the owner or operator of each affected facility shall record and maintain records of the amount of each fuel combusted during each operating day.

(2) As an alternative to meeting the requirements of paragraph (g)(1) of this section, the owner or operator of an affected facility that combusts only natural gas, wood, fuels using fuel certification in § 60.48c(f) to demonstrate compliance with the SO₂ standard, fuels not subject to an emissions standard (excluding opacity), or a mixture of these fuels may elect to record and maintain records of the amount of each fuel combusted during each calendar month.

(3) As an alternative to meeting the requirements of paragraph (g)(1) of this section, the owner or operator of an affected facility or multiple affected facilities located on a contiguous property unit where the only fuels combusted in any steam generating unit (including steam generating units not subject to this subpart) at that property are natural gas, wood, distillate oil meeting the most current requirements in § 60.42C to use fuel certification to demonstrate compliance with the SO₂ standard, and/or fuels, excluding coal and residual oil, not subject to an emissions standard (excluding opacity) may elect to record and maintain records of the total amount of each steam generating unit fuel delivered to that property during each calendar month.

(h) The owner or operator of each affected facility subject to a federally enforceable requirement limiting the annual capacity factor for any fuel or mixture of fuels under § 60.42c or § 60.43c shall calculate the annual capacity factor individually for each fuel combusted. The annual capacity factor is determined on a 12-month rolling average basis with a new annual capacity factor calculated at the end of the calendar month.

(i) All records required under this section shall be maintained by the owner or operator of the affected facility for a period of two years following the date of such record.

(j) The reporting period for the reports required under this subpart is each six-month period. All reports shall be submitted to the Administrator and shall be postmarked by the 30th day following the end of the reporting period.

[72 FR 32759, June 13, 2007, as amended at 74 FR 5091, Jan. 28, 2009]

**Indiana Department of Environmental Management
Office of Air Quality**

Technical Support Document (TSD) for an Exemption Transitioning to a
Registration

Source Description and Location

Source Name: Plumrose USA, Inc.
Source Location: 24401 County Road 45, Elkhart, Indiana 46516
County: Elkhart
SIC Code: 2011 (Meat Packing Plants)
Registration No.: R039-35017-00352
Permit Reviewer: Charles Sullivan

On October 8, 2014, the Office of Air Quality (OAQ) received an application from Plumrose USA, Inc. related to the construction and operation of new emission units and the continued operation of an existing meat processing and packaging facility.

Existing Approvals

The source has been operating under Exemption No. 039-12939-00352, issued on January 26, 2001. Due to this application, the source is transitioning from an Exemption to a Registration.

County Attainment Status

The source is located in Elkhart County.

Pollutant	Designation
SO ₂	Better than national standards.
CO	Unclassifiable or attainment effective November 15, 1990.
O ₃	Unclassifiable or attainment effective July 20, 2012, for the 2008 8-hour ozone standard. ¹
PM _{2.5}	Unclassifiable or attainment effective April 5, 2005, for the annual PM _{2.5} standard.
PM _{2.5}	Unclassifiable or attainment effective December 13, 2009, for the 24-hour PM _{2.5} standard.
PM ₁₀	Unclassifiable effective November 15, 1990.
NO ₂	Cannot be classified or better than national standards.
Pb	Unclassifiable or attainment effective December 31, 2011.

¹Attainment effective October 18, 2000, for the 1-hour ozone standard for the South Bend-Elkhart area, including Elkhart County, and is a maintenance area for the 1-hour National Ambient Air Quality Standards (NAAQS) for purposes of 40 CFR 51, Subpart X*. The 1-hour standard was revoked effective June 15, 2005.

- (a) Ozone Standards
 Volatile organic compounds (VOC) and Nitrogen Oxides (NO_x) are regulated under the Clean Air Act (CAA) for the purposes of attaining and maintaining the National Ambient Air Quality Standards (NAAQS) for ozone. Therefore, VOC and NO_x emissions are considered when evaluating the rule applicability relating to ozone. Elkhart County has been designated as attainment or unclassifiable for ozone. Therefore, VOC and NO_x emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2.

- (b) **PM_{2.5}**
Elkhart County has been classified as attainment for PM_{2.5}. Therefore, direct PM_{2.5}, SO₂, and NO_x emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2.
- (c) **Other Criteria Pollutants**
Elkhart County has been classified as attainment or unclassifiable in Indiana for all other criteria pollutants. Therefore, these emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2.

Fugitive Emissions

The fugitive emissions of criteria pollutants, hazardous air pollutants, and greenhouse gases are counted toward the determination of 326 IAC 2-5.1-2 (Registrations) applicability.

Background and Description of Emission Units and Pollution Control Equipment

The Office of Air Quality (OAQ) has reviewed an application, submitted by Plumrose USA, Inc. on October 8, 2014, relating to operation of a meat processing facility. From a recent environmental assessment the source indicated that the rated capacity for the boilers and other fuel burning units were higher than reported due to a misinterpretation of units. There has also been changes and additions to the fuel burning equipment utilized.

The source consists of the following existing emission unit:

- (a) One (1) batch Vector smokehouse, identified as SH-1 constructed in 1989, with a maximum meat throughput 1.5 tons per hour exhausting to stack S-1.
- (b) One (1) batch Alkar smokehouse, identified as SH-3, constructed in 1977, with a maximum meat throughput 0.75 tons per hour exhausting to stack S-3.
- (c) One (1) batch Alkar smokehouse, identified as SH-4, constructed in 1977, with a maximum meat throughput 0.75 tons per hour exhausting to stack S-4.
- (d) One (1) parts cleaning operation, identified as Parts Cleaner, constructed prior to 2001, used only with wipe cleaning activities, such as using a rag containing halogenated solvent or a spray cleaner containing halogenated solvent.

Unregistered Emission Units and Pollution Control Equipment

The source consists of the following unregistered emission units:

- (a) One (1) batch Enviropack smokehouse, identified as SH-2, constructed in 2002, with a maximum meat throughput of 2.0 tons per hour exhausting to two stacks S-2 and S-5.
- (b) One (1) liquid smoke operation, constructed in 2011, with a maximum meat throughput of 5 tons per hour, which can be utilized in any of the four (4) existing smokehouses and exhausts through the five associated stacks (S-1 through S-5).
- (c) One (1) natural gas-fired boiler, identified as Boiler 1, constructed in 1972, with a maximum capacity of 13.8 MMBtu/hr, exhausting outdoors.
- (d) One (1) natural gas-fired boiler, identified as Boiler 2, constructed in 2012, with a maximum capacity of 10.5 MMBtu/hr, exhausting outdoors.

Under 40 CFR 60, Subpart Dc, Boiler 2 is considered an affected facility.

- (e) One (1) natural gas-fired air makeup unit, Identified as Air Makeup 1, constructed in 2007, with a maximum capacity of 0.275 MMBtu/hr, exhausting outdoors.
- (f) One (1) clothes dryer, identified as Clothes Dryer, constructed in 2013, with a maximum capacity of 0.165 MMBtu/hr, exhausting outdoors.
- (g) Paved and Unpaved Roadways.

Enforcement Issues

IDEM is aware that equipment has been constructed and operated prior to obtaining a registration. IDEM is reviewing this matter and will take the appropriate action. This proposed approval is intended to satisfy the requirements of the registration rules.

Emission Calculations

See Appendix A of this TSD for detailed emission calculations.

Permit Level Determination – Registration

The following table reflects the unlimited potential to emit (PTE) of the entire source before controls. Control equipment is not considered federally enforceable until it has been required in a federally enforceable permit.

Process/ Emission Unit	Potential To Emit of the Entire Source (tons/year)								
	PM	PM10*	PM2.5*	SO ₂	NO _x	VOC	CO	Total HAPs	Worst Single HAP
NG - Boilers	0.20	0.79	0.79	0.06	10.43	0.57	8.77	0.20	0.19 Hexane
NG - Heaters	0.004	0.01	0.01	0.001	0.19	0.01	0.16	0.004	0.003 Hexane
NG - Smoke Houses	0.09	0.36	0.36	0.03	4.70	0.26	3.95	0.09	0.08 Hexane
Smokehouses	15.09	15.09	15.09	NA	NA	15.02	NA	0.37	0.37 Formaldehyde
Parts Cleaning Operation	NA	NA	NA	NA	NA	0.86	NA	0.86	0.86 Trichloroethylene
Fugitive Emissions									
Unpaved Roadways	3.10	1.14	0.08	NA	NA	NA	NA	NA	NA
Paved Roadway	4.85	0.97	0.24	NA	NA	NA	NA	NA	NA
Total PTE of Entire Source	23.33	18.37	16.57	0.09	15.33	16.72	12.87	1.51	0.86 Trichloroethylene
Exemptions Levels**	< 5	< 5	< 5	< 10	< 10	< 10	< 25	< 25	< 10
Registration Levels**	< 25	< 25	< 25	< 25	< 25	< 25	< 100	< 25	< 10

negl. = negligible
 *Under the Part 70 Permit program (40 CFR 70), PM10 and PM2.5, not particulate matter (PM), are each considered as a regulated air pollutant".

- (a) The potential to emit (PTE) (as defined in 326 IAC 2-1.1-1) of PM, PM10, NOx, VOC, and CO are within the ranges listed in 326 IAC 2-5.1-2(a)(1). The PTE of all other regulated criteria pollutants are less than the ranges listed in 326 IAC 2-5.1-2(a)(1). Therefore, the source is subject to the provisions of 326 IAC 2-5.1-2 (Registrations). A Registration will be issued.
- (b) The potential to emit (PTE) (as defined in 326 IAC 2-1.1-1) of any single HAP is less than ten (10) tons per year and the PTE of a combination of HAPs is less than twenty-five (25) tons per year. Therefore, this source is an area source under Section 112 of the Clean Air Act (CAA) and not subject to the provisions of 326 IAC 2-7.

Federal Rule Applicability Determination

New Source Performance Standards (NSPS)

- (a) The natural gas-fired boiler, identified as Boiler 2, constructed in 2012 is subject to the New Source Performance Standards for Small Industrial-Commercial-Institutional Steam Generating Units (40 CFR 60, Subpart Dc) (326 IAC 12), because the steam generating unit was constructed or modified after June 19, 1984, and has a maximum heat input capacity of less than 100 MMBtu/hr but greater than 10 MMBtu/hr.

Applicable portions of the NSPS are the following:

- (1) 40 CFR 60.40c
- (2) 40 CFR 60.41c
- (3) 40 CFR 60.48c(a)
- (4) 40 CFR 60.48c(g)
- (5) 40 CFR 60.48c(i)

The requirements of 40 CFR Part 60, Subpart A – General Provisions, which are incorporated as 326 IAC 12-1, apply to the natural gas-fired boiler (Boiler 2), except as otherwise specified in 40 CFR 60, Subpart Dc.

- (b) The requirements of the New Source Performance Standards (NSPS) for Small Industrial-Commercial-Institutional Steam Generating Units (40 CFR Part 60, Subpart Dc) (326 IAC 12) are not included in the permit for the natural gas-fired boiler, identified as Boiler 1, since this emission unit was constructed prior to June 19, 1984.
- (c) There are no other New Source Performance Standards (NSPS) (326 IAC 12 and 40 CFR Part 60) included in the Registration.

National Emission Standards for Hazardous Air Pollutants (NESHAP)

- (d) The requirements of the National Emission Standards for Hazardous Air Pollutants (NESHAPs) for Industrial, Commercial, and Institutional Boilers and Process Heaters 40 CFR 63, Subpart DDDDD (63.7480 through 63.7575) (326 IAC 20-95), are not included in the Registration for the natural gas-fired units, because this source is not a major source of HAPs.
- (e) The requirements of the National Emission Standards for Hazardous Air Pollutants (NESHAPs) for Industrial, Commercial, and Institutional Boilers Area Sources, 40 CFR 63, Subpart JJJJJJ, are not included in the Registration for the natural gas-fired boilers, (Unit IDs Boiler 1 and Boiler 2) because each unit is a gas-fired boiler, as defined by 40 CFR 63.11237, which is specifically exempted from this rule under 40 CFR 63.11195(e).
- (f) The requirements of the National Emission Standards for Hazardous Air Pollutants for Halogenated Solvent Cleaning, 40 CFR 63, Subpart T, are not included in the Registration for the parts degreaser because the unit is used only with wipe cleaning activities, such as using a rag containing halogenated solvent or a spray cleaner containing halogenated solvent which is not covered under provisions § 63.460 of this subpart.

- (g) There are no National Emission Standards for Hazardous Air Pollutants (NESHAPs) (326 IAC 14, 326 IAC 20 and 40 CFR Part 63) included in the Registration.

Compliance Assurance Monitoring (CAM)

- (h) Pursuant to 40 CFR 64.2, Compliance Assurance Monitoring (CAM) is not included in the registration, because the unlimited potential to emit of the source is less than the Title V major source thresholds and the source is not required to obtain a Part 70 or Part 71 permit.

State Rule Applicability Determination

The following state rules are applicable to the source:

- (a) 326 IAC 2-5.1-2 (Registrations)
Registration applicability is discussed under the Permit Level Determination – Registration section above.
- (b) 326 IAC 2-4.1 (Major Sources of Hazardous Air Pollutants (HAP))
The potential to emit of any single HAP is less than ten (10) tons per year and the potential to emit of a combination of HAPs is less than twenty-five (25) tons per year. Therefore, this source is an area source under Section 112 of the Clean Air Act (CAA) and not subject to the provisions of 326 IAC 2-4.1.
- (c) 326 IAC 2-6 (Emission Reporting)
Pursuant to 326 IAC 2-6-1, this source is not subject to this rule, because it is not required to have an operating permit under 326 IAC 2-7 (Part 70), it is not located in Lake, Porter, or LaPorte County, and it does not emit lead into the ambient air at levels equal to or greater than 5 tons per year. Therefore, 326 IAC 2-6 does not apply.
- (d) 326 IAC 5-1 (Opacity Limitations)
Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-3 (Temporary Alternative Opacity Limitations), opacity shall meet the following, unless otherwise stated in this registration:
- (1) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
 - (2) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.
- (e) 326 IAC 6-4 (Fugitive Dust Emissions Limitations)
Pursuant to 326 IAC 6-4 (Fugitive Dust Emissions Limitations), the source shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4.
- (f) 326 IAC 6-5 (Fugitive Particulate Matter Emission Limitations)
The source is not subject to the requirements of 326 IAC 6-5, because the source does not have potential fugitive particulate emissions greater than 25 tons per year. Therefore, 326 IAC 6-5 does not apply.
- (h) 326 IAC 8-1-6 (VOC Rules: General Reduction Requirements for New Facilities)
Each of the emission units at this source is not subject to the requirements of 326 IAC 8-1-6, since the unlimited VOC potential emissions from each emission unit is less than twenty-five (25) tons per year.

- (i) 326 IAC 12 (New Source Performance Standards)
See Federal Rule Applicability Section of this TSD.
- (j) 326 IAC 20 (Hazardous Air Pollutants)
See Federal Rule Applicability Section of this TSD.

Boiler 1 & Boiler 2

- (k) 326 IAC 6-2 (Particulate Emission Limitations for Sources of Indirect Heating)
Pursuant to 326 IAC 6-2-1(c), indirect heating facilities that were existing and in operation, or received a permit to construct, prior to September 21, 1983 and which are not located in Lake, Porter, Marion, Boone, Hamilton, Hendricks, Johnson, Morgan, Shelby, or Hancock county are subject to the requirements of 326 IAC 6-2-3. The one (1) natural gas-fired boiler, identified as Boiler 1, was constructed prior to September 21, 1983 and is located in Elkhart County. Pursuant to 326 IAC 6-2-3(a), particulate emissions from Boiler 1 shall be limited by the following equation:

$$Pt = \frac{C \times a \times h}{76.5 \times Q^{0.75} \times N^{0.25}} = \frac{(50)(0.67)(29)}{76.5(13.8)^{0.75}(1)^{0.25}} = 1.77 \text{ lbs/MMBtu}$$

where

- C = 50 u/m³
- Pt = emission rate limit (lbs/MMBtu)
- Q = total source heat input capacity (MMBtu/hr) (13.8)
- N = number of stacks (1)
- a = plume rise factor (0.67)
- h = stack height (ft) (29)

Pursuant to 326 IAC 6-2-3(d) particulate emissions from all facilities used for indirect heating purposes which were existing and in operation between June 8, 1972 and September 21, 1983, shall in no case exceed 0.8 lb/MMBtu heat input.

The lb/MMBtu emission rate from Boiler 1 was calculated as follows:

$$1.9 \text{ lb/MMCF} \times 1 \text{ MMCF} / 1,020 \text{ MMBtu} = 0.0019 \text{ lb/MMBtu}$$

Therefore, the one (1) natural gas-fired boiler, identified as Boiler 1, is capable of complying with this limit without the use of a control device.

- (l) 326 IAC 6-2-4 (Emission limitations for facilities specified in 326 IAC 6-2-1(d))
Pursuant to 326 IAC 6-2-1(d), indirect heating facilities which received permit to construct after September 21, 1983 are subject to the requirements of 326 IAC 6-2-4. Boiler 2 was constructed in 2012. Pursuant to 326 IAC 6-2-4, particulate matter emissions from Boiler 2 shall be limited as follows:

$$PT = \frac{1.09}{Q^{0.26}} = \frac{1.09}{24.3^{0.26}} = 0.48 \text{ lb/MMBtu}$$

Where:

- Pt = Pounds of particulate matter emitted per million British thermal units (lb/MMBtu).
- Q = Total source maximum operating capacity rating in MMBtu/hr heat input. The maximum operating capacity rating is defined as the maximum capacity at which the facility is operated or the nameplate capacity, whichever is specified in the facility's permit application, except when some lower capacity is contained in the facility's operation permit; in which case, the capacity specified in the operation.

The lb/MMBtu emission rate from Boiler 2 was calculated as follows:

$$1.9 \text{ lb/MMCF} \times 1 \text{ MMCF} / 1,020 \text{ MMBtu} = 0.0019 \text{ lb/MMBtu}$$

Therefore, the one (1) natural gas-fired boiler, identified as Boiler 2, is capable of complying with this limit without the use of a control device.

- (m) 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes)
Each of the natural gas-fired boilers at this source is exempt from the requirements of 326 IAC 6-3, because, pursuant to 326 IAC 1-2-59, liquid and gaseous fuels and combustion air are not considered as part of the process weight. In addition, pursuant to 326 IAC 6-3-1(b)(14), each of the natural gas-fired boilers at this source is also exempt from the requirements of 326 IAC 6-3, because they each have potential particulate emissions of less than five hundred fifty one thousandths (0.551) pound per hour.

Smokehouses (SH-1 through SH-4)

- (n) 326 IAC 6-3-2 (Particulate Emission Limitations for Manufacturing Processes)
Pursuant to 326 IAC 6-3-2, the particulate matter (PM) from the smokehouses identified as SMH-1 through SMH-4 shall not exceed the particulate emission limits as contained in the table below:

Emission Unit	Process Weight Rate (tons/hr)	326 IAC 6-3-2 Limit (lbs/hr)
Smokehouse SH-1	1.5	5.38
Smokehouse SH-2	2.0	6.52
Smokehouse SH-3	0.75	3.38
Smokehouse SH-4	0.75	3.38

The pound per hour limitations were calculated with the following equation:

Interpolation of the data for the process weight rate up to sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 4.10 P^{0.67} \quad \text{where } E = \text{rate of emission in pounds per hour and} \\ P = \text{process weight rate in tons per hour}$$

Based on the potential to emit calculations, no control device is needed for the smokehouses to comply with this limit.

Natural Gas-Fired Heater Units

- (o) 326 IAC 6-2 (Particulate Emission Limitations for Sources of Indirect Heating)
The two (2) natural gas-fired heater units, identified as Air Makeup 1 and Clothes Dryer, are not subject to this rule, since they are not sources of indirect heating.
- (p) 326 IAC 6-3 (Particulate Emission Limitations for Manufacturing Processes)
Each of the natural gas-fired heater units at this source is exempt from the requirements of 326 IAC 6-3, because, pursuant to 326 IAC 1-2-59, liquid and gaseous fuels and combustion air are not considered as part of the process weight. In addition, pursuant to 326 IAC 6-3-1(b)(14), each of the natural gas-fired heater units at this source is also exempt from the requirements of 326 IAC 6-3, because they each have potential particulate emissions of less than five hundred fifty one thousandths (0.551) pound per hour.
- (q) 326 IAC 7-1.1 (Sulfur Dioxide Emission Limitations)
The natural gas-fired heater units are not subject to 326 IAC 7-1.1, since they each have potential sulfur dioxide emissions of less than twenty-five (25) tons per year and ten (10) pounds per hour.

Parts Cleaning Operation

- (r) 326 IAC 6-3 (Particulate Emission Limitations for Manufacturing Processes)
Pursuant to 326 IAC 6-3-1(b)(14), the parts cleaning operation is exempt from the requirements of 326 IAC 6-3, since the potential particulate emissions are less than five hundred fifty-one (0.551) pound per hour.
- (s) 326 IAC 8-3 (Organic Solvent Emission Limitations)
The requirements of 326 IAC 8-3 are not applicable to the parts cleaning operation since the operation is not considered a cold cleaner degreaser, open top vapor degreaser, or conveyORIZED degreaser. The operation consists only of wipe cleaning activities, such as using a rag containing halogenated solvent or a spray cleaner containing halogenated solvent.

Conclusion and Recommendation

Unless otherwise stated, information used in this review was derived from the application and additional information submitted by the applicant. An application for the purposes of this review was received on October 8, 2014.

The operation of this source shall be subject to the conditions of the attached proposed Registration No. R039-35017-00352. The staff recommends to the Commissioner that this Registration be approved.

IDEM Contact

- (a) Questions regarding this proposed registration can be directed to Charles Sullivan at the Indiana Department Environmental Management, Office of Air Quality, Permits Branch, 100 North Senate Avenue, MC 61-53 IGCN 1003, Indianapolis, Indiana 46204-2251 or by telephone at (317) 232-8422 or toll free at 1-800-451-6027 extension 2-8422.
- (b) A copy of the findings is available on the Internet at: <http://www.in.gov/ai/appfiles/idem-caats/>
- (c) For additional information about air permits and how the public and interested parties can participate, refer to the IDEM Permit Guide on the Internet at: <http://www.in.gov/idem/5881.htm>; and the Citizens' Guide to IDEM on the Internet at: <http://www.in.gov/idem/6900.htm>.

**Appendix A: Emission Calculations
Emissions Summary**

Company Name: Plumrose USA, Inc.
Address City IN Zip: 24402 County Road 45, Elkhart, IN 46516
Permit Number: R039-35017-00352
Pit ID: 039-00352
Reviewer: C. Sullivan
Date: 11/19/2014

Unlimited/Uncontrolled Potential to Emit (tons/yr)										
Emission Unit	PM	PM10	PM2.5	SO ₂	NOx	VOC	CO	Total HAPs	Highest Single HAP	
Natural Gas-fired Boilers	0.20	0.79	0.79	0.06	10.43	0.57	8.77	0.20	0.19	Hexane
Natural Gas-fired Heaters	0.004	0.01	0.01	0.001	0.19	0.01	0.16	0.004	0.003	Hexane
Natural Gas-fired Smokehouses	0.09	0.36	0.36	0.03	4.70	0.26	3.95	0.09	0.08	Hexane
Smokehouses	15.09	15.09	15.09	--	--	15.02	--	0.37	0.37	Formaldehyde
Parts Cleaner	--	--	--	--	--	0.86	--	0.86	0.86	Trichloroethylene
Unpaved Roadways	3.10	1.14	0.08							
Paved Roadways	4.85	0.97	0.24	--	--	--	--	--	--	
Total	23.33	18.37	16.57	0.09	15.33	16.72	12.87	1.51	0.86	Trichloroethylene

Appendix A: Emissions Calculations
Natural Gas Combustion Only
MM BTU/HR <100
Natural Gas-Fired Combustion Units

Company Name: Plumrose USA, Inc.
Address City IN Zip: 24402 County Road 45, Elkhart, IN 46516
Permit Number: R039-35017-00352
Plt ID: 039-00352
Reviewer: C. Sullivan
Date: 11/19/2014

Boilers

Unit ID	Unit	Number of Units	Heat Input Capacity (MMBtu/hr)	Total Input Capacity (MMBtu/hr)	Year Installed
Cyclotherm	Cyclotherm Boiler	1	13.8	13.8	1972
Superior	Superior Boiler	1	10.5	10.5	2012
Totals		2		24.30	

Smokehouses

Unit ID	Unit	Number of Units	Heat Input Capacity (MMBtu/hr)	Total Input Capacity (MMBtu/hr)	Year Installed
Alkar	Alkar Smoke Houses	2	2.75	5.5	1977
Vector	Vector Smoke House	1	3.85	3.85	1989
Enviropack	Enviropack Smoke house	1	1.6	1.6	2002
Totals		4		10.95	

Heaters

Unit ID	Unit	Number of Units	Heat Input Capacity (MMBtu/hr)	Total Input Capacity (MMBtu/hr)	Year Installed
Air Makeup 1	Air Makeup	1	0.275	0.275	2007
Clothes Dryer	Clothes Dryer	1	0.165	0.165	2013
Totals		2		0.44	

**Appendix A: Emissions Calculations
Natural Gas Combustion Only
MM BTU/HR <100**

Company Name: Plumrose USA, Inc.
Address City IN Zip: 24402 County Road 45, Elkhart, IN 46516
Permit Number: R039-35017-00352
Plt ID: 039-00352
Reviewer: C. Sullivan
Date: 11/19/2014
NG - Boilers

Heat Input Capacity MMBtu/hr	HHV mmBtu mmscf	Potential Throughput MMCF/yr
24.3	1020	208.7

Emission Factor in lb/MMCF	Pollutant						
	PM*	PM10*	direct PM2.5*	SO2	NOx	VOC	CO
	1.9	7.6	7.6	0.6	100 **see below	5.5	84
Potential Emission in tons/yr	0.2	0.8	0.8	0.1	10.4	0.6	8.8

*PM emission factor is filterable PM only. PM10 emission factor is filterable and condensable PM10 combined.

PM2.5 emission factor is filterable and condensable PM2.5 combined.

**Emission Factors for NOx: Uncontrolled = 100, Low NOx Burner = 50, Low NOx Burners/Flue gas recirculation = 32

Methodology

All emission factors are based on normal firing.

MMBtu = 1,000,000 Btu

MMCF = 1,000,000 Cubic Feet of Gas

Emission Factors are from AP 42, Chapter 1.4, Tables 1.4-1, 1.4-2, 1.4-3, SCC #1-02-006-02, 1-01-006-02, 1-03-006-02, and 1-03-006-03

Potential Throughput (MMCF) = Heat Input Capacity (MMBtu/hr) x 8,760 hrs/yr x 1 MMCF/1,020 MMBtu

Emission (tons/yr) = Throughput (MMCF/yr) x Emission Factor (lb/MMCF)/2,000 lb/ton

HAPS Calculations

Emission Factor in lb/MMcf	HAPs - Organics					Total - Organics
	Benzene	Dichlorobenzene	Formaldehyde	Hexane	Toluene	
	2.1E-03	1.2E-03	7.5E-02	1.8E+00	3.4E-03	
Potential Emission in tons/yr	2.191E-04	1.252E-04	7.826E-03	1.878E-01	3.548E-04	1.963E-01

Emission Factor in lb/MMcf	HAPs - Metals					Total - Metals
	Lead	Cadmium	Chromium	Manganese	Nickel	
	5.0E-04	1.1E-03	1.4E-03	3.8E-04	2.1E-03	
Potential Emission in tons/yr	5.217E-05	1.148E-04	1.461E-04	3.965E-05	2.191E-04	5.718E-04
						Total HAPs
						1.969E-01
						Worst HAP
						1.878E-01

Methodology is the same as above.

The five highest organic and metal HAPs emission factors are provided above.

Additional HAPs emission factors are available in AP-42, Chapter 1.4.

**Appendix A: Emissions Calculations
Natural Gas Combustion Only
MM BTU/HR <100**

Company Name: Plumrose USA, Inc.
Address City IN Zip: 24402 County Road 45, Elkhart, IN 46516
Permit Number: R039-35017-00352
Plt ID: 039-00352
Reviewer: C. Sullivan
Date: 11/19/2014
NG- Heaters

Heat Input Capacity MMBtu/hr	HHV mmBtu mmscf	Potential Throughput MMCF/yr
0.44	1020	3.8

Emission Factor in lb/MMCF	Pollutant						
	PM*	PM10*	direct PM2.5*	SO2	NOx	VOC	CO
	1.9	7.6	7.6	0.6	100 **see below	5.5	84
Potential Emission in tons/yr	0.004	0.01	0.01	0.001	0.2	0.01	0.2

*PM emission factor is filterable PM only. PM10 emission factor is filterable and condensable PM10 combined.

PM2.5 emission factor is filterable and condensable PM2.5 combined.

**Emission Factors for NOx: Uncontrolled = 100, Low NOx Burner = 50, Low NOx Burners/Flue gas recirculation = 32

Methodology

All emission factors are based on normal firing.

MMBtu = 1,000,000 Btu

MMCF = 1,000,000 Cubic Feet of Gas

Emission Factors are from AP 42, Chapter 1.4, Tables 1.4-1, 1.4-2, 1.4-3, SCC #1-02-006-02, 1-01-006-02, 1-03-006-02, and 1-03-006-03

Potential Throughput (MMCF) = Heat Input Capacity (MMBtu/hr) x 8,760 hrs/yr x 1 MMCF/1,020 MMBtu

Emission (tons/yr) = Throughput (MMCF/yr) x Emission Factor (lb/MMCF)/2,000 lb/ton

HAPS Calculations

Emission Factor in lb/MMcf	HAPs - Organics					Total - Organics
	Benzene	Dichlorobenzene	Formaldehyde	Hexane	Toluene	
	2.1E-03	1.2E-03	7.5E-02	1.8E+00	3.4E-03	
Potential Emission in tons/yr	3.968E-06	2.267E-06	1.417E-04	3.401E-03	6.424E-06	3.555E-03

Emission Factor in lb/MMcf	HAPs - Metals					Total - Metals
	Lead	Cadmium	Chromium	Manganese	Nickel	
	5.0E-04	1.1E-03	1.4E-03	3.8E-04	2.1E-03	
Potential Emission in tons/yr	9.447E-07	2.078E-06	2.645E-06	7.180E-07	3.968E-06	1.035E-05
						Total HAPs
						3.566E-03
						Worst HAP
						3.401E-03

Methodology is the same as above.

The five highest organic and metal HAPs emission factors are provided above.

Additional HAPs emission factors are available in AP-42, Chapter 1.4.

**Appendix A: Emissions Calculations
Natural Gas Combustion Only
MM BTU/HR <100**

Company Name: Plumrose USA, Inc.
Address City IN Zip: 24402 County Road 45, Elkhart, IN 46516
Permit Number: R039-35017-00352
Plt ID: 039-00352
Reviewer: C. Sullivan
Date: 11/19/2014
NG - Smokehouses

Heat Input Capacity MMBtu/hr	HHV mmBtu mmscf	Potential Throughput MMCF/yr
10.95	1020	94.0

Emission Factor in lb/MMCF	Pollutant						
	PM*	PM10*	direct PM2.5*	SO2	NOx	VOC	CO
	1.9	7.6	7.6	0.6	100 **see below	5.5	84
Potential Emission in tons/yr	0.1	0.4	0.4	0.0	4.7	0.3	3.9

*PM emission factor is filterable PM only. PM10 emission factor is filterable and condensable PM10 combined.

PM2.5 emission factor is filterable and condensable PM2.5 combined.

**Emission Factors for NOx: Uncontrolled = 100, Low NOx Burner = 50, Low NOx Burners/Flue gas recirculation = 32

Methodology

All emission factors are based on normal firing.

MMBtu = 1,000,000 Btu

MMCF = 1,000,000 Cubic Feet of Gas

Emission Factors are from AP 42, Chapter 1.4, Tables 1.4-1, 1.4-2, 1.4-3, SCC #1-02-006-02, 1-01-006-02, 1-03-006-02, and 1-03-006-03

Potential Throughput (MMCF) = Heat Input Capacity (MMBtu/hr) x 8,760 hrs/yr x 1 MMCF/1,020 MMBtu

Emission (tons/yr) = Throughput (MMCF/yr) x Emission Factor (lb/MMCF)/2,000 lb/ton

HAPS Calculations

Emission Factor in lb/MMcf	HAPs - Organics					Total - Organics
	Benzene	Dichlorobenzene	Formaldehyde	Hexane	Toluene	
	2.1E-03	1.2E-03	7.5E-02	1.8E+00	3.4E-03	
Potential Emission in tons/yr	9.874E-05	5.642E-05	3.527E-03	8.464E-02	1.599E-04	8.848E-02

Emission Factor in lb/MMcf	HAPs - Metals					Total - Metals
	Lead	Cadmium	Chromium	Manganese	Nickel	
	5.0E-04	1.1E-03	1.4E-03	3.8E-04	2.1E-03	
Potential Emission in tons/yr	2.351E-05	5.172E-05	6.583E-05	1.787E-05	9.874E-05	2.577E-04
						Total HAPs
						8.874E-02
						Worst HAP
						8.464E-02

Methodology is the same as above.

The five highest organic and metal HAPs emission factors are provided above.

Additional HAPs emission factors are available in AP-42, Chapter 1.4.

**Appendix A: Emissions Calculations
Emissions from Pork Smoking
Wood and Liquid Smokehouses**

**Company Name: Plumrose USA, Inc.
Address City IN Zip: 24402 County Road 45, Elkhart, IN 46516
Permit Number: R039-35017-00352
Pit ID: 039-00352
Reviewer: C. Sullivan
Date: 11/19/2014**

Wood Smoke - Emission Factor Calculations												
		Wood Smoke Generator 1		Wood Smoke Generator 2		Wood Smoke Generator 3		Wood Smoke Generator 4		Wood Smoke Generator 5		
Pollutant	Emission Factor (lbs/ton) ¹	Throughput ² (lbs/hr)	Potential Emissions (tons/yr)	Totals								
PM	53	26	3.02	26	3.02	26	3.02	26	3.02	26	3.02	15.09
PM-10/PM-2.5	53	26	3.02	26	3.02	26	3.02	26	3.02	26	3.02	15.09
VOC	44	26	2.51	26	2.51	26	2.51	26	2.51	26	2.51	12.53
Formaldehyde	1.29	26	0.07	26	0.07	26	0.07	26	0.07	26	0.07	0.37
TOTAL HAPs												0.37

Methodology
 1- Emission factors for PM, PM-10 and VOC are from AP-42, Section 9.5.2. Emission factors for HAPs were based on information provided by source.
 2- Throughput (lb/hr) rates were based on information provided by source.
 Potential Emissions (tons/year) = Throughput (lbs/hr) * 8760 hr/year * (1 ton/2000 lbs) * EF (lb/ton) * (1 ton/2000 lb)

Liquid Smoke - Emission Factor Calculations					
Potential Emissions for Smokehouses					
Pollutant	Emission Factor (lbs/ton) ¹ of meat	Max Meat Throughput ² (tons/hr)	Max Meat Throughput (lbs/hr)	Potential Emissions (lbs/hr)	Total Emissions (tons/yr)
VOC	0.114	5	10000	0.57	2.50

Methodology
 1- Emission factor for VOC is from Red Arrow Products Company, Inc. (CharSol C-10) data provided by source.
 2- Throughput (tons/hr) is based on information provided by source.
 Max Meat Throughput (lbs/hr) = Throughput (tons/hr) * (1 ton/2000 lbs)
 PTE (tons/year) = Throughput (lbs/hr) * 8760 hr/year * (1 ton/2000 lbs) * EF (lb/ton) * (1 ton/2000 lb)

**Appendix A: Emissions Calculations
VOC and HAP
From Parts Degreasing Operation**

Company Name: Plumrose USA, Inc.
Address City IN Zip: 24402 County Road 45, Elkhart, IN 46516
Permit Number: R039-35017-00352
Plt ID: 039-00352
Reviewer: C. Sullivan
Date: 11/19/2014

Material	Gal of Mat. (gal/yr)	Density (lbs/gal)	Weight % VOC	VOC PTE (tons/yr)	Weight % Trichloroethylene	Trichloroethylene (tons/yr)
Degreaser Aerosol	145	12.04	98.00%	0.86	98.00%	0.86

Methodology:

VOC Emissions (tons/yr) = Gal. of Mat (gallon/yr) * Density of Solvent (lbs/gal) * Weight % VOC * 1 ton/2000 lbs

HAP Emissions (tons/yr) = Gal. of Mat (gallon/yr) * Density of Solvent (lbs/gal) * Weight % HAP * 1 ton/2000 lbs

**Appendix A: Emission Calculations
Fugitive Dust Emissions - Unpaved Roads**

Company Name: Plumrose USA, Inc.
Address City IN Zip: 24402 County Road 45, Elkhart, IN 46516
Permit Number: R039-35017-00352
Plt ID: 039-00352
Reviewer: C. Sullivan
Date: 11/19/2014

Unpaved Roads at Industrial Site

The following calculations determine the amount of emissions created by unpaved roads, based on 8,760 hours of use and AP-42, Ch 13.2.2 (11/2006).

Vehicle Information (provided by source)

Type	Maximum number of vehicles	Number of one-way trips per day per vehicle	Maximum trips per day (trip/day)	Maximum Weight Loaded (tons/trip)	Total Weight driven per day (ton/day)	Maximum one-way distance (feet/trip)	Maximum one-way distance (mi/trip)	Maximum one-way miles (miles/day)	Maximum one-way miles (miles/yr)
Vehicle (entering plant) (one-way trip)	15.0	1.0	15.0	40.0	600.0	471	0.089	1.3	487.9
Vehicle (leaving plant) (one-way trip)	15.0	1.0	15.0	40.0	600.0	471	0.089	1.3	487.9
Totals			30.0		1200.0			2.7	975.8

Average Vehicle Weight Per Trip =

40.0	tons/trip
------	-----------

Average Miles Per Trip =

0.09	miles/trip
------	------------

Unmitigated Emission Factor, $E_f = k[(s/12)^a][(W/3)^b]$ (Equation 1a from AP-42 13.2.2)

	PM	PM10	PM2.5	
where k =	4.9	1.5	0.15	lb/mi = particle size multiplier (AP-42 Table 13.2.2-2 for Industrial Roads)
s =	6.0	6.0	6.0	% = mean % silt content of unpaved roads (AP-42 Table 13.2.2-1 Iron and Steel Production)
a =	0.7	0.9	0.9	= constant (AP-42 Table 13.2.2-2 for Industrial Roads)
W =	40.0	40.0	40.0	tons = average vehicle weight (provided by source)
b =	0.45	0.45	0.45	= constant (AP-42 Table 13.2.2-2 for Industrial Roads)

Taking natural mitigation due to precipitation into consideration, Mitigated Emission Factor, $E_{ext} = E * [(365 - P)/365]$ (Equation 2 from AP-42 13.2.2)

Mitigated Emission Factor, $E_{ext} = E * [(365 - P)/365]$
where P =

125	days of rain greater than or equal to 0.01 inches (see Fig. 13.2.2-1)
-----	---

	PM	PM10	PM2.5	
Unmitigated Emission Factor, $E_f =$	9.68	2.58	0.26	lb/mile
Mitigated Emission Factor, $E_{ext} =$	6.36	1.70	0.17	lb/mile

Process	Unmitigated PTE of PM (tons/yr)	Unmitigated PTE of PM10 (tons/yr)	Unmitigated PTE of PM2.5 (tons/yr)	Mitigated PTE of PM (tons/yr)	Mitigated PTE of PM10 (tons/yr)	Mitigated PTE of PM2.5 (tons/yr)
Vehicle (entering plant) (one-way trip)	2.36	0.63	0.06	1.55	0.73	0.04
Vehicle (leaving plant) (one-way trip)	2.36	0.63	0.06	1.55	0.41	0.04
Totals	4.72	1.26	0.13	3.10	1.14	0.08

Methodology

- Total Weight driven per day (ton/day) = [Maximum Weight Loaded (tons/trip)] * [Maximum trips per day (trip/day)]
- Maximum one-way distance (mi/trip) = [Maximum one-way distance (feet/trip)] / [5280 ft/mile]
- Maximum one-way miles (miles/day) = [Maximum trips per year (trip/day)] * [Maximum one-way distance (mi/trip)]
- Average Vehicle Weight Per Trip (ton/trip) = SUM[Total Weight driven per day (ton/day)] / SUM[Maximum trips per day (trip/day)]
- Average Miles Per Trip (miles/trip) = SUM[Maximum one-way miles (miles/day)] / SUM[Maximum trips per year (trip/day)]
- Unmitigated PTE (tons/yr) = (Maximum one-way miles (miles/yr)) * (Unmitigated Emission Factor (lb/mile)) * (ton/2000 lbs)
- Mitigated PTE (tons/yr) = (Maximum one-way miles (miles/yr)) * (Mitigated Emission Factor (lb/mile)) * (ton/2000 lbs)
- Controlled PTE (tons/yr) = (Mitigated PTE (tons/yr)) * (1 - Dust Control Efficiency)

Abbreviations

- PM = Particulate Matter
- PM10 = Particulate Matter (<10 um)
- PM2.5 = Particulate Matter (<2.5 um)
- PTE = Potential to Emit

**Appendix A: Emission Calculations
Fugitive Dust Emissions - Paved Roads**

Company Name: Plumrose USA, Inc.
Address City IN Zip: 24402 County Road 45, Elkhart, IN 46516
Permit Number: R039-35017-00352
Plt ID: 039-00352
Reviewer: C. Sullivan
Date: 11/19/2014

Paved Roads at Industrial Site

The following calculations determine the amount of emissions created by paved roads, based on 8,760 hours of use and AP-42, Ch 13.2.1 (1/2011).

Vehicle Information (provided by source)

Type	Maximum number of vehicles per day	Number of one-way trips per day per vehicle	Maximum trips per day (trip/day)	Maximum Weight Loaded (tons/trip)	Weight driven per day (ton/day)	Maximum one-way distance (feet/trip)	Maximum one-way distance (mi/trip)	Maximum one-way miles (miles/day)	Maximum one-way miles (miles/yr)
Vehicle (entering plant) (one-way trip)	36.0	1.0	36.0	40.0	1440.0	569	0.108	3.9	1416.0
Vehicle (leaving plant) (one-way trip)	36.0	1.0	36.0	40.0	1440.0	569	0.108	3.9	1416.0
Totals			72.0		2880.0			7.8	2832.1

Average Vehicle Weight Per Trip =

40.0	tons/trip
------	-----------

Average Miles Per Trip =

0.11	miles/trip
------	------------

Unmitigated Emission Factor, Ef = $[k * (sL)^{0.91} * (W)^{1.02}]$ (Equation 1 from AP-42 13.2.1)

where k =	PM	PM10	PM2.5	lb/VMT = particle size multiplier (AP-42 Table 13.2.1-1)
W =	0.011	0.0022	0.00054	tons = average vehicle weight (provided by source)
sL =	40.0	40.0	40.0	g/m ² = silt loading value for paved roads at iron and steel production facilities - Table 13.2.1-
	9.7	9.7	9.7	

Taking natural mitigation due to precipitation into consideration, Mitigated Emission Factor, Eext = $E * [1 - (p/4N)]$ (Equation 2 from AP-42 13.2.1)

Mitigated Emission Factor, Eext = $Ef * [1 - (p/4N)]$
where p =

125	days of rain greater than or equal to 0.01 inches (see Fig. 13.2.1-2)
-----	---

N =

365	days per year
-----	---------------

Unmitigated Emission Factor, Ef =	PM	PM10	PM2.5	lb/mile
Mitigated Emission Factor, Eext =	3.745	0.749	0.1838	lb/mile
	3.424	0.685	0.1681	lb/mile

Process	Unmitigated PTE of PM (tons/yr)	Unmitigated PTE of PM10 (tons/yr)	Unmitigated PTE of PM2.5 (tons/yr)	Mitigated PTE of PM (tons/yr)	Mitigated PTE of PM10 (tons/yr)	Mitigated PTE of PM2.5 (tons/yr)
Vehicle (entering plant) (one-way trip)	2.65	0.53	0.13	2.42	0.48	0.12
Vehicle (leaving plant) (one-way trip)	2.65	0.53	0.13	2.42	0.48	0.12
Totals	5.30	1.06	0.26	4.85	0.97	0.24

Methodology

Total Weight driven per day (ton/day) = [Maximum Weight Loaded (tons/trip)] * [Maximum trips per day (trip/day)]
Maximum one-way distance (mi/trip) = [Maximum one-way distance (feet/trip) / 5280 ft/mile]
Maximum one-way miles (miles/day) = [Maximum trips per year (trip/day)] * [Maximum one-way distance (mi/trip)]
Average Vehicle Weight Per Trip (ton/trip) = SUM[Total Weight driven per day (ton/day)] / SUM[Maximum trips per day (trip/day)]
Average Miles Per Trip (miles/trip) = SUM[Maximum one-way miles (miles/day)] / SUM[Maximum trips per year (trip/day)]
Unmitigated PTE (tons/yr) = [Maximum one-way miles (miles/yr)] * [Unmitigated Emission Factor (lb/mile)] * (ton/2000 lbs)
Mitigated PTE (tons/yr) = [Maximum one-way miles (miles/yr)] * [Mitigated Emission Factor (lb/mile)] * (ton/2000 lbs)
Controlled PTE (tons/yr) = [Mitigated PTE (tons/yr)] * [1 - Dust Control Efficiency]

Abbreviations

PM = Particulate Matter
PM10 = Particulate Matter (<10 um)
PM2.5 = Particle Matter (<2.5 um)
PTE = Potential to Emit



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

100 N. Senate Avenue • Indianapolis, IN 46204
(800) 451-6027 • (317) 232-8603 • www.idem.IN.gov

Michael R. Pence
Governor

Thomas W. Easterly
Commissioner

SENT VIA U.S. MAIL: CONFIRMED DELIVERY AND SIGNATURE REQUESTED

TO: Terry Pletcher
Plumrose USA, Inc.
PO Box 160
Elkhart, IN 46516-6043

DATE: February 27, 2015

FROM: Matt Stuckey, Branch Chief
Permits Branch
Office of Air Quality

SUBJECT: Final Decision
Registration
039-35017-00352

Enclosed is the final decision and supporting materials for the air permit application referenced above. Please note that this packet contains the original, signed, permit documents.

The final decision is being sent to you because our records indicate that you are the contact person for this application. However, if you are not the appropriate person within your company to receive this document, please forward it to the correct person.

A copy of the final decision and supporting materials has also been sent via standard mail to:
OAQ Permits Branch Interested Parties List

If you have technical questions regarding the enclosed documents, please contact the Office of Air Quality, Permits Branch at (317) 233-0178, or toll-free at 1-800-451-6027 (ext. 3-0178), and ask to speak to the permit reviewer who prepared the permit. If you think you have received this document in error, please contact Joanne Smiddie-Brush of my staff at 1-800-451-6027 (ext 3-0185), or via e-mail at jbrush@idem.IN.gov.

Final Applicant Cover letter.dot 6/13/2013

Mail Code 61-53

IDEM Staff	CDENNY 2/27/2015 Plumrose USA, Inc. 039-35017-00352 (final)		Type of Mail: CERTIFICATE OF MAILING ONLY	AFFIX STAMP HERE IF USED AS CERTIFICATE OF MAILING
Name and address of Sender		Indiana Department of Environmental Management Office of Air Quality – Permits Branch 100 N. Senate Indianapolis, IN 46204		

Line	Article Number	Name, Address, Street and Post Office Address	Postage	Handing Charges	Act. Value (If Registered)	Insured Value	Due Send if COD	R.R. Fee	S.D. Fee	S.H. Fee	Rest. Del. Fee	Remarks
1		Terry Pletcher Plumrose USA, Inc. PO Box 160 Elkhart IN 46516-6043 (Source CAATS) VIA USPS CERTIFIED MAIL										
2		Rob Wilfert Plant Mgr Plumrose USA, Inc. PO Box 160 Elkhart IN 46516-6043 (RO CAATS)										
3		Elkhart City Council and Mayors Office 229 South Second Street Elkhart IN 46516 (Local Official)										
4		Elkhart County Health Department 608 Oakland Avenue Elkhart IN 46516 (Health Department)										
5		Elkhart County Board of Commissioners 117 North Second St. Goshen IN 46526 (Local Official)										
6		Jody Lindsey Environmental Compliance Services, Inc. PO Box 356 Sherman MS 33869 (Consultant)										
7												
8												
9												
10												
11												
12												
13												
14												
15												

Total number of pieces Listed by Sender	Total number of Pieces Received at Post Office	Postmaster, Per (Name of Receiving employee)	The full declaration of value is required on all domestic and international registered mail. The maximum indemnity payable for the reconstruction of nonnegotiable documents under Express Mail document reconstructing insurance is \$50,000 per piece subject to a limit of \$50, 000 per occurrence. The maximum indemnity payable on Express mil merchandise insurance is \$500. The maximum indemnity payable is \$25,000 for registered mail, sent with optional postal insurance. See Domestic Mail Manual R900, S913, and S921 for limitations of coverage on inured and COD mail. See International Mail Manual for limitations o coverage on international mail. Special handling charges apply only to Standard Mail (A) and Standard Mail (B) parcels.
5			